

## EQUITY BACKUP CALL-OUT REPORT

9<sup>th</sup> DECEMBER 2024

### 1. Site Details

Site: Equity Bank Migori Branch

Region: Migori county

Contact: Evans Omenya - 0720976228

### 2. Equipment on Site on arrival

Equipment	Quantity	Serial Number	Equity Tag Number	Status
Growatt 5kVA SPF5000 Inverter	3	JZM2DAM0RY	EQ385702	Okay
		JZM2DAN0QC	EQ385703	Okay
		JZM2DAM0PE	EQ385704	Okay
Monitoring dongle	3	DDD0CHD0QE	N/A	Okay
		DDD0CHD0K6		Okay
		DDD0CHD0UZ		Okay
Megatank 5kWh battery	2	GL48100D7210202RL	N/A	Okay
		GL48100D7210137RL		Okay

### 3. Job Description

Check why the power backup was not providing backup during a KPLC outage.

### 4. Actions Taken

- On arrival, the backup system was ON with loads on KPLC.
- One inverter had no output supply to the loads.
- Checked the batteries, both are fully charged with voltages of 55V.
- Restarted the system by turning all inverters and batteries OFF and turning them ON. The system was back to normal operation mode.
- Set the b2ac to 95% and ac2b to 100%, to ensure the batteries are always full.
- Switched the ATS to inverter mode and the power backup system was able to support the loads during power loss simulation.

### 5. Photos



Figure 1: Host inverter on line mode



Figure 2: Slave 2 inverter having no output supply to the loads



Figure 3: Slave 1 inverter on



Figure 4: ATS on KPLC mode



Figure 5: Host inverter on normal operation



Figure 6: Slave 1 inverter on normal operation



Figure 7: Slave 2 inverter on normal operation



Figure 8: ATS on inverter mode



Figure 9: AVS in normal operation

## **6. Recommendations**

There's an issue with KPLC supply since the generator has to be turned on for the inverters to turn on and batteries to start charging. This can be resolved by making a follow up with KPLC on the power supply issue