

# API Specification for Fire Test for End Connections

API SPECIFICATION 6FB  
THIRD EDITION, MAY 1998

EFFECTIVE DATE: NOVEMBER 30, 1998



**Helping You  
Get The Job  
Done Right.<sup>SM</sup>**



## **API ENVIRONMENTAL, HEALTH AND SAFETY MISSION AND GUIDING PRINCIPLES**

The members of the American Petroleum Institute are dedicated to continuous efforts to improve the compatibility of our operations with the environment while economically developing energy resources and supplying high quality products and services to consumers. We recognize our responsibility to work with the public, the government, and others to develop and to use natural resources in an environmentally sound manner while protecting the health and safety of our employees and the public. To meet these responsibilities, API members pledge to manage our businesses according to the following principles using sound science to prioritize risks and to implement cost-effective management practices:

- To recognize and to respond to community concerns about our raw materials, products and operations.
- To operate our plants and facilities, and to handle our raw materials and products in a manner that protects the environment, and the safety and health of our employees and the public.
- To make safety, health and environmental considerations a priority in our planning, and our development of new products and processes.
- To advise promptly, appropriate officials, employees, customers and the public of information on significant industry-related safety, health and environmental hazards, and to recommend protective measures.
- To counsel customers, transporters and others in the safe use, transportation and disposal of our raw materials, products and waste materials.
- To economically develop and produce natural resources and to conserve those resources by using energy efficiently.
- To extend knowledge by conducting or supporting research on the safety, health and environmental effects of our raw materials, products, processes and waste materials.
- To commit to reduce overall emissions and waste generation.
- To work with others to resolve problems created by handling and disposal of hazardous substances from our operations.
- To participate with government and others in creating responsible laws, regulations and standards to safeguard the community, workplace and environment.
- To promote these principles and practices by sharing experiences and offering assistance to others who produce, handle, use, transport or dispose of similar raw materials, petroleum products and wastes.

# **API Specification for Fire Test for End Connections**

**Exploration and Production Department**

API SPECIFICATION 6FB  
THIRD EDITION, MAY 1998

EFFECTIVE DATE: NOVEMBER 30, 1998



**American  
Petroleum  
Institute**

**Helping You  
Get The Job  
Done Right.<sup>SM</sup>**

## SPECIAL NOTES

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations under local, state, or federal laws.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet.

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. Sometimes a one-time extension of up to two years will be added to this review cycle. This publication will no longer be in effect five years after its publication date as an operative API standard or, where an extension has been granted, upon republication. Status of the publication can be ascertained from the API Exploration and Production Department [telephone (202) 682-8000]. A catalog of API publications and materials is published annually and updated quarterly by API, 1220 L Street, N.W., Washington, D.C. 20005.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this standard or comments and questions concerning the procedures under which this standard was developed should be directed in writing to the director of the Exploration and Production Department (shown on the title page of this document), American Petroleum Institute, 1220 L Street, N.W., Washington, D.C. 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

API standards are published to facilitate the broad availability of proven, sound engineering and operating practices. These standards are not intended to obviate the need for applying sound engineering judgment regarding when and where these standards should be utilized. The formulation and publication of API standards is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

*All rights reserved. No part of this work may be reproduced, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, N.W., Washington, D.C. 20005.*

Copyright © 1998 American Petroleum Institute

## FOREWORD

This specification is under the jurisdiction of the API Subcommittee on Standardization of Valves and Wellhead Equipment. This Third Edition is a reformatted, reissue of the Second Edition of this specification, which was reaffirmed by letter ballot in 1997.

This specification shall become effective on the date printed on the cover but may be used voluntarily from the date of distribution.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any federal, state, or municipal regulation with which this publication may conflict.

Suggested revisions are invited and should be submitted to the director of the Exploration and Production Department, American Petroleum Institute, 1220 L Street, N.W., Washington, D.C. 20005.

## **IMPORTANT INFORMATION CONCERNING USE OF ASBESTOS OR ALTERNATIVE MATERIALS**

Asbestos is specified or referenced for certain components of the equipment described in some API standards. It has been of extreme usefulness in minimizing fire hazards associated with petroleum processing. It has also been a universal sealing material, compatible with most refining fluid services.

Certain serious adverse health effects are associated with asbestos, among them the serious and often fatal diseases of lung cancer, asbestosis, and mesothelioma (a cancer of the chest and abdominal linings). The degree of exposure to asbestos varies with the product and the work practices involved.

Consult the most recent edition of the Occupational Safety and Health Administration (OSHA), U.S. Department of Labor, Occupational Safety and Health Standard for Asbestos, Tremolite, Anthophyllite, and Actinolite, 29 *Code of Federal Regulations* Section 1910.1001; the U.S. Environmental Protection Agency, National Emission Standard for Asbestos, 40 *Code of Federal Regulations* Sections 61.140 through 61.156; and the U.S. Environmental Protection Agency (EPA) rule on labeling requirements and phased banning of asbestos products (Sections 763.160-179).

There are currently in use and under development a number of substitute materials to replace asbestos in certain applications. Manufacturers and users are encouraged to develop and use effective substitute materials that can meet the specifications for, and operating requirements of, the equipment to which they would apply.

SAFETY AND HEALTH INFORMATION WITH RESPECT TO PARTICULAR PRODUCTS OR MATERIALS CAN BE OBTAINED FROM THE EMPLOYER, THE MANUFACTURER OR SUPPLIER OF THAT PRODUCT OR MATERIAL, OR THE MATERIAL SAFETY DATA SHEET.

# CONTENTS

	Page
1 SCOPE.....	1
1.1 Purpose.....	1
1.2 Applications.....	1
2 REFERENCED STANDARDS .....	1
3 PART I—FIRE TEST FOR END CONNECTIONS FOR ONSHORE LOCATIONS .....	1
3.1 General.....	1
3.2 Test Procedure .....	2
3.3 Performance Requirements .....	3
3.4 Safety Considerations .....	3
4 PART II—FIRE TEST FOR END CONNECTIONS FOR OFFSHORE WELL BAY CONDITIONS.....	3
4.1 General.....	3
4.2 Test Procedure .....	4
4.3 Performance Requirements .....	4
4.4 Safety Considerations .....	5
5 EQUIPMENT MARKING .....	5
5.1 Marking Requirements .....	5
6 QUALIFICATION BY SCALING.....	5
6.1 Scaling .....	5
6.2 Connection Family.....	5
6.3 Limitations of Scaling .....	5
APPENDIX A—FIGURES .....	7
Figures	
A-1 Schematic of Suggested Systems for Fire Testing of End Connections .....	9
A-2 Location of Thermocouples and Calorimeters—Onshore Conditions.....	10
A-3 Location of Burner, Calorimeter, and Thermocouple—Offshore Well Bay Conditions .....	10
A-4 Calorimeter Cube Design Details .....	11
A-5 Typical Bend Test Arrangement With One Ram Cylinder.....	12
A-6 Typical Bend Test Arrangement With Two Ram Cylinders.....	12
A-7 Schematic of Suggested Leak Measurement System.....	13
A-8 Location of Thermocouples and Calorimeters for Bending Tests—Onshore Conditions .....	14
A-9 Location of Burner, Calorimeter, and Thermocouples for Bending Tests—Offshore Well Bay Conditions.....	14
Tables	
1 Test Pressure .....	2





# API Specification for Fire Test for End Connections

## 1 Scope

### 1.1 PURPOSE

This specification was formulated to establish procedures for testing and evaluating the pressure-containing performance of API end connections when exposed to fire. Valves, wellhead seals, or other related equipment, are not included in the scope of this document. The procedures are presented in two parts.

Part I represents conditions in an onshore or open offshore location.

Part II represents conditions in an offshore platform well bay.

Background information on fire-resistance of API end connections is contained in API Bulletin 6F1. Further background on fire-resistance improvements of API flanges is contained in API Bulletin 6F2.

### 1.2 APPLICATIONS

This specification covers API Spec 6A end connections, which include:

- a. API Flanged End and Outlet Connections (6B, 6BX, and Segmented).
- b. API Threaded End and Outlet Connections.
- c. Other End Connections (OECs).

## 2 Referenced Standards

This specification includes by reference, either in whole or in part, other API standards, as listed below:

### API

Spec 6A	<i>Specification for Wellhead and Christmas Tree Equipment</i>
Bull 6AF	<i>Bulletin on Capabilities of API Flanges under Combinations of Load</i>
Bull 6F1	<i>Performance of API and ANSI End Connections in a Fire Test According to API Spec 6FA</i>
Bull 6F2	<i>Fire Resistance Improvements for API Flanges</i>

## 3 Part I—Fire Test for End Connections for Onshore Locations

### 3.1 GENERAL

#### 3.1.1 Scope

It is the purpose of this part to establish a procedure for testing and evaluating the pressure-containing performance of API 6A end connections when exposed to a fire representing conditions in an onshore or open offshore location. The per-

formance requirements of this part are intended to establish standard limits of acceptability regardless of size or pressure rating. This part is not intended to represent conditions which may be encountered in a fire in an offshore well bay.

The burn period has been established on the basis that it represents the maximum time required to extinguish most fires. Fires of greater duration are considered to be of a major magnitude with consequences greater than those anticipated by this test.

#### 3.1.2 Description of Fire Test (See Figure A-1)

**3.1.2.1** The connection shall be tested with water. The total volume of water which is isolated in the test fixture shall not exceed the volume of a cylinder whose diameter is the nominal test connection size and whose length is twice the nominal test connection size. The orientation of the axis of the bore may be vertical or horizontal. To qualify a connection design for bending as well as pressure, a second test is required.

**3.1.2.2** Each connection shall be enveloped in flame and temperature measurements made by thermocouples and calorimeters. The test setup shall include a minimum of three calorimeter blocks and thermocouples equally spaced around the circumference in the plane of the joint, as shown in Figure A-2. The maximum spacing between calorimeters shall be 12 inches (300 mm) on the circumference. An additional calorimeter block and thermocouple shall be placed on each side of the joint, at a distance of  $3/2$  of the length of the flange or twice the bore diameter, whichever is greatest, at a circumferential location which is furthest from any burner.

The calorimeter blocks shall be  $1\frac{1}{2}$  inch (38 mm) cubes made of carbon steel with a thermocouple located in the center of each cube, as shown in Figure A-4.

**3.1.2.3** The test pressure shall be 75% of the API rated working pressure.

**3.1.2.4** The burn period shall be at least 30 minutes from ignition. Detailed procedures are in Section 3.2.

#### 3.1.3 Description of the Bending Test

After 25 minutes of the burn period, an external bending moment shall be applied to one test connection. The moment which is sustained without causing leakage greater than the acceptable level shall be noted and reported. This will terminate testing on this connection.

Figures A-5 and A-6 show two suggested means of applying the bending moment. In using an arrangement like Figure A-5, the hydraulic ram will produce both a tension and a bending moment on the connection. The ram shall be sized so that the additional tension is not greater than 10% of the

total pressure end load through the connection. Any fixtures used to apply bending moment shall be designed to safely carry the test loads and shall be designed not to shield the connection from the flame.

### 3.1.4 Leakage Measurements

Leakage of the test connection is to be positively collected and measured by means of a system as shown in Figure A-7. The connection shall be provided with a secondary seal outside the main seal made of a high temperature material such as graphite or metal foil gasketing material. Two leakoff ports shall be drilled from the exterior of the connection to the region between primary and secondary seals, forming a closed chamber. The two connections shall be made on opposite sides of the test connection.

Two equal-length pieces of tubing shall be connected to the leakoff ports, and a third equal length of tubing shall be blanked off and mounted on the test vehicle similarly to the other two. This third dummy line will be used to compensate for expansion of air in the leakoff lines.

Each of the three lines shall pass in succession through a condenser, fluid trap and gas trap and shall terminate in a graduated cylinder for leakage measurements, as shown schematically in Figure A-7, if nitrogen gas is to be used to replace water in the valvebore, as provided for in 3.2.1j. If water is to be used throughout the test, the fluid and gas traps may be deleted and the discharge from the condensers connected directly to the graduated cylinder. The dummy line may also be deleted.

Leakage is calculated by adding the volumes accumulated from the two leakoff lines and subtracting twice the volume accumulated from the dummy line.

For the test with bending, the onset of leakage, as detected by a sustained loss of 200°F (93°C) or more in the indicated temperature of one or more thermocouples arrayed as shown in Figure A-8 may be used to indicate the bending moment which cannot be sustained without leakage, in lieu of the leakoff system described above.

## 3.2 TEST PROCEDURE

### 3.2.1 Stepwise Procedures (Item Numbers Refer to Figure A-1)

- a. Pressure test the leakoff lines shown in Figure A-7 to 5 psig (0.034 MPa) minimum to ensure that the secondary seals are effective.
- b. Purge the leakoff lines with dry nitrogen to verify communication and freedom from obstructions.
- c. Open valve(s) (Items 5 and 6) at water source, and any necessary vent valves (Items 15 and 16) to flood the system and purge the air.
- d. Close fill valve (Item 5) and close vent valves (Items 15 and 16). The system shall be completely water-filled.

e. Pressurize the system to the appropriate test pressure from Table 1. Maintain this pressure during the burn and cool-down periods. Momentary pressure losses are permissible, provided their cumulative recovery time is less than 2 minutes, and any resulting leakage is within the acceptance criteria.

f. Open the fuel supply, establish a fire and monitor the flame temperature. The average of the thermocouples (Item 14) must reach 1400°F (761°C) within 2 minutes. Maintain the average temperature between 1400 and 1800°F (761 and 980°C), with no reading less than 1300°F (704°C), until the average calorimeter temperature reaches 1200°F (650°C) per 3.2.1g. After that point, the flame temperature may be adjusted to any level as required to maintain the calorimeter temperatures per 3.2.1g.

g. The average temperature of the calorimeters (Item 13) shall reach at least 1200°F (650°C) within 15 minutes of fire ignition. For the remainder of the burn period, the calorimeters shall maintain a minimum average temperature of 1200°F (650°C), and no reading shall be below 1050°F (565°C).

h. Record instrument readings (Items 7, 13, and 14) at least every 30 seconds during the burn period.

i. At the end of the burn period, shut off the fuel.

j. Air cool the connection (or allow to cool) to 212°F (100°C) or less. Nitrogen may be used to maintain the pressure in the test connection during this time.

k. Depressurize the connection.

l. Increase pressure on the test connection to the test pressure in Table 1.

m. Hold the test pressure for 5 minutes minimum.

n. If the connection is to be tested in bending, repeat steps a through h for the unit to be tested in bending.

o. After 25 minutes of the burn period, begin the application of the bending moment to the connection being tested in bending.

p. As each bending moment increment is applied, pause for at least 15 seconds, record the moment, and observe for a total leakage volume in excess of the total leakage permitted in the test, or for the onset of leakage, if the thermocouple array of Figures A-8 or A-9 is used.

q. Record the maximum bending moment which is sustained without causing the total leakage to exceed the maximum allowable.

r. Record the duration of the burn and extinguish the flames. The connection may be depressurized at this time.

Table 1—Test Pressure

	Connection Rating		Test Pressure $\pm$ 10%	
	psig	(MPa)	psig	(MPa)
API Spec 6A Connections	2000	(13.8)	1500	(10.3)
	3000	(20.7)	2250	(15.5)
	5000	(34.5)	3750	(25.9)
	10000	(69.0)	7500	(51.7)
	15000	(103.5)	11250	(77.6)
	20000	(138.0)	15000	(103.5)

### 3.2.2 Test Adjustments

The test system, excluding the test connection itself, may be adjusted during the test period to keep the test within the limits specified herein.

## 3.3 PERFORMANCE REQUIREMENTS

### 3.3.1 Acceptance Criteria

#### 3.3.1.1 Non-Bending Tests

The allowable leakage rate, as determined by the leakoff system shown in Figure A-7, is 1 ml/mm per inch of mean primary gasket circumference during the burn and cooldown periods, and during the 5-minute period after depressurization and repressurization.

#### 3.3.1.2 Tests With Bending

- a. With Leakoff System: The allowable leakage rate, as determined by the leakoff system shown in Figure A-7, is 1 ml/mm per inch of mean primary gasket circumference during the unloaded portion of the burn, and at each applied increment of bending moment.
- b. With Thermocouple Array: The allowable leakage rate, as determined by the thermocouple array shown in Figure A-8, is that which results in a sustained drop of less than 200°F (93°C) in the indicated temperature of any of the thermocouples in the array during the unloaded portion of the burn, and at each applied increment of bending moment.
- c. Bending Moment Criterion: The applied bending moment achieved without exceeding the allowable leakage rate shall be at least 75% of the end connection capacity, as determined either from the API Bull 6AF values or from the manufacturer's documented design values.

## 3.4 SAFETY CONSIDERATIONS

### 3.4.1 Personnel Protection

Because of the possible design of the test connection and the nature of the test program, the potential may exist for a hazardous rupture of the pressure boundary components. Protection for test personnel shall be provided.

## 4 Part II—Fire Test for End Connections for Offshore Well Bay Conditions

### 4.1 GENERAL

#### 4.1.1 Scope

It is the purpose of this part to establish a procedure for testing and evaluating the pressure-containing performance of API 6A end connections when exposed to a fire representing conditions in an offshore platform well bay. The performance requirements of this part are intended to establish standard limits of acceptability regardless of size or pressure rating.

This part is not intended to represent conditions which may be encountered in a fire on a land or open offshore location.

The burn period has been established on the basis that it represents the maximum time required to extinguish most fires. Fires of greater duration are considered to be of a major magnitude with consequences greater than those anticipated by this test.

#### 4.1.2 Description of Fire Test (See Figure A-1)

**4.1.2.1** The connection shall be tested with water. The total volume of water which is isolated in the test fixture shall not exceed the volume of a cylinder whose diameter is the nominal test connection size and whose length is twice the nominal test connection size. The orientation of the axis of the bore may be vertical or horizontal. In order to qualify a connection design for bending as well as pressure a second test is required.

**4.1.2.2** Each connection shall be exposed to a flame from one burner directed at the centerline of the flange as shown in Figure A-3. The test setup shall include a 1½ inch (38 mm) cube calorimeter block made of carbon steel with a thermocouple located in the center of the block, as illustrated in Figure 4, and a flame temperature thermocouple.

**4.1.2.3** The test pressure shall be 75% of the API rated working pressure.

**4.1.2.4** The burn period shall be at least 30 minutes from ignition. Detailed procedures are in Section 4.2.

#### 4.1.3 Description of the Bending Test

After 25 minutes of the burn period, an external bending moment shall be applied to one test connection. The moment which is sustained without causing leakage greater than the acceptable level shall be noted and reported. This will terminate testing on this connection.

Figures A-5 and A-6 show two suggested means of applying the bending moment. In using an arrangement like Figure A-5, the hydraulic ram will produce both a tension and a bending moment on the connection. The ram shall be sized so that the additional tension is not greater than 10% of the total pressure end load through the connection. Any fixtures used to apply bending moment shall be designed to safely carry the test loads and shall be designed not to shield the connection from the flame. The highest temperature flame shall be applied to the tension side of the connection in bending.

#### 4.1.4 Leakage Measurements

Leakage of the test connection is to be positively collected and measured by means of a system as shown in Figure A-7. The connection shall be provided with a secondary seal outside the main seal made of a high temperature material, such as graphite or metal foil gasketing material. Two leakoff ports shall be drilled from the exterior of the connection to the

region between the primary and secondary seals, forming a closed chamber. The two connections shall be made on opposite sides of the test connection.

Two equal-length pieces of tubing shall be connected to the leakoff ports, and a third equal length of tubing shall be blanked off and mounted on the test vehicle similarly to the other two. This third dummy line will be used to compensate for expansion of air in the leakoff lines.

Each of the three lines shall pass in succession through a condenser, fluid trap, and gas trap, and shall terminate in a graduated cylinder for leakage measurements, as shown schematically in Figure A-7, if nitrogen gas is to be used to replace water in the valvebore, as provided for in 4.2.1j. If water is to be used throughout the test, the fluid and gas traps may be deleted and the discharge from the condensers connected directly to the graduated cylinder. The dummy line may also be deleted.

Leakage is calculated by adding the volumes accumulated from the two leakoff lines, and subtracting twice the volume accumulated from the dummy line.

For the test with bending, the onset of leakage, as detected by a sustained loss of 200°F (93°C) or more in the indicated temperature of one or more thermocouples arrayed as shown in Figure A-9 may be used to indicate the bending moment which cannot be sustained without leakage, in lieu of the leakoff system described above.

## 4.2 TEST PROCEDURE

### 4.2.1 Stepwise Procedures (Item Numbers Refer to Figure A-1)

- a. Pressure test the leakoff lines shown in Figure A-7 to 5 psig (0.034 MPa) minimum to ensure that the secondary seals are effective.
- b. Purge the leakoff lines with dry nitrogen to verify communication and freedom from obstructions.
- c. Open valve(s) (Items 5 and 6) at water source, and any necessary vent valves (Items 15 and 16) to flood the system and purge the air.
- d. Close fill valve (Item 5) and close vent valves (Items 15 and 16). The system shall be completely water-filled.
- e. Pressurize the system to the appropriate test pressure from Table 1. Maintain this pressure during the burn and cool-down periods. Momentary pressure losses are permissible, provided their cumulative recovery time is less than 2 minutes, and any resulting leakage is within the acceptance criteria.
- f. Open the fuel supply, establish a fire and monitor the flame temperature. The flame thermocouple (Item 14) must reach 2000°F (1093°C) within two minutes. Maintain the temperature between 2000 and 2500°F (1093 and 1371°C), with no reading below 1800°F (982°C) until the calorimeter temperature reaches 1800°F (982°C) per 4.2.1g. After that point, the flame temperature may be adjusted to any level as required to maintain the calorimeter temperature per 4.2.1g.

g. The temperature of the calorimeter (Item 13) shall reach at least 1800°F (982°C) within 15 minutes of fire ignition. For the remainder of the burn period, the calorimeter shall maintain a minimum temperature of 1800°F (982°C).

h. Record instrument readings (Items 7, 13, and 14) at least every 30 seconds during the burn period.

i. At the end of the burn period, shut off the fuel.

j. Air cool the connection (or allow to cool) to 212°F (100°C) or less. Nitrogen may be used to maintain the pressure in the test connection during this time.

k. Depressurize the connection.

l. Increase pressure on the test connection to the test pressure in Table 1.

m. Hold the test pressure for 5 minutes minimum.

n. If the connection is to be tested in bending, repeat steps a through h for the unit to be tested in bending.

o. After 25 minutes of the burn period, begin the application of the bending moment to the connection being tested in bending.

p. As each bending moment increment is applied, pause for at least 15 seconds, record the moment, and observe for a total leakage volume in excess of the total leakage permitted in the test, or for the onset of leakage, if the thermocouple array of Figures A-8 or A-9 is used.

q. Record the maximum bending moment which is sustained without causing the total leakage to exceed the maximum allowable.

r. Record the duration of the burn and extinguish the flames. The connection may be depressurized at this time.

### 4.2.2 Test Adjustments

The test system, excluding the test connection itself, may be adjusted during the test period to keep the test within the limits specified herein.

## 4.3 PERFORMANCE REQUIREMENTS

### 4.3.1 Acceptance Criteria

#### 4.3.1.1 Non-Bending Tests

The allowable leakage rate, as determined by the leakoff system shown in Figure A-7, is 1 ml/mm per inch of mean primary gasket circumference during the burn and cooldown periods, and during the 5-minute period after depressurization and repressurization.

#### 4.3.1.2 Tests With Bending

a. With Leakoff System: The allowable leakage rate, as determined by the leakoff system shown in Figure A-7, is 1 ml/mm per inch of mean primary gasket circumference during the unloaded portion of the burn, and at each applied increment of bending moment.

b. With Thermocouple Array: The allowable leakage rate, as determined by the thermocouple array shown in Figure A-8,

is that which results in a sustained drop of less than 200°F (93°C) in the indicated temperature of any of the thermocouples in the array during the unloaded portion of the burn, and at each applied increment of bending moment.

c. Bending Moment Criterion: The applied bending moment achieved without exceeding the allowable leakage rate shall be at least 75% of the end connection capacity, as determined either from the API Bull 6AF values or from the manufacturer's documented design values.

## **4.4 SAFETY CONSIDERATIONS**

### **4.4.1 Personnel Protection**

Because of the possible design of the test connection and the nature of the test program, the potential may exist for a hazardous rupture of the pressure boundary components. Protection for test personnel shall be provided.

## **5 Equipment Marking**

### **5.1 MARKING REQUIREMENTS**

End connections qualified by the testing of this Specification shall be marked 6FB on the exterior surface, in addition to the other marking requirements of API Spec 6A.

## **6 Qualification by Scaling**

### **6.1 SCALING**

Scaling may be used to verify the members of a connection family in accordance with the requirements and limitations of this section.

### **6.2 CONNECTION FAMILY**

A connection family shall meet the following design requirements.

- a. Configuration: The design principles of physical configuration and functional operation are the same.
- b. Design Stress Levels: The design stress levels in relation to material mechanical properties are based on the same criteria.
- c. Materials: Qualification of designs utilizing materials other than those tested is beyond the scope of this document.

### **6.3 LIMITATIONS OF SCALING**

Verification by scaling is subject to the following limitations.


- a. Verification by Pressure Rating: The test connection may be used to qualify connections of the same family having the same pressure rating.
- b. Verification by Size: Testing may be performed on individual sizes. Testing of two sizes of the same family also qualifies all nominal sizes between the two sizes tested, provided that the ratios of exposed external surface area to metal volume of the intermediate sizes fall between the values for the sizes tested. Calculation of the surface area/volume ratio shall be based on hub lengths equal to the bore diameter of the connection, up to a maximum of 12 inches (305 mm).



## **APPENDIX A—FIGURES**








#### Legend

1. Pressure source
2. Pressure regulator and relief
3. Vessel for water
4. Calibrated sight gauge
5. Water supply
6. Shutoff valve
7. Pressure gauge
8. Piping arranged to provide vapor trap
9. Enclosure for test—horizontal clearance between any part of the end connection and the closure shall be a minimum of 6 inches (150 mm)
10. Minimum height of enclosure shall be 6 inches (150 mm) above the top of the end connection
11. Test connection mounted vertically or horizontally
12. Fuel gas supply
13. Calorimeter cubes (Ref. 3.1.2.2 or 4.1.2.2)
14. Flame temperature thermocouple (Ref. 3.1.2.2 or 4.1.2.2)
15. Shutoff valve
16. Vent valve
17. Check valve

Figure A-1—Schematic of Suggested Systems for Fire Testing of End Connections



Note: Three T/Cs and three calorimeters spaced uniformly around circumference of joint (minimum—see 3.1.2.2).  
One T/C and one calorimeter on each side of joint at distance "T" (see 3.1.2.2).

$T = \frac{3}{2} L$ , or  $2D$ , whichever is greater

Figure A-2—Location of Thermocouples and Calorimeters—Onshore Conditions




Figure A-3—Location of Burner, Calorimeter, and Thermocouple—Offshore Well Bay Conditions




Figure A-4—Calorimeter Cube Design Details




Figure A-5—Typical Bend Test Arrangement With One Ram Cylinder




Figure A-6—Typical Bend Test Arrangement With Two Ram Cylinders






Figure A-7—Schematic of Suggested Leak Measurement System



Note: Three calorimeters spaced uniformly around circumference of joint (minimum—see 3.1.2.2).  
Thermocouples spaced at 45° max. for  $7\frac{1}{16}$ " (179 mm) and smaller connections, or at 30° max. for larger connections.

Figure A-8—Location of Thermocouples and Calorimeters for Bending Tests—Onshore Conditions



Note: Thermocouples spaced at 45° max. for  $7\frac{1}{16}$ " (179 mm) and smaller connections, or at 30° max. for larger connections.

Figure A-9—Location of Burner, Calorimeter, and Thermocouples for Bending Tests—Offshore Well Bay Conditions

# API Related Publications Order Form

Date: \_\_\_\_\_  
(Month, Day, Year)

☐ API Member  
(Check if Yes)

Invoice To – ☐ Check here if same as "Ship To"

Company: \_\_\_\_\_

Name/Dept.: \_\_\_\_\_

Address: \_\_\_\_\_

City: \_\_\_\_\_ State/Province: \_\_\_\_\_

Zip: \_\_\_\_\_ Country: \_\_\_\_\_

Customer Daytime Telephone No.: \_\_\_\_\_

Fax No.: \_\_\_\_\_

Ship To – (UPS will not deliver to a P.O. Box)

Company: \_\_\_\_\_

Name/Dept.: \_\_\_\_\_

Address: \_\_\_\_\_

City: \_\_\_\_\_ State/Province: \_\_\_\_\_

Zip: \_\_\_\_\_ Country: \_\_\_\_\_

Customer Daytime Telephone No.: \_\_\_\_\_

Fax No.: \_\_\_\_\_

(Essential for Foreign Orders)

☐ Payment Enclosed \$ \_\_\_\_\_

☐ Payment By Charge Account:

☐ MasterCard

☐ Visa

☐ American Express

Account No.: \_\_\_\_\_

Name (As It Appears on Card): \_\_\_\_\_

Expiration Date: \_\_\_\_\_

Signature: \_\_\_\_\_

☐ Please Bill Me

P.O. No.: \_\_\_\_\_

Customer Account No.: \_\_\_\_\_

State Sales Tax – The American Petroleum Institute is required to collect sales tax on publications mailed to the following states: AL, AR, CT, DC, FL, GA, IL, IN, IA, KS, KY, ME, MD, MA, MI, MN, MO, NE, NI, NY, NC, ND, OH, PA, RI, SC, TN, TX, VT, VA, WV and WI. Prepayment of orders shipped to these states should include applicable sales tax unless a purchaser is exempt. If exempt, please print your state exemption number and enclose a copy of the current exemption certificate.

Exemption Number: \_\_\_\_\_ State: \_\_\_\_\_

Quantity	Order Number	Title	SO*	Unit Price	Total
	G06A17	Spec 6A, Wellhead and Christmas Tree Equipment		\$ 115.00	
	G03207	Spec 6FA, Fire Test for Valves		\$ 50.00	
	G03211	Spec 6FC, Fire Test for Valve With Automatic Backseats		\$ 50.00	
	G06FD1	Spec 6FD, Fire Test for Check Valves		\$ 50.00	
	G03212	Bull 6F1, Performance of API and ANSI End Connections in a Fire Test According to API Specification 6FA		\$ 60.00	
	G03214	Bull 6F2, Fire Resistance Improvements for API Flanges		\$ 50.00	

Shipping and Handling – All orders are shipped via UPS or First Class Mail in the U.S. and Canada. Orders to all other countries will be sent by Airmail. U.S. and Canada, \$5 per order handling fee, plus actual shipping costs. All other countries, for Airmail (standard service) add 25% of order value. All other countries, for UPS Next Day, add an additional 10% of order value.

Rush Shipping Charge – FedEx, \$10 in addition to customer providing FedEx account number: \_\_\_\_\_. UPS Next Day, \$10 plus the actual shipping costs (1-9 items).

UPS Second Day, add \$10 plus the actual shipping costs (1-9 items).

Rush Bulk Orders – 1-9 items, \$10. Over 9 items, add \$1 each for every additional item.

NOTE: Shipping on foreign orders cannot be rushed without FedEx account number.

Subtotal  
State Sales Tax (see above)  
Rush Shipping Charge (see left)  
Shipping and Handling (see left)  
Total (in U.S. Dollars)

\*To be placed on Standing Order for future editions of this publication, place a check mark in the space provided. Pricing and availability subject to change without notice.

Mail Orders: American Petroleum Institute, Order Desk, 1220 L Street, N.W., Washington, DC 20005-4070  
Fax Orders: (202) 962-4776 Phone Orders: (202) 682-8375

To better serve you, please refer to this code when ordering: **G M 4 3 5 4 0 4 9 8**

The American Petroleum Institute provides additional resources and programs to industry which are based on API Standards. For more information, contact:

- |  |                                       |
|--|---------------------------------------|
| • Training/Workshops                                 | Ph: 202-682-8490<br>Fax: 202-682-8222 |
| • Inspector Certification Programs                   | Ph: 202-682-8161<br>Fax: 202-962-4739 |
| • American Petroleum Institute<br>Quality Registrar  | Ph: 202-682-8130<br>Fax: 202-682-8070 |
| • Monogram Program                                   | Ph: 202-962-4791<br>Fax: 202-682-8070 |
| • Engine Oil Licensing and<br>Certification System   | Ph: 202-682-8233<br>Fax: 202-962-4739 |
| • Petroleum Test Laboratory<br>Accreditation Program | Ph: 202-682-8129<br>Fax: 202-682-8070 |

In addition, petroleum industry technical, patent, and business information is available online through API EnCompass™. Call 1-888-604-1880 (toll-free) or 212-366-4040, or fax 212-366-4298 to discover more.

To obtain a free copy of the API Publications, Programs, and Services Catalog, call 202-682-8375 or fax your request to 202-962-4776. Or see the online interactive version of the catalog on our web site at [www.api.org/cat](http://www.api.org/cat).



**American  
Petroleum  
Institute**

**Helping You  
Get The Job  
Done Right.™**





Additional copies available from API Publications and Distribution:  
(202) 682-8375

Information about API Publications, Programs and Services is  
available on the World Wide Web at: <http://www.api.org>



**American  
Petroleum  
Institute**

1220 L Street, Northwest  
Washington, D.C. 20005-4070  
202-682-8000

Order No. G06FB3