Specification for Fire Test for Valves With Automatic Backseats

SPECIFICATION 6FC THIRD EDITION, APRIL 1999





Helping You Get The Job Done Right.™



API ENVIRONMENTAL, HEALTH AND SAFETY MISSION AND GUIDING PRINCIPLES

The members of the American Petroleum Institute are dedicated to continuous efforts to improve the compatibility of our operations with the environment while economically developing energy resources and supplying high quality products and services to consumers. We recognize our responsibility to work with the public, the government, and others to develop and to use natural resources in an environmentally sound manner while protecting the health and safety of our employees and the public. To meet these responsibilities, API members pledge to manage our businesses according to the following principles using sound science to prioritize risks and to implement cost-effective management practices:

- To recognize and to respond to community concerns about our raw materials, products and operations.
- To operate our plants and facilities, and to handle our raw materials and products in a manner that protects the environment, and the safety and health of our employees and the public.
- To make safety, health and environmental considerations a priority in our planning, and our development of new products and processes.
- To advise promptly, appropriate officials, employees, customers and the public of information on significant industry-related safety, health and environmental hazards, and to recommend protective measures.
- To counsel customers, transporters and others in the safe use, transportation and disposal of our raw materials, products and waste materials.
- To economically develop and produce natural resources and to conserve those resources by using energy efficiently.
- To extend knowledge by conducting or supporting research on the safety, health and environmental effects of our raw materials, products, processes and waste materials.
- To commit to reduce overall emissions and waste generation.
- To work with others to resolve problems created by handling and disposal of hazardous substances from our operations.
- To participate with government and others in creating responsible laws, regulations and standards to safeguard the community, workplace and environment.
- To promote these principles and practices by sharing experiences and offering assistance to others who produce, handle, use, transport or dispose of similar raw materials, petroleum products and wastes.

Specification for Fire Test for Valves With Automatic Backseats

Upstream Segment

SPECIFICATION 6FC THIRD EDITION, APRIL1999



Helping You Get The Job Done Right.™

SPECIAL NOTES

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations under local, state, or federal laws.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet.

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. Sometimes a one-time extension of up to two years will be added to this review cycle. This publication will no longer be in effect five years after its publication date as an operative API standard or, where an extension has been granted, upon republication. Status of the publication can be ascertained from the API Upstream Segment [telephone (202) 682-8000]. A catalog of API publications and materials is published annually and updated quarterly by API, 1220 L Street, N.W., Washington, D.C. 20005.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this standard or comments and questions concerning the procedures under which this standard was developed should be directed in writing to the general manager of the Upstream Segment, American Petroleum Institute, 1220 L Street, N.W., Washington, D.C. 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the general manager.

API standards are published to facilitate the broad availability of proven, sound engineering and operating practices. These standards are not intended to obviate the need for applying sound engineering judgment regarding when and where these standards should be utilized. The formulation and publication of API standards is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, N.W., Washington, D.C. 20005.

Copyright © 1999 American Petroleum Institute

FOREWORD

- a. This specification is under the jurisdiction of the API Committee on Standardization of Valves and Wellhead Equipment.
- b. This standard covers the requirements for testing and evaluating the performance of API Spec 6A and 6D valves with automatic backseats when exposed to specifically defined fire conditions. For the purpose of this specification, an automatic backseating valve is defined as a manual or actuated valve which allows the stem to effect a backseat against the bonnet and isolate the stem packing, by automatic means, when exposed to a fire.
- c. This standard is not intended to cover end connections. These are covered in API Specification 6FB, *Specification for Fire Test for End Connections*.
- d. Other standards under the jurisdiction of this committee include:

Spec 6A: Specification for Wellhead and Christmas Tree Equipment

Bull 6AF: Bulletin on Capabilities of API Flanges Under Combinations of Load

Bull 6AF1: Bulletin on Temperature Derating of API Flanges Under Combination of Loading

Spec 6D: Specification for Pipeline Valves (Gate, Plug, Ball, and Check Valves)

Spec 6FA: Specification for Fire Test for Valves

Spec 6FB: Specification for Fire Test for End Connections

TR 6F1: Performance of API and ANSI End Connections in a Fire Test According to API Spec 6FA

TR 6F2: Fire Resistance Improvements for API Flanges

- e. Conversions of English units to International System (SI) metric units are provided throughout the text of this specification in parentheses, e.g., 6 in. (152,4 mm). Note that the comma is used as a decimal market for metric data. SI equivalents have also been included in all tables. English units are in all cases preferential and shall be the standard in this specification. The factors used for conversion of English units to SI units were taken from API Publication 2564, and are listed below:
 - 1. Length:

1 inch (in.) = 25,4 millimeters (mm) exactly

2. Pressure:

1 pound per = 0,06894757 Bar square inch (psi) = 0,006894757 MPa

3. Temperature:

The following formula was used to convert degrees Fahrenheit (°F) to degrees Celsius (°C): $^{\circ}C = 5/9$ (°F-32)

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication

Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any federal, state, or municipal regulation with which this publication may conflict.

Suggested revisions are invited and should be submitted to the general manager of the Upstream Segment, American Petroleum Institute, 1220 L Street, N.W., Washington, D.C. 20005.

This Standard shall become effective on the date printed on the cover but may be used voluntarily from the date of distribution.

IMPORTANT INFORMATION CONCERNING USE OF ASBESTOS OR ALTERNATIVE MATERIALS

Asbestos is specified or referenced for certain components of the equipment described in some API standards. It has been of extreme usefulness in minimizing fire hazards associated with petroleum processing. It has also been a universal sealing material, compatible with most refining fluid services.

Certain serious adverse health effects are associated with asbestos, among them the serious and often fatal diseases of lung cancer, asbestosis, and mesothelioma (a cancer of the chest and abdominal linings). The degree of exposure to asbestos varies with the product and the work practices involved.

Consult the most recent edition of the Occupational Safety and Health Administration (OSHA), U.S. Department of Labor, Occupational Safety and Health Standard for Asbestos, Tremolite, Anthophyllite, and Actinolite, 29 *Code of Federal Regulations* Section 1910.1001; the U.S. Environmental Protection Agency, National Emission Standard for Asbestos, 40 *Code of Federal Regulations* Sections 61.140 through 61.156; and the U.S. Environmental Protection Agency (EPA) rule on labeling requirements and phased banning of asbestos products (Sections 763.160-179).

There are currently in use and under development a number of substitute materials to replace asbestos in certain applications. Manufacturers and users are encouraged to develop and use effective substitute materials that can meet the specifications for, and operating requirements of, the equipment to which they would apply.

SAFETY AND HEALTH INFORMATION WITH RESPECT TO PARTICULAR PRODUCTS OR MATERIALS CAN BE OBTAINED FROM THE EMPLOYER, THE MANUFACTURER OR SUPPLIER OF THAT PRODUCT OR MATERIAL, OR THE MATERIAL SAFETY DATA SHEET.

CONTENTS

		Page
1	SCOPE	. 1
2	DESCRIPTION OF FIRE TEST	. 1
3	TEST PROCEDURE. 3.1 Stepwise Procedures 3.2 Test Adjustments.	. 1
4	 4.1 Through Leakage (High Test Pressure)—During Burn Period. 4.2 External Leakage (High Test Pressure)—During Burn and 	3
	Cool-down Period (Valve in Closed Position)	. 4
	(Valve in Closed Position)	
	4.6 Operation of Test Valve After Fire Test 4.7 External Leakage—Open Position.	. 4
	4.8 Pressure Relief Provision	. 6
5	CERTIFICATION	. 7
6	SAFETY CONSIDERATIONS 6.1 Personnel Protection 6.2 Pressure Relief Provision	. 7
7	EQUIPMENT MARKING	. 7
	Figures	
	Location of Calorimeters Smaller Valves Location of Calorimeters Larger Valves Calorimeter Cube Design Schematic of Suggested Systems for Fire Test for Valves	. 2
	Tables 1 Test Pressure During Fire Test	. 6

Specification for Fire Test for Valves With Automatic Backseats

1 Scope

It is the purpose of this document to establish the requirements for testing and evaluating the pressure-containing performance of API Spec 6A and Spec 6D Automatic Backseating valves when exposed to fire. The performance requirements of this document are intended to establish standard limits of acceptability regardless of size or pressure rating.

This document establishes acceptable levels for leakage through the test valve and also external leakage after exposure to a fire for a 30-minute time period, both before and after reworking the stuffing box.

The burn period has been established on the basis that it represents the maximum time required to extinguish most fires. Fires of greater duration are considered to be of a major magnitude with consequences greater than those anticipated in this test.

2 Description of Fire Test

- **2.1** The valve shall be tested in the closed position with water with the stem and bore in the horizontal position.
- **2.2** The valve will be enveloped in flame having a temperature of $1,400^{\circ}\text{F}-1,800^{\circ}\text{F}$ ($761^{\circ}\text{C}-980^{\circ}\text{C}$) average of two thermocouples, located as shown in Figures 1 or 2. No reading shall be below $1,300^{\circ}\text{F}$ (704°C). The test set-up shall include $1^{1}/_{2}$ -in. cube calorimeter blocks made of carbon steel with a thermocouple located in the center of each block (refer to Figure 3 for calorimeter block configuration). For API 6A valves size $7^{1}/_{16}$ -in. and smaller, and API 6D valves size 6

and smaller, two blocks shall be located as shown in Figure 1. For larger size valves, three blocks shall be used as shown in Figure 2. Piping upstream of the test valve larger than one in. (25 mm) nominal pipe size or one-half of the valve nominal pipe size (whichever is smaller) must be enveloped in flame for a distance of at least six in. (152 mm).

- **2.3** The burn period will be 30 minutes from ignition.
- **2.4** The end connection piping-to-valve joint leakage (flanged, threaded, or welded) is not considered a part of this test and is not included in the allowable external leakage in 4.2, 4.4 and 4.7. For the test, it may be necessary to modify this joint to eliminate leakage.

3 Test Procedure

3.1 STEPWISE PROCEDURES (REFER TO FIGURE 4)

- **3.1.1** Open valve(s) (Items 5 and 6) at water source, and any necessary vent valves (Item 17) to flood the system and purge the air. The test valve may have to be placed in the partially open position in order to completely flood the valve body.
- **3.1.2** Close fill valve (Item 5) and test valve (Item 11), then close vent valves (Item 17). The piping system upstream of the test valve shall be completely water filled and the system downstream shall be drained.
- **3.1.3** Pressurize the system to the appropriate high test pressure from Table 1. Maintain this pressure during the burn




Figure 1—Location of Calorimeters Smaller Valves (Reference 2.2)




Figure 2—Location of Calorimeters Larger Valves (Reference 2.2)

and cool-down period. Momentary pressure losses are permissible, provided their cumulative recovery time is less than two minutes. Record the reading on the calibrated sight gauge (Item 4). Empty the graduated downstream container (Item 19).

- **3.1.4** Open fuel supply, establish a fire, and monitor the flame temperature. The average of two thermo-couples (Item 14) must reach 1,400°F (761°C) within two minutes. Maintain the average temperature between 1,400°F–1,800°F (761°C –980°C), with no reading less than 1,300°F (704°C) for the remainder of the burn period.
- **3.1.5** The average temperature of the calorimeters (Item 13) shall reach 1,200°F (650°C) within 15 minutes of fire ignition. For the remainder of the burn period, the calorimeters shall maintain a minimum average temperature of 1,200°F (650°C); and none of the calorimeters shall have a temperature less than 1,050°F (565°C).

Note: Impingement of water or steam from external leakage onto flame thermocouples or calorimeters can result in a substantial drop in the indicated temperature of the affected sensor(s), even if no actual drop in flame temperature has occurred. Such drops in indicated temperature(s) shall be noted in the test report. The test may continue with no downward adjustment of the burner controls provided that at least one flame thermocouple and one calorimeter are functioning.

- **3.1.6** Record instrument readings (Items 7, 13, 14 and 15) every 30 seconds during the burn period.
- **3.1.7** At the end of the burn period (30 minutes), shut off the fuel.
- **3.1.8** Immediately determine the amount of water collected in calibrated container (Item 19) to establish total through valve seat leakage. Continue collecting water in the calibrated container (Item 19) for use in establishing the external leakage rate. If the test valve is of the upstream sealing type, the volume of water that is trapped between the upstream seat seal and the downstream seat seal, when the valve is closed, shall be determined before the test is started and identified in the test report. It is assumed that during the test this volume of water would move through the valve, past the downstream seat seal and be collected in the calibrated container. Since this volume has not actually leaked past the upstream seat seal, it may be deducted from the total volume measured in the downstream calibrated container when determining the through valve leakage.

Note: If the total volume collected downstream during the burn and/ or cooldown is less than the body cavity volume, the through leakage can be assumed to have been zero.

3.1.9 Cool the valve (or allow to cool) to 212°F (100°C) or less. Record reading on sight gauge (Item 4), and calibrated




Figure 3—Calorimeter Cube Design (Reference 2.2)

container (Item 19). Cooling may, at the manufacturer's option, be natural or forced.

- **3.1.10** The following low pressure test is required only for API 6D valves with ratings of class 600 and lower. Decrease the test pressure to the low test pressure value shown in Table 1. Measure the through valve and external leakage over a 5 minute period.
- **3.1.11** If step 3.1.10 was performed, increase pressure on test valve to the high test pressure value in Table 1.
- **3.1.12** Verify that backseating has occurred by monitoring for (and measuring) leakage at a test port above the backseat, for a period of five minutes.
- **3.1.13** Rework the stuffing box as required, without releasing pressure. Rework shall be limited to replacement of packing and eutectic washer with parts of the same design and materials. Rework of the stuffing box may include the cleaning out of charred or burnt packing, and light honing or polishing of the sealing area of the stem and stuffing box.
- **3.1.14** Open the test valve against the high test pressure differential. The valve shall be moved to a partly open

(approximately half-way) position. Close the shutoff valve (Item 16). Vent the piping and test valve body cavity to remove air or steam.

3.1.15 Measure and record external leakage for a period of five minutes after valve is in the open position at high test pressure.

3.2 TEST ADJUSTMENTS

The stuffing box may be reworked per 3.1.13. No other part of the test valve may be adjusted during the test period. The test system may be adjusted during the test period to keep the test within the limits specified herein.

4 Performance Requirements

4.1 THROUGH LEAKAGE (HIGH TEST PRESSURE)—DURING BURN PERIOD

The maximum through seat (does not include bonnet and stem) leakage shall not be greater than the value shown below (refer to 3.1.8.):

	Valve Rating		High Test Pressure			Low Test Pressure			
	Class	(PN)a		psi	(bar)	(MPa)	psi	(bar)	(MPa)
Spec 6D	150	(20)	_	210	(14,5)	(1,5)	29	(2,0)	(0,2)
Valves	300	(50)	_	540	(37,2)	(3,7)	50	(3,4)	(0,34)
	400	(64)	_	720	(49,6)	(5,0)	70	(4,8)	(0,48)
	600	110	_	1080	(74,5)	(7,5)	105	(7,2)	(0,72)
	900	(150)	_	1620	(111,7)	(11,2)	_	_	_
	1500	(260)	_	2700	(186,2)	(18,6)	_	_	_
	2500	(420)	_	4500	(310,3)	(31,0)	_	_	_
	psi	(bar)	(MPa)	psi	(bar)	(MPa)			
Spec 6A	2000	(138)	(13,8)	1500	(103,4)	(10,3)	_	_	_
Valves	3000	(207)	(20,7)	2250	(155,1)	(15,5)	_	_	_
	5000	(345)	(34,5)	3750	(258,6)	(25,9)	_	_	_
	10000	(690)	(69,0)	7500	(517,1)	(51,7)	_	_	_
	15000	(1034)	(103,5)	11250	(775,7)	(77,6)	_	_	_
	2000	(1379)	(138,0)	15000	(1034,2)	(103,5)	_	_	_

Table 1—Test Pressure During Fire Test

 ^{a}PN is the pressure class designation utilized in ISO (International Standards Organization) documents. Tolerance on all test pressures is \pm 10%.

Burn Period 30 minutes
Rate

400 ml/in./min¹ (15,7 ml/mm/min)

4.2 EXTERNAL LEAKAGE (HIGH TEST PRESSURE)—DURING BURN AND COOL-DOWN PERIOD (VALVE IN CLOSED POSITION)

The maximum external leakage, not including seat leakage, shall not be greater than the value shown below (refer to 3.1.8 and 3.1.9):

Test Duration 30 minutes plus time to cool-down

to 212°F (100°C)

Rate 100 ml/in./min¹

(3.9 ml/mm/min)

4.3 THROUGH LEAKAGE (LOW TEST PRESSURE)—AFTER COOL-DOWN

The maximum through seat (does not include bonnet and stem) leakage shall not be greater than the value shown below (refer to 3.1.10):

Test Duration 5 minutes
Rate 40 ml/in./min¹
(1.6 ml/mm/min)

4.4 EXTERNAL LEAKAGE (LOW TEST PRESSURE)—AFTER COOL-DOWN (VALVE IN CLOSED POSITION)

The maximum external leakage not including seat leakage shall not be greater than the value shown below (refer to 3.1.10):

Test Duration 5 minutes
Rate 20 ml/in./min¹
(0,8 ml/mm/min)

4.5 EXTERNAL LEAKAGE (HIGH TEST PRESSURE)—DURING THE BACKSEAT TEST AND REWORK OF THE STUFFING BOX

After draining any water which may have entered the stuffing box before backseating was complete, no leakage is acceptable (refer to 3.1.12 and 3.1.13):


4.6 OPERATION OF TEST VALVE AFTER FIRE TEST


The valve shall be capable of being unseated from the closed position against high test pressure differential (Table 1). The valve shall be moved to the open position one time (as specified in 3.1.14).

4.7 EXTERNAL LEAKAGE—OPEN POSITION

With the test valve in the open position the external leakage (as determined in 3.1.15) shall not be greater than 200 ml/in./min (8 ml/mm/min).

¹Leakage rates are milliliters per inch of nominal value size per minute (milliliters per milliliter of nominal value size per minute), averaged over the duration of the particular test period.





Legend

- 1. Pressure source.
- 2. Pressure regulator and relief.
- Vessel for water. Calibrated sight gauge.
- 5. Water supply.
- Shutoff valve.
- Pressure gauge. 7.
- 8. Piping arranged to provide vapor trap.
- Enclosure for test—horizontal clearance between any part of the valve and the closure shall be a minimum of 6 in. (152 mm).
- 10. Minimum height of enclosure shall be 6 in. (152 mm) above the top of the valve.

- 11. Test valve mounted horizontally with stem in horizontal position.
- 12. Fuel gas supply to burners (Ref. 2.2).
- 13. Calorimeter—11/2 in. cubes (Ref. 2.2)
- 14. Flame temperature thermocouple (Ref. 2.2).
- 15. Pressure gauge and relief valve (if required—Ref. 2.2) connected to center cavity of valve.
- 16. Shutoff valve.
- 17. Vent valve.
- 18. Condenser.
- 19. Calibrated container.
- 20. Check valve.

Figure 4—Schematic of Suggested Systems for Fire Test for Valves

4.8 PRESSURE RELIEF PROVISION

The valve fails the test if the pressure relief valve identified in the provision of 6.2 activates. However, if the relieving device activates in the test valve, which normally includes the pressure relieving device as standard, the test shall continue and any leakage through this device shall be counted as external leakage.

4.9 TESTS REQUIRED

In lieu of testing each size and pressure rating of a given valve design, other valves of the same basic design as the test valve and same nonmetallic materials with respect to the seat to closure member seal, seat to body seal, stem seal, and body joint and seal, may be qualified, subject to the following limitations:

4.9.1 One test valve may be used to qualify valves larger than the test valve, not exceeding twice the size of the test

valve (refer to Table 2). A size 16 valve will qualify all larger sizes.

- **4.9.2** One test valve may be used to qualify valves with higher pressure ratings but no greater than twice the pressure rating of the test valve (refer to Table 3).
- **4.9.3** The nominal size of the test valve is determined by the size of the end connections.
- **4.9.4** Valves with asymmetric internal or external body construction (exclusive of the end connections), and/or asymmetric seats and closure mechanism, intended for bi-directional installation shall be qualified by conducting the test procedure twice, once in each direction of potential installation. Asymmetric valves intended for single direction installation shall be marked accordingly and shall be tested in the direction of recommended installation.
- **4.9.5** Valves shall not be protected with insulation material of any form during testing, except where such protection is part of the design of the component.

Table 2—Qualification of Other Size Valves (Reference 4.9.1)

Size of Test	Valve	Other Valve Sizes Qualified		
NPS	DNa	NPS	DNa	
2" API 6D,	50	2, 2 ¹ / ₂ , 3, 4 API 6D,	50, 65,	
1 ¹³ / ₁₆ , 2 ¹ / ₁₆ API 6A		$1^{13}/_{16}$, $\overline{2^{1}}/_{16}$, $2^{9}/_{16}$, $3^{1}/_{8}$,	80, 100	
		$4^{1}/_{16}$ API 6A		
2 ⁹ / ₁₆ API 6A,	65	$2^{9}/_{16}$, $3^{1}/_{8}$, $4^{1}/_{16}$, $5^{1}/_{8}$ API 6A,	65, 80,	
$2^{1}/_{2}$ API 6D		$2^{1}/_{2}$, 3, 4 API 6D	100, 125	
3 API 6D,	80	3, 4, 6 API 6D,	80, 100,	
3 ¹ / ₈ API 6A		$3^{1}/_{8}$, $4^{1}/_{16}$, $5^{1}/_{8}$, $7^{-1}/_{16}$ API 6A	125, 150	
4 API 6D,	100	4, 6, 8 API 6D,	100, 125,	
4 ¹ / ₁₆ API 6A		$4^{1}/_{16}$, $5^{1}/_{8}$, $7^{1}/_{16}$ API 6A	150, 200	
5 ¹ / ₈ API 6A	125	5 ¹ / ₈ , 7 ¹ / ₁₆ , 9 API 6A,	125, 150,	
		6, 8, 10 API 6D	200, 250	
6 API 6D,	150	6, 8, 10, 12 API 6D,	150, 200,	
7 ¹ / ₁₆ API 6A		7 ¹ / ₁₆ , 9, 11 API 6A	250, 300	
8 API 6D	200	8, 10, 12, 14, 16 API 6D,	200, 250,	
		9, 11 API 6A	300, 350, 400	
9 API 6A	N/A	9, 11 API 6A,	250 through	
		8 through 16 API 6D	400	
10 API 6D	250	10 through 20 API 6D,	250 through	
		11 API 6A	500	
11 API 6A	N/A	11 API 6A,	300 through	
		10 through 20 API 6D	500	
12 API 6D	300	12 through 24 API 6D	300 through	
			600	
14 API 6D	350	14 through 28 API 6D	350 through	
		•	700	
16 API 6D	400	16 and larger API 6D	400 and	
		•	larger	

^aDN is the size designation utilized in ISO (International Standards Organization) documents.

Rating of Test Valve Other Valve Ratings Qualified Class PNa Bar Class or psi PNa MPa Bar 150 API 6D 20, 50 20 N/A 150; 300 API 6D N/A N/A 300 API 6D 50 300; 400; 600 API 6D 50, 64, 110 N/A N/A N/A 400 API 6D 400; 600 API 6D 64, 110 64 N/A N/A N/A 600 API 6D 110 N/A 600: 900 API 6D: 110, 150 N/A N/A 13.8, 20.7 2 000; 3 000 API 6A N/A 138, 207 900 API 6D 150 N/A 900; 1,500 API 6D; 150, 260 N/A N/A 3 000 API 6A N/A 20.7 207 1 500 API 6D N/A 260 N/A 1 500; 2 500 API 6D; 260, 420 N/A 5 000 API 6A 34.5 345 N/A 2 500 API 6D 420 N/A 2 500 API 6D; 420 N/A N/A 10 000 API 6A N/A 69.0 690 PNa MPa psi or Class MPa Bar Bar psi 2 000 API 6A 2 000; 3 000 API 6A; N/A 13.8, 20.7 138, 207 13.8 138 900; 1 500 API 6D 150, 260 N/A N/A 3 000 API 6A 20.7 207 3 000; 5 000 API 6A; N/A 20.7, 34.5 207, 345 1500; 2500 API 6D 260, 420 N/A N/A 5 000 API 6A 34.5 345 5 000; 10 000 N/A 34.5, 69.0 345, 690 API 6A; 420 N/A N/A 2 500 API 6D 10 000 API 6A 69.0 690 10 000; 15 000; N/A 69.0, 103.5 690, 1 034, 20 000 API 6A 138.0 1 379 15 000 API 6A 103.5 1 034 15 000: 20 000 N/A 103.5, 138.0 1 034, 1 379 API 6A 138.0 20 000 API 6A 1 379 20 000 API 6A N/A 138.0 1 379

Table 3—Qualification of Other Pressure Rating Valves (refer to 4.9.2)

^aPN is the pressure class designation utilized in ISO (International Standards Organization) documents.

5 Certification

5.1 Records of the test upon which certifications are based shall be available for purchasers review at his request.

6 Safety Considerations

6.1 PERSONNEL PROTECTION

Because of the possible design of the test valve and the nature of the test program, the potential may exist for a hazardous rupture of the pressure boundary components. Protection for test personnel shall be provided.

6.2 PRESSURE RELIEF PROVISION

Provision of a pressure relief valve to atmosphere to protect the body cavity of double-seated valves against potential rupture shall be considered. Determination of the set pressure is the responsibility of the test valve manufacturer. The set pressure shall be low enough to preclude rupture of the valve at expected test temperatures.

7 Equipment Marking

7.1 In addition to the marking requirements specified in API Spec 6A or 6D, valves which have been qualified by this specification shall be permanently marked:

6FC

API F	Related Pul	olications Order Form	Date:	ur)		API Member (Check if Yes)		
Invoice To − □ Check here if same as "Ship To"			Ship To – (UPS will not deliver to a P.O. Box)					
Company:			Company:					
Name/Dept.:			Name/Dept.:					
Address:			Address:					
City:		State/Province:	City:		State/Province:	:		
Zip:		Country:	Zip:	Country:				
Customer Dayti	ime Telephone No.:		Customer Daytime Te	elephone No.:				
Fax No.:			Fax No.:					
(Essential for Fore	ign Orders)		(Essential for Foreign Ore	rders)				
_		ount.	☐ Please Bill Me P.O. No.:					
☐ Paymer	nt By Charge Acc and 🔲	Ount: Visa	Customer Account No.:					
Account No.:					roleum Institute is required to co			
Name (As It Ap	pears on Card):		mailed to the following states: AL, AR, CT, DC, FL, GA, IL, IN, IA, KS, KY, ME, MD, MA, MI, MN, MO, NE, NJ, NY, NC, ND, OH, PA, RI, SC, TN, TX, VT, VA, WV, and WI. Prepayment of orders shipped to these states should include					
Expiration Date:			applicable sales tax unless a purchaser is exempt. If exempt, please print your state exemption number and enclose a copy of the current exemption certificate.					
Signature:			Exemption Number: State:					
Quantity	Order Number	Title		S0*	Unit Price	Total		
	G06A17	Spec 6A, Wellhead and Christn	nas Tree Equipment		\$ 125.00			
	G06AF2	Bull 6AF, Capabilities of API Flanges U	Inder Combinations of	f Load	\$ 90.00			
	GO6AF1 TR 6AF1, Temperature Derating of Combination of Lo			r	\$ 100.00			
	G03200	Spec 6D, Pipeline Valves (Gate, Plug	g, Ball and Check Val	ves)	\$ 80.00			
	G03207	Spec 6FA, Fire Test i	for Valves		\$ 55.00			
	G06FB3	Spec 6FB, Fire Test for El			\$ 65.00			
	G06F13	TR 6F1, Technical Report on Perform Connections in a Fire Test Accor			\$ 70.00			
	G06F23	TR 6F2, Technical Report on Fire Res API Flanges		ts for	\$ 65.00			
Shipping a	nd Handling – All on	rders are shipped via UPS or First Class Mail in the U.S. oil. U.S. and Canada S5 ner order handling fee, plus a	. and Canada. Orders		Subtotal			
to all other countries will be sent by Airmail. U.S. and Canada, \$5 per order handling fee, plus at All other countries, for Airmail (standard service) add 25% of order value. All other countries, for an additional 10% of order value. Rush Shipping Charge – FedEx, \$10 in addition to customer providing FedEx. UPS Next Day, \$10 plus the actual shipping countries.			r UPS Next Day, add State Sales Tax (see above)					
			Ex account number: Fosts (1-9 items) TIPS	Rush Shippin	hipping Charge (see left)			
Second Day, add	d \$10 plus the actual ship	ping costs (1-9 items). \$10. Over 9 items, add \$1 each for every additional ite	S	Shipping and	ng and Handling (see left)			
on foreign ord	lers cannot be rushed wil	thout FedEx account number: ns received in damaged condition or as a result of sh		То	Total (in U.S. Dollars)			
errors, if unstar invoice date. A damaged in sh	nped and otherwise not d copy of the initiating ir ipment nor shipped in er	efaced, may be returned for replacement within 45 o nvoice must accompany each return. Material whio rror requires prior authorization and may be subjec	lays of the initiating ch has neither been ct to a shipping and	*To be placed on Standing Order for future editions publication, place a check mark in the space provi				
to processing	e. All returns must be g or shipping errors	shipped prepaid using third class postage. I API will refund the third class postage.	it returns are due	due Pricing and availability subject to change without notice.				

Mail Orders: American Petroleum Institute, Order Desk, 1220 L Street, N.W., Washington, DC 20005-4070 Fax Orders: (202) 962-4776 Phone Orders: (202) 682-8375

To better serve you, please refer to this code when ordering:

_] [A] [4] [4] [4] [8] [0] [1] [9

The American Petroleum Institute provides additional resources and programs to industry which are based on API Standards. For more information, contact:

•	Training/Workshops		202-682-8490 202-682-8222
•	Inspector Certification Programs	Ph: Fax:	202-682-8161 202-962-4739
•	American Petroleum Institute	Ph:	202-682-8130
	Quality Registrar	Fax:	202-682-8070
•	Monogram Program	Ph: Fax:	202-962-4791 202-682-8070
•	Engine Oil Licensing and	Ph:	202-682-8233
	Certification System	Fax:	202-962-4739
•	Petroleum Test Laboratory	Ph:	202-682-8129
	Accreditation Program	Fax:	202-682-8070

In addition, petroleum industry technical, patent, and business information is available online through API EnCompass[™]. Call 1-888-604-1880 (toll-free) or 212-366-4040, or fax 212-366-4298 to discover more.

To obtain a free copy of the API Publications, Programs, and Services Catalog, call 202-682-8375 or fax your request to 202-962-4776. Or see the online interactive version of the catalog on our web site at www.api.org/cat.

American Petroleum Institute

> Helping You Get The Job Done Right.™

Additional copies available from API Publications and Distribution: (202) 682-8375

Information about API Publications, Programs and Services is available on the World Wide Web at: http://www.api.org



1220 L Street, Northwest Washington, D.C. 20005-4070 202-682-8000

Order No. G06FC3