

कार्यालय सहायक यंत्री लोक स्वास्थ्य यांत्रिकी उपखण्ड वारासिवनी

क्रमांक 523 / लेब / सं० यं० / लो० स्वा० यां० वारासिवनी दिनांक :- 25/6/2025

प्रति,

प्राचार्य
गुरुदेव इंटरनेशनल पब्लिक
स्कूल कामदी (वारासिवनी)

जिला-बालाघाट (म.प्र.)

विषय :- गुरुदेव इंटरनेशनल पब्लिक स्कूल कामदी का जल
परीक्षण कर रिपोर्ट देने बाबद्।

सन्दर्भ :- आपका पत्र क्रं 41PS / जल परीक्षण / 2025 / दिनांक 23/06/2025

-00-

उपरोक्त विषयांतर्गत लेख है कि आपके द्वारा गुरुदेव इंटरनेशनल पब्लिक स्कूल कामदी का 1 नमूना पेयजल नमूना परीक्षण हेतु प्राप्त हुआ था जिनका प्रयोगशाला में परीक्षण कर जल परीक्षण रिपोर्ट आपकी ओर संलग्न कर प्रेषित है।

संलग्न - 1 रिपोर्ट।

सहायक यंत्री
लोक स्वास्थ्य यांत्रिकी उपखण्ड
वारासिवनी

WATER TESTING REPORT**PUBLIC HEALTH ENGINEERING DEPARTMENT SUB DIVISION - WARASEONI****DISTT. BALAGHAT (M.P.)**

Report Date -

25/06/2025

Sub Division Waraseoni

To - Principal
GIPS KaydiName Of Location - 1) Gyaadev International Public School
Kaydi (Waraseoni) Dist. Balaghat

Source - Tube well

Sample Collected by -

Date of Sample Collection - 23/06/2025

Date of Testing - 24/06/2025

Block - Waraseoni

Panchayat - Kaydi

Village - Kaydi

Sample Collected By Lab (Yes / No) -

S.No	Characteristics	unit	As per BIS-10500-2012 For Drinking Water		Results
			Desirable	Permissible	
PHYSICAL TEST					
1	Turbidity	NTU	1	5	2.0
2	Colour	Hazen	5	25	5.0
3	Taste	-	Unobjectionable	Unobjectionable	Agreeable
4	Odor	-	Unobjectionable	Unobjectionable	Agreeable
CHEMICAL TEST					
5	pH	PH Scale	6.5	8.5	7.0
6	Manganese	mg/l	0.1	0.3	0.2
7	Alkalinity	mg/l	200	600	200
8	Chloride	mg/l	250	1000	50
9	Nitrate	mg/l	45	45	5.0
10	Total Hardness	mg/l	200	600	180
11	Ca Hardness	mg/l	75	200	40
12	Mg Hardness	mg/l	30	100	19.2
13	Total Dissolved solids	mg/l	500	2000	301.4
14	Iron	mg/l	1	1	0.30
15	Fluoride	mg/l	1	1.5	0.36
16	Sulphate	mg/l	200	400	23.16
17	Residual Chlorine	mg/l	0.2	1	—
BACTRO. TEST					
18	Total Coliform	MPN/100 ml	0	0	Nil

Chemist

Public Health Engg. Sub. Division
WaraseoniAssistant Engineer
Public Health Engg.
Sub Division Waraseoni

Dated: 25/06/2025

Signature with Seal:

Designation

Name & Address of the Office / Department :

GURUDEV INTERNATIONAL

PUBLIC SCHOOL KAYDI, BALAGHAT

(Name & Address of the Institution)

130