KASHEF 701

Operation Manual

EECC Distribution Transformer Smart Monitoring System



Model: EECC-DTSMS

Version	Date	Formulation / Revision	Make	Verify
V1.0	2024.12.04	First Published	Fatema	Saleem



Contents

C	ontents	3
Pa	art 1: Safety Requirements	
Pa	art 2: General Description	5
Pa	art 3: Technical Description	6
1.	Functional Characteristics	6
2.	Functional Description	7
3.	Technical Specifications	8
3.1	Ratings:	8
3.2	Supported Functions:	9
3.3	Accuracy and Certification	11
_		
	art 5: Communication Description 1 Communication Standards:	
5.4	WAN Port and LAN Port:	
5.5	Configuration Software:	
5.6	Cellular Network Registeration:	
5.7	IEC104 Signals List:	
	Voltage, current, power, power factor	
	Energy	
	Tariff Energy	
	Demand register	
	Voltage and current harmonic register	
	Unbalance	
	Current K-factor and crest factor register	
_5.7.9	Voltage and current angle register	26
Pa	art 6: Dimensions & Installation	28
1.	Unit Dimensions:	
2.	Wiring System Connection diagram:	29
3.	Current Sensor Installation Steps:	30
4.	Terminal Block Connection:	31
Part 6	6: Order Placement Tips	32



Part 1: Safety Requirements

- ❖ Live Line Safety: Maintain a safe distance from live lines during installation. Only trained personnel should handle the installation.
- ❖ **Proper Insulation**: Ensure that installation tools, like the insulating rod and adaptor, are in good condition to prevent electrical hazards.
- ❖ **No Power Shutdown**: The device can be installed without turning off the grid power. Installers should remain on the ground and use the correct safety equipment.
- **Personal Protective Equipment (PPE)**: Wear insulated gloves, boots, helmets, and other safety gear during installation.
- ❖ **Authorized Personnel**: Only qualified personnel should perform installation and maintenance.
- ❖ Safe Distance: Always maintain a safe working distance from live electrical components.
- ❖ **Site Safety**: Verify that the installation site is clear of hazards to ensure a safe installation.
- **❖ Follow Local Regulations**: Comply with local electrical safety standards and guidelines during installation.



Part 2: General Description

The **EECC-DTSMS** (**Distribution Transformer Smart Monitoring System**) is an advanced monitoring solution designed to enhance the performance and reliability of distribution transformers. It continuously analyzes critical electrical parameters to ensure **power quality, minimize losses, and assess network health**.

The system utilizes **Current Transformers (CTs) and voltage sensors** to measure and monitor **power quality indicators**, including voltage stability, current balance, and power factor. Additionally, it detects **power losses**, enabling utilities to identify inefficiencies and optimize energy distribution.

A smart MCU processes the collected data, providing real-time analysis of network conditions. The system is fully integrated with SCADA, allowing remote monitoring and data acquisition. The collected information can be utilized by smart meters and SCADA systems for advanced analytics, predictive maintenance, and operational improvements.

By offering real-time insights and seamless data communication, the EECC-DTSMS supports utilities in enhancing grid stability, improving asset management, and ensuring efficient power distribution.

Device Outlook:









Part 3: Technical Description

1. Functional Characteristics

➤ Power Quality

- Measures key power quality parameters such as voltage fluctuations, harmonics, power factor, and frequency variations.
- Helps in identifying anomalies that may affect the performance of connected loads.

> Power losses.

- Identifies technical and non-technical losses in the distribution network.
- Provides data-driven insights to minimize energy wastage and improve system efficiency.

Network Health.

- Monitors transformer temperature, load conditions, and insulation health.
- Detects early signs of potential failures, enabling predictive maintenance and reducing.
- ➤ Providing Data could be utilized by smart meters SCADA for analysis.
 - Collects and transmits real-time operational data to smart meters and SCADA systems.
 - Enables advanced analytics, fault detection, and optimization of grid performance.



2. Functional Description

The EECC-DTSMS (Distribution Transformer Smart Monitoring System) is an advanced solution designed to enhance the reliability and efficiency of distribution transformers. It continuously monitors critical electrical parameters such as voltage stability, current balance, and power factor using Current Transformers (CTs) and voltage sensors. Additionally, it detects both technical and non-technical power losses, helping utilities identify inefficiencies and optimize energy distribution. The system also assesses network health by tracking transformer temperature, load conditions, and insulation status, enabling predictive maintenance and reducing the risk of failures. A smart MCU processes real-time data and integrates seamlessly with SCADA and smart meters, allowing for remote monitoring, advanced analytics, and operational improvements. By providing actionable insights and real-time communication, the EECC-DTSMS supports utilities in improving grid stability, optimizing asset management, and ensuring efficient power distribution.



3. Technical Specifications

3.1 Ratings:

Current					
Channel input voltage range	0-900mVAC peak,636 mV RMS				
Measurement range	Different current sensors have different ran	Different current sensors have different ranges			
Rcoil 50mV/kA@50Hz(0-12000A),@60Hz(0-1000 85mV/kA@50Hz(0-7000A),@60Hz(0-60000					
VCT	0~99999A	0~99999A			
Voltage					
Channel input voltage range	0~600VAC Phase Voltage	0~600VAC Phase Voltage			
Maximum range	720VAC Phase Voltage	720VAC Phase Voltage			
Power supply					
Power Supply	ME231N2	ME231N3			
Tower Suppry	95~265VAC/110~370VDC, 45~60Hz	24VDC			
Maximum power consumption 3.5VA					



3.2 Supported Functions:

Instantaneous value	
Instantaneous value	111 112 112 AVC
Phase Voltage	U1,U2,U3,AVG
Line Voltage	U12,U23,U31,AVG
Current	I1,I2,I3,AVG,IN
Grid Frequency	F1,F2,F3,∑
Power Factor PF	PF1,PF2,PF3,∑
Fundamental power factor DPF	DPF1,DPF2,DPF3,∑
Active power	P1,P2,P3,∑
Reactive power	Q1,Q2,Q3,∑
Apparent power	S1,S2,S3,∑
Energy	
Active energy Pos.	EP1,EP2,EP3,∑
Active Energy Neg.	EP1,EP2,EP3,∑
Reactive Energy Pos.	EQ1,EQ2,EQ3,∑
Reactive energy Neg.	EQ1,EQ2,EQ3,∑
Apparent Energy	ES1,ES2,ES3,∑
Tariff Energy	ET1,ET2, ET3,ET4, ET5,ET6
Harmonics	
Voltage Harmonic	THD (Total harmonic percentage), TOHD (Odd total
Distortion	harmonic percentage), TEHD (Even total harmonic
Voltage Harmonic Value	percentage), phase L1.L2.L3 1-50th harmonic percentage,
	phase ABC 1-50th harmonic voltage value
Current Harmonic Distortion	THD (Total harmonic percentage), TOHD (Odd total
	harmonic percentage), TEHD (Even total harmonic
Current Harmonic Value	percentage), phase L1.L2.L3 1-50th harmonic
	percentage, phase ABC 1-50th harmonic current value
Phasor diagram	
Phasor diagram	between voltage and current
Phase Sequence	voltage and current
Voltage Angle	U1,U2,U3

Current Angle	I1,I2,I3			
UI Angle	UI1,UI2,UI3			
Demand				
Demand	P,Q,S			
Active power DMD Max.	P and Time			
Reactive power DMD Max.	Q and Time			
Apparent power DMD Max.	S and Time			
Unbalance				
Voltage unbalance	Negative Sequence, zero Sequence			
current unbalance	Negative Sequence, zero Sequence			
Max.&Min.				
Phase Voltage	U1,U2,U3,AVG			
Line Voltage	U12,U23,U31,AVG			
Current	I1,I2,I3,AVG,IN			
Active power	P1,P2,P3,∑			
Reactive power	Q1,Q2,Q3,∑			
Apparent power	S1,S2,S3,∑			



3.3 Accuracy and Certification

Measuring accuracy				
current measurement accuracy	0.1%+Accuracy of current sensor			
Voltage measurement accuracy	•			
•	±0.2%(60V~600V AC)			
Grid frequency	±0.01%(45~65Hz)			
Power factor	±0.005			
Active and apparent power	IEC62053-22 level 0.5S			
Reactive power	IEC62053-21 level 1S			
Active energy	IEC62053-22 level 0.5S			
Reactive energy	IEC62053-21 level 1S			
Environment condition				
Operating temperature	-20°C∼+70°C			
Storage temperature	-40°C∼+85°C			
Humidity range	5~95% RH, 50°C(non-condensing)			
Class of pollution	2			
Over voltage capability	CAT III 1000V, It is suitable for distribution system			
	below 277 / 480VAC			
Insulation strength	IEC61010-1			
Altitude	3000m Max			
Antipollution level	IP20 (Meet the standard of IEC 60629)			
Quality guarantee period	12 months			
EMC (electromagnetic compat	ibility)			
Electrostatic discharge	Level IV(IEC61000-4-2)			
Radiated immunity	Level III (IEC61000-4-3)			
EFT Electrical fast burst immunity	Level IV (IEC61000-4-4)			
Surge immunity	Level IV (IEC61000-4-5)			
Conducted disturbance immunity	Level III (IEC61000-4-6)			
Power frequency magnetic field immunity	0.5mT (IEC61000-4-8)			
Conduction and radiation	Class B (EN55022)			
Measurement standard				
EN 62052-11, EN 61557-12, EN 62053-21, EN 62053-22, EN 62053-23, EN 50470-1, EN 50470-3, EN 61010-1, EN 61010-2, EN 61010-031				



Part 5: Communication Description

5.1 Communication Standards:

- Network Compatibility: GPRS/GSM, 2G, and 4G networks.
- Cellular Bands:
 - GSM/EDGE:850,900,1800MHz.
 - WCDMA:B1,B2,B5,B8.
 - FDD-LTE:B1,B3,B4,B5,B7,B8,B28.
 - TDD-LTE:B40.
- **Protocol**: Uses **IEC60870-5-104**, where the indicator serves as the **Master** and the SCADA system as the **Slave**.

5.2 SIM Card



- When inserting/removing a SIM card, make sure the device is turned off.
- Make sure the device is placed flatly like the above picture when inserting or removing SIM card.



5.3 LED Indicator



LED Indicator Introduction						
		Status	Description			
PWR	Power	Always ON	Power on			
PWK	Supply	OFF	Failure			
DUN	Dunning	Flickering	Device is running			
RUN	Running	OFF	Failure			
		Eliaka sina	Ethernet			
I TNUZ	Ethernet,	Flickering	communication			
LINK	4G, WiFi	Always ON	4G or WiFi is working			
		OFF	Failure			

5.4WAN Port and LAN Port:


Ethernet Port								
Indicator	Color	Status	Description					
Speed	C	Always ON	100Mbps mode					
	Green	OFF	10Mbps mode					
		Always ON	Connected					
LINK	Yellow	Flickering	Transmitting data					
		OFF	Connection disconnected					



5.5 Configuration Software:


WAN port IP is retrieved automatically, LAN port IP is 192.168.3.1

Connect to a router or switch, or connect directly as follows:



5.6 Cellular Network Registeration:

Set the APN of the SIM card, you don't need to set this if the device doesn't come with a 4G module. It's not necessary to set APN for some 4G network operators.



	4G Settings						
Function	Description						
APN	SIM card Internet access point						
User	SIM card user name						
Password	SIM card password						



5.7IEC104 Signals List:

5.7.1 Voltage, current, power, power factor

Alias	IOA	R/W	Size	Туре	Unit	Description		
Current								
I1	1000	R	2	Float32	A	Phase L1 current		
12	1002	R	2	Float32	A	Phase L2 current		
I3	1004	R	2	Float32	A	Phase L3 current		
Current Avg	1006	R	2	Float32	A	Average value of L1L2L3 three-phase current		
IN	1008	R	2	Float32	A	Phase N current		
Phase voltage	Phase voltage							
U1	1010	R	2	Float32	V	U1-UN voltage		
U2	1012	R	2	Float32	V	U2-UN voltage		
U3	1014	R	2	Float32	V	U3-UN voltage		
Phase Voltage Avg	1016	R	2	Float32	V	Average value of L1L2L3 three-phase phase voltage		
U0	1018	R	2	Float32	V	zero sequence voltage		
Line voltage								
U12	1020	R	2	Float32	V	U1-U2 voltage		
U23	1022	R	2	Float32	V	U2-U3 voltage		
U31	1024	R	2	Float32	V	U3-U1 voltage		
Line Voltage Avg	1026	R	2	Float32	v	Average value of three-phase line voltage		
Active power								
P1	1028	R	2	Float32	kW	Phase L1 Active power		
P2	1030	R	2	Float32	kW	Phase L2 Active power		
Р3	1032	R	2	Float32	kW	Phase L3 Active power		
PTotal	1034	R	2	Float32	kW	Total Active power		

Q1	1036	R	2	Float32	kVA R	Phase L1 Reactive power
Q2	1038	R	2	Float32	kVA R	Phase L2 Reactive power
Q3	1040	R	2	Float32	kVA R	Phase L3 Reactive power
QTotal	1042	R	2	Float32	kVA R	Total Reactive power

	1		1	1	•			
S2	1046	R	2	Float32	kVA	Phase L2 Reactive power		
S3	1048	R	2	Float32	kVA	Phase L3 Reactive power		
STotal	1050	R	2	Float32	kVA	Total Reactive power		
Power factor								
PF1	1052	R	2	Float32	-	Phase L1 Power factor		
PF2	1054	R	2	Float32	-	Phase L2 Power factor		
PF3	1056	R	2	Float32	-	Phase L3 Power factor		
PFTotal	1058	R	2	Float32	-	Total Power factor		
Fundament	al harmonic	power f	actor					
DPF1	1060	R	2	Float32	-	Phase L1 Fundamental harmonic power factor		
DPF2	1062	R	2	Float32	-	Phase L2 Fundamental harmonic power factor		
DPF3	1064	R	2	Float32	-	Phase L3 Fundamental harmonic power factor		
DPFTotal	1066	R	2	Float32	-	Total Fundamental harmonic power factor		
Frequency	Frequency							
Freq1	1068	R	2	Float32	Hz	Phase L1 Frequency		
Freq2	1070	R	2	Float32	Hz	Phase L2 Frequency		
Freq3	1072	R	2	Float32	Hz	Phase L3 Frequency		
FreqTotal	1074	R	2	Float32	Hz	Total Frequency		



5.7.2 Energy

There are two types of energy, possive energy and reverse energy.

When the total electric energy reaches 1.0×10^9 kwh, 1.0×10^9 kvarh, or 1.0×10^9 KVAh, the electric energy of each phase will be cleared automatically.

Alias	IOA	R/W	Size	Type	Unit	Description				
UInt32 Ener	rgy									
Active Energ	Active Energy- UInt32									
EP1Imp	2600	R	2	UInt32	kWh	Phase L1 Positive active energy				
EP2Imp	2602	R	2	UInt32	kWh	Phase L2 Positive active energy				
EP3Imp	2604	R	2	UInt32	kWh	Phase L3 Positive active energy				
EPImp	2606	R	2	UInt32	kWh	Total Positive active energy				
EP1Exp	2608	R	2	UInt32	kWh	Phase L1 Reverse active energy				
EP2Exp	2610	R	2	UInt32	kWh	Phase L2 Reverse active energy				
EP3Exp	2612	R	2	UInt32	kWh	Phase L3 Reverse active energy				
EPExp	2614	R	2	UInt32	kWh	Total Reverse active energy				
Reactive ene	Reactive energy- UInt32									
EQ1Imp	2616	R	2	UInt32	kVARh	Phase L1 Positive reactive				
EQ2Imp	2618	R	2	UInt32	kVARh	Phase L2 Positive reactive energy				
EQ3Imp	2620	R	2	UInt32	kVARh	Phase L3 Positive reactive energy				
EQImp	2622	R	2	UInt32	kVARh	Total Positive reactive energy				
EQ1Exp	2624	R	2	UInt32	kVARh	Phase L1 Reverse reactive energy				
EQ2Exp	2626	R	2	UInt32	kVARh	Phase L2 Reverse reactive energy				
EQ3Exp	2628	R	2	UInt32	kVARh	Phase L3 Reverse reactive energy				
EQExp	2630	R	2	UInt32	kVARh	Total Reverse reactive energy				
Apparent E	nergy-UInt32									
ES1	2632	R	2	UInt32	kVAh	Phase L1 Apparent Energy				
ES2	2634	R	2	UInt32	kVAh	Phase L2 Apparent Energy				
ES3	2636	R	2	UInt32	kVAh	Phase L3 Apparent Energy				
ES	2638	R	2	UInt32	kVAh	Total Apparent Energy				



5.7.3 Tariff Energy

Tariff Energy types are Int64 and UInt32, whose unit size is different. When the rate of electricity reaches 1.0×10^9 kWh, 1.0×10^9 kVarh, or v1.0 x 10^9 kVah, each Tariff Energy will be automatically cleared to zero.

Alias	IOA	R/W	Size	Type	Unit	Description				
Tariff Energy-Int64										
ET1	2700	R	4	Int64	Wh	Tariff 1 Active Energy				
ET2	2704	R	4	Int64	Wh	Tariff 2 Active Energy				
ЕТ3	2708	R	4	Int64	Wh	Tariff 3 Active Energy				
ET4	2712	R	4	Int64	Wh	Tariff 4 Active Energy				
ET5	2716	R	4	Int64	Wh	Tariff 5 Active Energy				
ET6	2720	R	4	Int64	Wh	Tariff 6 Active Energy				
Tariff End	ergy-UInt32									
ET1	2750	R	2	UInt32	kWh	Tariff 1 Active Energy				
ET2	2752	R	2	UInt32	kWh	Tariff 2 Active Energy				
ЕТ3	2754	R	2	UInt32	kWh	Tariff 3 Active Energy				
ET4	2756	R	2	UInt32	kWh	Tariff 4 Active Energy				
ET5	2758	R	2	UInt32	kWh	Tariff 5 Active Energy				
ET6	2760	R	2	UInt32	kWh	Tariff 6 Active Energy				



5.7.4 Demand register

Alias	IOA	R/W	Size	Type	Unit	Description					
Basic parameters	Basic parameters of demand										
DMDMethod	3000	R/WC	1	UInt16	-	Demand calculation method: 0= sliding type 1= fixed					
DMD block	3001	R/RC	1	UInt16	Minute	Demand interval					
PDMD Reset Time	3002	R	4	Date time	-	Peak demand reset date and time					
Power demand											
P1Demand	3020	R	2	Float32	kW	Current active power demand of phase L1					
P1PeakDemand	3022	R	2	Float32	kW	Peak demand of phase L1 active power					
P1PeakDemand Date	3024	R	4	Date time	-	Occurrence time of peak demand of phase L1 active power					
P2Demand	3028	R	2	Float32	kW	Current active power demand of phase 2					
P2PeakDemand	3030	R	2	Float32	kW	Peak demand of phase 2 active power					
P2PeakDemand Date	3032	R	4	Date time	-	Occurrence time of peak demand of phase 2 active power					
P3Demand	3036	R	2	Float32	kW	Current active power demand of phase 3					
P3PeakDemand	3038	R	2	Float32	kW	Peak demand of phase 3 active power					
P3PeakDemand Date	3040	R	4	Date time	-	Occurrence time of peak demand of phase 3 active power					
PSUMDemand	3044	R	2	Float32	kW	Current total active power demand					

PSUMPeakDem	2046			FI 422	1 ***	Peak demand of total active
and	3046	R	2	Float32	kW	power
PSUMPeakDem andDate	3048	R	4	Date time	-	Occurrence time of peak demand of total active power
Q1Demand	3052	R	2	Float32	kVar	Current reactive power demand of phase L1
Q1PeakDemand	3054	R	2	Float32	kVar	Peak demand of phase L1 reactive power
Q1PeakDemand Date	3056	R	4	Date time	-	Occurrence time of peak demand of phase L1 reactive power
Q2Demand	3060	R	2	Float32	kVar	Current reactive power demand of phase L2
Q2PeakDemand	3062	R	2	Float32	kVar	Peak demand of phase L2 reactive power
Q2PeakDemand Date	3064	R	4	Date time	1	Occurrence time of peak demand of phase L2 reactive power
Q3Demand	3068	R	2	Float32	kVar	Current reactive power demand of phase L3
Q3PeakDemand	3070	R	2	Float32	kVar	Peak demand of phase L3 reactive power
Q3PeakDemand Date	3072	R	4	Date time	1	Occurrence time of peak demand of phase L3 reactive power
QSUMDemand	3076	R	2	Float32	kVar	Current total reactive power demand
QSUMPeakDem and	3078	R	2	Float32	kVar	Peak demand of total reactive power
QSUMPeakDem andDate	3080	R	4	Date time	-	Occurrence time of peak demand of total reactive power
S1Demand	3084	R	2	Float32	kVa	Current apparent power demand of phase L1
S1PeakDemand	3086	R	2	Float32	kVa	Peak demand of phase L1 apparent power
S1PeakDemand Date	3088	R	4	Date time	-	Occurrence time of peak demand of phase L1 apparent power
S2Demand	3092	R	2	Float32	kVa	Current apparent power demand of phase L2
S2PeakDemand	3094	R	2	Float32	kVa	Peak demand of phase L2 apparent power
S2PeakDemand Date	3096	R	4	Date time	-	Occurrence time of peak demand of phase L2 apparent power



Alias	IOA	R/W	Size	Type	Unit	Description
S3Demand	3100	R	2	Float32	kVa	Current apparent power demand of phase L3
S3PeakDemand	3102	R	2	Float32	kVa	Peak demand of phase L3 apparent power
S3PeakDemand Date	3104	R	4	Date time	-	Occurrence time of peak demand of phase L3 apparent power
SSUMDemand	3108	R	2	Float32	kVa	Current total apparent power demand
SSUMPeakDem and	3110	R	2	Float32	kVa	Peak demand of total apparent power
SSUMPeakDem andDate	3112	R	4	Date time	-	Occurrence time of peak demand of total apparent power

5.7.5 Voltage and current harmonic register

Alias	IOA	R/W	Size	Type	Unit	Description				
Current harmonic percentage										
I1THD	4000	R	2	Float32	%	Phase L1 current total harmonic percentage				
I2THD	4002	R	2	Float32	%	Phase L2 current total harmonic percentage				
I3THD	4004	R	2	Float32	%	Phase L3 current total harmonic percentage				
I1TOHD	4006	R	2	Float32	%	Phase L1 current odd total harmonic percentage				
I2TOHD	4008	R	2	Float32	%	Phaese L2 current odd total harmonic percentage				
ІЗТОНD	4010	R	2	Float32	%	Phase L3 current odd total harmonic percentage				
I1TEHD	4012	R	2	Float32	%	Phase L1 current even total harmonic percentage				
I2TEHD	4014	R	2	Float32	%	Phase L2 current even total harmonic percentage				
ІЗТЕНО	4016	R	2	Float32	%	Phsee L3 curremt even total harmonic percentage				
I1HD1	4018	R	2	Float32	%	1st harmonic percentage of phase L1 current				
I2HD1	4020	R	2	Float32	%	1st harmonic percentage of phase L2 current				



4022	R	2	Float32	%	1st harmonic percentage of phase L3 current				
4024-4311	•••	•••	•••	•••	The 2nd-49th harmonic percentage of L1L2L3 phase current				
4312	R	2	Float32	%	The 50th harmonic percentage of phase L1 current				
4314	R	2	Float32	%	The 50th harmonic percentage of phase L2 current				
4316	R	2	Float32	%	The 50th harmonic percentage of phase L3 current				
Current harmonic value									
4400	R	2	Float32	A	Fundamental current value of phase L1 current				
4402	R	2	Float32	A	Fundamental current value of phase L2 current				
4404	R	2	Float32	A	Fundamental current value of phase L3 current				
4406-4693	•••	•••		•••	The 2nd-49th harmonic current value of L1L2L3 phase current				
4694	R	2	Float32	A	The 50th harmonic current value of phase L1 current				
4696	R	2	Float32	A	The 50th harmonic current value of phase L2 current				
4698	R	2	Float32	A	The 50th harmonic current value of phase L3 current				
nonic percent	age								
5000	R	2	Float32	%	Phase L1 volage total harmonic percentage				
5002	R	2	Float32	%	Phase L2 voltage total harmonic percentage				
5004	R	2	Float32	%	Phase L3 voltage votal harmonic percentage				
5006	R	2	Float32	%	Phase L1 voltage odd total harmonic percentage				
5008	R	2	Float32	%	Phase L2 voltage odd total harmonic percentage				
5010	R	2	Float32	%	Phase L3 voltage odd total harmonic percentage				
5012	R	2	Float32	%	Phase L1 voltage even total harmonic percentage				
5014	R	2	Float32	%	Phase L2 voltage even total harmonic percentage				
	4024-4311 4312 4314 4316 monic value 4400 4402 4404 4406-4693 4694 4696 4698 monic percent 5000 5002 5004 5006 5008 5010	4024-4311 4312 R 4314 R 4316 R monic value 4400 R 4402 R 4404 R 4406-4693 4694 R 4696 R 4698 R monic percentage 5000 R 5002 R 5004 R 5006 R 5008 R 5010 R	4024-4311	4024-4311	4024-4311				



U3TEHD	5016	R	2	Float32	%	Phase L3 voltage even total harmonic percentage
U1HD1	5018	R	2	Float32	%	The 1st harmonic percentage of phase L1 voltage
U2HD1	5020	R	2	Float32	%	The 1st harmonic percentage of phase L2 voltage
U3HD1	5022	R	2	Float32	%	The 1st harmonic percentage of phase L3 voltage
	5024-5311	•••	•••	•••	•••	The 2nd-49th harmonic percentage of L1L2L3 phase voltage
U1HD50	5312	R	2	Float32	%	The 50th harmonic percentage of phase L1 voltage
U2HD50	5314	R	2	Float32	%	The 50th harmonic percentage of phase L2 voltage
U3HD50	5316	R	2	Float32	%	The 50th harmonic percentage of phase L3 voltage
Voltage hari	monic value					
U1HDV1	5400	R	2	Float32	V	The 1st harmonic voltage value of phase L1 voltage
U2HDV1	5402	R	2	Float32	V	The 1st harmonic voltage value of phase L2 voltage
U3HDV1	5404	R	2	Float32	V	The 1st harmonic voltage value of phase L3 voltage
	5406-5693					The 2nd-49th harmonic voltage value of L1L2L3 phase voltage
U1HDV50	5694	R	2	Float32	v	The 50th harmonic voltage value of phase L1 voltage
U2HDV50	5696	R	2	Float32	V	The 50th harmonic voltage value of phase L2 voltage
U3HDV50	5698	R	2	Float32	V	The 50th harmonic voltage value of phase L3 voltage

5.7.6 Max.&Min.

Alias	IOA	R/W	Size	Type	Unit	Description				
Current max/min										
I1Max	6000	R	2	Float32	A	Phase L1 Maximum current				
I2Max	6002	R	2	Float32	A	Phase L2 Maximum current				
I3Max	6004	R	2	Float32	A	Phase L3 Maximum current				



I1VGMax	6006	R	2	Float32	A	Maximum three phase average current				
IN Max	6008	R	2	Float32	A	Phase N Maximum current				
I1Min	6010	R	2	Float32	A	Phase L1 Minimum current				
I2Min	6012	R	2	Float32	A	Phase L2 Minimum current				
I3Min	6014	R	2	Float32	A	Phase L3 Minimum current				
I1VGMin	6016	R	2	Float32	A	Minimum three phase average current				
IN Min	6018	R	2	Float32	A	Phase N Minimum current				
Voltage max / n	Voltage max / min									
U1Max	6020	R	2	Float32	V	U1-UN Maximum phase voltage				
U2Max	6022	R	2	Float32	V	U2-UN Maximum phase voltage				
U3Max	6024	R	2	Float32	V	U3-UN Maximum phase voltage				
Phase UAVG Max	6026	R	2	Float32	v	Maximum value of average value of three-phase phase voltage.				
U1Min	6030	R	2	Float32	V	U1-UN Minimum phase voltage				
U2Min	6032	R	2	Float32	V	U2-UN Minimum phase voltage				
U3Min	6034	R	2	Float32	V	U3-UN Minimum phase voltage				
U1VGMin	6036	R	2	Float32	V	Minimum value of average value of three-phase phase voltage.				
U12Max	6040	R	2	Float32	V	U1-U2 Maximum wire voltage				
U23Max	6042	R	2	Float32	V	U2-U3 Maximum wire voltage				
U31Max	6044	R	2	Float32	V	U3-U1 Maximum wire voltage				
LineUAVGMa x	6046	R	2	Float32	V	Maximum value of average value of three-phase phase voltage.				
U12Min	6050	R	2	Float32	V	U1-U2 Minimum phase voltage				
U23Min	6052	R	2	Float32	V	U2SS-U3 Minimum phase voltage				
U31Min	6054	R	2	Float32	V	U3-U1 Minimum phase voltage				
LineUAVGMi n	6056	R	2	Float32	V	Minimum value of average value of three-phase phase voltage.				
Maximum / mii	nimum power									
P1Max	6060	R	2	Float32	kW	Maximum active power of phase L1				
P2Max	6062	R	2	Float32	kW	Maximum active power of phase L2				
P3Max	6064	R	2	Float32	kW	Maximum active power of phase L3				
PSUMMax	6066	R	2	Float32	kW	Maximum value of three-phase total active power				
			_		_					

P1Min	6070	R	2	Float32	kW	Minimum active power of phase L1			
P2Min	6072	R	2	Float32	kW	Minimum active power of phase L2			
P3Min	6074	R	2	Float32	kW	Minimum active power of phase L3			
PSUMMin	6076	R	2	Float32	kW	Minimum value of three-phase total active power			
Reactive Power Max / min									
Q1Max	6080	R	2	Float32	kVar	Maximum value of phase L1 reactive power			
Q2Max	6082	R	2	Float32	kVar	Maximum value of phase L2 reactive powe			
Q3Max	6084	R	2	Float32	kVar	Maximum value of phase L3 reactive powe			
QSUMMax	6086	R	2	Float32	kVar	Maximum value of three-phase total reactive power			
Q1Min	6090	R	2	Float32	kVar	Minimum value of phase L1 reactive power			
Q2Min	6092	R	2	Float32	kVar	Minimum value of phase L2 reactive power			
Q3Min	6094	R	2	Float32	kVar	Minimum value of phase L3 reactive power			
QSUMMin	6096	R	2	Float32	kVar	Minimum value of three-phase total reactive power			
Apparent powe	r max / min								
S1Max	6100	R	2	Float32	kVa	Maximum apparent power of phase L1			
S2Max	6102	R	2	Float32	kVa	Maximum apparent power of phase L2			
S3Max	6104	R	2	Float32	kVa	Maximum apparent power of phase L3			
SSUMMax	6106	R	2	Float32	kVa	Maximum three-phase total apparent power			
S1Min	6110	R	2	Float32	kVa	Minimum apparent power of phase L1			
S2Min	6112	R	2	Float32	kVa	Minimum apparent power of phase L2			
S3Min	6114	R	2	Float32	kVa	Minimum apparent power of phase L3			
SSUMMin	6116	R	2	Float32	kVa	Minimum three phase total apparent power			



5.7.7 Unbalance

Alias	IOA	R/W	Size	Type	Unit	Description
Current negative sequence unbalance	7000	R	2	Float32	%	Current negative sequence unbalance
Current zero sequence unbalance	7002	R	2	Float32	%	Current zero sequence unbalance
Voltage negative sequence unbalance	7004	R	2	Float32	%	Voltage negative sequence unbalance
Voltage zero sequence unbalance	7006	R	2	Float32	%	Voltage zero sequence unbalance

5.7.8 Current K-factor and crest factor register

Alias	IOA	R/W	Size	Type	Unit	Description	
Current K factor							
KFI1	8000	R	2	Float32	-	Current K factor of phase L1	
KFI2	8002	R	2	Float32	-	Current K factor of phase L2	
KFI3	8004	R	2	Float32	-	Current K factor of phase L3	

5.7.9 Voltage and current angle register

Alias	IOA	R/W	Size	Type	Unit	Description	
Angle voltages:							
U1	8100	R	2	Float32	0	Angle phase L1 voltage	
U2	8102	R	2	Float32	0	Angle phase L2 voltage	
U3	8104	R	2	Float32	0	Angle phase L3 voltage	
Angle currents:							
I1	8106	R	2	Float32	0	Angle phase L1 current	
I2	8108	R	2	Float32	0	Angle phase L2 current	
13	8110	R	2	Float32	0	Angle phase L3 current	




Angle between voltage and current:							
UI1	8112	R	2	Float32	0	Angle between voltage and current of phase L1	
UI2	8114	R	2	Float32	0	Angle between voltage and current of phase L2	
UI3	8116	R	2	Float32	0	Angle between voltage and current of phase L3	




Part 6: Dimensions & Installation

1. Unit Dimensions:






2. Wiring System Connection diagram:






3. Current Sensor Installation Steps:





4. Terminal Block Connection:



Point number	Point name	Point function	Point type	Remarks	
1	Vn	N-phase voltage input			
2	V3	L3-phase voltage input	3 7.14	Measurement voltage input channel	
3	V2	L2-phase voltage input	Voltage input		
4	V1	L1-phase voltage input			
5	In+	Phase N current input positive			
6	In-	Phase N current input negative		Current channel	
7	I 3+	Phase L3 current input positive			
8	I3-	Phase L3 current input negative			
9	I2+	Phase L2 current input positive	Current input	Current channel	
10	12-	Phase L2 current input negative			
11	I1+	Phase L1 current input positive			
12	I1-	Phase L1 current input negative			



Part 6: Order Placement Tips

For orders, additional information or technical support, reach us on email, info@eecl.sa