UNIT L-53075 L-4994 47508
S.O. 82186

FORM P-2 MANUFACTURERS' DATA REPORT FOR ALL TYPES OF BOILERS EXCEPT WATER-TUBE

CB-500, 150 lbStm.

As Required by the Provisions of the ASME Code Rules

C18-8184 1-71

Part No. 270-461

1. Manufactured by Cleaver-Brooks Division of Aqua-Chem, Inc., Milwaukee, Wisconsin
(Name and address of manufacturer)

2. Manufactured for National Food Stores, Inc., Denver, Colorado
(Name and address of purchaser)

3. Type Internally Fired (H.R.T.-Loco.-Compact-Marine, Miniature) Boiler No. 47508 (Mfrs. Serial No.) (State and State No.) 25502 (Natl. Board No.) Year Built 1971

4. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section 1 Dated 1971

Remarks: Manufacturers' Data Records properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report:
(Name of Part — Item number, manufacturer's name, and identifying stamp)

We certify the statement in this data report to be correct.

Date September 17 19 71 Signed Cleaver-Brooks Division (Manufacturer) By Earl R. Stoudt (Representative)
Earl R. Stoudt

Certificate of Authorization Expires 1-15-74 19

CERTIFICATE OF SHOP INSPECTION

BOILER MADE BY Cleaver-Brooks Division at Lebanon, Pennsylvania

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of and employed by Hartford Steam Inspection & Insurance Co. of Hartford, Conn. have inspected parts of this boiler referred to as data items 1-9, 11, 16 & 19-23 and have examined manufacturer's partial data reports for items None and state that, to the best of my knowledge and belief, the manufacturer has constructed this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date September 17, 19 71

Frank Bergholm
Frank Bergholm
Inspector

Commissions PA HC 560 NB 3113
Natl. Board or State and No.

We certify that the field assembly of all parts of this boiler conforms with the requirements of SECTION I of the ASME BOILER AND PRESSURE VESSEL CODE.

Date 19 Signed (Assembler) By (Representative)

Our Certificate of Authorization to use the (A) or (S) Symbol Expires 19

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of and employed by of have compared the statements in this manufacturer's data report with the described boiler and state that the parts referred to as data items not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and/or the assembler has constructed and assembled this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described boiler was inspected and subjected to a hydrostatic test of psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19

Inspector Commissions
Natl. Board or State and No.

5. Boiler Shells or Drums: No. 1 Diam. 96" Length 168 In. Diam. Length Ft. In.

6. Shell Plates SA-515 GR. 70, 9/16" FBQ
(For each Drum, state Steel Manufacturer's Brand; Material Specification Number; Thickness)

7. (a) Longitudinal Joint Fusion double welded butt
(Seamless, Fusion or Forge Welded, Riveted-Lap or Butt-Single, Double, Triple or Quadruple)

(b) Rivets (Diameter and Material Specification No.) Rivet Holes (Diameter and Pitch) Eff. of Long. Joint 90 % (As compared to shell plates)

8. (a) Tube Sheet SA-285-C, 5/8" FBQ (Brand, Mat. Spec. No.; Thickness) Reinforcement (No. and Thickness of Straps) Rivets Fillet weld (No. Rows; Mat. Spec. No.; Hole Diam. & Pitch)

(b) Tube Holes 2.520" (Diameter) Pitch (Longitudinal and Girth) Eff. of Tube Ligament % (Compared to shell plate)

9. Girth Joints Fusion double welded butt (Seamless, Fusion or Forge Welded, Riveted-Lap or Butt) Rivet Holes No. of Courses 2

10. Heads

11. Boiler Tubes: No. SA-178-A, 273, Straight (Mat. Spec. No. Straight or Bent) Diam. 2-1/2" Length 168-5/8" (If various, give maximum and minimum lengths) Gage .105" (or thickness)

12. Headers: No. Heads or Ends Hydro. Test lb.

13. Mud Drum Heads or Ends Hydro. Test lb.

14. (a) Waterwall Headers, No. Heads or Ends Hydro. Test lb.

(b) Tube Holes Tubes Gage Heating Surface sq. ft.

15. (a) Superheater Headers, No. Heads or Ends Hydro. Test lb.

(b) Tube Holes Tubes Gage

16.

Stays or Braces	Material Spec. No.	Type	No.	Size	Welded or Weldless	Total Net Area	Fig. P-[illegible]	Dist. Tubes to Shell	Area to be Stayed	Max. S.W.P.
(a) F.H. above tubes	SA 31	Diag.	18	1-1/8	Weldless	17.67		24-1/4"	902	161 lb
(b) R.H. above tubes	SA 31	Diag.	18	1-1/8	Weldless	17.67		24-1/4"	902	161 lb
(c) F.H. below tubes										
(d) R.H. below tubes										
(e) Through below tubes										
(f) Dome Braces										

17. Staybolts Pitch Max. S.W.P.

18. (a) Dome: Diam. Longitudinal Seam Eff. % How secured to shell

(b) Opening in shell Head

19. (a) Furnace No. 1 Size 45" O.D. (Int. Diam. or LxWxH) Length, each Section in. in., Total 168¼". Type Corr. (Plain, Adamson, or Corr.)

SA-285-C, .415 FBQ (Brand, Mat. Spec. No.; Thickness) (b) Seams: Type Fusion double welded butt (Seamless Fusion or Forge W., Riveted, Lap or Butt) Location Longitudinal (Seam)

20. Openings: (a) Steam 1 @ 8" 300 lb. Flange (No., Size, and Type of Nozzles or Outlets) (b) Safety Valve 1 @ 3" NPT 2 @ 2-1/2" NPT (No., Size and Type of Nozzles or Outlets)

(c) Blowoff 2 @ 2" NPT Bottom ℄ (No., Size, Type and Location of Outlets) (d) Feed 2 @ 2-1/2 NPT (No., Size, Type and Location of Connections)

(e) Manholes: No. 1 Size 11" x 15" Location Shell – Ring (How Reinforced)

(f) Handholes: No. 6 Size 3-1/4" x 4-1/2" Location Shell (How Reinforced)

No connections to Item 20.

21. Fusible Plug (If Used) (No., Diam., Location, Mfgs. Stamp) Boiler Supports: No. 4 Legs (Hangers or Lugs; Riveted or Welded)

22. Max. AWP 150 psi Based on PG-27 (Code Par. and/or Formula) Heating Surface 2500 sq. ft. (Total)

23. Hydrostatic Test: (a) lb. (Welded Drums) (b) lb. (Riveted Drums) (c) 225 lb. (Completed Boiler)

Printed in U.S.A.