L-5250 47510

UNIT L-53197
S.O. 84026

100, 30 lb Water H.W.

FORM P-2 MANUFACTURERS' DATA REPORT FOR ALL TYPES OF BOILERS EXCEPT WATER-TUBE

C18-883A 10/67 Printed in U.S.A. As Required by the Provisions of the ASME Code Rules Part No. 270-89

1. Manufactured by Cleaver-Brooks Division of Aqua-Chem, Inc., Milwaukee, Wisconsin
(Name and address of manufacturer)

2. Manufactured for Newburg School Louisville, Kentucky
(Name and address of purchaser)

3. Type Internally Fired Boiler No. 47510 25503 Year Built 1971
(H.R.T.-Loco.-Compact-Marine, Miniature) (Mfrs Serial No.) (State and State No.) (Natl. Board No.)

4. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section IV (I or IV) dated 19 71

Remarks: Manufacturers' Data Records properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report:
(Name of Part – Item number, manufacturer's name, and identifying stamp)

We certify the statement in this data report to be correct.

Date September 16, 19 71 Signed Cleaver-Brooks Division By Earl R. Stoudt
(Manufacturer) Earl R. Stoudt (Representative)

Certificate of Authorization Expires ~~December 31~~ 1-15-74 19

CERTIFICATE OF SHOP INSPECTION

BOILER MADE BY Cleaver-Brooks Division at Lebanon, Pennsylvania

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and or the State or Province of and employed by Hartford Steam Boiler Inspection & Insurance Co. of Hartford, Conn. have inspected parts of this boiler referred to as data items 1-9, 11, 16, & 19-24 and have examined manufacturer's partial data reports for items None and state that, to the best of my knowledge and belief, the manufacturer has constructed this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date September 16, 19 71 Commissions PA WC 560 NB 3113
Frank Bergholm Natl. Board or State and No.

We certify that the field assembly of all parts of this boiler conforms with the requirements of SECTION I or IV of the ASME BOILER AND PRESSURE VESSEL CODE.

Date 19 Signed By
(Assembler) (Representative)

Our Certificate of Authorization to use the (A) or (S) Symbol Expires 19

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of and employed by of have compared the statements in this manufacturer's data report with the described boiler and state that the parts referred to as data items , not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and/or the assembler has constructed and assembled this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described boiler was inspected and subjected to a hydrostatic test of psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19

Inspector Commissions Natl. Board or State and No.

5. Boiler Shells or Drums: No. 1 Diam. 48" Length 140 Ft. Diam. Length Ft.

6. Shell Plates SA-36, 5/16" (If each Drum, state: Fixed Manufacturer's Name, Material Specification Number, Thickness)

7. (a) Longitudinal Joint Fusion double welded butt (Seamless, Fusion or Forge Welded, Riveted—Lap or Butt—Single, Double, Triple or Quadruple)

(b) Rivets (Diameter and Material Specification No.) Rivet Holes (Diameters and Pitch) Eff. of Long. Joint 85 % (As compared to shell plates)

8. (a) Tube Sheet SA-285-C, [illegible] 1/2" FVO (Brand, Mat. Spec. No., Thickness) Reinforcement (No. and Thickness of Straps) Rivets Fillet weld (No. Rows; Mat. Spec. No.; Hole Diam. and Pitch)

(b) Tube Holes 2.520" (Diameter) Pitch (Longitudinal and Girth) Eff. of Tube Ligament % (Compared to shell plate)

9. Girth Joints Fusion double welded butt (Seamless, Fusion or Forge Welded, Riveted—Lap or Butt) Rivet Holes (No. rows — Diam. and Pitch) No. of Courses 2

10. Heads

11. Boiler Tubes: No. SA-178-A, 62, Straight (Mat. Spec. No.—Straight or Bent) Diam. 2-1/2" Length 140-5/8" (If various, give maximum and minimum lengths) Gage .105" (or thicknesses)

12. Headers: No. Heads or Ends Hydro. Test lb.
13. Mud Drum Heads or Ends Hydro. Test lb.
14. (a) Waterwall: Headers, No. Heads or Ends Hydro. Test lb.
(b) Tubes Plugged Tubes Gage Heating Surface sq. ft.
15. (a) Superheater: Headers, No. Heads or Ends Hydro. Test lb.
(b) Tube Holes Tubes Gage

16.

Stays or Braces	Material Spec. No.	Type	No.	Size	Fastened or Welded	Total Net Area	Freq. P-20 [illegible]	Dist. Tubes to Shell	Area to be Stayed	Max. S.W.P.
(a) R.H. above tubes			0			0		13"	0	30 lb
(b) R.H. above tubes			0			0		13"	0	30 lb
(c) F.H. below tubes										
(d) R.H. below tubes										
(e) Through below tubes										
(f) Dome braces										

17. Staybolts Pitch Max. S.W.P.

18. (a) Dished Heads Diam. Longitudinal Seam Eff. % How secured to shell
(b) Bracing in shell Head

19. (a) Furnace: No. 1 Size 20" O.D. (Int. Diam. or L x W x H) Length, each Section, front [illegible] in., rear [illegible] in., Total 140-1/4" Type Plain (Plain, Adamson, or Corr.)

GR. B SA-53 .312" (Mat. and Mat. Spec. No., Thickness) (b) Seams: Type Seamless (Seamless Fusion or Forge W., Riveted, Lap or Butt) Location (Seam)

20. Openings (a) Water 2 @ 4" NPT (Outlet & Return) 1-1/2" (No., Size, and Type of Nozzles or Outlets) (b) Safety Valve 1 @ 2" NPT (No., Size, and Type of Nozzles or Outlets)

(c) Blowoff 2 @ [illegible]" NPT Bottom (No., Size, Type, and Location of Outlets) (d) Feed 2 @ 1-1/4" NPT (No., Size, Type, and Location of Connections)

(e) Manholes: No. None Size Location (How Reinforced)

(f) Handholes: No. 7 Size 3- 4" x 4-1/2" Location Shell (How reinforced)

21. Fusible Plug (If Used) (No., Diam., Location, Mfrs. Stamp) Boiler Supports: No. 4 Legs (Hangers or Lugs; Riveted or Welded)

22. Max AWP 30 Water psi Based on HG-[illegible] 312 (Code Par. and/or Formula) Heating Surface 500 sq ft (Total)

23. Hydrostatic Test: (a) lb. (Welded Drums) (b) lb. (Riveted Drums) (c) 60 lb (Completed Boiler)