L-5616 47511

UNIT L-53191
S.O. 84015

~~50,~~ 30 lb Water

FORM P-2 MANUFACTURERS' DATA REPORT FOR ALL TYPES OF BOILERS EXCEPT WATER-TUBE

C18-579A 7/66 Printed in U.S.A. **As Required by the Provisions of the ASME Code Rules** Part No. 27085

1. Manufactured by Cleaver-Brooks Company, Milwaukee, Wisconsin
(Name and address of manufacturer)

2. Manufactured for **North Davis Sewage Treatment Plant Syracuse, Utah**
(Name and address of purchaser)

3. Type Internally Fired Boiler No. 47511 25504 Year Built 1971
(H R T -Loco -Compact-Marine, Miniature) (Mfrs. Serial No.) (State and State No.) (Natl. Board No.)

4. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section IV (I or IV) dated 19 71

Remarks: Manufacturers' Data Records properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report:
(Name of Part – Item number, manufacturer's name, and identifying stamp)

We certify the statement in this data report to be correct

Date September 16, 19 71 Signed Cleaver-Brooks Company (Manufacturer) By Earl R Stoudt
Earl R. St[illegible] (Representative)

Certificate of Authorization Expires ~~XXXXXXXXXXXX~~ 19

CERTIFICATE OF SHOP INSPECTION

BOILER MADE BY Cleaver-Brooks Company at Lebanon, Pennsylvania

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of and employed by Hartford Steam Boiler Inspection & Insurance Co of Hartford, Conn. have inspected parts of this boiler referred to as data items 1-9, 11, 16, & 19-24 and have examined manufacturer's partial data reports for items None and state that, to the best of my knowledge and belief, the manufacturer has constructed this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date September 16, 19 71

Frank Bergholm
Frank Bergholm

Commissions PA WC 560 NB 3113
Natl. Board or State and No.

We certify that the field assembly of all parts of this boiler conforms with the requirements of SECTION I of the ASME BOILER AND PRESSURE VESSEL CODE.

Date 19 Signed (Assembler) By (Representative)

Our Certificate of Authorization to use the (A or S) Symbol Expires 19

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of and employed by of have compared the statements in this manufacturer's data report with the described boiler and state that the parts referred to as data items , not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and/or the assembler has constructed and assembled this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described boiler was inspected and subjected to a hydrostatic test of psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19

Inspector Commissions Natl. Board or State and No.

5. Boiler Shell or Drums No. 1 Diam. 48" Length 82 Diam. Length Ft. In.

6. Shell Plates [redacted] SA-36 5/16"
(No. Each Shell, Drum; Brand, Material Specification Number, Thickness)

7. (a) Longitudinal Joint Fusion double welded butt
(Seamless, Fusion or Forge Welded, Riveted—Lap or Butt—Single, Double, Triple or Quadruple)

(b) Rivets (Diameter and Material Specification No.) River Holes (Number and Pitch) Eff. of Long. Joint [redacted] 85 % (As compared to shell plates)

8. (a) Tube Sheet SA-285-C, [redacted] 1/2" (Brand, Mat. Spec. No., Thickness) Reinforcement (No. and Thickness of Straps) Rivets Fillet weld (No. Rows; Mat. Spec. No., Hole Diam. and Pitch)

(b) Tube Holes 2,520" (Diameter) Pitch (Longitudinal and Girth) Eff. of Tube Ligament % (Compared to shell plate)

9. Girth Joints (Seamless, Fusion or Forge Welded, Riveted—Lap or Butt) River Holes (No. rows — Diam. and Pitch) No. of Courses 1

10. Heads

11. Boiler Tubes: No. SA-178-A, 49, Straight (Mat. Spec. No.—Straight or Bent) Diam. 2-1/2" Length 82-5/8" (If various, give maximum and minimum lengths) Gage .105" (or thickness)

12. Headers: No. Heads or Ends Hydro. Test lb.
13. Mud Drum Heads or Ends Hydro. Test lb.
14. (a) Waterwall: Headers, No. Heads or Ends Hydro. Test lb.
(b) Tube Holes Tubes Gage Heating Surface sq. ft.
15. (a) Superheater: Headers, No. Heads or Ends Hydro. Test lb.
(b) Tube Holes Tubes Gage

16.

Stays or Braces	Material Spec. No.	Type	No.	Size	Welded or Weldless	Total Net Area	Fig. P-28 L/l	Dist. Tubes to Shell	Area to be Stayed	Max. S.W.P.
(a) F.H. above tubes		-	0			0		13"	0	30 lb
(b) R.H. above tubes		-	0			0		13"	0	30 lb
(c) F.H. below tubes										
(d) R.H. below tubes										
(e) Through below tubes										
(f) Dome braces										

17. Staybolts Pitch Max. S.W.P.
18. (a) Dome Diam. Longitudinal Seam Eff. % How secured to shell
(b) Opening in Shell Head

19. (a) Furnace No. 1 Size 20" O.D. (or Diam. or L x B x H) Length each Section Total 82-1/4" Type Plain (Plain, Adamson, or Corr.)

SA-53 .312" (Brand, Mat. Spec. No. Thickness) Gr. B (b) Seams Type Seamless (Seamless Fusion or Forge W. Riveted, Lap or Butt) Location (Seam)

20. Openings (a) Water 2 @ 4" NPT (Outlet & Return) (No. Size and Type of Nozzles or Outlets) (b) Safety Valve 1 - 1-1/2" NPT (No. Size and Type of Nozzles or Outlets)

(c) Blowoff 2 @ 1-1/4" NPT Bottom ℄ (No. Size Type and Location of Outlets) (d) Feed 2 - 1-1/4" NPT (No. Size, Type, and Location of Connections)

(e) Manholes No. None Size Location (How Reinforced)

(f) Handholes No. [redacted] 6 Size 3-1/4" x 4-1/2" Location Shell (How reinforced)

21. Fusible Plug (If Used) (No., Diam., Location, Mfr. Stamp) Boiler Supports No. 4 Legs (Hangers or Lugs, Riveted or Welded)

22. Fusion Welding Complies with Paragraphs Applicable Paragraphs of Section IV

23. Max AWP 30 Water psi Based on [redacted] HG-340 (Code Par. and/or Formula) Heating Surface 250 sq. ft. (Total)

24. Hydrostatic Test (a) lb. (Welded Drums) (b) lb. (Riveted Drums) (c) 60 lb (Completed Boiler)