UNIT L-53081 "87 L-5508 47515
S.O. X-82270 300, 200# Stm.

FORM P-2 MANUFACTURERS' DATA REPORT FOR ALL TYPES OF BOILERS EXCEPT WATER-TUBE

C12.3324 10-70 Printed in U.S.A. As Required by the Provisions of the ASME Code Rules Part No. 270- 419

1 Manufactured by Cleaver-Brooks Division of Aqua-Chem, Inc., Milwaukee, Wisconsin
(Name and address of manufacturer)

2. Manufactured for Inredeco, Inc. Panama
(Name and address of purchaser)

3. Type Internally Fired Boiler No. 47515 25508 Year Built 1971
(H R T - Loco - Compact - Marine, Miniature) (Mfrs. Serial No.) (State and State No.) (Natl. Board No.)

4. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section I dated 1971

Remarks: Manufacturers' Data Records properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report:
(Name of Part – Item number, manufacturer's name, and identifying stamp)

We certify the statement in this data report to be correct.

Date September 17, 1971 Signed Cleaver-Brooks Division of Aqua-Chem, Inc. By Earl R Stoudt
(Manufacturer) (Representative)

Certificate of Authorization Expires Earl R. Stoudt 1-15-74 19

CERTIFICATE OF SHOP INSPECTION

BOILER MADE BY Cleaver-Brooks Division of Aqua-Chem, Inc. at Lebanon, Pennsylvania

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of and employed by Hartford Steam Boiler Inspection & Insurance Co. of Hartford, Conn.

have inspected parts of this boiler referred to as data items 1-9, 11, 16, & 19-23 and have examined manufacturer's partial data reports for items None and state that, to the best of my knowledge and belief, the manufacturer has constructed this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date September 17 19 71 Frank Bergeron

Commissions PA MC 560 MB 3113
Natl. Board or State and No.

We certify that the field assembly of all parts of this boiler conforms with the requirements of SECTION I of the ASME BOILER AND AND PRESSURE VESSEL CODE.

Date 19 Signed By
(Assembler) (Representative)

Our Certificate of Authorization to use the (A) or (S) Symbol Expires 19

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of and employed by of have compared the statements in this manufacturer's data report with the described boiler and state that the parts referred to as data items not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and/or the assembler has constructed and assembled this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described boiler was inspected and subjected to a hydrostatic test of psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19

Commissions

Inspector Natl. Board or State and No.

5. Boiler Shells or Drums: No. 1 Diam. 78" Length 156-3/4" (1) Diam. ____ Length ____ Ft. ____ In. ____

6. SA 515-70 FVQ 5/8"
(For each Drum, state: Drum Identification, Brand, Material Specification Number, Thickness)

7. (a) Longitudinal Joint Fusion double welded butt
(Seamless, Fusion or Forge Welded, Riveted—Lap or Butt—Single, Double, Triple or Quadruple)

(b) Rivets ____ Rivet Holes ____ Eff. of Long. Joint 90 %
(Diameter and Material Specification No.) (Diameter and Pitch) (As compared to shell plates)

8. (a) Tube Sheet SA 285-C FVQ 5/8" Reinforcement ____ Rivets Fillet weld
(Brand, Mat. Spec. No.; Thickness) (No. and Thickness of Straps) (No. Rows; Mat. Spec. No.; Hole Diam. and Pitch)

(b) Tube Holes 2.520" Pitch ____ Eff. of Tube Ligament ____ %
(Diameter) (Longitudinal and Girth) (Compared to shell plate)

9. Girth Joints Fusion double welded butt Rivet Holes ____ No. of Courses 2
(Seamless, Fusion or Forge Welded, Riveted—Lap or Butt) (No. rows—Diam. and Pitch)

10. Heads ____

11. Boiler Tubes: No. SA 178-A, 175, straight Diam. 2-1/2" Length 156-5/8" Gage .109
(Mat. Spec. No.—Straight or Bent) (If various, give max. and min. lgths.) (or thickness)

12. Headers: No. ____ Heads or Ends ____ Hydro. Test ____ lb.
13. Mud Drum ____ Heads or Ends ____ Hydro. Test ____ lb.
14. (a) Waterwall Headers, No. ____ Heads or Ends ____ Hydro. Test ____ lb.
(b) Tube Holes ____ Tubes ____ Gage ____ Heating Surface ____ sq. ft.
15. (a) Superheater: Headers, No. ____ Heads or Ends ____ Hydro. Test ____ lb.
(b) Tube Holes ____ Tubes ____ Gage ____

16.

Stays or Braces	Material Spec. No.	Type	No.	Size	Welded or Weldless	Total Net Area	L/I	Dist. Tubes to Shell	Area to be Stayed	Max. S W P
(a) F.H. above tubes	SA31	diag	16	1¼	Weldless	15.70		21	637	208
(b) R.H. above tubes	SA31	diag	16	1¼	Weldless	15.70		21	637	208
(c) F.H. below tubes										
(d) R.H. below tubes										
(e) Through below tubes										
(f) Dome braces										

17. Staybolts ____ Pitch ____ Max. S.W.P. ____

18. (a) Dome Diam. ____ Longitudinal Seam ____ Eff. ____ % How secured to shell ____
(b) Opening in shell ____ Head ____

19. (a) Furnace: No. 1 Size 34" O.D. Length, each Section, front ____ in., rear ____ in., Total 156-1/4" Type Corr.
(Int. Diam. or L x W x H) (Plain, Adamson, or Corr.)

SA 285-E .413 FVQ (b) Seams: Type Fusion double welded butt Location Longitudinal
(Brand, Mat. Spec. No., Thickness) (Seamless Fusion or Forge W., Riveted, Lap, or Butt) (Seam)

20. Openings: (a) Steam 1 @ 6" 300# Flange (b) Safety Valve 2 @ 3" NPT
(No., Size, and Type of Nozzles or Outlets) (No., Size, and Type of Nozzles or Outlets)

(c) Blowoff 2 @ 1-1/2" NPT (d) Feed 2 @ 2" NPT
(No., Size, Type and Location of Outlets) (No., Size, Type and Location of Connections)

No connections to Item 20.

(e) Manholes: No. 1 Size 11" X 15" Location Shell - Ring
(How Reinforced)

(f) Handholes: No. 6 Size 3-1/4" X 4-1/2" Location Shell
(How Reinforced)

21. Fusible Plug (If Used) ____ Boiler Supports: No. 4 Legs
(No., Diam., Location, Mfrs. Stamp) (Hangers or Lugs; Riveted or Welded)

22. Max. AWP 200 psi Based on P-#3 Heating Surface 1500 sq. ft.
(Code Par. and/or Formula) (Total)

23. Hydrostatic Test: (a) ____ lb. (b) ____ lb. (c) 300 lb.
(Welded Drums) (Riveted Drums) (Completed Boiler)