UNIT L-53011 L-4424 47520
S.O. 79127 CB-300, 15 is Steam

FORM H-2 MANUFACTURERS' DATA REPORT FOR ALL TYPES OF BOILERS EXCEPT WATER-TUBE AND THOSE MADE OF CAST IRON

C16-69A 2/71 As Required by the Provisions of the ASME Code Rule Part No. 270-413

1. Manufactured by Cleaver-Brooks Division of Aqua-Chem, Inc., Milwaukee, Wisconsin
(Name and address of manufacturer)

2. Manufactured for Child Development Center St. Paul, Minnesota
(Name and address of purchaser)

3. Type Internally Fired (H.R.T.-Loco.-Compact-Marine, Miniature) Boiler No. 47520 (Mfr's Serial No.) 25512 (State and State No.) (Nat'l. Board No.) Year Built 1971

4. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section IV Dated 19 71

Remarks: Manufacturers' Data Records properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report:
(Name of Part — Item number, manufacturer's name, and identifying stamp)

We certify the statement in this data report to be correct

Date September 20th, 1971 Signed Cleaver-Brooks Division (Manufacturer) By Earl R Stoudt (Representative) Earl R. Stoudt

Certificate of Authorization Expires 19

CERTIFICATE OF SHOP INSPECTION

BOILER MADE BY Cleaver-Brooks Division at Lebanon, Pennsylvania

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and or the State or Province of and employed by Hartford Steam Inspection & Insurance Co. of Hartford, Conn.

have inspected parts of this boiler referred to as data items 1, 9, 11, 15, 19, 23 and have examined manufacturer's partial data reports for items None

and state that, to the best of my knowledge and belief, the manufacturer has constructed this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date September 20, 19 71

Frank Bergholm
Inspector's Signature

Commissions PA WC 560 NB 3113
State or Prov. and No. Nat'l Board (incl. endorsements) and No.

We certify that the field assembly of all parts of this boiler conforms with the requirements of SECTION IV of the ASME BOILER AND PRESSURE VESSEL CODE.

Date 19 Signed By
Assembler's Representative

Our Certificate of Authorization to use the Symbol Expires
Assembler

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and or the State or Province of and employed by of

have compared the statements in this manufacturer's data report with the described boiler and state that the parts referred to as data items , not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and or the assembler has constructed and assembled this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described boiler was inspected and subjected to a hydrostatic test of psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19

Inspector's Signature Commissions
National Board or State and No.

6. Boiler Shells or Drums: No. 1 Diam. 78" Length 156" No. Shells Length ft. in.

6. Shell Plates SA-36, 3/8" Fusion double welded butt
(For each Drum, state Shell Manufacturer's Name, Material Specification Number, Thickness)

(b) Rivets (Diameter and Material Specification No.) River Holes (Diameter and Pitch) (As compared to shell plates)

8. (a) Tube Sheet SA-36, 3/8" (Brand, Mat. Spec. No.; Thickness) Reinforcement (No. and Thickness of Straps) Rivets Fillet weld (No. Rows; Mat. Spec. No.; Hole Diam. & Pitch)

(b) Tube Holes 2.520" (Diameter) Pitch (Longitudinal and Girth) Eff. of Tube Ligament % (Compared to shell plate)

9. Girth Joints Fusion double welded butt (Seamless, Fusion or Forge Welded, Riveted-Lap or Butt) Rivet Holes No. of Courses 2

10. Heads

11. Boiler Tubes: No. SA-178-A, 175, Straight (Mat. Spec. No.-Straight or Bent) Diam. 2-1/2" Length 156-1/2" (If various, give maximum and minimum lengths) Gage .105" (or thickness)

12. Headers: No. Heads or Ends Hydro. Test lb.

13. Mud Drum Heads or Ends Hydro. Test lb.

14. (a) Waterwall: Headers, No. Heads or Ends Hydro. Test lb.

(b) Tube Holes Tubes Gage Heating Surface sq. ft.

15. (a) Superheater: Headers, No. Heads or Ends Hydro. Test lb.

(b) Tube Holes Tubes Gage

	Stays or Braces	Material Spec. No.	Type	No.	Size	Welded or Weldless	Total Net Area	Fig. P-28 L/i	Dist. Tubes to Shell	Area to be Stayed	Max. S.W.P.
	(a) F.H. above tubes			0					21"	0	15 lb
	(b) R.H. above tubes			0					21"	0	15 lb
16	(c) F.H. below tubes										
	(d) R.H. below tubes										
	(e) Through below tubes										
	(f) Dome Braces										

17. Staybolts Pitch Max. S.W.P.

18. (a) Dome Diam. Longitudinal Seam Eff % How secured to shell

(b) Opening in shell Head

19. (a) Furnace No. 1 Size 34" O.D. (Int. Diam. or Lx'VxH) Length, each Section, in., in., Total 156¼" Type Plain (Plain, Adamson, or Corr.)

SA-285-C, 3/8" (Brand, Mat. Spec. No., Thickness) (b) Seams Type Fusion double welded butt (Seamless Fusion or Forge W., Riveted, Lap or Butt) Location Longitudinal (Seam)

20. Openings (a) Steam 1 @ 12", 150 lb Flange (No., Size, and Type of Nozzles or Outlets) (b) Safety Valve 2 @ 3" (No., Size, and Type of Nozzles or Outlets)

(c) Blowoff 2 @ 2" NPT Bottom C (No., Size, Type and Location of Outlets) (d) Feed 2 @ 2" NPT (No., Size, Type, and Location of Connections)

(e) Manholes: No. 1 Size 11" x 15" Location Shell – Ring (How Reinforced)

(f) Handholes: No. 6 Size 3-1/4" x 4-1/2" Location Shell (How Reinforced)

21. Fusible Plug (If Used) (No., Diam., Location, Mfgs. Stamp) Boiler Supports: No. 4 Legs (Hangers or Lugs; Riveted or Welded)

22. Max. A.W.P. 15 psi Based on HG-312 (Code Par. and/or Formula) Heating Surface 1500 (Total) sq. ft.

23. Hydrostatic Test: (a) lb. (Welded Drums) (b) lb. (Riveted Drums) (c) 60 lb. (Completed Boiler)