15421 - 47521

125, 60# HW

UNIT L-53159 "08

S.O. 82108

FORM H-2 MANUFACTURERS' DATA REPORT FOR ALL TYPES OF BOILERS EXCEPT WATER-TUBE AND THOSE MADE OF CAST IRON

C18-280A 8/70 Printed in U.S.A. **As Required by the Provisions of the ASME Code Rules** Part No. 270- 427

1. Manufactured by Cleaver-Brooks Division of Aqua-Chem, Inc., Milwaukee, Wisconsin
(Name and address of manufacturer)

2. Manufactured for Clyde Savings & Loan Association, North Riverside, Illinois
(Name and address of purchaser)

3. Type Internally Fired Boiler No. 47521 25513 Year Built 1971
(H R T - Loco - Compact-Marine, Miniature) (Mfrs. Serial No.) (State and State No.) (Natl. Board No.)

4. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section IV dated 1971

Remarks: Manufacturers' Data Records properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report:
(Name of Part — Item number, manufacturer's name, and identifying stamp)

We certify the statement in this data report to be correct.

Date Sept. 21, 19 71 Signed Cleaver-Brooks Division By Earl R Stoudt
(Manufacturer) Earl R. Stoudt (Representative)

Certificate of Authorization Expires ~~December 31~~, 19 1-15-74

CERTIFICATE OF SHOP INSPECTION

BOILER MADE BY Cleaver-Brooks Division at Lebanon, Pennsylvania

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of and employed by Hartford Steam Boiler Inspection & Insurance Co. of Hartford, Conn. have inspected parts of this boiler referred to as data items 1-9, 11, 16, & 19-23 and have examined manufacturer's partial data reports for items None and state that, to the best of my knowledge and belief, the manufacturer has constructed this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate neither the inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date Sept. 21 19 71

Frank Bergholz Commissions PA WC560 NB3113
Natl. Board or State and No.

We certify that the field assembly of all parts of this boiler conforms with the requirements of SECTION IV of the ASME BOILER AND PRESSURE VESSEL CODE.

Date 19 Signed By
(Assembler) (Representative)

Our Certificate of Authorization to use the (A) or (H) Symbol Expires 19

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of and employed by of have compared the statements in this manufacturer's data report with the described boiler and state that the parts referred to as data items , not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and/or the assembler has constructed and assembled this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described boiler was inspected and subjected to a hydrostatic test of psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19

Inspector Commissions Natl. Board or State and No.

1 Diam. 60" Length ... Length ... ft.

7. (a) Longitudinal Joint Fusion double welded butt (Seamless, Fusion or Forge Welded, Riveted)

(b) Rivets (Diameter and Material Specification No.) Rivet Holes (Diameter and Pitch) Eff. of Long Joint 85 (as compared to shell plate)

8. (a) Tube Sheet SA 36 1/2" (Brand, Mat. Spec. No.; Thickness) Reinforcement (No. and Thickness of Straps) Rivets Fillet weld (No. Rows, Mat. Spec. No., Hole Diam. and Pitch)

(b) Tube Holes 2.520" (Diameter) Pitch (Longitudinal and Girth) Eff. of Tube Ligament ...% (Compared to shell plate)

9. Girth Joints Fusion double welded butt (Seamless, Fusion or Forge Welded, Riveted—Lap or Butt) Rivet Holes (No. rows – Diam. and Pitch) No. of Courses 2

10. Heads

11. Boiler Tubes: No. SA178A, 98, Straight (Mat. Spec. No.—Straight or Bent) Diam. 2-1/2" Length 113-5/8" (If various, give maximum and minimum lengths) Gage .105 (or Thickness)

12. Headers: No. Heads or Ends Hydro. Test lb.
13. Mud Drum Heads or Ends Hydro. Test lb.
14. (a) Waterwall Headers: No. Heads or Ends Hydro. Test lb.
(b) Tube Holes Tubes Gage Heating Surface sq. ft.
15. (a) Superheater: Headers, No. Heads or Ends Hydro. Test lb.
(b) Tube Holes Tubes Gage

16.

Stays or Braces	Material Spec. No.	Type	No.	Size	Welded or Weldless	Total Net Area	Fig. P-28 L/l	Dist. Tubes to Shell	Area to be Stayed	Max. S.W.P.
(a) F.H. above tubes	SA 31	Diag.	4	1-1/4	Weldless	3.96		16-1/2	357	92
(b) R.H. above tubes	SA 31	Diag.	4	1-1/4	Weldless	3.96		16-1/2	357	92
(c) F.H. below tubes										
(d) R.H. below tubes										
(e) Through below tubes										
(f) Dome braces										

17. Staybolts Pitch Max. S.W.P.
18. (a) Dome: Diam. Longitudinal Seam Eff. % How secured to shell
(b) Opening in shell Head

19. (a) Furnace: No. 1 Size 24" O.D. (Out. Diam. or L x W x H) Length, each Section, ft. in. Total ft. in. 113-1/4 Type Plain (Plain, Adamson, or Corr.)

SA 53B .312 (Brand, Mat. Spec. No., Thickness) (b) Seams: Type Seamless (Seamless, Fusion or Forge W., Riveted, Lap, or Butt) Location (Seal)

20. Openings: (a) ~~XXX~~ Water (O&R) 2 @ 6" Flg. 150# (No., Size, and Type of Nozzles or Outlets) (b) Safety Valve 1 @ 2" NPT - 1 @ 3/4" NPT (No., Size, and Type of Nozzles or Outlets)

(c) Blowoff 2 @ 1-1/2" NPT (No., Size, Type, and Location of Outlets) (d) Feed 2 @ 1-1/2" NPT (No., Size, Type, and Location of Connections)

(e) Manholes: No. 1 Size 11" x 15" Location Shell - Ring (How Reinforced)

(f) Handholes: No. 6 Size 3-1/4" x 4-1/2" Location Shell (How reinforced)

21. Fusible Plug (If Used) (No., Diam., Location, Mfrs. Stamp) Boiler Supports: No. 4 Lugs (Hangers or Lugs, Riveted or Welded)

22. Max. AWP 60 Water psi Based on HG 312 (Code Par. and/or Formula) Heating Surface 625 sq ft (Total)

23. Hydrostatic Test: (a) lb. (b) lb. (c) 90 lb.
(Welded Drums) (Riveted Drums) (Completed Boiler)

8/70 C18-200A