UNIT I-53084 L-5516 47523

S.O. 82193 CB-400, 150 lb Stm.

FORM P-2 MANUFACTURERS' DATA REPORT FOR ALL TYPES OF BOILERS EXCEPT WATER-TUBE

C18-612A 1/71 As Required by the Provisions of the ASME Code Rules Part No. 270-460

1. Manufactured by Cleaver-Brooks Division of Aqua-Chem, Inc., Milwaukee, Wisconsin
(Name and address of manufacturer)

2. Manufactured for Concordia Seminary, St. Louis, Missouri
(Name and address of purchaser)

3. Type Internally Fired Boiler No. 47523 25515 Year Built 1971
(H.R.T.-Loco.-Compact-Marine, Miniature) (Mfrs. Serial No.) (State and State No.) (Natl. Board No.)

4. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section I Dated 1971

Remarks: Manufacturers' Data Records properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report:
(Name of Part — Item number, manufacturer's name, and identifying stamp)

We certify the statement in this data report to be correct.

Date September 2b, 1971 Signed Cleaver-Brooks Division (Manufacturer) By Earl R Stoudt Earl R. Stoudt (Authorized Representative)

Certificate of Authorization Expires xxxxxxxxx 1-15-74 19

CERTIFICATE OF SHOP INSPECTION

BOILER MADE BY Cleaver-Brooks Division at Lebanon, Pennsylvania

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and or the State or Province of and employed by Hartford Steam Inspection & Insurance Co. of Hartford, Conn. have inspected parts of this boiler referred to as data items 1-9, 11, 16, & 19-23 and have examined manufacturer's partial data reports for items None and state that, to the best of my knowledge and belief, the manufacturer has constructed this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date September 21, 71 Frank Bergholm Commissions PA WC 560 NB 3113
(Inspector) (Natl. Board or State and No.)

We certify that the field assembly of all parts of this boiler conforms with the requirements of SECTION I of the ASME BOILER AND PRESSURE VESSEL CODE.

Date 19 Signed By
(Assembler) (Representative)

Our Certificate or Authorization to use the Symbol Expires 19

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and or the State or Province of and employed by of have compared the statements in this manufacturer's data report with the described boiler and state that the parts referred to as data items , not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and or the assembler has constructed and assembled this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described boiler was inspected and subjected to a hydrostatic test of psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19

(Inspector) Commissions (Natl. Board or State and No.)

7. (a) Longitudinal Joint Fusion double welded butt (Seamless, Fusion or Forge Welded, Riveted-Lap or Butt-Single, Double, Triple or Quadruple)

(b) Rivets ..... Rivet Holes ..... Eff. of Long. Joint 90 % (Diameter and Material Specification No.) (Diameter and Pitch) (As compared to shell plate)

8. (a) Tube Sheet SA-285-C, 5/8" PVQ Reinforcement ..... Rivets Fillet weld (Brand, Mat. Spec. No.; Thickness) (No. and Thickness of Straps) (No. Rows, Mat. Spec. No.; Hole Diam. & Pitch)

(b) Tube Holes 2.520" Pitch ..... Eff. of Tube Ligament ..... % (Diameter) (Longitudinal and Girth) (Compared to shell plate)

9. Girth Joints Fusion double welded butt Rivet Holes ..... No. of Courses 2 (Seamless, Fusion or Forge Welded, Riveted-Lap or Butt)

10. Heads .....

11. Boiler Tubes: No. SA-178-A, 273, Straight Diam. 2-1/2" Length 134-1/2" Gage .105" (Mat. Spec. No.-Straight or Bent) (If various, give maximum and minimum lengths) (or thickness)

12. Headers: No. ..... Heads or Ends ..... Hydro. Test ..... lb.

13. Mud Drum ..... Heads or Ends ..... Hydro. Test ..... lb.

14. (a) Waterwall: Headers No. ..... Heads or Ends ..... Hydro. Test ..... lb.

(b) Tube Holes XXXXXXXXX Tubes ..... Gage ..... Heating Surface ..... sq. ft.

15. (a) Superheater: Headers No. ..... Heads or Ends ..... Hydro. Test ..... lb.

(b) Tube Holes ..... Tubes ..... Gage .....

	Stays or Braces	Material Spec. No.	Type	No.	Size	Welded or Weldless	Total Net Area	Fig. P-28 L	Dist. Tubes to Shell	Area to be Stayed	Max. S.W.P.
	(a) F.H. above tubes	SA 31	Diag.	18	1-1/4	Weldless	17.67		24-1/4"	905	161 lb.
	(b) R.H. above tubes	SA 31	Diag.	18	1-1/4	Weldless	17.67		24-1/4"	905	161 lb.
16.	(c) F.H. below tubes										
	(d) R.H. below tubes										
	(e) Through below tubes										
	(f) Dome Braces										

17. Stayboits ..... Pitch ..... Max. S.W.P. .....

18. (a) Dome Diam. ..... Longitudinal Seam ..... Eff. ..... % How secured to shell .....

(b) Opening in shell ..... Head .....

19. (a) Furnace No. 1 Size 45" O.D. (Int. Diam. or LxWxH) Length, each Section, ... in., ... in., Total 134¼" Type Corr. q (Plain, Adamson, or Corr.)

SA-285-C, .415 PVQ (Brand, Mat. Spec. No.; Thickness) (b) Seams: Type Fusion double welded butt (Seamless Fusion or Forge W., Riveted, Lap, or Butt) Location Longitudinal (Seam)

20. Openings: (a) Steam 1 @ 12" 300 lb. Flange (No., Size, and Type of Nozzles or Outlets) (b) Safety Valve 2 @ 3" NPT and 1 @ 2-1/2" NPT (No., Size, and Type of Nozzle or Outlet)

(c) Blowoff 2 @ 2" NPT Bottom ℄ (No., Size, Type and Location of Outlets) (d) Feed 2 @ 2-1/2" NPT (No., Size, Type, and Location of Connections)

(e) Manholes: No. 1 Size 11" x 15" Location Shell – Ring (How Reinforced)

(f) Handholes: No. 6 Size 3-1/4" x 4-1/2" Location Shell (How Reinforced)

No connections to Item 20.

21. Fusible Plug (If Used) ..... (No., Diam., Location, Mfgs. Stamp) Boiler Supports: No. 4 Legs (Hangers or Lugs: Riveted or Welded)

22. Max. AWP 150 psi Based on PG-27 (Code Par. and or Formula) Heating Surface 2000 (Total) sq. ft.

23. Hydrostatic Test (a) ..... lb. (b) ..... lb. (c) 225 lb. (Welded Drums) (Riveted Drums) (Completed Boiler)

Printed in U.S.A.