L-5538 47525

UNIT ~~L-53117~~
S.O. 82208

CB-125, 150 lb. Stm.

FORM P-2 MANUFACTURERS' DATA REPORT FOR ALL TYPES OF BOILERS EXCEPT WATER-TUBE

C18-887A 1/71

As Required by the Provisions of the ASME Code Rules

Part No. 270-436

1. Manufactured by Cleaver-Brooks Division of Aqua-Chem, Inc., Milwaukee, Wisconsin
(Name and address of manufacturer)

2. Manufactured for **Opelousas General Hospital, Opelousas, Louisiana**
(Name and address of purchaser)

3. Type Internally Fired (H.R.T.-Loco.-Compact-Marine, Miniature) Boiler No. 47525 (Mfrs. Serial No.) (State and State No.) 25517 (Natl. Board No.) Year Built 1971

4. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section 1 Dated 19 71

Remarks: Manufacturers' Data Records properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report:
(Name of Part — Item number, manufacturer's name, and identifying stamp)

We certify the statement in this data report to be correct.

Date September 21, 1971 Signed Cleaver-Brooks Division (Manufacturer) By Earl R. Stoudt
Earl R. Stoudt

Certificate of Authorization Expires 1-15-74 19

CERTIFICATE OF SHOP INSPECTION

BOILER MADE BY Cleaver-Brooks Division at Lebanon, Pennsylvania

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of and employed by Hartford Steam Inspection & Insurance Co. of Hartford, Conn. have inspected parts of this boiler referred to as data items 1-9, 11, 16, & 19-23 and have examined manufacturer's partial data reports for items None and state that, to the best of my knowledge and belief, the manufacturer has constructed this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date September 21, 19 71

Frank Bergholm
Frank Bergholm

Commissions PA WC 560 NB 3113
Natl. Board or State and No.

We certify that the field assembly of all parts of this boiler conforms with the requirements of SECTION I of the ASME BOILER AND PRESSURE VESSEL CODE.

Date 19 Signed (Assembler) By (Representative)

Our Certificate of Authorization to use the (A) or (S) Symbol Expires 19

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of and employed by of have compared the statements in this manufacturer's data report with the described boiler and state that the parts referred to as data items , not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and/or the assembler has constructed and assembled this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described boiler was inspected and subjected to a hydrostatic test of psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19

Inspector Commissions Natl. Board or State and No.

5. Boiler Shells or Drums: No. 1 Diam. 60" Length 113 ... in. Diam. ... Length ... Ft. ... In.

6. Shell Plates SA-515 GR 70 5/8" PVQ
(For each Drum, state: Manufacturer's Brand, Material Specification Number, Thickness)

7. (a) Longitudinal Joint Fusion double welded butt
(Seamless, Fusion or Forge Welded, Riveted-Lap or Butt-Single, Double, Triple or Quadruple)

(b) Rivets ... Rivet Holes ... Eff. of Long. Joint 90 %
(Diameter and Material Specification No.) (Diameter and Pitch) (As compared to shell plates)

8. (a) Tube Sheet SA-285 GR C, 1/2" PVQ Reinforcement ... Rivets Fillet weld
(Brand, Mat. Spec. No.; Thickness) (No. and Thickness of Straps) (No. Rows; Mat. Spec. No.; Hole Diam. & Pitch)

(b) Tube Holes 2.520" Pitch ... Eff. of Tube Ligament ... %
(Diameter) (Longitudinal and Girth) (Compared to shell plate)

Fusion double welded butt ... Rivet Holes ... No. of Courses 2
(...less, Fusion or Forge Welded, Riveted-Lap or Butt)

11. Boiler Tubes: No. [illegible] 2-1/2" Length 113-1/2" Gage .105"
(Mat. ... Seamless or Butt) (If various, give maximum and minimum lengths) (or thickness)

12. Headers: No. ... Heads or Ends ... Hydro. Test ... lb.

13. Mud Drum ... Heads or Ends ... Hydro. Test ... lb.

14. (a) Waterwall: Headers, No. ... Heads or Ends ... Hydro. Test ... lb.

(b) Tube Holes ... Tubes ... Gage ... Heating Surface ...

15. (a) Superheater: Headers, No. ... Heads or Ends ... Hydro. Test ... lb.

(b) Tube Holes ... Tubes ... Gage ...

16.

Stays or Braces	Material Spec. No.	Type	No.	Size	Welded or Weldless	Total Net Area	Fig. P-28 L/l	Dist. Tubes to Shell	Area to be Stayed	Max. S.W.P.
(a) F.H. above tubes	SA 31	Diag.	8	1-1/4	Weldless	7.85		16-1/2"	357	176 lb.
(b) R.H. above tubes	SA 31	Diag.	8	1-1/4	Weldless	7.85		16-1/2"	357	176 lb.
(c) F.H. below tubes										
(d) R.H. below tubes										
(e) Through below tubes										
(f) Dome Braces										

17. Staybolts ... Pitch ... Max. S.W.P. ...

18. (a) Dome: Diam. ... Longitudinal Seam ... Eff. ... % How secured to shell ...

(b) Opening in shell ... Head ...

19. (a) Furnace No. 1 Size 24" O.D. Length, each Section, Plain 24 in., Corr. 89¼ in., Total 113¼" Type Plain & Corr.
(Int. Diam. or LxWxH) (Plain, Adamson, or Corr.)

Plain Sec. SA-53 B, .438"
Corr. Sec. SA-53 B, .312"
(Brand, Mat. Spec. No.; Thickness) (b) Seams: Type Fusion Double Welded Butt Location Girth
(Seamless Fusion or Forge W., Riveted, Lap, or Butt) (Seam)

20. Openings: (a) Steam 1 @ 4" 300 lb Flange (b) Safety Valve 2 @ 2" NPT
(No., Size, and Type of Nozzles or Outlets) (No., Size, and Type of Nozzles or Outlets)

(c) Blowoff 2 @ 1-1/2" NPT bottom ¢ front & rear (d) Feed 2 @ 1-1/2" NPT
(No., Size, Type and Location of Outlets) (No., Size, Type, and Location of Connections)

(e) Manholes: No. 1 Size 11" x 15" Location Shell – Ring
(How Reinforced)

(f) Handholes: No. 6 Size 3-1/4" x 4-1/2" Location Shell
(How Reinforced)

No connections to Item 20.

21. Fusible Plug (If Used) ... Boiler Supports: No 4 Legs
(No., Diam., Location, Mfgs. Stamp) (Hangers or Lugs: Riveted or Welded)

22. Max. AWP 150 psi Based on PG-27 Heating Surface 625 sq. ft.
(Code Par. and/or Formula) (Total)

23. Hydrostatic Test (a) ... lb. (b) ... lb. (c) 225 lb.
(Welded Drums) (Riveted Drums) (Completed Boiler)

Printed in U.S.A.

[illegible]