UNIT I-5312 I-5356 47526
S.O. 79076 CB-200, 15 lb Steam

FORM H-2 MANUFACTURERS' DATA REPORT FOR ALL TYPES OF BOILERS EXCEPT WATER-TUBE AND THOSE MADE OF CAST IRON

C10-866A 2/71 As Required by the Provisions of the ASME Code Rule Part No. 270-435

1. Manufactured by Cleaver-Brooks Division of Aqua-Chem, Inc., Milwaukee, Wisconsin
(Name and address of manufacturer)

2. Manufactured for Whispering Hills Aprtments, Oklahoma City, Oklahoma
(Name and address of purchaser)

3. Type Internally Fired (H.R.T.-Loco.-Compact-Marine, Miniature) Boiler No. 47526 (Mfrs. Serial No.) 25518 (State and State No.) (Natl. Board No.) Year Built 1971

4. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section IV Dated 19 71

Remarks: Manufacturers' Data Records properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report:
(Name of Part — Item number, manufacturer's name, and identifying stamp)

We certify the statement in this data report to be correct.

Date September 20, 1971 Signed Cleaver-Brooks Division (Manufacturer) By Earl R Stoudt
Earl R. Stoudt
Certificate of Authorization Expires 1-15-74 19

CERTIFICATE OF SHOP INSPECTION

BOILER MADE BY Cleaver-Brooks Division at Lebanon, Pennsylvania

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and or the State or Province of and employed by Hartford Steam Inspection & Insurance Co. of Hartford, Conn.
have inspected parts of this boiler referred to as data items 1-9, 11, 16, & 19-23 and have examined manufacturer's partial data reports for items None
and state that to the best of my knowledge and belief, the manufacturer has constructed this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date September 20, 19 71

Frank Bergholm
Commissions PA WC 560 NB 3113
Natl. Board or State and No.

We certify that the field assembly of all parts of this boiler conforms with the requirements of SECTION IV of the ASME BOILER AND PRESSURE VESSEL CODE.

Date 19 Signed By
Manufacturer Representative

Our Certificate of Authorization to use the (Symbol) Symbol Expires 19

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and or the State or Province of and employed by of
have compared the statements in this manufacturer's data report with the described boiler and state that the parts referred to as data items not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and or the assembler has constructed and assembled this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described boiler was inspected and subjected to a hydrostatic test of psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19

Inspector Commissions
Natl. Board or State and No.

5. Boiler Shells or Drums: No. 1 Diam. 40" Length 168" Inside Diam. ..... Length ..... ft. ..... in.

6. Shell Plates: SA-36, 5/16"
(For each Drum, state: Spec. No., Grade, Tensile Strength, Thickness)

7. (a) Longitudinal Joint: Fusion double welded butt
(Seamless, Fusion or Forge Welded, Riveted-Lap or Butt-Single, Double, Triple or Quadruple)

(b) Rivets ..... Rivet Holes ..... Eff. of Long. Joint 85 %
(Diameter and Material Specification No.) (Diameter and Pitch) (As compared to shell plates)

8. (a) Tube Sheet SA-36, 1/2" Reinforcement ..... Rivets Fillet weld
(Brand, Mat. Spec. No.; Thickness) (No. and Thickness of Strips) (No. Rows; Mat. Spec. No.; Hole Diam. & Pitch)

(b) Tube Holes 2.520" Pitch ..... Eff. of Tube Ligament ..... %
(Diameter) (Longitudinal and Girth) (Compared to shell plate)

9. Girth Joints: Fusion double welded butt Rivet Holes ..... No. of Courses 2
(Seamless, Fusion or Forge Welded, Riveted-Lap or Butt)

10. Heads .....

11. Boiler Tubes: No. SA-178-A, 108, Straight Diam. 2-1/2" Length 168-1/2" Gage .105"
(Mat. Spec. No.-Straight or Bent) (If various, give maximum and minimum lengths) (or thickness)

12. Headers: No. ..... Heads or Ends ..... Hydro. Test ..... lb.

13. Mud Drum ..... Heads ..... Hydro. Test ..... lb.

14. (a) Waterwall: Headers: No. ..... Heads or Ends ..... Hydro. Test ..... lb.

(b) Tube Holes ..... Tubes ..... Heating Surface

15. (a) Superheater: Headers: No. ..... Heads or Ends ..... Hydro. Test ..... lb.

(b) Tube Holes ..... Tubes ..... Gage .....

16.

Stays or Braces	Material Spec. No.	Type	No.	Size	Welded or Weldless	Total Net Area	Fig. P-28 L/I	Dist. Tubes to Shell	Area to be Stayed	Max. S.W.P.
(a) F.H. above tubes			0			0		16-1/2"	0	15 lb
(b) R.H. above tubes			0			0		16-1/2"	0	15 lb
(c) F.H. below tubes										
(d) R.H. below tubes										
(e) Through below tubes										
(f) Dome Braces										

17. Staybolts ..... Pitch ..... Max. S.W.P. .....

18. (a) Dome: Diam. ..... Longitudinal Seam ..... Eff. ..... % How secured to shell .....

(b) Opening in shell ..... Head .....

19. (a) Furnace No. 1 Size 24" O.D. Length, each Section, ... in., ... in., Total 168¼" Type Plain
(Int. Diam. or LxWxH) (Plain, Adamson, or Corr.)

SA-53B, .312" (b) Seams: Type Seamless Location .....
(Brand, Mat. Spec. No.; Thickness) (Seamless Fusion or Forge W., Riveted, Lap, or Butt) (Seam)

20. Openings: (a) Steam 1 @ 10" 150 lb Flange (b) Safety Valve 1 @ 2-1/2" and 1 @ 3" NPT
(No., Size, and Type of Nozzles or Outlets) (No., Size, and Type of Nozzles or Outlets)

(c) Blowoff 2 @ 2" NPT bottom ¢ (d) Feed 2 @ 2" NPT
(No., Size, Type and Location of Outlets) (No., Size, Type, and Location of Connections)

(e) Manholes: No. 1 Size 11" x 15" Location Shell – Ring
(How Reinforced)

(f) Handholes: No. 6 Size 3-1/4" x 4-1/2" Location Shell
(How Reinforced)

21. Fusible Plug (If Used) ..... Boiler Supports: No. 4 Legs – Welded
(No., Diam., Location, Mfgs. Stamp) (Hangers or Lugs: Riveted or Welded)

22. Max. AWP 15 psi Based on HG-312 Heating Surface 1000 sq. ft
(Code Par. and/or Formula) (Total)

23. Hydrostatic Test: (a) ..... lb. (b) ..... lb. (c) 60 lb.
(Welded Drums) (Riveted Drums) (Completed Boiler)