L-5517 47527

UNIT L-5[illegible]83
S.O. 62192

CB-300, 150 HP Stm.

FORM P-2 MANUFACTURERS' DATA REPORT FOR ALL TYPES OF BOILERS EXCEPT WATER-TUBE

C18-506A 7/70 Printed in U.S.A. As Required by the Provisions of the ASME Code Rules Part No. 270-416

1. Manufactured by Cleaver-Brooks Division of Aqua-Chem, Inc., Milwaukee, Wisconsin
(Name and address of manufacturer)

2. Manufactured for Banquet Foods Corporation, Macon, Missouri
(Name and address of purchaser)

3. Type Internally Fired (H F T - Loco - Compact - Marine, Miniature) Boiler No. 47527 (Mfrs Serial No.) 25519 (State and State No.) (Natl. Board No.) Year Built 1971

4. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section I dated 1971

Remarks: Manufacturers' Data Records properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report.
(Name of Part - Item number, manufacturer's name, and identifying stamp)

We certify the statement in this data report to be correct.

Date September 21, 19 71 Signed Cleaver-Brooks Division (Manufacturer) By Earl R Stroudt (Representative)
Earl R. Stroudt

Certificate of Authorization Expires 1-15-74 19

CERTIFICATE OF SHOP INSPECTION

BOILER MADE BY Cleaver-Brooks Division at Lebanon, Pennsylvania

I, the undersigned holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of and employed by Hartford Steam Boiler Inspection & Insurance Co. of Hartford, Conn.

have inspected parts of this boiler referred to as data items 1-9, 11, 16, & 19-23 and have examined manufacturer's partial data reports for items None

and state that to the best of my knowledge and belief, the manufacturer has constructed this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date September 21, 19 71 Commissions PA NB PA WC 560 NB 3113
Natl. Board or State and No.

Frank Berghelm

We certify that the field assembly of all parts of this boiler conforms with the requirements of SECTION I of the ASME BOILER AND PRESSURE VESSEL CODE.

Date 19 Signed By
Assembler (Representative)

Our Certificate of Authorization to use the Symbol Expires 19
(Assembly)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of and employed by of have compared the statements in this manufacturer's data report with the described boiler and state that the parts referred to as data items not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer and/or the assembler has constructed and assembled this boiler in accordance with the applicable sections of the ASME BOILER AND PRESSURE VESSEL CODE. The described boiler was inspected and subjected to a hydrostatic test of psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the boiler described in this manufacturer's data report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 19

Commissions

Inspector Natl. Board or State and No.

7. (a) Longitudinal Joints: Fusion double welded butt (Straight, Fusion or Flange Welded, Riveted-Lap or Butt-Single, Double, Triple or Quadruple)

(b) Rivets: (Diameter and Material Specification No.) Rivet Holes: (Diameter and Pitch) Eff. of Longitudinal Joint: 90 % (As compared to solid plate)

8. (a) Tube Sheet: SA-285-C, P.V.Q., 5/8" (Grade, Mat. Spec. No., Thickness) Reinforcement: (No. and Thickness of Strips) Rivets: Fillet weld (No., Rows, Diam., Spec. No., Hole Diam. and Pitch)

(b) Tube Holes: 2.520" (Diameter) Pitch: (Longitudinal and Girth) Eff. of Tube Ligament: % (Compared to shell plate)

9. Girth Joints: Fusion double welded butt (Seamless, Fusion or Forge Welded, Riveted-Lap or Butt) Rivet Holes: (No. rows - Diam. and Pitch) No. of Courses: 2

10. Heads:

11. Boiler Tubes: No. SA-178-A, 175 Strgight (Mat. Spec. No.-Straight or Bent) Diam. 2-1/2" Length: 156-5/8" (If various, give maximum and minimum lengths) Gage: .105" (or thickness)

12. Headers: Heads or Ends: Hydro. Test: lb.

13. Mudhum: Heads or Ends: Proof Test: lb.

14. (a) Waterwall Headers, No.: Heads or Ends: Hydro. Test: lb.

(b) Tube Holes: Tubes: Gage: Heating Surface: sq. ft.

15. (a) Superheater Headers, No.: Heads or Ends: Hydro. Test: lb.

(b) Tube Holes: Tubes: Gage:

16.

Steps or Braces	Material Spec. No.	Type	No.	Size	Welded or Welded	Total Net Area	Ratio L/r	Diam. Tubes to Shell	Area to be Stayed	Max. S.W.P.
(a) F.H. above tubes	SA 31	Diag.	14	1-1/4	Weldless	13.75		21"	673	174 lb
(b) R.H. above tubes	SA 31	Diag.	14	1-1/4	Weldless	13.75		21"	673	174 lb
(c) F.H. below tubes										
(d) R.H. below tubes										
(e) Through below tubes										
(f) Dome braces										

17. Staybolts: Pitch: Max. S.W.P.:

18. (a) Dome: Diam. Longitudinal Seam: Eff.: % How secured to shell:

(b) Opening in shell: Head:

19. (a) Furnace No. 1 Size: 34" O.D. (Int. Diam. or L x W x H) Length each Section, front: rear: Total: 156-1/4" Type: Corr. (Plain, Adamson, or Corr.)

SA-285-C, P.V.Q., 312 (Grade, Mat. Spec. No., Thickness) (b) Seams: Type: Fusion double welded butt (Seamless Fusion or Forge W., Riveted, Lap, or Butt) Location: Longitudinal (Seam)

20. Openings: (a) Steam: 1 @ 6", 300 lb Flange (No., Size, and Type of Nozzles or Outlets) (b) Safety Valve: 2 @ 3" NPT (No., Size, and Type of Nozzles or Outlets)

(c) Blowoff: 2 @ 1-1/2" NPT Bottom C... (No., Size, Type, and Location of Outlets) (d) Feed: 2 @ 2" NPT (No., Size, Type, and Location of Connections)

(e) Manholes No. 1 Size: 11" x 15" Location: Shell - Ring (How Reinforced)

(f) Handholes No. 6 Size: 3-1/4" x 4-1/2" Location: Shell (How reinforced)

21. Fusible Plug (If Used): (No., Diam., Location, Mfr. Name) Boiler Supports: No. 4 Legs (Hangers or Lugs; Riveted or Welded)

22. Max. AWP: 150 psi Based on: PG-27 (Code Par. and/or Formula) Heating Surface: 1500 (Total) Sq. ft.

23. Hydrostatic Test: (a) lb. (Welded Drums) (b) lb. (Riveted Drums) (c) 225 lb. (Completed Boiler)

No connections to Item 20.