FORM U-1A MANUFACTURERS' DATA REPORT FOR PRESSURE VESSELS
Alternate Form for Single Chamber Completely Shop-Fabricated Vessels Only
As Required by the Provisions of the ASME Code Rules, Section VIII, Division I

1. Manufactured by Chemi-Trol Chemical Co. Fremont, Ohio (Name and address of Manufacturer)

2. Manufactured for ______ (Name and address of Purchaser)

3. Type Horiz. (Horiz. or Vert.) Vessel No. (94363 (Mfrs. Serial)) (______ (State & State No.)) Nat'l. Bd. No. 94363 Yr. Built 1969

4. SHELL: Mat'l. SA-455 (Kind and Spec. No.) T.S. 75,000 (Fig. or F.B. & Spec. Min. T.S.) Nom. Thk. .32 In. Corr. Allow. ____ In. Diam. 3 Ft. 5 In. Length 16 Ft. 0 In.

Double

5. SEAMS: Long Butt Weld (Welded, Dbl., Single, Lap, Butt) H.T. Yes (Yes or No)¹ R.T. spot (Spot or Complete) Sectioned No (Yes or No) Efficiency 85 %

Girth Butt Weld H.T. Yes R.T. no Sectioned No No. of Courses 2

If riveted or brazed describe seams fully under remarks.

6. HEADS: (a) Material SA-285-C T.S. 55,000 (b) Material same T.S. same

Location (Top, bottom, ends)	Thickness	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a) End	.2306					20¼"		concave
(b) End	.2306					20¼"		concave

If removable, bolts used ______ (Material, Spec. No., T.S., Size, Number) Other fastening ______ (Describe or Attach Sketch)

7. Constructed for max. allowable working press.² 250 psi at max. temp. 650 °F. Min. temp. (when less than −20°) ______ °F. Hydrostatic ~~Pneumatic~~ ~~Combination~~ Test Press. 400 psi.

8. SAFETY OR RELIEF VALVE OUTLETS: Number 1 Size 3/4" Location Top Shell

9. NOZZLES:

Purpose (Inlet, Outlet, Drain)	Number	Diam. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
Float Gauge	1	3"	forging	steel	½"	weld	welded
Inlet-Outlet	4	1¼"	coupling	steel	X-Hvy.	weld	welded
	2	½"	coupling	steel	X-Hvy.	weld	welded

10. INSPECTION OPENINGS: Manholes, No. ______ Size ______ Location ______

Handholes, No. ______ Size ______ Location ______

Threaded, No. ______ Size ______ Location ______

11. SUPPORTS: Skirt no (Yes or No) Lugs ______ (Number) Legs 4 (Number) Other ______ (Describe) Attached Bottom-welded (Where & How)

12. REMARKS: Anhydrous Ammonia Storage Tank - with baffles

(Brief description of purpose of the vessel as Air Tank, Water Tank, L.P.G., Etc.—State Contents.
¹ If postweld heat-treated.
² List other internal or external pressures with coincident temperature when applicable.

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division I.

Date MAR 28 1969, 19____ Signed Chemi-Trol Chemical Co. (Manufacturer) By

Certificate of Authorization Expires December 31, 1970

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY Chemi-Trol Chemical Co. at Fremont, Ohio

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province Ohio and employed by Commercial Union Insurance Company of New York, New York have inspected the pressure vessel described in this manufacturer's data report on MAR 28 1969, 19___, and state that to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date MAR 28 1969, 19____

Inspector's Signature

Commissions NB-5635 Penna. WC-1333 (Nat'l Board, State, or Province and No.)

1000 - 41- SR