Electrical Panel Maintenance Procedure

1. Scope and PPE

The procedure applies to panels energized at 50 volts or more.

Required PPE includes arc-rated clothing, a face shield, and voltage-rated gloves.

Only qualified electricians may open an energized panel.

2. Isolation and inspection

De-energize and lock out the panel before removing covers.

Verify zero voltage with a meter rated for the panel voltage.

Inspect busbars and terminals for discoloration or overheating.

Tighten terminal connections to 20 Nm.

3. Thermal scan and repairs

Perform a thermal scan of the panel annually.

A hot spot above 20 °C over ambient requires investigation.

Record the thermal scan results in the maintenance log.

Replace damaged breakers with the same voltage and current rating.