Fire Extinguisher Inspection Procedure

1. Inspection schedule

Inspect every extinguisher visually every month.

Have a professional inspection annually.

Dry chemical extinguishers require maintenance every 6 years.

Hydrostatic testing is required every 12 years.

2. Visual inspection steps

Check that the pressure gauge is in the green zone.

Verify the pull pin is sealed and the tamper seal is intact.

Inspect the hose and nozzle for cracks or blockage.

Record the inspection date and inspector name on the tag.

3. Pass, fail, and records

Remove the extinguisher from service if the gauge is outside the green zone.

A damaged hose or missing pin means the extinguisher fails inspection.

Tag a failed extinguisher and place it in the red service area.

Keep inspection records for five years.