#### PID controllers and modified PID controllers

Dr. Ing. Rodrigo Gonzalez

rodralez@fing.uncu.edu.ar

Control y Sistemas, Facultad de Ingeniería, Universidad Nacional de Cuyo

May 2016



#### Summary

- Ziegler-Nichols Rules for Tuning PID Controllers
- Design of PID Controllers with Computational Optimization Approach
- Modifications of PID Control Schemes
- 4 Two-Degrees-of-Freedom Control
- 5 Zero-Placement Approach to Improve Response Characteristics
- Example Problems and Solutions

### Ziegler–Nichols Rules for Tuning PID Controllers PID Control of Plants

- If the plant mathematical model cannot be easily obtained, then an analytical or computational approach to the design of a PID controller is not possible.
- Then we must resort to experimental approaches to the tuning of PID controllers.
- Ziegler and Nichols suggested rules for tuning PID controllers (values  $K_p$  ,  $T_i$ , and  $T_d$ ) based on:
  - Experimental step responses (Method 1) or
  - Based on the value of K<sub>p</sub> that results in marginal stability when only proportional control action is used (Method 2).


Figure 8–1
PID control of a plant.

Plant

Plant

### Ziegler–Nichols Rules for Tuning PID Controllers First Method

- We obtain experimentally the response of the plant to a unit-step input.
- This method applies if the response to a step input exhibits an S-shaped curve.



### Ziegler–Nichols Rules for Tuning PID Controllers First Method

Table 8-1 Ziegler-Nichols Tuning Rule Based on Step Response of Plant (First Method)

Type of Controller	$K_p$	$T_i$	$T_d$
P	$\frac{T}{L}$	∞	0
PI	$0.9 \frac{T}{L}$	$\frac{L}{0.3}$	0
PID	$1.2\frac{T}{L}$	2L	0.5L

## Ziegler–Nichols Rules for Tuning PID Controllers First Method

function C(s)/U(s) may then be approximated by a first-order system with a transport lag as follows:

$$\frac{C(s)}{U(s)} = \frac{Ke^{-Ls}}{Ts+1}$$

Ziegler and Nichols suggested to set the values of  $K_p$ ,  $T_i$ , and  $T_d$  according to the formula shown in Table 8–1.

Notice that the PID controller tuned by the first method of Ziegler-Nichols rules gives

$$G_{c}(s) = K_{p} \left( 1 + \frac{1}{T_{i}s} + T_{d}s \right)$$


$$= 1.2 \frac{T}{L} \left( 1 + \frac{1}{2Ls} + 0.5Ls \right)$$

$$= 0.6T \frac{\left( s + \frac{1}{L} \right)^{2}}{s}$$

Thus, the PID controller has a pole at the origin and double zeros at s = -1/L.

### Ziegler–Nichols Rules for Tuning PID Controllers Second Method

- We first set  $T_i = \infty$ , and  $T_d = 0$
- Increase  $K_p$  from 0 to a critical value  $K_{cr}$  at which the output first exhibits sustained oscillations.



## Ziegler–Nichols Rules for Tuning PID Controllers Second Method

Table 8-2Ziegler-Nichols Tuning Rule Based on Critical Gain $K_{cr}$  and Critical Period  $P_{cr}$  (Second Method)

Type of Controller	$K_p$	$T_{i}$	$T_d$
P	0.5K <sub>cr</sub>	∞	0
PI	0.45K <sub>cr</sub>	$\frac{1}{1.2}P_{\rm cr}$	0
PID	0.6K <sub>cr</sub>	$0.5P_{\rm cr}$	0.125P <sub>cr</sub>

Notice that the PID controller tuned by the second method of Ziegler-Nichols rules gives


$$\begin{split} G_{\rm c}(s) &= K_p \bigg( 1 + \frac{1}{T_i s} + T_d s \bigg) \\ &= 0.6 K_{\rm cr} \bigg( 1 + \frac{1}{0.5 P_{\rm cr} s} + 0.125 P_{\rm cr} s \bigg) \\ &= 0.075 K_{\rm cr} P_{\rm cr} \frac{\bigg( s + \frac{4}{P_{\rm cr}} \bigg)^2}{s} \end{split}$$

### Ziegler–Nichols Rules for Tuning PID Controllers Second Method, Example 8-1

**EXAMPLE 8-1** Consider the control system shown in Figure 8-6 in which a PID controller is used to control the system. The PID controller has the transfer function

$$G_c(s) = K_p \left( 1 + \frac{1}{T_i s} + T_d s \right)$$

Although many analytical methods are available for the design of a PID controller for the present system, let us apply a Ziegler–Nichols tuning rule for the determination of the values of parameters  $K_p$ ,  $T_i$ , and  $T_d$ . Then obtain a unit-step response curve and check to see if the designed system exhibits approximately 25% maximum overshoot. If the maximum overshoot is excessive (40% or more), make a fine tuning and reduce the amount of the maximum overshoot to approximately 25% or less.



## Design of PID Controllers with Computational Optimization Approach Example 8-2

EXAMPLE 8-2 Consider the PID-controlled system shown in Figure 8-19. The PID controller is given by

$$G_c(s) = K \frac{(s+a)^2}{s}$$

It is desired to find a combination of K and a such that the closed-loop system will have 10% (or less) maximum overshoot in the unit-step response. (We will not include any other condition in this problem. But other conditions can easily be included, such as that the settling time be less than a specified value. See, for example, Example 8-3.)

There may be more than one set of parameters that satisfy the specifications. In this example, we shall obtain all sets of parameters that satisfy the given specifications.

To solve this problem with MATLAB, we first specify the region to search for appropriate K and a. We then write a MATLAB program that, in the unit-step response, will find a combination of K and a which will satisfy the criterion that the maximum overshoot is 10% or less.


Note that the gain K should not be too large, so as to avoid the possibility that the system require an unnecessarily large power unit.

Assume that the region to search for K and a is


$$2 \le K \le 3$$
 and  $0.5 \le a \le 1.5$ 

## Modifications of PID Control Schemes PI-D Control

- If u(t) change abruptly, the derivative term in the control action will involve an impulse function.
- Such a phenomenon is called set-point kick.



## Modifications of PID Control Schemes PI-D Control



## Modifications of PID Control Schemes PI-D Control

Notice that in the absence of the disturbances and noises, the closed-loop transfer function of the basic PID control system [shown in Figure 8–25(b)] and the PI-D control system (shown in Figure 8–26) are given, respectively, by

$$\frac{Y(s)}{R(s)} = \left(1 + \frac{1}{T_i s} + T_d s\right) \frac{K_p G_p(s)}{1 + \left(1 + \frac{1}{T_i s} + T_d s\right) K_p G_p(s)}$$

and


$$\frac{Y(s)}{R(s)} = \left(1 + \frac{1}{T_i s}\right) \frac{K_p G_p(s)}{1 + \left(1 + \frac{1}{T_i s} + T_d s\right) K_p G_p(s)}$$

It is important to point out that in the absence of the reference input and noises, the closed-loop transfer function between the disturbance D(s) and the output Y(s) in either case is the same and is given by

$$\frac{Y(s)}{D(s)} = \frac{G_p(s)}{1 + K_p G_p(s) \left(1 + \frac{1}{T_i s} + T_d s\right)}$$

## Modifications of PID Control Schemes I-PD Control


 The proportional action and derivative action are moved to the feedback path so that these actions affect the feedback signal only.



The closed-loop transfer function Y(s)/R(s) in the absence of the disturbance input and noise input is given by

$$\frac{Y(s)}{R(s)} = \left(\frac{1}{T_i s}\right) \frac{K_p G_p(s)}{1 + K_p G_p(s) \left(1 + \frac{1}{T_i s} + T_d s\right)}$$


## Two-Degrees-of-Freedom Control PID Control



For this system, three closed-loop transfer functions  $Y(s)/R(s)=G_{yr}$ ,  $Y(s)/D(s)=G_{yd}$ , and  $Y(s)/N(s)=G_{yg}$  may be derived. They are

$$G_{yr} = rac{Y(s)}{R(s)} = rac{G_c G_p}{1 + G_c G_p}$$
 $G_{yd} = rac{Y(s)}{D(s)} = rac{G_p}{1 + G_c G_p}$ 
 $G_{yn} = rac{Y(s)}{N(s)} = -rac{G_c G_p}{1 + G_c G_p}$ 
 $G_{yn} = rac{G_{yd} - G_p}{G_p}$ 

## Two-Degrees-of-Freedom Control PX-PX Control



$$G_{yr} = \frac{Y(s)}{R(s)} = \frac{G_{c1}G_p}{1 + (G_{c1} + G_{c2})G_p}$$

$$G_{yd} = \frac{Y(s)}{D(s)} = \frac{G_p}{1 + (G_{c1} + G_{c2})G_p}$$


$$G_{yn} = \frac{Y(s)}{N(s)} = -\frac{(G_{c1} + G_{c2})G_p}{1 + (G_{c1} + G_{c2})G_p}$$

$$G_{yn} = \frac{G_{yd} - G_p}{G_p}$$

## Two-Degrees-of-Freedom Control PX2 Control


$$\begin{split} G_{yr} &= \frac{Y(s)}{R(s)} = \frac{G_{c1}G_p}{1 + G_{c1}G_p} + \frac{G_{c2}G_p}{1 + G_{c1}G_p} \\ G_{yd} &= \frac{Y(s)}{D(s)} = \frac{G_p}{1 + G_{c1}G_p} \\ G_{yn} &= \frac{Y(s)}{N(s)} = -\frac{G_{c1}G_p}{1 + G_{c1}G_p} \end{split}$$

$$G_{yr} &= G_{c2}G_{yd} + \frac{G_p - G_{yd}}{G_p} \\ G_{yn} &= \frac{G_{yd} - G_p}{G_p} \end{split}$$



Consider the two-degrees-of-freedom control system shown in Figure 8–31. Assume that the plant transfer function  $G_p(s)$  is a minimum-phase transfer function and is given by

$$G_p(s) = K \frac{A(s)}{B(s)}$$



where

$$A(s) = (s + z_1)(s + z_2) \cdots (s + z_m)$$
  

$$B(s) = s^{N}(s + p_{N+1})(s + p_{N+2}) \cdots (s + p_n)$$

where N may be 0, 1, 2 and  $n \ge m$ . Assume also that  $G_{c1}$  is a PID controller followed by a filter 1/A(s), or

$$G_{c1}(s) = \frac{\alpha_1 s + \beta_1 + \gamma_1 s^2}{s} \frac{1}{A(s)}$$

and  $G_{c2}$  is a PID, PI, PD, I, D, or P controller followed by a filter 1/A(s). That is

$$G_{c2}(s) = \frac{\alpha_2 s + \beta_2 + \gamma_2 s^2}{s} \frac{1}{A(s)}$$

where some of  $\alpha_2$ ,  $\beta_2$ , and  $\gamma_2$  may be zero. Then it is possible to write  $G_{c1} + G_{c2}$  as

$$G_{c1} + G_{c2} = \frac{\alpha s + \beta + \gamma s^2}{s} \frac{1}{A(s)}$$
 (8-3)

where  $\alpha$ ,  $\beta$ , and  $\gamma$  are constants. Then

$$\frac{Y(s)}{D(s)} = \frac{G_p}{1 + (G_{c1} + G_{c2})G_p} = \frac{K\frac{A(s)}{B(s)}}{1 + \frac{\alpha s + \beta + \gamma s^2}{s}\frac{K}{B(s)}}$$
$$= \frac{sKA(s)}{sB(s) + (\alpha s + \beta + \gamma s^2)K}$$


if the disturbance input is a step function of magnitude d, or

$$D(s) = \frac{d}{s}$$

and assuming the system is stable, then

$$y(\infty) = \lim_{s \to 0} s \left[ \frac{sKA(s)}{sB(s) + (\alpha s + \beta + \gamma s^2)K} \right] \frac{d}{s}$$
$$= \lim_{s \to 0} \frac{sKA(0)d}{sB(0) + \beta K}$$

Figure 8–32
Typical response curve to a step disturbance input.



The response y(t) to a step disturbance input will have the general form shown in Figure 8–32.

Note that Y(s)/R(s) and Y(s)/D(s) are given by

$$\frac{Y(s)}{R(s)} = \frac{G_{c1}G_p}{1 + (G_{c1} + G_{c2})G_p}, \qquad \frac{Y(s)}{D(s)} = \frac{G_p}{1 + (G_{c1} + G_{c2})G_p}$$

### Zero-Placement Approach to Improve Response Characteristics Zero Placement

$$\frac{Y(s)}{R(s)} = \frac{p(s)}{s^{n+1} + a_n s^n + a_{n-1} s^{n-1} + \dots + a_2 s^2 + a_1 s + a_0}$$

If we choose p(s) as

$$p(s) = a_2 s^2 + a_1 s + a_0 = a_2(s + s_1)(s + s_2)$$

that is, choose the zeros  $s = -s_1$  and  $s = -s_2$  such that, together with  $a_2$ , the numerator polynomial p(s) is equal to the sum of the last three terms of the denominator polynomial—then the system will exhibit no steady-state errors in response to the step input, ramp input, and acceleration input.

## Zero-Placement Approach to Improve Response Characteristics Determination of *G*<sub>c2</sub>

**Determination of G\_{c2}.** Now that the coefficients of the transfer function Y(s)/R(s) are all known and Y(s)/R(s) is given by

$$\frac{Y(s)}{R(s)} = \frac{a_2 s^2 + a_1 s + a_0}{s^{n+1} + a_n s^n + a_{n-1} s^{n-1} + \dots + a_2 s^2 + a_1 s + a_0} \tag{8-4}$$

we have

$$\begin{split} \frac{Y(s)}{R(s)} &= G_{c1} \frac{Y(s)}{D(s)} \\ &= \frac{G_{c1} s K A(s)}{s B(s) + (\alpha s + \beta + \gamma s^2) K} \\ &= \frac{G_{c1} s K A(s)}{s^{n+1} + a_n s^n + a_{n-1} s^{n-1} + \dots + a_2 s^2 + a_1 s + a_0} \end{split}$$

## Zero-Placement Approach to Improve Response Characteristics Determination of *G*<sub>c2</sub>

Since  $G_{c1}$  is a PID controller and is given by

$$G_{c1} = \frac{\alpha_1 s + \beta_1 + \gamma_1 s^2}{s} \frac{1}{A(s)}$$

Y(s)/R(s) can be written as

$$\frac{Y(s)}{R(s)} = \frac{K(\alpha_1 s + \beta_1 + \gamma_1 s^2)}{s^{n+1} + a_n s^n + a_{n-1} s^{n-1} + \dots + a_2 s^2 + a_1 s + a_0}$$

Therefore, we choose

$$K\gamma_1 = a_2, \qquad K\alpha_1 = a_1, \qquad K\beta_1 = a_0$$

so that

$$G_{c1} = \frac{a_1 s + a_0 + a_2 s^2}{K s} \frac{1}{A(s)}$$
 (8-5)

## Zero-Placement Approach to Improve Response Characteristics Determination of *G*<sub>c2</sub>

The response of this system to the unit-step reference input can be made to exhibit the maximum overshoot between the chosen upper and lower limits, such as

$$2\%$$
 < maximum overshoot <  $10\%$ 

The response of the system to the ramp reference input or acceleration reference input can be made to exhibit no steady-state error. The characteristic of the system of Equation (8-4) is that it generally exhibits a short settling time. If we wish to further shorten the settling time, then we need to allow a larger maximum overshoot—for example,

The controller  $G_{c2}$  can now be determined from Equations (8–3) and (8–5). Since

$$G_{c1}+G_{c2}=\frac{\alpha s+\beta+\gamma s^2}{s}\frac{1}{A(s)}$$

we have

$$G_{c2} = \left[\frac{\alpha s + \beta + \gamma s^{2}}{s} - \frac{a_{1}s + a_{0} + a_{2}s^{2}}{Ks}\right] \frac{1}{A(s)}$$


$$= \frac{(K\alpha - a_{1})s + (K\beta - a_{0}) + (K\gamma - a_{2})s^{2}}{Ks} \frac{1}{A(s)}$$
(8-6)

The two controllers  $G_{c1}$  and  $G_{c2}$  can be determined from Equations (8–5) and (8–6).

**EXAMPLE 8-4** Consider the two-degrees-of-freedom control system shown in Figure 8-33. The plant transfer function  $G_p(s)$  is given by

$$G_p(s) = \frac{10}{s(s+1)}$$

Design controllers  $G_{cl}(s)$  and  $G_{c2}(s)$  such that the maximum overshoot in the response to the unit-step reference input be less than 19%, but more than 2%, and the settling time be less than 1 sec. It is desired that the steady-state errors in following the ramp reference input and acceleration reference input be zero. The response to the unit-step disturbance input should have a small amplitude and settle to zero quickly.



### Bibliography

 Ogata, Katsuhiko. Modern Control Engineering. Fifth Edition. Prentice Hall. 2009. Chapter 8.