

Pharma A/S Calibration Temperature Test Sheet

Issued: 01.09 (YR-2)	Doc. No: PAS-MAN-011.EN	Page 1 of 1
Editor: Maint Eng	Archive: Trail for document archive	
Approved: Maint Mgr		Version: 2.0

YR = Present year

Instrument:

Certificate number: Pharma A/S ID Temp 112067	
Instrument name: TI 012 Temperature sensor on fermenter tank T02	
Model: TST319 Class A (Pt 100)	Serial number: 1653876
Manufacturer: Endress & Hauser	

Instrument in tolerance:	X	Instrument out of tolerance:	
--------------------------	---	------------------------------	--

Standard instrument used:

Manufacturer	Model	Serial	Last verification	Due for verification
Beamex	MC6-T150	B-23268	01.12.(YR-2)	01.12.(YR-1)

Calibration data (Temperature °C):

Scale	Instrument Reading	Datalogger Reading	Desired Accuracy	Deviation	Corrected reading	Pass/Fail
Low	10,5	10,7	0,5	0,2	10,7	PASS
Medium	48,6	48,6	0,5	0	48,6	PASS
High	92,1	92,8	0,5	0,7	92,3	FAIL PASS

Completion	
Calibration performed by: <i>Electrician Technician</i>	Date: 02.24.YR
Calibration Review:	Date: