



Asset Performance: Ene 11 Installed controls



Credits

No Minimum Standard

Aim

To reduce operational energy consumption and associated carbon emissions by installing appropriate controls to reduce unnecessary energy consumption (waste).

Question

1. Are there internal temperature controllers in individual rooms or zones?
2. Can the output from the heat generator and the cooling generator be modulated?
3. Does the system have an interlock control?
4. Can the air flow be controlled at room level?
5. Is the supply air temperature controlled?
6. Is the air humidity controlled?

Credits	Question	Select a single answer option	Points awarded	Points available
*	1	Asset does not have both heating and cooling	Filtered	0
		Yes, with communication between controllers	3	3
		Yes, by thermostatic values or an electronic controller	2	3
		No	0	3
*	2	Asset does not have both heating and cooling	Filtered	0
		Indoor temperature control	3	3
		Outside temperature compensation control	2	3
		No control	0	3
*	3	Asset does not have both heating and cooling	Filtered	0
		Total interlock	3	3

Credits	Question	Select a single answer option	Points awarded	Points available
		Partial interlock	2	3
		No interlock	0	3
*	4	No mechanical ventilation or heating or cooling distributed by air	Filtered	0
		Demand or presence dependent air flow control at room level	3	3
		Time dependent air flow control at room level	2	3
		No air flow control at room level	0	3
*	5	No heating or cooling distributed by air	Filtered	0
		Variable set point with load compensation of supply air temperature	3	3
		Variable set point with outdoor temperature compensation of supply air temperature	2	3
		Constant set point for supply air temperature	1	3
		No control of air supply temperature	0	3
*	6	No humidification provided in the asset	Filtered	0
		Room or exhaust or supply air humidity control	3	3
		Supply air humidity limitation	2	3
		No air humidity control	0	3

* Refer to Methodology

Methodology

Credit allocation

Credits are based on the percentage of points achieved against the number of points available as follows;

Table 22: Allocation of Credits

Percentage of available points achieved	Credits
≥ 20%	1
≥ 40%	2
≥ 60%	3
≥ 80%	4

Evidence

Criteria	Evidence requirement
-	The evidence below is not exhaustive, please also refer to the 'BREEAM evidential requirements' section in the scope of the Guidance for appropriate evidence types which can be used to demonstrate compliance.
All	Visual inspection and verification through photographic evidence of controls.
All	Extract of relevant O&M manuals or a copy of manufacturer information.

Definitions

Interlock control:

This control prevents the heating system operating when the cooling system is operating and vice versa.