



Management Performance: Ene 21 Renewable electricity generated



Contributes to 50 credits
available for operational
energy rating



No Minimum
Standard

Aim

To minimise operational energy consumption and the associated carbon emissions by generating renewable electricity.

Question

1. What is the quantity of electricity generated by on-site and community renewable energy schemes in kWh per year (as metered in the reporting period)?
2. What is the net quantity of electricity exported off-site in kWh per year (as metered in the reporting period)?

Credits	Question	Enter value
-	1.	kWh/year
-	2.	kWh/year

Assessment criteria

Criterion	Assessment criteria
1.	To qualify as on-site or community renewable energy the generation source must be located on or near to the asset and must be connected to the asset using a private wire arrangement.
2.	Assessors must confirm that the metered electricity data relates to the start and end date

Methodology

Reporting period

The intention is that the user enters energy consumption data based on a 365-day reporting period; for both years. However, it is possible to enter data for any reporting period between 11 and 13 months. Any reporting period outside of the 11 to 13-month range would be invalid and result in zero credits being scored.

Evidence

Criteria	Evidence requirement
-	The evidence below is not exhaustive, please also refer to the 'BREEAM evidential requirements' section in the scope of the Guidance for appropriate evidence types which can be used to demonstrate compliance.
1	Photographic evidence of relevant generation meter
2	BEMS data or copies of verified data for the reporting period specified

Definitions

Private wire arrangement:

A private wire arrangement is one where electricity generated, on or in the vicinity of, the site is fed directly to the building being assessed, by dedicated power supplies. Electricity which is surplus to the instantaneous demand of the building, may be fed back to the grid supply network.