



Asset Performance:

Hea 02 Control of glare from sunlight



Credits



No Minimum Standard

Aim

To recognise and encourage features that control glare from sunlight in occupied spaces.

Question

Are features that control glare from sunlight provided in relevant occupied space?

Credits	Answer	Select a single answer option
0	A.	Question not answered
0	B.	No
2	C.	Yes, in $\geq 50\%$ of all relevant occupied space
4	D.	Yes, in $\geq 80\%$ of all relevant occupied space

Assessment criteria

Criterion	Assessment criteria	Applicable Answer
1.	Credits are awarded based on the percentage of relevant occupied space (weighted by floor area) that contains compliant glare control features (see Methodology).	C, D
2.	Control of glare from sunlight is required in occupied space where glare could be problematic for regular asset users. This includes in spaces with computer workstations that are used regularly (e.g. in offices, laboratories, libraries, control rooms and reception desks) and in spaces where people are likely to spend a significant amount of time in fixed locations (e.g. classrooms, hospital wards, retail checkouts, court rooms and factory production lines). Glare control must provide shading from both high-level summer and low-level winter sun where relevant to the sun positions found year-round in the country of assessment. Where relevant, glare control features must cover roof lights as well as side windows.	C, D
3.	Where a relevant occupied space does not have any windows or roof lights and is not at risk of glare from sunlight from connected spaces without glare control measures, e.g. atria, then the space can be considered to be compliant with the criteria and can be included in the calculation of the	C, D

Criterion	Assessment criteria	Applicable Answer
	percentage of relevant occupied space with compliant glare control features (see Methodology).	
4.	Potentially compliant glare control features include: • Building-integrated measures, e.g. overhangs or fins. • Occupant-controlled devices such as opaque Venetian or close weave fabric blinds, where the openness factor of blinds is 1% or less, and where the fabric light transmittance value is < 0.1 (10%). • External shading or brise soleil. • The asset's form or layout mitigates the potential for glare from sunlight, e.g. adjacent buildings provide adequate shade, north facing side windows for locations in the northern hemisphere, etc. • A combination of the above. The use of curtains, tinted glazing or window films are not compliant glare control features as they do not provide sufficient control to optimise daylight into the space and are likely to cause asset users to rely more on artificial lighting.	C, D

Methodology

Calculating the percentage of occupied space with compliant glare control features

The percentage is calculated based on the net internal area of relevant occupied space as follows:

Percentage of relevant occupied space with compliant glare control features =

$$\left(\frac{\text{Net internal area of relevant occupied space with compliant glare control features}}{\text{Total net internal area of all relevant occupied space requiring compliant glare control features}} \right) \times 100$$

For example, for an asset with a total net internal area of all occupied space of 1,000 m², at least 500 m² of net internal floor area of occupied space must have compliant glare control features to achieve any credits.

Evidence

Criteria	Evidence requirement
-	The evidence below is not exhaustive, please also refer to the 'BREEAM evidential requirements' section in the scope of the Guidance for appropriate evidence types which can be used to demonstrate compliance.
1 - 4	Photographic evidence of glare control features.

Definitions

Glare:

Condition of vision in which there is discomfort or a reduction in the ability to see details or objects, caused by an unsuitable distribution or range of luminance, or by extreme contrasts.

Additional information

Solar shading guidance

The following reference sources provide guidance on commonly used glare control features and shading devices and may be used to help find the best solution(s) for an asset's situation:

- BR 364 Solar shading of buildings (Second edition), BRE, 2018
- Tips for Daylighting with Windows: The Integrated Approach, Lawrence Berkeley National Laboratory and US Department of Energy, 2013.