



Asset Performance:

Wat 09 Isolation valves



Credits

No Minimum Standard

Aim

To minimise unnecessary water consumption due to defects and to minimise disruption during maintenance.

Question

What percentage of water fixtures and equipment have isolation valves fitted?

Credits	Answer	Select a single answer option
0	A.	Question not answered
0	B.	0%
1	C.	≥1 to <50%
2	D.	≥50 to <75%
3	E.	≥75 to <100%
4	F.	100%

Assessment criteria

Criterion	Assessment criteria	Applicable Answer
1.	Evidence illustrates that isolation valves are installed for relevant water using equipment within the asset. Relevant equipment includes (but is not limited to): a) Wash basin b) Shower c) Toilet d) Urinal e) Washing machine f) Dishwasher.	B – F

Criterion	Assessment criteria	Applicable Answer
2.	If isolation valves are fitted to areas in which water using equipment are installed, such as shower blocks and toilet areas, the aim of the credit would be met. The equipment in these areas can then be included in the overall percentage.	B – F
3.	Isolation valves are classified as any valve in the pipe which prevents the flow of water to a specific piece of equipment or area.	B – F
4.	Isolation valves must be easily accessible.	B – F
5.	Isolation valves can be automatic or manual.	B – F

Specific notes

Asset type specific	
1.	No facilities Where the asset under assessment contains no water using equipment and therefore there is no water supply to the building identify and assess the facilities most likely to be used by the occupants and visitors to the asset under assessment. This rule also applies where the assessment consists solely of an extension to an existing building, i.e. where the extended building contains no new water using equipment because there are facilities present within the existing building.

Evidence

Criteria	Evidence requirement
-	The evidence below is not exhaustive, please also refer to the 'BREEAM evidential requirements' section in the scope of the Guidance for appropriate evidence types which can be used to demonstrate compliance.
All	Photographic evidence of water isolation controls.