



Asset Performance:

Ene 13 Solar photovoltaic (PV) panels



Credits



No Minimum Standard

Aim

To minimise carbon emissions through on-site renewable energy generation from photovoltaics (PV).

Question

1. Is there any accessible roof area where PV panels could be installed?
2. What is the total accessible roof area (m²) where PV panels could be installed?
3. What is the total area of PV panels installed on the roofs?
4. Is there any significant over shading of PV panels on the roof?
5. Are there any accessible areas elsewhere on-site where PV panels could be installed?
6. What is the total area of accessible areas elsewhere on-site where PV panels could be installed?
7. What is the total area of PV panels installed elsewhere on-site?
8. Is there any significant over shading of PV panels elsewhere on-site?

Credits	Question	For questions 2,3,6 and 7 provide area in m ² . For questions 1,4,5 and 8 select Yes or No
Max. 4	1.	Yes/No
Max. 4	2.	m ²
Max. 4	3.	m ²
Max. 4	4.	Yes/No
Max. 4	5.	Yes/No
Max. 4	6.	m ²
Max 4	7.	m ²
Max. 4	8.	Yes/No

Assessment criteria

Criterion	Assessment criteria	Applicable Answer
1.	Filtering Where the asset does not have an accessible roof or suitable site areas, this issue can be filtered out of the assessment.	All

Methodology

Credits	Total PV panels installed (m ²) = (Q2+Q5)/total accessible area where PV panels could be installed (m ²) (Q1+Q4)	% of PV panels covered (significant over shading)
1	>10%	>30%
2	>30%	>70%
3	>50%	-
4	>70%	-

Evidence

Criteria	Evidence requirement
-	The evidence below is not exhaustive, please also refer to the 'BREEAM evidential requirements' section in the scope of the Guidance for appropriate evidence types which can be used to demonstrate compliance.
All	Extract of relevant O&M manuals or a copy of manufacturer information.
All	Visual inspection and verification through photographic evidence of the PV panels

Definitions

Accessible area elsewhere on-site:

This is the area defined by the perimeter of the asset. This excludes car parking areas, landscaping, and other nonbuilding facilities.

Accessible roof area:

This relates to the area of the roof where it would be feasible to install PV panels.

Significant over shading:

Over shading is significant where 60% or more of the sky is blocked from the panel by obstacles.