



Management Performance:

Ene 20 Carbon intensity district heating and cooling



Contributes to 50 credits
available for operational
energy rating

☆☆☆☆☆☆
☆☆☆☆☆
☆☆☆☆
☆☆☆
☆☆
☆
No Minimum
Standard

Aim

To minimise operational energy consumption and the associated carbon emissions by employing effective energy management practices.

Question

1. If known, what is the carbon intensity of the district heating system in kgCO₂eq/kWh delivered heat?
2. If known, what is the carbon intensity of the district cooling system in kgCO₂eq/kWh delivered cooling?

Credits	Question	Enter value
-	1	kgCO ₂ eq/kWh
-	2	kgCO ₂ eq/kWh

Assessment criteria

Criterion	Assessment criteria
1.	The carbon intensity of the district heating and/or cooling system should be sourced from the supplier of this system.
2.	The carbon intensity value should be an average annual value and should be provided for the most recent year available.
3.	As a minimum, the carbon emissions from all fuels used to generate heat or to generate cooling must include all direct (scope 1) emissions and indirect (scope 2) emissions associated with any electricity used to generate heat or to generate cooling and take account of distribution losses.

Evidence

Criteria	Evidence requirement
-	The evidence below is not exhaustive, please also refer to the 'BREEAM evidential requirements' section in the scope of the Guidance for appropriate evidence types which can be used to demonstrate compliance.

Criteria	Evidence requirement
1	Relevant literature/records/data or other information from the district heating and/or district cooling supplier stating the carbon intensity of the system