



Asset Performance:

Hea 06 View out



Credits

No Minimum Standard

Aim

To allow asset users the opportunity for the relaxation afforded by a change of scene and a change from a constant focus at workstations.

Question

Do relevant spaces with workstations for asset users have an adequate external view out of a window?

Credits	Answer	Select a single answer option
0	A.	Question not answered
0	B.	No
1	C.	Yes, $\geq 80\%$ of the net internal area within each relevant space provides an adequate view out in $\geq 50\%$ of all relevant spaces within the asset
2	D.	Yes, $\geq 95\%$ of the net internal area within each relevant space provides an adequate view out in $\geq 50\%$ of all relevant spaces within the asset
3	E.	Yes, $\geq 80\%$ of the net internal area within each relevant space provides an adequate view out in $\geq 80\%$ of all relevant spaces within the asset
4	F.	Yes, $\geq 95\%$ of the net internal area within each relevant space provides an adequate view out in $\geq 80\%$ of all relevant spaces within the asset

Assessment criteria

Criterion	Assessment criteria	Applicable Answer
1.	Credits are awarded based on the percentage of relevant spaces that contain a compliant view out (see Methodology).	C – F
2.	Relevant spaces should be within 8m horizontal distance from a window or permanent opening providing a view out. The area of the window or opening must be at least 20% of the surrounding wall area. The view out must be a view of a landscape or buildings (rather than just the sky) at seated eye level (1.2 – 1.3m) within the relevant space and should ideally be through an external window. A view into an internal courtyard or atrium will comply	C – F

Criterion	Assessment criteria	Applicable Answer
	provided the distance from the opening to the back wall of the courtyard or atrium is at least 10m.	
3.	Relevant spaces requiring a view out include: a) Spaces with fixed workstations or desks that are used by regular asset users (e.g. members of staff) for 30 minutes or more per day. b) Spaces where close work is performed or visual aids are used by regular asset users (e.g. members of staff) for 30 minutes or more per day. c) Where a view out will be of benefit to the asset users, e.g. in spaces where occupants are likely to spend a significant amount of time. Spaces that do not require a view out include: a) Nurse bases where they are located centrally in a ward or patient area in order to enable patient observation. b) Courts and interview rooms where compliance is not possible due to security or privacy criteria. c) Clinical areas where the control of environmental or operational conditions prevents such spaces from providing a view out. d) Conference rooms, lecture theatres, sports halls, cinemas, space used for acute special educational needs, etc. e) Where exclusion or limitation of natural light is a functional requirement of the space, e.g. laboratories, media spaces, etc. f) Isolated workstations for intermittent, short-term work, e.g. within a server room.	C – F

Specific notes

Asset type specific	
1.	Supportive housing and Educational Halls of Residence For living rooms in self-contained flats and for communal lounges, individual bedrooms and bedsits in sheltered housing, all relevant space must be within 5m of a wall which has a window or permanent opening providing an adequate view out. The window or opening must be $\geq 20\%$ of the surrounding wall area.
2.	Healthcare buildings Patient-occupied spaces, e.g. wards and dayrooms, with inpatient areas must meet the minimum room depth and window area in criterion 2, PLUS the distance between the wall with the window or opening and the nearest external solid object (e.g. building, screen, wall or fence) is $\geq 10\text{m}$.

Methodology

Calculating the percentage of relevant space with a compliant view out

For each relevant space, the percentage net internal area with a compliant view out is calculated as follows:

Percentage of relevant space with a compliant view out =

$$\left(\frac{\text{Net internal area of relevant space with a compliant view out}}{\text{Total net internal area of relevant space}} \right) \times 100$$

For example, for a relevant space with a net internal area of 10m², at least 8m² or 9.5m² of net internal floor area within the relevant space must have a compliant view out to demonstrate compliance with the criteria for the respective credit levels.

At least 85% of all the relevant spaces within the asset must comply with the criteria. This is calculated based simply on the number of relevant spaces with a compliant view out as follows:

Percentage of all relevant spaces with a compliant view out =

$$\left(\frac{\text{Number of relevant spaces with a compliant view out}}{\text{Total number of relevant spaces}} \right) \times 100$$

For example, if there are 20 relevant spaces within the asset, at least 10 of these spaces would need to have a compliant view out to achieve any credits. In this example, to achieve maximum credits, at least 95% of the net internal area in at least 16 spaces must have a compliant view out.

Evidence

Criteria	Evidence requirement
-	The evidence below is not exhaustive, please also refer to the 'BREEAM evidential requirements' section in the scope of the Guidance for appropriate evidence types which can be used to demonstrate compliance.
All	Photographic evidence.
All	Floor plans illustrating the room depths and window areas for each relevant space.