

LESER GmbH & Co.KG  
Postfach 26 16 51 D-20506 Hamburg  
Wendenstr. 133-135 D-20537 Hamburg

Firma  
HESCH Industrietechnik GmbH  
Postfach 17 55  
90707 Fürth

Customers Order No.:	190847
LESER-Job-No.:	20415326 / 10
LESER-Customers-No.:	111733
LESER-Contact:	Florian Schmidt
Fon:	040 25165 146
Fax:	040 25165 500
eMail:	schmidt.f@leser.com

Attention! Translation of original and signed document.

### Inspection certificate 3.2 according to DIN EN 10204 for setting of safety valves

in accordance to AD 2000-Merkblatt A2 chapter 11.4, AD 2000-Merkblatt HP 512R chapter 5, HP 512 chapter 7 and PED 2014/68/EU, annex I chapter 3.2.3

### Test object

High Performance Safety Relief Valve, Type 442 DIN,  
open bonnet, lifting device H3,  
for steam, gas and liquid service

Art.-No.	Cold differential test pressure		Option Code: <b>K7UM33MB1K4XH03K3GP2AJA7X00H88H84H51H47H22L8JL64L49H01</b>			
<b>4422.4575</b>	<b>18,24 barg</b>	<b>264,6 psig</b>	Further SV-Info:			
Tag-No.	LESER-Job-No.	Pos.-No.	Serial-No.	Body material	Nominal size: Inlet   Outlet	Pressure rating: Inlet   Outlet
	<b>20415326</b>	<b>10</b>	11574735	1.0619/ WCB/ WCC	DN 100   DN 150	PN 40   PN 16
Kind of certification	VdTUEV Type Test Approval		EG-Type Examination		ASME Certification	
Rules	AD 2000-Merkblatt A2:		DIN EN ISO 4126-1:		ASME-Code Sec.VIII, Div.1:	
Certification No. / valid until	D/G:	TÜV-SV 19-576 05.24	G/S:	072020111Z0008/0/08-3 06.20	G/S:	M37044 02.24
	F:	TÜV-SV 19-576 05.24	L:	072020111Z0008/0/08-3 06.20	L:	M37055 02.24
Flow diameter	d <sub>0</sub>	92 [mm]	-	92 [mm]	-	3,622 [in.]
Flow area	A	6647,6 [mm <sup>2</sup> ]	A	6647,6 [mm <sup>2</sup> ]	A	10,304 [sq.in.]
Certified derated coefficient of discharge	a <sub>w</sub>	D/G: 0,70 F: 0,45	K <sub>dr</sub>	G/S: 0,70 L: 0,45	K	G/S: 0,699 L: 0,521
Certified capacity						
Lift	H	22,4 [mm]	h	22,4 [mm]	l	0,88 [in.]
Overpressure	c	D/G: 5 [%] F: 10 [%]	c	G/S: 5 [%] L: 10 [%]	-	G/S: 10[%] L: 10[%]
Cold differential test pressure	p	18,24 [bar g]	p <sub>e</sub>	18,24 [bar g]	cdtp	264,6 [psig]
Temperature	T	250,00 [°C]	T	250,00 [°C]	T	482 [°F]
Backpressure	p <sub>a</sub>	0,00 [bar g]	-	0,00 [bar g]	-	0,00 [psig]
Set pressure	p	18,00 [bar g]	p	18,00 [bar g]	p	261,1 [psig]

### Setting

Setting at  
with  
at  
according to LGS 0202.

[X] air  
[X] ambient temperature

[ ] water  
[ ] saturated steam temperature

18,24 [X] barg [ ] psig  
[ ] saturated steam  
[ ] °C [ ] °F

The safety valve is locked by a seal, marked with:




Anatoli Vilenski  
Inspection Representative

Attention! Translation of original and signed document.

Representative of the AB of the TÜVNORD