

## LESER CERTIFICATE FOR GLOBAL APPLICATION

Inspection certificate 3.1 according to DIN EN 10204

Declaration of conformity according to Pressure Equipment Directive 2014/68/EU

LESER GmbH & Co. KG - Postfach 26 16 51 - 20506 Hamburg - Germany

Firma  
HESCH Industrietechnik GmbH  
Postfach 17 55  
D-90707 Fürth  
Deutschland

Customers Order No.: 190847  
LESER-Job-No.: 20415326 / 10  
LESER-Customers-No.: 111733

LESER-Contact: Florian Schmidt  
Fon: 040 25165 146  
Fax: 040 25165 500  
eMail: schmidt.f@leser.com

This LESER CGA confirms that the undermentioned LESER safety valves are manufactured and certified according to the rules world-wide. LESER makes the world-wide employment possible of the safety valves by the reference on these regulations.

**1 Test object** High Performance Safety Relief Valve, Type 442 DIN,  
open bonnet, lifting device H3,  
for steam, gas and liquid service

Art.-No.	Cold differential test pressure		Option Code: <b>K7UM33MB1K4XH03K3GP2AJA7X00H88H84H51H47H22L8JL64L49H01</b>			
4422.4575	18,24 barg	264,58 psig	Further SV-Info:			
Tag-No.:	LESER-Job-No.	Pos.No.	Serial-No.:	Body material	Nominal size: Inlet   Outlet	Pressure rating: Inlet   Outlet
	20415326	10	11574734	1.0619/ WCB/ WCC	DN 100   DN 150	PN 40   PN 16
Kind of certification	VdTUEV-Type test approval		EC Type-examination		ASME certification	
Rules	AD 2000-Merkblatt A2:		DIN EN ISO 4126-1:		ASME-Code Sec.VIII, Div.1:	
Certification No./ valid until	D/G:	TÜV-SV 19-576 05.24	G/S:	072020111Z0008/0/08-3 06.20	G/S:	M37044 02.24
	F:	TÜV-SV 19-576 05.24	L:	072020111Z0008/0/08-3 06.20	L:	M37055 02.24
Flow diameter	d <sub>0</sub>	92 [mm]	-	92 [mm]	-	3,622 [in.]
Flow area	A	6647,6 [mm <sup>2</sup> ]	A	6647,6 [mm <sup>2</sup> ]	A	10,304 [sq.in.]
Certified derated coefficient of discharge	a <sub>w</sub>	D/G: 0,70 F: 0,45	K <sub>dr</sub>	G/S: 0,70 L: 0,45	K	G/S: 0,699 L: 0,521
Certified capacity						
Lift	H	22,4 [mm]	h	22,4 [mm]	I	0,88 [in.]
Overpressure	c	D/G: 5 [%] or 0,1bar for p<1bar F: 10 [%] or 0,1bar for p<1bar	c	G/S: 5 [%] or 0,1bar for p<1bar L: 10 [%] or 0,1bar for p<1bar	-	G/S: 10[%] or 3,0psig for p<30,0 psig L: 10[%] or 3,0psig for p<30,0 psig
Cold differential test pressure	p	18,24 [bar g]	p <sub>e</sub>	18,24 [bar g]	cdtp	264,58 [psig]
Temperature	T	250,00 [°C]	T	250,00 [°C]	T	482 [°F]
Backpressure	p <sub>a</sub>	0,00 [bar g]	-	0,00 [bar g]	-	0,00 [psig]
Set pressure	p	18,00 [bar g]	p	18,00 [bar g]	p	261,07 [psig]

## 2 Conformity assessment procedure and LESER Management Systems

Conformity assessment procedure: Category IV according to PED 2014/68/EU Modul B D/D1  
Notified Body: TÜV NORD Systems GmbH & Co. KG, Große Bahnstraße 31, D-22525 Hamburg  
Certification No.: 0045

LESER Management Systems: Quality Management System DIN EN ISO 9001  
Environmental Management System DIN EN ISO 14001  
Production Quality Assurance PED 2014/68/EU Modul D/D1  
ASME Certificate of Authorization ASME Code Sec.VIII, Div.1

## 3 Regulations

3.1 LESER certifies with this CGA that design, marking, production an approval of this pressure equipment corresponds to the requirements of the following harmonized standards and other regulations.

Harmonized standards:	Other regulations:			
DIN EN ISO 4126-1	PED 2014/68/EU	VdTÜV SV 100	ASME-Code Sec. II	API RP 521
DIN EN ISO 4126-7	AD 2000-Merkblatt A2		ASME-Code Sec. VIII Div.1	API Std. 526
DIN EN 12266-1	AD 2000-Merkblatt A4		ASME PTC 25	API Std. 527
DIN EN 12266-2	AD2000-Merkblatt HP0		API RP 520	API RP 576

LESER GmbH & Co. KG-Hamburg HRA 82 424  
20537 Hamburg, Wendenstr. 133-135  
BoM: Joachim Klaus, Thomas Gellweiler, Alexander Vocke

+49 (40) 251 65 - 100  
sales@leser.com;www.leser.com

UniCredit Bank AG, Hamburg  
BLZ 200 300 00  
Konto - Account 3203171  
BIC: HYVEDEMM300  
IBAN: DE64 2003 0000 0003 2031 71  
USt-ID - VAT-Reg DE 118840936

LESER - The-Safety-Valve.com

3.2 Tests	Directive	DIN EN ISO	DIN EN 12266		ASME CODE	API			AD2000 Merkblatt			LESER Standard
	2014/68/EU Annex 1	4126-1	Teil 1	Teil 2	Sec.VIII Div.1	526	527	576	A2	A4	HPO	
Cdtp test	3.2.3	6.5			UG 136(d)(4)	4.2	2/3/4	6.2.14	11.1 11.4			LGS 0202-E
Seat tightness test		6.6	4.4 (P12)		UG 136(d)(5)	4.3	2/3/4	6.2.17				LGS 0201-E
Back seat tightness test				4. (P21)	UG 136(d)(3)							LGS 0201-E
Test of operability		7		4. (F20)					11.3			LGS 0217-E
Shell tightness test			4.4 (P11)									LGS 0201-E
Hydrostatic testing	3.2.2 7.4	6.3.1 6.3.2	4.4 (P10)		UG 136(d)(2)				6.1.(4)			LGS 0209-E
Nondestructive testing					UG 136(f)				6.1.(5)			LGS 0203-E - 0206-E
Material identification									6.1.(6)			LGS 0207-E
Marking					UG 77				8	7.1	4	LGS 0218-E
Check for dimensional accuracy									6.1.(3)			LGS 0216-E

## 4 Material suitability and marking

4.1. LESER certifies that the suitability of the used materials corresponds to the regulations quoted in chapter 3.1.

4.2. The marking of the materials as well as their transmission took place as follows:

Pos	Description	Material	Manufacturer	Manufacturer Batch	LESER-Batch
1	Body	1.0619/SA-216 WCB/WCC	Peekay Steel Castings Ltd. PKC	E6073	

## 5 Tests

The tests specified in the following one were realized on basis of the stated LESER standards without any objection:

### 5.1. Shell test

Shell tightness test

Hydrostatic testing

Nondestructive testing

Material identification check for alloyed materials

The realization of the test took place through:

LESER GmbH & Co.KG

### 5.2. Valve setting and testing

Seat tightness

Back seat tightness

Operability

Cold differential test pressure

Setting at

with

at

☒ air

☒ ambient temperature

☐ water

☐ saturated steam temperature

18,24 ☒ barg ☐ psig

☐ saturated steam

☐ \_\_\_\_\_ ☐ °C ☐ °F

The safety valve is protected by a seal marked with:




Setting and testing were done by:

LESER GmbH & Co. KG

## 6 CERTIFICATE OF SHOP COMPLIANCE

By the signature of the Certified Individual (CI) noted below, we certify that the statements made in this report are correct and that all details for design, material, construction, and workmanship of the pressure relief devices are conform with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

UV Certificate of Authorization No.: 27,806



Joachim Klaus  
LESER GmbH & Co. KG

Date: 17.07.2019



Anatoli Vilenski  
Inspection Representative Works Hohenwestedt  
Certified Individual (CI)