

# Keysight InfiniiVision 3000T X-Series Oscilloscopes



Programmer's  
Guide

# Notices

© Keysight Technologies, Inc. 2005-2020

No part of this manual may be reproduced in any form or by any means (including electronic storage and retrieval or translation into a foreign language) without prior agreement and written consent from Keysight Technologies, Inc. as governed by United States and international copyright laws.

## Revision

Version 07.35.0000

## Edition

December 14, 2020

Available in electronic format only

Published by:

Keysight Technologies, Inc.  
1900 Garden of the Gods Road  
Colorado Springs, CO 80907 USA

## Warranty

The material contained in this document is provided "as is," and is subject to being changed, without notice, in future editions. Further, to the maximum extent permitted by applicable law, Keysight disclaims all warranties, either express or implied, with regard to this manual and any information contained herein, including but not limited to the implied warranties of merchantability and fitness for a particular purpose. Keysight shall not be liable for errors or for incidental or consequential damages in connection with the furnishing, use, or performance of this document or of any information contained herein. Should Keysight and the user have a separate written agreement with warranty terms covering the material in this document that conflict with these terms, the warranty terms in the separate agreement shall control.

## Technology License

The hardware and/or software described in this document are furnished under a license and may be used or copied only in accordance with the terms of such license.

## U.S. Government Rights

The Software is "commercial computer software," as defined by Federal Acquisition Regulation ("FAR") 2.101. Pursuant to FAR 12.212 and 27.405-3 and Department of Defense FAR Supplement ("DFARS") 227.7202, the U.S. government acquires commercial computer software under the same terms by which the software is customarily provided to the public. Accordingly, Keysight provides the Software to U.S. government customers under its standard commercial license, which is embodied in its End User License Agreement (EULA), a copy of which can be found at [www.keysight.com/find/sweula](http://www.keysight.com/find/sweula). The license set forth in the EULA represents the exclusive authority by which the U.S. government may use, modify, distribute, or disclose the Software. The EULA and the license set forth therein, does not require or permit, among other things, that Keysight: (1) Furnish technical information related to commercial computer software or commercial computer software documentation that is not customarily provided to the public; or (2) Relinquish to, or otherwise provide, the government rights in excess of these rights customarily provided to the public to use, modify, reproduce, release, perform, display, or disclose commercial computer software or commercial computer software documentation. No additional government requirements beyond those set forth in the EULA shall apply, except to the extent that those terms, rights, or licenses are explicitly required from all providers of commercial computer software pursuant to the FAR and the DFARS and are set forth specifically in writing elsewhere in the EULA. Keysight shall be under no obligation to update, revise or otherwise modify the Software. With respect to any technical data as defined by FAR 2.101, pursuant to FAR 12.211 and 27.404.2 and DFARS 227.7102, the U.S. government acquires no greater than Limited Rights as defined in FAR 27.401 or DFAR 227.7103-5 (c), as applicable in any technical data.

## Safety Notices

### CAUTION

A **CAUTION** notice denotes a hazard. It calls attention to an operating procedure, practice, or the like that, if not correctly performed or adhered to, could result in damage to the product or loss of important data. Do not proceed beyond a **CAUTION** notice until the indicated conditions are fully understood and met.

### WARNING

A **WARNING** notice denotes a hazard. It calls attention to an operating procedure, practice, or the like that, if not correctly performed or adhered to, could result in personal injury or death. Do not proceed beyond a **WARNING** notice until the indicated conditions are fully understood and met.

# In This Book

This book is your guide to programming the 3000T X-Series oscilloscopes:

**Table 1** InfiniiVision 3000T X-Series Oscilloscope Models, Bandwidths, Sample Rates

Bandwidth	100 MHz	200 MHz	350 MHz	500 MHz	1 GHz
Sample Rate (interleaved, non-interleaved)	5 GSa/s, 2.5 GSa/s				
2-Channel + 16 Logic Channels MSO	MSO-X 3012T	MSO-X 3022T	MSO-X 3032T	MSO-X 3052T	MSO-X 3102T
4-Channel + 16 Logic Channels MSO	MSO-X 3014T	MSO-X 3024T	MSO-X 3034T	MSO-X 3054T	MSO-X 3104T
2-Channel DSO	DSO-X 3012T	DSO-X 3022T	DSO-X 3032T	DSO-X 3052T	DSO-X 3102T
4-Channel DSO	DSO-X 3014T	DSO-X 3024T	DSO-X 3034T	DSO-X 3054T	DSO-X 3104T

The first few chapters describe how to set up and get started:

- **Chapter 1**, “What’s New,” starting on page 41, describes programming command changes in the latest version of oscilloscope software.
- **Chapter 2**, “Setting Up,” starting on page 65, describes the steps you must take before you can program the oscilloscope.
- **Chapter 3**, “Getting Started,” starting on page 73, gives a general overview of oscilloscope program structure and shows how to program the oscilloscope using a few simple examples.
- **Chapter 4**, “Sequential (Blocking) vs. Overlapped Commands,” starting on page 87, describes these command types and how they affect the oscilloscope and synchronization.
- **Chapter 5**, “Commands Quick Reference,” starting on page 89, is a brief listing of the 3000T X-Series oscilloscope commands and syntax.

The next chapters provide reference information on common commands, root level commands, other subsystem commands, and error messages:

- **Chapter 6**, “Common (\*) Commands,” starting on page 227, describes commands defined by the IEEE 488.2 standard that are common to all instruments.
- **Chapter 7**, “Root (:) Commands,” starting on page 255, describes commands that reside at the root level of the command tree and control many of the basic functions of the oscilloscope.
- **Chapter 8**, “:ACQuire Commands,” starting on page 299, describes commands for setting the parameters used when acquiring and storing data.
- **Chapter 9**, “:BUS<n> Commands,” starting on page 319, describes commands that control all oscilloscope functions associated with the digital channels bus display.

- **Chapter 10**, “:CALibrate Commands,” starting on page 329, describes utility commands for determining the state of the calibration factor protection button.
- **Chapter 11**, “:CHANnel<n> Commands,” starting on page 341, describes commands that control all oscilloscope functions associated with individual analog channels or groups of channels.
- **Chapter 12**, “:COMPliance Commands,” starting on page 371, describes commands that control the USB 2.0 signal quality analysis feature.
- **Chapter 13**, “:COUNter Commands,” starting on page 383, describes commands that control the counter analysis feature.
- **Chapter 14**, “:DEMO Commands,” starting on page 395, describes commands that control the education kit demonstration signals that can be output on the oscilloscope’s Demo 1 and Demo 2 terminals.
- **Chapter 15**, “:DIGItal<d> Commands,” starting on page 403, describes commands that control all oscilloscope functions associated with individual digital channels.
- **Chapter 16**, “:DISPlay Commands,” starting on page 411, describes commands that control how waveforms, graticule, and text are displayed and written on the screen.
- **Chapter 17**, “:DVM Commands,” starting on page 437, describes commands that control the digital voltmeter analysis feature.
- **Chapter 18**, “:EXTernal Trigger Commands,” starting on page 443, describes commands that control the input characteristics of the external trigger input.
- **Chapter 19**, “:FFT Commands,” starting on page 449, describes commands that control the FFT function in the oscilloscope.
- **Chapter 20**, “:FRANalysis Commands,” starting on page 469, describes commands that control oscilloscope functions associated with the Frequency Response Analysis (FRA) feature, which is available with the license-enabled built-in waveform generator).
- **Chapter 21**, “:FUNCTION<m> Commands,” starting on page 485, describes commands that control math waveforms.
- **Chapter 22**, “:HARDcopy/:HCOPY Commands,” starting on page 541, describes commands that set and query the selection of hardcopy device and formatting options.
- **Chapter 23**, “:LISTER Commands,” starting on page 561, describes commands that turn on/off the Lister display for decoded serial data and get the Lister data.
- **Chapter 24**, “:LTESt Commands,” starting on page 565, describes commands that control the Measurement Limit Test feature.
- **Chapter 25**, “:MARKer Commands,” starting on page 579, describes commands that set and query the settings of X-axis markers (X1 and X2 cursors) and the Y-axis markers (Y1 and Y2 cursors).
- **Chapter 26**, “:MEASure Commands,” starting on page 601, describes commands that select automatic measurements (and control markers).

- **Chapter 27**, “:MEASure Power Commands,” starting on page 693, describes measurement commands that are available when the power measurements and analysis application is licensed and enabled.
- **Chapter 28**, “:MTEST Commands,” starting on page 717, describes commands that control the license-enabled mask test feature.
- **Chapter 29**, “:POD Commands,” starting on page 751, describes commands that control all oscilloscope functions associated with groups of digital channels.
- **Chapter 30**, “:POWer Commands,” starting on page 757, describes commands that control the license-enabled power measurement application.
- **Chapter 31**, “:RECall Commands,” starting on page 861, describes commands that recall previously saved oscilloscope setups, reference waveforms, or masks.
- **Chapter 32**, “:SAVE Commands,” starting on page 873, describes commands that save oscilloscope setups, screen images, and data.
- **Chapter 33**, “:SBUS<n> Commands,” starting on page 905, describes commands that control oscilloscope functions associated with the serial decode bus and serial triggering.
- **Chapter 34**, “:SEARch Commands,” starting on page 1201, describes commands that control oscilloscope functions associated with searching for waveform events.
- **Chapter 35**, “:SYSTem Commands,” starting on page 1311, describes commands that control basic system functions of the oscilloscope.
- **Chapter 36**, “:TIMEbase Commands,” starting on page 1337, describes commands that control all horizontal sweep functions.
- **Chapter 37**, “:TRIGger Commands,” starting on page 1349, describes commands that control the trigger modes and parameters for each trigger type.
- **Chapter 38**, “:WAVEform Commands,” starting on page 1453, describes commands that provide access to waveform data.
- **Chapter 39**, “:WGEN<w> Commands,” starting on page 1491, describes commands that control waveform generator (Option WGN) functions and parameters.
- **Chapter 40**, “:WMEMory<r> Commands,” starting on page 1537, describes commands that control reference waveforms.
- **Chapter 41**, “Obsolete and Discontinued Commands,” starting on page 1547, describes obsolete commands which still work but have been replaced by newer commands and discontinued commands which are no longer supported.
- **Chapter 42**, “Error Messages,” starting on page 1605, lists the instrument error messages that can occur while programming the oscilloscope.

The command descriptions in this reference show upper and lowercase characters. For example, :AUToscale indicates that the entire command name is :AUTOSCALE. The short form, :AUT, is also accepted by the oscilloscope.

Then, there are chapters that describe programming topics and conceptual information in more detail:

- **Chapter 43**, "Status Reporting," starting on page 1613, describes the oscilloscope's status registers and how to check the status of the instrument.
- **Chapter 44**, "Synchronizing Acquisitions," starting on page 1645, describes how to wait for acquisitions to complete before querying measurement results or performing other operations with the captured data.
- **Chapter 45**, "More About Oscilloscope Commands," starting on page 1665, contains additional information about oscilloscope programming commands.

Finally, there is a chapter that contains programming examples:

- **Chapter 46**, "Programming Examples," starting on page 1675.

#### Mixed-Signal Oscilloscope Channel Differences

Because both the "analog channels only" oscilloscopes (DSO models) and the mixed-signal oscilloscopes (MSO models) have analog channels, topics that describe analog channels refer to all oscilloscope models. Whenever a topic describes digital channels, that information applies only to the mixed-signal oscilloscope models.

#### See Also

- For more information on using the SICL, VISA, and VISA COM libraries in general, see the documentation that comes with the Keysight IO Libraries Suite.
- For information on controller PC interface configuration, see the documentation for the interface card used (for example, the Keysight 82350B GPIB interface).
- For information on oscilloscope front-panel operation, see the *User's Guide*.
- For detailed connectivity information, refer to the *Keysight Technologies USB/LAN/GPIB Connectivity Guide*. For a printable electronic copy of the *Connectivity Guide*, direct your Web browser to [www.keysight.com](http://www.keysight.com) and search for "Connectivity Guide".
- For the latest versions of this and other manuals, see:  
<http://www.keysight.com/find/3000T-X-Series-manual>

# Contents

In This Book / 3

## 1 What's New

What's New in Version 7.35 / 42
What's New in Version 7.30 / 44
What's New in Version 7.20 / 46
What's New in Version 7.10 / 48
What's New in Version 4.08 / 51
What's New in Version 4.07 / 54
What's New in Version 4.06 / 56
What's New in Version 4.05 / 57
Version 4.00 at Introduction / 59
Command Differences From 4000 X-Series Oscilloscopes / 60

## 2 Setting Up

Step 1. Install Keysight IO Libraries Suite software / 66
Step 2. Connect and set up the oscilloscope / 67
Using the USB (Device) Interface / 67
Using the LAN Interface / 67
Using the GPIB Interface / 68
Step 3. Verify the oscilloscope connection / 69

## 3 Getting Started

Basic Oscilloscope Program Structure / 74
Initializing / 74
Capturing Data / 74
Analyzing Captured Data / 75

Programming the Oscilloscope / 76
Referencing the IO Library / 76
Opening the Oscilloscope Connection via the IO Library / 77
Initializing the Interface and the Oscilloscope / 77
Using :AUToscale to Automate Oscilloscope Setup / 78
Using Other Oscilloscope Setup Commands / 78
Capturing Data with the :DIGitize Command / 79
Reading Query Responses from the Oscilloscope / 81
Reading Query Results into String Variables / 82
Reading Query Results into Numeric Variables / 82
Reading Definite-Length Block Query Response Data / 82
Sending Multiple Queries and Reading Results / 83
Checking Instrument Status / 84
Other Ways of Sending Commands / 85
Telnet Sockets / 85
Sending SCPI Commands Using Browser Web Control / 85

## 4 Sequential (Blocking) vs. Overlapped Commands

## 5 Commands Quick Reference

Command Summary / 90
Syntax Elements / 224
Number Format / 224
<NL> (Line Terminator) / 224
[ ] (Optional Syntax Terms) / 224
{ } (Braces) / 224
:= (Defined As) / 224
< > (Angle Brackets) / 225
... (Ellipsis) / 225
n,...,p (Value Ranges) / 225
d (Digits) / 225
Quoted ASCII String / 225
Definite-Length Block Response Data / 225

## 6 Common (\*) Commands

*CLS (Clear Status) / 233
*ESE (Standard Event Status Enable) / 234
*ESR (Standard Event Status Register) / 236
*IDN (Identification Number) / 238
*LRN (Learn Device Setup) / 239
*OPC (Operation Complete) / 240

\*OPT (Option Identification) / 241  
\*RCL (Recall) / 243  
\*RST (Reset) / 244  
\*SAV (Save) / 247  
\*SRE (Service Request Enable) / 248  
\*STB (Read Status Byte) / 250  
\*TRG (Trigger) / 252  
\*TST (Self Test) / 253  
\*WAI (Wait To Continue) / 254

## 7 Root (: ) Commands

:ACTivity / 259  
:AER (Arm Event Register) / 260  
:AUToscale / 261  
:AUToscale:AMODE / 263  
:AUToscale:CHANnels / 264  
:AUToscale:FDEBug / 265  
:BLANK / 266  
:DIGitize / 268  
:HWEnable (Hardware Event Enable Register) / 270  
:HWERegister:CONDITION (Hardware Event Condition Register) / 272  
:HWERegister[:EVENT] (Hardware Event Event Register) / 273  
:MTEenable (Mask Test Event Enable Register) / 274  
:MTERegister[:EVENT] (Mask Test Event Event Register) / 276  
:OPEE (Operation Status Enable Register) / 278  
:OPERegister:CONDITION (Operation Status Condition Register) / 280  
:OPERegister[:EVENT] (Operation Status Event Register) / 283  
:OVLenable (Overload Event Enable Register) / 286  
:OVLRegister (Overload Event Register) / 288  
:PRINt / 290  
:RSTate? / 291  
:RUN / 292  
:SERial / 293  
:SINGle / 294  
:STATus / 295  
:STOP / 296  
:TER (Trigger Event Register) / 297  
:VIEW / 298

## 8 :ACQuire Commands

:ACQuire:AALias / 302

:ACQuire:COMplete / 303  
:ACQuire:COUNt / 304  
:ACQuire:DAALias / 305  
:ACQuire:DIGitizer / 306  
:ACQuire:MODE / 307  
:ACQuire:POINTs[:ANALog] / 308  
:ACQuire:POINTs[:ANALog]:AUTO / 309  
:ACQuire:SEGmented:ANALyze / 310  
:ACQuire:SEGmented:COUNt / 311  
:ACQuire:SEGmented:INDex / 312  
:ACQuire:SRATe[:ANALog] / 315  
:ACQuire:SRATe[:ANALog]:AUTO / 316  
:ACQuire:TYPE / 317

## 9 :BUS<n> Commands

:BUS<n>:BIT<m> / 321  
:BUS<n>:BITS / 322  
:BUS<n>:CLEar / 324  
:BUS<n>:DISPlay / 325  
:BUS<n>:LABel / 326  
:BUS<n>:MASK / 327

## 10 :CALibrate Commands

:CALibrate:DATE / 331  
:CALibrate:LABel / 332  
:CALibrate:OUTPut / 333  
:CALibrate:PROTected / 335  
:CALibrate:STARt / 336  
:CALibrate:STATus / 337  
:CALibrate:TEMPerature / 338  
:CALibrate:TIME / 339

## 11 :CHANnel<n> Commands

:CHANnel<n>:BWLimit / 345  
:CHANnel<n>:COUpling / 346  
:CHANnel<n>:DISPLAY / 347  
:CHANnel<n>:IMPedance / 348  
:CHANnel<n>:INVert / 349  
:CHANnel<n>:LABel / 350  
:CHANnel<n>:OFFSet / 351  
:CHANnel<n>:PROBe / 352

:CHANnel<n>:PROBe:BTN / 353  
:CHANnel<n>:PROBe:CALibration / 354  
:CHANnel<n>:PROBe:EXTernal / 355  
:CHANnel<n>:PROBe:EXTernal:GAIN / 356  
:CHANnel<n>:PROBe:EXTernal:UNITS / 357  
:CHANnel<n>:PROBe:HEAD[:TYPE] / 358  
:CHANnel<n>:PROBe:ID / 359  
:CHANnel<n>:PROBe:MMODel / 360  
:CHANnel<n>:PROBe:MODE / 361  
:CHANnel<n>:PROBe:RSENse / 362  
:CHANnel<n>:PROBe:SKEW / 363  
:CHANnel<n>:PROBe:STYPe / 364  
:CHANnel<n>:PROBe:ZOOM / 365  
:CHANnel<n>:PROTection / 366  
:CHANnel<n>:RANGE / 367  
:CHANnel<n>:SCALE / 368  
:CHANnel<n>:UNITS / 369  
:CHANnel<n>:VERNier / 370

## 12 :COMPliance Commands

:COMPliance:USB:AUTosetup / 372  
:COMPliance:USB:HUBS / 373  
:COMPliance:USB:RUN / 374  
:COMPliance:USB:SOURce:ADJacent / 375  
:COMPliance:USB:SOURce:DIFFerential / 376  
:COMPliance:USB:SOURce:DMINus / 377  
:COMPliance:USB:SOURce:DPLus / 378  
:COMPliance:USB:TEST / 379  
:COMPliance:USB:TEST:CONNnection / 380  
:COMPliance:USB:TEST:TYPE / 381

## 13 :COUNter Commands

:COUNter:CURREnt / 385  
:COUNter:ENABLE / 386  
:COUNter:MODE / 387  
:COUNter:NDIGits / 388  
:COUNter:SOURce / 389  
:COUNter:TOTalize:CLEar / 390  
:COUNter:TOTalize:GATE:ENABLE / 391  
:COUNter:TOTalize:GATE:POLarity / 392  
:COUNter:TOTalize:GATE:SOURce / 393

:COUNter:TOTalize:SLOPe / 394

## 14 :DEMO Commands

:DEMO:FUNCtion / 396  
:DEMO:FUNCtion:PHASe:PHASe / 401  
:DEMO:OUTPut / 402

## 15 :DIGItal<d> Commands

:DIGItal<d>:DISPlay / 405  
:DIGItal<d>:LABel / 406  
:DIGItal<d>:POSition / 407  
:DIGItal<d>:SIZE / 408  
:DIGItal<d>:THReShold / 409

## 16 :DISPlay Commands

:DISPlay:ANNotation<n> / 414  
:DISPlay:ANNotation<n>:BACKground / 415  
:DISPlay:ANNotation<n>:COLor / 416  
:DISPlay:ANNotation<n>:TEXT / 417  
:DISPlay:ANNotation<n>:X1Position / 418  
:DISPlay:ANNotation<n>:Y1Position / 419  
:DISPlay:BACKlight / 420  
:DISPlay:CLEar / 421  
:DISPlay:DATA / 422  
:DISPlay:GRATicule:ALABels / 424  
:DISPlay:GRATicule:INTensity / 425  
:DISPlay:GRATicule:TYPE / 426  
:DISPlay:INTensity:WAVeform / 427  
:DISPlay:LABel / 428  
:DISPlay:LABList / 429  
:DISPlay:MENU / 430  
:DISPlay:MESSAge:CLEar / 431  
:DISPlay:PERSistence / 432  
:DISPlay:PERSistence:CLEar / 433  
:DISPlay:SIDebar / 434  
:DISPlay:TRANsparent / 435  
:DISPlay:VECTors / 436

## 17 :DVM Commands

:DVM:ARAnge / 438  
:DVM:CURREnt / 439

:DVM:ENABLE / 440  
:DVM:MODE / 441  
:DVM:SOURce / 442

## 18 :EXTernal Trigger Commands

:EXTernal:BWLImIt / 444  
:EXTernal:PROBe / 445  
:EXTernal:RANGe / 446  
:EXTernal:UNITs / 447

## 19 :FFT Commands

:FFT:AVERage:COUNt / 451  
:FFT:CENTer / 452  
:FFT:CLEar / 453  
:FFT:DISPlay / 454  
:FFT:DMODe / 455  
:FFT:FREQuency:STARt / 457  
:FFT:FREQuency:STOP / 458  
:FFT:GATE / 459  
:FFT:OFFSet / 460  
:FFT:RANGe / 461  
:FFT:REFerence / 462  
:FFT:SCALe / 463  
:FFT:SOURce1 / 464  
:FFT:SPAN / 465  
:FFT:VTPe / 466  
:FFT:WINDOW / 467

## 20 :FRANalysis Commands

:FRANalysis:DATA / 471  
:FRANalysis:ENABLE / 472  
:FRANalysis:FREQuency:MODE / 473  
:FRANalysis:FREQuency:SINGle / 474  
:FRANalysis:FREQuency:STARt / 475  
:FRANalysis:FREQuency:STOP / 476  
:FRANalysis:PPDecade / 477  
:FRANalysis:RUN / 478  
:FRANalysis:SOURce:INPut / 479  
:FRANalysis:SOURce:OUTPut / 480  
:FRANalysis:TRACe / 481  
:FRANalysis:WGEN:LOAD / 482

```
:FRANalysis:WGEN:VOLTage / 483  
:FRANalysis:WGEN:VOLTage:PROFile / 484
```

## 21 :FUNCTION<m> Commands

```
:FUNCTION<m>:AVERage:COUNt / 492  
:FUNCTION<m>:BUS:CLOCk / 493  
:FUNCTION<m>:BUS:SLOPe / 494  
:FUNCTION<m>:BUS:YINCrement / 495  
:FUNCTION<m>:BUS:YORigin / 496  
:FUNCTION<m>:BUS:YUNits / 497  
:FUNCTION<m>:CLEar / 498  
:FUNCTION<m>:DISPlay / 499  
:FUNCTION<m>[:FFT]:BSIZe / 500  
:FUNCTION<m>[:FFT]:CENTer / 501  
:FUNCTION<m>[:FFT]:DETection:POINTs / 502  
:FUNCTION<m>[:FFT]:DETection:TYPE / 503  
:FUNCTION<m>[:FFT]:FREQuency:STARt / 504  
:FUNCTION<m>[:FFT]:FREQuency:STOP / 505  
:FUNCTION<m>[:FFT]:GATE / 506  
:FUNCTION<m>[:FFT]:PHASE:REFerence / 507  
:FUNCTION<m>[:FFT]:RBWidth / 508  
:FUNCTION<m>[:FFT]:READout<n> / 509  
:FUNCTION<m>[:FFT]:SPAN / 510  
:FUNCTION<m>[:FFT]:SRATe / 511  
:FUNCTION<m>[:FFT]:VTYPe / 512  
:FUNCTION<m>[:FFT]:WINDOW / 513  
:FUNCTION<m>:FREQuency:BANDpass:CENTer / 514  
:FUNCTION<m>:FREQuency:BANDpass:WIDTh / 515  
:FUNCTION<m>:FREQuency:HIGHpass / 516  
:FUNCTION<m>:FREQuency:LOWPass / 517  
:FUNCTION<m>:INTegrate:IICondition / 518  
:FUNCTION<m>:INTegrate:IOFFset / 519  
:FUNCTION<m>:LINEar:GAIN / 520  
:FUNCTION<m>:LINEar:OFFSet / 521  
:FUNCTION<m>:OFFSet / 522  
:FUNCTION<m>:OPERation / 523  
:FUNCTION<m>:RANGe / 528  
:FUNCTION<m>:REFERENCE / 529  
:FUNCTION<m>:SCALE / 530  
:FUNCTION<m>:SERChart:SOURce / 531  
:FUNCTION<m>:SERChart:TIME:MODE / 532
```

:FUNCTION<m>:SERChart:TIME:RANGE / 534  
:FUNCTION<m>:SERChart:TIME:OFFSet / 535  
:FUNCTION<m>:SMOooth:POINTs / 536  
:FUNCTION<m>:SOURce1 / 537  
:FUNCTION<m>:SOURce2 / 539  
:FUNCTION<m>:TRENd:NMEasurement / 540

## 22 :HARDcopy/:HCOPY Commands

:HARDcopy:AREA / 544  
:HARDcopy:APRinter / 545  
:HARDcopy:FACTors / 546  
:HARDcopy:FFEed / 547  
:HARDcopy:INKSaver / 548  
:HARDcopy:LAYout / 549  
:HARDcopy:NETWork:ADDRess / 550  
:HARDcopy:NETWork:APPLy / 551  
:HARDcopy:NETWork:DOMain / 552  
:HARDcopy:NETWork:PASSWORD / 553  
:HARDcopy:NETWork:SLOT / 554  
:HARDcopy:NETWork:USERname / 555  
:HARDcopy:PALETTE / 556  
:HARDcopy:PRINTER:LIST / 557  
:HARDcopy:STARt / 558  
:HCOPY:SDUMP:DATA / 559  
:HCOPY:SDUMP:FORMAT / 560

## 23 :LITer Commands

:LITer:DATA / 562  
:LITer:DISPLAY / 563  
:LITer:REFERENCE / 564

## 24 :LTESt Commands

:LTESt:COPY / 567  
:LTESt:COPY:ALL / 568  
:LTESt:COPY:MARGIN / 569  
:LTESt:ENABLE / 570  
:LTESt:FAIL / 571  
:LTESt:LLIMit / 572  
:LTESt:MEASurement / 573  
:LTESt:RESults / 574  
:LTESt:RUMode:SOFailure / 575

:LTEST:TEST / 576  
:LTEST:ULIMit / 577

## 25 :MARKer Commands

:MARKer:DYDX / 582  
:MARKer:MODE / 583  
:MARKer:X1:DISPlay / 584  
:MARKer:X1Position / 585  
:MARKer:X1Y1source / 586  
:MARKer:X2:DISPlay / 587  
:MARKer:X2Position / 588  
:MARKer:X2Y2source / 589  
:MARKer:XDELta / 590  
:MARKer:XUNits / 591  
:MARKer:XUNits:USE / 592  
:MARKer:Y1:DISPlay / 593  
:MARKer:Y1Position / 594  
:MARKer:Y2:DISPlay / 595  
:MARKer:Y2Position / 596  
:MARKer:YDELta / 597  
:MARKer:YUNits / 598  
:MARKer:YUNits:USE / 599

## 26 :MEASure Commands

:MEASure:ALL / 622  
:MEASure:AREa / 623  
:MEASure:BRATe / 624  
:MEASure:BWIDth / 625  
:MEASure:CLEar / 626  
:MEASure:COUNter / 627  
:MEASure:DEFine / 629  
:MEASure:DELay / 632  
:MEASure:DELay:DEFine / 634  
:MEASure:DUAL:CHARge / 635  
:MEASure:DUAL:VAMplitude / 636  
:MEASure:DUAL:VAverage / 637  
:MEASure:DUAL:VBASe / 638  
:MEASure:DUAL:VPP / 639  
:MEASure:DUAL:VRMS / 640  
:MEASure:DUTYcycle / 641  
:MEASure:FALLtime / 642

:MEASure:FFT:ACPR / 643  
:MEASure:FFT:CPOWer / 644  
:MEASure:FFT:OBW / 645  
:MEASure:FFT:THD / 646  
:MEASure:FREQuency / 647  
:MEASure:NDUTy / 648  
:MEASure:NEDGes / 649  
:MEASure:NPULses / 650  
:MEASure:NWIDth / 651  
:MEASure:OVERshoot / 652  
:MEASure:PEDGes / 654  
:MEASure:PERiod / 655  
:MEASure:PHASe / 656  
:MEASure:PPULses / 657  
:MEASure:PREShoot / 658  
:MEASure:PVIDth / 659  
:MEASure:RESults / 660  
:MEASure:RISetime / 663  
:MEASure:SDEViation / 664  
:MEASure:SHOW / 665  
:MEASure:SLEWrate / 666  
:MEASure:SOURce / 667  
:MEASure:STATistics / 669  
:MEASure:STATistics:DISPlay / 670  
:MEASure:STATistics:INCRelement / 671  
:MEASure:STATistics:MCOut / 672  
:MEASure:STATistics:RESet / 673  
:MEASure:STATistics:RSDeviation / 674  
:MEASure:TEDGE / 675  
:MEASure:TVALue / 678  
:MEASure:VAMPLitude / 680  
:MEASure:VAVerage / 681  
:MEASure:VBASe / 682  
:MEASure:VMAX / 683  
:MEASure:VMIN / 684  
:MEASure:VPP / 685  
:MEASure:VRATio / 686  
:MEASure:VRMS / 687  
:MEASure:VTOP / 688  
:MEASure:WINDOW / 689  
:MEASure:XMAX / 690  
:MEASure:XMIN / 691

:MEASure:YATX / 692

## 27 :MEASure Power Commands

:MEASure:ANGLE / 698  
:MEASure:APPARENT / 699  
:MEASure:CPLoss / 700  
:MEASure:CRESt / 701  
:MEASure:EFFiciency / 702  
:MEASure:ELOSSs / 703  
:MEASure:FACTOr / 704  
:MEASure:IPOWER / 705  
:MEASure:OFFTime / 706  
:MEASure:ONTime / 707  
:MEASure:OPOWER / 708  
:MEASure:PCURrent / 709  
:MEASure:PLOSSs / 710  
:MEASure:RDSon / 711  
:MEASure:REACTive / 712  
:MEASure:REAL / 713  
:MEASure:RIPPle / 714  
:MEASure:TRESPonse / 715  
:MEASure:VCESat / 716

## 28 :MTEST Commands

:MTEST:ALL / 722  
:MTEST:AMASK:CREate / 723  
:MTEST:AMASK:SOURce / 724  
:MTEST:AMASK:UNITs / 725  
:MTEST:AMASK:XDELta / 726  
:MTEST:AMASK:YDELta / 727  
:MTEST:COUNT:FWAVeforms / 728  
:MTEST:COUNT:RESet / 729  
:MTEST:COUNT:TIME / 730  
:MTEST:COUNT:WAVEforms / 731  
:MTEST:DATA / 732  
:MTEST:DElete / 733  
:MTEST:ENABLE / 734  
:MTEST:LOCK / 735  
:MTEST:RMODE / 736  
:MTEST:RMODE:FACTion:MEASure / 737  
:MTEST:RMODE:FACTion:PRINT / 738

```
:MTEST:RMODE:FACTion:SAVE / 739
:MTEST:RMODE:FACTion:STOP / 740
:MTEST:RMODE:SIGMa / 741
:MTEST:RMODE:TIME / 742
:MTEST:RMODE:WAVeforms / 743
:MTEST:SCALe:BIND / 744
:MTEST:SCALe:X1 / 745
:MTEST:SCALe:XDELta / 746
:MTEST:SCALe:Y1 / 747
:MTEST:SCALe:Y2 / 748
:MTEST:SOURce / 749
:MTEST:TITLe / 750
```

## 29 :POD Commands

```
:POD<n>:DISPlay / 753
:POD<n>:SIZE / 754
:POD<n>:THRehold / 755
```

## 30 :POWer Commands

```
:POWER:CLResponse / 765
:POWER:CLResponse:APPLy / 766
:POWER:CLResponse:DATA / 767
:POWER:CLResponse:DATA:GMARgin / 768
:POWER:CLResponse:DATA:GMARgin:FREQuency / 769
:POWER:CLResponse:DATA:PMARgin / 770
:POWER:CLResponse:DATA:PMARgin:FREQuency / 771
:POWER:CLResponse:FREQuency:MODE / 772
:POWER:CLResponse:FREQuency:SINGle / 773
:POWER:CLResponse:FREQuency:STARt / 774
:POWER:CLResponse:FREQuency:STOP / 775
:POWER:CLResponse:PPDecade / 776
:POWER:CLResponse:SOURce:INPut / 777
:POWER:CLResponse:SOURce:OUTPut / 778
:POWER:CLResponse:TRACe / 779
:POWER:CLResponse:WGEN:LOAD / 780
:POWER:CLResponse:WGEN:VOLTage / 781
:POWER:CLResponse:WGEN:VOLTage:PROFile / 782
:POWER:DESKew / 783
:POWER:EFFiciency:APPLy / 784
:POWER:EFFiciency:TYPE / 785
:POWER:ENABLE / 786
```

:POWER:HARMonics:APPLy / 787  
:POWER:HARMonics:DATA / 788  
:POWER:HARMonics:DISPlay / 789  
:POWER:HARMonics:FAILcount / 790  
:POWER:HARMonics:LINE / 791  
:POWER:HARMonics:POWERfactor / 792  
:POWER:HARMonics:RPOWER / 793  
:POWER:HARMonics:RPOWER:USER / 794  
:POWER:HARMonics:RUNCount / 795  
:POWER:HARMonics:STANDARD / 796  
:POWER:HARMonics:STATus / 797  
:POWER:HARMonics:THD / 798  
:POWER:INRush:APPLy / 799  
:POWER:INRush:EXIT / 800  
:POWER:INRush:NEXT / 801  
:POWER:ITYPE / 802  
:POWER:MODulation:APPLy / 803  
:POWER:MODulation:SOURce / 804  
:POWER:MODulation:TYPE / 805  
:POWER:ONOFF:APPLy / 806  
:POWER:ONOFF:EXIT / 807  
:POWER:ONOFF:NEXT / 808  
:POWER:ONOFF:TEST / 809  
:POWER:ONOFF:THRESHolds / 810  
:POWER:PSRR / 812  
:POWER:PSRR:APPLy / 813  
:POWER:PSRR:DATA / 814  
:POWER:PSRR:FREQuency:MAXimum / 815  
:POWER:PSRR:FREQuency:MINimum / 816  
:POWER:PSRR:FREQuency:MODE / 817  
:POWER:PSRR:FREQuency:SINGle / 818  
:POWER:PSRR:PPDecade / 819  
:POWER:PSRR:SOURce:INPut / 820  
:POWER:PSRR:SOURce:OUTPut / 821  
:POWER:PSRR:TRACe / 822  
:POWER:PSRR:WGEN:LOAD / 823  
:POWER:PSRR:WGEN:VOLTage / 824  
:POWER:PSRR:WGEN:VOLTage:PROFile / 825  
:POWER:QUALity:APPLy / 826  
:POWER:RIPPLE:APPLy / 827  
:POWER:SIGNals:AUTosetup / 828  
:POWER:SIGNals:CYCLES:HARMonics / 829

:POWER:SIGNals:CYCLes:QUALity / 830  
:POWER:SIGNals:DURation:EFFiciency / 831  
:POWER:SIGNals:DURation:MODulation / 832  
:POWER:SIGNals:DURation:ONOFF:OFF / 833  
:POWER:SIGNals:DURation:ONOFF:ON / 834  
:POWER:SIGNals:DURation:RIPPLe / 835  
:POWER:SIGNals:DURation:TRANsient / 836  
:POWER:SIGNals:IEXPected / 837  
:POWER:SIGNals:OVERshoot / 838  
:POWER:SIGNals:VMAXimum:INRush / 839  
:POWER:SIGNals:VMAXimum:ONOFF:OFF / 840  
:POWER:SIGNals:VMAXimum:ONOFF:ON / 841  
:POWER:SIGNals:VSteady:ONOFF:OFF / 842  
:POWER:SIGNals:VSteady:ONOFF:ON / 843  
:POWER:SIGNals:VSteady:TRANsient / 844  
:POWER:SIGNals:SOURce:CURREnt<i> / 845  
:POWER:SIGNals:SOURce:VOLTage<i> / 846  
:POWER:SLEW:APPLy / 847  
:POWER:SLEW:SOURce / 848  
:POWER:SWITch:APPLy / 849  
:POWER:SWITch:CONDuction / 850  
:POWER:SWITch:IREFerence / 851  
:POWER:SWITch:RDS / 852  
:POWER:SWITch:VCE / 853  
:POWER:SWITch:VREFerence / 854  
:POWER:TRANSient:APPLy / 855  
:POWER:TRANSient:EXIT / 856  
:POWER:TRANSient:INITial / 857  
:POWER:TRANSient:INew / 858  
:POWER:TRANSient:NEXT / 859

### 31 :RECall Commands

:RECall:ARBitrary[:STARt] / 864  
:RECall:DBC[:STARt] / 865  
:RECall:FILEname / 866  
:RECall:LDF[:STARt] / 867  
:RECall:MASK[:STARt] / 868  
:RECall:PWD / 869  
:RECall:SETup[:STARt] / 870  
:RECall:WMEMory<r>[:STARt] / 871

## 32 :SAVE Commands

:SAVE:ARBitrary[:STARt] / 877  
:SAVE:COMPliance:USB[:STARt] / 878  
:SAVE:FILEname / 879  
:SAVE:IMAGe[:STARt] / 880  
:SAVE:IMAGe:FACTors / 881  
:SAVE:IMAGe:FORMAT / 882  
:SAVE:IMAGe:INKSaver / 883  
:SAVE:IMAGe:PALETTE / 884  
:SAVE:LISTER[:STARt] / 885  
:SAVE:MASK[:STARt] / 886  
:SAVE:MULTi[:STARt] / 887  
:SAVE:POWER[:STARt] / 888  
:SAVE:PWD / 889  
:SAVE:RESUlt[:STARt] / 890  
:SAVE:RESUlt:FORMAT:CURSOR / 891  
:SAVE:RESUlt:FORMAT:MASK / 892  
:SAVE:RESUlt:FORMAT:MEASurement / 893  
:SAVE:RESUlt:FORMAT:SEARch / 894  
:SAVE:RESUlt:FORMAT:SEGmented / 895  
:SAVE[:SETup[:STARt]] / 896  
:SAVE:WAVeform[:STARt] / 897  
:SAVE:WAVeform:FORMAT / 898  
:SAVE:WAVeform:LENGTH / 899  
:SAVE:WAVeform:LENGTH:MAX / 900  
:SAVE:WAVeform:SEGmented / 901  
:SAVE:WMEMory:SOURce / 902  
:SAVE:WMEMory[:STARt] / 903

## 33 :SBUS<n> Commands

General :SBUS<n> Commands / 907  
:SBUS<n>:DISPlay / 908  
:SBUS<n>:MODE / 909  
:SBUS<n>:A429 Commands / 910  
:SBUS<n>:A429:AUTosetup / 912  
:SBUS<n>:A429:BASE / 913  
:SBUS<n>:A429:BAUDrate / 914  
:SBUS<n>:A429:COUNT:ERRor / 915  
:SBUS<n>:A429:COUNT:RESet / 916  
:SBUS<n>:A429:COUNT:WORD / 917  
:SBUS<n>:A429:FORMAT / 918

:SBUS<n>:A429:SIGNal / 919  
:SBUS<n>:A429:SOURce / 920  
:SBUS<n>:A429:SPeed / 921  
:SBUS<n>:A429:TRIGger:LAbel / 922  
:SBUS<n>:A429:TRIGger:PATTern:DATA / 923  
:SBUS<n>:A429:TRIGger:PATTern:SDI / 924  
:SBUS<n>:A429:TRIGger:PATTern:SSM / 925  
:SBUS<n>:A429:TRIGger:RANGe / 926  
:SBUS<n>:A429:TRIGger:TYPE / 927

:SBUS<n>:CAN Commands / 929  
:SBUS<n>:CAN:COUNT:ERRor / 932  
:SBUS<n>:CAN:COUNT:OVERload / 933  
:SBUS<n>:CAN:COUNT:RESet / 934  
:SBUS<n>:CAN:COUNT:SPEC / 935  
:SBUS<n>:CAN:COUNT:TOTal / 936  
:SBUS<n>:CAN:COUNT:UTILization / 937  
:SBUS<n>:CAN:DISPlay / 938  
:SBUS<n>:CAN:FDSPoint / 939  
:SBUS<n>:CAN:FDSTandard / 940  
:SBUS<n>:CAN:SAMPLEpoint / 941  
:SBUS<n>:CAN:SIGNal:BAUDrate / 942  
:SBUS<n>:CAN:SIGNal:DEFinition / 943  
:SBUS<n>:CAN:SIGNal:FDBaudrate / 944  
:SBUS<n>:CAN:SOURce / 945  
:SBUS<n>:CAN:TRIGger / 946  
:SBUS<n>:CAN:TRIGger:IDFilter / 949  
:SBUS<n>:CAN:TRIGger:PATTern:DATA / 950  
:SBUS<n>:CAN:TRIGger:PATTern:DATA:DLC / 951  
:SBUS<n>:CAN:TRIGger:PATTern:DATA:LENGTH / 952  
:SBUS<n>:CAN:TRIGger:PATTern:DATA:STARt / 953  
:SBUS<n>:CAN:TRIGger:PATTern:ID / 954  
:SBUS<n>:CAN:TRIGger:PATTern:ID:MODE / 955  
:SBUS<n>:CAN:TRIGger:SYMBolic:MESSAge / 956  
:SBUS<n>:CAN:TRIGger:SYMBolic:SIGNal / 957  
:SBUS<n>:CAN:TRIGger:SYMBolic:VALue / 958

:SBUS<n>:CXPI Commands / 959  
:SBUS<n>:CXPI:BAUDrate / 961  
:SBUS<n>:CXPI:PARity / 962  
:SBUS<n>:CXPI:SOURce / 963  
:SBUS<n>:CXPI:TOLerance / 964  
:SBUS<n>:CXPI:TRIGger / 965

:SBUS<n>:CXPI:TRIGger:IDFilter / 967  
:SBUS<n>:CXPI:TRIGger:PTYPe / 968  
:SBUS<n>:CXPI:TRIGger:PATTERn:DATA / 969  
:SBUS<n>:CXPI:TRIGger:PATTERn:DATA:LENGth / 970  
:SBUS<n>:CXPI:TRIGger:PATTERn:DATA:STARt / 971  
:SBUS<n>:CXPI:TRIGger:PATTERn:ID / 972  
:SBUS<n>:CXPI:TRIGger:PATTERn:INFO:CT / 973  
:SBUS<n>:CXPI:TRIGger:PATTERn:INFO:DLC / 974  
:SBUS<n>:CXPI:TRIGger:PATTERn:INFO:NM / 975

:SBUS<n>:FLEXray Commands / 976  
:SBUS<n>:FLEXray:AUTosetup / 978  
:SBUS<n>:FLEXray:BAUDrate / 979  
:SBUS<n>:FLEXray:CHANnel / 980  
:SBUS<n>:FLEXray:COUNT:NULL / 981  
:SBUS<n>:FLEXray:COUNT:RESet / 982  
:SBUS<n>:FLEXray:COUNT:SYNC / 983  
:SBUS<n>:FLEXray:COUNT:TOTal / 984  
:SBUS<n>:FLEXray:SOURce / 985  
:SBUS<n>:FLEXray:TRIGger / 986  
:SBUS<n>:FLEXray:TRIGger:ERRor:TYPE / 987  
:SBUS<n>:FLEXray:TRIGger:EVENT:AUToset / 988  
:SBUS<n>:FLEXray:TRIGger:EVENT:BSS:ID / 989  
:SBUS<n>:FLEXray:TRIGger:EVENT:TYPE / 990  
:SBUS<n>:FLEXray:TRIGger:FRAMe:CCBase / 991  
:SBUS<n>:FLEXray:TRIGger:FRAMe:CCRepetition / 992  
:SBUS<n>:FLEXray:TRIGger:FRAMe:ID / 993  
:SBUS<n>:FLEXray:TRIGger:FRAMe:TYPE / 994

:SBUS<n>:I2S Commands / 995  
:SBUS<n>:I2S:ALIGNment / 998  
:SBUS<n>:I2S:BASE / 999  
:SBUS<n>:I2S:CLOCK:SLOPe / 1000  
:SBUS<n>:I2S:RWIDth / 1001  
:SBUS<n>:I2S:SOURce:CLOCK / 1002  
:SBUS<n>:I2S:SOURce:DATA / 1003  
:SBUS<n>:I2S:SOURce:WSElect / 1004  
:SBUS<n>:I2S:TRIGger / 1005  
:SBUS<n>:I2S:TRIGger:AUDIO / 1007  
:SBUS<n>:I2S:TRIGger:PATTERn:DATA / 1008  
:SBUS<n>:I2S:TRIGger:PATTERn:FORMAT / 1010  
:SBUS<n>:I2S:TRIGger:RANGE / 1011  
:SBUS<n>:I2S:TWIDth / 1012

:SBUS<n>:I2S:WSLow / 1013  
:SBUS<n>:IIC Commands / 1014  
:SBUS<n>:IIC:ASIZe / 1016  
:SBUS<n>:IIC[:SOURce]:CLOCK / 1017  
:SBUS<n>:IIC[:SOURce]:DATA / 1018  
:SBUS<n>:IIC:TRIGger:PATTern:ADDRes / 1019  
:SBUS<n>:IIC:TRIGger:PATTern:DATA / 1020  
:SBUS<n>:IIC:TRIGger:PATTern:DATa2 / 1021  
:SBUS<n>:IIC:TRIGger:QUALifier / 1022  
:SBUS<n>:IIC:TRIGger[:TYPE] / 1023  
  
:SBUS<n>:LIN Commands / 1025  
:SBUS<n>:LIN:DISPlay / 1027  
:SBUS<n>:LIN:PARity / 1028  
:SBUS<n>:LIN:SAMPlepoint / 1029  
:SBUS<n>:LIN:SIGNal:BAUDrate / 1030  
:SBUS<n>:LIN:SOURce / 1031  
:SBUS<n>:LIN:STANDARD / 1032  
:SBUS<n>:LIN:SYNCbreak / 1033  
:SBUS<n>:LIN:TRIGger / 1034  
:SBUS<n>:LIN:TRIGger:ID / 1036  
:SBUS<n>:LIN:TRIGger:PATTern:DATA / 1037  
:SBUS<n>:LIN:TRIGger:PATTern:DATA:LENGth / 1039  
:SBUS<n>:LIN:TRIGger:PATTern:FORMat / 1040  
:SBUS<n>:LIN:TRIGger:SYMBOLic:FRAMe / 1041  
:SBUS<n>:LIN:TRIGger:SYMBOLic:SIGNal / 1042  
:SBUS<n>:LIN:TRIGger:SYMBOLic:VALue / 1043  
  
:SBUS<n>:M1553 Commands / 1044  
:SBUS<n>:M1553:AUTosetup / 1045  
:SBUS<n>:M1553:BASE / 1046  
:SBUS<n>:M1553:SOURce / 1047  
:SBUS<n>:M1553:TRIGger:PATTern:DATA / 1048  
:SBUS<n>:M1553:TRIGger:RTA / 1049  
:SBUS<n>:M1553:TRIGger:TYPE / 1050  
  
:SBUS<n>:MANchester Commands / 1051  
:SBUS<n>:MANchester:BASE / 1053  
:SBUS<n>:MANchester:BAUDrate / 1054  
:SBUS<n>:MANchester:BITorder / 1055  
:SBUS<n>:MANchester:DISPlay / 1056  
:SBUS<n>:MANchester:DSIZe / 1057  
:SBUS<n>:MANchester:HSIZe / 1058

```
:SBUS<n>:MANChester:IDLE:BITS / 1059
:SBUS<n>:MANChester:LOGic / 1060
:SBUS<n>:MANChester:SOURce / 1061
:SBUS<n>:MANChester:SSIZE / 1062
:SBUS<n>:MANChester:START / 1063
:SBUS<n>:MANChester:TOLerance / 1064
:SBUS<n>:MANChester:TRIGger / 1065
:SBUS<n>:MANChester:TRIGger:PATTERn:VALue:DATA / 1066
:SBUS<n>:MANChester:TRIGger:PATTERn:VALue:WIDTh / 1067
:SBUS<n>:MANChester:TSIZE / 1068
:SBUS<n>:MANChester:WSIZE / 1069

:SBUS<n>:NRZ Commands / 1070
:SBUS<n>:NRZ:BASE / 1072
:SBUS<n>:NRZ:BAUDrate / 1073
:SBUS<n>:NRZ:BITorder / 1074
:SBUS<n>:NRZ:DISPlay / 1075
:SBUS<n>:NRZ:DSIZE / 1076
:SBUS<n>:NRZ:FSIZE / 1077
:SBUS<n>:NRZ:HSIZE / 1078
:SBUS<n>:NRZ:IDLE:BITS / 1079
:SBUS<n>:NRZ:IDLE:STATe / 1080
:SBUS<n>:NRZ:LOGic / 1081
:SBUS<n>:NRZ:SOURce / 1082
:SBUS<n>:NRZ:STARt / 1083
:SBUS<n>:NRZ:TRIGger / 1084
:SBUS<n>:NRZ:TRIGger:PATTERn:VALue:DATA / 1085
:SBUS<n>:NRZ:TRIGger:PATTERn:VALue:WIDTh / 1086
:SBUS<n>:NRZ:TSIZE / 1087
:SBUS<n>:NRZ:WSIZE / 1088

:SBUS<n>:SENT Commands / 1089
:SBUS<n>:SENT:CLOCK / 1092
:SBUS<n>:SENT:CRC / 1093
:SBUS<n>:SENT:DISPlay / 1094
:SBUS<n>:SENT:FORMAT / 1096
:SBUS<n>:SENT:IDLE / 1098
:SBUS<n>:SENT:LENGTH / 1099
:SBUS<n>:SENT:PPULse / 1100
:SBUS<n>:SENT:SIGNAl<s>:DISPlay / 1102
:SBUS<n>:SENT:SIGNAl<s>:LENGTH / 1103
:SBUS<n>:SENT:SIGNAl<s>:MULTiplier / 1105
:SBUS<n>:SENT:SIGNAl<s>:OFFSet / 1107
```

```
:SBUS<n>:SENT:SIGNAl<s>:ORDer / 1109
:SBUS<n>:SENT:SIGNAl<s>:STARt / 1111
:SBUS<n>:SENT:SOURce / 1113
:SBUS<n>:SENT:TOlerance / 1115
:SBUS<n>:SENT:TRIGger / 1116
:SBUS<n>:SENT:TRIGger:FAST:DATA / 1118
:SBUS<n>:SENT:TRIGger:SLOW:DATA / 1119
:SBUS<n>:SENT:TRIGger:SLOW:ID / 1121
:SBUS<n>:SENT:TRIGger:SLOW:ILENgt / 1123
:SBUS<n>:SENT:TRIGger:TOLerance / 1124

:SBUS<n>:SPI Commands / 1125
:SBUS<n>:SPI:BITorder / 1127
:SBUS<n>:SPI:CLOCK:SLOPe / 1128
:SBUS<n>:SPI:CLOCK:TIMEout / 1129
:SBUS<n>:SPI:DELay / 1130
:SBUS<n>:SPI:FRAMing / 1131
:SBUS<n>:SPI:SOURce:CLOCK / 1132
:SBUS<n>:SPI:SOURce:FRAME / 1133
:SBUS<n>:SPI:SOURce:MISO / 1134
:SBUS<n>:SPI:SOURce:MOSt / 1135
:SBUS<n>:SPI:TRIGger:PATTern:MISO:DATA / 1136
:SBUS<n>:SPI:TRIGger:PATTern:MISO:WIDTh / 1137
:SBUS<n>:SPI:TRIGger:PATTern:MOSt:DATA / 1138
:SBUS<n>:SPI:TRIGger:PATTern:MOSt:WIDTh / 1139
:SBUS<n>:SPI:TRIGger:TYPE / 1140
:SBUS<n>:SPI:WIDTh / 1141

:SBUS<n>:UART Commands / 1142
:SBUS<n>:UART:BASE / 1145
:SBUS<n>:UART:BAUDrate / 1146
:SBUS<n>:UART:BITorder / 1147
:SBUS<n>:UART:COUNT:ERRor / 1148
:SBUS<n>:UART:COUNT:RESet / 1149
:SBUS<n>:UART:COUNT:RXFRAMES / 1150
:SBUS<n>:UART:COUNT:TXFRAMES / 1151
:SBUS<n>:UART:FRAMing / 1152
:SBUS<n>:UART:PARity / 1153
:SBUS<n>:UART:POLarity / 1154
:SBUS<n>:UART:SOURce:RX / 1155
:SBUS<n>:UART:SOURce:TX / 1156
:SBUS<n>:UART:TRIGger:BASE / 1157
:SBUS<n>:UART:TRIGger:BURSt / 1158
```

```
:SBUS<n>:UART:TRIGger:DATA / 1159
:SBUS<n>:UART:TRIGger:IDLE / 1160
:SBUS<n>:UART:TRIGger:QUALifier / 1161
:SBUS<n>:UART:TRIGger:TYPE / 1162
:SBUS<n>:UART:WIDTH / 1163

:SBUS<n>:USB Commands / 1164
:SBUS<n>:USB:BASE / 1167
:SBUS<n>:USB:SOURce:DMINus / 1168
:SBUS<n>:USB:SOURce:DPLus / 1169
:SBUS<n>:USB:SOURce:DIFFerential / 1170
:SBUS<n>:USB:SPEed / 1171
:SBUS<n>:USB:TRIGger / 1172
:SBUS<n>:USB:TRIGger:ADDRess / 1173
:SBUS<n>:USB:TRIGger:CRC / 1174
:SBUS<n>:USB:TRIGger:DATA / 1175
:SBUS<n>:USB:TRIGger:DATA:LENGTH / 1176
:SBUS<n>:USB:TRIGger:ENDPoint / 1177
:SBUS<n>:USB:TRIGger:ET / 1178
:SBUS<n>:USB:TRIGger:FRAMe / 1179
:SBUS<n>:USB:TRIGger:HADDress / 1180
:SBUS<n>:USB:TRIGger:PCheck / 1181
:SBUS<n>:USB:TRIGger:PID:DATA / 1182
:SBUS<n>:USB:TRIGger:PID:HANDshake / 1183
:SBUS<n>:USB:TRIGger:PID:SPECial / 1184
:SBUS<n>:USB:TRIGger:PID:TOKen / 1185
:SBUS<n>:USB:TRIGger:PORT / 1186
:SBUS<n>:USB:TRIGger:SC / 1187
:SBUS<n>:USB:TRIGger:SEU / 1188

:SBUS<n>:USBPd Commands / 1189
:SBUS<n>:USBPd:SOURce / 1190
:SBUS<n>:USBPd:TRIGger / 1191
:SBUS<n>:USBPd:TRIGger:HEADER / 1192
:SBUS<n>:USBPd:TRIGger:HEADER:CMESsage / 1194
:SBUS<n>:USBPd:TRIGger:HEADER:DMESsage / 1196
:SBUS<n>:USBPd:TRIGger:HEADER:EMESsage / 1197
:SBUS<n>:USBPd:TRIGger:HEADER:VALue / 1199
:SBUS<n>:USBPd:TRIGger:HEADER:QUALifier / 1200
```

## 34 :SEARch Commands

General :SEARch Commands / 1202

:SEARch:COUNt / 1203  
:SEARch:EVENT / 1204  
:SEARch:MODE / 1205  
:SEARch:STATe / 1206

:SEARch:EDGE Commands / 1207  
:SEARch:EDGE:SLOPe / 1208  
:SEARch:EDGE:SOURce / 1209

:SEARch:GLITch Commands / 1210  
:SEARch:GLITch:GREaterthan / 1211  
:SEARch:GLITch:LESSthan / 1212  
:SEARch:GLITch:POLarity / 1213  
:SEARch:GLITch:QUALifier / 1214  
:SEARch:GLITch:RANGe / 1215  
:SEARch:GLITch:SOURce / 1216

:SEARch:PEAK Commands / 1217  
:SEARch:PEAK:EXCursion / 1218  
:SEARch:PEAK:NPEaks / 1219  
:SEARch:PEAK:SOURce / 1220  
:SEARch:PEAK:THRehold / 1221

:SEARch:RUNT Commands / 1222  
:SEARch:RUNT:POLarity / 1223  
:SEARch:RUNT:QUALifier / 1224  
:SEARch:RUNT:SOURce / 1225  
:SEARch:RUNT:TIME / 1226

:SEARch:TRANSition Commands / 1227  
:SEARch:TRANSition:QUALifier / 1228  
:SEARch:TRANSition:SLOPe / 1229  
:SEARch:TRANSition:SOURce / 1230  
:SEARch:TRANSition:TIME / 1231

:SEARch:SERial:A429 Commands / 1232  
:SEARch:SERial:A429:LABel / 1233  
:SEARch:SERial:A429:MODE / 1234  
:SEARch:SERial:A429:PATTERn:DATA / 1235  
:SEARch:SERial:A429:PATTERn:SDI / 1236  
:SEARch:SERial:A429:PATTERn:SSM / 1237

:SEARch:SERial:CAN Commands / 1238  
:SEARch:SERial:CAN:MODE / 1239  
:SEARch:SERial:CAN:PATTERn:DATA / 1241  
:SEARch:SERial:CAN:PATTERn:DATA:LENGth / 1242

:SEARch:SERial:CAN:PATTern:ID / 1243  
:SEARch:SERial:CAN:PATTern:ID:MODE / 1244  
:SEARch:SERial:CAN:SYMBolic:MESSAge / 1245  
:SEARch:SERial:CAN:SYMBolic:SIGNAl / 1246  
:SEARch:SERial:CAN:SYMBolic:VALue / 1247

:SEARch:SERial:FLEXray Commands / 1248  
:SEARch:SERial:FLEXray:CYCLE / 1249  
:SEARch:SERial:FLEXray:DATA / 1250  
:SEARch:SERial:FLEXray:DATA:LENGth / 1251  
:SEARch:SERial:FLEXray:FRAMe / 1252  
:SEARch:SERial:FLEXray:MODE / 1253

:SEARch:SERial:I2S Commands / 1254  
:SEARch:SERial:I2S:AUDIO / 1255  
:SEARch:SERial:I2S:MODE / 1256  
:SEARch:SERial:I2S:PATTern:DATA / 1257  
:SEARch:SERial:I2S:PATTern:FORMAT / 1258  
:SEARch:SERial:I2S:RANGE / 1259

:SEARch:SERial:IIC Commands / 1260  
:SEARch:SERial:IIC:MODE / 1261  
:SEARch:SERial:IIC:PATTern:ADDResS / 1263  
:SEARch:SERial:IIC:PATTern:DATA / 1264  
:SEARch:SERial:IIC:PATTern:DATA2 / 1265  
:SEARch:SERial:IIC:QUALifier / 1266

:SEARch:SERial:LIN Commands / 1267  
:SEARch:SERial:LIN:ID / 1268  
:SEARch:SERial:LIN:MODE / 1269  
:SEARch:SERial:LIN:PATTern:DATA / 1270  
:SEARch:SERial:LIN:PATTern:DATA:LENGTH / 1271  
:SEARch:SERial:LIN:PATTern:FORMAT / 1272  
:SEARch:SERial:LIN:SYMBolic:FRAMe / 1273  
:SEARch:SERial:LIN:SYMBolic:SIGNAl / 1274  
:SEARch:SERial:LIN:SYMBolic:VALue / 1275

:SEARch:SERial:M1553 Commands / 1276  
:SEARch:SERial:M1553:MODE / 1277  
:SEARch:SERial:M1553:PATTern:DATA / 1278  
:SEARch:SERial:M1553:RTA / 1279

:SEARch:SERial:SENT Commands / 1280  
:SEARch:SERial:SENT:FAST:DATA / 1281  
:SEARch:SERial:SENT:MODE / 1282

:SEARch:SERial:SENT:SLOW:DATA / 1283  
:SEARch:SERial:SENT:SLOW:ID / 1284  
:SEARch:SERial:SPI Commands / 1285  
:SEARch:SERial:SPI:MODE / 1286  
:SEARch:SERial:SPI:PATTERn:DATA / 1287  
:SEARch:SERial:SPI:PATTERn:WIDTh / 1288  
:SEARch:SERial:UART Commands / 1289  
:SEARch:SERial:UART:DATA / 1290  
:SEARch:SERial:UART:MODE / 1291  
:SEARch:SERial:UART:QUALifier / 1292  
:SEARch:SERial:USB Commands / 1293  
:SEARch:SERial:USB:MODE / 1295  
:SEARch:SERial:USB:ADDResS / 1296  
:SEARch:SERial:USB:CRC / 1297  
:SEARch:SERial:USB:DATA / 1298  
:SEARch:SERial:USB:DATA:LENGth / 1299  
:SEARch:SERial:USB:ENDPoint / 1300  
:SEARch:SERial:USB:ET / 1301  
:SEARch:SERial:USB:FRAMe / 1302  
:SEARch:SERial:USB:HADDress / 1303  
:SEARch:SERial:USB:PID:DATA / 1304  
:SEARch:SERial:USB:PID:HANDshake / 1305  
:SEARch:SERial:USB:PID:SPECial / 1306  
:SEARch:SERial:USB:PID:TOKen / 1307  
:SEARch:SERial:USB:PORT / 1308  
:SEARch:SERial:USB:SC / 1309  
:SEARch:SERial:USB:SEU / 1310

### 35 :SYSTem Commands

:SYSTem:DATE / 1314  
:SYSTem:DIDentifier / 1315  
:SYSTem:DSP / 1316  
:SYSTem:ERRor / 1317  
:SYSTem:LOCK / 1318  
:SYSTem:PERSONa[:MANufacturer] / 1319  
:SYSTem:PERSONa[:MANufacturer]:DEFault / 1320  
:SYSTem:PRESet / 1321  
:SYSTem:PROTection:LOCK / 1324  
:SYSTem:RLOGger / 1325  
:SYSTem:RLOGger:DESTination / 1326

:SYSTem:RLOGger:DISPlay / 1327  
:SYSTem:RLOGger:FNAME / 1328  
:SYSTem:RLOGger:STATe / 1329  
:SYSTem:RLOGger:TRANsparent / 1330  
:SYSTem:RLOGger:WMODe / 1331  
:SYSTem:SETup / 1332  
:SYSTem:TIME / 1334  
:SYSTem:TOUCH / 1335

## 36 :TImebase Commands

:TImebase:MODE / 1339  
:TImebase:POSIon / 1340  
:TImebase:RANGE / 1341  
:TImebase:REFerence / 1342  
:TImebase:REFerence:LOCation / 1343  
:TImebase:SCALe / 1344  
:TImebase:VERNier / 1345  
:TImebase:WINDOW:POSIon / 1346  
:TImebase:WINDOW:RANGE / 1347  
:TImebase:WINDOW:SCALe / 1348

## 37 :TRIGger Commands

General :TRIGger Commands / 1351  
:TRIGger:FORCe / 1353  
:TRIGger:HFReject / 1354  
:TRIGger:HOLDoff / 1355  
:TRIGger:HOLDoff:MAXimum / 1356  
:TRIGger:HOLDoff:MINimum / 1357  
:TRIGger:HOLDoff:RANDOM / 1358  
:TRIGger:LEVel:ASETup / 1359  
:TRIGger:LEVel:HIGH / 1360  
:TRIGger:LEVel:LOW / 1361  
:TRIGger:MODE / 1362  
:TRIGger:NREject / 1363  
:TRIGger:SWEep / 1364  
:TRIGger:DELay Commands / 1365  
:TRIGger:DELay:ARM:SLOPe / 1366  
:TRIGger:DELay:ARM:SOURce / 1367  
:TRIGger:DELay:TDELay:TIME / 1368  
:TRIGger:DELay:TRIGger:COUNt / 1369  
:TRIGger:DELay:TRIGger:SLOPe / 1370

:TRIGger:DELay:TRIGger:SOURce / 1371  
:TRIGger:EBURst Commands / 1372  
:TRIGger:EBURst:COUNt / 1373  
:TRIGger:EBURst:IDLE / 1374  
:TRIGger:EBURst:SLOPe / 1375  
:TRIGger:EBURst:SOURce / 1376  
:TRIGger[:EDGE] Commands / 1377  
:TRIGger[:EDGE]:COUPling / 1379  
:TRIGger[:EDGE]:LEVel / 1380  
:TRIGger[:EDGE]:REJect / 1381  
:TRIGger[:EDGE]:SLOPe / 1382  
:TRIGger[:EDGE]:SOURce / 1383  
:TRIGger:GLITch Commands / 1384  
:TRIGger:GLITch:GREaterthan / 1386  
:TRIGger:GLITch:LESSthan / 1387  
:TRIGger:GLITch:LEVel / 1388  
:TRIGger:GLITch:POLarity / 1389  
:TRIGger:GLITch:QUALifier / 1390  
:TRIGger:GLITch:RANGE / 1391  
:TRIGger:GLITch:SOURce / 1392  
:TRIGger:NFC Commands / 1393  
:TRIGger:NFC:AEvent / 1394  
:TRIGger:NFC:ATTime / 1395  
:TRIGger:NFC:RPOLarity / 1396  
:TRIGger:NFC:SOURce / 1397  
:TRIGger:NFC:STANDARD / 1398  
:TRIGger:NFC:TEVent / 1399  
:TRIGger:NFC:TIMEout / 1401  
:TRIGger:NFC:TIMEout:ENABLE / 1402  
:TRIGger:NFC:TIMEout:TIME / 1403  
:TRIGger:OR Commands / 1404  
:TRIGger:OR / 1405  
:TRIGger:PATTERn Commands / 1406  
:TRIGger:PATTERn / 1407  
:TRIGger:PATTERn:FORMAT / 1409  
:TRIGger:PATTERn:GREaterthan / 1410  
:TRIGger:PATTERn:LESSthan / 1411  
:TRIGger:PATTERn:QUALifier / 1412  
:TRIGger:PATTERn:RANGE / 1413

:TRIGger:RUNT Commands / 1414  
:TRIGger:RUNT:POLarity / 1415  
:TRIGger:RUNT:QUALifier / 1416  
:TRIGger:RUNT:SOURce / 1417  
:TRIGger:RUNT:TIME / 1418

:TRIGger:SHOLd Commands / 1419  
:TRIGger:SHOLd:SLOPe / 1420  
:TRIGger:SHOLd:SOURce:CLOCK / 1421  
:TRIGger:SHOLd:SOURce:DATA / 1422  
:TRIGger:SHOLd:TIME:HOLD / 1423  
:TRIGger:SHOLd:TIME:SETup / 1424

:TRIGger:TRANSition Commands / 1425  
:TRIGger:TRANSition:QUALifier / 1426  
:TRIGger:TRANSition:SLOPe / 1427  
:TRIGger:TRANSition:SOURce / 1428  
:TRIGger:TRANSition:TIME / 1429

:TRIGger:TV Commands / 1430  
:TRIGger:TV:LINE / 1431  
:TRIGger:TV:MODE / 1432  
:TRIGger:TV:POLarity / 1433  
:TRIGger:TV:SOURce / 1434  
:TRIGger:TV:STANDARD / 1435  
:TRIGger:TV:UDTV:ENUMber / 1436  
:TRIGger:TV:UDTV:HSYNC / 1437  
:TRIGger:TV:UDTV:HTIME / 1438  
:TRIGger:TV:UDTV:PGTHan / 1439

:TRIGger:USB Commands / 1440  
:TRIGger:USB:SOURce:DMINus / 1441  
:TRIGger:USB:SOURce:DPLus / 1442  
:TRIGger:USB:SPEed / 1443  
:TRIGger:USB:TRIGger / 1444

:TRIGger:ZONE Commands / 1445  
:TRIGger:ZONE:SOURce / 1446  
:TRIGger:ZONE:STATe / 1447  
:TRIGger:ZONE<n>:MODE / 1448  
:TRIGger:ZONE<n>:PLACement / 1449  
:TRIGger:ZONE<n>:VALIDity / 1450  
:TRIGger:ZONE<n>:STATe / 1451

## 38 :WAVeform Commands

:WAVeform:BYTeorder / 1461  
:WAVeform:COUNt / 1462  
:WAVeform:DATA / 1463  
:WAVeform:FORMat / 1465  
:WAVeform:POINts / 1466  
:WAVeform:POINts:MODE / 1468  
:WAVeform:PREamble / 1470  
:WAVeform:SEGmented:ALL / 1473  
:WAVeform:SEGmented:COUNt / 1474  
:WAVeform:SEGmented:TTAG / 1475  
:WAVeform:SEGmented:XLISt / 1476  
:WAVeform:SOURce / 1477  
:WAVeform:SOURce:SUBSource / 1481  
:WAVeform:TYPE / 1482  
:WAVeform:UNSIGNED / 1483  
:WAVeform:VIEW / 1484  
:WAVeform:XINCrement / 1485  
:WAVeform:XORigin / 1486  
:WAVeform:XREFerence / 1487  
:WAVeform:YINCrement / 1488  
:WAVeform:YORigin / 1489  
:WAVeform:YREFerence / 1490

## 39 :WGEN<w> Commands

:WGEN<w>:ARBitrary:BYTeorder / 1496  
:WGEN<w>:ARBitrary:DATA / 1497  
:WGEN<w>:ARBitrary:DATA:ATTRibute:POINts / 1500  
:WGEN<w>:ARBitrary:DATA:CLEar / 1501  
:WGEN<w>:ARBitrary:DATA:DAC / 1502  
:WGEN<w>:ARBitrary:INTerpolate / 1503  
:WGEN<w>:ARBitrary:STORe / 1504  
:WGEN<w>:FREQuency / 1505  
:WGEN<w>:FUNCTION / 1506  
:WGEN<w>:FUNCTION:PULSe:WIDTh / 1510  
:WGEN<w>:FUNCTION:RAMP:SYMMetry / 1511  
:WGEN<w>:FUNCTION:SQUare:DCYCle / 1512  
:WGEN<w>:MODulation:AM:DEPTh / 1513  
:WGEN<w>:MODulation:AM:FREQuency / 1514  
:WGEN<w>:MODulation:FM:DEViation / 1515  
:WGEN<w>:MODulation:FM:FREQuency / 1516

```
:WGEN<w>:MODulation:FSKey:FREQuency / 1517
:WGEN<w>:MODulation:FSKey:RATE / 1518
:WGEN<w>:MODulation:FUNCTION / 1519
:WGEN<w>:MODulation:FUNCTION:RAMP:SYMMetry / 1520
:WGEN<w>:MODulation:NOISE / 1521
:WGEN<w>:MODulation:STATe / 1522
:WGEN<w>:MODulation:TYPE / 1523
:WGEN<w>:OUTPut / 1525
:WGEN<w>:OUTPut:LOAD / 1526
:WGEN<w>:OUTPut:MODE / 1527
:WGEN<w>:OUTPut:POLarity / 1528
:WGEN<w>:OUTPut:SINGle / 1529
:WGEN<w>:PERiod / 1530
:WGEN<w>:RST / 1531
:WGEN<w>:VOLTage / 1532
:WGEN<w>:VOLTage:HIGH / 1533
:WGEN<w>:VOLTage:LOW / 1534
:WGEN<w>:VOLTage:OFFSet / 1535
```

## 40 :WMEMory<r> Commands

```
:WMEMory<r>:CLEar / 1539
:WMEMory<r>:DISPlay / 1540
:WMEMory<r>:LABel / 1541
:WMEMory<r>:SAVE / 1542
:WMEMory<r>:SKEW / 1543
:WMEMory<r>:YOFFset / 1544
:WMEMory<r>:YRANGE / 1545
:WMEMory<r>:YSCALE / 1546
```

## 41 Obsolete and Discontinued Commands

```
:CHANnel:ACTivity / 1554
:CHANnel:LABel / 1555
:CHANnel:THRehold / 1556
:CHANnel2:SKEW / 1557
:CHANnel<n>:INPut / 1558
:CHANnel<n>:PMODe / 1559
:DISPlay:CONNect / 1560
:DISPlay:ORDer / 1561
:ERASE / 1562
:EXTernal:PMODE / 1563
:FUNCTION:GOFT:OPERation / 1564
```

:FUNCTION:GOFT:SOURce1 / 1565  
:FUNCTION:GOFT:SOURce2 / 1566  
:FUNCTION:SOURce / 1567  
:FUNCTION:VIEW / 1568  
:HARDcopy:DESTination / 1569  
:HARDcopy:FILEname / 1570  
:HARDcopy:GRAYscale / 1571  
:HARDcopy:IGColors / 1572  
:HARDcopy:PDRiver / 1573  
:MEASure:LOWER / 1574  
:MEASure:SCRatch / 1575  
:MEASure:TDELta / 1576  
:MEASure:THResholds / 1577  
:MEASure:TMAX / 1578  
:MEASure:TMIN / 1579  
:MEASure:TSTArt / 1580  
:MEASure:TSTOP / 1581  
:MEASure:TVOLT / 1582  
:MEASure:UPPer / 1583  
:MEASure:VDELta / 1584  
:MEASure:VSTArt / 1585  
:MEASure:VSTOP / 1586  
:MEASure:VTIMe / 1587  
:MTEST:AMASK:{SAVE | STORe} / 1588  
:MTEST:AVERage / 1589  
:MTEST:AVERage:COUNt / 1590  
:MTEST:LOAD / 1591  
:MTEST:RUMode / 1592  
:MTEST:RUMode:SOFailure / 1593  
:MTEST:{STARt | STOP} / 1594  
:MTEST:TRIGger:SOURce / 1595  
:PRINT? / 1596  
:SAVE:IMAGe:AREA / 1598  
:SBUS<n>:LIN:SIGNAl:DEFinition / 1599  
:SBUS<n>:SPI:SOURce:DATA / 1600  
:SYSTem:MENU / 1601  
:TIMEbase:DELay / 1602  
:TRIGger:THReshold / 1603  
:TRIGger:TV:TMode / 1604

## 42 Error Messages

### 43 Status Reporting

- Status Reporting Data Structures / 1615
- Status Byte Register (STB) / 1618
- Service Request Enable Register (SRE) / 1620
- Trigger Event Register (TER) / 1621
- Output Queue / 1622
- Message Queue / 1623
- (Standard) Event Status Register (ESR) / 1624
- (Standard) Event Status Enable Register (ESE) / 1625
- Error Queue / 1626
- Operation Status Event Register (:OPERegister[:EVENT]) / 1627
- Operation Status Condition Register (:OPERegister:CONDition) / 1629
- Arm Event Register (AER) / 1630
- Overload Event Register (:OVLRegister) / 1631
- Hardware Event Event Register (:HWERegister[:EVENT]) / 1632
- Hardware Event Condition Register (:HWERegister:CONDition) / 1633
- Mask Test Event Event Register (:MTERegister[:EVENT]) / 1634
- Clearing Registers and Queues / 1635
- Status Reporting Decision Chart / 1636
- Example: Checking for Armed Status / 1637
- Example: Waiting for IO Operation Complete / 1642

## 44 Synchronizing Acquisitions

- Synchronization in the Programming Flow / 1646
- Set Up the Oscilloscope / 1646
- Acquire a Waveform / 1646
- Retrieve Results / 1646
- Blocking Synchronization / 1647
- Polling Synchronization With Timeout / 1648
- Synchronizing with a Single-Shot Device Under Test (DUT) / 1650
- Synchronization with an Averaging Acquisition / 1652

Example: Blocking and Polling Synchronization / 1654

## 45 More About Oscilloscope Commands

Command Classifications / 1666  
Core Commands / 1666  
Non-Core Commands / 1666  
Obsolete Commands / 1666  
Valid Command/Query Strings / 1667  
Program Message Syntax / 1667  
Duplicate Mnemonics / 1671  
Tree Traversal Rules and Multiple Commands / 1671  
Query Return Values / 1673

## 46 Programming Examples

VISA COM Examples / 1676  
VISA COM Example in Visual Basic / 1676  
VISA COM Example in C# / 1685  
VISA COM Example in Visual Basic .NET / 1694  
VISA COM Example in Python 3 / 1702  
VISA Examples / 1709  
VISA Example in C / 1709  
VISA Example in Visual Basic / 1718  
VISA Example in C# / 1728  
VISA Example in Visual Basic .NET / 1739  
VISA Example in Python 3 / 1749  
VISA.NET Examples / 1756  
VISA.NET Example in C# / 1756  
VISA.NET Example in Visual Basic .NET / 1762  
SICL Examples / 1769  
SICL Example in C / 1769  
SICL Example in Visual Basic / 1778  
SCPI.NET Examples / 1789

## Index



# 1 What's New

- What's New in Version 7.35 / 42
- What's New in Version 7.30 / 44
- What's New in Version 7.20 / 46
- What's New in Version 7.10 / 48
- What's New in Version 4.08 / 51
- What's New in Version 4.07 / 54
- What's New in Version 4.06 / 56
- What's New in Version 4.05 / 57
- Version 4.00 at Introduction / 59
- Command Differences From 4000 X-Series Oscilloscopes / 60

## What's New in Version 7.35

New features in version 7.35 of the InfiniiVision 3000T X-Series oscilloscope software are:

- New commands for clearing persistence data from the display and querying the run state.
- New commands for measurement limit test.
- New commands for external scaling on analog input channels.
- New commands for the band-pass filter and Chart Serial Signal math functions.
- New command for setting the INTegrate math function initial condition.
- New commands for the N275xA probe's InfiniiMode and Single button controls.
- USB 2.0 serial decode and triggering option.

More detailed descriptions of the new and changed commands appear below.

### New Commands

Command	Description
:CHANnel<n>:PROBe:BTN (see <a href="#">page 353</a> )	For N275xA InfiniiMode probes, this command sets the probe's quick-action button mode.
:CHANnel<n>:PROBe:CALibration (see <a href="#">page 354</a> )	Begins the probe degauss operation. For the N7026A and N2893A probes only.
:CHANnel<n>:PROBe:EXTernal (see <a href="#">page 355</a> )	Enables or disables External Scaling on the analog input channel.
:CHANnel<n>:PROBe:EXTernal:GAIN (see <a href="#">page 356</a> )	Sets the gain associated with External Scaling.
:CHANnel<n>:PROBe:EXTernal:UNITS (see <a href="#">page 357</a> )	Sets the units to associated with the analog input channel.
:CHANnel<n>:PROBe:MODE (see <a href="#">page 361</a> )	For N275xA InfiniiMode probes, this command sets the probe's mode.
:COMpliance Commands (see <a href="#">page 371</a> )	Commands that control the license-enabled USB 2.0 signal quality analysis feature.
:DISPlay:PERsistence:CLEar (see <a href="#">page 433</a> )	Erases all persistence data from the display, leaving the data from the last acquisition.
:FUNCTION<m>:FREQuency:BA NDpass:CENTER (see <a href="#">page 514</a> )	Sets the center frequency of the band-pass filter.
:FUNCTION<m>:FREQuency:BA NDpass:WIDth (see <a href="#">page 515</a> )	Sets the frequency width of the band-pass filter.
:FUNCTION<m>:INTegrate:ICOndition (see <a href="#">page 518</a> )	Sets the Initial Condition of the Integrate math function waveform.

Command	Description
:FUNCTION<m>:SERChart:SOURCE (see <a href="#">page 531</a> )	Sets the serial bus source for the Chart Serial Signal math function.
:FUNCTION<m>:SERChart:TIME:MODE (see <a href="#">page 532</a> )	Sets the time mode for the Chart Serial Signal math function.
:FUNCTION<m>:SERChart:TIME:RANGE (see <a href="#">page 534</a> )	When the ROLL serial chart time mode is selected, this command sets the full-scale range value for the Chart Serial Signal math function.
:FUNCTION<m>:SERChart:TIME:OFFSET (see <a href="#">page 535</a> )	When the ROLL serial chart time mode is selected, this command sets the time offset for the Chart Serial Signal math function.
:LTEST Commands (see <a href="#">page 565</a> )	Commands for using the Measurement Limit Test feature.
:RSTate? (see <a href="#">page 291</a> )	Returns the run state.
:SAVE:COMPliance:USB[:STARt] (see <a href="#">page 878</a> )	Lets you save USB 2.0 signal quality test results.
:SBUS<n>:USB Commands (see <a href="#">page 1164</a> )	Commands for using the USB 2.0 triggering and serial decode feature.
:SEARch:SERIAL:USB Commands (see <a href="#">page 1293</a> )	Commands for searching USB 2.0 serial decode events.

### Changed Commands

Command	Differences
:DEMO:FUNCTION (see <a href="#">page 396</a> )	The USB function is now available.
:FUNCTION<m>:OPERation (see <a href="#">page 523</a> )	The BAND and SERChart (Chart Serial Signal) operations have been added.
:MEASure:DELay:DEFine (see <a href="#">page 634</a> )	Adds the ability to specify LOWER or UPPER edge thresholds (in addition to MIDDLE) for both source 1 and source 2.
:SBUS<n>:MODE (see <a href="#">page 909</a> )	The USB mode is now available with the USB Test Software license.

## What's New in Version 7.30

New features in version 7.30 of the InfiniiVision 3000T X-Series oscilloscope software are:

- New Slew Rate and Y at X measurements along with improvements to the Time at Edge measurement and support for digital channels in the Delay, Positive Pulse Count, and Negative Pulse Count measurements.
- The new Digitizer (acquisition) mode lets you choose the acquisition sample rate and memory depth instead of having them be determined automatically based on the horizontal time per division setting.
- Added support for getting waveform data for all segments at once (when in the segmented acquisition mode).
- Added support for licenses that allow support subscriptions.

More detailed descriptions of the new and changed commands appear below.

### New Commands

Command	Description
:ACQuire:DIGItizer (see page 306)	Turns Digitizer mode on or off.
:ACQuire:POINTs[:ANALog]:AUT 0 (see page 309)	Enables or disables Automatic determination of the analog channel memory depth.
:ACQuire:SRATE[:ANALog]:AUT 0 (see page 316)	Enables or disables Automatic determination of the analog channel sampling rate.
:MEASure:SLEWrate (see page 666)	Installs a slew rate measurement on screen or returns the measured value.
:MEASure:YATX (see page 692)	Installs a Y at X (vertical value at horizontal location) measurement on screen or returns the measured value.
:SYSTem:DIDentifier? (see page 1315)	Returns the oscilloscope's Host ID string.
:WAVEform:SEGmented:ALL (see page 1473)	Enables or disables the "waveform data for all segments" setting.
:WAVEform:SEGmented:XLISt? (see page 1476)	Returns the X (time) information for all segments at once.

### Changed Commands

Command	Differences
:ACQuire:POINTs[:ANALog] (see page 308)	This command can now set a memory depth and turn on Digitizer mode. Previously, this was a query only.
:ACQuire:SRATE[:ANALog] (see page 315)	This command can now set a sample rate and turn on Digitizer mode. Previously, this was a query only.

Command	Differences
:MEASure:DELay (see page 632)	You are now able to perform delay measurements on digital input channels.
:MEASure:NPULses (see page 650)	You are now able to perform delay measurements on digital input channels.
:MEASure:PPULses (see page 657)	You are now able to perform delay measurements on digital input channels.
:MEASure:TEDGE (see page 675)	There is now a command to install the measurement on the oscilloscope's display and there is a new optional <slope> parameter.
*OPT? (see page 241)	New license information is possible in the returned string.
:WAVeform:VIEW (see page 1484)	The ALL parameter is available when Digitizer mode is enabled to specify a waveform data view view that includes all captured data, which may extend beyond the edges of the oscilloscope's main waveform display area depending on the settings for sample rate, memory depth, and horizontal time/div.

### Obsolete Commands

Obsolete Command	Current Command Equivalent	Behavior Differences
:MEASure:VTIMe (see page 1587)	:MEASure:YATX (see page 692)	With :MEASure:YATX, there is a command for installing the measurement on the oscilloscope's display. :MEASure:VTIMe had no command, only a query.

## What's New in Version 7.20

New features in version 7.20 of the InfiniiVision 3000T X-Series oscilloscope software are:

- USB PD (Power Delivery) serial decode and triggering option.

More detailed descriptions of the new and changed commands appear below.

### New Commands

Command	Description
:DISPlay:MESSAge:CLEar (see page 431)	Removes all user messages that are currently on screen.
:FRANalysis:FREQuency:SINGle (see page 474)	Sets the single frequency value.
:FRANalysis:TRACe (see page 481)	Specifies whether to include gain, phase, both gain and phase, or neither in the frequency response analysis results.
:POWer:CLResponse:DATA:GM ARgin? (see page 768)	Returns the gain margin in dB.
:POWer:CLResponse:DATA:GM ARgin:FREQuency? (see page 769)	Returns the 0° phase crossover frequency in Hz.
:POWer:CLResponse:DATA:PM ARgin? (see page 770)	Returns the phase margin in degrees.
:POWer:CLResponse:DATA:PM ARgin:FREQuency? (see page 771)	Returns the 0 dB gain crossover frequency in Hz.
:POWer:CLResponse:FREQuency:SINGle (see page 773)	Sets the single frequency value.
:POWer:CLResponse:TRACe (see page 779)	Specifies whether to include gain, phase, both gain and phase, or neither in the control loop response analysis results.
:POWer:PSRR:FREQuency:SIN Gle (see page 818)	Sets the single frequency value.
:POWer:PSRR:TRACe (see page 822)	Specifies whether to include gain (PSRR) data in the power supply rejection ratio analysis results.
:SBUS<n>:A429:BAUDrate (see page 914)	Specifies the user-defined baud rate.
:SBUS<n>:SPI:DELay (see page 1130)	Specifies the number of bits to ignore (delay) before decoding the MISO stream.
:SBUS<n>:USBPd Commands (see page 1189)	Commands for using the USB PD triggering and serial decode feature.

**Changed Commands**

Command	Differences
:DEMO:FUNCTION (see <a href="#">page 396</a> )	The USBPd function is now available.
:RECall:WMEMory<r>:[STARt] (see <a href="#">page 871</a> )	There is now a <data> option for recalling waveform data from the controller PC.
:SBUS<n>:A429:SPEEd (see <a href="#">page 921</a> )	The USER option is now available to select a user-defined baud rate.
:SBUS<n>:MANChester:BAUDRate (see <a href="#">page 1054</a> )	The minimum baud rate is changed from "2000" to "500".
:SBUS<n>:MODE (see <a href="#">page 909</a> )	The USBPd mode is now available with the USB PD serial decode and triggering license.
:SBUS<n>:SENT:PPULse (see <a href="#">page 1100</a> )	The pause mode now, in addition supporting pause pulses off and on, supports SENT SPC (Short PWM Code) where message events are triggered by the master.

## What's New in Version 7.10

New features in version 7.10 of the InfiniiVision 3000T X-Series oscilloscope software are:

- Random trigger holdoff mode.
- FFT detectors are added.
- FFT measurements are added: Adjacent Channel Power Ratio (ACPR), Channel Power, Occupied Bandwidth, and Total Harmonic Distortion.
- Frequency Response Analysis feature is added.

More detailed descriptions of the new and changed commands appear below.

### New Commands

Command	Description
:DISPlay:GRATicule:ALABels (see <a href="#">page 424</a> )	Turns graticule (grid) axis labels on or off.
:DISPlay:GRATicule:INTensity (see <a href="#">page 425</a> )	Sets the graticule (grid) intensity.
:DISPlay:GRATicule:TYPE (see <a href="#">page 426</a> )	Sets the graticule (grid) type.
:FRANalysis Commands (see <a href="#">page 469</a> )	Commands for using the Frequency Response Analysis feature.
:FUNCtion<m>[:FFT]:BSIZE? (see <a href="#">page 500</a> )	Returns the Bin Size setting for the FFT.
:FUNCtion<m>[:FFT]:DETection :POINTs (see <a href="#">page 502</a> )	Specifies the maximum number of points that the FFT detector should decimate to.
:FUNCtion<m>[:FFT]:DETection :TYPE (see <a href="#">page 503</a> )	Sets the FFT detector decimation type.
:FUNCtion<m>[:FFT]:RBWidth? (see <a href="#">page 508</a> )	Returns the Resolution Bandwidth setting for the FFT.
:FUNCtion<m>[:FFT]:READout<n> (see <a href="#">page 509</a> )	For the FFT, selects from these types of readouts: Resolution Bandwidth, Bin Size, or Sample Rate.
:FUNCtion<m>[:FFT]:SRATE? (see <a href="#">page 511</a> )	Returns the Sample Rate setting for the FFT.
:HCOPY:SDUMp:DATA? (see <a href="#">page 559</a> )	Reads screen image data.
:HCOPY:SDUMp:FORMAT (see <a href="#">page 560</a> )	Specifies the format for screen image data: 24-bit PNG, 24-bit BMP, or 8-bit BMP8bit.
:MEASure:DELay:DEFine (see <a href="#">page 634</a> )	Defines slope directions and edge numbers for the :MEASure:DELay command.

Command	Description
:MEASure:FFT:ACPR (see page 643)	Installs an FFT analysis Adjacent Channel Power Ratio (ACPR) measurement on screen or returns the measured value.
:MEASure:FFT:CPOWer (see page 644)	Installs an FFT analysis Channel Power measurement on screen or returns the measured value.
:MEASure:FFT:OBW (see page 645)	Installs an FFT analysis Occupied Bandwidth measurement on screen or returns the measured value.
:MEASure:FFT:THD (see page 646)	Installs an FFT analysis Total Harmonic Distortion measurement on screen or returns the measured value.
:SBUS<n>:MANChester Commands (see page 1051)	Commands for using the Manchester triggering and serial decode feature.
:SBUS<n>:NRZ Commands (see page 1070)	Commands for using the NRZ triggering and serial decode feature.
:TRIGger:HOLDoff:MAXimum (see page 1356)	When the random trigger holdoff mode is enabled, this command specifies the maximum trigger holdoff time.
:TRIGger:HOLDoff:MINimum (see page 1357)	When the random trigger holdoff mode is enabled, this command specifies the minimum trigger holdoff time.
:TRIGger:HOLDoff:RANDOM (see page 1358)	Enables or disables the random trigger holdoff mode.
:TRIGger:NFC:RPOLarity (see page 1396)	Enables or disables triggering on signals with "reverse" polarity.

### Changed Commands

Command	Differences
:CALibrate:OUTPut (see page 333)	The TSOurce option can now be selected to output the raw trigger signal from the oscilloscope's trigger circuit to Trig Out.
:CHANnel<n>:PROBe:HEAD:TYPE (see page 358)	The DSMA and DSMA6 probe head types can now be selected.
:DEMO:FUNCTION (see page 396)	The CXPI, NFC, and MANChester functions are now available with the educator's kit.
:FFT:WINDOW (see page 467)	The BARTlett window is now available.
:FUNCtion<m>[:FFT]:WINDOW (see page 513)	The BARTlett window is now available.
:MEASure:DELay (see page 632)	You can now specify an <edge_select_mode> with the command and query.
:OPERegister:CONDITION (see page 280)	Bit 4 in the Operation Status Condition Register now shows whether the remote user interface is enabled.

Command	Differences
:OPERegister[:EVENT] (see <a href="#">page 283</a> )	Bit 4 in the Operation Status Event Register now indicates when the remote user interface has gone from a disabled state to an enabled state.
:SBUS<n>:MODE (see <a href="#">page 909</a> )	The MANChester and NRZ modes are now available with the Manchester/NRZ serial decode and triggering license.

## Discontinued Commands

Discontinued Command	Current Command Equivalent	Comments
:FUNCTION<m>:TRENd:MEASurement	:FUNCTION<m>:TRENd:NMEasurement (see <a href="#">page 540</a> )	The current command specifies the number of an installed measurement instead of a measurement name.

## What's New in Version 4.08

New features in version 4.08 of the InfiniiVision 3000T X-Series oscilloscope software are:

- CXPI (Clock Extension Peripheral Interface) serial decode and triggering option.
- Power measurements application updates.
- Added FFTPhase math function.
- Custom timebase reference—as a percent, from the left edge to the right edge of the graticule.
- Added remote commands for specifying N2820A high-sensitivity current probe zoom-in channel and N2825A user-defined R-sense head resistor value.

More detailed descriptions of the new and changed commands appear below.

New Commands

Command	Description
:CHANnel<n>:PROBe:RSENse (see <a href="#">page 362</a> )	When the N2820A high-sensitivity current probe is used with the N2825A user-defined R-sense head, this command specifies the value of the R-sense resistor that is being probed in the device under test (DUT).
:CHANnel<n>:PROBe:ZOOM (see <a href="#">page 365</a> )	When the N2820A high-sensitivity current probe is used with both the Primary and Secondary cables, this command specifies whether this cable will have the Zoom In waveform (ON) or the Zoom Out waveform (OFF).
:FUNCTION<m>[:FFT]:PHASE:REFERENCE (see <a href="#">page 507</a> )	Sets the reference point for calculating the FFT Phase function to either the trigger point or beginning of the displayed waveform.
:POWER:CLResponse? (see <a href="#">page 765</a> )	Returns the Control Loop Response (Bode) power analysis settings.
:POWER:CLResponse:DATA? (see <a href="#">page 767</a> )	Returns data from the Control Loop Response (Bode) power analysis.
:POWER:CLResponse:FREQuency:MODE (see <a href="#">page 772</a> )	Specifies whether the analysis should be performed by sweeping through a range of frequencies (SWEep) or at a single frequency (SINGle).
:POWER:CLResponse:PPDecade (see <a href="#">page 776</a> )	Selects the number of frequency test points per decade (in the log scale).
:POWER:CLResponse:SOURce:INPut (see <a href="#">page 777</a> )	Selects the oscilloscope channel that is probing the power supply input.
:POWER:CLResponse:SOURce:OUTPut (see <a href="#">page 778</a> )	Selects the oscilloscope channel that is probing the power supply output.
:POWER:CLResponse:WGEN:LOAD (see <a href="#">page 780</a> )	Sets the waveform generator expected output load impedance.

Command	Description
:POWer:CLResponse:WGEN:VO LTage (see <a href="#">page 781</a> )	Sets the waveform generator output amplitude(s).
:POWer:CLResponse:WGEN:VO LTage:PROFile (see <a href="#">page 782</a> )	Enables or disables the ability to set initial waveform generator ramp amplitudes for each frequency range.
:POWer:ITYPE (see <a href="#">page 802</a> )	Specifies the type of input power that is being converted to the output.
:POWer:ONOFF:THresholds (see <a href="#">page 810</a> )	Specifies the input and output thresholds used in the Turn On/Turn Off analysis.
:POWer:PSRR? (see <a href="#">page 812</a> )	Returns the Power Supply Rejection Ratio (PSRR) power analysis settings.
:POWer:PSRR:DATA? (see <a href="#">page 814</a> )	Returns data from the Power Supply Rejection Ratio (PSRR) power analysis.
:POWer:PSRR:FREQuency:MO DE (see <a href="#">page 817</a> )	Specifies whether the analysis should be performed by sweeping through a range of frequencies (SWEep) or at a single frequency (SINGle).
:POWer:PSRR:PPDecade (see <a href="#">page 819</a> )	Selects the number of frequency test points per decade (in the log scale).
:POWer:PSRR:SOURce:INPut (see <a href="#">page 820</a> )	Selects the oscilloscope channel that is probing the power supply input.
:POWer:PSRR:SOURce:OUTPut (see <a href="#">page 821</a> )	Selects the oscilloscope channel that is probing the power supply output.
:POWer:PSRR:WGEN:LOAD (see <a href="#">page 823</a> )	Sets the waveform generator expected output load impedance.
:POWer:PSRR:WGEN:VOLTage (see <a href="#">page 824</a> )	Sets the waveform generator output amplitude(s).
:POWer:PSRR:WGEN:VOLTage: PROFile (see <a href="#">page 825</a> )	Enables or disables the ability to set initial waveform generator ramp amplitudes for each frequency range.
:SBUS<n>:CXPI Commands (see <a href="#">page 959</a> )	Commands for using the CXPI triggering and serial decode feature.
:TIMEbase:REFerence:LOCation (see <a href="#">page 1343</a> )	When the :TIMEbase:REFerence is set to CUSTom, this command lets you place the time reference location at a percent of the graticule width (where 0.0 is the left edge and 1.0 is the right edge).

**Changed Commands**

Command	Differences
:CHANnel<n>:PROBe (see page 352)	The probe attenuation factor can now be set from 0.001:1 to 10000:1.
:FUNCtion<m>[:FFT]:VTYPe (see page 512)	With the FFTPhase operation, you can select vertical units in DEGRees or RADians.
:FUNCtion<m>:OPERation (see page 523)	The FFTPhase operation is added.
:FUNCtion<m>:SOURce1 (see page 537)	Reference waveforms can now be specified as source 1.
:FUNCtion<m>:SOURce2 (see page 539)	Reference waveforms can now be specified as source 2.
:POWER:HARMonics:LINE (see page 791)	The AUTO frequency option is added. This option automatically determines the frequency of the Current waveform.
:SBUS<n>:LIN:STANDARD (see page 1032)	The LIN13NLC option is added for selecting LIN 1.3 (no length control).
:SBUS<n>:MODE (see page 909)	The CXPI mode is now available with the CXPI serial decode and triggering license.
:TIMEbase:REFerence (see page 1342)	The CUSTom option is added for placing the time reference location at a percent of the graticule width.

**Discontinued Commands**

Discontinued Command	Current Command Equivalent	Comments
:POWER:CLResponse:VIEW	none	Because the plot now appears in its own dialog box and contains both gain and phase plots, there is no longer a need to select one or the other.
:POWER:CLResponse:YMAXimum	none	Specifying the plot's initial vertical scale maximum value is no longer necessary because the plot now appears in its own dialog box and is autoscaled.
:POWER:CLResponse:YMINimum	none	Specifying the plot's initial vertical scale minimum value is no longer necessary because the plot now appears in its own dialog box and is autoscaled.
:POWER:PSRR:RMAXimum	none	Specifying the plot's initial vertical scale value is no longer necessary because the plot now appears in its own dialog box and is autoscaled.

## What's New in Version 4.07

New features in version 4.07 of the InfiniiVision 3000T X-Series oscilloscope software are:

- Remote commands for remote command logging.
- Near Field Communication (NFC) trigger mode.

More detailed descriptions of the new and changed commands appear below.

### New Commands

Command	Description
:FFT:GATE (see <a href="#">page 459</a> )	Specifies whether the FFT is performed on the Main time base window or the Zoom window when the zoomed time base is displayed.
:FUNCTION<m>[:FFT]:GATE (see <a href="#">page 506</a> )	Specifies whether the FFT is performed on the Main time base window or the Zoom window when the zoomed time base is displayed.
:MARKer:X1:DISPlay (see <a href="#">page 584</a> )	Specifies whether the X1 cursor is displayed.
:MARKer:X2:DISPlay (see <a href="#">page 587</a> )	Specifies whether the X2 cursor is displayed.
:MARKer:Y1:DISPlay (see <a href="#">page 593</a> )	Specifies whether the Y1 cursor is displayed.
:MARKer:Y2:DISPlay (see <a href="#">page 595</a> )	Specifies whether the Y2 cursor is displayed.
:SYSTem:RLOGger (see <a href="#">page 1325</a> )	Enables or disables remote command logging, optionally specifying the log file name and write mode.
:SYSTem:RLOGger:DESTination (see <a href="#">page 1326</a> )	Specifies whether remote commands are logged to a text file (on a connected USB storage device), logged to the screen, or both.
:SYSTem:RLOGger:DISPLAY (see <a href="#">page 1327</a> )	Enables or disables the screen display of logged remote commands and their return values (if applicable).
:SYSTem:RLOGger:FNAME (see <a href="#">page 1328</a> )	Specifies the remote command log file name.
:SYSTem:RLOGger:STATE (see <a href="#">page 1329</a> )	Enables or disables remote command logging.
:SYSTem:RLOGger:TRANsparenT (see <a href="#">page 1330</a> )	Specifies whether the screen display background for remote command logging is transparent or solid.
:SYSTem:RLOGger:WMODE (see <a href="#">page 1331</a> )	Specifies the remote command logging write mode (either CREate or APPend).
:TRIGger:NFC Commands (see <a href="#">page 1393</a> )	Commands for setting up the Near Field Communication (NFC) trigger mode.

**Changed Commands**

Command	Differences
:CALibrate:OUTPut (see page 333)	The NFC option becomes available in the Near Field Communication (NFC) trigger mode when the ATRigger (Arm & Trigger) trigger event is selected.
:FUNCTION<m>:OPERation (see page 523)	The MAXimum, MINimum, and PEAK operations are added.
:TRIGger:MODE (see page 1362)	The NFC option is now available for setting the Near Field Communication (NFC) trigger mode. See " <b>:TRIGger:NFC Commands</b> " on page 1393.

## What's New in Version 4.06

New features in version 4.06 of the InfiniiVision 3000T X-Series oscilloscope software are:

- The Control Loop Response (Bode) power analysis now lets you select a phase plot as well as a gain plot.
- The ISO standard for CAN FD is now supported.
- Up to 10 annotations are supported.

More detailed descriptions of the new and changed commands appear below.

### New Commands

Command	Description
:POWER:CLResponse:VIEW	When the Control Loop Response (Bode) power analysis is selected, this command selects whether to display a gain or phase plot.
:SBUS<n>:CAN:FDSTandard (see <a href="#">page 940</a> )	Lets you pick the standard that will be used when decoding or triggering on FD frames, ISO, or non-ISO.

### Changed Commands

Command	Differences
:DISPLAY:ANNOTATION<n> (see <a href="#">page 414</a> )	You can now define up to 10 annotations.
:DISPLAY:ANNOTATION<n>:BACKGROUND (see <a href="#">page 415</a> )	
:DISPLAY:ANNOTATION<n>:COLOR (see <a href="#">page 416</a> )	
:DISPLAY:ANNOTATION<n>:TEXT (see <a href="#">page 417</a> )	
:DISPLAY:ANNOTATION<n>:X1POSITION (see <a href="#">page 418</a> )	
:DISPLAY:ANNOTATION<n>:Y1POSITION (see <a href="#">page 419</a> )	
:SBUS<n>:CAN:TRIGGER (see <a href="#">page 946</a> )	Has some description changes related to the CAN FD ISO support changes.

## What's New in Version 4.05

New features in version 4.05 of the InfiniiVision 3000T X-Series oscilloscope software are:

- Being able to load LIN symbolic data from an LDF (\*.ldf) file into the oscilloscope, display it in the decode, and use it to set up triggers and protocol decode searches.

More detailed descriptions of the new and changed commands appear below.

### New Commands

Command	Description
:DISPlay:BACKlight (see <a href="#">page 420</a> )	Turns the display's backlight off or on.
:POWER:CLResponse:APPLy (see <a href="#">page 766</a> )	Performs the Control Loop Response (Bode) power analysis.
:POWER:CLResponse:FREQuency:STARt (see <a href="#">page 774</a> )	Sets the sweep start frequency value.
:POWER:CLResponse:FREQuency:STOP (see <a href="#">page 775</a> )	Sets the sweep stop frequency value.
:POWER:CLResponse:YMAXimum	Specifies the Bode plot's initial vertical scale maximum value.
:POWER:CLResponse:YMINimum	Specifies the Bode plot's initial vertical scale minimum value.
:POWER:HARMonics:RPOWER (see <a href="#">page 793</a> )	When Class D is selected as the current harmonics analysis standard, this command specifies whether the Real Power value used for the current-per-watt measurement is measured by the oscilloscope or is defined by the user.
:POWER:HARMonics:RPOWER:USER (see <a href="#">page 794</a> )	When Class D is selected as the current harmonics analysis standard and you have chosen to use a user-defined Real Power value, this command specifies the Real Power value used in the current-per-watt measurement.
:RECall:LDF[:STARt] (see <a href="#">page 867</a> )	Loads a LIN description file (LDF) into the oscilloscope.
:SBUS<n>:LIN:DISPlay (see <a href="#">page 1027</a> )	Specifies whether symbolic values (from a loaded LDF file) or hexadecimal values are displayed in the decode waveform and the Lister window
:SBUS<n>:LIN:TRIGger:SYMBOLic:FRAME (see <a href="#">page 1041</a> )	Specifies the frame to trigger on when LIN symbolic data has been loaded (recalled) into the oscilloscope and the LIN trigger mode is set to FRAME or FSIGNAL.
:SBUS<n>:LIN:TRIGger:SYMBOLic:SIGNal (see <a href="#">page 1042</a> )	Specifies signal to trigger on when LIN symbolic data has been loaded (recalled) into the oscilloscope and the LIN trigger mode is set to FSIGNAL.

Command	Description
:SBUS<n>:LIN:TRIGger:SYMBOLic:VALue (see <a href="#">page 1043</a> )	Specifies signal value to trigger on when LIN symbolic data has been loaded (recalled) into the oscilloscope and the LIN trigger mode is set to FSIGnal.
:SEARch:SERial:LIN:SYMBOLic:FRAMe (see <a href="#">page 1273</a> )	Specifies the message to search for when LIN symbolic data has been loaded (recalled) into the oscilloscope and the LIN serial search mode is set to FRAMe or FSIGnal.
:SEARch:SERial:LIN:SYMBOLic:SIGNal (see <a href="#">page 1274</a> )	Specifies signal to search for when LIN symbolic data has been loaded (recalled) into the oscilloscope and the LIN serial search mode is set to FSIGnal.
:SEARch:SERial:LIN:SYMBOLic:VALue (see <a href="#">page 1275</a> )	Specifies signal value to search for when LIN symbolic data has been loaded (recalled) into the oscilloscope and the LIN serial search mode is set to FSIGnal.
:TRIGger:USB Commands (see <a href="#">page 1440</a> )	Resurrected from the 3000 X-Series oscilloscopes, these commands let you trigger on a Start of Packet (SOP), End of Packet (EOP), Reset Complete, Enter Suspend, or Exit Suspend signal on the differential USB data lines. USB Low Speed and Full Speed are supported by this trigger.
:WGEN<w>:OUTPut:MODE (see <a href="#">page 1527</a> )	Specifies whether the defined waveform is output continuously or as a single cycle (single-shot).
:WGEN<w>:OUTPut:SINGle (see <a href="#">page 1529</a> )	When the single-shot output mode is selected, this command causes a single cycle of the defined waveform to be output.

#### Changed Commands

Command	Differences
:SBUS<n>:LIN:TRIGger (see <a href="#">page 1034</a> )	You can now trigger on symbolic frames (with parameter FRAMe) or frames and signal values (with parameter FSIGnal).
:SEARch:SERial:LIN:MODE (see <a href="#">page 1269</a> )	You can now search for symbolic messages (with parameter FRAMe) or frames and signal values (with parameter FSIGnal).
:TRIGger:MODE (see <a href="#">page 1362</a> )	The parameter USB is now allowed to permit USB triggering.

## Version 4.00 at Introduction

The Keysight InfiniiVision 3000T X-Series oscilloscopes were introduced with version 4.00 of oscilloscope operating software.

The command set is most closely related to the InfiniiVision 4000 X-Series oscilloscopes (and the 3000 X-Series, 7000A/B Series, 6000 Series, and 54620/54640 Series oscilloscopes before them). For more information, see ["Command Differences From 4000 X-Series Oscilloscopes"](#) on page 60.

## Command Differences From 4000 X-Series Oscilloscopes

The Keysight InfiniiVision 3000T X-Series oscilloscopes command set is most closely related to the InfiniiVision 4000 X-Series oscilloscopes (and the 3000 X-Series, 7000A/B Series, 6000 Series, and 54620/54640 Series oscilloscopes before them).

The main differences between the version 4.00 programming command set for the InfiniiVision 3000T X-Series oscilloscopes and the 3.20 programming command set for the InfiniiVision 4000 X-Series oscilloscopes are related to:

- Dedicated FFT function (and selectable math functions – 4000 X-Series oscilloscopes have four selectable math functions).
- SENT serial decode and triggering option.
- Updates to support CAN FD serial decode and triggering.
- Counter feature.
- New built-in demo signals (with the education kit).
- One waveform generator output (4000 X-Series oscilloscopes have two waveform generator outputs).
- No 10 MHz REF connector.
- No support for USB 2.0 serial decode, triggering, or signal quality analysis.

More detailed descriptions of the new, changed, obsolete, and discontinued commands appear below.

### New Commands

Command	Description
:CHANnel<n>:PROBe:MMODel (see <a href="#">page 360</a> )	Sets the model number of the supported Tektronix probe.
:COUNter Commands (see <a href="#">page 383</a> )	Commands for controlling the counter feature.
:DISPlay:ANNotation<n>:X1Pos ition (see <a href="#">page 418</a> )	Sets the horizontal position of one of the four annotations.
:DISPlay:ANNotation<n>:Y1Pos ition (see <a href="#">page 419</a> )	Sets the horizontal position of one of the four annotations.
:FFT Commands (see <a href="#">page 449</a> )	Commands for using the FFT function feature.
:FUNCTION<m>:CLEar (see <a href="#">page 498</a> )	When the :FUNCTION<m>:OPERation is AVERage, MAXHold, or MINHold, this command clears the number of evaluated waveforms.

Command	Description
:FUNCTION<m>[:FFT]:FREQuency:STARt (see <a href="#">page 504</a> )	Lets you set the displayed frequency range using start and stop frequency values.
:FUNCTION<m>[:FFT]:FREQuency:STOP (see <a href="#">page 505</a> )	
:FUNCTION<m>:SMOooth:POINTs (see <a href="#">page 536</a> )	Sets the number of smoothing points for the new SMOOTH :FUNCTION<m>:OPERation.
:MEASure:BRATe (see <a href="#">page 624</a> )	Installs a bit rate measurement on screen or returns the measured value.
:MEASure:RDSon (see <a href="#">page 711</a> )	Installs an RDS(on) power measurement on screen or returns the measured value.
:MEASure:VCESat (see <a href="#">page 716</a> )	Installs a VCE(sat) power measurement on screen or returns the measured value.
:POWER:EFFiciency:TYPE (see <a href="#">page 785</a> )	Specifies the type of power that is being converted from the input to the output.
:SAVE:RESults:[STARt] (see <a href="#">page 890</a> )	Saves analysis results to a comma-separated values (*.csv) file on a USB storage device.
:SAVE:RESults:FORMAT:CURSo r (see <a href="#">page 891</a> )	Specifies whether cursor values will be included when analysis results are saved.
:SAVE:RESults:FORMAT:MASK (see <a href="#">page 892</a> )	Specifies whether mask statistics will be included when analysis results are saved.
:SAVE:RESults:FORMAT:MEASu rement (see <a href="#">page 893</a> )	Specifies whether measurement results will be included when analysis results are saved.
:SAVE:RESults:FORMAT:SEARc h (see <a href="#">page 894</a> )	Specifies whether found search event times will be included when analysis results are saved.
:SAVE:RESults:FORMAT:SEGMe nted (see <a href="#">page 895</a> )	Specifies whether segmented memory acquisition times will be included when analysis results are saved.
:SEARch:PEAK Commands (see <a href="#">page 1217</a> )	Commands to set up searching for FFT peaks.
:SBUS<n>:CAN:COUNT:SPEC (see <a href="#">page 935</a> )	Returns the count for the number of Spec errors (Ack + Form + Stuff + CRC errors).
:SBUS<n>:CAN:FDSPoint (see <a href="#">page 939</a> )	Sets the CAN FD sample point.
:SBUS<n>:CAN:SIGNal:FDBaud rate (see <a href="#">page 944</a> )	Sets the CAN FD baud rate.
:SBUS<n>:CAN:TRIGger:IDFilte r (see <a href="#">page 949</a> )	Specifies, in certain error and bit trigger modes, whether triggers are filtered by CAN IDs.
:SBUS<n>:CAN:TRIGger:PATTer n:DATA:DLC (see <a href="#">page 951</a> )	Specifies the DLC value to be used in the CAN FD data trigger mode.

Command	Description
:SBUS<n>:CAN:TRIGger:PATTer n:DATA:START (see <a href="#">page 953</a> )	Specifies the starting byte position for CAN FD data triggers.
:SBUS<n>:SENT Commands (see <a href="#">page 1089</a> )	Commands for using the SENT triggering and serial decode feature.
:SEARch:SERial:SENT Commands (see <a href="#">page 1280</a> )	Commands for searching SENT serial decode events.
:SYSTem:PERSonA[:MANufactu rer] (see <a href="#">page 1319</a> )	Lets you change the manufacturer string portion of the identification string returned by the *IDN? query.
:SYSTem:PERSonA[:MANufactu rer]:DEFault (see <a href="#">page 1320</a> )	Sets manufacturer string to "KEYSIGHT TECHNOLOGIES".

### Changed Commands

Command	Differences From InfiniiVision 4000 X-Series Oscilloscopes
:ACQuire:MODE (see <a href="#">page 307</a> )	The ETIMe option is not supported in the 3000T X-Series oscilloscopes.
:DEMO:FUNCTION (see <a href="#">page 396</a> )	The DCMotor, HARMonics, COUPling, CFD, and SENT functions are now available with the educator's kit.
:DISPlay:ANNotation<n> (see <a href="#">page 414</a> )	You can now define up to four annotations.
:DISPlay:ANNotation<n>:BACK ground (see <a href="#">page 415</a> )	
:DISPlay:ANNotation<n>:COLor (see <a href="#">page 416</a> )	
:DISPlay:ANNotation<n>:TEXT (see <a href="#">page 417</a> )	
:DISPlay:SIDebar (see <a href="#">page 434</a> )	The EVENTs and COUNter options are now available.
:DISPlay:VECTors (see <a href="#">page 436</a> )	Always ON (no display as dots option).
:DVM:MODE (see <a href="#">page 441</a> )	The FREQuency option has been replaced by the new <a href="#">Chapter 13</a> , “:COUNter Commands,” starting on page 383.
:EXTernal:RANGe (see <a href="#">page 446</a> )	When using 1:1 probe attenuation, the range can only be set to 8.0 V.
:FUNCTION<m>:OPERation (see <a href="#">page 523</a> )	The SMOOTH, ENvelope, MAXHold, and MINHold operations are added.
:POWER:SIGNals:AUTosetup (see <a href="#">page 828</a> )	The RDSVce option is now available.
:SBUS<n>:CAN:COUNT:OVERload (see <a href="#">page 933</a> )	Always returns zero.

Command	Differences From InfiniiVision 4000 X-Series Oscilloscopes
:SBUS<n>:CAN:TRIGger (see page 946)	Has additional parameters that support CAN FD triggering.
:SBUS<n>:MODE (see page 909)	The SENT mode is now available with the SENT serial decode and triggering license.
:SEARch:MODE (see page 1205)	The PEAK option has been added to enable searching for FFT peaks (see ".:SEARch:PEAK Commands" on page 1217).
:SEARch:SERial:CAN:MODE (see page 1239)	Has additional parameters that support CAN FD searching.
:WAVeform:SOURce:SUBSource (see page 1481)	You can use FAST (alias for SUB0) to get SENT fast channel data or SLOW (alias for SBUS1) to get SENT slow channel data.

### Discontinued Commands

Discontinued Command	Current Command Equivalent	Comments
:ACQuire:RSIGnal	none	There is no 10 MHz REF connector on the 3000T X-Series oscilloscopes.
:COMPliance Commands	none	USB signal quality analysis is not supported on the 3000T X-Series oscilloscopes.
:DVM:FREQuency?	:COUNter:CURREnt? (see page 385)	The :DVM:FREQuency? query has been replaced by the new Chapter 13, ".:COUNter Commands," starting on page 383.
:SAVE:COMPliance:USB[:STARt ]	none	USB signal quality analysis is not supported on the 3000T X-Series oscilloscopes.
:SBUS<n>:USB Commands	none	USB serial decode and triggering is not supported on the 3000T X-Series oscilloscopes.
:SEARch:SERial:USB Commands	none	Searching USB serial decode is not supported on the 3000T X-Series oscilloscopes.
:TIMEbase:REFClock	none	There is no 10 MHz REF connector on the 3000T X-Series oscilloscopes.

Discontinued Command	Current Command Equivalent	Comments
:WGEN<w>:TRACk	none	There is only one waveform generator output on the 3000T X-Series oscilloscopes.
:WGEN<w>:TRACk:AMPLitude	none	
:WGEN<w>:TRACk:CSIGnal	none	
:WGEN<w>:TRACk:FREQuency	none	

## 2 Setting Up

Step 1. Install Keysight IO Libraries Suite software / 66

Step 2. Connect and set up the oscilloscope / 67

Step 3. Verify the oscilloscope connection / 69

This chapter explains how to install the Keysight IO Libraries Suite software, connect the oscilloscope to the controller PC, set up the oscilloscope, and verify the oscilloscope connection.

## Step 1. Install Keysight IO Libraries Suite software


- 1** Download the Keysight IO Libraries Suite software from the Keysight web site at:
  - <http://www.keysight.com/find/iolib>
- 2** Run the setup file, and follow its installation instructions.

## Step 2. Connect and set up the oscilloscope

The 3000T X-Series oscilloscope has two different interfaces you can use for programming:

- USB (device port).
- LAN. To configure the LAN interface, press the **[Utility]** key on the front panel, then press the **I/O** softkey, then press the **Configure** softkey.

These interfaces are always active.



**Figure 1** Control Connectors on Rear Panel

### Using the USB (Device) Interface

- 1 Connect a USB cable from the controller PC's USB port to the "USB DEVICE" port on the back of the oscilloscope.

This is a USB 2.0 high-speed port.

### Using the LAN Interface

- 1 If the controller PC is not already connected to the local area network (LAN), do that first.
- 2 Contact your network administrator about adding the oscilloscope to the network.

Find out if automatic configuration via DHCP or AutoIP can be used. Also, find out whether your network supports Dynamic DNS or Multicast DNS.

If automatic configuration is not supported, get the oscilloscope's network parameters (hostname, domain, IP address, subnet mask, gateway IP, DNS IP, etc.).

- 3 Connect the oscilloscope to the local area network (LAN) by inserting LAN cable into the "LAN" port on the LAN/VGA option module.
- 4 Configure the oscilloscope's LAN interface:
  - a Press the **Configure** softkey until "LAN" is selected.
  - b Press the **LAN Settings** softkey.
  - c Press the **Config** softkey, and enable all the configuration options supported by your network.
  - d If automatic configuration is not supported, press the **Addresses** softkey.

Use the **Modify** softkey (and the other softkeys and the Entry knob) to enter the IP Address, Subnet Mask, Gateway IP, and DNS IP values.


- When you are done, press the **[Back up]** key.
- e Press the **Host name** softkey. Use the softkeys and the Entry knob to enter the Host name.
- When you are done, press the **[Back up]** key.

## Using the GPIB Interface


- 1 Connect a GPIB cable from the controller PC's GPIB interface to the "GPIB" port on the GPIB option module.
- 2 Configure the oscilloscope's GPIB interface:
  - a Press the **Configure** softkey until "GPIB" is selected.
  - b Use the Entry knob to select the **Address** value.

## Step 3. Verify the oscilloscope connection


- 1 On the controller PC, click on the Keysight IO Control icon in the taskbar and choose **Connection Expert** from the popup menu.



- 2 In the Keysight Connection Expert application, instruments connected to the controller's USB and GPIB interfaces as well as instruments on the same LAN subnet should automatically appear in the Instruments tab.



- 3 If your instrument does not appear, you can add it using the Manual Configuration tab.




For example, to add a device:

- a Select **LAN instrument** in the list on the left.
- b Enter the oscilloscope's **Hostname or IP address**.
- c Select the protocol.
- d Select **Instrument** under Set Protocol.
- e Click **Test This VISA Address** to verify the connection.
- f If the connection test is successful, click **Accept** to add the instrument.


If the connection test is not successful, go back and verify the LAN connections and the oscilloscope setup.

**4** Test some commands on the instrument:

- a** In the Details for the selected instrument, click **Send Commands To This Instrument**.



- b** In the Keysight Interactive IO application, enter commands in the **Command** field and press **Send Command**, **Read Response**, or **Send & Read**.



- c Choose **Connect > Exit** from the menu to exit the Keysight Interactive IO application.
- 5 In the Keysight Connection Expert application, choose **File > Exit** from the menu to exit the application.

# 3 Getting Started

Basic Oscilloscope Program Structure / 74

Programming the Oscilloscope / 76

Other Ways of Sending Commands / 85

This chapter gives you an overview of programming the 3000T X-Series oscilloscopes. It describes basic oscilloscope program structure and shows how to program the oscilloscope using a few simple examples.

The getting started examples show how to send oscilloscope setup, data capture, and query commands, and they show how to read query results.

**NOTE**


**Language for Program Examples**

The programming examples in this guide are written in Visual Basic using the Keysight VISA COM library.

---

## Basic Oscilloscope Program Structure

The following figure shows the basic structure of every program you will write for the oscilloscope.



### Initializing

To ensure consistent, repeatable performance, you need to start the program, controller, and oscilloscope in a known state. Without correct initialization, your program may run correctly in one instance and not in another. This might be due to changes made in configuration by previous program runs or from the front panel of the oscilloscope.

- Program initialization defines and initializes variables, allocates memory, or tests system configuration.
- Controller initialization ensures that the interface to the oscilloscope is properly set up and ready for data transfer.
- Oscilloscope initialization sets the channel configuration, channel labels, threshold voltages, trigger specification, trigger mode, timebase, and acquisition type.

### Capturing Data

Once you initialize the oscilloscope, you can begin capturing data for analysis. Remember that while the oscilloscope is responding to commands from the controller, it is not performing acquisitions. Also, when you change the oscilloscope configuration, any data already captured will most likely be rendered.

To collect data, you use the :DIGitize command. This command clears the waveform buffers and starts the acquisition process. Acquisition continues until acquisition memory is full, then stops. The acquired data is displayed by the oscilloscope, and the captured data can be measured, stored in acquisition memory in the oscilloscope, or transferred to the controller for further analysis. Any additional commands sent while :DIGITIZE is working are buffered until :DIGITIZE is complete.

You could also put the oscilloscope into run mode, then use a wait loop in your program to ensure that the oscilloscope has completed at least one acquisition before you make a measurement. Keysight does not recommend this because the needed length of the wait loop may vary, causing your program to fail. :DIGItize, on the other hand, ensures that data capture is complete. Also, :DIGItize, when complete, stops the acquisition process so that all measurements are on displayed data, not on a constantly changing data set.

## Analyzing Captured Data

After the oscilloscope has completed an acquisition, you can find out more about the data, either by using the oscilloscope measurements or by transferring the data to the controller for manipulation by your program. Built-in measurements include: frequency, duty cycle, period, positive pulse width, and negative pulse width.

Using the :WAVeform commands, you can transfer the data to your controller. You may want to display the data, compare it to a known good measurement, or simply check logic patterns at various time intervals in the acquisition.

## Programming the Oscilloscope

- "Referencing the IO Library" on page 76
- "Opening the Oscilloscope Connection via the IO Library" on page 77
- "Using :AUToscale to Automate Oscilloscope Setup" on page 78
- "Using Other Oscilloscope Setup Commands" on page 78
- "Capturing Data with the :DIGitize Command" on page 79
- "Reading Query Responses from the Oscilloscope" on page 81
- "Reading Query Results into String Variables" on page 82
- "Reading Query Results into Numeric Variables" on page 82
- "Reading Definite-Length Block Query Response Data" on page 82
- "Sending Multiple Queries and Reading Results" on page 83
- "Checking Instrument Status" on page 84


### Referencing the IO Library

No matter which instrument programming library you use (SICL, VISA, or VISA COM), you must reference the library from your program.

In C/C++, you must tell the compiler where to find the include and library files (see the Keysight IO Libraries Suite documentation for more information).

To reference the Keysight VISA COM library in Visual Basic for Applications (VBA, which comes with Microsoft Office products like Excel):

- 1 Choose **Tools > References...** from the main menu.
- 2 In the References dialog, check the "VISA COM 5.5 Type Library".



- 3 Click **OK**.

To reference the Keysight VISA COM library in Microsoft Visual Basic 6.0:

- 1** Choose **Project > References...** from the main menu.
- 2** In the References dialog, check the "VISA COM 5.5 Type Library".
- 3** Click **OK**.

## Opening the Oscilloscope Connection via the IO Library

PC controllers communicate with the oscilloscope by sending and receiving messages over a remote interface. Once you have opened a connection to the oscilloscope over the remote interface, programming instructions normally appear as ASCII character strings embedded inside write statements of the programming language. Read statements are used to read query responses from the oscilloscope.

For example, when using the Keysight VISA COM library in Visual Basic (after opening the connection to the instrument using the ResourceManager object's Open method), the FormattedIO488 object's WriteString, WriteNumber, WriteList, or WriteIEEEBlock methods are used for sending commands and queries. After a query is sent, the response is read using the ReadString, ReadNumber, ReadList, or ReadIEEEBlock methods.

The following Visual Basic statements open the connection and send a command that turns on the oscilloscope's label display.

```
Dim myMgr As VisaComLib.ResourceManager
Dim myScope As VisaComLib.FormattedIO488

Set myMgr = New VisaComLib.ResourceManager
Set myScope = New VisaComLib.FormattedIO488

' Open the connection to the oscilloscope. Get the VISA Address from the
' Keysight Connection Expert (installed with Keysight IO Libraries Suite
').
Set myScope.IO = myMgr.Open("<VISA Address>")

' Send a command.
myScope.WriteString ":DISPLAY:LABEL ON"
```

The ":DISPLAY:LABEL ON" in the above example is called a *program message*. Program messages are explained in more detail in "[Program Message Syntax](#)" on page 1667.

## Initializing the Interface and the Oscilloscope

To make sure the bus and all appropriate interfaces are in a known state, begin every program with an initialization statement. When using the Keysight VISA COM library, you can use the resource session object's Clear method to clear the interface buffer:

```

Dim myMgr As VisaComLib.ResourceManager
Dim myScope As VisaComLib.FormattedIO488

Set myMgr = New VisaComLib.ResourceManager
Set myScope = New VisaComLib.FormattedIO488

' Open the connection to the oscilloscope. Get the VISA Address from the
' Keysight Connection Expert (installed with Keysight IO Libraries Suite
'). 
Set myScope.IO = myMgr.Open("<VISA Address>")

' Clear the interface buffer and set the interface timeout to 10 seconds
.
myScope.IO.Clear
myScope.IO.Timeout = 10000

```

When you are using GPIB, CLEAR also resets the oscilloscope's parser. The parser is the program which reads in the instructions which you send it.

After clearing the interface, initialize the instrument to a preset state:

```
myScope.WriteString "*RST"
```

#### NOTE

#### Information for Initializing the Instrument

The actual commands and syntax for initializing the instrument are discussed in [Chapter 6, "Common \(\\*\) Commands,"](#) starting on page 227.

Refer to the Keysight IO Libraries Suite documentation for information on initializing the interface.

### Using :AUToscale to Automate Oscilloscope Setup

The :AUToscale command performs a very useful function for unknown waveforms by setting up the vertical channel, time base, and trigger level of the instrument.

The syntax for the autoscale command is:

```
myScope.WriteString ":AUToscale"
```

### Using Other Oscilloscope Setup Commands

A typical oscilloscope setup would set the vertical range and offset voltage, the horizontal range, delay time, delay reference, trigger mode, trigger level, and slope. An example of the commands that might be sent to the oscilloscope are:

```

myScope.WriteString ":CHANnel1:PROBe 10"
myScope.WriteString ":CHANnel1:RANGE 16"
myScope.WriteString ":CHANnel1:OFFSet 1.00"
myScope.WriteString ":TIMEbase:MODE MAIN"
myScope.WriteString ":TIMEbase:RANGE 1E-3"
myScope.WriteString ":TIMEbase:DELay 100E-6"

```

Vertical is set to 16 V full-scale (2 V/div) with center of screen at 1 V and probe attenuation set to 10. This example sets the time base at 1 ms full-scale (100 ms/div) with a delay of 100 µs.

### Example Oscilloscope Setup Code

This program demonstrates the basic command structure used to program the oscilloscope.

```
' Initialize the instrument interface to a known state.
myScope.IO.Clear
myScope.IO.Timeout = 10000      ' Set interface timeout to 10 seconds.

' Initialize the instrument to a preset state.
myScope.WriteString "*RST"

' Set the time base mode to normal with the horizontal time at
' 50 ms/div with 0 s of delay referenced at the center of the
' graticule.
myScope.WriteString ":TIMEbase:RANGE 5E-4"      ' Time base to 50 us/div.
myScope.WriteString ":TIMEbase:DElay 0"          ' Delay to zero.
myScope.WriteString ":TIMEbase:REference CENTER"   ' Display ref. at
                                                ' center.

' Set the vertical range to 1.6 volts full scale with center screen
' at -0.4 volts with 10:1 probe attenuation and DC coupling.
myScope.WriteString ":CHANnel1:PROBe 10"           ' Probe attenuation
                                                ' to 10:1.
myScope.WriteString ":CHANnel1:RANGE 1.6"          ' Vertical range
                                                ' 1.6 V full scale.
myScope.WriteString ":CHANnel1:OFFSet -0.4"        ' Offset to -0.4.
myScope.WriteString ":CHANnel1:COUPling DC"         ' Coupling to DC.

' Configure the instrument to trigger at -0.4 volts with normal
' triggering.
myScope.WriteString ":TRIGger:SWEep NORMAL"        ' Normal triggering.
myScope.WriteString ":TRIGger:LEVel -0.4"           ' Trigger level to -0.4.
myScope.WriteString ":TRIGger:SLOPe POSitive"       ' Trigger on pos. slope.

' Configure the instrument for normal acquisition.
myScope.WriteString ":ACQuire:TYPE NORMAL"         ' Normal acquisition.
```

### Capturing Data with the :DIGITIZE Command

The :DIGITIZE command captures data that meets the specifications set up by the :ACQUIRE subsystem. When the digitize process is complete, the acquisition is stopped. The captured data can then be measured by the instrument or transferred to the controller for further analysis. The captured data consists of two parts: the waveform data record, and the preamble.

**NOTE****Ensure New Data is Collected**

When you change the oscilloscope configuration, the waveform buffers are cleared. Before doing a measurement, send the :DIGitize command to the oscilloscope to ensure new data has been collected.

When you send the :DIGITIZE command to the oscilloscope, the specified channel signal is digitized with the current :ACQUIRE parameters. To obtain waveform data, you must specify the :WAVEFORM parameters for the SOURCE channel, the FORMAT type, and the number of POINTS prior to sending the :WAVEFORM:DATA? query.

**NOTE****Set :TIMEbase:MODE to MAIN when using :DIGITIZE**

:TIMEbase:MODE must be set to MAIN to perform a :DIGITIZE command or to perform any :WAVEFORM subsystem query. A "Settings conflict" error message will be returned if these commands are executed when MODE is set to ROLL, XY, or WINDow (zoomed). Sending the \*RST (reset) command will also set the time base mode to normal.

The number of data points comprising a waveform varies according to the number requested in the :ACQUIRE subsystem. The :ACQUIRE subsystem determines the number of data points, type of acquisition, and number of averages used by the :DIGITIZE command. This allows you to specify exactly what the digitized information contains.

The following program example shows a typical setup:

```
myScope.WriteString ":ACQUIRE:TYPE AVERAGE"
myScope.WriteString ":ACQUIRE:COMPLETE 100"
myScope.WriteString ":ACQUIRE:COUNT 8"
myScope.WriteString ":DIGITIZE CHANnel1"
myScope.WriteString ":WAVEFORM:SOURCE CHANnel1"
myScope.WriteString ":WAVEFORM:FORMAT BYTE"
myScope.WriteString ":WAVEFORM:POINTS 500"
myScope.WriteString ":WAVEFORM:DATA?"
```

This setup places the instrument into the averaged mode with eight averages. This means that when the :DIGITIZE command is received, the command will execute until the signal has been averaged at least eight times.

After receiving the :WAVEFORM:DATA? query, the instrument will start passing the waveform information.

Digitized waveforms are passed from the instrument to the controller by sending a numerical representation of each digitized point. The format of the numerical representation is controlled with the :WAVEFORM:FORMAT command and may be selected as BYTE, WORD, or ASCII.

The easiest method of transferring a digitized waveform depends on data structures, formatting available and I/O capabilities. You must scale the integers to determine the voltage value of each point. These integers are passed starting with the left most point on the instrument's display.

For more information, see the waveform subsystem commands and corresponding program code examples in [Chapter 38](#), “:WAVeform Commands,” starting on page 1453.

#### NOTE

#### **Aborting a Digitize Operation Over the Programming Interface**

When using the programming interface, you can abort a digitize operation by sending a Device Clear over the bus (for example, `myScope.IO.Clear`).

### Reading Query Responses from the Oscilloscope

After receiving a query (command header followed by a question mark), the instrument interrogates the requested function and places the answer in its output queue. The answer remains in the output queue until it is read or another command is issued. When read, the answer is transmitted across the interface to the designated listener (typically a controller).

The statement for reading a query response message from an instrument's output queue typically has a format specification for handling the response message.

When using the VISA COM library in Visual Basic, you use different read methods (`ReadString`, `ReadNumber`, `ReadList`, or `ReadIEEEBlock`) for the various query response formats. For example, to read the result of the query command `:CHANnel1:COUpling?` you would execute the statements:

```
myScope.WriteString ":CHANnel1:COUpling?"
Dim strQueryResult As String
strQueryResult = myScope.ReadString
```

This reads the current setting for the channel one coupling into the string variable `strQueryResult`.

All results for queries (sent in one program message) must be read before another program message is sent.

Sending another command before reading the result of the query clears the output buffer and the current response. This also causes an error to be placed in the error queue.

Executing a read statement before sending a query causes the controller to wait indefinitely.

The format specification for handling response messages depends on the programming language.

## Reading Query Results into String Variables

The output of the instrument may be numeric or character data depending on what is queried. Refer to the specific command descriptions for the formats and types of data returned from queries.

### NOTE

#### Express String Variables Using Exact Syntax

In Visual Basic, string variables are case sensitive and must be expressed exactly the same each time they are used.

The following example shows numeric data being returned to a string variable:

```
myScope.WriteString ":CHANnel1:RANGE?"
Dim strQueryResult As String
strQueryResult = myScope.ReadString
MsgBox "Range (string):" + strQueryResult
```

After running this program, the controller displays:

**Range (string): +40.0E+00**

## Reading Query Results into Numeric Variables

The following example shows numeric data being returned to a numeric variable:

```
myScope.WriteString ":CHANnel1:RANGE?"
Dim varQueryResult As Variant
varQueryResult = myScope.ReadNumber
MsgBox "Range (variant):" + CStr(varQueryResult)
```


After running this program, the controller displays:

**Range (variant): 40**

## Reading Definite-Length Block Query Response Data

Definite-length block query response data allows any type of device-dependent data to be transmitted over the system interface as a series of 8-bit binary data bytes. This is particularly useful for sending large quantities of data or 8-bit extended ASCII codes. The syntax is a pound sign (#) followed by a non-zero digit representing the number of digits in the decimal integer. After the non-zero digit is the decimal integer that states the number of 8-bit data bytes being sent. This is followed by the actual data.

For example, for transmitting 1000 bytes of data, the syntax would be:



**Figure 2** Definite-length block response data

The "8" states the number of digits that follow, and "00001000" states the number of bytes to be transmitted.

The VISA COM library's ReadIEEEBlock and WriteIEEEBlock methods understand the definite-length block syntax, so you can simply use variables that contain the data:

```
' Read oscilloscope setup using ":SYSTem:SETup?" query.
myScope.WriteString ":SYSTem:SETup?"
Dim varQueryResult As Variant
varQueryResult = myScope.ReadIEEEBlock(BinaryType_UI1)

' Write learn string back to oscilloscope using ":SYSTem:SETup" command:
myScope.WriteIEEEBlock ":SYSTem:SETup ", varQueryResult
```

## Sending Multiple Queries and Reading Results

You can send multiple queries to the instrument within a single command string, but you must also read them back as a single query result. This can be accomplished by reading them back into a single string variable, multiple string variables, or multiple numeric variables.

For example, to read the :TIMEbase:RANGE?;DElay? query result into a single string variable, you could use the commands:

```
myScope.WriteString ":TIMEbase:RANGE?;DElay?"
Dim strQueryResult As String
strQueryResult = myScope.ReadString
MsgBox "Timebase range; delay:" + strQueryResult
```

When you read the result of multiple queries into a single string variable, each response is separated by a semicolon. For example, the output of the previous example would be:

```
Timebase range; delay: <range_value>;<delay_value>
```

To read the :TIMEbase:RANGE?;DElay? query result into multiple string variables, you could use the ReadList method to read the query results into a string array variable using the commands:

```
myScope.WriteString ":TIMEbase:RANGE?;DElay?"
Dim strResults() As String
strResults() = myScope.ReadList(ASCIIIType_BSTR)
MsgBox "Timebase range: " + strResults(0) + ", delay: " + strResults(1)
```

To read the :TIMEbase:RANGE?;DElay? query result into multiple numeric variables, you could use the ReadList method to read the query results into a variant array variable using the commands:

```
myScope.WriteString ":TIMEbase:RANGE?;DElay?"
Dim varResults() As Variant
varResults() = myScope.ReadList
MsgBox "Timebase range: " + FormatNumber(varResults(0) * 1000, 4) + _
       " ms, delay: " + FormatNumber(varResults(1) * 1000000, 4) + " us"
```

## Checking Instrument Status

Status registers track the current status of the instrument. By checking the instrument status, you can find out whether an operation has been completed, whether the instrument is receiving triggers, and more.

For more information, see [Chapter 43](#), “Status Reporting,” starting on page 1613 which explains how to check the status of the instrument.

## Other Ways of Sending Commands

Standard Commands for Programmable Instrumentation (SCPI) can also be sent via a Telnet socket or through the Browser Web Control:

- "Telnet Sockets" on page 85
- "Sending SCPI Commands Using Browser Web Control" on page 85

### Telnet Sockets

The following information is provided for programmers who wish to control the oscilloscope with SCPI commands in a Telnet session.

To connect to the oscilloscope via a telnet socket, issue the following command:

```
telnet <hostname> 5024
```

where <hostname> is the hostname of the oscilloscope. This will give you a command line with prompt.

For a command line without a prompt, use port 5025. For example:

```
telnet <hostname> 5025
```

### Sending SCPI Commands Using Browser Web Control

To send SCPI commands using the Browser Web Control feature, establish a connection to the oscilloscope via LAN as described in the *InfiniiVision 3000T X-Series Oscilloscopes User's Guide*. When you make the connection to the oscilloscope via LAN and the instrument's welcome page is displayed, select the **Browser Web Control** tab, then select the **Remote Programming** link.



## 4 Sequential (Blocking) vs. Overlapped Commands

IEEE 488.2 makes the distinction between sequential and overlapped commands (and queries):

- *Sequential commands* also known as *blocking commands*, finish their task before the execution of the next command starts.

These oscilloscope commands and queries are sequential (blocking):

- :AUToscale
- :DIGitize
- :WMMemory<r>:SAVE <source>
- :WAVeform:DATA?
- *Overlapped commands* run concurrently. Commands following an overlapped command may be started before the overlapped command is completed.

Some oscilloscope commands are overlapped. For example, the oscilloscope's save and recall commands are overlapped as well as some commands that perform analysis.

With sequential (blocking) commands and queries, the oscilloscope is expected to stop processing inputs, including additional remote commands and queries as well as front panel knobs, until completed.

### Pausing Execution Between Overlapped Commands

With overlapped commands, you can use the \*OPC? query to prevent any more commands from being executed until the overlapped command is complete. This may be necessary when a command that follows an overlapped command interferes with the overlapped command's processing or analysis. For example:

```
:RECall:SETup "setup.scp";*OPC?;:RECall:ARBITrary "arb_wfm.csv"
```

You can also use the \*ESR? query to look at the OPC bit (bit 0) in the Standard Event Status Register to determine when an operation is complete.

**Pausing Programs Until Sequential (Blocking) Commands are Complete**

Sequential (blocking) commands do not prevent additional commands from being sent to the queue or cause the remote program to wait. For example, if your program does something like:

```
myScope.WriteString ":DIGITIZE"
Debug.Print "Signal acquired."
```

The "Signal acquired" message will be written immediately after the :DIGITIZE is sent, not after the acquisition and processing is complete.

To pause the program until a sequential (blocking) command is complete, you must wait for a query result after the sequential (blocking) command. For example, in this case:

```
Public strQueryResult As String
myScope.WriteString ":DIGITIZE;*OPC?"
strQueryResult = myScope.ReadString
Debug.Print "Signal acquired."
```

The "Signal acquired" message will be written after the acquisition and processing is complete. The \*OPC? query is appended to :DIGITIZE with a semi-colon (;), which essentially ties it to the same thread in the parser. It is immediately dealt with once :DIGITIZE finishes and gives a "1" back to the program (whether the program uses it or not), allowing the program to move on.

When using a query to wait until a sequential (blocking) command is complete, it is possible for the sequential (blocking) command execution to take longer than the I/O timeout, in which case, there will be a timeout error while waiting for the query results. You can increase the I/O timeout or have your program poll the Status Byte Register using the IO libraries' unblocked ReadSTB function to wait for execution completion.

**Using Device Clear to Abort a Sequential (Blocking) Command**

When sequential (blocking) commands take too long or fail to complete for some reason, you can send a Device Clear over the bus to clear the input buffer and output queue, reset the parser, and clear any pending commands.

**See Also**

- ["\\*OPC \(Operation Complete\)"](#) on page 240
- ["\\*ESR \(Standard Event Status Register\)"](#) on page 236
- [Chapter 44](#), "Synchronizing Acquisitions," starting on page 1645

# 5 Commands Quick Reference

Command Summary / 90

Syntax Elements / 224

## Command Summary

- Common (\*) Commands Summary (see [page 92](#))
- Root (:) Commands Summary (see [page 96](#))
- :ACQuire Commands Summary (see [page 100](#))
- :BUS<n> Commands Summary (see [page 102](#))
- :CALibrate Commands Summary (see [page 103](#))
- :CHANnel<n> Commands Summary (see [page 103](#))
- :COMPliance Commands Summary (see [page 106](#))
- :COUNter Commands Summary (see [page 107](#))
- :DEMO Commands Summary (see [page 108](#))
- :DIGItal<n> Commands Summary (see [page 109](#))
- :DISPlay Commands Summary (see [page 109](#))
- :DVM Commands Summary (see [page 111](#))
- :EXTernal Trigger Commands Summary (see [page 112](#))
- :FFT Commands Summary (see [page 112](#))
- :FRANalysis Commands Summary (see [page 114](#))
- :FUNCTION Commands Summary (see [page 115](#))
- :HARDcopy Commands Summary (see [page 121](#))
- :LISTer Commands Summary (see [page 123](#))
- :LTESt Commands Summary (see [page 123](#))
- :MARKer Commands Summary (see [page 124](#))
- :MEASure Commands Summary (see [page 126](#))
- :MEASure Power Commands Summary (see [page 146](#))
- :MTESt Commands Summary (see [page 150](#))
- :POD<n> Commands Summary (see [page 152](#))
- :POWER Commands Summary (see [page 153](#))
- :RECall Commands Summary (see [page 161](#))
- :SAVE Commands Summary (see [page 162](#))
- General :SBUS<n> Commands Summary (see [page 165](#))
- :SBUS<n>:A429 Commands Summary (see [page 165](#))
- :SBUS<n>:CAN Commands Summary (see [page 167](#))
- :SBUS<n>:CXPI Commands Summary (see [page 169](#))
- :SBUS<n>:FLEXray Commands Summary (see [page 171](#))
- :SBUS<n>:I2S Commands Summary (see [page 172](#))

- :SBUS<n>:IIC Commands Summary (see [page 175](#))
- :SBUS<n>:LIN Commands Summary (see [page 176](#))
- :SBUS<n>:M1553 Commands Summary (see [page 177](#))
- :SBUS<n>:MANChester Commands Summary (see [page 178](#))
- :SBUS<n>:NRZ Commands Summary (see [page 179](#))
- :SBUS<n>:SENT Commands Summary (see [page 181](#))
- :SBUS<n>:SPI Commands Summary (see [page 183](#))
- :SBUS<n>:UART Commands Summary (see [page 185](#))
- :SBUS<n>:USB Commands Summary (see [page 187](#))
- :SBUS<n>:USBPd Commands Summary (see [page 189](#))
- General :SEARch Commands Summary (see [page 190](#))
- :SEARch:EDGE Commands Summary (see [page 191](#))
- :SEARch:GLITch Commands Summary (see [page 191](#))
- :SEARch:PEAK Commands Summary (see [page 192](#))
- :SEARch:RUNT Commands Summary (see [page 192](#))
- :SEARch:TRANSition Commands Summary (see [page 193](#))
- :SEARch:SERial:A429 Commands Summary (see [page 193](#))
- :SEARch:SERial:CAN Commands Summary (see [page 194](#))
- :SEARch:SERial:FLEXray Commands Summary (see [page 194](#))
- :SEARch:SERial:I2S Commands Summary (see [page 195](#))
- :SEARch:SERial:IIC Commands Summary (see [page 196](#))
- :SEARch:SERial:LIN Commands Summary (see [page 196](#))
- :SEARch:SERial:M1553 Commands Summary (see [page 197](#))
- :SEARch:SERial:SENT Commands Summary (see [page 198](#))
- :SEARch:SERial:SPI Commands Summary (see [page 198](#))
- :SEARch:SERial:UART Commands Summary (see [page 199](#))
- :SEARch:SERial:USB Commands Summary (see [page 199](#))
- :SYSTem Commands Summary (see [page 201](#))
- :TIMEbase Commands Summary (see [page 203](#))
- General :TRIGger Commands Summary (see [page 203](#))
- :TRIGger:DELay Commands Summary (see [page 205](#))
- :TRIGger:EBURst Commands Summary (see [page 205](#))
- :TRIGger[:EDGE] Commands Summary (see [page 206](#))
- :TRIGger:GLITch Commands Summary (see [page 207](#))
- :TRIGger:NFC Commands Summary (see [page 209](#))

- :TRIGger:OR Commands Summary (see [page 210](#))
- :TRIGger:PATTern Commands Summary (see [page 210](#))
- :TRIGger:RUNT Commands Summary (see [page 211](#))
- :TRIGger:SHOLd Commands Summary (see [page 211](#))
- :TRIGger:TRANsition Commands Summary (see [page 212](#))
- :TRIGger:TV Commands Summary (see [page 213](#))
- :TRIGger:USB Commands Summary (see [page 214](#))
- :TRIGger:ZONE Commands Summary (see [page 214](#))
- :WAVEform Commands Summary (see [page 215](#))
- :WGEN Commands Summary (see [page 218](#))
- :WMEMory<r> Commands Summary (see [page 222](#))

**Table 2** Common (\*) Commands Summary

Command	Query	Options and Query Returns
*CLS (see <a href="#">page 233</a> )	n/a	n/a
*ESE <mask> (see <a href="#">page 234</a> )	*ESE? (see <a href="#">page 234</a> )	<mask> ::= 0 to 255; an integer in NR1 format:  Bit Weight Name Enables --- ----- --- ----- 7 128 PON Power On 6 64 URQ User Request 5 32 CME Command Error 4 16 EXE Execution Error 3 8 DDE Dev. Dependent Error 2 4 QYE Query Error 1 2 RQL Request Control 0 1 OPC Operation Complete
n/a	*ESR? (see <a href="#">page 236</a> )	<status> ::= 0 to 255; an integer in NR1 format
n/a	*IDN? (see <a href="#">page 236</a> )	KEYSIGHT TECHNOLOGIES,<model>,<serial number>,X.XX.XX  <model> ::= the model number of the instrument  <serial number> ::= the serial number of the instrument  <X.XX.XX> ::= the software revision of the instrument
n/a	*LRN? (see <a href="#">page 239</a> )	<learn_string> ::= current instrument setup as a block of data in IEEE 488.2 # format

**Table 2** Common (\*) Commands Summary (continued)

Command	Query	Options and Query Returns
*OPC (see page 240)	*OPC? (see page 240)	ASCII "1" is placed in the output queue when all pending device operations have completed.
n/a	*OPT? (see page 241)	<pre>&lt;return_value&gt; ::= 0,0,&lt;license info&gt;  &lt;license info&gt; ::= &lt;All field&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;MSO&gt;, &lt;reserved&gt;, &lt;Memory&gt;, &lt;Low Speed Serial&gt;, &lt;Automotive Serial&gt;, &lt;FlexRay Serial&gt;, &lt;Frequency Response Analysis&gt;, &lt;Power Measurements&gt;, &lt;RS-232/UART Serial&gt;, &lt;Segmented Memory&gt;, &lt;Mask Test&gt;, &lt;reserved&gt;, &lt;Bandwidth&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;I2S Serial&gt;, &lt;reserved&gt;, &lt;Educator's Kit&gt;, &lt;Waveform Generator&gt;, &lt;MIL-1553/ARINC 429 Serial&gt;, &lt;Extended Video&gt;, &lt;Advanced Math&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;Digital Voltmeter/Counter&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;Remote Command Logging&gt;, &lt;reserved&gt;, &lt;SENT Serial&gt;, &lt;CAN FD Serial&gt;, &lt;CXPI Serial&gt;, &lt;NFC Trigger&gt;, &lt;reserved&gt;"', &lt;reserved&gt;, &lt;reserved&gt;, &lt;Manchester/NRZ Serial&gt;, &lt;USB PD Serial&gt;, &lt;reserved&gt;, &lt;Automotive Software&gt;, &lt;General Purpose Software&gt;, &lt;Aerospace Software&gt;, &lt;Power Supply Test Software&gt;, &lt;reserved&gt;, &lt;Near Field Communications (NFC) Software&gt;, &lt;Software Bundle&gt;</pre>

**Table 2** Common (\*) Commands Summary (continued)

Command	Query	Options and Query Returns
n/a	*OPT? (see <a href="#">page 241</a> ) (cont'd)	<All field> ::= {0   All} <reserved> ::= 0 <MSO> ::= {0   MSO} <Memory> ::= {0   MEMUP} <Low Speed Serial> ::= {0   EMBD} <Automotive Serial> ::= {0   AUTO} <FlexRay Serial> ::= {0   FLEX} <Frequency Response Analysis> ::= {0   FRA} <Power Measurements> ::= {0   PWR} <RS-232/UART Serial> ::= {0   COMP} <Mask Test> ::= {0   MASK} <Bandwidth> ::= {0   BW20   BW50} <I2S Serial> ::= {0   AUDIO} <Educator's Kit> ::= {0   EDK} <Waveform Generator> ::= {0   WAVEGEN} <MIL-1553/ARINC 429 Serial> ::= {0   AERO} <Extended Video> ::= {0   VID} <Digital Voltmeter/Counter> ::= {0   DVMCTR} <Remote Command Logging> ::= {0   RML} <SENT Serial> ::= {0   SENSOR} <CAN FD Serial> ::= {0   CANFD} <CXPI Serial> ::= {0   CXPI} <NFC Trigger> ::= {0   NFC}

**Table 2** Common (\*) Commands Summary (continued)

Command	Query	Options and Query Returns
n/a	*OPT? (see <a href="#">page 241</a> ) (cont'd)	<Manchester/NRZ Serial> ::= {0   NRZ}  <USB PD Serial> ::= {0   USBPD}  <Automotive Software> ::= {0   D3000AUTA}  <General Purpose Software> ::= {0   D3000GENA}  <Aerospace Software> ::= {0   D3000AERA}  <Power Supply Test Software> ::= {0   D3000PWRA}  <Near Field Communications (NFC) Software> ::= {0   D3000NFCA}  <Software Bundle> ::= {0   D3000BDLA}
*RCL <value> (see <a href="#">page 243</a> )	n/a	<value> ::= {0   1   4   5   6   7   8   9}
*RST (see <a href="#">page 244</a> )	n/a	See *RST (Reset) (see <a href="#">page 244</a> )
*SAV <value> (see <a href="#">page 247</a> )	n/a	<value> ::= {0   1   4   5   6   7   8   9}
*SRE <mask> (see <a href="#">page 248</a> )	*SRE? (see <a href="#">page 249</a> )	<mask> ::= sum of all bits that are set, 0 to 255; an integer in NR1 format. <mask> ::= following values:  Bit Weight Name Enables --- ----- --- 7 128 OPER Operation Status Reg 6 64 ---- (Not used.) 5 32 ESB Event Status Bit 4 16 MAV Message Available 3 8 ---- (Not used.) 2 4 MSG Message 1 2 USR User 0 1 TRG Trigger

**Table 2** Common (\*) Commands Summary (continued)

Command	Query	Options and Query Returns																																				
n/a	*STB? (see <a href="#">page 250</a> )	<p>&lt;value&gt; ::= 0 to 255; an integer in NR1 format, as shown in the following:</p> <table> <thead> <tr> <th>Bit</th> <th>Weight</th> <th>Name</th> <th>Indicates</th> </tr> </thead> <tbody> <tr> <td>7</td> <td>128</td> <td>OPER</td> <td>Operation status condition occurred.</td> </tr> <tr> <td>6</td> <td>64</td> <td>RQS/</td> <td>Instrument is MSS requesting service.</td> </tr> <tr> <td>5</td> <td>32</td> <td>ESB</td> <td>Enabled event status condition occurred.</td> </tr> <tr> <td>4</td> <td>16</td> <td>MAV</td> <td>Message available.</td> </tr> <tr> <td>3</td> <td>8</td> <td>----</td> <td>(Not used.)</td> </tr> <tr> <td>2</td> <td>4</td> <td>MSG</td> <td>Message displayed.</td> </tr> <tr> <td>1</td> <td>2</td> <td>USR</td> <td>User event condition occurred.</td> </tr> <tr> <td>0</td> <td>1</td> <td>TRG</td> <td>A trigger occurred.</td> </tr> </tbody> </table>	Bit	Weight	Name	Indicates	7	128	OPER	Operation status condition occurred.	6	64	RQS/	Instrument is MSS requesting service.	5	32	ESB	Enabled event status condition occurred.	4	16	MAV	Message available.	3	8	----	(Not used.)	2	4	MSG	Message displayed.	1	2	USR	User event condition occurred.	0	1	TRG	A trigger occurred.
Bit	Weight	Name	Indicates																																			
7	128	OPER	Operation status condition occurred.																																			
6	64	RQS/	Instrument is MSS requesting service.																																			
5	32	ESB	Enabled event status condition occurred.																																			
4	16	MAV	Message available.																																			
3	8	----	(Not used.)																																			
2	4	MSG	Message displayed.																																			
1	2	USR	User event condition occurred.																																			
0	1	TRG	A trigger occurred.																																			
*TRG (see <a href="#">page 252</a> )	n/a	n/a																																				
n/a	*TST? (see <a href="#">page 253</a> )	<result> ::= 0 or non-zero value; an integer in NR1 format																																				
*WAI (see <a href="#">page 254</a> )	n/a	n/a																																				

**Table 3** Root (:) Commands Summary

Command	Query	Options and Query Returns
:ACTivity (see <a href="#">page 259</a> )	:ACTivity? (see <a href="#">page 259</a> )	<p>&lt;return value&gt; ::= &lt;edges&gt;,&lt;levels&gt;</p> <p>&lt;edges&gt; ::= presence of edges (32-bit integer in NR1 format)</p> <p>&lt;levels&gt; ::= logical highs or lows (32-bit integer in NR1 format)</p>
n/a	:AER? (see <a href="#">page 260</a> )	{0   1}; an integer in NR1 format

**Table 3** Root (: ) Commands Summary (continued)

Command	Query	Options and Query Returns
:AUToscale [ <source/> [,...<source>]] (see <a href="#">page 261</a> )	n/a	<p>&lt;source&gt; ::= CHANnel&lt;n&gt; for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   POD1   POD2} for MSO models</p> <p>&lt;source&gt; can be repeated up to 5 times</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p>
:AUToscale:AMODE <value> (see <a href="#">page 263</a> )	:AUToscale:AMODE?	<value> ::= {NORMAl   CURRent}
:AUToscale:CHANnels <value> (see <a href="#">page 264</a> )	:AUToscale:CHANnels?	<value> ::= {ALL   DISPlayed}
:AUToscale:FDEBug {{0   OFF}   {1   ON}} (see <a href="#">page 265</a> )	:AUToscale:FDEBug?	{0   1}
:BLANK [<source>] (see <a href="#">page 266</a> )	n/a	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;}   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   FFT   SBUS{1   2}   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   POD{1   2}   BUS{1   2}   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   FFT   SBUS{1   2}   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p>

**Table 3** Root (: ) Commands Summary (continued)

Command	Query	Options and Query Returns
:DIGItize [ <source/> [,...<source>]] (see <a href="#">page 268</a> )	n/a	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT   SBUS{1   2}} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   POD{1   2}   BUS{1   2}   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT   SBUS{1   2}} for MSO models</p> <p>&lt;source&gt; can be repeated up to 5 times</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p>
:HWEenable <n> (see <a href="#">page 270</a> )	:HWEenable? (see <a href="#">page 270</a> )	<n> ::= 16-bit integer in NR1 format
n/a	:HWERegister:CONDitiOn? (see <a href="#">page 272</a> )	<n> ::= 16-bit integer in NR1 format
n/a	:HWERegister[:EVENT]? (see <a href="#">page 273</a> )	<n> ::= 16-bit integer in NR1 format
:MTEenable <n> (see <a href="#">page 274</a> )	:MTEenable? (see <a href="#">page 274</a> )	<n> ::= 16-bit integer in NR1 format
n/a	:MTERegister[:EVENT]? (see <a href="#">page 276</a> )	<n> ::= 16-bit integer in NR1 format
:OPEE <n> (see <a href="#">page 278</a> )	:OPEE? (see <a href="#">page 279</a> )	<n> ::= 15-bit integer in NR1 format
n/a	:OPERegister:CONDitiOn? (see <a href="#">page 280</a> )	<n> ::= 15-bit integer in NR1 format
n/a	:OPERegister[:EVENT]? (see <a href="#">page 283</a> )	<n> ::= 15-bit integer in NR1 format

**Table 3** Root(:) Commands Summary (continued)

Command	Query	Options and Query Returns																																	
:OVLenable <mask> (see <a href="#">page 286</a> )	:OVLenable? (see <a href="#">page 287</a> )	<p>&lt;mask&gt; ::= 16-bit integer in NR1 format as shown:</p> <table> <thead> <tr> <th>Bit</th><th>Weight</th><th>Input</th></tr> </thead> <tbody> <tr><td>10</td><td>1024</td><td>Ext Trigger Fault</td></tr> <tr><td>9</td><td>512</td><td>Channel 4 Fault</td></tr> <tr><td>8</td><td>256</td><td>Channel 3 Fault</td></tr> <tr><td>7</td><td>128</td><td>Channel 2 Fault</td></tr> <tr><td>6</td><td>64</td><td>Channel 1 Fault</td></tr> <tr><td>4</td><td>16</td><td>Ext Trigger OVL</td></tr> <tr><td>3</td><td>8</td><td>Channel 4 OVL</td></tr> <tr><td>2</td><td>4</td><td>Channel 3 OVL</td></tr> <tr><td>1</td><td>2</td><td>Channel 2 OVL</td></tr> <tr><td>0</td><td>1</td><td>Channel 1 OVL</td></tr> </tbody> </table>	Bit	Weight	Input	10	1024	Ext Trigger Fault	9	512	Channel 4 Fault	8	256	Channel 3 Fault	7	128	Channel 2 Fault	6	64	Channel 1 Fault	4	16	Ext Trigger OVL	3	8	Channel 4 OVL	2	4	Channel 3 OVL	1	2	Channel 2 OVL	0	1	Channel 1 OVL
Bit	Weight	Input																																	
10	1024	Ext Trigger Fault																																	
9	512	Channel 4 Fault																																	
8	256	Channel 3 Fault																																	
7	128	Channel 2 Fault																																	
6	64	Channel 1 Fault																																	
4	16	Ext Trigger OVL																																	
3	8	Channel 4 OVL																																	
2	4	Channel 3 OVL																																	
1	2	Channel 2 OVL																																	
0	1	Channel 1 OVL																																	
n/a	:OVLRegister? (see <a href="#">page 288</a> )	<value> ::= integer in NR1 format. See OVLenable for <value>																																	
:PRINT [<options>] (see <a href="#">page 290</a> )	n/a	<p>&lt;options&gt; ::= [&lt;print option&gt;] [,...,&lt;print option&gt;]</p> <p>&lt;print option&gt; ::= {COLOR   GRAYscale   PRINTER0   BMP8bit   BMP   PNG   NOFactors   FACTors}</p> <p>&lt;print option&gt; can be repeated up to 5 times.</p>																																	
n/a	:RSTate? (see <a href="#">page 291</a> )	n/a																																	
:RUN (see <a href="#">page 292</a> )	n/a	n/a																																	
n/a	:SERial? (see <a href="#">page 293</a> )	<return value> ::= unquoted string containing serial number																																	
:SINGle (see <a href="#">page 294</a> )	n/a	n/a																																	
n/a	:STATUS? <display> (see <a href="#">page 295</a> )	<p>{0   1}</p> <p>&lt;display&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   POD{1   2}   BUS{1   2}   FUNCTion&lt;m&gt;   MATH&lt;m&gt;   FFT   SBUS{1   2}   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p>																																	

**Table 3** Root (: ) Commands Summary (continued)

Command	Query	Options and Query Returns
:STOP (see <a href="#">page 296</a> )	n/a	n/a
n/a	:TER? (see <a href="#">page 297</a> )	{0   1}
:VIEW <source> (see <a href="#">page 298</a> )	n/a	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   FFT   SBUS{1   2}   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   POD{1   2}   BUS{1   2}   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   FFT   SBUS{1   2}   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p>

**Table 4** :ACQuire Commands Summary

Command	Query	Options and Query Returns
n/a	:ACQuire:AALias? (see <a href="#">page 302</a> )	{1   0}
:ACQuire:COMplete <complete> (see <a href="#">page 303</a> )	:ACQuire:COMplete? (see <a href="#">page 303</a> )	<complete> ::= 100; an integer in NR1 format
:ACQuire:COUNT <count> (see <a href="#">page 304</a> )	:ACQuire:COUNT? (see <a href="#">page 304</a> )	<count> ::= an integer from 2 to 65536 in NR1 format
:ACQuire:DAALias <mode> (see <a href="#">page 305</a> )	:ACQuire:DAALias? (see <a href="#">page 305</a> )	<mode> ::= {DISable   AUTO}
:ACQuire:DIGitizer {{0   OFF}   {1   ON}} (see <a href="#">page 306</a> )	:ACQuire:DIGitizer? (see <a href="#">page 306</a> )	{0   1}
:ACQuire:MODE <mode> (see <a href="#">page 307</a> )	:ACQuire:MODE? (see <a href="#">page 307</a> )	<mode> ::= {RTIMe   ETIMe   SEGmented}

**Table 4** :ACQuire Commands Summary (continued)

Command	Query	Options and Query Returns
:ACQuire:POINTS[:ANALog] <points> (see page 308)	:ACQuire:POINTS[:ANALog]? (see page 308)	<points> ::= {AUTO   <points_value>} <points_value> ::= desired analog memory depth in integer NR1 format
:ACQuire:POINTS[:ANALog]:AUTO {{0   OFF}   {1   ON}} (see page 309)	:ACQuire:POINTS[:ANALog]:AUTO? (see page 309)	{0   1}
:ACQuire:SEGMediated:ANALyze (see page 310)	n/a	n/a
:ACQuire:SEGMediated:COUNT <count> (see page 311)	:ACQuire:SEGMediated:COUNT? (see page 311)	<count> ::= an integer from 2 to 1000 in NR1 format
:ACQuire:SEGMediated:INDEX <index> (see page 312)	:ACQuire:SEGMediated:INDEX? (see page 312)	<index> ::= an integer from 1 to 1000 in NR1 format
:ACQuire:SRATE[:ANALog] <rate> (see page 315)	:ACQuire:SRATE[:ANALog]? (see page 315)	<rate> ::= {AUTO   <sample_rate>} <sample_rate> ::= desired analog sample rate in NR3 format
:ACQuire:SRATE[:ANALog]:AUTO {{0   OFF}   {1   ON}} (see page 316)	:ACQuire:SRATE[:ANALog]:AUTO? (see page 316)	{0   1}
:ACQuire:TYPE <type> (see page 317)	:ACQuire:TYPE? (see page 317)	<type> ::= {NORMAL   AVERage   HRESolution   PEAK}

**Table 5** :BUS<n> Commands Summary

Command	Query	Options and Query Returns
:BUS<n>:BIT<m> {{0   OFF}   {1   ON}} (see page 321)	:BUS<n>:BIT<m>? (see page 321)	{0   1} <n> ::= 1 or 2; an integer in NR1 format <m> ::= 0-15; an integer in NR1 format
:BUS<n>:BITS <channel_list>, {{0   OFF}   {1   ON}} (see page 322)	:BUS<n>:BITS? (see page 322)	<channel_list>, {0   1} <channel_list> ::= (@<m>,<m>:<m> ... ) where "," is separator and ":" is range <n> ::= 1 or 2; an integer in NR1 format <m> ::= 0-15; an integer in NR1 format
:BUS<n>:CLEar (see page 324)	n/a	<n> ::= 1 or 2; an integer in NR1 format
:BUS<n>:DISPlay {{0   OFF}   {1   ON}} (see page 325)	:BUS<n>:DISPlay? (see page 325)	{0   1} <n> ::= 1 or 2; an integer in NR1 format
:BUS<n>:LABel <string> (see page 326)	:BUS<n>:LABel? (see page 326)	<string> ::= quoted ASCII string up to 10 characters <n> ::= 1 or 2; an integer in NR1 format
:BUS<n>:MASK <mask> (see page 327)	:BUS<n>:MASK? (see page 327)	<mask> ::= 32-bit integer in decimal, <nondecimal>, or <string> <nondecimal> ::= #Hnn...n where n ::= {0,...,9   A,...,F} for hexadecimal <nondecimal> ::= #Bnn...n where n ::= {0   1} for binary <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F} for hexadecimal <n> ::= 1 or 2; an integer in NR1 format

**Table 6** :CALibrate Commands Summary

Command	Query	Options and Query Returns
n/a	:CALibrate:DATE? (see <a href="#">page 331</a> )	<return value> ::= <year>,<month>,<day>; all in NR1 format
:CALibrate:LABEL <string> (see <a href="#">page 332</a> )	:CALibrate:LABEL?	<string> ::= quoted ASCII string up to 32 characters
:CALibrate:OUTPut <signal> (see <a href="#">page 333</a> )	:CALibrate:OUTPut? (see <a href="#">page 334</a> )	<signal> ::= {TRIGgers   MASK   WAVEgen   WGEN1   WGEN2   TSource} Note: WAVE and WGEN1 are equivalent. Note: WGEN2 only available on models with 2 WaveGen outputs.
n/a	:CALibrate:PROTected? (see <a href="#">page 335</a> )	{"PROTected"   "UNPROtected"}
:CALibrate:START (see <a href="#">page 336</a> )	n/a	n/a
n/a	:CALibrate:STATUS? (see <a href="#">page 337</a> )	<return value> ::= <status_code>,<status_string> <status_code> ::= an integer status code <status_string> ::= an ASCII status string
n/a	:CALibrate:TEMPERatur e? (see <a href="#">page 338</a> )	<return value> ::= degrees C delta since last cal in NR3 format
n/a	:CALibrate:TIME? (see <a href="#">page 339</a> )	<return value> ::= <hours>,<minutes>,<seconds>; all in NR1 format

**Table 7** :CHANnel<n> Commands Summary

Command	Query	Options and Query Returns
:CHANnel<n>:BWLimit { {0   OFF}   {1   ON} } (see <a href="#">page 345</a> )	:CHANnel<n>:BWLimit? (see <a href="#">page 345</a> )	{0   1} <n> ::= 1 to (# analog channels) in NR1 format
:CHANnel<n>:COUpling <coupling> (see <a href="#">page 346</a> )	:CHANnel<n>:COUpling? (see <a href="#">page 346</a> )	<coupling> ::= {AC   DC} <n> ::= 1 to (# analog channels) in NR1 format

**Table 7** :CHANnel<n> Commands Summary (continued)

Command	Query	Options and Query Returns
:CHANnel<n>:DISPLAY { {0   OFF}   {1   ON} } (see page 347)	:CHANnel<n>:DISPLAY? (see page 347)	{0   1} <n> ::= 1 to (# analog channels) in NR1 format
:CHANnel<n>:IMPedance <impedance> (see page 348)	:CHANnel<n>:IMPedance? (see page 348)	<impedance> ::= {ONEMeg   FIFTy} <n> ::= 1 to (# analog channels) in NR1 format
:CHANnel<n>:INVert { {0   OFF}   {1   ON} } (see page 349)	:CHANnel<n>:INVert? (see page 349)	{0   1} <n> ::= 1 to (# analog channels) in NR1 format
:CHANnel<n>:LABEL <string> (see page 350)	:CHANnel<n>:LABEL? (see page 350)	<string> ::= any series of 32 or less ASCII characters enclosed in quotation marks <n> ::= 1 to (# analog channels) in NR1 format
:CHANnel<n>:OFFSet <offset>[suffix] (see page 351)	:CHANnel<n>:OFFSet? (see page 351)	<offset> ::= Vertical offset value in NR3 format [suffix] ::= {V   mV} <n> ::= 1-2 or 1-4; in NR1 format
:CHANnel<n>:PROBe <attenuation> (see page 352)	:CHANnel<n>:PROBe? (see page 352)	<attenuation> ::= Probe attenuation ratio in NR3 format <n> ::= 1-2 or 1-4r in NR1 format
:CHANnel<n>:PROBe:BTN <setting> (see page 353)	:CHANnel<n>:PROBe:BTN? (see page 353)	<n> ::= 1 to (# analog channels) in NR1 format <setting> ::= {HEADlight   INFiniemode   RSTop   SINGLE   CDISplay   AUToscale   FTRigger   QACTION   NACTION   NONE}
:CHANnel<n>:PROBe:CALibration (see page 354)	n/a	n/a
:CHANnel<n>:PROBe:EXTERNAL { {0   OFF}   {1   ON} } (see page 355)	:CHANnel<n>:PROBe:EXTERNAL? (see page 355)	<n> ::= 1 to (# analog channels) in NR1 format <setting> ::= {0   1}
:CHANnel<n>:PROBe:EXTERNAL:GAIN <gain_factor> (see page 356)	:CHANnel<n>:PROBe:EXTERNAL:GAIN? (see page 356)	<n> ::= 1 to (# analog channels) in NR1 format <gain_factor> ::= a real number from 0.0001 to 1000 in NR3 format

**Table 7** :CHANnel<n> Commands Summary (continued)

Command	Query	Options and Query Returns
:CHANnel<n>:PROBe:EXTernal:UNITS <units> (see <a href="#">page 357</a> )	:CHANnel<n>:PROBe:EXTernal:UNITS? (see <a href="#">page 357</a> )	<n> ::= 1 to (# analog channels) in NR1 format <units> ::= {VOLT   AMPere}
:CHANnel<n>:PROBe:HEAD[:TYPE] <head_param> (see <a href="#">page 358</a> )	:CHANnel<n>:PROBe:HEAD[:TYPE]? (see <a href="#">page 358</a> )	<head_param> ::= {SEND0   SEND6   SEND12   SEND20   DIFF0   DIFF6   DIFF12   DIFF20   DSMA   DSMA6   NONE}  <n> ::= 1 to (# analog channels) in NR1 format
n/a	:CHANnel<n>:PROBe:ID? (see <a href="#">page 359</a> )	<probe id> ::= unquoted ASCII string up to 11 characters  <n> ::= 1 to (# analog channels) in NR1 format
:CHANnel<n>:PROBe:MMO:Del <value> (see <a href="#">page 360</a> )	:CHANnel<n>:PROBe:MMO:Del? (see <a href="#">page 360</a> )	<value> ::= {P5205   P5210   P6205   P6241   P6243   P6245   P6246   P6247   P6248   P6249   P6250   P6251   P670X   P671X   TCP202}  <n> ::= 1 to (# analog channels) in NR1 format
:CHANnel<n>:PROBe:MODE <setting> (see <a href="#">page 361</a> )	:CHANnel<n>:PROBe:MODE? (see <a href="#">page 361</a> )	<n> ::= 1 to (# analog channels) in NR1 format  <setting> ::= {DIFFerential   DOFFset   SEA   SEB   CM}
:CHANnel<n>:PROBe:RSENse <value> (see <a href="#">page 362</a> )	:CHANnel<n>:PROBe:RSENse? (see <a href="#">page 362</a> )	<value> ::= Ohms in NR3 format  <n> ::= 1 to (# analog channels) in NR1 format
:CHANnel<n>:PROBe:SKEW <skew_value> (see <a href="#">page 363</a> )	:CHANnel<n>:PROBe:SKEW? (see <a href="#">page 363</a> )	<skew_value> ::= -100 ns to +100 ns in NR3 format  <n> ::= 1 to (# analog channels) in NR1 format
:CHANnel<n>:PROBe:STYPE <signal type> (see <a href="#">page 364</a> )	:CHANnel<n>:PROBe:STYPE? (see <a href="#">page 364</a> )	<signal type> ::= {DIFFerential   SINGLE}  <n> ::= 1 to (# analog channels) in NR1 format
:CHANnel<n>:PROBe:ZOOM {{0   OFF}   {1   ON}} (see <a href="#">page 365</a> )	:CHANnel<n>:PROBe:ZOOM? (see <a href="#">page 365</a> )	<setting> ::= {0   1}  <n> ::= 1 to (# analog channels) in NR1 format

**Table 7** :CHANnel<n> Commands Summary (continued)

Command	Query	Options and Query Returns
:CHANnel<n>:PROTectio n (see <a href="#">page 366</a> )	:CHANnel<n>:PROTectio n? (see <a href="#">page 366</a> )	{NORM   TRIP} <n> ::= 1 to (# analog channels) in NR1 format
:CHANnel<n>:RANGE <range>[suffix] (see <a href="#">page 367</a> )	:CHANnel<n>:RANGE? (see <a href="#">page 367</a> )	<range> ::= Vertical full-scale range value in NR3 format [suffix] ::= {V   mV} <n> ::= 1 to (# analog channels) in NR1 format
:CHANnel<n>:SCALE <scale>[suffix] (see <a href="#">page 368</a> )	:CHANnel<n>:SCALE? (see <a href="#">page 368</a> )	<scale> ::= Vertical units per division value in NR3 format [suffix] ::= {V   mV} <n> ::= 1 to (# analog channels) in NR1 format
:CHANnel<n>:UNITS <units> (see <a href="#">page 369</a> )	:CHANnel<n>:UNITS? (see <a href="#">page 369</a> )	<units> ::= {VOLT   AMPere} <n> ::= 1 to (# analog channels) in NR1 format
:CHANnel<n>:VERNier { {0   OFF}   {1   ON} } (see <a href="#">page 370</a> )	:CHANnel<n>:VERNier? (see <a href="#">page 370</a> )	{0   1} <n> ::= 1 to (# analog channels) in NR1 format

**Table 8** :COMPliance Commands Summary

Command	Query	Options and Query Returns
:COMPliance:USB:AUTos etup (see <a href="#">page 372</a> )	n/a	n/a
:COMPliance:USB:HUBS <number> (see <a href="#">page 373</a> )	:COMPliance:USB:HUBS? (see <a href="#">page 373</a> )	<number> ::= 0-5 in NR1 format
:COMPliance:USB:RUN (see <a href="#">page 374</a> )	n/a	n/a
:COMPliance:USB:SOURc e:ADJacent <source> (see <a href="#">page 375</a> )	:COMPliance:USB:SOURc e:ADJacent? (see <a href="#">page 375</a> )	<source> ::= {CHANnel<n>}
:COMPliance:USB:SOURc e:DIFFerential <source> (see <a href="#">page 376</a> )	:COMPliance:USB:SOURc e:DIFFerential? (see <a href="#">page 376</a> )	<source> ::= {CHANnel<n>}

**Table 8** :COMPliance Commands Summary (continued)

Command	Query	Options and Query Returns
:COMPliance:USB:SOURce:DMINus <source> (see page 377)	:COMPliance:USB:SOURce:DMINus? (see page 377)	<source> ::= {CHANnel<n>}
:COMPliance:USB:SOURce:DPLus <source> (see page 378)	:COMPliance:USB:SOURce:DPLus? (see page 378)	<source> ::= {CHANnel<n>}
:COMPliance:USB:TEST <test> (see page 379)	:COMPliance:USB:TEST? (see page 379)	<test> ::= {DHSS   HHSS   DLSS   HLSS   DFSS   HFSS}
:COMPliance:USB:TEST:CONNection <connection> (see page 380)	:COMPliance:USB:TEST:CONNection? (see page 380)	<connection> ::= {SINGleended   DIFFerential}
:COMPliance:USB:TEST:TYPE <type> (see page 381)	:COMPliance:USB:TEST:TYPE? (see page 381)	<type> ::= {NEARend   FARend}

**Table 9** :COUNter Commands Summary

Command	Query	Options and Query Returns
n/a	:COUNTER:CURREnt? (see page 385)	<value> ::= current counter value in NR3 format
:COUNTER:ENABLE {{0   OFF}   {1   ON}} (see page 386)	:COUNTER:ENABLE? (see page 386)	{0   1}
:COUNTER:MODE <mode> (see page 387)	:COUNTER:MODE (see page 387)	<mode> ::= {FREQuency   PERiod   TOTalize}
:COUNTER:NDIGits <value> (see page 388)	:COUNTER:NDIGits (see page 388)	<value> ::= 3 to 8 in NR1 format
:COUNTER:SOURce <source> (see page 389)	:COUNTER:SOURce? (see page 389)	<source> ::= {CHANnel<n>   TQEEvent} <n> ::= 1 to (# analog channels) in NR1 format
:COUNTER:TOTalize:CLEar (see page 390)	n/a	n/a
:COUNTER:TOTalize:GATE:ENABLE {{0   OFF}   {1   ON}} (see page 391)	:COUNTER:TOTalize:GATE:ENABLE? (see page 391)	{0   1}

**Table 9** :COUNter Commands Summary (continued)

Command	Query	Options and Query Returns
:COUNTER:TOTalize:GAT E:POLarity <polarity> (see page 392)	:COUNTER:TOTalize:GAT E:POLarity? (see page 392)	<polarity> ::= {{NEGative   FALLing}   {POSitive   RISing}}
:COUNTER:TOTalize:GAT E:SOURce <source> (see page 393)	:COUNTER:TOTalize:GAT E:SOURce? (see page 393)	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:COUNTER:TOTalize:SLO Pe <slope> (see page 394)	:COUNTER:TOTalize:SLO Pe? (see page 394)	<slope> ::= {{NEGative   FALLing}   {POSitive   RISing}}

**Table 10** :DEMO Commands Summary

Command	Query	Options and Query Returns
:DEMO:FUNCTION <signal> (see page 396)	:DEMO:FUNCTION? (see page 399)	<signal> ::= {SINusoid   NOISy   PHASe   RINGing   SINGle   AM   CLK   GLITch   BURSt   MSO   RUNT   TRANSition   RFBURst   SHOLD   LFSine   FMBurst   ETE   NFC   CAN   LIN   UART   I2C   SPI   I2S   CANLin   CXPI   ARINC   FLEXray   MANChester   MIL   MIL2   USB   NMONotonic   DCMotor   HARMonics   COUPLing   CFD   SENT   USBPD   KEYSight}
:DEMO:FUNCTION:PHASE: PHASE <angle> (see page 401)	:DEMO:FUNCTION:PHASE: PHASE? (see page 401)	<angle> ::= angle in degrees from 0 to 360 in NR3 format
:DEMO:OUTPut {{0   OFF}   {1   ON}} (see page 402)	:DEMO:OUTPut? (see page 402)	{0   1}

**Table 11** :DIGItal<d> Commands Summary

Command	Query	Options and Query Returns
:DIGItal<d>:DISPlay { {0   OFF}   {1   ON}} (see page 405)	:DIGItal<d>:DISPlay? (see page 405)	<d> ::= 0 to (# digital channels - 1) in NR1 format {0   1}
:DIGItal<d>:LABel <string> (see page 406)	:DIGItal<d>:LABEL? (see page 406)	<d> ::= 0 to (# digital channels - 1) in NR1 format <string> ::= any series of 10 or less ASCII characters enclosed in quotation marks
:DIGItal<d>:POSIon <position> (see page 407)	:DIGItal<d>:POSITION? (see page 407)	<d> ::= 0 to (# digital channels - 1) in NR1 format <position> ::= 0-7 if display size = large, 0-15 if size = medium, 0-31 if size = small Returns -1 when there is no space to display the digital waveform.
:DIGItal<d>:SIZE <value> (see page 408)	:DIGItal<d>:SIZE? (see page 408)	<d> ::= 0 to (# digital channels - 1) in NR1 format <value> ::= {SMALL   MEDium   LARGe}
:DIGItal<d>:THreshold <value>[suffix] (see page 409)	:DIGItal<d>:THreshold? (see page 409)	<d> ::= 0 to (# digital channels - 1) in NR1 format <value> ::= {CMOS   ECL   TTL   <user defined value>} <user defined value> ::= value in NR3 format from -8.00 to +8.00 [suffix] ::= {V   mV   uV}

**Table 12** :DISPlay Commands Summary

Command	Query	Options and Query Returns
:DISPlay:ANNotatIon<n> { {0   OFF}   {1   ON}} (see page 414)	:DISPlay:ANNotatIon<n>? (see page 414)	{0   1} <n> ::= an integer from 1 to 4 in NR1 format.
:DISPlay:ANNotatIon<n>:BACKground <mode> (see page 415)	:DISPlay:ANNotatIon<n>:BACKground? (see page 415)	<mode> ::= {OPAQue   INVerted   TRANsparent} <n> ::= an integer from 1 to 4 in NR1 format.

**Table 12** :DISPlay Commands Summary (continued)

Command	Query	Options and Query Returns
:DISPlay:ANAnnotation<n>:COLOR <color> (see page 416)	:DISPlay:ANAnnotation<n>:COLOR? (see page 416)	<color> ::= {CH1   CH2   CH3   CH4   DIG   MATH   REF   MARKer   WHITe   RED} <n> ::= an integer from 1 to 4 in NR1 format.
:DISPlay:ANAnnotation<n>:TEXT <string> (see page 417)	:DISPlay:ANAnnotation<n>:TEXT? (see page 417)	<string> ::= quoted ASCII string (up to 254 characters) <n> ::= an integer from 1 to 4 in NR1 format.
:DISPlay:ANAnnotation<n>:X1Position <value> (see page 418)	:DISPlay:ANAnnotation<n>:X1Position? (see page 418)	<value> ::= an integer from 0 to (800 - width of annotation) in NR1 format. <n> ::= an integer from 1 to 4 in NR1 format.
:DISPlay:ANAnnotation<n>:Y1Position <value> (see page 419)	:DISPlay:ANAnnotation<n>:Y1Position? (see page 419)	<value> ::= an integer from 0 to (480 - height of annotation) in NR1 format. <n> ::= an integer from 1 to 4 in NR1 format.
:DISPlay:BACKlight {{0   OFF}   {1   ON}} (see page 420)	n/a	n/a
:DISPlay:CLEar (see page 421)	n/a	n/a
n/a	:DISPlay:DATA? [<format>] [,] [<palette>] (see page 422)	<format> ::= {BMP   BMP8bit   PNG} <palette> ::= {COLOR   GRAYscale} <display data> ::= data in IEEE 488.2 # format
:DISPlay:GRATICULE:ALABels {{0   OFF}   {1   ON}} (see page 424)	:DISPlay:GRATICULE:ALABels? (see page 424)	<setting> ::= {0   1}
:DISPlay:GRATICULE:INTensity <value> (see page 425)	:DISPlay:GRATICULE:INTensity? (see page 425)	<value> ::= an integer from 0 to 100 in NR1 format.
:DISPlay:GRATICULE:TYPE <type> (see page 426)	:DISPlay:GRATICULE:TYPE? (see page 426)	<type> ::= {FULL   MVOLT   IRE}

**Table 12** :DISPlay Commands Summary (continued)

Command	Query	Options and Query Returns
:DISPlay:INTensity:WA Veform <value> (see <a href="#">page 427</a> )	:DISPlay:INTensity:WA Veform? (see <a href="#">page 427</a> )	<value> ::= an integer from 0 to 100 in NR1 format.
:DISPlay:LABel {{0   OFF}   {1   ON}} (see <a href="#">page 428</a> )	:DISPlay:LABel? (see <a href="#">page 428</a> )	{0   1}
:DISPlay:LABList <binary block> (see <a href="#">page 429</a> )	:DISPlay:LABList? (see <a href="#">page 429</a> )	<binary block> ::= an ordered list of up to 75 labels, each 10 characters maximum, separated by newline characters
:DISPlay:MENU <menu> (see <a href="#">page 430</a> )	n/a	<menu> ::= {MASK   MEASure   SEGmented   LISTer   POWER}
:DISPlay:MESSAge:CLEar (see <a href="#">page 431</a> )	n/a	n/a
:DISPlay:PERSistence <value> (see <a href="#">page 432</a> )	:DISPlay:PERSistence? (see <a href="#">page 432</a> )	<value> ::= {MINimum   INFinite   <time>} <time> ::= seconds in in NR3 format from 100E-3 to 60E0
:DISPlay:PERSistence: CLEAR (see <a href="#">page 433</a> )	n/a	n/a
:DISPlay:SIDebar <sidebar> (see <a href="#">page 434</a> )	n/a	<sidebar> ::= {SUMMARY   CURSors   MEASurements   DVM   NAVigate   CONTrols   EVENTS   COUNTER}
:DISPlay:TRANsparent {OFF   ON} (see <a href="#">page 435</a> )	:DISPlay:TRANsparent? (see <a href="#">page 435</a> )	{OFF   ON}
:DISPlay:VECTors {1   ON} (see <a href="#">page 436</a> )	:DISPlay:VECTors? (see <a href="#">page 436</a> )	1

**Table 13** :DVM Commands Summary

Command	Query	Options and Query Returns
:DVM:ARAnge {{0   OFF}   {1   ON}} (see <a href="#">page 438</a> )	:DVM:ARAnge? (see <a href="#">page 438</a> )	{0   1}
n/a	:DVM:CURREnt? (see <a href="#">page 439</a> )	<dvm_value> ::= floating-point number in NR3 format
:DVM:ENABLE {{0   OFF}   {1   ON}} (see <a href="#">page 440</a> )	:DVM:ENABLE? (see <a href="#">page 440</a> )	{0   1}

**Table 13** :DVM Commands Summary (continued)

Command	Query	Options and Query Returns
:DVM:MODE <mode> (see page 441)	:DVM:MODE? (see page 441)	<dvm_mode> ::= {ACRMs   DC   DCRMs}
:DVM:SOURce <source> (see page 442)	:DVM:SOURce? (see page 442)	<source> ::= {CHANnel<n>} <n> ::= 1-2 or 1-4 in NR1 format

**Table 14** :EXTernal Trigger Commands Summary

Command	Query	Options and Query Returns
:EXTernal:BWLImIt <bwlimit> (see page 444)	:EXTernal:BWLImIt? (see page 444)	<bwlimit> ::= {0   OFF}
:EXTernal:PROBe <attenuation> (see page 445)	:EXTernal:PROBe? (see page 445)	<attenuation> ::= probe attenuation ratio in NR3 format
:EXTernal:RANGE <range> [<suffix>] (see page 446)	:EXTernal:RANGE? (see page 446)	<range> ::= vertical full-scale range value in NR3 format <suffix> ::= {V   mV}
:EXTernal:UNITS <units> (see page 447)	:EXTernal:UNITS? (see page 447)	<units> ::= {VOLT   AMPere}

**Table 15** :FFT Commands Summary

Command	Query	Options and Query Returns
:FFT:AVERage:COUNT <count> (see page 451)	:FFT:AVERage:COUNT? (see page 451)	<count> ::= an integer from 2 to 65536 in NR1 format.
:FFT:CENTER <frequency> (see page 452)	:FFT:CENTER? (see page 452)	<frequency> ::= the current center frequency in NR3 format. The range of legal values is from -25 GHz to 25 GHz.
:FFT:CLEar (see page 453)	n/a	n/a
:FFT:DISPlay {{0   OFF}   {1   ON}} (see page 454)	:FFT:DISPlay? (see page 454)	<s> ::= 1-6, in NR1 format. {0   1}
:FFT:DMode <display_mode> (see page 455)	:FFT:DMode? (see page 455)	<display_mode> ::= {NORMAL   AVERAGE   MAXHold   MINHold}

**Table 15** :FFT Commands Summary (continued)

Command	Query	Options and Query Returns
:FFT:FREQuency:STARt <frequency> (see page 457)	:FFT:FREQuency:STARt? (see page 457)	<frequency> ::= the start frequency in NR3 format.
:FFT:FREQuency:STOP <frequency> (see page 458)	:FFT:FREQuency:STOP? (see page 458)	<frequency> ::= the stop frequency in NR3 format.
:FFT:GATE <gating> (see page 459)	:FFT:GATE? (see page 459)	<gating> ::= {NONE   ZOOM}
:FFT:OFFSet <offset> (see page 460)	:FFT:OFFSet? (see page 460)	<offset> ::= the value at center screen in NR3 format.
:FFT:RANGe <range> (see page 461)	:FFT:RANGe? (see page 461)	<range> ::= the full-scale vertical axis value in NR3 format.
:FFT:REFerence <level> (see page 462)	:FFT:REFerence? (see page 462)	<level> ::= the current reference level in NR3 format.
:FFT:SCALe <scale value>[<suffix>] (see page 463)	:FFT:SCALe? (see page 463)	<scale_value> ::= integer in NR1 format. <suffix> ::= dB
:FFT:SOURcel <source> (see page 464)	:FFT:SOURcel? (see page 464)	<source> ::= {CHANnel<n>   FUNCTION<c>   MATH<c>} <n> ::= 1 to (# analog channels) in NR1 format. <c> ::= {1   2}
:FFT:SPAN <span> (see page 465)	:FFT:SPAN? (see page 465)	<span> ::= the current frequency span in NR3 format. Legal values are 1 Hz to 100 GHz.
:FFT:VTYPe <units> (see page 466)	:FFT:VTYPe? (see page 466)	<units> ::= {DECibel   VRMS}
:FFT:WINDOW <>window> (see page 467)	:FFT:WINDOW? (see page 467)	<window> ::= {RECTangular   HANNing   FLATtop   BHARRis   BARTlett}

**Table 16** :FRANalysis Commands Summary

Command	Query	Options and Query Returns
n/a	:FRANalysis:DATA? [SWEep   SINGLE] (see page 471)	<binary_block> ::= comma-separated data with newlines at the end of each row
:FRANalysis:ENABLE { { 0   OFF }   { 1   ON } } (see page 472)	:FRANalysis:ENABLE? (see page 472)	{ 0   1 }
:FRANalysis:FREQuency :MODE <setting> (see page 473)	:FRANalysis:FREQuency :MODE? (see page 473)	<setting> ::= { SWEep   SINGLE }
:FRANalysis:FREQuency :SINGle <value>[suffix] (see page 474)	:FRANalysis:FREQuency :SINGle? (see page 474)	<value> ::= { 20   100   1000   10000   100000   1000000   10000000   2000000 } [suffix] ::= { Hz   kHz   MHz }
:FRANalysis:FREQuency :STARt <value>[suffix] (see page 475)	:FRANalysis:FREQuency :STARt? (see page 475)	<value> ::= { 20   100   1000   10000   100000   1000000   10000000 } [suffix] ::= { Hz   kHz   MHz }
:FRANalysis:FREQuency :STOP <value>[suffix] (see page 476)	:FRANalysis:FREQuency :STOP? (see page 476)	<value> ::= { 100   1000   10000   100000   1000000   10000000 } [suffix] ::= { Hz   kHz   MHz }
:FRANalysis:PPDecade <value> (see page 477)	:FRANalysis:PPDecade? (see page 477)	<value> ::= { 10   20   30   40   50   60   70   80   90   100 }
:FRANalysis:RUN (see page 478)	n/a	n/a
:FRANalysis:SOURce:IN Put <source> (see page 479)	:FRANalysis:SOURce:IN Put? (see page 479)	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:FRANalysis:SOURce:OU TPut <source> (see page 480)	:FRANalysis:SOURce:OU TPut? (see page 480)	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:FRANalysis:TRACe <selection> (see page 481)	:FRANalysis:TRACe? (see page 481)	<selection> ::= { NONE   ALL   GAIN   PHASE } [, { GAIN   PHASE } ]
:FRANalysis:WGEN:LOAD <impedance> (see page 482)	:FRANalysis:WGEN:LOAD ? (see page 482)	<impedance> ::= { ONEMeg   FIFTy }

**Table 16** :FRANalysis Commands Summary (continued)

Command	Query	Options and Query Returns
:FRANalysis:WGEN:VOLTage <amplitude>, [<range>] (see <a href="#">page 483</a> )	:FRANalysis:WGEN:VOLTage? [<range>] (see <a href="#">page 483</a> )	<amplitude> ::= amplitude in volts in NR3 format <range> ::= {F20HZ   F100HZ   F1KHZ   F10KHZ   F100KHZ   F1MHZ   F10MHZ   F20MHZ}
:FRANalysis:WGEN:VOLTage:PROFile {{0   OFF}   {1   ON}} (see <a href="#">page 484</a> )	:FRANalysis:WGEN:VOLTage:PROFile? (see <a href="#">page 484</a> )	{0   1}

**Table 17** :FUNCTION<m> Commands Summary

Command	Query	Options and Query Returns
:FUNCTION<m>:AVERage:COUNT <count> (see <a href="#">page 492</a> )	:FUNCTION<m>:AVERage:COUNT? (see <a href="#">page 492</a> )	<count> ::= an integer from 2 to 65536 in NR1 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:BUS:CLOCK <source> (see <a href="#">page 493</a> )	:FUNCTION<m>:BUS:CLOCK? (see <a href="#">page 493</a> )	<source> ::= {CHANnel<n>   DIGItal<d>} <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:BUS:SLOPe <slope> (see <a href="#">page 494</a> )	:FUNCTION<m>:BUS:SLOPe? (see <a href="#">page 494</a> )	<slope> ::= {NEGative   POSitive   EITHer} <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:BUS:YINC rement <value> (see <a href="#">page 495</a> )	:FUNCTION<m>:BUS:YINC rement? (see <a href="#">page 495</a> )	<value> ::= value per bus code, in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:BUS:YORigin <value> (see <a href="#">page 496</a> )	:FUNCTION<m>:BUS:YORigin? (see <a href="#">page 496</a> )	<value> ::= value at bus code = 0, in NR3 format <m> ::= 1 to (# math functions) in NR1 format

**Table 17** :FUNCTION<m> Commands Summary (continued)

Command	Query	Options and Query Returns
:FUNCTION<m>:BUS:YUNits <units> (see page 497)	:FUNCTION<m>:BUS:YUNits? (see page 497)	<units> ::= {VOLT   AMPere   NONE} <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:CLEAR (see page 498)	n/a	n/a
:FUNCTION<m>:DISPLAY {{0   OFF}   {1   ON}} (see page 499)	:FUNCTION<m>:DISPLAY? (see page 499)	{0   1} <m> ::= 1 to (# math functions) in NR1 format
n/a	:FUNCTION<m>[:FFT]:BSIZE? (see page 500)	<bin_size> ::= Hz in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:CENTER <frequency> (see page 501)	:FUNCTION<m>[:FFT]:CENTER? (see page 501)	<frequency> ::= the current center frequency in NR3 format. The range of legal values is from -25 GHz to 25 GHz. <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:DETECTION:POINTS <number_of_buckets> (see page 502)	:FUNCTION<m>[:FFT]:DETECTION:POINTS? (see page 502)	<number_of_buckets> ::= an integer from 640 to 64K in NR1 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:DETECTION:TYPE <type> (see page 503)	:FUNCTION<m>[:FFT]:DETECTION:TYPE? (see page 503)	<type> ::= {OFF   SAMPLE   PPOSitive   PNENegative   NORMAL   AVERAGE} <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:FREQUENCY:START <frequency> (see page 504)	:FUNCTION<m>[:FFT]:FREQUENCY:START? (see page 504)	<frequency> ::= the start frequency in NR3 format. <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:FREQUENCY:STOP <frequency> (see page 505)	:FUNCTION<m>[:FFT]:FREQUENCY:STOP? (see page 505)	<frequency> ::= the stop frequency in NR3 format. <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:GATE <gating> (see page 506)	:FUNCTION<m>[:FFT]:GATE? (see page 506)	<gating> ::= {NONE   ZOOM} <m> ::= 1-4 in NR1 format

**Table 17** :FUNCTION<m> Commands Summary (continued)

Command	Query	Options and Query Returns
:FUNCTION<m>[:FFT]:PH ASe:REference <ref_point> (see <a href="#">page 507</a> )	:FUNCTION<m>[:FFT]:PH ASe:REference? (see <a href="#">page 507</a> )	<ref_point> ::= {TRIGger   DISPLAY} <m> ::= 1-4 in NR1 format
n/a	:FUNCTION<m>[:FFT]:RB Width? (see <a href="#">page 508</a> )	<resolution_bw> ::= Hz in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:RE ADout<n> <readout_type> (see <a href="#">page 509</a> )	:FUNCTION<m>[:FFT]:RE ADout<n>? (see <a href="#">page 509</a> )	<readout_type> ::= {SRATE   BSIZE   RBWidth} <m> ::= 1 to (# math functions) in NR1 format <n> ::= 1-2 in NR1 format, 2 is for dedicated FFT function
:FUNCTION<m>[:FFT]:SP AN <span> (see <a href="#">page 510</a> )	:FUNCTION<m>[:FFT]:SP AN? (see <a href="#">page 510</a> )	<span> ::= the current frequency span in NR3 format. Legal values are 1 Hz to 100 GHz. <m> ::= 1 to (# math functions) in NR1 format
n/a	:FUNCTION<m>[:FFT]:SR ATe? (see <a href="#">page 511</a> )	<sample_rate> ::= Hz in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:VT YPe <units> (see <a href="#">page 512</a> )	:FUNCTION<m>[:FFT]:VT YPe? (see <a href="#">page 512</a> )	<units> ::= {DECibel   VRMS} for the FFT (magnitude) operation <units> ::= {DEGREes   RADians} for the FFTPhase operation <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:WI NDow <window> (see <a href="#">page 513</a> )	:FUNCTION<m>[:FFT]:WI NDow? (see <a href="#">page 513</a> )	<>window> ::= {RECTangular   HANNing   FLATtop   BHARris   BARTlett} <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:FREQuenc y:BANDpass:CENTER <center_freq> (see <a href="#">page 514</a> )	:FUNCTION<m>:FREQuenc y:BANDpass:CENTER? (see <a href="#">page 514</a> )	<center_freq> ::= center frequency of band-pass filter in NR3 format

**Table 17** :FUNCTION<m> Commands Summary (continued)

Command	Query	Options and Query Returns
:FUNCTION<m>:FREQuency:BANDpass:WIDTh <freq_width> (see page 515)	:FUNCTION<m>:FREQuency:BANDpass:WIDTh? (see <a href="#">page 515</a> )	<freq_width> ::= frequency width of band-pass filter in NR3 format
:FUNCTION<m>:FREQuency:HIGHpass <3dB_freq> (see <a href="#">page 516</a> )	:FUNCTION<m>:FREQuency:HIGHpass? (see <a href="#">page 516</a> )	<3dB_freq> ::= 3dB cutoff frequency value in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:FREQuency:LOWPass <3dB_freq> (see <a href="#">page 517</a> )	:FUNCTION<m>:FREQuency:LOWPass? (see <a href="#">page 517</a> )	<3dB_freq> ::= 3dB cutoff frequency value in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:INTegrat>e:IICondition {{0   OFF}   {1   ON}} (see <a href="#">page 518</a> )	:FUNCTION<m>:INTegrat>e:IICondition? (see <a href="#">page 518</a> )	{0   1} <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:INTegrat>e:IOFFset <input_offset> (see <a href="#">page 519</a> )	:FUNCTION<m>:INTegrat>e:IOFFset? (see <a href="#">page 519</a> )	<input_offset> ::= DC offset correction in NR3 format. <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:LINEar:GAIN <value> (see <a href="#">page 520</a> )	:FUNCTION<m>:LINEar:GAIN? (see <a href="#">page 520</a> )	<value> ::= 'A' in Ax + B, value in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:LINEar:OFFSet <value> (see <a href="#">page 521</a> )	:FUNCTION<m>:LINEar:OFFSet? (see <a href="#">page 521</a> )	<value> ::= 'B' in Ax + B, value in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:OFFSET <offset> (see <a href="#">page 522</a> )	:FUNCTION<m>:OFFSET? (see <a href="#">page 522</a> )	<offset> ::= the value at center screen in NR3 format. The range of legal values is +/-10 times the current sensitivity of the selected function. <m> ::= 1 to (# math functions) in NR1 format

**Table 17** :FUNCTION<m> Commands Summary (continued)

Command	Query	Options and Query Returns
:FUNCTION<m>:OPERation <operation> (see page 523)	:FUNCTION<m>:OPERation? (see page 526)	<p>&lt;operation&gt; ::= {ADD   SUBTract   MULTIPLY   DIVide   INTegrate   DIFF   FFT   FFTPhase   SQRT   MAGNify   ABSolute   SQUare   LN   LOG   EXP   TEN   LOWPass   HIGHpass   BANDpass   AVERage   LINEar   MAXimum   MINimum   PEAK   MAXhold   MINhold   TRENd   BTIMing   BSTate   SERChart}</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p>
:FUNCTION<m>:RANGE <range> (see page 528)	:FUNCTION<m>:RANGE? (see page 528)	<p>&lt;range&gt; ::= the full-scale vertical axis value in NR3 format.</p> <p>The range for ADD, SUBT, MULT is 8E-6 to 800E+3. The range for the INTegrate function is 8E-9 to 400E+3.</p> <p>The range for the DIFF function is 80E-3 to 8.0E12 (depends on current sweep speed).</p> <p>The range for the FFT function is 8 to 800 dBV.</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p>
:FUNCTION<m>:REFERenc e <level> (see page 529)	:FUNCTION<m>:REFERenc e? (see page 529)	<p>&lt;level&gt; ::= the value at center screen in NR3 format.</p> <p>The range of legal values is +/-10 times the current sensitivity of the selected function.</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p>
:FUNCTION<m>:SCALE <scale value>[<suffix>] (see page 530)	:FUNCTION<m>:SCALE? (see page 530)	<p>&lt;scale value&gt; ::= integer in NR1 format</p> <p>&lt;suffix&gt; ::= {V   dB}</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p>

**Table 17** :FUNCTION<m> Commands Summary (continued)

Command	Query	Options and Query Returns
:FUNCTION<m>:SERChart :SOURce <serialbus> (see <a href="#">page 531</a> )	:FUNCTION<m>:SERChart :SOURce? (see <a href="#">page 531</a> )	<m> ::= 1 to (# math functions) in NR1 format <serialbus> ::= {SBUS<n>} <n> ::= 1 to (# of serial bus) in NR1 format
:FUNCTION<m>:SERChart :TIME:MODE <value> (see <a href="#">page 532</a> )	:FUNCTION<m>:SERChart :TIME:MODE? (see <a href="#">page 532</a> )	<m> ::= 1 to (# math functions) in NR1 format <value> ::= {MAIN   ROLL}
:FUNCTION<m>:SERChart :TIME:RANGE <range_value> (see <a href="#">page 534</a> )	:FUNCTION<m>:SERChart :TIME:RANGE? (see <a href="#">page 534</a> )	<m> ::= 1 to (# math functions) in NR1 format <range_value> ::= time value in NR3 format
:FUNCTION<m>:SERChart :TIME:OFFSET <offset> (see <a href="#">page 535</a> )	:FUNCTION<m>:SERChart :TIME:OFFSET? (see <a href="#">page 535</a> )	<m> ::= 1 to (# math functions) in NR1 format <offset> ::= vertical offset value in NR3 format
:FUNCTION<m>:SMOoth:POINTs <points> (see <a href="#">page 536</a> )	:FUNCTION<m>:SMOoth:POINTs? (see <a href="#">page 536</a> )	<points> ::= odd integer in NR1 format
:FUNCTION<m>:SOURcel <source> (see <a href="#">page 537</a> )	:FUNCTION<m>:SOURcel? (see <a href="#">page 537</a> )	<source> ::= {CHANnel<n>   FUNCTION<c>   MATH<c>   WMMemory<r>   BUS<b>} <n> ::= 1 to (# analog channels) in NR1 format <c> ::= {1}, must be lower than <m> <r> ::= 1 to (# ref waveforms) in NR1 format <b> ::= {1   2} <m> ::= 1 to (# math functions) in NR1 format

**Table 17** :FUNCTION<m> Commands Summary (continued)

Command	Query	Options and Query Returns
:FUNCTION<m>:SOURCE2 <source> (see page 539)	:FUNCTION<m>:SOURCE2? (see page 539)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   WMEMory&lt;r&gt;   NONE}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p>
:FUNCTION<m>:TRENd:NM Easurement MEAS<n> (see page 540)	:FUNCTION<m>:TRENd:NM Easurement? (see page 540)	<p>&lt;n&gt; ::= # of installed measurement, from 1 to 8</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p>

**Table 18** :HARDcopy/:HCOPY Commands Summary

Command	Query	Options and Query Returns
:HARDcopy:AREA <area> (see page 544)	:HARDcopy:AREA? (see page 544)	<area> ::= SCReen
:HARDcopy:APRinter <active_printer> (see page 545)	:HARDcopy:APRinter? (see page 545)	<p>&lt;active_printer&gt; ::= {&lt;index&gt;   &lt;name&gt;}</p> <p>&lt;index&gt; ::= integer index of printer in list</p> <p>&lt;name&gt; ::= name of printer in list</p>
:HARDcopy:FACTors {{0   OFF}   {1   ON}} (see page 546)	:HARDcopy:FACTors? (see page 546)	{0   1}
:HARDcopy:FFEed {{0   OFF}   {1   ON}} (see page 547)	:HARDcopy:FFEed? (see page 547)	{0   1}
:HARDcopy:INKSaver { {0   OFF}   {1   ON}} (see page 548)	:HARDcopy:INKSaver? (see page 548)	{0   1}
:HARDcopy:LAYout <layout> (see page 549)	:HARDcopy:LAYout? (see page 549)	<layout> ::= {LANDscape   PORTRait}
:HARDcopy:NETWork:ADD Ress <address> (see page 550)	:HARDcopy:NETWork:ADD Ress? (see page 550)	<address> ::= quoted ASCII string

**Table 18** :HARDcopy/:HCOPY Commands Summary (continued)

Command	Query	Options and Query Returns
:HARDcopy:NETWork:APP Ly (see <a href="#">page 551</a> )	n/a	n/a
:HARDcopy:NETWork:DOM ain <domain> (see <a href="#">page 552</a> )	:HARDcopy:NETWork:DOM ain? (see <a href="#">page 552</a> )	<domain> ::= quoted ASCII string
:HARDcopy:NETWork:PAS Sword <password> (see <a href="#">page 553</a> )	n/a	<password> ::= quoted ASCII string
:HARDcopy:NETWork:SLO T <slot> (see <a href="#">page 554</a> )	:HARDcopy:NETWork:SLO T? (see <a href="#">page 554</a> )	<slot> ::= {NET0   NET1}
:HARDcopy:NETWork:USE Rname <username> (see <a href="#">page 555</a> )	:HARDcopy:NETWork:USE Rname? (see <a href="#">page 555</a> )	<username> ::= quoted ASCII string
:HARDcopy:PAlette <palette> (see <a href="#">page 556</a> )	:HARDcopy:PAlette? (see <a href="#">page 556</a> )	<palette> ::= {COLOR   GRAYscale   NONE}
n/a	:HARDcopy:PRINTER:LIS T? (see <a href="#">page 557</a> )	<list> ::= [<printer_spec>] ... <printer_spec> [<printer_spec>] " <index>,<active>,<name> ;" <index> ::= integer index of printer <active> ::= {Y   N} <name> ::= name of printer
:HARDcopy:STARt (see <a href="#">page 558</a> )	n/a	n/a
n/a	:HCOPY:SDUMp:DATA? (see <a href="#">page 559</a> )	<display_data> ::= binary block data in IEEE-488.2 # format.
:HCOPY:SDUMp:FORMAT <format> (see <a href="#">page 560</a> )	:HCOPY:SDUMp:FORMAT? (see <a href="#">page 560</a> )	<format> ::= {BMP   BMP8bit   PNG}

**Table 19** :LISTer Commands Summary

Command	Query	Options and Query Returns
n/a	:LISTer:DATA? (see <a href="#">page 562</a> )	<binary_block> ::= comma-separated data with newlines at the end of each row
:LISTer:DISPlay {{OFF   0}   {SBUS1   ON   1}   {SBUS2   2}   ALL} (see <a href="#">page 563</a> )	:LISTer:DISPlay? (see <a href="#">page 563</a> )	{OFF   SBUS1   SBUS2   ALL}
:LISTer:REFERENCE <time_ref> (see <a href="#">page 564</a> )	:LISTer:REFERENCE? (see <a href="#">page 564</a> )	<time_ref> ::= {TRIGger   PREVIOUS}

**Table 20** :LTETest Commands Summary

Command	Query	Options and Query Returns
:LTETest:COPY (see <a href="#">page 567</a> )	n/a	n/a
:LTETest:COPY:ALL (see <a href="#">page 568</a> )	n/a	n/a
:LTETest:COPY:MARGIN <percent> (see <a href="#">page 569</a> )	:LTETest:COPY:MARGIN? (see <a href="#">page 569</a> )	<percent> ::= copy margin percent in NR1 format
:LTETest:ENABLE {{0   OFF}   {1   ON}} (see <a href="#">page 570</a> )	:LTETest:ENABLE? (see <a href="#">page 570</a> )	<setting> ::= {0   1}
:LTETest:FAIL <condition> (see <a href="#">page 571</a> )	:LTETest:FAIL? (see <a href="#">page 571</a> )	<condition> ::= {INSIDE   OUTSIDE}
:LTETest:LLIMit <lower_value> (see <a href="#">page 572</a> )	:LTETest:LLIMit? (see <a href="#">page 572</a> )	<lower_value> ::= a real number in NR3 format
:LTETest:MEASurement {MEAS<n>} (see <a href="#">page 573</a> )	:LTETest:MEASurement? (see <a href="#">page 573</a> )	<n> ::= # of installed measurement, from 1 to 10
n/a	:LTETest:RESULTS? [{MEAS<n>}]] (see <a href="#">page 574</a> )	<n> ::= # of installed measurement, from 1 to 10
:LTETest:RUMode:SOFailure {{0   OFF}   {1   ON}} (see <a href="#">page 575</a> )	:LTETest:RUMode:SOFailure? (see <a href="#">page 575</a> )	<setting> ::= {0   1}

**Table 20** :LTEST Commands Summary (continued)

Command	Query	Options and Query Returns
:LTEST:TEST {{0   OFF}   {1   ON}} (see page 576)	:LTEST:TEST? (see page 576)	<setting> ::= {0   1}
:LTEST:ULIMit <upper_value> (see page 577)	:LTEST:ULIMit? (see page 577)	<upper_value> ::= a real number in NR3 format

**Table 21** :MARKer Commands Summary

Command	Query	Options and Query Returns
n/a	:MARKer:DYDX? (see page 582)	<return_value> ::= •Y/•X value in NR3 format
:MARKer:MODE <mode> (see page 583)	:MARKer:MODE? (see page 583)	<mode> ::= {OFF   MEASurement   MANUAL   WAVEform   BINary   HEX}
:MARKer:X1:DISPlay {{0   OFF}   {1   ON}} (see page 584)	:MARKer:X1:DISPLAY? (see page 584)	<setting> ::= {0   1}
:MARKer:X1Position <position>[suffix] (see page 585)	:MARKer:X1Position? (see page 585)	<position> ::= X1 cursor position value in NR3 format [suffix] ::= {s   ms   us   ns   ps   Hz   kHz   MHz} <return_value> ::= X1 cursor position value in NR3 format
:MARKer:X1Y1source <source> (see page 586)	:MARKer:X1Y1source? (see page 586)	<source> ::= {CHANnel<n>   FUNCtion<m>   MATH<m>   WMEMory<r>} <n> ::= 1 to (# analog channels) in NR1 format <m> ::= 1 to (# math functions) in NR1 format <r> ::= 1 to (# ref waveforms) in NR1 format <return_value> ::= <source>
:MARKer:X2:DISPlay {{0   OFF}   {1   ON}} (see page 587)	:MARKer:X2:DISPLAY? (see page 587)	<setting> ::= {0   1}

**Table 21** :MARKer Commands Summary (continued)

Command	Query	Options and Query Returns
:MARKer:X2Position <position>[suffix] (see <a href="#">page 588</a> )	:MARKer:X2Position? (see <a href="#">page 588</a> )	<p>&lt;position&gt; ::= X2 cursor position value in NR3 format</p> <p>[suffix] ::= {s   ms   us   ns   ps   Hz   kHz   MHz}</p> <p>&lt;return_value&gt; ::= X2 cursor position value in NR3 format</p>
:MARKer:X2Y2source <source> (see <a href="#">page 589</a> )	:MARKer:X2Y2source? (see <a href="#">page 589</a> )	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMemory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= &lt;source&gt;</p>
n/a	:MARKer:XDELta? (see <a href="#">page 590</a> )	<return_value> ::= X cursors delta value in NR3 format
:MARKer:XUNits <mode> (see <a href="#">page 591</a> )	:MARKer:XUNits? (see <a href="#">page 591</a> )	<units> ::= {SEConds   HERTz   DEGRees   PERCent}
:MARKer:XUNits:USE (see <a href="#">page 592</a> )	n/a	n/a
:MARKer:Y1:DISPlay { {0   OFF}   {1   ON} } (see <a href="#">page 593</a> )	:MARKer:Y1:DISPLAY? (see <a href="#">page 593</a> )	<setting> ::= {0   1}
:MARKer:Y1Position <position>[suffix] (see <a href="#">page 594</a> )	:MARKer:Y1Position? (see <a href="#">page 594</a> )	<p>&lt;position&gt; ::= Y1 cursor position value in NR3 format</p> <p>[suffix] ::= {V   mV   dB}</p> <p>&lt;return_value&gt; ::= Y1 cursor position value in NR3 format</p>
:MARKer:Y2:DISPlay { {0   OFF}   {1   ON} } (see <a href="#">page 595</a> )	:MARKer:Y2:DISPLAY? (see <a href="#">page 595</a> )	<setting> ::= {0   1}
:MARKer:Y2Position <position>[suffix] (see <a href="#">page 596</a> )	:MARKer:Y2Position? (see <a href="#">page 596</a> )	<p>&lt;position&gt; ::= Y2 cursor position value in NR3 format</p> <p>[suffix] ::= {V   mV   dB}</p> <p>&lt;return_value&gt; ::= Y2 cursor position value in NR3 format</p>

**Table 21** :MARKer Commands Summary (continued)

Command	Query	Options and Query Returns
n/a	:MARKer:YDELta? (see page 597)	<return_value> ::= Y cursors delta value in NR3 format
:MARKer:YUNits <mode> (see page 598)	:MARKer:YUNits? (see page 598)	<units> ::= {BASE   PERCent}
:MARKer:YUNits:USE (see page 599)	n/a	n/a

**Table 22** :MEASure Commands Summary

Command	Query	Options and Query Returns
:MEASure:ALL (see page 622)	n/a	n/a
:MEASure:AREA [<interval>] [,<source>] (see page 623)	:MEASure:AREA? [<interval>] [,<source>] (see page 623)	<p>&lt;interval&gt; ::= {CYCLE   DISPLAY}</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= area in volt-seconds, NR3 format</p>
:MEASure:BRATE [<source>] (see page 624)	:MEASure:BRATE? [<source>] (see page 624)	<p>&lt;source&gt; ::= {&lt;digital channels&gt;   CHANNEL&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMMEMory&lt;r&gt;}</p> <p>&lt;digital channels&gt; ::= DIGItal&lt;d&gt; for the MSO models</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;n&gt; ::= 1 to (# of analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= bit rate in Hz, NR3 format</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:BWIDth [<source>] (see <a href="#">page 625</a> )	:MEASure:BWIDth? [<source>] (see <a href="#">page 625</a> )	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= burst width in seconds, NR3 format</p>
:MEASure:CLEar (see <a href="#">page 626</a> )	n/a	n/a
:MEASure:COUNTER [<source>] (see <a href="#">page 627</a> )	:MEASure:COUNTER? [<source>] (see <a href="#">page 627</a> )	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   EXTernal} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   EXTernal} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= counter frequency in Hertz in NR3 format</p>
:MEASure:DEFine DElAy, <delay spec> (see <a href="#">page 629</a> )	:MEASure:DEFine? DElAy (see <a href="#">page 631</a> )	<p>&lt;delay spec&gt; ::= &lt;edge_spec1&gt;, &lt;edge_spec2&gt;</p> <p>edge_spec1 ::= [&lt;slope&gt;]&lt;occurrence&gt;</p> <p>edge_spec2 ::= [&lt;slope&gt;]&lt;occurrence&gt;</p> <p>&lt;slope&gt; ::= {+   -}</p> <p>&lt;occurrence&gt; ::= integer</p>
:MEASure:DEFine THReSholds, <threshold spec> (see <a href="#">page 629</a> )	:MEASure:DEFine? THReSholds (see <a href="#">page 631</a> )	<p>&lt;threshold spec&gt; ::= {STANDARD}   {&lt;threshold mode&gt;, &lt;upper&gt;, &lt;middle&gt;, &lt;lower&gt;}</p> <p>&lt;threshold mode&gt; ::= {PERCent   ABSolute}</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:DELay [<source1>] [,<source2>] (see <a href="#">page 632</a> )	:MEASure:DELay? [<source1>] [,<source2>] (see <a href="#">page 632</a> )	<p>&lt;source1,2&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;   &lt;digital channels&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;digital channels&gt; ::= DIGItal&lt;d&gt; for the MSO models</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= floating-point number delay time in seconds in NR3 format</p>
:MEASure:DELay:DEFine <source1_edge_slope>, <source1_edge_number> ,<source1_edge_threshold>, <source2_edge_slope>, <source2_edge_number> ,<source2_edge_threshold> (see <a href="#">page 634</a> )	:MEASure:DELay:DEFine ? (see <a href="#">page 634</a> )	<p>&lt;source1_edge_slope&gt;, &lt;source2_edge_slope&gt; ::= {RISing   FALLing}</p> <p>&lt;source1_edge_number&gt;, &lt;source2_edge_number&gt; ::= 0 to 1000 in NR1 format</p> <p>&lt;source1_edge_threshold&gt;, &lt;source2_edge_threshold&gt; ::= {LOWer   MIDDLE   UPPer}</p>
:MEASure:DUAL:CHARge [<interval>] [,<source1>] [,<source2>] (see <a href="#">page 635</a> )	:MEASure:DUAL:CHARge? [<interval>] [,<source1>] [,<source2>] (see <a href="#">page 635</a> )	<p>&lt;interval&gt; ::= {CYCLE   DISPLAY}</p> <p>&lt;source1&gt;, &lt;source2&gt; ::= CHANnel&lt;n&gt; with N2820A probe connected}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;return_value&gt; ::= area in Amp-hours, NR3 format</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:DUAL:VAMplitude [ <source1>] [,&lt;source2&gt;] (see <a href="#">page 636</a>)</source1>	:MEASure:DUAL:VAMplitude? [ <source1>] [,&lt;source2&gt;] (see <a href="#">page 636</a>)</source1>	<source1>, <source2> ::= CHANnel<n> with N2820A probe connected <n> ::= 1 to (# analog channels) in NR1 format <return_value> ::= the amplitude of the selected waveform in volts in NR3 format
:MEASure:DUAL:VAVerage [<interval>] [,<source1>] [,<source2>] (see <a href="#">page 637</a> )	:MEASure:DUAL:VAVerage? [<interval>] [,<source1>] [,<source2>] (see <a href="#">page 637</a> )	<interval> ::= {CYCLE   DISPLAY} <source1>, <source2> ::= CHANnel<n> with N2820A probe connected <n> ::= 1 to (# analog channels) in NR1 format <return_value> ::= calculated average voltage in NR3 format
:MEASure:DUAL:VBASe [ <source1>] [,&lt;source2&gt;] (see <a href="#">page 638</a>)</source1>	:MEASure:DUAL:VBASe? [ <source1>] [,&lt;source2&gt;] (see <a href="#">page 638</a>)</source1>	<source1>, <source2> ::= CHANnel<n> with N2820A probe connected <n> ::= 1 to (# analog channels) in NR1 format <base_voltage> ::= voltage at the base of the selected waveform in NR3 format
:MEASure:DUAL:VPP [ <source1>] [,&lt;source2&gt;] (see <a href="#">page 639</a>)</source1>	:MEASure:DUAL:VPP? [ <source1>] [,&lt;source2&gt;] (see <a href="#">page 639</a>)</source1>	<source1>, <source2> ::= CHANnel<n> with N2820A probe connected <n> ::= 1 to (# analog channels) in NR1 format <return_value> ::= voltage peak-to-peak of the selected waveform in NR3 format
:MEASure:DUAL:VRMS [<interval>] [,<type>] [,<source1>] [,<source2>] (see <a href="#">page 640</a> )	:MEASure:DUAL:VRMS? [<interval>] [,<type>] [,<source1>] [,<source2>] (see <a href="#">page 640</a> )	<interval> ::= {CYCLE   DISPLAY} <type> ::= {AC   DC} <source1>, <source2> ::= CHANnel<n> with N2820A probe connected <n> ::= 1 to (# analog channels) in NR1 format <return_value> ::= calculated RMS voltage in NR3 format

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:DUTYcycle [<source>] (see page 641)	:MEASure:DUTYcycle? [<source>] (see page 641)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= ratio of positive pulse width to period in NR3 format</p>
:MEASure:FALLtime [<source>] (see page 642)	:MEASure:FALLtime? [<source>] (see page 642)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= time in seconds between the lower and upper thresholds in NR3 format</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:FFT:ACPR <chan_width>, <chan_spacing>, <chan>[,<source>] (see <a href="#">page 643</a> )	:MEASure:FFT:ACPR? <chan_width>, <chan_spacing>, <chan>[,<source>] (see <a href="#">page 643</a> )	<p>&lt;chan_width&gt; ::= width of main range and sideband channels, Hz in NR3 format</p> <p>&lt;chan_spacing&gt; ::= spacing between main range and sideband channels, Hz in NR3 format</p> <p>&lt;chan&gt; ::= {CENTer   HIGH&lt;sb&gt;   LOW&lt;sb&gt;}</p> <p>&lt;sb&gt; ::= sideband 1 to 5</p> <p>&lt;source&gt; ::= {FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT} (source must be an FFT waveform)</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;return_value&gt; ::= adjacent channel power ratio, dBV in NR3 format</p>
:MEASure:FFT:CPOWER [<source>] (see <a href="#">page 644</a> )	:MEASure:FFT:CPOWER? [<source>] (see <a href="#">page 644</a> )	<p>&lt;source&gt; ::= {FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT} (source must be an FFT waveform)</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;return_value&gt; ::= spectral channel power, dBV in NR3 format</p>
:MEASure:FFT:OBW <percentage>[,<source>] (see <a href="#">page 645</a> )	:MEASure:FFT:OBW? <percentage>[,<source>] (see <a href="#">page 645</a> )	<p>&lt;percentage&gt; ::= percent of spectral power occupied bandwidth is measured for in NR3 format</p> <p>&lt;source&gt; ::= {FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT} (source must be an FFT waveform)</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;return_value&gt; ::= occupied bandwidth, Hz in NR3 format</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:FFT:THD [<source>] (see page 646)	:MEASure:FFT:THD? [<source>] (see page 646)	<p>&lt;source&gt; ::= {FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT} (source must be an FFT waveform)</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;return_value&gt; ::= total harmonic distortion ratio percent in NR3 format</p>
:MEASure:FREQuency [<source>] (see page 647)	:MEASure:FREQuency? [<source>] (see page 647)	<p>&lt;source&gt; ::= {CHANNEL&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMORY&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANNEL&lt;n&gt;   DIGITAL&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMORY&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= frequency in Hertz in NR3 format</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:NDUTy [<source>] (see page 648)	:MEASure:NDUTy? [<source>] (see page 648)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= ratio of negative pulse width to period in NR3 format</p>
:MEASure:NEDGes [<source>] (see page 649)	:MEASure:NEDGes? [<source>] (see page 649)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the falling edge count in NR3 format</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:NPULses [<source>] (see page 650)	:MEASure:NPULses? [<source>] (see page 650)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;   &lt;digital channels&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;digital channels&gt; ::= DIGItal&lt;d&gt; for the MSO models</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= the falling pulse count in NR3 format</p>
:MEASure:NWIDth [<source>] (see page 651)	:MEASure:NWIDth? [<source>] (see page 651)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= negative pulse width in seconds-NR3 format</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:OVERshoot [<source>] (see page 652)	:MEASure:OVERshoot? [<source>] (see page 652)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the percent of the overshoot of the selected waveform in NR3 format</p>
:MEASure:PEDGes [<source>] (see page 654)	:MEASure:PEDGes? [<source>] (see page 654)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the rising edge count in NR3 format</p>
:MEASure:PERiod [<source>] (see page 655)	:MEASure:PERiod? [<source>] (see page 655)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= waveform period in seconds in NR3 format</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:PHASE [<source1>] [,<source2>] (see <a href="#">page 656</a> )	:MEASure:PHASE? [<source1>] [,<source2>] (see <a href="#">page 656</a> )	<p>&lt;source1,2&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the phase angle value in degrees in NR3 format</p>
:MEASure:PPULses [<source>] (see <a href="#">page 657</a> )	:MEASure:PPULses? [<source>] (see <a href="#">page 657</a> )	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;   &lt;digital channels&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;digital channels&gt; ::= DIGItal&lt;d&gt; for the MSO models</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= the rising pulse count in NR3 format</p>
:MEASure:PREShoot [<source>] (see <a href="#">page 658</a> )	:MEASure:PREShoot? [<source>] (see <a href="#">page 658</a> )	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the percent of preshoot of the selected waveform in NR3 format</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:PWIDth [<source>] (see page 659)	:MEASure:PWIDth? [<source>] (see page 659)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= width of positive pulse in seconds in NR3 format</p>
n/a	:MEASure:RESults? <result_list> (see page 660)	<result_list> ::= comma-separated list of measurement results
:MEASure:RISetime [<source>] (see page 663)	:MEASure:RISetime? [<source>] (see page 663)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= rise time in seconds in NR3 format</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:SDEViation [ <source/> ] (see page 664)	:MEASure:SDEViation? [ <source/> ] (see page 664)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= calculated std deviation in NR3 format</p>
:MEASure:SHOW {{0   OFF}   {1   ON}} (see page 665)	:MEASure:SHOW? (see page 665)	{0   1}
:MEASure:SLEWrate [ <source/> [,<slope>]] (see page 666)	:MEASure:SLEWrate? [ <source/> [,<slope>]] (see page 666)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# of analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p>
:MEASure:SOURce <source1> [,<source2>] (see page 667)	:MEASure:SOURce? (see page 667)	<p>&lt;source1,2&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;   EXTERNAL} for DSO models</p> <p>&lt;source1,2&gt; ::= {CHANnel&lt;n&gt;   DIGITAL&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMORY&lt;r&gt;   EXTERNAL} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= {&lt;source&gt;   NONE}</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:STATistics <type> (see <a href="#">page 669</a> )	:MEASure:STATistics? (see <a href="#">page 669</a> )	<type> ::= {{ON   1}   CURRent   MEAN   MINimum   MAXimum   STDDev   COUNT} ON ::= all statistics returned
:MEASure:STATistics:D ISPlay {{0   OFF}   {1   ON}} (see <a href="#">page 670</a> )	:MEASure:STATistics:D ISPlay? (see <a href="#">page 670</a> )	{0   1}
:MEASure:STATistics:I NCREMENT (see <a href="#">page 671</a> )	n/a	n/a
:MEASure:STATistics:M COunt <setting> (see <a href="#">page 672</a> )	:MEASure:STATistics:M COunt? (see <a href="#">page 672</a> )	<setting> ::= {INFinite   <count>} <count> ::= 2 to 2000 in NR1 format
:MEASure:STATistics:R ESet (see <a href="#">page 673</a> )	n/a	n/a
:MEASure:STATistics:R SDeviation {{0   OFF}   {1   ON}} (see <a href="#">page 674</a> )	:MEASure:STATistics:R SDeviation? (see <a href="#">page 674</a> )	{0   1}

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:TEDGE [<slope>,<occurrence>] >[,<source>] (see <a href="#">page 675</a> )	:MEASure:TEDGE? [<slope>,<occurrence>] >[,<source>] (see <a href="#">page 676</a> )	<p>&lt;slope&gt; ::= {RISing   FALLing   EITHer}</p> <p>&lt;occurrence&gt; ::= [+   -]&lt;number&gt;</p> <p>&lt;number&gt; ::= the edge number in NR1 format</p> <p>&lt;source&gt; ::= {&lt;digital channels&gt;   CHANNEL&lt;n&gt;   FUNCTion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;digital channels&gt; ::= DIGItal&lt;d&gt; for the MSO models</p> <p>&lt;n&gt; ::= 1 to (# of analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= time in seconds of the specified transition</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
n/a	:MEASure:TValue? <value>, [<>slope>]<occurrence> [, <source>] (see page 678)	<p>&lt;value&gt; ::= voltage level that the waveform must cross.</p> <p>&lt;slope&gt; ::= direction of the waveform when &lt;value&gt; is crossed.</p> <p>&lt;occurrence&gt; ::= transitions reported.</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= time in seconds of specified voltage crossing in NR3 format</p>
:MEASure:VAMplitude [<source>] (see page 680)	:MEASure:VAMplitude? [<source>] (see page 680)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the amplitude of the selected waveform in volts in NR3 format</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:VAverage [<interval>] [,<source>] (see page 681)	:MEASure:VAverage? [<interval>] [,<source>] (see page 681)	<p>&lt;interval&gt; ::= {CYCLE   DISPLAY}</p> <p>&lt;source&gt; ::= {CHANNEL&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT   WMEMORY&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= calculated average voltage in NR3 format</p>
:MEASure:VBASE [<source>] (see page 682)	:MEASure:VBASE? [<source>] (see page 682)	<p>&lt;source&gt; ::= {CHANNEL&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMORY&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;base_voltage&gt; ::= voltage at the base of the selected waveform in NR3 format</p>
:MEASure:VMAX [<source>] (see page 683)	:MEASure:VMAX? [<source>] (see page 683)	<p>&lt;source&gt; ::= {CHANNEL&lt;n&gt;   FUNCTION&lt;m&gt;   FFT   MATH&lt;m&gt;   WMEMORY&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= maximum voltage of the selected waveform in NR3 format</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:VMIN [<source>] (see page 684)	:MEASure:VMIN? [<source>] (see page 684)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   FFT   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= minimum voltage of the selected waveform in NR3 format</p>
:MEASure:VPP [<source>] (see page 685)	:MEASure:VPP? [<source>] (see page 685)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   FFT   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= voltage peak-to-peak of the selected waveform in NR3 format</p>
:MEASure:VRATio [<interval>] [, <source1>] [, <source2>] (see page 686)	:MEASure:VRATio? [<interval>] [, <source1>] [, <source2>] (see page 686)	<p>&lt;interval&gt; ::= {CYCLE   DISPLAY}</p> <p>&lt;source1,2&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the ratio value in dB in NR3 format</p>

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:VRMS [<interval>] [,<type>] [,<source>] (see <a href="#">page 687</a> )	:MEASure:VRMS? [<interval>] [,<type>] [,<source>] (see <a href="#">page 687</a> )	<interval> ::= {CYCLE   DISPLAY} <type> ::= {AC   DC} <source> ::= {CHANnel<n>   FUNCTION<m>   MATH<m>   WMEMORY<r>} <n> ::= 1 to (# analog channels) in NR1 format <m> ::= 1 to (# math functions) in NR1 format <r> ::= 1 to (# ref waveforms) in NR1 format <return_value> ::= calculated dc RMS voltage in NR3 format
:MEASure:VTOP [<source>] (see <a href="#">page 688</a> )	:MEASure:VTOP? [<source>] (see <a href="#">page 688</a> )	<source> ::= {CHANnel<n>   FUNCTION<m>   MATH<m>   WMEMORY<r>} <n> ::= 1 to (# analog channels) in NR1 format <m> ::= 1 to (# math functions) in NR1 format <r> ::= 1 to (# ref waveforms) in NR1 format <return_value> ::= voltage at the top of the waveform in NR3 format
:MEASure:WINDOW <type> (see <a href="#">page 689</a> )	:MEASure:WINDOW? (see <a href="#">page 689</a> )	<type> ::= {MAIN   ZOOM   AUTO   GATE}
:MEASure:XMAX [<source>] (see <a href="#">page 690</a> )	:MEASure:XMAX? [<source>] (see <a href="#">page 690</a> )	<source> ::= {CHANnel<n>   FUNCTION<m>   FFT   MATH<m>   WMEMORY<r>} <n> ::= 1 to (# analog channels) in NR1 format <m> ::= 1 to (# math functions) in NR1 format <r> ::= 1 to (# ref waveforms) in NR1 format <return_value> ::= horizontal value of the maximum in NR3 format

**Table 22** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:XMIN [<source>] (see page 691)	:MEASure:XMIN? [<source>] (see page 691)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   FFT   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= horizontal value of the minimum in NR3 format</p>
:MEASure:YATX <horiz_location>[,<source>] (see page 692)	:MEASure:YATX? <horiz_location>[,<source>] (see page 692)	<p>&lt;horiz_location&gt; ::= displayed time from trigger in seconds in NR3 format</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= voltage at the specified time in NR3 format</p>

**Table 23** :MEASure Power Commands Summary

Command	Query	Options and Query Returns
:MEASure:ANGLE [<source1>] [,<source2>] (see <a href="#">page 698</a> )	:MEASure:ANGLE? [<source1>] [,<source2>] (see <a href="#">page 698</a> )	<source1>, <source2> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format  <return_value> ::= the power phase angle in degrees in NR3 format
:MEASure:APPARENT [<source1>] [,<source2>] (see <a href="#">page 699</a> )	:MEASure:APPARENT? [<source1>] [,<source2>] (see <a href="#">page 699</a> )	<source1>, <source2> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format  <return_value> ::= the apparent power value in NR3 format
:MEASure:CPLoss [<source1>] [,<source2>] (see <a href="#">page 700</a> )	:MEASure:CPLoss? [<source1>] [,<source2>] (see <a href="#">page 700</a> )	<source1>, <source2> <source1> ::= {FUNCTION<m>   MATH<m>}  <source2> ::= {CHANnel<n>} <m> ::= 1 to (# math functions) in NR1 format  <n> ::= 1 to (# analog channels) in NR1 format  <return_value> ::= the switching loss per cycle watts value in NR3 format
:MEASure:CREST [<source>] (see <a href="#">page 701</a> )	:MEASure:CREST? [<source>] (see <a href="#">page 701</a> )	<source> ::= {CHANnel<n>   FUNCTION<m>   MATH<m>} <n> ::= 1 to (# analog channels) in NR1 format  <m> ::= 1 to (# math functions) in NR1 format  <return_value> ::= the crest factor value in NR3 format
:MEASure:EFFiciency (see <a href="#">page 702</a> )	:MEASure:EFFiciency? (see <a href="#">page 702</a> )	<return_value> ::= percent value in NR3 format

**Table 23** :MEASure Power Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:ELOSS [<source>] (see page 703)	:MEASure:ELOSS? [<source>] (see page 703)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the energy loss value in NR3 format</p>
:MEASure:FACTOr [<source1> [, <source2>] (see page 704)	:MEASure:FACTOr? [<source1> [, <source2>] (see page 704)	<p>&lt;source1&gt;, &lt;source2&gt; ::= {CHANnel&lt;n&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;return_value&gt; ::= the power factor value in NR3 format</p>
:MEASure:IPOWer (see page 705)	:MEASure:IPOWer? (see page 705)	<return_value> ::= the input power value in NR3 format
:MEASure:OFFTime [<source1> [, <source2>] (see page 706)	:MEASure:OFFTime? [<source1> [, <source2>] (see page 706)	<p>&lt;source1&gt;, &lt;source2&gt; ::= {CHANnel&lt;n&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;return_value&gt; ::= the time in seconds in NR3 format</p>
:MEASure:ONTime [<source1> [, <source2>] (see page 707)	:MEASure:ONTIME? [<source1> [, <source2>] (see page 707)	<p>&lt;source1&gt;, &lt;source2&gt; ::= {CHANnel&lt;n&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;return_value&gt; ::= the time in seconds in NR3 format</p>
:MEASure:OPOWer (see page 708)	:MEASure:OPOWer? (see page 708)	<return_value> ::= the output power value in NR3 format

**Table 23** :MEASure Power Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:PCURrent [<source>] (see <a href="#">page 709</a> )	:MEASure:PCURrent? [<source>] (see <a href="#">page 709</a> )	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the peak current value in NR3 format</p>
:MEASure:PLOSS [<source>] (see <a href="#">page 710</a> )	:MEASure:PLOSS? [<source>] (see <a href="#">page 710</a> )	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the power loss value in NR3 format</p>
:MEASure:RDSon [<source1>[,<source2>] (see <a href="#">page 711</a> )	:MEASure:RDSon? [<source1>[,<source2>] (see <a href="#">page 711</a> )	<p>&lt;source1&gt;, &lt;source2&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the Rds(on) value in NR3 format</p>
:MEASure:REACTive [<source1>[,<source2>] (see <a href="#">page 712</a> )	:MEASure:REACTive? [<source1>[,<source2>] (see <a href="#">page 712</a> )	<p>&lt;source1&gt;, &lt;source2&gt; ::= {CHANnel&lt;n&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;return_value&gt; ::= the reactive power value in NR3 format</p>

**Table 23** :MEASure Power Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:REAL [<source>] (see page 713)	:MEASure:REAL? [<source>] (see page 713)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;return_value&gt; ::= the real power value in NR3 format</p>
:MEASure:RIPPLE [<source>] (see page 714)	:MEASure:RIPPLE? [<source>] (see page 714)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the output ripple value in NR3 format</p>

**Table 23** :MEASure Power Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:TRESPonse [<source>] (see page 715)	:MEASure:TRESPonse? [<source>] (see page 715)	<pre>&lt;source&gt; ::= {CHANnel&lt;n&gt;  FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}  &lt;n&gt; ::= 1 to (# analog channels) in NR1 format  &lt;m&gt; ::= 1 to (# math functions) in NR1 format  &lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format  &lt;return_value&gt; ::= time in seconds for the overshoot to settle back into the band in NR3 format</pre>
:MEASure:VCESat [<source>] (see page 716)	:MEASure:VCESat? [<source>] (see page 716)	<pre>&lt;source&gt; ::= {CHANnel&lt;n&gt;  FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}  &lt;n&gt; ::= 1 to (# analog channels) in NR1 format  &lt;m&gt; ::= 1 to (# math functions) in NR1 format  &lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format  &lt;return_value&gt; ::= the Vce(sat) value in NR3 format</pre>

**Table 24** :MTEST Commands Summary

Command	Query	Options and Query Returns
:MTEST:ALL {{0   OFF}   {1   ON}} (see page 722)	:MTEST:ALL? (see page 722)	{0   1}
:MTEST:AMASK:CREate (see page 723)	n/a	n/a
:MTEST:AMASK:SOURce <source> (see page 724)	:MTEST:AMASK:SOURce? (see page 724)	<pre>&lt;source&gt; ::= CHANnel&lt;n&gt; &lt;n&gt; ::= {1   2   3   4} for 4ch models  &lt;n&gt; ::= {1   2} for 2ch models</pre>
:MTEST:AMASK:UNITS <units> (see page 725)	:MTEST:AMASK:UNITS? (see page 725)	<units> ::= {CURRent   DIVisions}

**Table 24** :MTEST Commands Summary (continued)

Command	Query	Options and Query Returns
:MTEST:AMASK:XDELta <value> (see page 726)	:MTEST:AMASK:XDELta? (see page 726)	<value> ::= X delta value in NR3 format
:MTEST:AMASK:YDELta <value> (see page 727)	:MTEST:AMASK:YDELta? (see page 727)	<value> ::= Y delta value in NR3 format
n/a	:MTEST:COUNT:FWAVefor ms? [CHANnel<n>] (see page 728)	<failed> ::= number of failed waveforms in NR1 format
:MTEST:COUNT:RESet (see page 729)	n/a	n/a
n/a	:MTEST:COUNT:TIME? (see page 730)	<time> ::= elapsed seconds in NR3 format
n/a	:MTEST:COUNT:WAVEfor ms? (see page 731)	<count> ::= number of waveforms in NR1 format
:MTEST:DATA <mask> (see page 732)	:MTEST:DATA? (see page 732)	<mask> ::= data in IEEE 488.2 # format.
:MTEST:DELETE (see page 733)	n/a	n/a
:MTEST:ENABLE {{0   OFF}   {1   ON}} (see page 734)	:MTEST:ENABLE? (see page 734)	{0   1}
:MTEST:LOCK {{0   OFF}   {1   ON}} (see page 735)	:MTEST:LOCK? (see page 735)	{0   1}
:MTEST:RMODE <rmode> (see page 736)	:MTEST:RMODE? (see page 736)	<rmode> ::= {FORever   TIME   SIGMa   WAVEforms}
:MTEST:RMODE:FACTion: MEASure {{0   OFF}   {1   ON}} (see page 737)	:MTEST:RMODE:FACTion: MEASure? (see page 737)	{0   1}
:MTEST:RMODE:FACTion: PRINT {{0   OFF}   {1   ON}} (see page 738)	:MTEST:RMODE:FACTion: PRINT? (see page 738)	{0   1}
:MTEST:RMODE:FACTion: SAVE {{0   OFF}   {1   ON}} (see page 739)	:MTEST:RMODE:FACTion: SAVE? (see page 739)	{0   1}
:MTEST:RMODE:FACTion: STOP {{0   OFF}   {1   ON}} (see page 740)	:MTEST:RMODE:FACTion: STOP? (see page 740)	{0   1}

**Table 24** :MTEST Commands Summary (continued)

Command	Query	Options and Query Returns
:MTEST:RMODE:SIGMa <level> (see <a href="#">page 741</a> )	:MTEST:RMODE:SIGMa? (see <a href="#">page 741</a> )	<level> ::= from 0.1 to 9.3 in NR3 format
:MTEST:RMODE:TIME <seconds> (see <a href="#">page 742</a> )	:MTEST:RMODE:TIME? (see <a href="#">page 742</a> )	<seconds> ::= from 1 to 86400 in NR3 format
:MTEST:RMODE:WAVEform s <count> (see <a href="#">page 743</a> )	:MTEST:RMODE:WAVEform s? (see <a href="#">page 743</a> )	<count> ::= number of waveforms in NR1 format
:MTEST:SCALe:BIND {{0   OFF}   {1   ON}} (see <a href="#">page 744</a> )	:MTEST:SCALe:BIND? (see <a href="#">page 744</a> )	{0   1}
:MTEST:SCALe:X1 <x1_value> (see <a href="#">page 745</a> )	:MTEST:SCALe:X1? (see <a href="#">page 745</a> )	<x1_value> ::= X1 value in NR3 format
:MTEST:SCALe:XDELta <xdelta_value> (see <a href="#">page 746</a> )	:MTEST:SCALe:XDELta? (see <a href="#">page 746</a> )	<xdelta_value> ::= X delta value in NR3 format
:MTEST:SCALe:Y1 <y1_value> (see <a href="#">page 747</a> )	:MTEST:SCALe:Y1? (see <a href="#">page 747</a> )	<y1_value> ::= Y1 value in NR3 format
:MTEST:SCALe:Y2 <y2_value> (see <a href="#">page 748</a> )	:MTEST:SCALe:Y2? (see <a href="#">page 748</a> )	<y2_value> ::= Y2 value in NR3 format
:MTEST:SOURce <source> (see <a href="#">page 749</a> )	:MTEST:SOURce? (see <a href="#">page 749</a> )	<source> ::= {CHANnel<n>   NONE} <n> ::= {1   2   3   4} for 4ch models <n> ::= {1   2} for 2ch models
n/a	:MTEST:TITLe? (see <a href="#">page 750</a> )	<title> ::= a string of up to 128 ASCII characters

**Table 25** :POD<n> Commands Summary

Command	Query	Options and Query Returns
:POD<n>:DISPlay {{0   OFF}   {1   ON}} (see <a href="#">page 753</a> )	:POD<n>:DISPlay? (see <a href="#">page 753</a> )	{0   1} <n> ::= 1-2 in NR1 format

**Table 25** :POD<n> Commands Summary (continued)

Command	Query	Options and Query Returns
:POD<n>:SIZE <value> (see <a href="#">page 754</a> )	:POD<n>:SIZE? (see <a href="#">page 754</a> )	<value> ::= {SMALL   MEDIUM   LARGe}
:POD<n>:THreshold <type>[suffix] (see <a href="#">page 755</a> )	:POD<n>:THreshold? (see <a href="#">page 755</a> )	<n> ::= 1-2 in NR1 format <type> ::= {CMOS   ECL   TTL   <user defined value>} <user defined value> ::= value in NR3 format [suffix] ::= {V   mV   uV }

**Table 26** :POWer Commands Summary

Command	Query	Options and Query Returns
n/a	:POWer:CLResponse? (see <a href="#">page 765</a> )	n/a
:POWer:CLResponse:APP Ly (see <a href="#">page 766</a> )	n/a	n/a
n/a	:POWer:CLResponse:DAT A? [SWEep   SINGle] (see <a href="#">page 767</a> )	<binary_block> ::= comma-separated data with newlines at the end of each row
n/a	:POWer:CLResponse:DAT A:GMARgin? (see <a href="#">page 768</a> )	<gain_margin> ::= gain margin in dB in NR3 format.
n/a	:POWer:CLResponse:DAT A:GMARgin:FREQuency? (see <a href="#">page 769</a> )	<frequency> ::= 0 degrees phase crossover frequency in Hz in NR3 format
n/a	:POWer:CLResponse:DAT A:PMARgin? (see <a href="#">page 770</a> )	<phase_margin> ::= phase margin in degrees in NR3 format.
n/a	:POWer:CLResponse:DAT A:PMARgin:FREQuency? (see <a href="#">page 771</a> )	<frequency> ::= 0dB gain crossover frequency in Hz in NR3 format.
:POWer:CLResponse:FRE Quency:MODE <mode> (see <a href="#">page 772</a> )	:POWer:CLResponse:FRE Quency:MODE? (see <a href="#">page 772</a> )	<mode> ::= {SWEep   SINGle}
:POWer:CLResponse:FRE Quency:SINGle <value>[suffix] (see <a href="#">page 773</a> )	:POWer:CLResponse:FRE Quency:SINGle? (see <a href="#">page 773</a> )	<value> ::= {20   100   1000   10000   100000   1000000   10000000   2000000} [suffix] ::= {Hz   kHz   MHz}

**Table 26** :POWer Commands Summary (continued)

Command	Query	Options and Query Returns
:POWer:CLResponse:FREQuency:STARt <value>[suffix] (see page 774)	:POWer:CLResponse:FREQuency:STARt? (see page 774)	<value> ::= {20   100   1000   10000   100000   1000000   10000000} [suffix] ::= {Hz   kHz  MHz}
:POWer:CLResponse:FREQuency:STOP <value>[suffix] (see page 775)	:POWer:CLResponse:FREQuency:STOP? (see page 775)	<value> ::= {100   1000   10000   100000   1000000   10000000   20000000} [suffix] ::= {Hz   kHz  MHz}
:POWer:CLResponse:PPDecade <pts> (see page 776)	:POWer:CLResponse:PPDecade? (see page 776)	<pts> ::= {10   20   30   40   50   60   70   80   90   100}
:POWer:CLResponse:SOURce:INPUT <source> (see page 777)	:POWer:CLResponse:SOURce:INPUT? (see page 777)	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:POWer:CLResponse:SOURce:OUTPUT <source> (see page 778)	:POWer:CLResponse:SOURce:OUTPUT? (see page 778)	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:POWer:CLResponse:TRACe <selection> (see page 779)	:POWer:CLResponse:TRACe? (see page 779)	<selection> ::= {NONE   ALL   GAIN   PHASE} [, {GAIN   PHASE}]
:POWer:CLResponse:WGEN:LOAD <impedance> (see page 780)	:POWer:CLResponse:WGEN:LOAD? (see page 780)	<impedance> ::= {ONEMeg   FIFTy}
:POWer:CLResponse:WGEN:VOLTage <amplitude>[,<range>] (see page 781)	:POWer:CLResponse:WGEN:VOLTage? [<range>] (see page 781)	<amplitude> ::= amplitude in volts in NR3 format <range> ::= {F20HZ   F100HZ   F1KHZ   F10KHZ   F100KHZ   F1MHZ   F10MHZ   F20MHZ}
:POWer:CLResponse:WGEN:VOLTage:PROFILE {{0   OFF}   {1   ON}} (see page 782)	:POWer:CLResponse:WGEN:VOLTage:PROFILE? (see page 782)	{0   1}
:POWer:DESKew (see page 783)	n/a	n/a
:POWer:EFFiciency:APPly (see page 784)	n/a	n/a
:POWer:EFFiciency:TYPE <type> (see page 785)	:POWer:EFFiciency:TYPE? (see page 785)	<type> ::= {DCDC   DCAC   ACDC   ACAC}

**Table 26** :POWer Commands Summary (continued)

Command	Query	Options and Query Returns
:POWer:ENABLE {{0   OFF}   {1   ON}} (see page 786)	:POWer:ENABLE? (see page 786)	{0   1}
:POWer:HARMonics:APPLy (see page 787)	n/a	n/a
n/a	:POWer:HARMonics:DATA? (see page 788)	<binary_block> ::= comma-separated data with newlines at the end of each row
:POWer:HARMonics:DISPLAY <display> (see page 789)	:POWer:HARMonics:DISPLAY? (see page 789)	<display> ::= {TABLE   BAR   OFF}
n/a	:POWer:HARMonics:FAILCOUNT? (see page 790)	<count> ::= integer in NR1 format
:POWer:HARMonics:LINE <frequency> (see page 791)	:POWer:HARMonics:LINE? (see page 791)	<frequency> ::= {F50   F60   F400   AUTO}
n/a	:POWer:HARMonics:POWERFACtor? (see page 792)	<value> ::= Class C power factor in NR3 format
:POWer:HARMonics:RPOWER <source> (see page 793)	:POWer:HARMonics:RPOWER? (see page 793)	<source> ::= {MEASured   USER}
:POWer:HARMonics:RPOWER:USER <value> (see page 794)	:POWer:HARMonics:RPOWER:USER? (see page 794)	<value> ::= Watts from 1.0 to 600.0 in NR3 format
n/a	:POWer:HARMonics:RUNCOUNT? (see page 795)	<count> ::= integer in NR1 format
:POWer:HARMonics:STANDARD <class> (see page 796)	:POWer:HARMonics:STANDARD? (see page 796)	<class> ::= {A   B   C   D}
n/a	:POWer:HARMonics:STATUS? (see page 797)	<status> ::= {PASS   FAIL   UNTested}
n/a	:POWer:HARMonics:THD? (see page 798)	<value> ::= Total Harmonics Distortion in NR3 format
:POWer:INRUSH:APPLY (see page 799)	n/a	n/a
:POWer:INRUSH:EXIT (see page 800)	n/a	n/a

**Table 26** :POWer Commands Summary (continued)

Command	Query	Options and Query Returns
:POWer:INRush:NEXT (see <a href="#">page 801</a> )	n/a	n/a
:POWer:ITYPe <type> (see <a href="#">page 802</a> )	:POWer:ITYPe? (see <a href="#">page 802</a> )	<type> ::= {DC   AC}
:POWer:MODulation:APP Ly (see <a href="#">page 803</a> )	n/a	n/a
:POWer:MODulation:SOU Rce <source> (see <a href="#">page 804</a> )	:POWer:MODulation:SOU Rce? (see <a href="#">page 804</a> )	<source> ::= {V   I}
:POWer:MODulation:TYP E <modulation> (see <a href="#">page 805</a> )	:POWer:MODulation:TYP E? (see <a href="#">page 805</a> )	<modulation> ::= {VAverage   ACRMs   VRATio   PERiod   FREQuency   PWIDith   NWIDth   DUTYcycle   RISetime   FALLtime}
:POWer:ONOFF:APPLY (see <a href="#">page 806</a> )	n/a	n/a
:POWer:ONOFF:EXIT (see <a href="#">page 807</a> )	n/a	n/a
:POWer:ONOFF:NEXT (see <a href="#">page 808</a> )	n/a	n/a
:POWer:ONOFF:TEST {{0   OFF}   {1   ON}} (see <a href="#">page 809</a> )	:POWer:ONOFF:TEST? (see <a href="#">page 809</a> )	{0   1}
:POWer:ONOFF:THReshol ds <type>, <input_thr>, <output_thr> (see <a href="#">page 810</a> )	:POWer:ONOFF:THReshol ds? <type> (see <a href="#">page 810</a> )	<type> ::= {0   1} <input_thr> ::= percent from 0-100 in NR1 format <output_thr> ::= percent from 0-100 in NR1 format
n/a	:POWer:PSRR? (see <a href="#">page 812</a> )	n/a
:POWer:PSRR:APPLy (see <a href="#">page 813</a> )	n/a	n/a
n/a	:POWer:PSRR:DATA? [SWEep   SINGle] (see <a href="#">page 814</a> )	<binary_block> ::= comma-separated data with newlines at the end of each row
:POWer:PSRR:FREQuency :MAXimum <value>[suffix] (see <a href="#">page 815</a> )	:POWer:PSRR:FREQuency :MAXimum? (see <a href="#">page 815</a> )	<value> ::= {10   100   1000   10000   100000   1000000   10000000   20000000} [suffix] ::= {Hz   kHz   MHz}

**Table 26** :POWer Commands Summary (continued)

Command	Query	Options and Query Returns
:POWer:PSRR:FREQuency :MINimum <value>[suffix] (see page 816)	:POWer:PSRR:FREQuency :MINimum? (see page 816)	<value> ::= {1   10   100   1000   10000   100000   1000000   10000000} [suffix] ::= {Hz   kHz   MHz}
:POWer:PSRR:FREQuency :MODE <mode> (see page 817)	:POWer:PSRR:FREQuency :MODE? (see page 817)	<mode> ::= {SWEep   SINGLE}
:POWer:PSRR:FREQuency :SINGle <value>[suffix] (see page 818)	:POWer:PSRR:FREQuency :SINGle? (see page 818)	<value> ::= {1   10   100   1000   10000   100000   1000000   10000000   2000000} [suffix] ::= {Hz   kHz   MHz}
:POWer:PSRR:PPDecade <pts> (see page 819)	:POWer:PSRR:PPDecade? (see page 819)	<pts> ::= {10   20   30   40   50   60   70   80   90   100}
:POWer:PSRR:SOURce:IN Put <source> (see page 820)	:POWer:PSRR:SOURce:IN Put? (see page 820)	<source> ::= CHANNEL<n> <n> ::= 1 to (# analog channels) in NR1 format
:POWer:PSRR:SOURce:OU TPut <source> (see page 821)	:POWer:PSRR:SOURce:OU TPut? (see page 821)	<source> ::= CHANNEL<n> <n> ::= 1 to (# analog channels) in NR1 format
:POWer:PSRR:TRACe <selection> (see page 822)	:POWer:PSRR:TRACe? (see page 822)	<selection> ::= {NONE   GAIN}
:POWer:PSRR:WGEN:LOAD <impedance> (see page 823)	:POWer:PSRR:WGEN:LOAD ? (see page 823)	<impedance> ::= {ONEMeg   FIFTy}
:POWer:PSRR:WGEN:VOLTage <amplitude>[,<range>] (see page 824)	:POWer:PSRR:WGEN:VOLTage? [<range>] (see page 824)	<amplitude> ::= amplitude in volts in NR3 format <range> ::= {F20HZ   F100HZ   F1KHZ   F10KHZ   F100KHZ   F1MHZ   F10MHZ   F20MHZ}
:POWer:PSRR:WGEN:VOLTage:PROFILE { {0   OFF}   {1   ON} } (see page 825)	:POWer:PSRR:WGEN:VOLTage:PROFILE? (see page 825)	{0   1}
:POWer:QUALity:APPLy (see page 826)	n/a	n/a
:POWer:RIPple:APPLy (see page 827)	n/a	n/a

**Table 26** :POWer Commands Summary (continued)

Command	Query	Options and Query Returns
:POWer:SIGNals:AUToSetup <analysis> (see page 828)	n/a	<analysis> ::= {HARMonics   EFFiciency   RIPPLE   MODulation   QUALity   SLEW   SWITch   RDSVce}
:POWer:SIGNals:CYCLES:HARMonics <count> (see page 829)	:POWer:SIGNals:CYCLES:HARMonics? (see page 829)	<count> ::= integer in NR1 format Legal values are 1 to 100.
:POWer:SIGNals:CYCLES:QUALity <count> (see page 830)	:POWer:SIGNals:CYCLES:QUALity? (see page 830)	<count> ::= integer in NR1 format Legal values are 1 to 100.
:POWer:SIGNals:DURatiOn:EFFiciency <value>[suffix] (see page 831)	:POWer:SIGNals:DURatiOn:EFFiciency? (see page 831)	<value> ::= value in NR3 format [suffix] ::= {s   ms   us   ns}
:POWer:SIGNals:DURatiOn:MODulation <value>[suffix] (see page 832)	:POWer:SIGNals:DURatiOn:MODulation? (see page 832)	<value> ::= value in NR3 format [suffix] ::= {s   ms   us   ns}
:POWer:SIGNals:DURatiOn:ONOFF:OFF <value>[suffix] (see page 833)	:POWer:SIGNals:DURatiOn:ONOFF:OFF? (see page 833)	<value> ::= value in NR3 format [suffix] ::= {s   ms   us   ns}
:POWer:SIGNals:DURatiOn:ONOFF:ON <value>[suffix] (see page 834)	:POWer:SIGNals:DURatiOn:ONOFF:ON? (see page 834)	<value> ::= value in NR3 format [suffix] ::= {s   ms   us   ns}
:POWer:SIGNals:DURatiOn:RIPPLE <value>[suffix] (see page 835)	:POWer:SIGNals:DURatiOn:RIPPLE? (see page 835)	<value> ::= value in NR3 format [suffix] ::= {s   ms   us   ns}
:POWer:SIGNals:DURatiOn:TRANsient <value>[suffix] (see page 836)	:POWer:SIGNals:DURatiOn:TRANsient? (see page 836)	<value> ::= value in NR3 format [suffix] ::= {s   ms   us   ns}
:POWer:SIGNals:IEXPected <value>[suffix] (see page 837)	:POWer:SIGNals:IEXPected? (see page 837)	<value> ::= Expected current value in NR3 format [suffix] ::= {A   mA}
:POWer:SIGNals:OVERshoot <percent> (see page 838)	:POWer:SIGNals:OVERshoot? (see page 838)	<percent> ::= percent of overshoot value in NR1 format [suffix] ::= {V   mV}}

**Table 26** :POWer Commands Summary (continued)

Command	Query	Options and Query Returns
:POWer:SIGNals:VMAXim um:INRush <value>[suffix] (see page 839)	:POWer:SIGNals:VMAXim um:INRush? (see page 839)	<value> ::= Maximum expected input Voltage in NR3 format [suffix] ::= {V   mV}
:POWer:SIGNals:VMAXim um:ONOFF:OFF <value>[suffix] (see page 840)	:POWer:SIGNals:VMAXim um:ONOFF:OFF? (see page 840)	<value> ::= Maximum expected input Voltage in NR3 format [suffix] ::= {V   mV}
:POWer:SIGNals:VMAXim um:ONOFF:ON <value>[suffix] (see page 841)	:POWer:SIGNals:VMAXim um:ONOFF:ON? (see page 841)	<value> ::= Maximum expected input Voltage in NR3 format [suffix] ::= {V   mV}
:POWer:SIGNals:VSTead y:ONOFF:OFF <value>[suffix] (see page 842)	:POWer:SIGNals:VSTead y:ONOFF:OFF? (see page 842)	<value> ::= Expected steady stage output Voltage value in NR3 format [suffix] ::= {V   mV}
:POWer:SIGNals:VSTead y:ONOFF:ON <value>[suffix] (see page 843)	:POWer:SIGNals:VSTead y:ONOFF:ON? (see page 843)	<value> ::= Expected steady stage output Voltage value in NR3 format [suffix] ::= {V   mV}
:POWer:SIGNals:VSTead y:TRANSient <value>[suffix] (see page 844)	:POWer:SIGNals:VSTead y:TRANSient? (see page 844)	<value> ::= Expected steady stage output Voltage value in NR3 format [suffix] ::= {V   mV}
:POWer:SIGNals:SOURce :CURRent<i> <source> (see page 845)	:POWer:SIGNals:SOURce :CURRent<i>? (see page 845)	<i> ::= 1, 2 in NR1 format <source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:POWer:SIGNals:SOURce :VOLTage<i> <source> (see page 846)	:POWer:SIGNals:SOURce :VOLTage<i>? (see page 846)	<i> ::= 1, 2 in NR1 format <source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:POWer:SLEW:APPLY (see page 847)	n/a	n/a
:POWer:SLEW:SOURce <source> (see page 848)	:POWer:SLEW:SOURce? (see page 848)	<source> ::= {V   I}
:POWer:SWITch:APPLY (see page 849)	n/a	n/a

**Table 26** :POWer Commands Summary (continued)

Command	Query	Options and Query Returns
:POWer:SWITch:CONDuct ion <conduction> (see page 850)	:POWer:SWITch:CONDuct ion? (see page 850)	<conduction> ::= {WAVEform   RDS   VCE}
:POWer:SWITch:IREFere nce <percent> (see page 851)	:POWer:SWITch:IREFere nce? (see page 851)	<percent> ::= percent in NR1 format
:POWer:SWITch:RDS <value>[suffix] (see page 852)	:POWer:SWITch:RDS? (see page 852)	<value> ::= Rds(on) value in NR3 format [suffix] ::= {OHM   mOHM}
:POWer:SWITch:VCE <value>[suffix] (see page 853)	:POWer:SWITch:VCE? (see page 853)	<value> ::= Vce(sat) value in NR3 format [suffix] ::= {V   mV}
:POWer:SWITch:VREFere nce <percent> (see page 854)	:POWer:SWITch:VREFere nce? (see page 854)	<percent> ::= percent in NR1 format
:POWer:TRANSient:APPL y (see page 855)	n/a	n/a
:POWer:TRANSient:EXIT (see page 856)	n/a	n/a
:POWer:TRANSient:IINI tial <value>[suffix] (see page 857)	:POWer:TRANSient:IINI tial? (see page 857)	<value> ::= Initial current value in NR3 format [suffix] ::= {A   mA}
:POWer:TRANSient:INEW <value>[suffix] (see page 858)	:POWer:TRANSient:INEW ? (see page 858)	<value> ::= New current value in NR3 format [suffix] ::= {A   mA}
:POWer:TRANSient:NEXT (see page 859)	n/a	n/a

**Table 27** :RECall Commands Summary

Command	Query	Options and Query Returns
:RECall:ARbitrary[:START] [<file_spec>] [, <column>] [, <wavegen_id>] (see page 864)	n/a	<p>&lt;file_spec&gt; ::= {&lt;internal_loc&gt;   &lt;file_name&gt;}</p> <p>&lt;column&gt; ::= Column in CSV file to load. Column number starts from 1.</p> <p>&lt;internal_loc&gt; ::= 0-3; an integer in NR1 format</p> <p>&lt;file_name&gt; ::= quoted ASCII string</p> <p>&lt;wavegen_id&gt; ::= WGEN1</p>
:RECall:DBC[:START] [<file_name>] [, <serialbus>] (see page 865)	n/a	<p>&lt;file_name&gt; ::= quoted ASCII string</p> <p>If extension included in file name, it must be ".dbc".</p> <p>&lt;serialbus&gt; ::= {SBUS&lt;n&gt;}</p> <p>&lt;n&gt; ::= 1 to (# of serial bus) in NR1 format</p>
:RECall:FILename <base_name> (see page 866)	:RECall:FILename? (see page 866)	<p>&lt;base_name&gt; ::= quoted ASCII string</p>
:RECall:LDF[:START] [<file_name>] [, <serialbus>] (see page 867)	n/a	<p>&lt;file_name&gt; ::= quoted ASCII string</p> <p>If extension included in file name, it must be ".ldf".</p> <p>&lt;serialbus&gt; ::= {SBUS&lt;n&gt;}</p> <p>&lt;n&gt; ::= 1 to (# of serial bus) in NR1 format</p>
:RECall:MASK[:START] [<file_spec>] (see page 868)	n/a	<p>&lt;file_spec&gt; ::= {&lt;internal_loc&gt;   &lt;file_name&gt;}</p> <p>&lt;internal_loc&gt; ::= 0-3; an integer in NR1 format</p> <p>&lt;file_name&gt; ::= quoted ASCII string</p>
:RECall:PWD <path_name> (see page 869)	:RECall:PWD? (see page 869)	<p>&lt;path_name&gt; ::= quoted ASCII string</p>

**Table 27** :RECall Commands Summary (continued)

Command	Query	Options and Query Returns
:RECall:SETUp [:START] [<file_spec>] (see page 870)	n/a	<p>&lt;file_spec&gt; ::= {&lt;internal_loc&gt;   &lt;file_name&gt;}</p> <p>&lt;internal_loc&gt; ::= 0-9; an integer in NR1 format</p> <p>&lt;file_name&gt; ::= quoted ASCII string</p>
:RECall:WMEMOrY<r> [:START] [<file_name>   <data>] (see page 871)	n/a	<p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;file_name&gt; ::= quoted ASCII string</p> <p>If extension included in file name, it must be ".h5".</p> <p>&lt;data&gt; ::= binary block data in IEEE 488.2 # format</p>

**Table 28** :SAVE Commands Summary

Command	Query	Options and Query Returns
:SAVE:ARBitrary[:STARt] [<file_spec>] [, <wavegen_id>] (see page 877)	n/a	<p>&lt;file_spec&gt; ::= {&lt;internal_loc&gt;   &lt;file_name&gt;}</p> <p>&lt;internal_loc&gt; ::= 0-3; an integer in NR1 format</p> <p>&lt;file_name&gt; ::= quoted ASCII string</p> <p>&lt;wavegen_id&gt; ::= WGEN1</p>
:SAVE:COMpliance:USB [:START] [<file_name>] (see page 878)	n/a	<file_name> ::= quoted ASCII string
:SAVE:FIlename <base_name> (see page 879)	:SAVE:FIlename? (see page 879)	<base_name> ::= quoted ASCII string
:SAVE:IMAGE [:START] [<file_name>] (see page 880)	n/a	<file_name> ::= quoted ASCII string
:SAVE:IMAGE:FACTOrs {{0   OFF}   {1   ON}} (see page 881)	:SAVE:IMAGE:FACTOrs? (see page 881)	{0   1}
:SAVE:IMAGE:FORMAT <format> (see page 882)	:SAVE:IMAGE:FORMAT? (see page 882)	<format> ::= {{BMP   BMP24bit}   BMP8bit   PNG   NONE}

**Table 28** :SAVE Commands Summary (continued)

Command	Query	Options and Query Returns
:SAVE:IMAGE:INKSaver { {0   OFF}   {1   ON}} (see <a href="#">page 883</a> )	:SAVE:IMAGE:INKSaver? (see <a href="#">page 883</a> )	{0   1}
:SAVE:IMAGE:PALETTE <palette> (see <a href="#">page 884</a> )	:SAVE:IMAGE:PALETTE? (see <a href="#">page 884</a> )	<palette> ::= {COLOR   GRAYscale}
:SAVE:LISTER[:START] [<file_name>] (see <a href="#">page 885</a> )	n/a	<file_name> ::= quoted ASCII string
:SAVE:MASK[:START] [<file_spec>] (see <a href="#">page 886</a> )	n/a	<file_spec> ::= {<internal_loc>   <file_name>} <internal_loc> ::= 0-3; an integer in NR1 format <file_name> ::= quoted ASCII string
:SAVE:MULTI[:START] [<file_name>] (see <a href="#">page 887</a> )	n/a	<file_name> ::= quoted ASCII string
:SAVE:POWER[:START] [<file_name>] (see <a href="#">page 888</a> )	n/a	<file_name> ::= quoted ASCII string
:SAVE:PWD <path_name> (see <a href="#">page 889</a> )	:SAVE:PWD? (see <a href="#">page 889</a> )	<path_name> ::= quoted ASCII string
:SAVE:RESULTS:[START] [<file_spec>] (see <a href="#">page 890</a> )	n/a	<file_name> ::= quoted ASCII string
:SAVE:RESULTS:FORMAT:CURSOR {{0   OFF}   {1   ON}} (see <a href="#">page 891</a> )	:SAVE:RESULTS:FORMAT:CURSOR? (see <a href="#">page 891</a> )	{0   1}
:SAVE:RESULTS:FORMAT:MASK {{0   OFF}   {1   ON}} (see <a href="#">page 892</a> )	:SAVE:RESULTS:FORMAT:MASK? (see <a href="#">page 892</a> )	{0   1}
:SAVE:RESULTS:FORMAT:MEASUREMENT {{0   OFF}   {1   ON}} (see <a href="#">page 893</a> )	:SAVE:RESULTS:FORMAT:MEASUREMENT? (see <a href="#">page 893</a> )	{0   1}
:SAVE:RESULTS:FORMAT:SEARCH {{0   OFF}   {1   ON}} (see <a href="#">page 894</a> )	:SAVE:RESULTS:FORMAT:SEARCH? (see <a href="#">page 894</a> )	{0   1}

**Table 28** :SAVE Commands Summary (continued)

Command	Query	Options and Query Returns
:SAVE:RESUlt:FORMAT: SEGmented {{0   OFF}   {1   ON}} (see <a href="#">page 895</a> )	:SAVE:RESUlt:FORMAT: SEGmented? (see <a href="#">page 895</a> )	{0   1}
:SAVE:SETup [:START] [<file_spec>] (see <a href="#">page 896</a> )	n/a	<file_spec> ::= {<internal_loc>   <file_name>} <internal_loc> ::= 0-9; an integer in NR1 format <file_name> ::= quoted ASCII string
:SAVE:WAVEform[:STARt] ] [<file_name>] (see <a href="#">page 897</a> )	n/a	<file_name> ::= quoted ASCII string
:SAVE:WAVEform:FORMAT <format> (see <a href="#">page 898</a> )	:SAVE:WAVEform:FORMAT ? (see <a href="#">page 898</a> )	<format> ::= {ASCIixy   CSV   BINary   NONE}
:SAVE:WAVEform:LENGTH <length> (see <a href="#">page 899</a> )	:SAVE:WAVEform:LENGTH ? (see <a href="#">page 899</a> )	<length> ::= 100 to max. length; an integer in NR1 format
:SAVE:WAVEform:LENGTH :MAX {{0   OFF}   {1   ON}} (see <a href="#">page 900</a> )	:SAVE:WAVEform:LENGTH :MAX? (see <a href="#">page 900</a> )	{0   1}
:SAVE:WAVEform:SEGMen ted <option> (see <a href="#">page 901</a> )	:SAVE:WAVEform:SEGMen ted? (see <a href="#">page 901</a> )	<option> ::= {ALL   CURRent}

**Table 28** :SAVE Commands Summary (continued)

Command	Query	Options and Query Returns
:SAVE:WMEMORY:SOURce <source> (see page 902)	:SAVE:WMEMORY:SOURce? (see page 902)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMORY&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>NOTE: Only ADD or SUBtract math operations can be saved as reference waveforms.</p> <p>&lt;return_value&gt; ::= &lt;source&gt;</p>
:SAVE:WMEMORY[:START] [<file_name>] (see page 903)	n/a	<p>&lt;file_name&gt; ::= quoted ASCII string</p> <p>If extension included in file name, it must be ".h5".</p>

**Table 29** General :SBUS<n> Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:DISPLAY {{0   OFF}   {1   ON}} (see page 908)	:SBUS<n>:DISPLAY? (see page 908)	{0   1}
:SBUS<n>:MODE <mode> (see page 909)	:SBUS<n>:MODE? (see page 909)	<p>&lt;mode&gt; ::= {A429   CAN   CXPI   FLEXray   I2S   IIC   LIN   M1553   Manchester   NRZ   SENT   SPI   UART   USB   USBPd}</p>

**Table 30** :SBUS<n>:A429 Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:A429:AUToset up (see page 912)	n/a	n/a
:SBUS<n>:A429:BASE <base> (see page 913)	:SBUS<n>:A429:BASE? (see page 913)	<base> ::= {BINary   HEX}
:SBUS<n>:A429:BAUDrat e <baudrate> (see page 914)	:SBUS<n>:A429:BAUDrat e? (see page 914)	<baudrate> ::= integer from 10000 to 1000000

**Table 30** :SBUS<n>:A429 Commands Summary (continued)

Command	Query	Options and Query Returns
n/a	:SBUS<n>:A429:COUNT:EROR? (see <a href="#">page 915</a> )	<error_count> ::= integer in NR1 format
:SBUS<n>:A429:COUNT:RESet (see <a href="#">page 916</a> )	n/a	n/a
n/a	:SBUS<n>:A429:COUNT:WORD? (see <a href="#">page 917</a> )	<word_count> ::= integer in NR1 format
:SBUS<n>:A429:FORMAT<format> (see <a href="#">page 918</a> )	:SBUS<n>:A429:FORMAT? (see <a href="#">page 918</a> )	<format> ::= {LDSDi   LDSSm   LDATA}
:SBUS<n>:A429:SIGNAl<signal> (see <a href="#">page 919</a> )	:SBUS<n>:A429:SIGNAl? (see <a href="#">page 919</a> )	<signal> ::= {A   B   DIFFerential}
:SBUS<n>:A429:SOURce<source> (see <a href="#">page 920</a> )	:SBUS<n>:A429:SOURce? (see <a href="#">page 920</a> )	<source> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format
:SBUS<n>:A429:SPEed<speed> (see <a href="#">page 921</a> )	:SBUS<n>:A429:SPEed? (see <a href="#">page 921</a> )	<speed> ::= {LOW   HIGH   USER}
:SBUS<n>:A429:TRIGger:LABEL <value> (see <a href="#">page 922</a> )	:SBUS<n>:A429:TRIGger:LABEL? (see <a href="#">page 922</a> )	<value> ::= 8-bit integer in decimal, <hex>, <octal>, or <string> from 0-255 or "0xXX" (don't care)  <hex> ::= #Hnn where n ::= {0,...,9   A,...,F}  <octal> ::= #Qnnn where n ::= {0,...,7}  <string> ::= "0xnn" where n ::= {0,...,9   A,...,F}
:SBUS<n>:A429:TRIGger:PATTERn:DATA<string> (see <a href="#">page 923</a> )	:SBUS<n>:A429:TRIGger:PATTERn:DATA? (see <a href="#">page 923</a> )	<string> ::= "nn...n" where n ::= {0   1   X}, length depends on FORMAT
:SBUS<n>:A429:TRIGger:PATTERn:SDI <string> (see <a href="#">page 924</a> )	:SBUS<n>:A429:TRIGger:PATTERn:SDI? (see <a href="#">page 924</a> )	<string> ::= "nn" where n ::= {0   1   X}, length always 2 bits
:SBUS<n>:A429:TRIGger:PATTERn:SSM <string> (see <a href="#">page 925</a> )	:SBUS<n>:A429:TRIGger:PATTERn:SSM? (see <a href="#">page 925</a> )	<string> ::= "nn" where n ::= {0   1   X}, length always 2 bits

**Table 30** :SBUS<n>:A429 Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:A429:TRIGger :RANGE <min>, <max> (see <a href="#">page 926</a> )	:SBUS<n>:A429:TRIGger :RANGE? (see <a href="#">page 926</a> )	<min> ::= 8-bit integer in decimal, <hex>, <octal>, or <string> from 0-255  <max> ::= 8-bit integer in decimal, <hex>, <octal>, or <string> from 0-255  <hex> ::= #Hnn where n ::= {0,...,9   A,...,F}  <octal> ::= #Qnnn where n ::= {0,...,7}  <string> ::= "0xnn" where n ::= {0,...,9   A,...,F}
:SBUS<n>:A429:TRIGger :TYPE <condition> (see <a href="#">page 927</a> )	:SBUS<n>:A429:TRIGger :TYPE? (see <a href="#">page 927</a> )	<condition> ::= {WSTArt   WSTOP   LABel   LBITS   PERRor   WERRor   GERRor   WGERRors   ALLerrors   LRANGE   ABITS   AOBits   AZBits}

**Table 31** :SBUS<n>:CAN Commands Summary

Command	Query	Options and Query Returns
n/a	:SBUS<n>:CAN:COUNT:ER Ror? (see <a href="#">page 932</a> )	<frame_count> ::= integer in NR1 format
n/a	:SBUS<n>:CAN:COUNT:OV ERload? (see <a href="#">page 933</a> )	<frame_count> ::= 0 in NR1 format
:SBUS<n>:CAN:COUNT:RE Set (see <a href="#">page 934</a> )	n/a	n/a
n/a	:SBUS<n>:CAN:COUNT:SP EC? (see <a href="#">page 935</a> )	<spec_error_count> ::= integer in NR1 format
n/a	:SBUS<n>:CAN:COUNT:TO Tal? (see <a href="#">page 936</a> )	<frame_count> ::= integer in NR1 format
n/a	:SBUS<n>:CAN:COUNT:UT ILization? (see <a href="#">page 937</a> )	<percent> ::= floating-point in NR3 format
:SBUS<n>:CAN:DISPLAY <type> (see <a href="#">page 938</a> )	:SBUS<n>:CAN:DISPLAY? (see <a href="#">page 938</a> )	<type> ::= {HEXadecimal   SYMBolic}
:SBUS<n>:CAN:FDSPoint <value> (see <a href="#">page 939</a> )	:SBUS<n>:CAN:FDSPoint ? (see <a href="#">page 939</a> )	<value> ::= even numbered percentages from 30 to 90 in NR3 format.

**Table 31** :SBUS<n>:CAN Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:CAN:FDSTanda rd <std> (see <a href="#">page 940</a> )	:SBUS<n>:CAN:FDSTanda rd? (see <a href="#">page 940</a> )	<std> ::= {ISO   NISO}
:SBUS<n>:CAN:SAMPLEpo int <percent> (see <a href="#">page 941</a> )	:SBUS<n>:CAN:SAMPLEpo int? (see <a href="#">page 941</a> )	<percent> ::= 30.0 to 90.0 in NR3 format
:SBUS<n>:CAN:SIGNAl:B AUDrate <baudrate> (see <a href="#">page 942</a> )	:SBUS<n>:CAN:SIGNAl:B AUDrate? (see <a href="#">page 942</a> )	<baudrate> ::= integer from 10000 to 4000000 in 100 b/s increments, or 5000000
:SBUS<n>:CAN:SIGNAl:D EFinition <value> (see <a href="#">page 943</a> )	:SBUS<n>:CAN:SIGNAl:D EFinition? (see <a href="#">page 943</a> )	<value> ::= {CANH   CANL   RX   TX   DIFFerential   DIFL   DIFH}
:SBUS<n>:CAN:SIGNAl:F DBaudrate <baudrate> (see <a href="#">page 944</a> )	:SBUS<n>:CAN:SIGNAl:F DBaudrate? (see <a href="#">page 944</a> )	<baudrate> ::= integer from 10000 to 10000000 in 100 b/s increments.
:SBUS<n>:CAN:SOURce <source> (see <a href="#">page 945</a> )	:SBUS<n>:CAN:SOURce? (see <a href="#">page 945</a> )	<source> ::= {CHANnel<n>   EXTernal} for DSO models  <source> ::= {CHANnel<n>   DIGital<d>} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:CAN:TRIGger <condition> (see <a href="#">page 946</a> )	:SBUS<n>:CAN:TRIGger? (see <a href="#">page 947</a> )	<condition> ::= {SOF   EOF   IDData   DATA   FDData   IDRremote   IDEither   ERRor   ACKerror   FORMerror   STUFFerror   CRCerror   SPECerror   ALLerrors   BRSBit   CRCDbit   EBActive   EBPassive   OVERload   MESSAGE   MSIGnal   FDMSignal}
:SBUS<n>:CAN:TRIGger: IDFilter {{0   OFF}   {1   ON}} (see <a href="#">page 949</a> )	:SBUS<n>:CAN:TRIGger: IDFilter? (see <a href="#">page 949</a> )	{0   1}
:SBUS<n>:CAN:TRIGger: PATtern:DATA <string> (see <a href="#">page 950</a> )	:SBUS<n>:CAN:TRIGger: PATtern:DATA? (see <a href="#">page 950</a> )	<string> ::= "nn...n" where n ::= {0   1   X   \$}  <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$}

**Table 31** :SBUS<n>:CAN Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:CAN:TRIGger: PATtern:DATA:DLC <dlc> (see page 951)	:SBUS<n>:CAN:TRIGger: PATtern:DATA:DLC? (see page 951)	<dlc> ::= integer between -1 (don't care) and 64, in NR1 format.
:SBUS<n>:CAN:TRIGger: PATtern:DATA:LENGTH <length> (see page 952)	:SBUS<n>:CAN:TRIGger: PATtern:DATA:LENGTH? (see page 952)	<length> ::= integer from 1 to 8 in NR1 format
:SBUS<n>:CAN:TRIGger: PATtern:DATA:START <start> (see page 953)	:SBUS<n>:CAN:TRIGger: PATtern:DATA:START? (see page 953)	<start> ::= integer between 0 and 63, in NR1 format.
:SBUS<n>:CAN:TRIGger: PATtern:ID <string> (see page 954)	:SBUS<n>:CAN:TRIGger: PATtern:ID? (see page 954)	<string> ::= "nn...n" where n ::= {0   1   X   \$} <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:CAN:TRIGger: PATtern:ID:MODE <value> (see page 955)	:SBUS<n>:CAN:TRIGger: PATtern:ID:MODE? (see page 955)	<value> ::= {STANDARD   EXTENDED}
:SBUS<n>:CAN:TRIGger: SYMBolic:MESSAge <name> (see page 956)	:SBUS<n>:CAN:TRIGger: SYMBolic:MESSAge? (see page 956)	<name> ::= quoted ASCII string
:SBUS<n>:CAN:TRIGger: SYMBolic:SIGNAl <name> (see page 957)	:SBUS<n>:CAN:TRIGger: SYMBolic:SIGNAl? (see page 957)	<name> ::= quoted ASCII string
:SBUS<n>:CAN:TRIGger: SYMBolic:VALue <data> (see page 958)	:SBUS<n>:CAN:TRIGger: SYMBolic:VALue? (see page 958)	<data> ::= value in NR3 format

**Table 32** :SBUS<n>:CXPI Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:CXPI:BAUDrate <baudrate> (see page 961)	:SBUS<n>:CXPI:BAUDrate? (see page 961)	<baudrate> ::= integer from 9600 to 40000 in 100 b/s increments.
:SBUS<n>:CXPI:PARity {{0   OFF}   {1   ON}} (see page 962)	:SBUS<n>:CXPI:PARity? (see page 962)	{0   1}
:SBUS<n>:CXPI:SOURce <source> (see page 963)	:SBUS<n>:CXPI:SOURce? (see page 963)	<source> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format

**Table 32** :SBUS<n>:CXPI Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:CXPI:TOLERance <percent> (see page 964)	:SBUS<n>:CXPI:TOLERance? (see page 964)	<percent> ::= from 1-30, in NR1 format.
:SBUS<n>:CXPI:TRIGGER <mode> (see page 965)	:SBUS<n>:CXPI:TRIGGER? (see page 966)	<mode> ::= {SOF   EOF   PTYPe   ID   DATA   LDATA   CRCerror   PARityerror   IBSerror   IFSerror   FRAMingerror   DLENgtherror   SAMPLerror   ALLerrors   SLEepframe   WAKEuppulse}
:SBUS<n>:CXPI:TRIGGER:IDFilter {{0   OFF}   {1   ON}} (see page 967)	:SBUS<n>:CXPI:TRIGGER:IDFilter? (see page 967)	{0   1}
:SBUS<n>:CXPI:TRIGGER:PTYPe {{0   OFF}   {1   ON}} (see page 968)	:SBUS<n>:CXPI:TRIGGER:PTYPe? (see page 968)	{0   1}
:SBUS<n>:CXPI:TRIGGER:PATTERn:DATA <string> (see page 969)	:SBUS<n>:CXPI:TRIGGER:PATTERn:DATA? (see page 969)	<string> ::= "nn...n" where n ::= {0   1   X} <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X}
:SBUS<n>:CXPI:TRIGGER:PATTERn:DATA:LENGTH <length> (see page 970)	:SBUS<n>:CXPI:TRIGGER:PATTERn:DATA:LENGTH? (see page 970)	<start> ::= integer between 0 and 12, in NR1 format.
:SBUS<n>:CXPI:TRIGGER:PATTERn:DATA:START <start> (see page 971)	:SBUS<n>:CXPI:TRIGGER:PATTERn:DATA:START? (see page 971)	<start> ::= integer between 0 and 124, in NR1 format.
:SBUS<n>:CXPI:TRIGGER:PATTERn:ID <string> (see page 972)	:SBUS<n>:CXPI:TRIGGER:PATTERn:ID? (see page 972)	<string> ::= "nn...n" where n ::= {0   1   X} <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X}
:SBUS<n>:CXPI:TRIGGER:PATTERn:INFO:CT <string> (see page 973)	:SBUS<n>:CXPI:TRIGGER:PATTERn:INFO:CT? (see page 973)	<string> ::= "nn" where n ::= {0   1   X}

**Table 32** :SBUS<n>:CXPI Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:CXPI:TRIGger :PATtern:INFO:DLC <dlc> (see <a href="#">page 974</a> )	:SBUS<n>:CXPI:TRIGger :PATtern:INFO:DLC? (see <a href="#">page 974</a> )	<dlc> ::= integer between -1 (don't care) and 15, in NR1 format, when trigger is in DATA mode.  <dlc> ::= integer between -1 (don't care) and 255, in NR1 format, when trigger is in LDATA mode.
:SBUS<n>:CXPI:TRIGger :PATtern:INFO:NM <string> (see <a href="#">page 975</a> )	:SBUS<n>:CXPI:TRIGger :PATtern:INFO:NM? (see <a href="#">page 975</a> )	<string> ::= "nn" where n ::= {0   1   X}

**Table 33** :SBUS<n>:FLEXray Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:FLEXray:AUTOsetup (see <a href="#">page 978</a> )	n/a	n/a
:SBUS<n>:FLEXray:BAUDrate <baudrate> (see <a href="#">page 979</a> )	:SBUS<n>:FLEXray:BAUDrate? (see <a href="#">page 979</a> )	<baudrate> ::= {2500000   5000000   10000000}
:SBUS<n>:FLEXray:CHANNEL <channel> (see <a href="#">page 980</a> )	:SBUS<n>:FLEXray:CHANNEL? (see <a href="#">page 980</a> )	<channel> ::= {A   B}
n/a	:SBUS<n>:FLEXray:COUNT:NULL? (see <a href="#">page 981</a> )	<frame_count> ::= integer in NR1 format
:SBUS<n>:FLEXray:COUNT:RESET (see <a href="#">page 982</a> )	n/a	n/a
n/a	:SBUS<n>:FLEXray:COUNT:SYNC? (see <a href="#">page 983</a> )	<frame_count> ::= integer in NR1 format
n/a	:SBUS<n>:FLEXray:COUNT:TOTAl? (see <a href="#">page 984</a> )	<frame_count> ::= integer in NR1 format
:SBUS<n>:FLEXray:SOURCE <source> (see <a href="#">page 985</a> )	:SBUS<n>:FLEXray:SOURCE? (see <a href="#">page 985</a> )	<source> ::= {CHANNEL<n>} <n> ::= 1-2 or 1-4 in NR1 format
:SBUS<n>:FLEXray:TRIGGER <condition> (see <a href="#">page 986</a> )	:SBUS<n>:FLEXray:TRIGGER? (see <a href="#">page 986</a> )	<condition> ::= {FRAME   ERROR   EVENT}

**Table 33** :SBUS<n>:FLEXray Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:FLEXray:TRIG ger:ERRor:TYPE <error_type> (see <a href="#">page 987</a> )	:SBUS<n>:FLEXray:TRIG ger:ERRor:TYPE? (see <a href="#">page 987</a> )	<error_type> ::= {ALL   HCRC   FCRC}
:SBUS<n>:FLEXray:TRIG ger:EVENT:AUToset (see <a href="#">page 988</a> )	n/a	n/a
:SBUS<n>:FLEXray:TRIG ger:EVENT:BSS:ID <frame_id> (see <a href="#">page 989</a> )	:SBUS<n>:FLEXray:TRIG ger:EVENT:BSS:ID? (see <a href="#">page 989</a> )	<frame_id> ::= {ALL   <frame #>} <frame #> ::= integer from 1-2047
:SBUS<n>:FLEXray:TRIG ger:EVENT:TYPE <event> (see <a href="#">page 990</a> )	:SBUS<n>:FLEXray:TRIG ger:EVENT:TYPE? (see <a href="#">page 990</a> )	<event> ::= {WAKEup   TSS   {FES   DTS}   BSS}
:SBUS<n>:FLEXray:TRIG ger:FRAMe:CCBase <cycle_count_base> (see <a href="#">page 991</a> )	:SBUS<n>:FLEXray:TRIG ger:FRAMe:CCBase? (see <a href="#">page 991</a> )	<cycle_count_base> ::= integer from 0-63
:SBUS<n>:FLEXray:TRIG ger:FRAMe:CCRepetitio n <cycle_count_repetiti on> (see <a href="#">page 992</a> )	:SBUS<n>:FLEXray:TRIG ger:FRAMe:CCRepetitio n? (see <a href="#">page 992</a> )	<cycle_count_repetition> ::= {ALL   <rep #>} <rep #> ::= integer values 2, 4, 8, 16, 32, or 64
:SBUS<n>:FLEXray:TRIG ger:FRAMe:ID <frame_id> (see <a href="#">page 993</a> )	:SBUS<n>:FLEXray:TRIG ger:FRAMe:ID? (see <a href="#">page 993</a> )	<frame_id> ::= {ALL   <frame #>} <frame #> ::= integer from 1-2047
:SBUS<n>:FLEXray:TRIG ger:FRAMe:TYPE <frame_type> (see <a href="#">page 994</a> )	:SBUS<n>:FLEXray:TRIG ger:FRAMe:TYPE? (see <a href="#">page 994</a> )	<frame_type> ::= {NORMal   STARtup   NULL   SYNC   NSTArtup   NNULl   NSYNC   ALL}

**Table 34** :SBUS<n>:I2S Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:I2S:ALIGNmen t <setting> (see <a href="#">page 998</a> )	:SBUS<n>:I2S:ALIGNmen t? (see <a href="#">page 998</a> )	<setting> ::= {I2S   LJ   RJ}
:SBUS<n>:I2S:BASE <base> (see <a href="#">page 999</a> )	:SBUS<n>:I2S:BASE? (see <a href="#">page 999</a> )	<base> ::= {DECimal   HEX}

**Table 34** :SBUS<n>:I2S Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:I2S:CLOCK:SL OPe <slope> (see <a href="#">page 1000</a> )	:SBUS<n>:I2S:CLOCK:SL OPe? (see <a href="#">page 1000</a> )	<slope> ::= {NEGative   POSitive}
:SBUS<n>:I2S:RWIDth <receiver> (see <a href="#">page 1001</a> )	:SBUS<n>:I2S:RWIDth? (see <a href="#">page 1001</a> )	<receiver> ::= 4-32 in NR1 format
:SBUS<n>:I2S:SOURce:CO LOCK <source> (see <a href="#">page 1002</a> )	:SBUS<n>:I2S:SOURce:CO LOCK? (see <a href="#">page 1002</a> )	<source> ::= {CHANnel<n>   EXTernal} for DSO models  <source> ::= {CHANnel<n>   DIGital<d>} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:I2S:SOURce:D ATA <source> (see <a href="#">page 1003</a> )	:SBUS<n>:I2S:SOURce:D ATA? (see <a href="#">page 1003</a> )	<source> ::= {CHANnel<n>   EXTernal} for DSO models  <source> ::= {CHANnel<n>   DIGital<d>} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:I2S:SOURce:W SElect <source> (see <a href="#">page 1004</a> )	:SBUS<n>:I2S:SOURce:W SElect? (see <a href="#">page 1004</a> )	<source> ::= {CHANnel<n>   EXTernal} for DSO models  <source> ::= {CHANnel<n>   DIGital<d>} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:I2S:TRIGger <operator> (see <a href="#">page 1005</a> )	:SBUS<n>:I2S:TRIGger? (see <a href="#">page 1005</a> )	<operator> ::= {EQUAL   NOTequal   LESSthan   GREaterthan   INRange   OUTRange   INCReasing   DECReasing}
:SBUS<n>:I2S:TRIGger: AUDIO <audio_ch> (see <a href="#">page 1007</a> )	:SBUS<n>:I2S:TRIGger: AUDIO? (see <a href="#">page 1007</a> )	<audio_ch> ::= {RIGHT   LEFT   EITHER}

**Table 34** :SBUS<n>:I2S Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:I2S:TRIGger: PATtern:DATA <string> (see <a href="#">page 1008</a> )	:SBUS<n>:I2S:TRIGger: PATtern:DATA? (see <a href="#">page 1009</a> )	<string> ::= "n" where n ::= 32-bit integer in signed decimal when <base> = DECimal  <string> ::= "nn...n" where n ::= {0   1   X   \$} when <base> = BINary  <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$} when <base> = HEX
:SBUS<n>:I2S:TRIGger: PATtern:FORMAT <base> (see <a href="#">page 1010</a> )	:SBUS<n>:I2S:TRIGger: PATtern:FORMAT? (see <a href="#">page 1010</a> )	<base> ::= {BINary   HEX   DECimal}
:SBUS<n>:I2S:TRIGger: RANGE <lower>,<upper> (see <a href="#">page 1011</a> )	:SBUS<n>:I2S:TRIGger: RANGE? (see <a href="#">page 1011</a> )	<lower> ::= 32-bit integer in signed decimal, <nondecimal>, or <string>  <upper> ::= 32-bit integer in signed decimal, <nondecimal>, or <string>  <nondecimal> ::= #Hnn...n where n ::= {0,...,9   A,...,F} for hexadecimal  <nondecimal> ::= #Bnn...n where n ::= {0   1} for binary  <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F} for hexadecimal
:SBUS<n>:I2S:TWIDth <word_size> (see <a href="#">page 1012</a> )	:SBUS<n>:I2S:TWIDth? (see <a href="#">page 1012</a> )	<word_size> ::= 4-32 in NR1 format
:SBUS<n>:I2S:WSLow <low_def> (see <a href="#">page 1013</a> )	:SBUS<n>:I2S:WSLow? (see <a href="#">page 1013</a> )	<low_def> ::= {LEFT   RIGHT}

**Table 35** :SBUS<n>:IIC Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:IIC:ASIZE <size> (see page 1016)	:SBUS<n>:IIC:ASIZE? (see page 1016)	<size> ::= {BIT7   BIT8}
:SBUS<n>:IIC[:SOURce] :CLOCk <source> (see page 1017)	:SBUS<n>:IIC[:SOURce] :CLOCk? (see page 1017)	<source> ::= {CHANnel<n>   EXTERNAL} for DSO models <source> ::= {CHANnel<n>   DIGITAL<d>} for MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:IIC[:SOURce] :DATA <source> (see page 1018)	:SBUS<n>:IIC[:SOURce] :DATA? (see page 1018)	<source> ::= {CHANnel<n>   EXTERNAL} for DSO models <source> ::= {CHANnel<n>   DIGITAL<d>} for MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:IIC:TRIGger: PATtern:ADDRess <value> (see page 1019)	:SBUS<n>:IIC:TRIGger: PATtern:ADDRess? (see page 1019)	<value> ::= integer or <string> <string> ::= "0xnn" n ::= {0,...,9   A,...,F}
:SBUS<n>:IIC:TRIGger: PATtern:DATA <value> (see page 1020)	:SBUS<n>:IIC:TRIGger: PATtern:DATA? (see page 1020)	<value> ::= integer or <string> <string> ::= "0xnn" n ::= {0,...,9   A,...,F}
:SBUS<n>:IIC:TRIGger: PATtern:DATA2 <value> (see page 1021)	:SBUS<n>:IIC:TRIGger: PATtern:DATA2? (see page 1021)	<value> ::= integer or <string> <string> ::= "0xnn" n ::= {0,...,9   A,...,F}
:SBUS<n>:IIC:TRIGger: QUALifier <value> (see page 1022)	:SBUS<n>:IIC:TRIGger: QUALifier? (see page 1022)	<value> ::= {EQUAL   NOTEQUAL   LESSthan   GREATERthan}
:SBUS<n>:IIC:TRIGger[: TYPE] <type> (see page 1023)	:SBUS<n>:IIC:TRIGger[: TYPE]? (see page 1023)	<type> ::= {START   STOP   RESTART   ADDRess   ANACK   DNACK   NACKnowledge   READEprom   READ7   WRITE7   R7Data2   W7Data2   WRITE10}

**Table 36** :SBUS<n>:LIN Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:LIN:DISPLAY <type> (see <a href="#">page 1027</a> )	:SBUS<n>:LIN:DISPLAY? (see <a href="#">page 1027</a> )	<type> ::= {HEXadecimal   SYMBolic}
:SBUS<n>:LIN:PARity { {0   OFF}   {1   ON} } (see <a href="#">page 1028</a> )	:SBUS<n>:LIN:PARity? (see <a href="#">page 1028</a> )	{0   1}
:SBUS<n>:LIN:SAMPLEpo int <value> (see <a href="#">page 1029</a> )	:SBUS<n>:LIN:SAMPLEpo int? (see <a href="#">page 1029</a> )	<value> ::= {60   62.5   68   70   75   80   87.5} in NR3 format
:SBUS<n>:LIN:SIGNAl:B AUDrate <baudrate> (see <a href="#">page 1030</a> )	:SBUS<n>:LIN:SIGNAl:B AUDrate? (see <a href="#">page 1030</a> )	<baudrate> ::= integer from 2400 to 625000 in 100 b/s increments
:SBUS<n>:LIN:SOURce <source> (see <a href="#">page 1031</a> )	:SBUS<n>:LIN:SOURce? (see <a href="#">page 1031</a> )	<source> ::= {CHANnel<n>   EXTernal} for DSO models  <source> ::= {CHANnel<n>   DIGital<d>} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:LIN:STANDARD <std> (see <a href="#">page 1032</a> )	:SBUS<n>:LIN:STANDARD ? (see <a href="#">page 1032</a> )	<std> ::= {LIN13   LIN13NLC   LIN20}
:SBUS<n>:LIN:SYNCbrea k <value> (see <a href="#">page 1033</a> )	:SBUS<n>:LIN:SYNCbrea k? (see <a href="#">page 1033</a> )	<value> ::= integer = {11   12   13}
:SBUS<n>:LIN:TRIGger <condition> (see <a href="#">page 1034</a> )	:SBUS<n>:LIN:TRIGger? (see <a href="#">page 1034</a> )	<condition> ::= {SYNCbreak   ID   DATA}
:SBUS<n>:LIN:TRIGger: ID <value> (see <a href="#">page 1036</a> )	:SBUS<n>:LIN:TRIGger: ID? (see <a href="#">page 1036</a> )	<value> ::= 7-bit integer in decimal, <nondecimal>, or <string> from 0-63 or 0x00-0x3f  <nondecimal> ::= #Hnn where n ::= {0,...,9   A,...,F} for hexadecimal  <nondecimal> ::= #Bnn...n where n ::= {0   1} for binary  <string> ::= "0xnn" where n ::= {0,...,9   A,...,F} for hexadecimal

**Table 36** :SBUS<n>:LIN Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:LIN:TRIGger:PATTern:DATA <string> (see page 1037)	:SBUS<n>:LIN:TRIGger:PATTern:DATA? (see page 1037)	<string> ::= "n" where n ::= 32-bit integer in unsigned decimal when <base> = DECimal <string> ::= "nn...n" where n ::= {0   1   X   \$} when <base> = BINary <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$} when <base> = HEX
:SBUS<n>:LIN:TRIGger:PATTern:DATA:LENGTH <length> (see page 1039)	:SBUS<n>:LIN:TRIGger:PATTern:DATA:LENGTH? (see page 1039)	<length> ::= integer from 1 to 8 in NR1 format
:SBUS<n>:LIN:TRIGger:PATTern:FORMAT <base> (see page 1040)	:SBUS<n>:LIN:TRIGger:PATTern:FORMAT? (see page 1040)	<base> ::= {BINary   HEX   DECimal}
:SBUS<n>:LIN:TRIGger:SYMBolic:FRAMe <name> (see page 1041)	:SBUS<n>:LIN:TRIGger:SYMBolic:FRAMe? (see page 1041)	<name> ::= quoted ASCII string
:SBUS<n>:LIN:TRIGger:SYMBolic:SIGNAL <name> (see page 1042)	:SBUS<n>:LIN:TRIGger:SYMBolic:SIGNAL? (see page 1042)	<name> ::= quoted ASCII string
:SBUS<n>:LIN:TRIGger:SYMBolic:VALue <data> (see page 1043)	:SBUS<n>:LIN:TRIGger:SYMBolic:VALue? (see page 1043)	<data> ::= value in NR3 format

**Table 37** :SBUS<n>:M1553 Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:M1553:AUTose tup (see page 1045)	n/a	n/a
:SBUS<n>:M1553:BASE <base> (see page 1046)	:SBUS<n>:M1553:BASE? (see page 1046)	<base> ::= {BINary   HEX}
:SBUS<n>:M1553:SOURce <source> (see page 1047)	:SBUS<n>:M1553:SOURce? (see page 1047)	<source> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format
:SBUS<n>:M1553:TRIGge r:PATTern:DATA <string> (see page 1048)	:SBUS<n>:M1553:TRIGge r:PATTern:DATA? (see page 1048)	<string> ::= "nn...n" where n ::= {0   1   X}

**Table 37** :SBUS<n>:M1553 Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:M1553:TRIGge r:RTA <value> (see <a href="#">page 1049</a> )	:SBUS<n>:M1553:TRIGge r:RTA? (see <a href="#">page 1049</a> )	<value> ::= 5-bit integer in decimal, <nondecimal>, or <string> from 0-31 <nondecimal> ::= #Hnn where n ::= {0,...,9 A,...,F} <string> ::= "0xnn" where n ::= {0,...,9 A,...,F}
:SBUS<n>:M1553:TRIGge r:TYPE <type> (see <a href="#">page 1050</a> )	:SBUS<n>:M1553:TRIGge r:TYPE? (see <a href="#">page 1050</a> )	<type> ::= {DSTArt   DSTOp   CSTArt   CSTOp   RTA   PERRor   SERRor   MERRor   RTA11}

**Table 38** :SBUS<n>:MANChester Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:MANChester:B ASE <base> (see <a href="#">page 1053</a> )	:SBUS<n>:MANChester:B ASE? (see <a href="#">page 1053</a> )	<base> ::= {HEX   DECimal   ASCII}
:SBUS<n>:MANChester:B AUDrate <baudrate> (see <a href="#">page 1054</a> )	:SBUS<n>:MANChester:B AUDrate? (see <a href="#">page 1054</a> )	<baudrate> ::= integer from 500 to 5000000 in 100 b/s increments
:SBUS<n>:MANChester:B ITorder <bitorder> (see <a href="#">page 1055</a> )	:SBUS<n>:MANChester:B ITorder? (see <a href="#">page 1055</a> )	<bitorder> ::= {MSBFirst   LSBFirst}
:SBUS<n>:MANChester:D ISPlay <format> (see <a href="#">page 1056</a> )	:SBUS<n>:MANChester:D ISPlay? (see <a href="#">page 1056</a> )	<format> ::= {BIT   WORD}
:SBUS<n>:MANChester:D SIZE {AUTO   <#words>} (see <a href="#">page 1057</a> )	:SBUS<n>:MANChester:D SIZE? (see <a href="#">page 1057</a> )	<#words> ::= from 1-255, in NR1 format
:SBUS<n>:MANChester:H SIZE <#bits> (see <a href="#">page 1058</a> )	:SBUS<n>:MANChester:H SIZE? (see <a href="#">page 1058</a> )	<#bits> ::= from 0-32, in NR1 format
:SBUS<n>:MANChester:I DLE:BITS <#bits> (see <a href="#">page 1059</a> )	:SBUS<n>:MANChester:I DLE:BITS? (see <a href="#">page 1059</a> )	<#bits> ::= minimum idle time in terms of bit width, from 1.50 to 32.0, in NR3 format.
:SBUS<n>:MANChester:L OGic <logic> (see <a href="#">page 1060</a> )	:SBUS<n>:MANChester:L OGic? (see <a href="#">page 1060</a> )	<logic> ::= {FALLing   RISing}

**Table 38** :SBUS<n>:MANChester Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:MANChester:SOURce <source> (see page 1061)	:SBUS<n>:MANChester:SOURce? (see page 1061)	<source> ::= {CHANnel<n>   DIGItal<d>}
:SBUS<n>:MANChester:SIZe <#bits> (see page 1062)	:SBUS<n>:MANChester:SIZe? (see page 1062)	<#bits> ::= from 0-255, in NR1 format
:SBUS<n>:MANChester:STArt <edge#> (see page 1063)	:SBUS<n>:MANChester:STArt? (see page 1063)	<edge#> ::= from 1-256, in NR1 format
:SBUS<n>:MANChester:TOLerance <percent> (see page 1064)	:SBUS<n>:MANChester:TOLerance? (see page 1064)	<percent> ::= from 1-30, in NR1 format
:SBUS<n>:MANChester:TRIGger <mode> (see page 1065)	:SBUS<n>:MANChester:TRIGger? (see page 1065)	<mode> ::= {SOF   VALue   MERRor}
:SBUS<n>:MANChester:TRIGger:PATTern:VALue:DATA <string> (see page 1066)	:SBUS<n>:MANChester:TRIGger:PATTern:VALue:DATA? (see page 1066)	<string> ::= "nn...n" where n ::= {0   1   X   \$} <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:MANChester:TRIGger:PATTern:VALue:WIDTh <width> (see page 1067)	:SBUS<n>:MANChester:TRIGger:PATTern:VALue:WIDTh? (see page 1067)	<width> ::= integer from 4 to 128 in NR1 format
:SBUS<n>:MANChester:SIZe <#bits> (see page 1068)	:SBUS<n>:MANChester:SIZe? (see page 1068)	<#bits> ::= from 0-32, in NR1 format
:SBUS<n>:MANChester:SIZE <#bits> (see page 1069)	:SBUS<n>:MANChester:SIZE? (see page 1069)	<#bits> ::= from 2-32, in NR1 format

**Table 39** :SBUS<n>:NRZ Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:NRZ:BASE <base> (see page 1072)	:SBUS<n>:NRZ:BASE? (see page 1072)	<base> ::= {HEX   DECimal   ASCII}
:SBUS<n>:NRZ:BAUDrate <baudrate> (see page 1073)	:SBUS<n>:NRZ:BAUDrate? (see page 1073)	<baudrate> ::= integer from 5000 to 5000000 in 100 b/s increments

**Table 39** :SBUS<n>:NRZ Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:NRZ:BITorder <bitorder> (see <a href="#">page 1074</a> )	:SBUS<n>:NRZ:BITorder? (see <a href="#">page 1074</a> )	<bitorder> ::= {MSBFIRST   LSBFIRST}
:SBUS<n>:NRZ:DISPLAY <format> (see <a href="#">page 1075</a> )	:SBUS<n>:NRZ:DISPLAY? (see <a href="#">page 1075</a> )	<format> ::= {BIT   WORD}
:SBUS<n>:NRZ:DSize <#words> (see <a href="#">page 1076</a> )	:SBUS<n>:NRZ:DSize? (see <a href="#">page 1076</a> )	<#words> ::= from 1-255, in NR1 format
:SBUS<n>:NRZ:FSize <#bits> (see <a href="#">page 1077</a> )	:SBUS<n>:NRZ:FSize? (see <a href="#">page 1077</a> )	<#bits> ::= from 2-255, in NR1 format
:SBUS<n>:NRZ:HSize <#bits> (see <a href="#">page 1078</a> )	:SBUS<n>:NRZ:HSize? (see <a href="#">page 1078</a> )	<#bits> ::= from 0-32, in NR1 format
:SBUS<n>:NRZ:IDLE:BIT S <#bits> (see <a href="#">page 1079</a> )	:SBUS<n>:NRZ:IDLE:BIT S? (see <a href="#">page 1079</a> )	<#bits> ::= minimum idle time in terms of bit width, from 1.50 to 32.0, in NR3 format.
:SBUS<n>:NRZ:IDLE:STA Te <state> (see <a href="#">page 1080</a> )	:SBUS<n>:NRZ:IDLE:STA Te? (see <a href="#">page 1080</a> )	<state> ::= {LOW   HIGH}
:SBUS<n>:NRZ:LOGic <logic> (see <a href="#">page 1081</a> )	:SBUS<n>:NRZ:LOGic? (see <a href="#">page 1081</a> )	<logic> ::= {HIGH   LOW}
:SBUS<n>:NRZ:SOURce <source> (see <a href="#">page 1082</a> )	:SBUS<n>:NRZ:SOURce? (see <a href="#">page 1082</a> )	<source> ::= {CHANnel<n>   DIGItal<d>}
:SBUS<n>:NRZ:START <#bits> (see <a href="#">page 1083</a> )	:SBUS<n>:NRZ:START? (see <a href="#">page 1083</a> )	<#bits> ::= from 0-255, in NR1 format
:SBUS<n>:NRZ:TRIGger <mode> (see <a href="#">page 1084</a> )	:SBUS<n>:NRZ:TRIGger? (see <a href="#">page 1084</a> )	<mode> ::= {SOF   VALue}
:SBUS<n>:NRZ:TRIGger: PATtern:VALue:DATA <string> (see <a href="#">page 1085</a> )	:SBUS<n>:NRZ:TRIGger: PATtern:VALue:DATA? (see <a href="#">page 1085</a> )	<string> ::= "nn...n" where n ::= {0   1   X   \$}  <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:NRZ:TRIGger: PATtern:VALue:WIDTH <width> (see <a href="#">page 1086</a> )	:SBUS<n>:NRZ:TRIGger: PATtern:VALue:WIDTH? (see <a href="#">page 1086</a> )	<width> ::= integer from 4 to 128 in NR1 format

**Table 39** :SBUS<n>:NRZ Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:NRZ:TSize <#bits> (see page 1087)	:SBUS<n>:NRZ:TSize? (see page 1087)	<#bits> ::= from 0-32, in NR1 format
:SBUS<n>:NRZ:WSize <#bits> (see page 1088)	:SBUS<n>:NRZ:WSize? (see page 1088)	<#bits> ::= from 2-32, in NR1 format

**Table 40** :SBUS<n>:SENT Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:SENT:CLOCK <period> (see page 1092)	:SBUS<n>:SENT:CLOCK? (see page 1092)	<period> ::= the nominal clock period (tick), from 500 ns to 300 us, in NR3 format.
:SBUS<n>:SENT:CRC <format> (see page 1093)	:SBUS<n>:SENT:CRC? (see page 1093)	<format> ::= {LEGacy   RECommended}
:SBUS<n>:SENT:DISPlay <base> (see page 1094)	:SBUS<n>:SENT:DISPlay? (see page 1094)	<base> ::= {HEX   DECimal   SYMBolic}
:SBUS<n>:SENT:FORMAT <decode> (see page 1096)	:SBUS<n>:SENT:FORMAT? (see page 1096)	<decode> ::= {NIBBles   FSIGnal   FSSerial   FESerial   SSErial   ESErial}
:SBUS<n>:SENT:IDLE <state> (see page 1098)	:SBUS<n>:SENT:IDLE? (see page 1098)	<state> ::= {LOW   HIGH}
:SBUS<n>:SENT:LENGTH <#_nibbles> (see page 1099)	:SBUS<n>:SENT:LENGTH? (see page 1099)	<#_nibbles> ::= from 1-6, in NR1 format.
:SBUS<n>:SENT:PPULse { {0   OFF}   {1   ON}   SPC } (see page 1100)	:SBUS<n>:SENT:PPULse? (see page 1100)	{0   1   SPC}
:SBUS<n>:SENT:SIGNAl< s>:DISPlay { {0   OFF}   {1   ON} } (see page 1102)	:SBUS<n>:SENT:SIGNAl< s>:DISPlay? (see page 1102)	<s> ::= 1-6, in NR1 format. {0   1}
:SBUS<n>:SENT:SIGNAl< s>:LENGTH <length> (see page 1103)	:SBUS<n>:SENT:SIGNAl< s>:LENGTH? (see page 1103)	<s> ::= 1-6, in NR1 format. <length> ::= from 1-24, in NR1 format.

**Table 40** :SBUS<n>:SENT Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:SENT:SIGNAl<s>:MULTiplier <multiplier> (see page 1105)	:SBUS<n>:SENT:SIGNAl<s>:MULTiplier? (see page 1105)	<s> ::= 1-6, in NR1 format. <multiplier> ::= from 1-24, in NR3 format.
:SBUS<n>:SENT:SIGNAl<s>:OFFSet <offset> (see page 1107)	:SBUS<n>:SENT:SIGNAl<s>:OFFSet? (see page 1107)	<s> ::= 1-6, in NR1 format. <offset> ::= from 1-24, in NR3 format.
:SBUS<n>:SENT:SIGNAl<s>:ORDer <order> (see page 1109)	:SBUS<n>:SENT:SIGNAl<s>:ORDer? (see page 1109)	<s> ::= 1-6, in NR1 format. <order> ::= {MSNFirst   LSNFirst}
:SBUS<n>:SENT:SIGNAl<s>:STARt <position> (see page 1111)	:SBUS<n>:SENT:SIGNAl<s>:STARt? (see page 1111)	<s> ::= 1-6, in NR1 format. <position> ::= from 0-23, in NR1 format.
:SBUS<n>:SENT:SOURce <source> (see page 1113)	:SBUS<n>:SENT:SOURce? (see page 1113)	<source> ::= {CHANnel<n>   DIGital<d>} <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:SENT:TOLERance <percent> (see page 1115)	:SBUS<n>:SENT:TOLERance? (see page 1115)	<percent> ::= from 3-30, in NR1 format.
:SBUS<n>:SENT:TRIGger <mode> (see page 1116)	:SBUS<n>:SENT:TRIGger? (see page 1116)	<mode> ::= {SFCMessage   SSCMessage   FCData   SCMid   SCData   FCCerror   SCCerror   CRCerror   TOLerror   PPERror   SSPerror}
:SBUS<n>:SENT:TRIGger :FAST:DATA <string> (see page 1118)	:SBUS<n>:SENT:TRIGger :FAST:DATA? (see page 1118)	<string> ::= "nnnn..." where n ::= {0   1   X} <string> ::= "0xn..." where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:SENT:TRIGger :SLOW:DATA <data> (see page 1119)	:SBUS<n>:SENT:TRIGger :SLOW:DATA? (see page 1119)	<data> ::= when ILEngth = SHORT, from -1 (don't care) to 65535, in NR1 format. <data> ::= when ILEngth = LONG, from -1 (don't care) to 4095, in NR1 format.

**Table 40** :SBUS<n>:SENT Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:SENT:TRIGger :SLOW:ID <id> (see page 1121)	:SBUS<n>:SENT:TRIGger :SLOW:ID? (see page 1121)	<id> ::= when ILength = SHOrt, from -1 (don't care) to 15, in NR1 format. <id> ::= when ILength = LONG, from -1 (don't care) to 255, in NR1 format.
:SBUS<n>:SENT:TRIGger :SLOW:ILENGth <length> (see page 1123)	:SBUS<n>:SENT:TRIGger :SLOW:ILENGth? (see page 1123)	<length> ::= {SHOrt   LONG}
:SBUS<n>:SENT:TRIGger :TOLerance <percent> (see page 1124)	:SBUS<n>:SENT:TRIGger :TOLerance? (see page 1124)	<percent> ::= from 1-18, in NR1 format.

**Table 41** :SBUS<n>:SPI Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:SPI:BITorder <order> (see page 1127)	:SBUS<n>:SPI:BITorder? (see page 1127)	<order> ::= {LSBFirst   MSBFFirst}
:SBUS<n>:SPI:CLOCK:SL OPe <slope> (see page 1128)	:SBUS<n>:SPI:CLOCK:SL OPe? (see page 1128)	<slope> ::= {NEGative   POSitive}
:SBUS<n>:SPI:CLOCK:TI Meout <time_value> (see page 1129)	:SBUS<n>:SPI:CLOCK:TI Meout? (see page 1129)	<time_value> ::= time in seconds in NR3 format
:SBUS<n>:SPI:DELay <value> (see page 1130)	:SBUS<n>:SPI:DELay? (see page 1130)	<value> ::= {OFF   2-63}
:SBUS<n>:SPI:FRAMing <value> (see page 1131)	:SBUS<n>:SPI:FRAMing? (see page 1131)	<value> ::= {CHIPselect   {NCHipselect   NOTC}   TIMeout}
:SBUS<n>:SPI:SOURce:C LOCK <source> (see page 1132)	:SBUS<n>:SPI:SOURce:C LOCK? (see page 1132)	<value> ::= {CHANnel<n>   EXTernal} for the DSO models <value> ::= {CHANnel<n>   DIGital<d>} for the MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format

**Table 41** :SBUS<n>:SPI Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:SPI:SOURCe:FRAMe <source> (see page 1133)	:SBUS<n>:SPI:SOURCe:FRAMe? (see page 1133)	<value> ::= {CHANnel<n>   EXTERNAL} for the DSO models <value> ::= {CHANnel<n>   DIGITAL<d>} for the MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:SPI:SOURCe:MIso <source> (see page 1134)	:SBUS<n>:SPI:SOURCe:MIso? (see page 1134)	<value> ::= {CHANnel<n>   EXTERNAL} for the DSO models <value> ::= {CHANnel<n>   DIGITAL<d>} for the MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:SPI:SOURCe:MOsi <source> (see page 1135)	:SBUS<n>:SPI:SOURCe:MOsi? (see page 1135)	<value> ::= {CHANnel<n>   EXTERNAL} for the DSO models <value> ::= {CHANnel<n>   DIGITAL<d>} for the MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:SPI:TRIGger:PATTern:MIso:DATA <string> (see page 1136)	:SBUS<n>:SPI:TRIGger:PATTern:MIso:DATA? (see page 1136)	<string> ::= "nn...n" where n ::= {0   1   X   \$} <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:SPI:TRIGger:PATTern:MIso:WIDTh <width> (see page 1137)	:SBUS<n>:SPI:TRIGger:PATTern:MIso:WIDTh? (see page 1137)	<width> ::= integer from 4 to 64 in NR1 format
:SBUS<n>:SPI:TRIGger:PATTern:MOsi:DATA <string> (see page 1138)	:SBUS<n>:SPI:TRIGger:PATTern:MOsi:DATA? (see page 1138)	<string> ::= "nn...n" where n ::= {0   1   X   \$} <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:SPI:TRIGger:PATTern:MOsi:WIDTh <width> (see page 1139)	:SBUS<n>:SPI:TRIGger:PATTern:MOsi:WIDTh? (see page 1139)	<width> ::= integer from 4 to 64 in NR1 format

**Table 41** :SBUS<n>:SPI Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:SPI:TRIGger: TYPE <value> (see <a href="#">page 1140</a> )	:SBUS<n>:SPI:TRIGger: TYPE? (see <a href="#">page 1140</a> )	<value> ::= {MOSI   MISO}
:SBUS<n>:SPI:WIDTH <word_width> (see <a href="#">page 1141</a> )	:SBUS<n>:SPI:WIDTH? (see <a href="#">page 1141</a> )	<word_width> ::= integer 4-16 in NR1 format

**Table 42** :SBUS<n>:UART Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:UART:BASE <base> (see <a href="#">page 1145</a> )	:SBUS<n>:UART:BASE? (see <a href="#">page 1145</a> )	<base> ::= {ASCII   BINary   HEX}
:SBUS<n>:UART:BAUDrat e <baudrate> (see <a href="#">page 1146</a> )	:SBUS<n>:UART:BAUDrat e? (see <a href="#">page 1146</a> )	<baudrate> ::= integer from 100 to 8000000, 10000000, or 12000000
:SBUS<n>:UART:BITorde r <bitorder> (see <a href="#">page 1147</a> )	:SBUS<n>:UART:BITorde r? (see <a href="#">page 1147</a> )	<bitorder> ::= {LSBFFirst   MSBFFirst}
n/a	:SBUS<n>:UART:COUNT:E RRor? (see <a href="#">page 1148</a> )	<frame_count> ::= integer in NR1 format
:SBUS<n>:UART:COUNT:R ESet (see <a href="#">page 1149</a> )	n/a	n/a
n/a	:SBUS<n>:UART:COUNT:R XFRAMES? (see <a href="#">page 1150</a> )	<frame_count> ::= integer in NR1 format
n/a	:SBUS<n>:UART:COUNT:T XFRAMES? (see <a href="#">page 1151</a> )	<frame_count> ::= integer in NR1 format
:SBUS<n>:UART:FRAMing <value> (see <a href="#">page 1152</a> )	:SBUS<n>:UART:FRAMing? (see <a href="#">page 1152</a> )	<value> ::= {OFF   <decimal>   <nondecimal>} <decimal> ::= 8-bit integer from 0-255 (0x00-0xff) <nondecimal> ::= #Hnn where n ::= {0,...,9   A,...,F} for hexadecimal <nondecimal> ::= #Bnn...n where n ::= {0   1} for binary
:SBUS<n>:UART:PARity <parity> (see <a href="#">page 1153</a> )	:SBUS<n>:UART:PARity? (see <a href="#">page 1153</a> )	<parity> ::= {EVEN   ODD   NONE}

**Table 42** :SBUS<n>:UART Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:UART:POLarit y <polarity> (see <a href="#">page 1154</a> )	:SBUS<n>:UART:POLarit y? (see <a href="#">page 1154</a> )	<polarity> ::= {HIGH   LOW}
:SBUS<n>:UART:SOURce: RX <source> (see <a href="#">page 1155</a> )	:SBUS<n>:UART:SOURce: RX? (see <a href="#">page 1155</a> )	<source> ::= {CHANnel<n>   EXTernal} for DSO models  <source> ::= {CHANnel<n>   DIGital<d>} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:UART:SOURce: TX <source> (see <a href="#">page 1156</a> )	:SBUS<n>:UART:SOURce: TX? (see <a href="#">page 1156</a> )	<source> ::= {CHANnel<n>   EXTernal} for DSO models  <source> ::= {CHANnel<n>   DIGital<d>} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:UART:TRIGger :BASE <base> (see <a href="#">page 1157</a> )	:SBUS<n>:UART:TRIGger :BASE? (see <a href="#">page 1157</a> )	<base> ::= {ASCII   HEX}
:SBUS<n>:UART:TRIGger :BURSt <value> (see <a href="#">page 1158</a> )	:SBUS<n>:UART:TRIGger :BURSt? (see <a href="#">page 1158</a> )	<value> ::= {OFF   1 to 4096 in NR1 format}
:SBUS<n>:UART:TRIGger :DATA <value> (see <a href="#">page 1159</a> )	:SBUS<n>:UART:TRIGger :DATA? (see <a href="#">page 1159</a> )	<value> ::= 8-bit integer from 0-255 (0x00-0xff) in decimal, <hexadecimal>, <binary>, or <quoted_string> format  <hexadecimal> ::= #Hnn where n ::= {0,...,9   A,...,F} for hexadecimal  <binary> ::= #Bnn...n where n ::= {0   1} for binary  <quoted_string> ::= any of the 128 valid 7-bit ASCII characters (or standard abbreviations)
:SBUS<n>:UART:TRIGger :IDLE <time_value> (see <a href="#">page 1160</a> )	:SBUS<n>:UART:TRIGger :IDLE? (see <a href="#">page 1160</a> )	<time_value> ::= time from 1 us to 10 s in NR3 format

**Table 42** :SBUS<n>:UART Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:UART:TRIGger :QUALifier <value> (see page 1161)	:SBUS<n>:UART:TRIGger :QUALifier? (see page 1161)	<value> ::= {EQUAL   NOTequal   GREaterthan   LESSthan}
:SBUS<n>:UART:TRIGger :TYPE <value> (see page 1162)	:SBUS<n>:UART:TRIGger :TYPE? (see page 1162)	<value> ::= {RSTArt   RSTOP   RDATa   RD1   RD0   RDX   PARityerror   TSTArt   TSTOP   TDATa   TD1   TD0   TDX}
:SBUS<n>:UART:WIDTh <width> (see page 1163)	:SBUS<n>:UART:WIDTh? (see page 1163)	<width> ::= {5   6   7   8   9}

**Table 43** :SBUS<n>:USB Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:USB:BASE <base> (see page 1167)	:SBUS<n>:USB:BASE? (see page 1167)	<base> ::= {ASCII   BINARY   DECIMAL   HEX}
:SBUS<n>:USB:SOURce:D MINus <source> (see page 1168)	:SBUS<n>:USB:SOURce:D MINus? (see page 1168)	<source> ::= {CHANnel<n>} for DSO models  <source> ::= {CHANnel<n>   DIGital<d>} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:USB:SOURce:D PPlus <source> (see page 1169)	:SBUS<n>:USB:SOURce:D PPlus? (see page 1169)	<source> ::= {CHANnel<n>} for DSO models  <source> ::= {CHANnel<n>   DIGital<d>} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:USB:SOURce:D IFFerential <source> (see page 1170)	:SBUS<n>:USB:SOURce:D IFFerential? (see page 1170)	<source> ::= {CHANnel<n>}  <n> ::= 1 to (# analog channels) in NR1 format
:SBUS<n>:USB:SPEed <speed> (see page 1171)	:SBUS<n>:USB:SPEed? (see page 1171)	<speed> ::= {LOW   FULL   HIGH}

**Table 43** :SBUS<n>:USB Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:USB:TRIGger <condition> (see <a href="#">page 1172</a> )	:SBUS<n>:USB:TRIGger? (see <a href="#">page 1172</a> )	<condition> ::= {SOP   EOP   ENTersuspend   EXITsuspend   RESet   TOKen   DATA   HANDshake   SPECIAL   ALLerrors   PIDerror   CRC5error   CRC16error   GLITcherror   STUFFerror   SElerror}
:SBUS<n>:USB:TRIGger: ADDReSS <string> (see <a href="#">page 1173</a> )	:SBUS<n>:USB:TRIGger: ADDReSS? (see <a href="#">page 1173</a> )	<string> ::= "nnnnnnnn" where n ::= {0   1   X}  <string> ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:USB:TRIGger: CRC <string> (see <a href="#">page 1174</a> )	:SBUS<n>:USB:TRIGger: CRC? (see <a href="#">page 1174</a> )	<string> ::= "nnnn" where n ::= {0   1   X}  <string> ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:USB:TRIGger: DATA <string> (see <a href="#">page 1175</a> )	:SBUS<n>:USB:TRIGger: DATA? (see <a href="#">page 1175</a> )	<string> ::= "nnnn..." where n ::= {0   1   X}  <string> ::= "0xn..." where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:USB:TRIGger: DATA:LENGTH <value> (see <a href="#">page 1176</a> )	:SBUS<n>:USB:TRIGger: DATA:LENGTH? (see <a href="#">page 1176</a> )	<length> ::= data length between 1-20
:SBUS<n>:USB:TRIGger: ENDPoint <string> (see <a href="#">page 1177</a> )	:SBUS<n>:USB:TRIGger: ENDPoint? (see <a href="#">page 1177</a> )	<string> ::= "nnnn" where n ::= {0   1   X}  <string> ::= "0xn" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:USB:TRIGger: ET <string> (see <a href="#">page 1178</a> )	:SBUS<n>:USB:TRIGger: ET? (see <a href="#">page 1178</a> )	<string> ::= "nn" where n ::= {0   1   X}  <string> ::= "0xn" where n ::= {0   1   2   3   X   \$}
:SBUS<n>:USB:TRIGger: FRAMe <string> (see <a href="#">page 1179</a> )	:SBUS<n>:USB:TRIGger: FRAMe? (see <a href="#">page 1179</a> )	<string> ::= "nnnnnnnnnnnn" where n ::= {0   1   X}  <string> ::= "0xnnn" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:USB:TRIGger: HADDress <string> (see <a href="#">page 1180</a> )	:SBUS<n>:USB:TRIGger: HADDress? (see <a href="#">page 1180</a> )	<string> ::= "nnnnnnnn" where n ::= {0   1   X}  <string> ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}

**Table 43** :SBUS<n>:USB Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:USB:TRIGger: PCHeck <string> (see <a href="#">page 1181</a> )	:SBUS<n>:USB:TRIGger: PCHeck? (see <a href="#">page 1181</a> )	<string> ::= "nnnn" where n ::= {0   1   X}  <string> ::= "0xn" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:USB:TRIGger: PID:DATA <pid> (see <a href="#">page 1182</a> )	:SBUS<n>:USB:TRIGger: PID:DATA? (see <a href="#">page 1182</a> )	<pid> ::= {DATA0   DATA1   DATA2   MDATA}
:SBUS<n>:USB:TRIGger: PID:HANDshake <pid> (see <a href="#">page 1183</a> )	:SBUS<n>:USB:TRIGger: PID:HANDshake? (see <a href="#">page 1183</a> )	<pid> ::= {ACK   NAK   STALL   NYET}
:SBUS<n>:USB:TRIGger: PID:SPECial <pid> (see <a href="#">page 1184</a> )	:SBUS<n>:USB:TRIGger: PID:SPECIAL? (see <a href="#">page 1184</a> )	<pid> ::= {PING   PRE   ERR   SPLIt}
:SBUS<n>:USB:TRIGger: PID:TOKen <pid> (see <a href="#">page 1185</a> )	:SBUS<n>:USB:TRIGger: PID:TOKEN? (see <a href="#">page 1185</a> )	<pid> ::= {OUT   IN   SETup   SOF}
:SBUS<n>:USB:TRIGger: PORT <string> (see <a href="#">page 1186</a> )	:SBUS<n>:USB:TRIGger: PORT? (see <a href="#">page 1186</a> )	<string> ::= "nnnnnnn" where n ::= {0   1   X}  <string> ::= "0xn" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:USB:TRIGger: SC <string> (see <a href="#">page 1187</a> )	:SBUS<n>:USB:TRIGger: SC? (see <a href="#">page 1187</a> )	<string> ::= "n" where n ::= {0   1   X}  <string> ::= "0xn" where n ::= {0   1   X   \$}
:SBUS<n>:USB:TRIGger: SEU <string> (see <a href="#">page 1188</a> )	:SBUS<n>:USB:TRIGger: SEU? (see <a href="#">page 1188</a> )	<string> ::= "nn" where n ::= {0   1   X}  <string> ::= "0xn" where n ::= {0   1   2   3   X   \$}

**Table 44** :SBUS<n>:USBPd Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:USBPd:SOURce <source> (see <a href="#">page 1190</a> )	:SBUS<n>:USBPd:SOURce ? (see <a href="#">page 1190</a> )	<source> ::= {CHANnel<n>}  <n> ::= 1 to (# analog channels) in NR1 format
:SBUS<n>:USBPd:TRIGge r <mode> (see <a href="#">page 1191</a> )	:SBUS<n>:USBPd:TRIGge r? (see <a href="#">page 1191</a> )	<mode> ::= {PSTart   EOP   SOP   SPRime   SDPrime   SPDebug   SDPDebug   HRST   CRST   CRCerror   PERRor   HEADer}

**Table 44** :SBUS<n>:USBPd Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:USBPd:TRIGge r:HEADER <type> (see page 1192)	:SBUS<n>:USBPd:TRIGge r:HEADER? (see page 1192)	<type> ::= {CMESsage   DMESsage   EMESsage   VALue}
:SBUS<n>:USBPd:TRIGge r:HEADER:CMESsage <type> (see page 1194)	:SBUS<n>:USBPd:TRIGge r:HEADER:CMESsage? (see page 1194)	<type> ::= {GOODcrc   GOTomin   ACCept   REJECT   PING   PSRDy   GSRCap   GSNCap   DRSSwap   PRSSwap   VCSswap   WAIT   SRST   GSCX   GSTatus   FRSswap   GPSTatus   GCCodes}
:SBUS<n>:USBPd:TRIGge r:HEADER:DMESsage <type> (see page 1196)	:SBUS<n>:USBPd:TRIGge r:HEADER:DMESsage? (see page 1196)	<type> ::= {SRCap   REQuest   BIST   SNCap   BSTatus   ALERt   GCInfo   VDEFined}
:SBUS<n>:USBPd:TRIGge r:HEADER:EMESsage <type> (see page 1197)	:SBUS<n>:USBPd:TRIGge r:HEADER:EMESsage? (see page 1197)	<type> ::= {SCX   STATus   GBCap   GBStatus   BCAP   GMInfo   MINFO   SREQuest   SREsponse   FREQuest   FREsponse   PSTatus   CINFO   CCODes}
:SBUS<n>:USBPd:TRIGge r:HEADER:VALue <string> (see page 1199)	:SBUS<n>:USBPd:TRIGge r:HEADER:VALue? (see page 1199)	<string> ::= "nn...n" where n ::= {0   1   X}  <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X}
:SBUS<n>:USBPd:TRIGge r:HEADER:QUALifier <type> (see page 1200)	:SBUS<n>:USBPd:TRIGge r:HEADER:QUALifier? (see page 1200)	<type> ::= {NONE   SOP   SPRime   SDPRime}

**Table 45** General :SEARch Commands Summary

Command	Query	Options and Query Returns
n/a	:SEARch:COUNT? (see page 1203)	<count> ::= an integer count value
:SEARch:EVENT <event_number> (see page 1204)	:SEARch:EVENT? (see page 1204)	<event_number> ::= the integer number of a found search event
:SEARch:MODE <value> (see page 1205)	:SEARch:MODE? (see page 1205)	<value> ::= {EDGE   GLITch   RUNT   TRANSition   SERial{1   2}   PEAK}
:SEARch:STATE <value> (see page 1206)	:SEARch:STATE? (see page 1206)	<value> ::= {{0   OFF}   {1   ON}}

**Table 46** :SEARch:EDGE Commands Summary

Command	Query	Options and Query Returns
:SEARch:EDGE:SLOPe <slope> (see page 1208)	:SEARch:EDGE:SLOPe? (see <a href="#">page 1208</a> )	<slope> ::= {POsitive   NEGative   EITHer}
:SEARch:EDGE:SOURce <source> (see page 1209)	:SEARch:EDGE:SOURce? (see <a href="#">page 1209</a> )	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format

**Table 47** :SEARch:GLITch Commands Summary

Command	Query	Options and Query Returns
:SEARch:GLITch:GREaterthan <greater_than_time>[suffix] (see <a href="#">page 1211</a> )	:SEARch:GLITch:GREaterthan? (see <a href="#">page 1211</a> )	<greater_than_time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}
:SEARch:GLITch:LESSthan <less_than_time>[suffix] (see <a href="#">page 1212</a> )	:SEARch:GLITch:LESSthan? (see <a href="#">page 1212</a> )	<less_than_time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}
:SEARch:GLITch:POLarity <polarity> (see <a href="#">page 1213</a> )	:SEARch:GLITch:POLarity? (see <a href="#">page 1213</a> )	<polarity> ::= {POsitive   NEGative}
:SEARch:GLITch:QUALifier <qualifier> (see <a href="#">page 1214</a> )	:SEARch:GLITch:QUALifier? (see <a href="#">page 1214</a> )	<qualifier> ::= {GREaterthan   LESSthan   RANGE}
:SEARch:GLITch:RANGE <less_than_time>[suffix], <greater_than_time>[suffix] (see <a href="#">page 1215</a> )	:SEARch:GLITch:RANGE? (see <a href="#">page 1215</a> )	<less_than_time> ::= 15 ns to 10 seconds in NR3 format <greater_than_time> ::= 10 ns to 9.99 seconds in NR3 format [suffix] ::= {s   ms   us   ns   ps}
:SEARch:GLITch:SOURce <source> (see <a href="#">page 1216</a> )	:SEARch:GLITch:SOURce? (see <a href="#">page 1216</a> )	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format

**Table 48** :SEARch:PEAK Commands Summary

Command	Query	Options and Query Returns
:SEARch:PEAK:EXCursion <delta_level> (see page 1218)	:SEARch:PEAK:EXCursion? (see page 1218)	<delta_level> ::= required change in level to be recognized as a peak, in NR3 format.
:SEARch:PEAK:NPeaks <number> (see page 1219)	:SEARch:PEAK:NPeaks? (see page 1219)	<number> ::= max number of peaks to find, 1-11 in NR1 format.
:SEARch:PEAK:SOURce <source> (see page 1220)	:SEARch:PEAK:SOURce? (see page 1220)	<source> ::= {FUNCTION<m>   MATH<m>} (must be an FFT waveform) <m> ::= 1 to 4 in NR1 format
:SEARch:PEAK:THRESHold <level> (see page 1221)	:SEARch:PEAK:THRESHold? (see page 1221)	<level> ::= necessary level to be considered a peak, in NR3 format.

**Table 49** :SEARch:RUNT Commands Summary

Command	Query	Options and Query Returns
:SEARch:RUNT:POLarity <polarity> (see page 1223)	:SEARch:RUNT:POLarity? (see page 1223)	<polarity> ::= {POSitive   NEGative   EITHer}
:SEARch:RUNT:QUALifier <qualifier> (see page 1224)	:SEARch:RUNT:QUALifier? (see page 1224)	<qualifier> ::= {GREaterthan   LESSthan   NONE}
:SEARch:RUNT:SOURce <source> (see page 1225)	:SEARch:RUNT:SOURce? (see page 1225)	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:SEARch:RUNT:TIME <time>[suffix] (see page 1226)	:SEARch:RUNT:TIME? (see page 1226)	<time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}

**Table 50** :SEARch:TRANSition Commands Summary

Command	Query	Options and Query Returns
:SEARch:TRANSition:QU ALifier <qualifier> (see <a href="#">page 1228</a> )	:SEARch:TRANSition:QU ALifier? (see <a href="#">page 1228</a> )	<qualifier> ::= {GREaterthan   LESSthan}
:SEARch:TRANSition:SL OPe <slope> (see <a href="#">page 1229</a> )	:SEARch:TRANSition:SL OPe? (see <a href="#">page 1229</a> )	<slope> ::= {NEGative   POSitive}
:SEARch:TRANSition:SO URce <source> (see <a href="#">page 1230</a> )	:SEARch:TRANSition:SO URce? (see <a href="#">page 1230</a> )	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:SEARch:TRANSition:TI ME <time>[suffix] (see <a href="#">page 1231</a> )	:SEARch:TRANSition:TI ME? (see <a href="#">page 1231</a> )	<time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}

**Table 51** :SEARch:SERial:A429 Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:A429:L ABel <value> (see <a href="#">page 1233</a> )	:SEARch:SERial:A429:L ABel? (see <a href="#">page 1233</a> )	<value> ::= 8-bit integer in decimal, <hex>, <octal>, or <string> from 0-255 <hex> ::= #Hnn where n ::= {0,...,9   A,...,F} <octal> ::= #Qnnn where n ::= {0,...,7} <string> ::= "0xnn" where n ::= {0,...,9   A,...,F}
:SEARch:SERial:A429:M ODE <condition> (see <a href="#">page 1234</a> )	:SEARch:SERial:A429:M ODE? (see <a href="#">page 1234</a> )	<condition> ::= {LABEL   LBITS   PERRor   WERRor   GERRor   WGERRors   ALLerrors}
:SEARch:SERial:A429:P ATTern:DATA <string> (see <a href="#">page 1235</a> )	:SEARch:SERial:A429:P ATTern:DATA? (see <a href="#">page 1235</a> )	<string> ::= "nn...n" where n ::= {0   1}, length depends on FORMAT
:SEARch:SERial:A429:P ATTern:SDI <string> (see <a href="#">page 1236</a> )	:SEARch:SERial:A429:P ATTern:SDI? (see <a href="#">page 1236</a> )	<string> ::= "nn" where n ::= {0   1}, length always 2 bits
:SEARch:SERial:A429:P ATTern:SSM <string> (see <a href="#">page 1237</a> )	:SEARch:SERial:A429:P ATTern:SSM? (see <a href="#">page 1237</a> )	<string> ::= "nn" where n ::= {0   1}, length always 2 bits

**Table 52** :SEARch:SERial:CAN Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:CAN:MODE <value> (see page 1239)	:SEARch:SERial:CAN:MODE? (see page 1239)	<value> ::= { IDEither   IDData   DATA   IDRremote   ERRor   ACKerror   FORMerror   STUFFerror   CRCerror   ALLerrors   OVERload   MESSage   MSIGnal}
:SEARch:SERial:CAN:PA TTern:DATA <string> (see page 1241)	:SEARch:SERial:CAN:PA TTern:DATA? (see page 1241)	<string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X} for hexadecimal
:SEARch:SERial:CAN:PA TTern:DATA:LENGTH <length> (see page 1242)	:SEARch:SERial:CAN:PA TTern:DATA:LENGTH? (see page 1242)	<length> ::= integer from 1 to 8 in NR1 format
:SEARch:SERial:CAN:PA TTern:ID <string> (see page 1243)	:SEARch:SERial:CAN:PA TTern:ID? (see page 1243)	<string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X} for hexadecimal
:SEARch:SERial:CAN:PA TTern:ID:MODE <value> (see page 1244)	:SEARch:SERial:CAN:PA TTern:ID:MODE? (see page 1244)	<value> ::= { STANDARD   EXTended }
:SEARch:SERial:CAN:SY MBolic:MESSAge <name> (see page 1245)	:SEARch:SERial:CAN:SY MBolic:MESSAge? (see page 1245)	<name> ::= quoted ASCII string
:SEARch:SERial:CAN:SY MBolic:SIGNAl <name> (see page 1246)	:SEARch:SERial:CAN:SY MBolic:SIGNAl? (see page 1246)	<name> ::= quoted ASCII string
:SEARch:SERial:CAN:SY MBolic:VALue <data> (see page 1247)	:SEARch:SERial:CAN:SY MBolic:VALue? (see page 1247)	<data> ::= value in NR3 format

**Table 53** :SEARch:SERial:FLEXray Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:FLEXray:CYCLE <cycle> (see page 1249)	:SEARch:SERial:FLEXray:CYCLE? (see page 1249)	<cycle> ::= { ALL   <cycle #>} <cycle #> ::= integer from 0-63
:SEARch:SERial:FLEXray:DATA <string> (see page 1250)	:SEARch:SERial:FLEXray:DATA? (see page 1250)	<string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X }
:SEARch:SERial:FLEXray:DATA:LENGTH <length> (see page 1251)	:SEARch:SERial:FLEXray:DATA:LENGTH? (see page 1251)	<length> ::= integer from 1 to 12 in NR1 format

**Table 53** :SEARch:SERial:FLEXray Commands Summary (continued)

Command	Query	Options and Query Returns
:SEARch:SERial:FLEXra y:FRAMe <frame id> (see page 1252)	:SEARch:SERial:FLEXra y:FRAMe? (see page 1252)	<frame_id> ::= {ALL   <frame #>} <frame #> ::= integer from 1-2047
:SEARch:SERial:FLEXra y:MODE <value> (see page 1253)	:SEARch:SERial:FLEXra y:MODE? (see page 1253)	<value> ::= {FRAMe   CYCLE   DATA   HERRor   FERRor   AERRor}

**Table 54** :SEARch:SERial:I2S Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:I2S:AU Dio <audio_ch> (see page 1255)	:SEARch:SERial:I2S:AU Dio? (see page 1255)	<audio_ch> ::= {RIGHT   LEFT   EITHER}
:SEARch:SERial:I2S:MO DE <value> (see page 1256)	:SEARch:SERial:I2S:MO DE? (see page 1256)	<value> ::= {EQUAL   NOTEQUAL   LESSthan   GREATERthan   INRange   OUTRange}
:SEARch:SERial:I2S:PA TTern:DATA <string> (see page 1257)	:SEARch:SERial:I2S:PA TTern:DATA? (see page 1257)	<string> ::= "n" where n ::= 32-bit integer in signed decimal when <base> = DECimal  <string> ::= "nn...n" where n ::= {0   1   X} when <base> = BINary  <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X} when <base> = HEX
:SEARch:SERial:I2S:PA TTern:FORMAT <base> (see page 1258)	:SEARch:SERial:I2S:PA TTern:FORMAT? (see page 1258)	<base> ::= {BINary   HEX   DECimal}
:SEARch:SERial:I2S:RA NGe <lower>, <upper> (see page 1259)	:SEARch:SERial:I2S:RA NGe? (see page 1259)	<lower> ::= 32-bit integer in signed decimal, <nondecimal>, or <string>  <upper> ::= 32-bit integer in signed decimal, <nondecimal>, or <string>  <nondecimal> ::= #Hnn...n where n ::= {0,...,9   A,...,F} for hexadecimal  <nondecimal> ::= #Bnn...n where n ::= {0   1} for binary  <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F} for hexadecimal

**Table 55** :SEARch:SERial:IIC Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:IIC:MO DE <value> (see <a href="#">page 1261</a> )	:SEARch:SERial:IIC:MO DE? (see <a href="#">page 1261</a> )	<value> ::= {REStart   ADDRess   ANACK   NACKnowledge   READEprom   READ7   WRITE7   R7Data2   W7Data2}
:SEARch:SERial:IIC:PA TTern:ADDRess <value> (see <a href="#">page 1263</a> )	:SEARch:SERial:IIC:PA TTern:ADDRess? (see <a href="#">page 1263</a> )	<value> ::= integer or <string> <string> ::= "0xnn" n ::= {0,...,9   A,...,F}
:SEARch:SERial:IIC:PA TTern:DATA <value> (see <a href="#">page 1264</a> )	:SEARch:SERial:IIC:PA TTern:DATA? (see <a href="#">page 1264</a> )	<value> ::= integer or <string> <string> ::= "0xnn" n ::= {0,...,9   A,...,F}
:SEARch:SERial:IIC:PA TTern:DATA2 <value> (see <a href="#">page 1265</a> )	:SEARch:SERial:IIC:PA TTern:DATA2? (see <a href="#">page 1265</a> )	<value> ::= integer or <string> <string> ::= "0xnn" n ::= {0,...,9   A,...,F}
:SEARch:SERial:IIC:QU ALifier <value> (see <a href="#">page 1266</a> )	:SEARch:SERial:IIC:QU ALifier? (see <a href="#">page 1266</a> )	<value> ::= {EQUAL   NOTEqual   LESSthan   GREaterthan}

**Table 56** :SEARch:SERial:LIN Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:LIN:ID <value> (see <a href="#">page 1268</a> )	:SEARch:SERial:LIN:ID ? (see <a href="#">page 1268</a> )	<value> ::= 7-bit integer in decimal, <nondecimal>, or <string> from 0-63 or 0x00-0x3f <nondecimal> ::= #Hnn where n ::= {0,...,9   A,...,F} for hexadecimal <nondecimal> ::= #Bnn...n where n ::= {0   1} for binary <string> ::= "0xnn" where n ::= {0,...,9   A,...,F} for hexadecimal
:SEARch:SERial:LIN:MO DE <value> (see <a href="#">page 1269</a> )	:SEARch:SERial:LIN:MO DE? (see <a href="#">page 1269</a> )	<value> ::= {ID   DATA   ERROR}

**Table 56** :SEARch:SERial:LIN Commands Summary (continued)

Command	Query	Options and Query Returns
:SEARch:SERial:LIN:PA TTern:DATA <string> (see <a href="#">page 1270</a> )	:SEARch:SERial:LIN:PA TTern:DATA? (see <a href="#">page 1270</a> )	When :SEARch:SERial:LIN:PATTern:FORMat DECimal, <string> ::= "n" where n ::= 32-bit integer in unsigned decimal, returns "\$" if data has any don't cares When :SEARch:SERial:LIN:PATTern:FORMat HEX, <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X}
:SEARch:SERial:LIN:PA TTern:DATA:LENGTH <length> (see <a href="#">page 1271</a> )	:SEARch:SERial:LIN:PA TTern:DATA:LENGTH? (see <a href="#">page 1271</a> )	<length> ::= integer from 1 to 8 in NR1 format
:SEARch:SERial:LIN:PA TTern:FORMAT <base> (see <a href="#">page 1272</a> )	:SEARch:SERial:LIN:PA TTern:FORMAT? (see <a href="#">page 1272</a> )	<base> ::= {HEX   DECimal}
:SEARch:SERial:LIN:SY MBolic:FRAMe <name> (see <a href="#">page 1273</a> )	:SEARch:SERial:LIN:SY MBolic:FRAMe? (see <a href="#">page 1273</a> )	<name> ::= quoted ASCII string
:SEARch:SERial:LIN:SY MBolic:SIGNal <name> (see <a href="#">page 1274</a> )	:SEARch:SERial:LIN:SY MBolic:SIGNal? (see <a href="#">page 1274</a> )	<name> ::= quoted ASCII string
:SEARch:SERial:LIN:SY MBolic:VALue <data> (see <a href="#">page 1275</a> )	:SEARch:SERial:LIN:SY MBolic:VALue? (see <a href="#">page 1275</a> )	<data> ::= value in NR3 format

**Table 57** :SEARch:SERial:M1553 Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:M1553: MODE <value> (see <a href="#">page 1277</a> )	:SEARch:SERial:M1553: MODE? (see <a href="#">page 1277</a> )	<value> ::= {DSTArt   CSTArt   RTA   RTA11   PERRor   SERRor   MERRor}

**Table 57** :SEARch:SERial:M1553 Commands Summary (continued)

Command	Query	Options and Query Returns
:SEARch:SERial:M1553:PATTern:DATA <string> (see page 1278)	:SEARch:SERial:M1553:PATTern:DATA? (see page 1278)	<string> ::= "nn...n" where n ::= {0   1}
:SEARch:SERial:M1553:RTA <value> (see page 1279)	:SEARch:SERial:M1553:RTA? (see page 1279)	<value> ::= 5-bit integer in decimal, <hexadecimal>, <binary>, or <string> from 0-31 <hexadecimal> ::= #Hnn where n ::= {0,...,9 A,...,F} <binary> ::= #Bnn...n where n ::= {0   1} for binary <string> ::= "0xnn" where n ::= {0,...,9 A,...,F}

**Table 58** :SEARch:SERial:SENT Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:SENT:FAST:DATA <string> (see page 1281)	:SEARch:SERial:SENT:FAST:DATA? (see page 1281)	<string> ::= "0xn..." where n ::= {0,...,9   A,...,F   X   \$}
:SEARch:SERial:SENT:MODE <mode> (see page 1282)	:SEARch:SERial:SENT:MODE? (see page 1282)	<mode> ::= {FCData   SCMid   SCData   CRCerror PPERror}
:SEARch:SERial:SENT:SLOW:DATA <data> (see page 1283)	:SEARch:SERial:SENT:SLOW:DATA? (see page 1283)	<data> ::= from -1 (don't care) to 65535, in NR1 format.
:SEARch:SERial:SENT:SLOW:ID <id> (see page 1284)	:SEARch:SERial:SENT:SLOW:ID? (see page 1284)	<id> ::= from -1 (don't care) to 255, in NR1 format.

**Table 59** :SEARch:SERial:SPI Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:SPI:MODE <value> (see page 1286)	:SEARch:SERial:SPI:MODE? (see page 1286)	<value> ::= {MOSI   MISO}

**Table 59** :SEARch:SERial:SPI Commands Summary (continued)

Command	Query	Options and Query Returns
:SEARch:SERial:SPI:PA TTern:DATA <string> (see page 1287)	:SEARch:SERial:SPI:PA TTern:DATA? (see page 1287)	<string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X}
:SEARch:SERial:SPI:PA TTern:WIDTH <width> (see page 1288)	:SEARch:SERial:SPI:PA TTern:WIDTH? (see page 1288)	<width> ::= integer from 1 to 10

**Table 60** :SEARch:SERial:UART Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:UART:D ATA <value> (see page 1290)	:SEARch:SERial:UART:D ATA? (see page 1290)	<value> ::= 8-bit integer from 0-255 (0x00-0xff) in decimal, <hexadecimal>, <binary>, or <quoted_string> format <hexadecimal> ::= #Hnn where n ::= {0,...,9   A,...,F} for hexadecimal <binary> ::= #Bnn...n where n ::= {0   1} for binary <quoted_string> ::= any of the 128 valid 7-bit ASCII characters (or standard abbreviations)
:SEARch:SERial:UART:M ODE <value> (see page 1291)	:SEARch:SERial:UART:M ODE? (see page 1291)	<value> ::= {RDATa   RD1   RD0   RDX   TDATA   TD1   TD0   TDX   PARityerror   AERRor}
:SEARch:SERial:UART:Q UALifier <value> (see page 1292)	:SEARch:SERial:UART:Q UALifier? (see page 1292)	<value> ::= {EQUAL   NOTEqual   GREaterthan   LESSthan}

**Table 61** :SEARch:SERial:USB Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:USB:MO DE <condition> (see page 1295)	:SEARch:SERial:USB:MO DE? (see page 1295)	<event> ::= {TOKEN   DATA   HANDshake   SPECial   ALLerrors   PIDerror   CRC5error   CRC16error   GLITCHerror   STUFFerror   SE1error}
:SEARch:SERial:USB:AD DRess <string> (see page 1296)	:SEARch:SERial:USB:AD DRess? (see page 1296)	<string> ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}

**Table 61** :SEARch:SERial:USB Commands Summary (continued)

Command	Query	Options and Query Returns
:SEARch:SERial:USB:CR C <string> (see <a href="#">page 1297</a> )	:SEARch:SERial:USB:CR C? (see <a href="#">page 1297</a> )	<string> ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}
:SEARch:SERial:USB:DA TA <string> (see <a href="#">page 1298</a> )	:SEARch:SERial:USB:DA TA? (see <a href="#">page 1298</a> )	<string> ::= "0xn..." where n ::= {0,...,9   A,...,F   X   \$}
:SEARch:SERial:USB:DA TA:LENGth <value> (see <a href="#">page 1299</a> )	:SEARch:SERial:USB:DA TA:LENGth? (see <a href="#">page 1299</a> )	<length> ::= data length between 1-20
:SEARch:SERial:USB:EN DPoint <string> (see <a href="#">page 1300</a> )	:SEARch:SERial:USB:EN DPoint? (see <a href="#">page 1300</a> )	<string> ::= "0xn" where n ::= {0,...,9   A,...,F   X   \$}
:SEARch:SERial:USB:ET <string> (see <a href="#">page 1301</a> )	:SEARch:SERial:USB:ET ? (see <a href="#">page 1301</a> )	<string> ::= "0xn" where n ::= {0   1   2   3   X   \$}
:SEARch:SERial:USB:FR AMe <string> (see <a href="#">page 1302</a> )	:SEARch:SERial:USB:FR AMe? (see <a href="#">page 1302</a> )	<string> ::= "0xnnn" where n ::= {0,...,9   A,...,F   X   \$}
:SEARch:SERial:USB:HA DDress <string> (see <a href="#">page 1303</a> )	:SEARch:SERial:USB:HA DDress? (see <a href="#">page 1303</a> )	<string> ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}
:SEARch:SERial:USB:PI D:DATA <pid> (see <a href="#">page 1304</a> )	:SEARch:SERial:USB:PI D:DATA? (see <a href="#">page 1304</a> )	<pid> ::= {DATA0   DATA1   DATA2   MDATA}
:SEARch:SERial:USB:PI D:HAndshake <pid> (see <a href="#">page 1305</a> )	:SEARch:SERial:USB:PI D:HAndshake? (see <a href="#">page 1305</a> )	<pid> ::= {ACK   NAK   STALL   NYET}
:SEARch:SERial:USB:PI D:SPECial <pid> (see <a href="#">page 1306</a> )	:SEARch:SERial:USB:PI D:SPECial? (see <a href="#">page 1306</a> )	<pid> ::= {PING   PRE   ERR   SPLIt}
:SEARch:SERial:USB:PI D:TOKen <pid> (see <a href="#">page 1307</a> )	:SEARch:SERial:USB:PI D:TOKen? (see <a href="#">page 1307</a> )	<pid> ::= {OUT   IN   SETup   SOF}
:SEARch:SERial:USB:PO RT <string> (see <a href="#">page 1308</a> )	:SEARch:SERial:USB:PO RT? (see <a href="#">page 1308</a> )	<string> ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}

**Table 61** :SEARch:SERial:USB Commands Summary (continued)

Command	Query	Options and Query Returns
:SEARch:SERial:USB:SC<string> (see page 1309)	:SEARch:SERial:USB:SC? (see page 1309)	<string> ::= "0xn" where n ::= {0   1   X   \$}
:SEARch:SERial:USB:SEU <string> (see page 1310)	:SEARch:SERial:USB:SEU? (see page 1310)	<string> ::= "0xn" where n ::= {0   1   2   3   X   \$}

**Table 62** :SYSTem Commands Summary

Command	Query	Options and Query Returns
:SYSTem:DATE <date> (see page 1314)	:SYSTem:DATE? (see page 1314)	<date> ::= <year>,<month>,<day> <year> ::= 4-digit year in NR1 format <month> ::= {1,...,12   JANuary   FEBruary   MARch   APRil   MAY   JUNe   JULy   AUGust   SEPtember   OCTober   NOVember   DECember} <day> ::= {1,...31}
n/a	:SYSTem:DIDentifier? (see page 1315)	n/a
:SYSTem:DSP <string> (see page 1316)	n/a	<string> ::= up to 75 characters as a quoted ASCII string
n/a	:SYSTem:ERRor? (see page 1317)	<error> ::= an integer error code <error string> ::= quoted ASCII string. See Error Messages (see page 1605).
:SYSTem:LOCK <value> (see page 1318)	:SYSTem:LOCK? (see page 1318)	<value> ::= {{1   ON}   {0   OFF}}
:SYSTem:PERsona [:MANufacturer]<manufacturer_string> (see page 1319)	:SYSTem:PERsona [:MANufacturer]? (see page 1319)	<manufacturer_string> ::= quoted ASCII string, up to 63 characters
:SYSTem:PERsona [:MANufacturer] :DEFault (see page 1320)	n/a	Sets manufacturer string to "KEYSIGHT TECHNOLOGIES"
:SYSTem:PRESet (see page 1321)	n/a	See :SYSTem:PRESet (see page 1321)

**Table 62** :SYSTem Commands Summary (continued)

Command	Query	Options and Query Returns
:SYSTem:PROTection:LOCK <value> (see page 1324)	:SYSTem:PROTection:LOCK? (see page 1324)	<value> ::= {{1   ON}   {0   OFF}}
:SYSTem:RLOGger <setting>[,<file_name>[,<write_mode>]] (see page 1325)	n/a	<setting> ::= {0   OFF}   {1   ON} <file_name> ::= quoted ASCII string <write_mode> ::= {CREATE   APPEND}
:SYSTem:RLOGger:DESTination <dest> (see page 1326)	:SYSTem:RLOGger:DESTination? (see page 1326)	<dest> ::= {FILE   SCReen   BOTH}
:SYSTem:RLOGger:DISPLAY {{0   OFF}   {1   ON}} (see page 1327)	:SYSTem:RLOGger:DISPLAY? (see page 1327)	<setting> ::= {0   1}
:SYSTem:RLOGger:FNAME <file_name> (see page 1328)	:SYSTem:RLOGger:FNAME? (see page 1328)	<file_name> ::= quoted ASCII string
:SYSTem:RLOGger:STATE {{0   OFF}   {1   ON}} (see page 1329)	:SYSTem:RLOGger:STATE? (see page 1329)	<setting> ::= {0   1}
:SYSTem:RLOGger:TRANSparent {{0   OFF}   {1   ON}} (see page 1330)	:SYSTem:RLOGger:TRANSparent? (see page 1330)	<setting> ::= {0   1}
:SYSTem:RLOGger:WMODe <write_mode> (see page 1331)	:SYSTem:RLOGger:WMODe? (see page 1331)	<write_mode> ::= {CREATE   APPEND}
:SYSTem:SETup <setup_data> (see page 1332)	:SYSTem:SETup? (see page 1332)	<setup_data> ::= data in IEEE 488.2 # format.
:SYSTem:TIME <time> (see page 1334)	:SYSTem:TIME? (see page 1334)	<time> ::= hours,minutes,seconds in NR1 format
:SYSTem:TOUCH {{1   ON}   {0   OFF}} (see page 1335)	:SYSTem:TOUCH? (see page 1335)	{1   0}

**Table 63** :TIMEbase Commands Summary

Command	Query	Options and Query Returns
:TIMEbase:MODE <value> (see <a href="#">page 1339</a> )	:TIMEbase:MODE? (see <a href="#">page 1339</a> )	<value> ::= {MAIN   WINDOW   XY   ROLL}
:TIMEbase:POSITION <pos> (see <a href="#">page 1340</a> )	:TIMEbase:POSITION? (see <a href="#">page 1340</a> )	<pos> ::= time from the trigger event to the display reference point in NR3 format
:TIMEbase:RANGE <range_value> (see <a href="#">page 1341</a> )	:TIMEbase:RANGE? (see <a href="#">page 1341</a> )	<range_value> ::= time for 10 div in seconds in NR3 format
:TIMEbase:REFERENCE {LEFT   CENTER   RIGHT   CUSTOM} (see <a href="#">page 1342</a> )	:TIMEbase:REFERENCE? (see <a href="#">page 1342</a> )	<return_value> ::= {LEFT   CENTER   RIGHT   CUSTOM}
:TIMEbase:REFERENCE:LOCATION <loc> (see <a href="#">page 1343</a> )	:TIMEbase:REFERENCE:LOCATION? (see <a href="#">page 1343</a> )	<loc> ::= 0.0 to 1.0 in NR3 format
:TIMEbase:SCALE <scale_value> (see <a href="#">page 1344</a> )	:TIMEbase:SCALE? (see <a href="#">page 1344</a> )	<scale_value> ::= time/div in seconds in NR3 format
:TIMEbase:VERNier {{0   OFF}   {1   ON}} (see <a href="#">page 1345</a> )	:TIMEbase:VERNier? (see <a href="#">page 1345</a> )	{0   1}
:TIMEbase:WINDOW:POSITION <pos> (see <a href="#">page 1346</a> )	:TIMEbase:WINDOW:POSITION? (see <a href="#">page 1346</a> )	<pos> ::= time from the trigger event to the zoomed view reference point in NR3 format
:TIMEbase:WINDOW:RANGE <range_value> (see <a href="#">page 1347</a> )	:TIMEbase:WINDOW:RANGE? (see <a href="#">page 1347</a> )	<range_value> ::= range value in seconds in NR3 format for the zoomed window
:TIMEbase:WINDOW:SCALE <scale_value> (see <a href="#">page 1348</a> )	:TIMEbase:WINDOW:SCALE? (see <a href="#">page 1348</a> )	<scale_value> ::= scale value in seconds in NR3 format for the zoomed window

**Table 64** General :TRIGger Commands Summary

Command	Query	Options and Query Returns
:TRIGger:FORCe (see <a href="#">page 1353</a> )	n/a	n/a
:TRIGger:HFReject {{0   OFF}   {1   ON}} (see <a href="#">page 1354</a> )	:TRIGger:HFReject? (see <a href="#">page 1354</a> )	{0   1}

**Table 64** General :TRIGger Commands Summary (continued)

Command	Query	Options and Query Returns
:TRIGger:HOLDoff <holdoff_time> (see page 1355)	:TRIGger:HOLDoff? (see page 1355)	<holdoff_time> ::= 60 ns to 10 s in NR3 format
:TRIGger:HOLDoff:MAXimum <max_holdoff> (see page 1356)	:TRIGger:HOLDoff:MAXimum? (see page 1356)	<max_holdoff> ::= maximum holdoff time in seconds in NR3 format
:TRIGger:HOLDoff:MINimum <min_holdoff> (see page 1357)	:TRIGger:HOLDoff:MINimum? (see page 1357)	<min_holdoff> ::= minimum holdoff time in seconds in NR3 format
:TRIGger:HOLDoff:RANDom {{0   OFF}   {1   ON}} (see page 1358)	:TRIGger:HOLDoff:RANDom? (see page 1358)	<setting> ::= {0   1}
:TRIGger:LEVel:ASETup (see page 1359)	n/a	n/a
:TRIGger:LEVel:HIGH <level>, <source> (see page 1360)	:TRIGger:LEVel:HIGH? <source> (see page 1360)	<level> ::= .75 x full-scale voltage from center screen in NR3 format.  <source> ::= CHANnel<n>  <n> ::= 1 to (# analog channels) in NR1 format
:TRIGger:LEVel:LOW <level>, <source> (see page 1361)	:TRIGger:LEVel:LOW? <source> (see page 1361)	<level> ::= .75 x full-scale voltage from center screen in NR3 format.  <source> ::= CHANnel<n>  <n> ::= 1 to (# analog channels) in NR1 format
:TRIGger:MODE <mode> (see page 1362)	:TRIGger:MODE? (see page 1362)	<mode> ::= {EDGE   GLITch   PATTern   TV   DELay   EBURst   OR   RUNT   SHOLD   TRANSition   SBUS{1   2}}  <return_value> ::= {<mode>   <none>}  <none> ::= query returns "NONE" if the :TIMEbase:MODE is ROLL or XY
:TRIGger:NREJect {{0   OFF}   {1   ON}} (see page 1363)	:TRIGger:NREJect? (see page 1363)	{0   1}
:TRIGger:SWEep <sweep> (see page 1364)	:TRIGger:SWEep? (see page 1364)	<sweep> ::= {AUTO   NORMAL}

**Table 65** :TRIGger:DELay Commands Summary

Command	Query	Options and Query Returns
:TRIGger:DELay:ARM:SL OPe <slope> (see <a href="#">page 1366</a> )	:TRIGger:DELay:ARM:SL OPe? (see <a href="#">page 1366</a> )	<slope> ::= {NEGative   POSitive}
:TRIGger:DELay:ARM:SO URce <source> (see <a href="#">page 1367</a> )	:TRIGger:DELay:ARM:SO URce? (see <a href="#">page 1367</a> )	<source> ::= {CHANnel<n>   DIGital<d>} <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:TRIGger:DELay:TDELay :TIME <time_value> (see <a href="#">page 1368</a> )	:TRIGger:DELay:TDELay :TIME? (see <a href="#">page 1368</a> )	<time_value> ::= time in seconds in NR3 format
:TRIGger:DELay:TRIGge r:COUNT <count> (see <a href="#">page 1369</a> )	:TRIGger:DELay:TRIGge r:COUNT? (see <a href="#">page 1369</a> )	<count> ::= integer in NR1 format
:TRIGger:DELay:TRIGge r:SLOPe <slope> (see <a href="#">page 1370</a> )	:TRIGger:DELay:TRIGge r:SLOPe? (see <a href="#">page 1370</a> )	<slope> ::= {NEGative   POSitive}
:TRIGger:DELay:TRIGge r:SOURce <source> (see <a href="#">page 1371</a> )	:TRIGger:DELay:TRIGge r:SOURce? (see <a href="#">page 1371</a> )	<source> ::= {CHANnel<n>   DIGital<d>} <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format

**Table 66** :TRIGger:EBURst Commands Summary

Command	Query	Options and Query Returns
:TRIGger:EBURst:COUNT <count> (see <a href="#">page 1373</a> )	:TRIGger:EBURst:COUNT ? (see <a href="#">page 1373</a> )	<count> ::= integer in NR1 format
:TRIGger:EBURst:IDLE <time_value> (see <a href="#">page 1374</a> )	:TRIGger:EBURst:IDLE? (see <a href="#">page 1374</a> )	<time_value> ::= time in seconds in NR3 format

**Table 66** :TRIGger:EBURst Commands Summary (continued)

Command	Query	Options and Query Returns
:TRIGger:EBURst:SLOPe <slope> (see <a href="#">page 1375</a> )	:TRIGger:EBURst:SLOPe ? (see <a href="#">page 1375</a> )	<slope> ::= {NEGative   POSitive}
:TRIGger:EBURst:SOURce <source> (see <a href="#">page 1376</a> )	:TRIGger:EBURst:SOURce? (see <a href="#">page 1376</a> )	<source> ::= {CHANnel<n>   DIGItal<d>} <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format

**Table 67** :TRIGger[:EDGE] Commands Summary

Command	Query	Options and Query Returns
:TRIGger[:EDGE] :COUPLing {AC   DC   LFReject} (see <a href="#">page 1379</a> )	:TRIGger[:EDGE] :COUPLing? (see <a href="#">page 1379</a> )	{AC   DC   LFReject}
:TRIGger[:EDGE] :LEVel <level> [,<source>] (see <a href="#">page 1380</a> )	:TRIGger[:EDGE] :LEVel ? [<source>] (see <a href="#">page 1380</a> )	For internal triggers, <level> ::= .75 x full-scale voltage from center screen in NR3 format.  For external triggers, <level> ::= ±(external range setting) in NR3 format.  For digital channels (MSO models), <level> ::= ±8 V.  <source> ::= {CHANnel<n>   EXTernal} for DSO models  <source> ::= {CHANnel<n>   DIGItal<d>   EXTernal } for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:TRIGger[:EDGE] :REJect {OFF   LFReject   HFReject} (see <a href="#">page 1381</a> )	:TRIGger[:EDGE] :REJect? (see <a href="#">page 1381</a> )	{OFF   LFReject   HFReject}

**Table 67** :TRIGger[:EDGE] Commands Summary (continued)

Command	Query	Options and Query Returns
:TRIGger[:EDGE]:SLOPe <polarity> (see page 1382)	:TRIGger[:EDGE]:SLOPe? ? (see <a href="#">page 1382</a> )	<polarity> ::= {POSitive   NEGative   EITHer   ALTernate}
:TRIGger[:EDGE]:SOURce <source> (see page 1383)	:TRIGger[:EDGE]:SOURce? ? (see <a href="#">page 1383</a> )	<source> ::= {CHANnel<n>   EXTERNAL   LINE   WGEN} for the DSO models <source> ::= {CHANnel<n>   DIGItal<d>   EXTERNAL   LINE   WGEN} for the MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format

**Table 68** :TRIGger:GLITch Commands Summary

Command	Query	Options and Query Returns
:TRIGger:GLITch:GREAt erthan <greater_than_time>[s uffix] (see <a href="#">page 1386</a> )	:TRIGger:GLITch:GREAt erthan? ? (see <a href="#">page 1386</a> )	<greater_than_time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}
:TRIGger:GLITch:LESSt han <less_than_time>[suff ix] (see <a href="#">page 1387</a> )	:TRIGger:GLITch:LESSt han? ? (see <a href="#">page 1387</a> )	<less_than_time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}

**Table 68** :TRIGger:GLITch Commands Summary (continued)

Command	Query	Options and Query Returns
:TRIGger:GLITch:LEVel <level> [<source>] (see <a href="#">page 1388</a> )	:TRIGger:GLITch:LEVel ? (see <a href="#">page 1388</a> )	For internal triggers, <level> :::= .75 x full-scale voltage from center screen in NR3 format.  For external triggers (DSO models), <level> :::= ±(external range setting) in NR3 format.  For digital channels (MSO models), <level> :::= ±8 V.  <source> :::= {CHANnel<n>   EXTERNAL} for DSO models  <source> :::= {CHANnel<n>   DIGItal<d>} for MSO models  <n> :::= 1 to (# analog channels) in NR1 format  <d> :::= 0 to (# digital channels - 1) in NR1 format
:TRIGger:GLITch:POLArity <polarity> (see <a href="#">page 1389</a> )	:TRIGger:GLITch:POLArity? (see <a href="#">page 1389</a> )	<polarity> :::= {POSitive   NEGative}
:TRIGger:GLITch:QUALifier <qualifier> (see <a href="#">page 1390</a> )	:TRIGger:GLITch:QUALifier? (see <a href="#">page 1390</a> )	<qualifier> :::= {GREaterthan   LESSthan   RANGE}
:TRIGger:GLITch:RANGE <less_than_time>[suffix], <greater_than_time>[suffix] (see <a href="#">page 1391</a> )	:TRIGger:GLITch:RANGE ? (see <a href="#">page 1391</a> )	<less_than_time> :::= 15 ns to 10 seconds in NR3 format  <greater_than_time> :::= 10 ns to 9.99 seconds in NR3 format  [suffix] :::= {s   ms   us   ns   ps}
:TRIGger:GLITch:SOURce <source> (see <a href="#">page 1392</a> )	:TRIGger:GLITch:SOURce? (see <a href="#">page 1392</a> )	<source> :::= {CHANnel<n>   DIGItal<d>}  <n> :::= 1 to (# analog channels) in NR1 format  <d> :::= 0 to (# digital channels - 1) in NR1 format

**Table 69** :TRIGger:NFC Commands Summary

Command	Query	Options and Query Returns
:TRIGger:NFC:AEvent <arm_event> (see page 1394)	:TRIGger:NFC:AEvent? (see <a href="#">page 1394</a> )	<arm_event> ::= {NONE   ASReq   AALLreq   AEITher   BSReq   BALLreq   BEITher   FSReq}
n/a	:TRIGger:NFC:ATTime? (see <a href="#">page 1395</a> )	<time> ::= seconds in NR3 format
:TRIGger:NFC:RPOLarit y {{0   OFF}   {1   ON}} (see <a href="#">page 1396</a> )	:TRIGger:NFC:RPOLarit y? (see <a href="#">page 1396</a> )	{0   1}
:TRIGger:NFC:SOURce <source> (see page 1397)	:TRIGger:NFC:SOURce? (see <a href="#">page 1397</a> )	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:TRIGger:NFC:STANDARD <standard> (see page 1398)	:TRIGger:NFC:STANDARD ? (see <a href="#">page 1398</a> )	<standard> ::= {{A   A106}   {B   B106}   F212   F424}
:TRIGger:NFC:TEVENT <trigger_event> (see page 1399)	:TRIGger:NFC:TEVENT? (see <a href="#">page 1399</a> )	<trigger_event> ::= {ATRigger   ASReq   AALLreq   AEITher   ASDDreq   BSReq   BALLreq   BEITher   BATTrib   FSReq   FAReq   FPReqamble}
n/a	:TRIGger:NFC:TIMEout? (see <a href="#">page 1401</a> )	{0   1}
:TRIGger:NFC:TIMEout: ENABLE {{0   OFF}   {1   ON}} (see page 1402)	:TRIGger:NFC:TIMEout: ENABLE? (see <a href="#">page 1402</a> )	{0   1}
:TRIGger:NFC:TIMEout: TIME <time> (see page 1403)	:TRIGger:NFC:TIMEout: TIME? (see <a href="#">page 1403</a> )	<time> ::= seconds in NR3 format

**Table 70** :TRIGger:OR Commands Summary

Command	Query	Options and Query Returns
:TRIGger:OR <string> (see <a href="#">page 1405</a> )	:TRIGger:OR? (see <a href="#">page 1405</a> )	<p>&lt;string&gt; ::= "nn...n" where n ::= {R   F   E   X}</p> <p>R = rising edge, F = falling edge, E = either edge, X = don't care.</p> <p>Each character in the string is for an analog or digital channel as shown on the front panel display.</p>

**Table 71** :TRIGger:PATTern Commands Summary

Command	Query	Options and Query Returns
:TRIGger:PATTern <string>[,<edge_source>,<edge>] (see <a href="#">page 1407</a> )	:TRIGger:PATTern? (see <a href="#">page 1408</a> )	<p>&lt;string&gt; ::= "nn...n" where n ::= {0   1   X   R   F} when &lt;base&gt; = ASCII &lt;string&gt; ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$} when &lt;base&gt; = HEX</p> <p>&lt;edge_source&gt; ::= {CHANnel&lt;n&gt;   NONE} for DSO models</p> <p>&lt;edge_source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   NONE} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;edge&gt; ::= {POSitive   NEGative}</p>
:TRIGger:PATTern:FORM at <base> (see <a href="#">page 1409</a> )	:TRIGger:PATTern:FORM at? (see <a href="#">page 1409</a> )	<base> ::= {ASCII   HEX}
:TRIGger:PATTern:GREaterthan <greater_than_time>[suffix] (see <a href="#">page 1410</a> )	:TRIGger:PATTern:GREaterthan? (see <a href="#">page 1410</a> )	<p>&lt;greater_than_time&gt; ::= floating-point number in NR3 format</p> <p>[suffix] ::= {s   ms   us   ns   ps}</p>
:TRIGger:PATTern:LESS than <less_than_time>[suffix] (see <a href="#">page 1411</a> )	:TRIGger:PATTern:LESS than? (see <a href="#">page 1411</a> )	<p>&lt;less_than_time&gt; ::= floating-point number in NR3 format</p> <p>[suffix] ::= {s   ms   us   ns   ps}</p>

**Table 71** :TRIGger:PATTERn Commands Summary (continued)

Command	Query	Options and Query Returns
:TRIGger:PATTERn:QUALifier <qualifier> (see page 1412)	:TRIGger:PATTERn:QUALifier? (see page 1412)	<qualifier> ::= {ENTERed   GREaterthan   LESSthan   INRange   OUTRange   TIMEout}
:TRIGger:PATTERn:RANGE <less_than_time>[suffix], <greater_than_time>[suffix] (see page 1413)	:TRIGger:PATTERn:RANGE? (see page 1413)	<less_than_time> ::= 15 ns to 10 seconds in NR3 format <greater_than_time> ::= 10 ns to 9.99 seconds in NR3 format [suffix] ::= {s   ms   us   ns   ps}

**Table 72** :TRIGger:RUNT Commands Summary

Command	Query	Options and Query Returns
:TRIGger:RUNT:POLarity <polarity> (see page 1415)	:TRIGger:RUNT:POLarity? (see page 1415)	<polarity> ::= {POSitive   NEGative   EITHer}
:TRIGger:RUNT:QUALifier <qualifier> (see page 1416)	:TRIGger:RUNT:QUALifier? (see page 1416)	<qualifier> ::= {GREaterthan   LESSthan   NONE}
:TRIGger:RUNT:SOURce <source> (see page 1417)	:TRIGger:RUNT:SOURce? (see page 1417)	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:TRIGger:RUNT:TIME <time>[suffix] (see page 1418)	:TRIGger:RUNT:TIME? (see page 1418)	<time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}

**Table 73** :TRIGger:SHOLD Commands Summary

Command	Query	Options and Query Returns
:TRIGger:SHOLD:SLOPe <slope> (see page 1420)	:TRIGger:SHOLD:SLOPe? (see page 1420)	<slope> ::= {NEGative   POSitive}
:TRIGger:SHOLD:SOURce:CLOCK <source> (see page 1421)	:TRIGger:SHOLD:SOURce:CLOCK? (see page 1421)	<source> ::= {CHANnel<n>   DIGital<d>} <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format

**Table 73** :TRIGger:SHOLD Commands Summary (continued)

Command	Query	Options and Query Returns
:TRIGger:SHOLD:SOURce :DATA <source> (see page 1422)	:TRIGger:SHOLD:SOURce :DATA? (see page 1422)	<source> ::= {CHANnel<n>   DIGItal<d>} <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:TRIGger:SHOLD:TIME:H OLD <time>[suffix] (see page 1423)	:TRIGger:SHOLD:TIME:H OLD? (see page 1423)	<time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}
:TRIGger:SHOLD:TIME:S ETup <time>[suffix] (see page 1424)	:TRIGger:SHOLD:TIME:S ETup? (see page 1424)	<time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}

**Table 74** :TRIGger:TRANSition Commands Summary

Command	Query	Options and Query Returns
:TRIGger:TRANSition:Q UALifier <qualifier> (see page 1426)	:TRIGger:TRANSition:Q UALifier? (see page 1426)	<qualifier> ::= {GREaterthan   LESSthan}
:TRIGger:TRANSition:S LOPe <slope> (see page 1427)	:TRIGger:TRANSition:S LOPe? (see page 1427)	<slope> ::= {NEGative   POSitive}
:TRIGger:TRANSition:S OURce <source> (see page 1428)	:TRIGger:TRANSition:S OURce? (see page 1428)	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:TRIGger:TRANSition:T IME <time>[suffix] (see page 1429)	:TRIGger:TRANSition:T IME? (see page 1429)	<time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}

**Table 75** :TRIGger:TV Commands Summary

Command	Query	Options and Query Returns
:TRIGger:TV:LINE <line number> (see <a href="#">page 1431</a> )	:TRIGger:TV:LINE? (see <a href="#">page 1431</a> )	<line number> ::= integer in NR1 format
:TRIGger:TV:MODE <tv mode> (see <a href="#">page 1432</a> )	:TRIGger:TV:MODE? (see <a href="#">page 1432</a> )	<tv mode> ::= {FIELD1   FIELD2   AFIELDS   ALINES   LINE   LFIELD1   LFIELD2   LATERNATE}
:TRIGger:TV:POLarity <polarity> (see <a href="#">page 1433</a> )	:TRIGger:TV:POLarity? (see <a href="#">page 1433</a> )	<polarity> ::= {POSITIVE   NEGATIVE}
:TRIGger:TV:SOURce <source> (see <a href="#">page 1434</a> )	:TRIGger:TV:SOURce? (see <a href="#">page 1434</a> )	<source> ::= {CHANNEL<n>} <n> ::= 1 to (# analog channels) in NR1 format
:TRIGger:TV:STANDARD <standard> (see <a href="#">page 1435</a> )	:TRIGger:TV:STANDARD? (see <a href="#">page 1435</a> )	<standard> ::= {NTSC   PAL   PALM   SECAM}  <standard> ::= {GENERIC   {P480L60HZ   P480}   {P720L60HZ   P720}   {P1080L24HZ   P1080}   P1080L25HZ   P1080L50HZ   P1080L60HZ   {I1080L50HZ   I1080}   I1080L60HZ} with extended video triggering license
:TRIGger:TV:UDTV:ENUM ber <count> (see <a href="#">page 1436</a> )	:TRIGger:TV:UDTV:ENUM ber? (see <a href="#">page 1436</a> )	<count> ::= edge number in NR1 format
:TRIGger:TV:UDTV:HSYN c {{0   OFF}   {1   ON}} (see <a href="#">page 1437</a> )	:TRIGger:TV:UDTV:HSYN c? (see <a href="#">page 1437</a> )	{0   1}
:TRIGger:TV:UDTV:HTIM e <time> (see <a href="#">page 1438</a> )	:TRIGger:TV:UDTV:HTIM e? (see <a href="#">page 1438</a> )	<time> ::= seconds in NR3 format
:TRIGger:TV:UDTV:PGTH an <min_time> (see <a href="#">page 1439</a> )	:TRIGger:TV:UDTV:PGTH an? (see <a href="#">page 1439</a> )	<min_time> ::= seconds in NR3 format

**Table 76** :TRIGger:USB Commands Summary

Command	Query	Options and Query Returns
:TRIGger:USB:SOURce:D MINus <source> (see <a href="#">page 1441</a> )	:TRIGger:USB:SOURce:D MINus? (see <a href="#">page 1441</a> )	<source> ::= {CHANnel<n>   EXTernal} for the DSO models  <source> ::= {CHANnel<n>   DIGItal<d>} for the MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:TRIGger:USB:SOURce:D PLus <source> (see <a href="#">page 1442</a> )	:TRIGger:USB:SOURce:D PLus? (see <a href="#">page 1442</a> )	<source> ::= {CHANnel<n>   EXTernal} for the DSO models  <source> ::= {CHANnel<n>   DIGItal<d>} for the MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:TRIGger:USB:SPEed <value> (see <a href="#">page 1443</a> )	:TRIGger:USB:SPEed? (see <a href="#">page 1443</a> )	<value> ::= {LOW   FULL}
:TRIGger:USB:TRIGGER <value> (see <a href="#">page 1444</a> )	:TRIGger:USB:TRIGGER? (see <a href="#">page 1444</a> )	<value> ::= {SOP   EOP   ENTerSuspend   EXITsuspend   RESet}

**Table 77** :TRIGger:ZONE Commands Summary

Command	Query	Options and Query Returns
:TRIGger:ZONE:SOURce <source> (see <a href="#">page 1446</a> )	:TRIGger:ZONE:SOURce? (see <a href="#">page 1446</a> )	<source> ::= {CHANnel<n>}  <n> ::= 1 to (# analog channels) in NR1 format
:TRIGger:ZONE:STATE { {0   OFF}   {1   ON} } (see <a href="#">page 1447</a> )	:TRIGger:ZONE:STATE? (see <a href="#">page 1447</a> )	{0   1}
:TRIGger:ZONE<n>:MODE <mode> (see <a href="#">page 1448</a> )	:TRIGger:ZONE<n>:MODE ? (see <a href="#">page 1448</a> )	<mode> ::= {INTersect   NOTintersect}  <n> ::= 1-2 in NR1 format

**Table 77** :TRIGger:ZONE Commands Summary (continued)

Command	Query	Options and Query Returns
:TRIGger:ZONE<n>:PLACEMENT <width>, <height>, <x_center>, <y_center> (see page 1449)	:TRIGger:ZONE<n>:PLACEMENT? (see page 1449)	<width> ::= width of zone in seconds <height> ::= height of zone in volts <x_center> ::= center of zone in seconds <y_center> ::= center of zone in volts <n> ::= 1-2 in NR1 format
n/a	:TRIGger:ZONE<n>:VALIDITY? (see page 1450)	<value> ::= {VALid   INValid   OSCReen} <n> ::= 1-2 in NR1 format
:TRIGger:ZONE<n>:STATE {{0   OFF}   {1   ON}} (see page 1451)	:TRIGger:ZONE<n>:STATE? (see page 1451)	{0   1} <n> ::= 1-2 in NR1 format

**Table 78** :WAVEform Commands Summary

Command	Query	Options and Query Returns
:WAVEform:BYTeorder <value> (see page 1461)	:WAVEform:BYTeorder? (see page 1461)	<value> ::= {LSBFFirst   MSBFFirst}
n/a	:WAVEform:COUNT? (see page 1462)	<count> ::= an integer from 1 to 65536 in NR1 format
n/a	:WAVEform:DATA? (see page 1463)	<binary block length bytes>, <binary data> For example, to transmit 1000 bytes of data, the syntax would be: #800001000<1000 bytes of data><NL> 8 is the number of digits that follow 00001000 is the number of bytes to be transmitted <1000 bytes of data> is the actual data
:WAVEform:FORMAT <value> (see page 1465)	:WAVEform:FORMAT? (see page 1465)	<value> ::= {WORD   BYTE   ASCII}

**Table 78** :WAVEform Commands Summary (continued)

Command	Query	Options and Query Returns
:WAVEform:POINTs <# points> (see <a href="#">page 1466</a> )	:WAVEform:POINTs? (see <a href="#">page 1466</a> )	<# points> ::= {100   250   500   1000   <points_mode>} if waveform points mode is NORMAl  <# points> ::= {100   250   500   1000   2000 ... 8000000 in 1-2-5 sequence   <points_mode>} if waveform points mode is MAXimum or RAW  <points_mode> ::= {NORMAl   MAXimum   RAW}
:WAVEform:POINTs:MODE <points_mode> (see <a href="#">page 1468</a> )	:WAVEform:POINTs:MODE? (see <a href="#">page 1468</a> )	<points_mode> ::= {NORMAl   MAXimum   RAW}
n/a	:WAVEform:PREamble? (see <a href="#">page 1470</a> )	<preamble_block> ::= <format NR1>, <type NR1>, <points NR1>, <count NR1>, <xincrement NR3>, <xorigin NR3>, <xreference NR1>, <yincrement NR3>, <yorigin NR3>, <yreference NR1>  <format> ::= an integer in NR1 format: <ul style="list-style-type: none"><li>• 0 for BYTE format</li><li>• 1 for WORD format</li><li>• 2 for ASCii format</li></ul> <type> ::= an integer in NR1 format: <ul style="list-style-type: none"><li>• 0 for NORMAl type</li><li>• 1 for PEAK detect type</li><li>• 3 for AVERage type</li><li>• 4 for HRESolution type</li></ul> <count> ::= Average count, or 1 if PEAK detect type or NORMAl; an integer in NR1 format
:WAVEform:SEGmented:A LL {{0   OFF}   {1   ON}} (see <a href="#">page 1473</a> )	:WAVEform:SEGmented:A LL? (see <a href="#">page 1473</a> )	<setting> ::= {0   1}
n/a	:WAVEform:SEGmented:C OUNT? (see <a href="#">page 1474</a> )	<count> ::= an integer from 2 to 1000 in NR1 format
n/a	:WAVEform:SEGmented:T TAG? (see <a href="#">page 1475</a> )	<time_tag> ::= in NR3 format

**Table 78** :WAVEform Commands Summary (continued)

Command	Query	Options and Query Returns
n/a	:WAVEform:SEGmented:XLIST? <xlist_type> (see <a href="#">page 1476</a> )	<xlist_type> ::= {RELXorigin   ABSXorigin   TTAG} <return_value> ::= X-info for all segments
:WAVEform:SOURce <source> (see <a href="#">page 1477</a> )	:WAVEform:SOURce? (see <a href="#">page 1477</a> )	<source> ::= {CHANnel<n>   FUNCtion<m>   MATH<m>   FFT   SBUS} for DSO models  <source> ::= {CHANnel<n>   POD{1   2}   BUS{1   2}   FUNCtion<m>   MATH<m>   FFT   SBUS} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <m> ::= 1 to (# math functions) in NR1 format
:WAVEform:SOURce:SUBSource <subsource> (see <a href="#">page 1481</a> )	:WAVEform:SOURce:SUBSource? (see <a href="#">page 1481</a> )	<subsource> ::= {{SUB0   RX   MOSI}   {SUB1   TX   MISO}}
n/a	:WAVEform:TYPE? (see <a href="#">page 1482</a> )	<return_mode> ::= {NORM   PEAK   AVER   HRES}
:WAVEform:UNSIGNED {{0   OFF}   {1   ON}} (see <a href="#">page 1483</a> )	:WAVEform:UNSIGNED? (see <a href="#">page 1483</a> )	{0   1}
:WAVEform:VIEW <view> (see <a href="#">page 1484</a> )	:WAVEform:VIEW? (see <a href="#">page 1484</a> )	<view> ::= {MAIN   ALL}
n/a	:WAVEform:XINCREMENT? (see <a href="#">page 1485</a> )	<return_value> ::= x-increment in the current preamble in NR3 format
n/a	:WAVEform:XORIGIN? (see <a href="#">page 1486</a> )	<return_value> ::= x-origin value in the current preamble in NR3 format
n/a	:WAVEform:XREFERENCE? (see <a href="#">page 1487</a> )	<return_value> ::= 0 (x-reference value in the current preamble in NR1 format)
n/a	:WAVEform:YINCREMENT? (see <a href="#">page 1488</a> )	<return_value> ::= y-increment value in the current preamble in NR3 format

**Table 78** :WAVEform Commands Summary (continued)

Command	Query	Options and Query Returns
n/a	:WAVEform:YORigin? (see <a href="#">page 1489</a> )	<return_value> ::= y-origin in the current preamble in NR3 format
n/a	:WAVEform:YREFerence? (see <a href="#">page 1490</a> )	<return_value> ::= y-reference value in the current preamble in NR1 format

**Table 79** :WGEN<w> Commands Summary

Command	Query	Options and Query Returns
:WGEN<w>:ARBitrary:BYTeorder <order> (see <a href="#">page 1496</a> )	:WGEN<w>:ARBitrary:BYTeorder? (see <a href="#">page 1496</a> )	<order> ::= {MSBFIRST   LSBFIRST} <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:ARBitrary:DAT {<binary>   <value>, <value> ...} (see <a href="#">page 1497</a> )	n/a	<binary> ::= floating point values between -1.0 to +1.0 in IEEE 488.2 binary block format <value> ::= floating point values between -1.0 to +1.0 in comma-separated format <w> ::= 1 to (# WaveGen outputs) in NR1 format
n/a	:WGEN<w>:ARBitrary:DAT:ATTRibute:POINTs? (see <a href="#">page 1500</a> )	<points> ::= number of points in NR1 format <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:ARBitrary:DAT:CLEar (see <a href="#">page 1501</a> )	n/a	<w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:ARBitrary:DAT:DAC {<binary>   <value>, <value> ...} (see <a href="#">page 1502</a> )	n/a	<binary> ::= decimal 16-bit integer values between -512 to +511 in IEEE 488.2 binary block format <value> ::= decimal integer values between -512 to +511 in comma-separated NR1 format <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:ARBitrary:INTerpolate {{0   OFF}   {1   ON}} (see <a href="#">page 1503</a> )	:WGEN<w>:ARBitrary:INTerpolate? (see <a href="#">page 1503</a> )	{0   1} <w> ::= 1 to (# WaveGen outputs) in NR1 format

**Table 79** :WGEN<w> Commands Summary (continued)

Command	Query	Options and Query Returns
:WGEN<w>:ARBitrary:STORe <source> (see page 1504)	n/a	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   WMEMory&lt;r&gt;   FUNCTion&lt;m&gt;   FFT   MATH&lt;m&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</p>
:WGEN<w>:FREQuency <frequency> (see page 1505)	:WGEN<w>:FREQuency? (see page 1505)	<p>&lt;frequency&gt; ::= frequency in Hz in NR3 format</p> <p>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</p>
:WGEN<w>:FUNCTion <signal> (see page 1506)	:WGEN<w>:FUNCTion? (see page 1509)	<p>&lt;signal&gt; ::= {SINusoid   SQUARE   RAMP   PULSE   NOISE   DC   SINC   EXPRIse   EXPFall   CARDiac   GAUSSian   ARBitrary}</p> <p>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</p>
:WGEN<w>:FUNCTion:PULSe:WIDTh <width> (see page 1510)	:WGEN<w>:FUNCTion:PULSe:WIDTh? (see page 1510)	<p>&lt;width&gt; ::= pulse width in seconds in NR3 format</p> <p>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</p>
:WGEN<w>:FUNCTion:RAMP:SYMMetry <percent> (see page 1511)	:WGEN<w>:FUNCTion:RAMP:SYMMetry? (see page 1511)	<p>&lt;percent&gt; ::= symmetry percentage from 0% to 100% in NR1 format</p> <p>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</p>
:WGEN<w>:FUNCTion:SQUARE:DCYCle <percent> (see page 1512)	:WGEN<w>:FUNCTion:SQUARE:DCYCle? (see page 1512)	<p>&lt;percent&gt; ::= duty cycle percentage from 20% to 80% in NR1 format</p> <p>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</p>
:WGEN<w>:MODulation:AM:DEPTH <percent> (see page 1513)	:WGEN<w>:MODulation:AM:DEPTH? (see page 1513)	<p>&lt;percent&gt; ::= AM depth percentage from 0% to 100% in NR1 format</p> <p>&lt;w&gt; ::= 1 in NR1 format</p>

**Table 79** :WGEN<w> Commands Summary (continued)

Command	Query	Options and Query Returns
:WGEN<w>:MODulation:A M:FREQuency <frequency> (see <a href="#">page 1514</a> )	:WGEN<w>:MODulation:A M:FREQuency? (see <a href="#">page 1514</a> )	<frequency> ::= modulating waveform frequency in Hz in NR3 format <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:F M:DEViation <frequency> (see <a href="#">page 1515</a> )	:WGEN<w>:MODulation:F M:DEViation? (see <a href="#">page 1515</a> )	<frequency> ::= frequency deviation in Hz in NR3 format <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:F M:FREQuency <frequency> (see <a href="#">page 1516</a> )	:WGEN<w>:MODulation:F M:FREQuency? (see <a href="#">page 1516</a> )	<frequency> ::= modulating waveform frequency in Hz in NR3 format <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:F SKey:FREQuency <percent> (see <a href="#">page 1517</a> )	:WGEN<w>:MODulation:F SKey:FREQuency? (see <a href="#">page 1517</a> )	<frequency> ::= hop frequency in Hz in NR3 format <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:F SKey:RATE <rate> (see <a href="#">page 1518</a> )	:WGEN<w>:MODulation:F SKey:RATE? (see <a href="#">page 1518</a> )	<rate> ::= FSK modulation rate in Hz in NR3 format <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:F UNCTion <shape> (see <a href="#">page 1519</a> )	:WGEN<w>:MODulation:F UNCTion? (see <a href="#">page 1519</a> )	<shape> ::= {SINusoid   SQUare   RAMP} <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:F UNCTion:RAMP:SYMMetry <percent> (see <a href="#">page 1520</a> )	:WGEN<w>:MODulation:F UNCTion:RAMP:SYMMetry ? (see <a href="#">page 1520</a> )	<percent> ::= symmetry percentage from 0% to 100% in NR1 format <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:N OISE <percent> (see <a href="#">page 1521</a> )	:WGEN<w>:MODulation:N OISE? (see <a href="#">page 1521</a> )	<percent> ::= 0 to 100 <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:S TATE {{0   OFF}   {1   ON}} (see <a href="#">page 1522</a> )	:WGEN<w>:MODulation:S TATE? (see <a href="#">page 1522</a> )	{0   1} <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:T YPE <type> (see <a href="#">page 1523</a> )	:WGEN<w>:MODulation:T YPE? (see <a href="#">page 1523</a> )	<type> ::= {AM   FM   FSK} <w> ::= 1 in NR1 format
:WGEN<w>:OUTPut {{0   OFF}   {1   ON}} (see <a href="#">page 1525</a> )	:WGEN<w>:OUTPut? (see <a href="#">page 1525</a> )	{0   1} <w> ::= 1 to (# WaveGen outputs) in NR1 format

**Table 79** :WGEN<w> Commands Summary (continued)

Command	Query	Options and Query Returns
:WGEN<w>:OUTPut:LOAD <impedance> (see <a href="#">page 1526</a> )	:WGEN<w>:OUTPut:LOAD? (see <a href="#">page 1526</a> )	<impedance> ::= {ONEMeg   FIFTy} <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:OUTPut:MODE <mode> (see <a href="#">page 1527</a> )	:WGEN<w>:OUTPut:MODE? (see <a href="#">page 1527</a> )	<mode> ::= {NORMAL   SINGLE}
:WGEN<w>:OUTPut:POLarity <polarity> (see <a href="#">page 1528</a> )	:WGEN<w>:OUTPut:POLarity? (see <a href="#">page 1528</a> )	<polarity> ::= {NORMAL   INVerted} <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:OUTPut:SINGLe (see <a href="#">page 1529</a> )	n/a	n/a
:WGEN<w>:PERiod <period> (see <a href="#">page 1530</a> )	:WGEN<w>:PERiod? (see <a href="#">page 1530</a> )	<period> ::= period in seconds in NR3 format <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:RST (see <a href="#">page 1531</a> )	n/a	<w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:VOLTage <amplitude> (see <a href="#">page 1532</a> )	:WGEN<w>:VOLTage? (see <a href="#">page 1532</a> )	<amplitude> ::= amplitude in volts in NR3 format <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:VOLTage:HIGH <high> (see <a href="#">page 1533</a> )	:WGEN<w>:VOLTage:HIGH? (see <a href="#">page 1533</a> )	<high> ::= high-level voltage in volts, in NR3 format <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:VOLTage:LOW <low> (see <a href="#">page 1534</a> )	:WGEN<w>:VOLTage:LOW? (see <a href="#">page 1534</a> )	<low> ::= low-level voltage in volts, in NR3 format <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:VOLTage:OFFSet <offset> (see <a href="#">page 1535</a> )	:WGEN<w>:VOLTage:OFFS et? (see <a href="#">page 1535</a> )	<offset> ::= offset in volts in NR3 format <w> ::= 1 to (# WaveGen outputs) in NR1 format

**Table 80** :WMEMory<r> Commands Summary

Command	Query	Options and Query Returns
:WMEMory<r>:CLEAR (see <a href="#">page 1539</a> )	n/a	<r> ::= 1 to (# ref waveforms) in NR1 format
:WMEMory<r>:DISPlay { {0   OFF}   {1   ON}} (see <a href="#">page 1540</a> )	:WMEMory<r>:DISPLAY? (see <a href="#">page 1540</a> )	<r> ::= 1 to (# ref waveforms) in NR1 format {0   1}
:WMEMory<r>:LABEL <string> (see <a href="#">page 1541</a> )	:WMEMory<r>:LABEL? (see <a href="#">page 1541</a> )	<r> ::= 1 to (# ref waveforms) in NR1 format <string> ::= any series of 10 or less ASCII characters enclosed in quotation marks
:WMEMory<r>:SAVE <source> (see <a href="#">page 1542</a> )	n/a	<r> ::= 1 to (# ref waveforms) in NR1 format <source> ::= {CHANnel<n>   FUNCTion<m>   MATH<m>} <n> ::= 1 to (# analog channels) in NR1 format <m> ::= 1 to (# math functions) in NR1 format NOTE: Math functions whose x-axis is not frequency can be saved as reference waveforms.
:WMEMory<r>:SKEW <skew> (see <a href="#">page 1543</a> )	:WMEMory<r>:SKEW? (see <a href="#">page 1543</a> )	<r> ::= 1 to (# ref waveforms) in NR1 format <skew> ::= time in seconds in NR3 format
:WMEMory<r>:YOFFset <offset>[suffix] (see <a href="#">page 1544</a> )	:WMEMory<r>:YOFFset? (see <a href="#">page 1544</a> )	<r> ::= 1 to (# ref waveforms) in NR1 format <offset> ::= vertical offset value in NR3 format [suffix] ::= {V   mV}

**Table 80** :WMEMory<r> Commands Summary (continued)

Command	Query	Options and Query Returns
:WMEMory<r>:YRANGE <range>[suffix] (see page 1545)	:WMEMory<r>:YRANGE? (see page 1545)	<r> ::= 1 to (# ref waveforms) in NR1 format  <range> ::= vertical full-scale range value in NR3 format  [suffix] ::= {V   mV}
:WMEMory<r>:YScale <scale>[suffix] (see page 1546)	:WMEMory<r>:YScale? (see page 1546)	<r> ::= 1 to (# ref waveforms) in NR1 format  <scale> ::= vertical units per division value in NR3 format  [suffix] ::= {V   mV}

## Syntax Elements

- "[Number Format](#)" on page 224
- "[<NL> \(Line Terminator\)](#)" on page 224
- "[\[ \] \(Optional Syntax Terms\)](#)" on page 224
- "[{ } \(Braces\)](#)" on page 224
- "[::= \(Defined As\)](#)" on page 224
- "[<> \(Angle Brackets\)](#)" on page 225
- "[... \(Ellipsis\)](#)" on page 225
- "[n,...,p \(Value Ranges\)](#)" on page 225
- "[d \(Digits\)](#)" on page 225
- "[Quoted ASCII String](#)" on page 225
- "[Definite-Length Block Response Data](#)" on page 225

### Number Format

NR1 specifies integer data.

NR3 specifies exponential data in floating point format (for example, -1.0E-3).

### <NL> (Line Terminator)

<NL> = new line or linefeed (ASCII decimal 10).

The line terminator, or a leading colon, will send the parser to the "root" of the command tree.

### [ ] (Optional Syntax Terms)

Items enclosed in square brackets, [ ], are optional.

### { } (Braces)

When several items are enclosed by braces, { }, only one of these elements may be selected. Vertical line ( | ) indicates "or". For example, {ON | OFF} indicates that only ON or OFF may be selected, not both.

### ::= (Defined As)

::= means "defined as".

For example, <A> ::= <B> indicates that <A> can be replaced by <B> in any statement containing <A>.

## < > (Angle Brackets)

< > Angle brackets enclose words or characters that symbolize a program code parameter or an interface command.

## ... (Ellipsis)

... An ellipsis (trailing dots) indicates that the preceding element may be repeated one or more times.

## n,...,p (Value Ranges)

n,...,p ::= all integers between n and p inclusive.

## d (Digits)

d ::= A single ASCII numeric character 0 - 9.

## Quoted ASCII String

A quoted ASCII string is a string delimited by either double quotes ("") or single quotes (''). Some command parameters require a quoted ASCII string. For example, when using the Keysight VISA COM library in Visual Basic, the command:

```
myScope.WriteString " :CHANNEL1:LABEL 'One'"
```

has a quoted ASCII string of:

```
'one'
```

In order to read quoted ASCII strings from query return values, some programming languages require special handling or syntax.

## Definite-Length Block Response Data

Definite-length block response data allows any type of device-dependent data to be transmitted over the system interface as a series of 8-bit binary data bytes. This is particularly useful for sending large quantities of data or 8-bit extended ASCII codes. This syntax is a pound sign (#) followed by a non-zero digit representing the number of digits in the decimal integer. After the non-zero digit is the decimal integer that states the number of 8-bit data bytes being sent. This is followed by the actual data.

For example, for transmitting 1000 bytes of data, the syntax would be

```
#800001000<1000 bytes of data> <NL>
```

**8** is the number of digits that follow

**00001000** is the number of bytes to be transmitted

**<1000 bytes of data>** is the actual data

# 6 Common (\*) Commands

Commands defined by IEEE 488.2 standard that are common to all instruments.  
See "[Introduction to Common \(\\*\) Commands](#)" on page 231.

**Table 81** Common (\*) Commands Summary

Command	Query	Options and Query Returns																																				
*CLS (see <a href="#">page 233</a> )	n/a	n/a																																				
*ESE <mask> (see <a href="#">page 234</a> )	*ESE? (see <a href="#">page 234</a> )	<p>&lt;mask&gt; ::= 0 to 255; an integer in NR1 format:</p> <table> <thead> <tr> <th>Bit</th> <th>Weight</th> <th>Name</th> <th>Enables</th> </tr> </thead> <tbody> <tr><td>7</td><td>128</td><td>PON</td><td>Power On</td></tr> <tr><td>6</td><td>64</td><td>URQ</td><td>User Request</td></tr> <tr><td>5</td><td>32</td><td>CME</td><td>Command Error</td></tr> <tr><td>4</td><td>16</td><td>EXE</td><td>Execution Error</td></tr> <tr><td>3</td><td>8</td><td>DDE</td><td>Dev. Dependent Error</td></tr> <tr><td>2</td><td>4</td><td>QYE</td><td>Query Error</td></tr> <tr><td>1</td><td>2</td><td>RQL</td><td>Request Control</td></tr> <tr><td>0</td><td>1</td><td>OPC</td><td>Operation Complete</td></tr> </tbody> </table>	Bit	Weight	Name	Enables	7	128	PON	Power On	6	64	URQ	User Request	5	32	CME	Command Error	4	16	EXE	Execution Error	3	8	DDE	Dev. Dependent Error	2	4	QYE	Query Error	1	2	RQL	Request Control	0	1	OPC	Operation Complete
Bit	Weight	Name	Enables																																			
7	128	PON	Power On																																			
6	64	URQ	User Request																																			
5	32	CME	Command Error																																			
4	16	EXE	Execution Error																																			
3	8	DDE	Dev. Dependent Error																																			
2	4	QYE	Query Error																																			
1	2	RQL	Request Control																																			
0	1	OPC	Operation Complete																																			
n/a	*ESR? (see <a href="#">page 236</a> )	<status> ::= 0 to 255; an integer in NR1 format																																				
n/a	*IDN? (see <a href="#">page 236</a> )	<p>KEYSIGHT TECHNOLOGIES,&lt;model&gt;,&lt;serial number&gt;,X.XX.XX</p> <p>&lt;model&gt; ::= the model number of the instrument</p> <p>&lt;serial number&gt; ::= the serial number of the instrument</p> <p>&lt;X.XX.XX&gt; ::= the software revision of the instrument</p>																																				
n/a	*LRN? (see <a href="#">page 239</a> )	<learn_string> ::= current instrument setup as a block of data in IEEE 488.2 # format																																				

**Table 81** Common (\*) Commands Summary (continued)

Command	Query	Options and Query Returns
*OPC (see page 240)	*OPC? (see page 240)	ASCII "1" is placed in the output queue when all pending device operations have completed.
n/a	*OPT? (see page 241)	<pre>&lt;return_value&gt; ::= 0,0,&lt;license info&gt;  &lt;license info&gt; ::= &lt;All field&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;MSO&gt;, &lt;reserved&gt;, &lt;Memory&gt;, &lt;Low Speed Serial&gt;, &lt;Automotive Serial&gt;, &lt;FlexRay Serial&gt;, &lt;Frequency Response Analysis&gt;, &lt;Power Measurements&gt;, &lt;RS-232/UART Serial&gt;, &lt;Segmented Memory&gt;, &lt;Mask Test&gt;, &lt;reserved&gt;, &lt;Bandwidth&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;I2S Serial&gt;, &lt;reserved&gt;, &lt;Educator's Kit&gt;, &lt;Waveform Generator&gt;, &lt;MIL-1553/ARINC 429 Serial&gt;, &lt;Extended Video&gt;, &lt;Advanced Math&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;Digital Voltmeter/Counter&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;reserved&gt;, &lt;Remote Command Logging&gt;, &lt;reserved&gt;, &lt;SENT Serial&gt;, &lt;CAN FD Serial&gt;, &lt;CXPI Serial&gt;, &lt;NFC Trigger&gt;, &lt;reserved&gt;"', &lt;reserved&gt;, &lt;reserved&gt;, &lt;Manchester/NRZ Serial&gt;, &lt;USB PD Serial&gt;, &lt;reserved&gt;, &lt;Automotive Software&gt;, &lt;General Purpose Software&gt;, &lt;Aerospace Software&gt;, &lt;Power Supply Test Software&gt;, &lt;reserved&gt;, &lt;Near Field Communications (NFC) Software&gt;, &lt;Software Bundle&gt;</pre>

**Table 81** Common (\*) Commands Summary (continued)

Command	Query	Options and Query Returns
n/a	*OPT? (see <a href="#">page 241</a> ) (cont'd)	<All field> ::= {0   All} <reserved> ::= 0 <MSO> ::= {0   MSO} <Memory> ::= {0   MEMUP} <Low Speed Serial> ::= {0   EMBD} <Automotive Serial> ::= {0   AUTO} <FlexRay Serial> ::= {0   FLEX} <Frequency Response Analysis> ::= {0   FRA} <Power Measurements> ::= {0   PWR} <RS-232/UART Serial> ::= {0   COMP} <Mask Test> ::= {0   MASK} <Bandwidth> ::= {0   BW20   BW50} <I2S Serial> ::= {0   AUDIO} <Educator's Kit> ::= {0   EDK} <Waveform Generator> ::= {0   WAVEGEN} <MIL-1553/ARINC 429 Serial> ::= {0   AERO} <Extended Video> ::= {0   VID} <Digital Voltmeter/Counter> ::= {0   DVMCTR} <Remote Command Logging> ::= {0   RML} <SENT Serial> ::= {0   SENSOR} <CAN FD Serial> ::= {0   CANFD} <CXPI Serial> ::= {0   CXPI} <NFC Trigger> ::= {0   NFC}

**Table 81** Common (\*) Commands Summary (continued)

Command	Query	Options and Query Returns
n/a	*OPT? (see <a href="#">page 241</a> ) (cont'd)	<Manchester/NRZ Serial> ::= {0   NRZ}  <USB PD Serial> ::= {0   USBPD}  <Automotive Software> ::= {0   D3000AUTA}  <General Purpose Software> ::= {0   D3000GENA}  <Aerospace Software> ::= {0   D3000AERA}  <Power Supply Test Software> ::= {0   D3000PWRA}  <Near Field Communications (NFC) Software> ::= {0   D3000NFCA}  <Software Bundle> ::= {0   D3000BDLA}
*RCL <value> (see <a href="#">page 243</a> )	n/a	<value> ::= {0   1   4   5   6   7   8   9}
*RST (see <a href="#">page 244</a> )	n/a	See *RST (Reset) (see <a href="#">page 244</a> )
*SAV <value> (see <a href="#">page 247</a> )	n/a	<value> ::= {0   1   4   5   6   7   8   9}
*SRE <mask> (see <a href="#">page 248</a> )	*SRE? (see <a href="#">page 249</a> )	<mask> ::= sum of all bits that are set, 0 to 255; an integer in NR1 format. <mask> ::= following values:  Bit Weight Name Enables --- ----- --- 7 128 OPER Operation Status Reg 6 64 ---- (Not used.) 5 32 ESB Event Status Bit 4 16 MAV Message Available 3 8 ---- (Not used.) 2 4 MSG Message 1 2 USR User 0 1 TRG Trigger

**Table 81** Common (\*) Commands Summary (continued)

Command	Query	Options and Query Returns																																				
n/a	*STB? (see <a href="#">page 250</a> )	<p>&lt;value&gt; ::= 0 to 255; an integer in NR1 format, as shown in the following:</p> <table> <thead> <tr> <th>Bit</th> <th>Weight</th> <th>Name</th> <th>Indicates</th> </tr> </thead> <tbody> <tr> <td>7</td> <td>128</td> <td>OPER</td> <td>Operation status condition occurred.</td> </tr> <tr> <td>6</td> <td>64</td> <td>RQS/</td> <td>Instrument is MSS requesting service.</td> </tr> <tr> <td>5</td> <td>32</td> <td>ESB</td> <td>Enabled event status condition occurred.</td> </tr> <tr> <td>4</td> <td>16</td> <td>MAV</td> <td>Message available.</td> </tr> <tr> <td>3</td> <td>8</td> <td>----</td> <td>(Not used.)</td> </tr> <tr> <td>2</td> <td>4</td> <td>MSG</td> <td>Message displayed.</td> </tr> <tr> <td>1</td> <td>2</td> <td>USR</td> <td>User event condition occurred.</td> </tr> <tr> <td>0</td> <td>1</td> <td>TRG</td> <td>A trigger occurred.</td> </tr> </tbody> </table>	Bit	Weight	Name	Indicates	7	128	OPER	Operation status condition occurred.	6	64	RQS/	Instrument is MSS requesting service.	5	32	ESB	Enabled event status condition occurred.	4	16	MAV	Message available.	3	8	----	(Not used.)	2	4	MSG	Message displayed.	1	2	USR	User event condition occurred.	0	1	TRG	A trigger occurred.
Bit	Weight	Name	Indicates																																			
7	128	OPER	Operation status condition occurred.																																			
6	64	RQS/	Instrument is MSS requesting service.																																			
5	32	ESB	Enabled event status condition occurred.																																			
4	16	MAV	Message available.																																			
3	8	----	(Not used.)																																			
2	4	MSG	Message displayed.																																			
1	2	USR	User event condition occurred.																																			
0	1	TRG	A trigger occurred.																																			
*TRG (see <a href="#">page 252</a> )	n/a	n/a																																				
n/a	*TST? (see <a href="#">page 253</a> )	<result> ::= 0 or non-zero value; an integer in NR1 format																																				
*WAI (see <a href="#">page 254</a> )	n/a	n/a																																				

### Introduction to Common (\*) Commands

The common commands are defined by the IEEE 488.2 standard. They are implemented by all instruments that comply with the IEEE 488.2 standard. They provide some of the basic instrument functions, such as instrument identification and reset, reading the instrument setup, and determining how status is read and cleared.

Common commands can be received and processed by the instrument whether they are sent over the interface as separate program messages or within other program messages. If an instrument subsystem has been selected and a common command is received by the instrument, the instrument remains in the selected subsystem. For example, if the program message ":ACQuire:TYPE AVERage; \*CLS; COUNT 256" is received by the instrument, the instrument sets the acquire type, then clears the status information and sets the average count.

In contrast, if a root level command or some other subsystem command is within the program message, you must re-enter the original subsystem after the command. For example, the program message ":ACQuire:TYPE AVERage; :AUToscale; :ACQuire:COUNT 256" sets the acquire type, completes the autoscale, then sets the acquire count. In this example, :ACQuire must be sent again after the :AUToscale command in order to re-enter the ACQuire subsystem and set the count.

**NOTE**

Each of the status registers has an enable (mask) register. By setting the bits in the enable register, you can select the status information you want to use.

---

## \*CLS (Clear Status)

 (see [page 1666](#))

### Command Syntax

`*CLS`

The \*CLS common command clears the status data structures, the device-defined error queue, and the Request-for-OPC flag.

### NOTE

If the \*CLS command immediately follows a program message terminator, the output queue and the MAV (message available) bit are cleared.

### See Also

- ["Introduction to Common \(\\*\) Commands"](#) on page 231
- ["\\*STB \(Read Status Byte\)"](#) on page 250
- ["\\*ESE \(Standard Event Status Enable\)"](#) on page 234
- ["\\*ESR \(Standard Event Status Register\)"](#) on page 236
- ["\\*SRE \(Service Request Enable\)"](#) on page 248
- [":SYSTem:ERRor"](#) on page 1317


## \*ESE (Standard Event Status Enable)

**C** (see [page 1666](#))

**Command Syntax** \*ESE <mask\_argument>

<mask\_argument> ::= integer from 0 to 255

The \*ESE common command sets the bits in the Standard Event Status Enable Register. The Standard Event Status Enable Register contains a mask value for the bits to be enabled in the Standard Event Status Register. A "1" in the Standard Event Status Enable Register enables the corresponding bit in the Standard Event Status Register. A zero disables the bit.



**Table 82** Standard Event Status Enable (ESE)

Bit	Name	Description	When Set (1 = High = True), Enables:
7	PON	Power On	Event when an OFF to ON transition occurs.
6	URQ	User Request	Event when a front-panel key is pressed.
5	CME	Command Error	Event when a command error is detected.
4	EXE	Execution Error	Event when an execution error is detected.
3	DDE	Device Dependent Error	Event when a device-dependent error is detected.
2	QYE	Query Error	Event when a query error is detected.
1	RQL	Request Control	Event when the device is requesting control. (Not used.)
0	OPC	Operation Complete	Event when an operation is complete.

**Query Syntax** \*ESE?

The \*ESE? query returns the current contents of the Standard Event Status Enable Register.

<b>Return Format</b>	<code>&lt;mask_argument&gt;&lt;NL&gt;</code> <code>&lt;mask_argument&gt; ::= 0, ..., 255; an integer in NR1 format.</code>
<b>See Also</b>	<ul style="list-style-type: none"><li>• <a href="#">"Introduction to Common (*) Commands" on page 231</a></li><li>• <a href="#">"*ESR (Standard Event Status Register)" on page 236</a></li><li>• <a href="#">"*OPC (Operation Complete)" on page 240</a></li><li>• <a href="#">"*CLS (Clear Status)" on page 233</a></li></ul>


## \*ESR (Standard Event Status Register)

**C** (see [page 1666](#))

Query Syntax \*ESR?

The \*ESR? query returns the contents of the Standard Event Status Register. When you read the Event Status Register, the value returned is the total bit weights of all of the bits that are high at the time you read the byte. Reading the register clears the Event Status Register.

The following table shows bit weight, name, and condition for each bit.



**Table 83** Standard Event Status Register (ESR)

Bit	Name	Description	When Set (1 = High = True), Indicates:
7	PON	Power On	An OFF to ON transition has occurred.
6	URQ	User Request	A front-panel key has been pressed.
5	CME	Command Error	A command error has been detected.
4	EXE	Execution Error	An execution error has been detected.
3	DDE	Device Dependent Error	A device-dependent error has been detected.
2	QYE	Query Error	A query error has been detected.
1	RQL	Request Control	The device is requesting control. (Not used.)
0	OPC	Operation Complete	Operation is complete.

Return Format <status><NL>

<status> ::= 0, ..., 255; an integer in NR1 format.

**NOTE**

Reading the Standard Event Status Register clears it. High or 1 indicates the bit is true.

---

**See Also**

- ["Introduction to Common \(\\*\) Commands"](#) on page 231
- ["\\*ESE \(Standard Event Status Enable\)"](#) on page 234
- ["\\*OPC \(Operation Complete\)"](#) on page 240
- ["\\*CLS \(Clear Status\)"](#) on page 233
- [":SYSTem:ERRor"](#) on page 1317

## \*IDN (Identification Number)

 (see [page 1666](#))

**Query Syntax** \*IDN?

The \*IDN? query identifies the instrument type and software version.

**Return Format**

```
<manufacturer_string>,<model>,<serial_number>,X.XX.XX <NL>
<manufacturer_string> ::= KEYSIGHT TECHNOLOGIES
<model> ::= the model number of the instrument
<serial_number> ::= the serial number of the instrument
X.XX.XX ::= the software revision of the instrument
```

**See Also**

- "[Introduction to Common \(\\*\) Commands](#)" on page 231
- "["\\*OPT \(Option Identification\)"](#) on page 241
- "[":SYSTem:PERSONa\[:MANufacturer\]"](#) on page 1319
- "[":SYSTem:PERSONa\[:MANufacturer\]:DEFault"](#) on page 1320

## \*LRN (Learn Device Setup)

 (see [page 1666](#))

### Query Syntax

`*LRN?`

The `*LRN?` query result contains the current state of the instrument. This query is similar to the `:SYST:SEUp?` (see [page 1332](#)) query, except that it contains `".SYST:SET "` before the binary block data. The query result is a valid command that can be used to restore instrument settings at a later time.

### Return Format

```
<learn_string><NL>
<learn_string> ::= :SYST:SET <setup_data>
<setup_data> ::= binary block data in IEEE 488.2 # format
```

`<learn_string>` specifies the current instrument setup. The block size is subject to change with different firmware revisions.

### NOTE

The `*LRN?` query return format has changed from previous Keysight oscilloscopes to match the IEEE 488.2 specification which says that the query result must contain `".SYST:SET "` before the binary block data.

### See Also

- ["Introduction to Common \(\\*\) Commands"](#) on page 231
- ["\\*\\*RCL \(Recall\)"](#) on page 243
- ["\\*\\*SAV \(Save\)"](#) on page 247
- [":SYST:SEUp"](#) on page 1332

## \*OPC (Operation Complete)

 (see [page 1666](#))

### Command Syntax

`*OPC`

The `*OPC` command sets the operation complete bit in the Standard Event Status Register when all pending device operations have finished.

You can use the `*ESR?` query to look at the OPC bit (bit 0) in the Standard Event Status Register to determine when an operation is complete.

### NOTE

The front-panel graphical user interface can disable most of the remote interface, including the `*OPC` syntax, in certain situations. Bit 4 in the Operation Status Condition Register shows whether the remote user interface is enabled or disabled. For more information, see [":OPERegister:CONDition \(Operation Status Condition Register\)" on page 280](#).

### Query Syntax

`*OPC?`

The `*OPC?` query places an ASCII "1" in the output queue when all pending device operations have completed. The interface hangs until this query returns.

The `*OPC?` query can be used between overlapped commands to make sure one is complete before the next one begins. The `*OPC?` query can also be used to pause a controller program until an operation is complete.

### Return Format

`<complete><NL>`

`<complete> ::= 1`

### See Also

- ["Introduction to Common \(\\*\) Commands" on page 231](#)
- ["\\*\\*ESE \(Standard Event Status Enable\)" on page 234](#)
- ["\\*\\*ESR \(Standard Event Status Register\)" on page 236](#)
- ["\\*\\*CLS \(Clear Status\)" on page 233](#)
- [":OPERegister:CONDition \(Operation Status Condition Register\)" on page 280](#)
- [":OPERegister\[:EVENT\] \(Operation Status Event Register\)" on page 283](#)
- [Chapter 4, "Sequential \(Blocking\) vs. Overlapped Commands," starting on page 87](#)
- ["Synchronization with an Averaging Acquisition" on page 1652](#)
- ["Set Up the Oscilloscope" on page 1646](#)
- ["Example: Blocking and Polling Synchronization" on page 1654](#)
- ["Example: Waiting for IO Operation Complete" on page 1642](#)

## \*OPT (Option Identification)

**C** (see [page 1666](#))

**Query Syntax** \*OPT?

The \*OPT? query reports the options installed in the instrument. This query returns a string that identifies the module and its software revision level.

**Return Format** 0,0,<license info>

```

<license info> ::= <All field>, <reserved>, <reserved>, <MSO>,
    <reserved>, <Memory>, <Low Speed Serial>, <Automotive Serial>,
    <FlexRay Serial>, <Frequency Response Analysis>,
    <Power Measurements>, <RS-232/UART Serial>, <Segmented Memory>,
    <Mask Test>, <reserved>, <Bandwidth>, <reserved>, <reserved>,
    <reserved>, <reserved>, <reserved>, <reserved>, <I2S Serial>,
    <reserved>, <Educator's Kit>, <Waveform Generator>,
    <MIL-1553/ARINC 429 Serial>, <Extended Video>, <Advanced Math>,
    <reserved>, <reserved>, <reserved>, <reserved>,
    <Digital Voltmeter/Counter>, <reserved>, <reserved>, <reserved>,
    <reserved>, <reserved>, <Remote Command Logging>, <reserved>,
    <SENT Serial>, <CAN FD Serial>, <CXPI Serial>, <NFC Trigger>,
    <reserved>", <reserved>, <reserved>, <Manchester/NRZ Serial>,
    <USB PD Serial>, <reserved>, <Automotive Software>,
    <General Purpose Software>, <Aerospace Software>,
    <Power Supply Test Software>, <USB Test Software>,
    <Near Field Communications (NFC) Software>, <Software Bundle>

<All field> ::= {0 | All}

<reserved> ::= 0

<MSO> ::= {0 | MSO}

<Memory> ::= {0 | memMax}

<Low Speed Serial> ::= {0 | EMBD}

<Automotive Serial> ::= {0 | AUTO}

<FlexRay Serial> ::= {0 | FLEX}

<Frequency Response Analysis> ::= {0 | FRA}

<Power Measurements> ::= {0 | PWR}

<RS-232/UART Serial> ::= {0 | COMP}

<Segmented Memory> ::= {0 | SGM}

<Mask Test> ::= {0 | MASK}

<Bandwidth> ::= {0 | BW50}

<I2S Serial> ::= {0 | AUDIO}

<Educator's Kit> ::= {0 | EDK}

<Waveform Generator> ::= {0 | WAVEGEN}

```

```
<MIL-1553/ARINC 429 Serial> ::= {0 | AERO}
<Extended Video> ::= {0 | VID}
<Advanced Math> ::= {0 | ADVMATH}
<Digital Voltmeter/Counter>> ::= {0 | DVMCTR}
<Remote Command Logging> ::= {0 | RML}
<SENT Serial> ::= {0 | SENSOR}
<CAN FD Serial> ::= {0 | CANFD}
<CXPI Serial> ::= {0 | CXPI}
<NFC Trigger> ::= {0 | NFC}
<Manchester/NRZ Serial> ::= {0 | NRZ}
<USB PD Serial> ::= {0 | USBPD}
<Automotive Software> ::= {0 | D3000AUTA}
<General Purpose Software> ::= {0 | D3000GENA}
<Aerospace Software> ::= {0 | D3000AERA}
<Power Supply Test Software> ::= {0 | D3000PWRA}
<USB Test Software> ::= {0 | D3000USBA}
<Near Field Communications (NFC) Software> ::= {0 | D3000NFCA}
<Software Bundle> ::= {0 | D3000BDLA}
```

The **<MSO>** field indicates whether the unit is a mixed-signal oscilloscope.

The \*OPT? query returns the following:

- See Also**

  - ["Introduction to Common \(\\*\) Commands" on page 231](#)
  - ["IDN \(Identification Number\)" on page 238](#)

## \*RCL (Recall)

 (see [page 1666](#))

**Command Syntax** \*RCL <value>

<value> ::= {0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9}

The \*RCL command restores the state of the instrument from the specified save/recall register.

**See Also** • ["Introduction to Common \(\\*\) Commands" on page 231](#)  
• ["\\*SAV \(Save\)" on page 247](#)

## \*RST (Reset)

 (see [page 1666](#))

### Command Syntax

\*RST

The \*RST command places the instrument in a known state. This is the same as pressing [**Save/Recall**] > **Default/Erase** > **Factory Default** on the front panel.

When you perform a factory default setup, there are no user settings that remain unchanged. To perform the equivalent of the front panel's [**Default Setup**] key, where some user settings (like preferences) remain unchanged, use the :SYSTem:PRESet command.

Reset conditions are:

Acquire Menu	
Mode	Normal
Averaging	Off
# Averages	8

Analog Channel Menu	
Channel 1	On
Channel 2	Off
Volts/division	5.00 V
Offset	0.00
Coupling	DC
Probe attenuation	AutoProbe (if AutoProbe is connected), otherwise 1.0:1
Vernier	Off
Invert	Off
BW limit	Off
Impedance	1 M Ohm
Units	Volts
Skew	0

Cursor Menu	
Source	Channel 1

<b>Digital Channel Menu (MSO models only)</b>	
Channel 0 - 15	Off
Labels	Off
Threshold	TTL (1.4 V)

<b>Display Menu</b>	
Persistence	Off
Grid	20%

<b>Quick Meas Menu</b>	
Source	Channel 1

<b>Run Control</b>	
	Scope is running

<b>Time Base Menu</b>	
Main time/division	100 us
Main time base delay	0.00 s
Delay time/division	500 ns
Delay time base delay	0.00 s
Reference	center
Mode	main
Vernier	Off

<b>Trigger Menu</b>	
Type	Edge
Mode	Auto
Coupling	dc
Source	Channel 1
Level	0.0 V
Slope	Positive

Trigger Menu	
HF Reject and noise reject	Off
Holdoff	40 ns
External probe attenuation	10:1
External Units	Volts
External Impedance	1 M Ohm (cannot be changed)

- See Also
- "[Introduction to Common \(\\*\) Commands](#)" on page 231
  - "[":SYSTem:PRESet](#)" on page 1321

Example Code

```

' RESET - This command puts the oscilloscope into a known state.
' This statement is very important for programs to work as expected.
' Most of the following initialization commands are initialized by
' *RST. It is not necessary to reinitialize them unless the default
' setting is not suitable for your application.
myScope.WriteString "*RST"  ' Reset the oscilloscope to the defaults.

```

See complete example programs at: [Chapter 46](#), "Programming Examples," starting on page 1675

## \*SAV (Save)

 (see [page 1666](#))

**Command Syntax** \*SAV <value>

```
<value> ::= {0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9}
```

The \*SAV command stores the current state of the instrument in a save register. The data parameter specifies the register where the data will be saved.

**See Also** • ["Introduction to Common \(\\*\) Commands" on page 231](#)  
• ["\\*RCL \(Recall\)" on page 243](#)


## \*SRE (Service Request Enable)

**C** (see [page 1666](#))

**Command Syntax** \*SRE <mask>

<mask> ::= integer with values defined in the following table.

The \*SRE command sets the bits in the Service Request Enable Register. The Service Request Enable Register contains a mask value for the bits to be enabled in the Status Byte Register. A one in the Service Request Enable Register enables the corresponding bit in the Status Byte Register. A zero disables the bit.



**Table 84** Service Request Enable Register (SRE)

Bit	Name	Description	When Set (1 = High = True), Enables:
7	OPER	Operation Status Register	Interrupts when enabled conditions in the Operation Status Register (OPER) occur.
6	---	---	(Not used.)
5	ESB	Event Status Bit	Interrupts when enabled conditions in the Standard Event Status Register (ESR) occur.
4	MAV	Message Available	Interrupts when messages are in the Output Queue.
3	---	---	(Not used.)
2	MSG	Message	Interrupts when an advisory has been displayed on the oscilloscope.
1	USR	User Event	Interrupts when enabled user event conditions occur.
0	TRG	Trigger	Interrupts when a trigger occurs.

Query Syntax \*SRE?

The \*SRE? query returns the current value of the Service Request Enable Register.

Return Format &lt;mask&gt;&lt;NL&gt;

```
<mask> ::= sum of all bits that are set, 0,...,255;
an integer in NR1 format
```

See Also

- ["Introduction to Common \(\\*\) Commands"](#) on page 231
- ["\\*STB \(Read Status Byte\)"](#) on page 250
- ["\\*CLS \(Clear Status\)"](#) on page 233

## \*STB (Read Status Byte)


**C** (see [page 1666](#))

**Query Syntax** \*STB?

The \*STB? query returns the current value of the instrument's status byte. The MSS (Master Summary Status) bit is reported on bit 6 instead of the RQS (request service) bit. The MSS indicates whether or not the device has at least one reason for requesting service.

**Return Format** <value><NL>

<value> ::= 0, ..., 255; an integer in NR1 format



**Table 85** Status Byte Register (STB)

Bit	Name	Description	When Set (1 = High = True), Indicates:
7	OPER	Operation Status Register	An enabled condition in the Operation Status Register (OPER) has occurred.
6	RQS	Request Service	When polled, that the device is requesting service.
	MSS	Master Summary Status	When read (by *STB?), whether the device has a reason for requesting service.
5	ESB	Event Status Bit	An enabled condition in the Standard Event Status Register (ESR) has occurred.
4	MAV	Message Available	There are messages in the Output Queue.
3	---	---	(Not used, always 0.)
2	MSG	Message	An advisory has been displayed on the oscilloscope.
1	USR	User Event	An enabled user event condition has occurred.
0	TRG	Trigger	A trigger has occurred.

**NOTE**

To read the instrument's status byte with RQS reported on bit 6, use the interface Serial Poll.

**See Also**

- ["Introduction to Common \(\\*\) Commands"](#) on page 231
- ["\\*SRE \(Service Request Enable\)"](#) on page 248

## \*TRG (Trigger)

 (see [page 1666](#))

**Command Syntax** \*TRG

The \*TRG command has the same effect as the :DIGitize command with no parameters.

- See Also**
- ["Introduction to Common \(\\*\) Commands"](#) on page 231
  - [":DIGITIZE"](#) on page 268
  - [":RUN"](#) on page 292
  - [":STOP"](#) on page 296

## \*TST (Self Test)

 (see [page 1666](#))

**Query Syntax** \*TST?

The \*TST? query performs a self-test on the instrument. The result of the test is placed in the output queue. A zero indicates the test passed and a non-zero indicates the test failed. If the test fails, refer to the troubleshooting section of the *Service Guide*.

**Return Format** <result><NL>

<result> ::= 0 or non-zero value; an integer in NR1 format

**See Also** · ["Introduction to Common \(\\*\) Commands"](#) on page 231

## \*WAI (Wait To Continue)

 (see [page 1666](#))

**Command Syntax** \*WAI

The \*WAI command has no function in the oscilloscope, but is parsed for compatibility with other instruments.

**See Also** • ["Introduction to Common \(\\*\) Commands"](#) on page 231

## 7 Root (:) Commands

Control many of the basic functions of the oscilloscope and reside at the root level of the command tree. See "[Introduction to Root \(:\) Commands](#)" on page 258.

**Table 86** Root (:) Commands Summary

Command	Query	Options and Query Returns
:ACTivity (see <a href="#">page 259</a> )	:ACTivity? (see <a href="#">page 259</a> )	<p>&lt;return value&gt; ::= &lt;edges&gt;,&lt;levels&gt;</p> <p>&lt;edges&gt; ::= presence of edges (32-bit integer in NR1 format)</p> <p>&lt;levels&gt; ::= logical highs or lows (32-bit integer in NR1 format)</p>
n/a	:AER? (see <a href="#">page 260</a> )	{0   1}; an integer in NR1 format
:AUToscale [<source>[,...,<source>]] (see <a href="#">page 261</a> )	n/a	<p>&lt;source&gt; ::= CHANnel&lt;n&gt; for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   POD1   POD2} for MSO models</p> <p>&lt;source&gt; can be repeated up to 5 times</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p>
:AUToscale:AMODE <value> (see <a href="#">page 263</a> )	:AUToscale:AMODE? (see <a href="#">page 263</a> )	<value> ::= {NORMal   CURRent}
:AUToscale:CHANnels <value> (see <a href="#">page 264</a> )	:AUToscale:CHANnels? (see <a href="#">page 264</a> )	<value> ::= {ALL   DISPlayed}
:AUToscale:FDEBug {{0   OFF}   {1   ON}} (see <a href="#">page 265</a> )	:AUToscale:FDEBug? (see <a href="#">page 265</a> )	{0   1}

**Table 86** Root (:) Commands Summary (continued)

Command	Query	Options and Query Returns
:BLANK [<source>] (see <a href="#">page 266</a> )	n/a	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;}   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT   SBUS{1   2}   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;}   DIGItal&lt;d&gt;   POD{1   2}   BUS{1   2}   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT   SBUS{1   2}   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p>
:DIGItize [<source>[, . . . , <source>]] (see <a href="#">page 268</a> )	n/a	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;}   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT   SBUS{1   2}} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;}   DIGItal&lt;d&gt;   POD{1   2}   BUS{1   2}   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT   SBUS{1   2}} for MSO models</p> <p>&lt;source&gt; can be repeated up to 5 times</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p>
:HWEenable <n> (see <a href="#">page 270</a> )	:HWEenable? (see <a href="#">page 270</a> )	<n> ::= 16-bit integer in NR1 format
n/a	:HWERegister:CONDiti on? (see <a href="#">page 272</a> )	<n> ::= 16-bit integer in NR1 format
n/a	:HWERegister[:EVENT]? (see <a href="#">page 273</a> )	<n> ::= 16-bit integer in NR1 format
:MTEenable <n> (see <a href="#">page 274</a> )	:MTEenable? (see <a href="#">page 274</a> )	<n> ::= 16-bit integer in NR1 format

**Table 86** Root (:) Commands Summary (continued)

Command	Query	Options and Query Returns
n/a	:MTERegister[:EVENT] ? (see <a href="#">page 276</a> )	<n> ::= 16-bit integer in NR1 format
:OPEE <n> (see <a href="#">page 278</a> )	:OPEE? (see <a href="#">page 279</a> )	<n> ::= 15-bit integer in NR1 format
n/a	:OPERegister:CONDition? (see <a href="#">page 280</a> )	<n> ::= 15-bit integer in NR1 format
n/a	:OPERegister[:EVENT] ? (see <a href="#">page 283</a> )	<n> ::= 15-bit integer in NR1 format
:OVLenable <mask> (see <a href="#">page 286</a> )	:OVLenable? (see <a href="#">page 287</a> )	<mask> ::= 16-bit integer in NR1 format as shown:  Bit Weight Input --- ----- 10 1024 Ext Trigger Fault 9 512 Channel 4 Fault 8 256 Channel 3 Fault 7 128 Channel 2 Fault 6 64 Channel 1 Fault 4 16 Ext Trigger OVL 3 8 Channel 4 OVL 2 4 Channel 3 OVL 1 2 Channel 2 OVL 0 1 Channel 1 OVL
n/a	:OVLRegister? (see <a href="#">page 288</a> )	<value> ::= integer in NR1 format. See OVLenable for <value>
:PRINT [<options>] (see <a href="#">page 290</a> )	n/a	<options> ::= [<print option>] [,...,<print option>] <print option> ::= {COLor   GRAYscale   PRINTER0   BMP8bit   BMP   PNG   NOFactors   FACTors} <print option> can be repeated up to 5 times.
n/a	:RSTate? (see <a href="#">page 291</a> )	n/a
:RUN (see <a href="#">page 292</a> )	n/a	n/a
n/a	:SERial? (see <a href="#">page 293</a> )	<return value> ::= unquoted string containing serial number
:SINGle (see <a href="#">page 294</a> )	n/a	n/a

**Table 86** Root (:) Commands Summary (continued)

Command	Query	Options and Query Returns
n/a	:STATus? <display> (see <a href="#">page 295</a> )	{0   1} <display> ::= {CHANnel<n>   DIGItal<d>   POD{1   2}   BUS{1   2}   FUNCtion<m>   MATH<m>   FFT   SBUS{1   2}   WMEMory<r>} <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format <m> ::= 1 to (# math functions) in NR1 format <r> ::= 1 to (# ref waveforms) in NR1 format
:STOP (see <a href="#">page 296</a> )	n/a	n/a
n/a	:TER? (see <a href="#">page 297</a> )	{0   1}
:VIEW <source> (see <a href="#">page 298</a> )	n/a	<source> ::= {CHANnel<n>   FUNCtion<m>   MATH<m>   FFT   SBUS{1   2}   WMEMory<r>} for DSO models <source> ::= {CHANnel<n>   DIGItal<d>   POD{1   2}   BUS{1   2}   FUNCtion<m>   MATH<m>   FFT   SBUS{1   2}   WMEMory<r>} for MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format <m> ::= 1 to (# math functions) in NR1 format <r> ::= 1 to (# ref waveforms) in NR1 format

**Introduction to Root (:) Commands** Root level commands control many of the basic operations of the instrument. These commands are always recognized by the parser if they are prefixed with a colon, regardless of current command tree position. After executing a root-level command, the parser is positioned at the root of the command tree.

## :ACTivity

**N** (see [page 1666](#))

**Command Syntax** :ACTivity

The :ACTivity command clears the cumulative edge variables for the next activity query.

**Query Syntax** :ACTivity?

The :ACTivity? query returns whether there has been activity (edges) on the digital channels since the last query, and returns the current logic levels.

**NOTE** Because the :ACTivity? query returns edge activity since the last :ACTivity? query, you must send this query twice before the edge activity result is valid.

**Return Format**

```
<edges>,<levels><NL>
<edges> ::= presence of edges (16-bit integer in NR1 format).
<levels> ::= logical highs or lows (16-bit integer in NR1 format).
bit 0 ::= DIGital 0
bit 15 ::= DIGital 15
```

**NOTE** A bit = 0 (zero) in the <edges> result indicates that no edges were detected on that channel (across the specified threshold voltage) since the last query.

A bit = 1 (one) in the <edges> result indicates that edges have been detected on that channel (across the specified threshold voltage) since the last query.

(The threshold voltage must be set appropriately for the logic levels of the signals being probed.)

**See Also**

- "[Introduction to Root \(\) Commands](#)" on page 258
- "[":POD<n>:THreshold](#)" on page 755
- "[":DIGital<d>:THreshold](#)" on page 409

## :AER (Arm Event Register)

 (see [page 1666](#))

**Query Syntax** :AER?

The AER query reads the Arm Event Register. After the Arm Event Register is read, it is cleared. A "1" indicates the trigger system is in the armed state, ready to accept a trigger.

The Armed Event Register is summarized in the Wait Trig bit of the Operation Status Event Register. A Service Request can be generated when the Wait Trig bit transitions and the appropriate enable bits have been set in the Operation Status Enable Register (OPEE) and the Service Request Enable Register (SRE).

**Return Format** <value><NL>

<value> ::= {0 | 1}; an integer in NR1 format.

**See Also**

- "[Introduction to Root \(:\) Commands](#)" on page 258
- "[:OPEE \(Operation Status Enable Register\)](#)" on page 278
- "[:OPERegister:CONDition \(Operation Status Condition Register\)](#)" on page 280
- "[:OPERegister\[:EVENT\] \(Operation Status Event Register\)](#)" on page 283
- "[\\*STB \(Read Status Byte\)](#)" on page 250
- "[\\*SRE \(Service Request Enable\)](#)" on page 248

## :AUToscale

**C** (see [page 1666](#))

### Command Syntax

```
:AUToscale
:AUToscale [<source>[,...,<source>]]
<source> ::= CHANnel<n> for the DSO models
<source> ::= {DIGItal<d> | POD1 | POD2 | CHANnel<n>} for the
MSO models
<n> ::= 1 to (# analog channels) in NR1 format
<d> ::= 0 to (# digital channels - 1) in NR1 format
The <source> parameter may be repeated up to 5 times.
```

The :AUToscale command evaluates all input signals and sets the correct conditions to display the signals. This is the same as pressing the **[Auto Scale]** key on the front panel.

If one or more sources are specified, those specified sources will be enabled and all others blanked. The autoscale channels mode (see "[:AUToscale:CHANnels](#)" on page 264) is set to DISPlayed channels. Then, the autoscale is performed.

When the :AUToscale command is sent, the following conditions are affected and actions are taken:

- Thresholds.
- Channels with activity around the trigger point are turned on, others are turned off.
- Channels are reordered on screen; analog channel 1 first, followed by the remaining analog channels, then the digital channels 0-15.
- Delay is set to 0 seconds.
- Time/Div.

The :AUToscale command does not affect the following conditions:

- Label names.
- Trigger conditioning.

The :AUToscale command turns off the following items:

- Cursors.
- Measurements.
- Math waveforms.
- Reference waveforms.
- Zoomed (delayed) time base mode.

For further information on :AUToscale, see the *User's Guide*.

- See Also**
- "[Introduction to Root \(:\) Commands](#)" on page 258
  - "[:AUToscale:CHANnels](#)" on page 264
  - "[:AUToscale:AMODE](#)" on page 263
- Example Code**
- ```
' AUTOSCALE - This command evaluates all the input signals and sets  
' the correct conditions to display all of the active signals.  
myScope.WriteString ":AUToscale"      ' Same as pressing Auto Scale key.
```
- See complete example programs at: [Chapter 46, “Programming Examples,”](#) starting on page 1675

## :AUToscale:AMODE

**N** (see [page 1666](#))

**Command Syntax** :AUToscale:AMODE <value>

<value> ::= {NORMal | CURRent}

The :AUToscale:AMODE command specifies the acquisition mode that is set by subsequent :AUToscales.

- When NORMal is selected, an :AUToscale command sets the NORMal acquisition type and the RTIMe (real-time) acquisition mode.
- When CURRent is selected, the current acquisition type and mode are kept on subsequent :AUToscales.

Use the :ACQuire:TYPE and :ACQuire:MODE commands to set the acquisition type and mode.

**Query Syntax** :AUToscale:AMODE?

The :AUToscale:AMODE? query returns the autoscale acquire mode setting.

**Return Format** <value><NL>

<value> ::= {NORM | CURR}

- See Also**
- "[Introduction to Root \(\) Commands](#)" on page 258
  - "[":AUToscale"](#)" on page 261
  - "[":AUToscale:CHANnels"](#)" on page 264
  - "[":ACQuire:TYPE"](#)" on page 317
  - "[":ACQuire:MODE"](#)" on page 307

## :AUToscale:CHANnels

**N** (see [page 1666](#))

**Command Syntax**    `:AUToscale:CHANnels <value>`  
`<value> ::= {ALL | DISPlayed}`

The :AUToscale:CHANnels command specifies which channels will be displayed on subsequent :AUToscales.

- When ALL is selected, all channels that meet the requirements of :AUToscale will be displayed.
- When DISPlayed is selected, only the channels that are turned on are autoscaled.

Use the :VIEW or :BLANK root commands to turn channels on or off.

**Query Syntax**    `:AUToscale:CHANnels?`

The :AUToscale:CHANnels? query returns the autoscale channels setting.

**Return Format**    `<value><NL>`  
`<value> ::= {ALL | DISP}`

**See Also**

- "[Introduction to Root \(:\) Commands](#)" on page 258
- "[":AUToscale](#)" on page 261
- "[":AUToscale:AMODE](#)" on page 263
- "[":VIEW](#)" on page 298
- "[":BLANK](#)" on page 266

## :AUToscale:FDEBug

**N** (see [page 1666](#))

**Command Syntax** :AUToscale:FDEBug <on\_off>

<on\_off> ::= {{1 | ON} | {0 | OFF}}

The :AUToscale:FDEBug command turns fast debug auto scaling on or off.

The Fast Debug option changes the behavior of :AUToscale to let you make quick visual comparisons to determine whether the signal being probed is a DC voltage, ground, or an active AC signal.

Channel coupling is maintained for easy viewing of oscillating signals.

**Query Syntax** :AUToscale:FDEBug?

The :AUToscale:FDEBug? query returns the current autoscale fast debug setting.

**Return Format** <on\_off><NL>

<on\_off> ::= {1 | 0}

**See Also** • ["Introduction to Root \(:\) Commands"](#) on page 258

• [":AUToscale"](#) on page 261

## :BLANK

**N** (see [page 1666](#))

### Command Syntax

```
:BLANK [<source>]

<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | FFT | SBUS{1 | 2}
              | WMEMory<r>}
              for the DSO models

<source> ::= {CHANnel<n> | DIGital<d> | POD{1 | 2}
              | BUS{1 | 2} | FUNCtion<m> | MATH<m> | FFT | SBUS{1 | 2}
              | WMEMory<r>}
              for the MSO models

<n> ::= 1 to (# analog channels) in NR1 format

<d> ::= 0 to (# digital channels - 1) in NR1 format

<m> ::= 1 to (# math functions) in NR1 format

<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :BLANK command turns off (stops displaying) the specified channel, digital pod, math function, serial decode bus, or reference waveform location. The :BLANK command with no parameter turns off all sources.

### NOTE

To turn on (start displaying) a channel, etc., use the :VIEW command. The DISPLAY commands, :CHANnel<n>:DISPLAY, :FUNCtion:DISPLAY, :POD<n>:DISPLAY, :DIGital<n>:DISPLAY, :SBUS<n>:DISPLAY, or :WMEMory<r>:DISPLAY, are the preferred method to turn on/off a channel, etc.

### NOTE

MATH<m> is an alias for FUNCtion<m>.

### See Also

- "[Introduction to Root \(:\) Commands](#)" on page 258
- "[:DISPLAY:CLEar](#)" on page 421
- "[:CHANnel<n>:DISPLAY](#)" on page 347
- "[:DIGital<d>:DISPLAY](#)" on page 405
- "[:FUNCtion<m>:DISPLAY](#)" on page 499
- "[:POD<n>:DISPLAY](#)" on page 753
- "[:SBUS<n>:DISPLAY](#)" on page 908
- "[:WMEMory<r>:DISPLAY](#)" on page 1540
- "[:STATus](#)" on page 295
- "[:VIEW](#)" on page 298

Example Code · "Example Code" on page 298

## :DIGItize

**C** (see [page 1666](#))

**Command Syntax**

```
:DIGItize [<source>[, . . . ,<source>]]  
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | FFT | SBUS{1 | 2}  
for the DSO models  
<source> ::= {CHANnel<n> | DIGItal<d> | POD{1 | 2}  
| BUS{1 | 2} | FUNCtion<m> | MATH<m> | FFT | SBUS{1 | 2}  
for the MSO models  
<n> ::= 1 to (# analog channels) in NR1 format  
<d> ::= 0 to (# digital channels - 1) in NR1 format  
<m> ::= 1 to (# math functions) in NR1 format  
The <source> parameter may be repeated up to 5 times.
```

The :DIGItize command is a specialized RUN command. It causes the instrument to acquire waveforms according to the settings of the :ACQuire commands subsystem. When the acquisition is complete, the instrument is stopped.

If no argument is given, :DIGItize acquires the channels currently displayed. If no channels are displayed, all channels are acquired.

**NOTE**

The :DIGItize command is only executed when the :TIMEbase:MODE is MAIN or WINDow.

**NOTE**

To halt a :DIGItize in progress, use the device clear command.

**NOTE**

MATH<m> is an alias for FUNCtion<m>.

**See Also**

- ["Introduction to Root \(: Commands"](#) on page 258
- [":RUN"](#) on page 292
- [":SINGle"](#) on page 294
- [":STOP"](#) on page 296
- [":TIMEbase:MODE"](#) on page 1339
- [Chapter 8, “:ACQuire Commands,”](#) starting on page 299
- [Chapter 38, “:WAVeform Commands,”](#) starting on page 1453

- [Chapter 4](#), “Sequential (Blocking) vs. Overlapped Commands,” starting on page 87
- [“Example: Checking for Armed Status”](#) on page 1637

**Example Code**

```
' Capture an acquisition using :DIGITIZE.  
' -----  
myScope.WriteString ":DIGITIZE CHANnel1"
```

See complete example programs at: [Chapter 46](#), “Programming Examples,” starting on page 1675


## :HWEenable (Hardware Event Enable Register)

**N** (see [page 1666](#))

**Command Syntax**

```
:HWEenable <mask>
<mask> ::= 16-bit integer
```

The :HWEenable command sets a mask in the Hardware Event Enable register. Set any of the following bits to "1" to enable bit 12 in the Operation Status Condition Register and potentially cause an SRQ (Service Request interrupt) to be generated.



**Table 87** Hardware Event Enable Register (HWEenable)

Bit	Name	Description	When Set (1 = High = True), Enables:
15-13	---	---	(Not used.)
12	PLL Locked	PLL Locked	This bit is for internal use and is not intended for general use.
11-0	---	---	(Not used.)

**Query Syntax**

```
:HWEenable?
```

The :HWEenable? query returns the current value contained in the Hardware Event Enable register as an integer number.

**Return Format**

```
<value><NL>
<value> ::= integer in NR1 format.
```

**See Also**

- ["Introduction to Root \(:\) Commands"](#) on page 258
- [":AER \(Arm Event Register\)"](#) on page 260
- [":CHANnel<n>:PROTection"](#) on page 366


- [":OPERegister\[:EVENT\] \(Operation Status Event Register\)" on page 283](#)
- [":OVLenable \(Overload Event Enable Register\)" on page 286](#)
- [":OVLRegister \(Overload Event Register\)" on page 288](#)
- ["\\*STB \(Read Status Byte\)" on page 250](#)
- ["\\*SRE \(Service Request Enable\)" on page 248](#)

## :HWERegister:CONDition (Hardware Event Condition Register)

**N** (see [page 1666](#))

**Query Syntax** :HWERegister:CONDition?

The :HWERegister:CONDition? query returns the integer value contained in the Hardware Event Condition Register.



**Table 88** Hardware Event Condition Register

Bit	Name	Description	When Set (1 = High = True), Indicates:
15-13	---	---	(Not used.)
12	PLL Locked	PLL Locked	This bit is for internal use and is not intended for general use.
11-0	---	---	(Not used.)

**Return Format** <value><NL>

<value> ::= integer in NR1 format.

**See Also**


- "[Introduction to Root \(:\) Commands](#)" on page 258
- "[:CHANnel<n>:PROtection](#)" on page 366
- "[:OPEE \(Operation Status Enable Register\)](#)" on page 278
- "[:OPERegister\[:EVENTj\] \(Operation Status Event Register\)](#)" on page 283
- "[:OVLenable \(Overload Event Enable Register\)](#)" on page 286
- "[:OVLRegister \(Overload Event Register\)](#)" on page 288
- "[\\*:STB \(Read Status Byte\)](#)" on page 250
- "[\\*:SRE \(Service Request Enable\)](#)" on page 248

## :HWERegister[:EVENT] (Hardware Event Event Register)

**N** (see [page 1666](#))

**Query Syntax** :HWERegister [:EVENT] ?

The :HWERegister[:EVENT]? query returns the integer value contained in the Hardware Event Event Register.



**Table 89** Hardware Event Event Register

Bit	Name	Description	When Set (1 = High = True), Indicates:
15-13	---	---	(Not used.)
12	PLL Locked	PLL Locked	This bit is for internal use and is not intended for general use.
11-0	---	---	(Not used.)

**Return Format** <value><NL>

<value> ::= integer in NR1 format.

**See Also**


- "[Introduction to Root \(:\) Commands](#)" on page 258
- "[:CHANnel<n>:PROtection](#)" on page 366
- "[:OPEE \(Operation Status Enable Register\)](#)" on page 278
- "[:OPERegister:CONDITION \(Operation Status Condition Register\)](#)" on page 280
- "[:OVLenable \(Overload Event Enable Register\)](#)" on page 286
- "[:OVLRegister \(Overload Event Register\)](#)" on page 288
- "[\\*:STB \(Read Status Byte\)](#)" on page 250
- "[\\*:SRE \(Service Request Enable\)](#)" on page 248

## :MTEenable (Mask Test Event Enable Register)

**N** (see [page 1666](#))

**Command Syntax** :MTEenable <mask>  
 <mask> ::= 16-bit integer

The :MTEenable command sets a mask in the Mask Test Event Enable register. Set any of the following bits to "1" to enable bit 9 in the Operation Status Condition Register and potentially cause an SRQ (Service Request) interrupt to be generated.



**Table 90** Mask Test Event Enable Register (MTEenable)

Bit	Name	Description	When Set (1 = High = True), Enables:
15-11	---	---	(Not used.)
10	Auto Mask	Auto Mask Created	Auto mask creation completed.
9	Pass	Mask Test Pass	Mask test passed.
8	Started	Mask Testing Started	Mask testing started.
7-2	---	---	(Not used.)
1	Fail	Mask Test Fail	Mask test failed.
0	Complete	Mask Test Complete	Mask test is complete.

**Query Syntax** :MTEenable?

The :MTEenable? query returns the current value contained in the Mask Test Event Enable register as an integer number.

**Return Format** <value><NL>

<value> ::= integer in NR1 format.


- See Also
- "[Introduction to Root \(\) Commands](#)" on page 258
  - "[:AER \(Arm Event Register\)](#)" on page 260
  - "[:CHANnel<n>:PROTection](#)" on page 366
  - "[:OPERegister\[:EVENT\] \(Operation Status Event Register\)](#)" on page 283
  - "[:OVLenable \(Overload Event Enable Register\)](#)" on page 286
  - "[:OVLRegister \(Overload Event Register\)](#)" on page 288
  - "[\\*STB \(Read Status Byte\)](#)" on page 250
  - "[\\*SRE \(Service Request Enable\)](#)" on page 248

## :MTERegister[:EVENT] (Mask Test Event Event Register)

**N** (see [page 1666](#))

**Query Syntax** :MTERegister[:EVENT]?

The :MTERegister[:EVENT]? query returns the integer value contained in the Mask Test Event Event Register and clears the register.



**Table 91** Mask Test Event Event Register

Bit	Name	Description	When Set (1 = High = True), Indicates:
15-11	---	---	(Not used.)
10	Auto Mask	Auto Mask Created	Auto mask creation completed.
9	Pass	Mask Test Pass	The mask test passed.
8	Started	Mask Testing Started	Mask testing started.
7-2	---	---	(Not used.)
1	Fail	Mask Test Fail	The mask test failed.
0	Complete	Mask Test Complete	The mask test is complete.

**Return Format** <value><NL>

<value> ::= integer in NR1 format.

**See Also**

- "[Introduction to Root \(:\) Commands](#)" on page 258
- "[":CHANnel<n>:PROTection](#)" on page 366
- "[":OPEE \(Operation Status Enable Register\)"](#) on page 278
- "[":OPERegister:CONDition \(Operation Status Condition Register\)"](#) on page 280

- [":OVLenable \(Overload Event Enable Register\)" on page 286](#)
- [":OVLregister \(Overload Event Register\)" on page 288](#)
- ["\\*STB \(Read Status Byte\)" on page 250](#)
- ["\\*SRE \(Service Request Enable\)" on page 248](#)


## :OPEE (Operation Status Enable Register)

**C** (see [page 1666](#))

**Command Syntax** :OPEE <mask>

<mask> ::= 15-bit integer

The :OPEE command sets a mask in the Operation Status Enable register. Set any of the following bits to "1" to enable bit 7 in the Status Byte Register and potentially cause an SRQ (Service Request) interrupt to be generated.



**Table 92** Operation Status Enable Register (OPEE)

Bit	Name	Description	When Set (1 = High = True), Enables:
14	IOF	IO Operation Failed	Event only when something causes the IO operation to fail, like disconnecting a USB device or interrupting the operation from the oscilloscope's front panel.
13	IOC	IO Operation Complete	Event when any IO operation completes. IO operations are any remote data request using any interface (USB, LAN, or GPIB). For example, if you connect to an oscilloscope using the USB interface and then request waveform data, the IOC bit will be set when the IO operation completes.
12	HWE	Hardware Event	Event when hardware event occurs.
11	OVLR	Overload	Event when 50Ω input overload occurs.

**Table 92** Operation Status Enable Register (OPEE) (continued)

Bit	Name	Description	When Set (1 = High = True), Enables:
10	---	---	(Not used.)
9	MTE	Mask Test Event	Event when mask test event occurs.
8-6	---	---	(Not used.)
5	Wait Trig	Wait Trig	Event when the trigger is armed.
4	---	---	(Not used.)
3	Run	Running	Event when the oscilloscope is running (not stopped).
2-0	---	---	(Not used.)

**Query Syntax** :OPEE?

The :OPEE? query returns the current value contained in the Operation Status Enable register as an integer number.

**Return Format** <value><NL>

<value> ::= integer in NR1 format.

**See Also**


- "[Introduction to Root \(:\) Commands](#)" on page 258
- "[":AER \(Arm Event Register\)](#)" on page 260
- "[":CHANnel<n>:PROTection](#)" on page 366
- "[":OPERegister\[:EVENT\] \(Operation Status Event Register\)](#)" on page 283
- "[":OVLenable \(Overload Event Enable Register\)](#)" on page 286
- "[":OVLRegister \(Overload Event Register\)](#)" on page 288
- "[":\\*STB \(Read Status Byte\)](#)" on page 250
- "[":\\*SRE \(Service Request Enable\)](#)" on page 248
- "[":Operation Status Event Register \(:OPERegister\[:EVENT\]\)](#)" on page 1627
- "[":Example: Checking for Armed Status](#)" on page 1637
- "[":Example: Waiting for IO Operation Complete](#)" on page 1642

## :OPERegister:CONDition (Operation Status Condition Register)

**C** (see [page 1666](#))

**Query Syntax** :OPERegister:CONDition?

The :OPERegister:CONDition? query returns the integer value contained in the Operation Status Condition Register.



**Table 93** Operation Status Condition Register

Bit	Name	Description	When Set (1 = High = True), Indicates:
14	IOF	IO Operation Failed	Event only when something causes the IO operation to fail, like disconnecting a USB device or interrupting the operation from the oscilloscope's front panel.
13	IOC	IO Operation Complete	Event when any IO operation completes. IO operations are any remote data request using any interface (USB, LAN, or GPIB). For example, if you connect to an oscilloscope using the USB interface and then request waveform data, the IOC bit will be set when the IO operation completes.
12	HWE	Hardware Event	Event when hardware event occurs.
11	OVLR	Overload	A 50Ω input overload has occurred.
10	---	---	(Not used.)

**Table 93** Operation Status Condition Register (continued)

Bit	Name	Description	When Set (1 = High = True), Indicates:
9	MTE	Mask Test Event	A mask test event has occurred.
8-6	---	---	(Not used.)
5	Wait Trig	Wait Trig	The trigger is armed (set by the Trigger Armed Event Register (TER)).
4	RUI Enab	Remote Enabled	<p>Shows whether the remote user interface is enabled.</p> <p>The front-panel graphical user interface can disable most of the remote interface, including the *OPC syntax, for example when:</p> <ul style="list-style-type: none"> <li>▪ a modal dialog box is open</li> <li>▪ the user is being prompted</li> <li>▪ all segments are being analyzed</li> <li>▪ there is a channel overload</li> <li>▪ certain compliance applications are running</li> </ul> <p>When disabled, commands or queries are accepted, but "settings conflict" errors are returned. The status model is the only part of the remote user interface that is enabled.</p> <p>To determine when the remote interface is re-enabled, you can read this bit or wait for the event that gets generated when its status goes from disabled to enabled.</p>
3	Run	Running	The oscilloscope is running (not stopped).
2-0	---	---	(Not used.)

Return Format &lt;value&gt;&lt;NL&gt;

&lt;value&gt; ::= integer in NR1 format.

## See Also

- "[Introduction to Root \(:\) Commands](#)" on page 258
- "[:CHANnel<n>:PROTection](#)" on page 366
- "[:OPEE \(Operation Status Enable Register\)](#)" on page 278
- "[:OPERegister\[:EVENT\] \(Operation Status Event Register\)](#)" on page 283
- "[:OVLenable \(Overload Event Enable Register\)](#)" on page 286
- "[:OVLRegister \(Overload Event Register\)](#)" on page 288
- "[\\*STB \(Read Status Byte\)](#)" on page 250
- "[\\*SRE \(Service Request Enable\)](#)" on page 248
- "[:MTERegister\[:EVENT\] \(Mask Test Event Event Register\)](#)" on page 276


- "[:MTEnable \(Mask Test Event Enable Register\)](#)" on page 274
- "[\\*OPC \(Operation Complete\)](#)" on page 240
- "[Operation Status Condition Register \(:OPERegister:CONDITION\)](#)" on page 1629
- "[Example: Checking for Armed Status](#)" on page 1637
- "[Example: Waiting for IO Operation Complete](#)" on page 1642

## :OPERRegister[:EVENT] (Operation Status Event Register)

**C** (see [page 1666](#))

**Query Syntax** :OPERRegister [:EVENT]?

The :OPERRegister[:EVENT]? query reads and clears the integer value contained in the Operation Status Event Register.



**Table 94** Operation Status Event Register

Bit	Name	Description	When Set (1 = High = True), Indicates:
14	IOF	IO Operation Failed	Event only when something causes the IO operation to fail, like disconnecting a USB device or interrupting the operation from the oscilloscope's front panel.
13	IOC	IO Operation Complete	Event when any IO operation completes. IO operations are any remote data request using any interface (USB, LAN, or GPIB). For example, if you connect to an oscilloscope using the USB interface and then request waveform data, the IOC bit will be set when the IO operation completes.
12	HWE	Hardware Event	Event when hardware event occurs.
11	OVLR	Overload	A 50Ω input overload has occurred.
10	---	---	(Not used.)

**Table 94** Operation Status Event Register (continued)

Bit	Name	Description	When Set (1 = High = True), Indicates:
9	MTE	Mask Test Event	A mask test event has occurred.
8-6	---	---	(Not used.)
5	Wait Trig	Wait Trig	The trigger is armed (set by the Trigger Armed Event Register (TER)).
4	RUI Enab	Remote Enabled	<p>The remote user interface has gone from a disabled state to an enabled state.</p> <p>The front-panel graphical user interface can disable most of the remote interface, including the *OPC syntax, for example when:</p> <ul style="list-style-type: none"> <li>▪ a modal dialog box is open</li> <li>▪ the user is being prompted</li> <li>▪ all segments are being analyzed</li> <li>▪ there is a channel overload</li> <li>▪ certain compliance applications are running</li> </ul> <p>When disabled, commands or queries are accepted, but "settings conflict" errors are returned. The status model is the only part of the remote user interface that is enabled.</p> <p>To determine when the remote interface is re-enabled, you can read this bit or wait for the event that gets generated when its status goes from disabled to enabled.</p>
3	Run	Running	The oscilloscope has gone from a stop state to a single or running state.
2-0	---	---	(Not used.)

Return Format

```
<value><NL>
<value> ::= integer in NR1 format.
```

See Also

- "[Introduction to Root \(:\) Commands](#)" on page 258
- "[":CHANnel<n>:PROtection](#)" on page 366
- "[":OPEE \(Operation Status Enable Register\)"](#) on page 278
- "[":OPERregister:CONDition \(Operation Status Condition Register\)"](#) on page 280
- "[":OVLenable \(Overload Event Enable Register\)"](#) on page 286
- "[":OVLRegister \(Overload Event Register\)"](#) on page 288
- "[":\\*STB \(Read Status Byte\)"](#) on page 250
- "[":\\*SRE \(Service Request Enable\)"](#) on page 248

- "[:MTERegister\[:EVENT\] \(Mask Test Event Event Register\)](#)" on page 276
- "[:MTEenable \(Mask Test Event Enable Register\)](#)" on page 274
- "[\\*OPC \(Operation Complete\)](#)" on page 240
- "[Operation Status Event Register \(:OPERregister\[:EVENT\]\)](#)" on page 1627
- "[Example: Checking for Armed Status](#)" on page 1637
- "[Example: Waiting for IO Operation Complete](#)" on page 1642

## :OVLenable (Overload Event Enable Register)

**C** (see [page 1666](#))

**Command Syntax**


```
:OVLenable <enable_mask>
<enable_mask> ::= 16-bit integer
```

The overload enable mask is an integer representing an input as described in the following table.

The :OVLenable command sets the mask in the Overload Event Enable Register and enables the reporting of the Overload Event Register. If an overvoltage is sensed on a  $50\Omega$  input, the input will automatically switch to  $1 M\Omega$  input impedance. If enabled, such an event will set bit 11 in the Operation Status Register.

### NOTE

You can set analog channel input impedance to  $50\Omega$  on the 300 MHz, 500 MHz, and 1 GHz bandwidth oscilloscope models. On these same bandwidth models, if there are only two analog channels, you can also set external trigger input impedance to  $50\Omega$ .



**Table 95** Overload Event Enable Register (OVL)

Bit	Description	When Set (1 = High = True), Enables:
15-10	---	(Not used.)
9	Channel 4 Fault	Event when fault occurs on Channel 4 input.
8	Channel 3 Fault	Event when fault occurs on Channel 3 input.
7	Channel 2 Fault	Event when fault occurs on Channel 2 input.
6	Channel 1 Fault	Event when fault occurs on Channel 1 input.
5-4	---	(Not used.)
3	Channel 4 OVL	Event when overload occurs on Channel 4 input.

**Table 95** Overload Event Enable Register (OVL) (continued)

Bit	Description	When Set (1 = High = True), Enables:
2	Channel 3 OVL	Event when overload occurs on Channel 3 input.
1	Channel 2 OVL	Event when overload occurs on Channel 2 input.
0	Channel 1 OVL	Event when overload occurs on Channel 1 input.

**Query Syntax** :OVLenable?

The :OVLenable query returns the current enable mask value contained in the Overload Event Enable Register.

**Return Format** <enable\_mask><NL>

<enable\_mask> ::= integer in NR1 format.

**See Also**

- "[Introduction to Root \(:\) Commands](#)" on page 258
- "[:CHANnel<n>:PROTection](#)" on page 366
- "[:OPEE \(Operation Status Enable Register\)](#)" on page 278
- "[:OPERegister:CONDition \(Operation Status Condition Register\)](#)" on page 280
- "[:OPERegister\[:EVENT\] \(Operation Status Event Register\)](#)" on page 283
- "[:OVLRegister \(Overload Event Register\)](#)" on page 288
- "[:\\*STB \(Read Status Byte\)](#)" on page 250
- "[:\\*SRE \(Service Request Enable\)](#)" on page 248

## :OVLRegister (Overload Event Register)


**C** (see [page 1666](#))

**Query Syntax** :OVLRegister?

The :OVLRegister query returns the overload protection value stored in the Overload Event Register (OVLR). If an overvoltage is sensed on a  $50\Omega$  input, the input will automatically switch to  $1 M\Omega$  input impedance. A "1" indicates an overload has occurred.

### NOTE

You can set analog channel input impedance to  $50\Omega$  on the 300 MHz, 500 MHz, and 1 GHz bandwidth oscilloscope models. On these same bandwidth models, if there are only two analog channels, you can also set external trigger input impedance to  $50\Omega$ .



**Table 96** Overload Event Register (OVLR)

Bit	Description	When Set (1 = High = True), Indicates:
15-10	---	(Not used.)
9	Channel 4 Fault	Fault has occurred on Channel 4 input.
8	Channel 3 Fault	Fault has occurred on Channel 3 input.
7	Channel 2 Fault	Fault has occurred on Channel 2 input.
6	Channel 1 Fault	Fault has occurred on Channel 1 input.
5-4	---	(Not used.)
3	Channel 4 OVL	Overload has occurred on Channel 4 input.
2	Channel 3 OVL	Overload has occurred on Channel 3 input.
1	Channel 2 OVL	Overload has occurred on Channel 2 input.
0	Channel 1 OVL	Overload has occurred on Channel 1 input.

Return Format	<pre>&lt;value&gt;&lt;NL&gt; &lt;value&gt; ::= integer in NR1 format.</pre>
See Also	<ul style="list-style-type: none"><li>· "<a href="#">Introduction to Root (:) Commands</a>" on page 258</li><li>· "<a href="#">:CHANnel&lt;n&gt;:PROTection</a>" on page 366</li><li>· "<a href="#">:OPEE (Operation Status Enable Register)</a>" on page 278</li><li>· "<a href="#">:OVLenable (Overload Event Enable Register)</a>" on page 286</li><li>· "<a href="#">*STB (Read Status Byte)</a>" on page 250</li><li>· "<a href="#">*SRE (Service Request Enable)</a>" on page 248</li></ul>

## :PRINT

**C** (see [page 1666](#))

**Command Syntax**

```
:PRINT [<options>]  
<options> ::= [<print option>] [,...<print option>]  
<print option> ::= {COLor | GRAYscale | PRINTER0 | PRINTER1 | BMP8bit  
| BMP | PNG | NOFactors | FACTors}
```

The <print option> parameter may be repeated up to 5 times.

The PRINT command formats the output according to the currently selected format (device). If an option is not specified, the value selected in the Print Config menu is used.

**See Also**

- "[Introduction to Root \(:\) Commands](#)" on page 258
- "[Introduction to :HARDcopy Commands](#)" on page 542
- "[":HARDcopy:FACTors](#)" on page 546
- "[":HARDcopy:GRAYscale](#)" on page 1571
- "[":DISPLAY:DATA](#)" on page 422

## :RSTate?

**N** (see [page 1666](#))

**Query Syntax** :RSTate?

The :RSTate? query returns the run state:

- RUN – The oscilloscope is acquiring and displaying new waveforms.
- STOP – The oscilloscope is no longer acquiring new waveforms.
- SING – A single acquisition has been started and the oscilloscope is waiting for the trigger condition to be met.

These are the same run states displayed on the front panel and in the user interface.

**Return Format** {RUN | STOP | SING}<NL>

**See Also**

- "[:RUN](#)" on page 292
- "[:SINGLE](#)" on page 294
- "[:STOP](#)" on page 296
- "[:OPERegister\[:EVENT\] \(Operation Status Event Register\)](#)" on page 283

:RUN

 (see [page 1666](#))

**Command Syntax** :RUN

The :RUN command starts repetitive acquisitions. This is the same as pressing the Run key on the front panel.

- See Also**
- "[Introduction to Root \(:\) Commands](#)" on page 258
  - "[":SINGle](#)" on page 294
  - "[":STOP](#)" on page 296

**Example Code**

```
' RUN_STOP - (not executed in this example)
'   - RUN starts the data acquisition for the active waveform display.
'   - STOP stops the data acquisition and turns off AUTOSTORE.
' myScope.WriteString ":RUN"      ' Start data acquisition.
' myScope.WriteString ":STOP"     ' Stop the data acquisition.
```

See complete example programs at: [Chapter 46, “Programming Examples,”](#) starting on page 1675

## :SERial

**N** (see [page 1666](#))

**Query Syntax** :SERial?

The :SERial? query returns the serial number of the instrument.

**Return Format:** Unquoted string<NL>

**See Also** • ["Introduction to Root \(\) Commands"](#) on page 258

## :SINGle

 (see [page 1666](#))

**Command Syntax** :SINGle

The :SINGle command causes the instrument to acquire a single trigger of data. This is the same as pressing the Single key on the front panel.

**See Also**

- ["Introduction to Root \(:\) Commands"](#) on page 258
- [":RUN"](#) on page 292
- [":STOP"](#) on page 296

## :STATus

**N** (see [page 1666](#))

**Query Syntax**

```
:STATus? <source>

<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | FFT | SBUS{1 | 2}
              | WMEMory<r>}
              for the DSO models

<source> ::= {CHANnel<n> | DIGital<d> | POD{1 | 2}
              | BUS{1 | 2} | FUNCtion<m> | MATH<m> | FFT | SBUS{1 | 2}
              | WMEMory<r>}
              for the MSO models

<n> ::= 1 to (# analog channels) in NR1 format
<d> ::= 0 to (# digital channels - 1) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :STATus? query reports whether the channel, function, serial decode bus, or reference waveform location specified by <source> is displayed.

### NOTE

MATH<m> is an alias for FUNCtion<m>.

**Return Format**

<value><NL>

<value> ::= {1 | 0}

**See Also**

- "[Introduction to Root \(\) Commands](#)" on page 258
- "[":BLANK"](#) on page 266
- "[":CHANnel<n>:DISPlay"](#) on page 347
- "[":DIGital<d>:DISPlay"](#) on page 405
- "[":FUNCtion<m>:DISPlay"](#) on page 499
- "[":POD<n>:DISPlay"](#) on page 753
- "[":SBUS<n>:DISPlay"](#) on page 908
- "[":WMEMory<r>:DISPlay"](#) on page 1540
- "[":VIEW"](#) on page 298

:STOP

 (see [page 1666](#))

**Command Syntax** :STOP

The :STOP command stops the acquisition. This is the same as pressing the Stop key on the front panel.

**See Also** • ["Introduction to Root \(:\) Commands"](#) on page 258

- [":RUN"](#) on page 292
- [":SINGLE"](#) on page 294

**Example Code** • ["Example Code"](#) on page 292

## :TER (Trigger Event Register)

 (see [page 1666](#))

**Query Syntax** :TER?

The :TER? query reads the Trigger Event Register. After the Trigger Event Register is read, it is cleared. A one indicates a trigger has occurred. A zero indicates a trigger has not occurred.

The Trigger Event Register is summarized in the TRG bit of the Status Byte Register (STB). A Service Request (SRQ) can be generated when the TRG bit of the Status Byte transitions, and the TRG bit is set in the Service Request Enable register. The Trigger Event Register must be cleared each time you want a new service request to be generated.

**Return Format** <value><NL>

<value> ::= {1 | 0}; a 16-bit integer in NR1 format.

**See Also**

- ["Introduction to Root \(:\) Commands"](#) on page 258
- ["\\*SRE \(Service Request Enable\)"](#) on page 248
- ["\\*STB \(Read Status Byte\)"](#) on page 250

## :VIEW

**N** (see [page 1666](#))

**Command Syntax** :VIEW <source>

```
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | FFT | SBUS{1 | 2}
              | WMEMory<r>}
              for DSO models

<source> ::= {CHANnel<n> | DIGItal<d> | POD{1 | 2}
              | BUS{1 | 2} | FUNCtion<m> | MATH<m> | FFT | SBUS{1 | 2}
              | WMEMory<r>}
              for MSO models

<n> ::= 1 to (# analog channels) in NR1 format
<d> ::= 0 to (# digital channels - 1) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :VIEW command turns on the specified channel, function, serial decode bus, or reference waveform location.

### NOTE

MATH<m> is an alias for FUNCtion<m>.

### See Also

- "[Introduction to Root \(:\) Commands](#)" on page 258
- "[:BLANK](#)" on page 266
- "[:CHANnel<n>:DISPlay](#)" on page 347
- "[:DIGItal<d>:DISPlay](#)" on page 405
- "[:FUNCtion<m>:DISPlay](#)" on page 499
- "[:POD<n>:DISPlay](#)" on page 753
- "[:SBUS<n>:DISPlay](#)" on page 908
- "[:WMEMory<r>:DISPlay](#)" on page 1540
- "[:STATus](#)" on page 295

### Example Code

```
' VIEW_BLANK - (not executed in this example)
'   - VIEW turns on (starts displaying) a channel.
'   - BLANK turns off (stops displaying) a channel.
' myScope.WriteString ":BLANK CHANnel1"    ' Turn channel 1 off.
' myScope.WriteString ":VIEW CHANnel1"     ' Turn channel 1 on.
```

See complete example programs at: [Chapter 46, “Programming Examples,”](#) starting on page 1675

# 8 :ACQuire Commands

Set the parameters for acquiring and storing data. See "[Introduction to :ACQuire Commands](#)" on page 300.

**Table 97** :ACQuire Commands Summary

Command	Query	Options and Query Returns
n/a	:ACQuire:AALias? (see <a href="#">page 302</a> )	{1   0}
:ACQuire:COMplete <complete> (see <a href="#">page 303</a> )	:ACQuire:COMplete? (see <a href="#">page 303</a> )	<complete> ::= 100; an integer in NR1 format
:ACQuire:COUNT <count> (see <a href="#">page 304</a> )	:ACQuire:COUNT? (see <a href="#">page 304</a> )	<count> ::= an integer from 2 to 65536 in NR1 format
:ACQuire:DAALias <mode> (see <a href="#">page 305</a> )	:ACQuire:DAALias? (see <a href="#">page 305</a> )	<mode> ::= {DISable   AUTO}
:ACQuire:DIGitizer {{0   OFF}   {1   ON}} (see <a href="#">page 306</a> )	:ACQuire:DIGitizer? (see <a href="#">page 306</a> )	{0   1}
:ACQuire:MODE <mode> (see <a href="#">page 307</a> )	:ACQuire:MODE? (see <a href="#">page 307</a> )	<mode> ::= {RTIMe   ETIMe   SEGmented}
:ACQuire:POINTS[:ANALog] <points> (see <a href="#">page 308</a> )	:ACQuire:POINTS[:ANALog]? (see <a href="#">page 308</a> )	<points> ::= {AUTO   <points_value>} <points_value> ::= desired analog memory depth in integer NR1 format
:ACQuire:POINTS[:ANALog]:AUTO {{0   OFF}   {1   ON}} (see <a href="#">page 309</a> )	:ACQuire:POINTS[:ANALog]:AUTO? (see <a href="#">page 309</a> )	{0   1}
:ACQuire:SEGmented:ANALyze (see <a href="#">page 310</a> )	n/a	n/a

**Table 97** :ACQuire Commands Summary (continued)

Command	Query	Options and Query Returns
:ACQuire:SEGMENTed:COUNT <count> (see <a href="#">page 311</a> )	:ACQuire:SEGMENTed:COUNT? (see <a href="#">page 311</a> )	<count> ::= an integer from 2 to 1000 in NR1 format
:ACQuire:SEGMENTed:INDEX <index> (see <a href="#">page 312</a> )	:ACQuire:SEGMENTed:INDEX? (see <a href="#">page 312</a> )	<index> ::= an integer from 1 to 1000 in NR1 format
:ACQuire:SRATE [:ANALOG] <rate> (see <a href="#">page 315</a> )	:ACQuire:SRATE [:ANALOG]? (see <a href="#">page 315</a> )	<rate> ::= {AUTO   <sample_rate>} <sample_rate> ::= desired analog sample rate in NR3 format
:ACQuire:SRATE [:ANALOG]:AUTO {{0   OFF}   {1   ON}} (see <a href="#">page 316</a> )	:ACQuire:SRATE [:ANALOG]:AUTO? (see <a href="#">page 316</a> )	{0   1}
:ACQuire:TYPE <type> (see <a href="#">page 317</a> )	:ACQuire:TYPE? (see <a href="#">page 317</a> )	<type> ::= {NORMal   AVERage   HRESolution   PEAK}

**Introduction to :ACQuire Commands** The ACQuire subsystem controls the way in which waveforms are acquired. These acquisition types are available: normal, averaging, peak detect, and high resolution.

### Normal

The :ACQuire:TYPE NORMal command sets the oscilloscope in the normal acquisition mode. For the majority of user models and signals, NORMal mode yields the best oscilloscope picture of the waveform.

### Averaging

The :ACQuire:TYPE AVERage command sets the oscilloscope in the averaging mode. You can set the count by sending the :ACQuire:COUNt command followed by the number of averages. In this mode, the value for averages is an integer from 2 to 65536. The COUNt value determines the number of averages that must be acquired.

### High-Resolution

The :ACQuire:TYPE HRESolution command sets the oscilloscope in the high-resolution mode (also known as *smoothing*). This mode is used to reduce noise at slower sweep speeds where the digitizer samples faster than needed to fill memory for the displayed time range. Instead of decimating samples, they are averaged together to provide the value for one display point. The slower the sweep speed, the greater the number of samples that are averaged together for each display point.

### Peak Detect

The :ACQuire:TYPE PEAK command sets the oscilloscope in the peak detect mode. In this mode, :ACQuire:COUNt has no meaning.

### Reporting the Setup

Use :ACQuire? to query setup information for the ACQuire subsystem.

### Return Format

The following is a sample response from the :ACQuire? query. In this case, the query was issued following a \*RST command.

```
:ACQ:MODE RTIM;TYPE NORM;COMP 100;COUNT 8;SEGM:COUN 2
```

## :ACQuire:AALias

**N** (see [page 1666](#))

**Query Syntax** `:ACQuire:AALias?`

The `:ACQuire:AALias?` query returns the current state of the oscilloscope acquisition anti-alias control. This control can be directly disabled or disabled automatically.

**Return Format** `<value><NL>`

`<value> ::= {1 | 0}`

**See Also** • ["Introduction to :ACQuire Commands" on page 300](#)  
• [":ACQuire:DAALias" on page 305](#)

## :ACQuire:COMplete

**C** (see [page 1666](#))

<b>Command Syntax</b>	<code>:ACQuire:COMplete &lt;complete&gt;</code> <code>&lt;complete&gt; ::= 100; an integer in NR1 format</code>
	The :ACQuire:COMplete command affects the operation of the :DIGitize command. It specifies the minimum completion criteria for an acquisition. The parameter determines the percentage of the time buckets that must be "full" before an acquisition is considered complete. If :ACQuire:TYPE is NORMAl, it needs only one sample per time bucket for that time bucket to be considered full.
	The only legal value for the :COMplete command is 100. All time buckets must contain data for the acquisition to be considered complete.
<b>Query Syntax</b>	<code>:ACQuire:COMplete?</code>
	The :ACQuire:COMplete? query returns the completion criteria (100) for the currently selected mode.
<b>Return Format</b>	<code>&lt;completion_criteria&gt;&lt;NL&gt;</code> <code>&lt;completion_criteria&gt; ::= 100; an integer in NR1 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">"Introduction to :ACQuire Commands"</a> on page 300</li> <li>· <a href="#">":ACQuire:TYPE"</a> on page 317</li> <li>· <a href="#">":DIGitize"</a> on page 268</li> <li>· <a href="#">":WAVeform:POINts"</a> on page 1466</li> </ul>
<b>Example Code</b>	<pre>' AQUIRE_COMPLETE - Specifies the minimum completion criteria for ' an acquisition. The parameter determines the percentage of time ' buckets needed to be "full" before an acquisition is considered ' to be complete. myScope.WriteString ":ACQuire:COMplete 100"</pre>
	See complete example programs at: <a href="#">Chapter 46, “Programming Examples,”</a> starting on page 1675

## :ACQuire:COUNt

**C** (see [page 1666](#))

**Command Syntax**    `:ACQuire:COUNt <count>`

`<count>` ::= integer in NR1 format

In averaging mode, the :ACQuire:COUNt command specifies the number of values to be averaged for each time bucket before the acquisition is considered to be complete for that time bucket. When :ACQuire:TYPE is set to AVERage, the count can be set to any value from 2 to 65536.

### NOTE

The :ACQuire:COUNt 1 command has been deprecated. The AVERage acquisition type with a count of 1 is functionally equivalent to the HRESolution acquisition type; however, you should select the high-resolution acquisition mode with the :ACQuire:TYPE HRESolution command instead.

**Query Syntax**    `:ACQuire:COUNT?`

The :ACQuire:COUNT? query returns the currently selected count value for averaging mode.

**Return Format**    `<count_argument><NL>`

`<count_argument>` ::= an integer from 2 to 65536 in NR1 format

**See Also**

- "[Introduction to :ACQuire Commands](#)" on page 300
- "[":ACQuire:TYPE"](#) on page 317
- "[":DIGitize"](#) on page 268
- "[":WAVeform:COUNT"](#) on page 1462

## :ACQuire:DAALias

**N** (see [page 1666](#))

**Command Syntax** :ACQuire:DAALias <mode>

<mode> ::= {DISable | AUTO}

The :ACQuire:DAALias command sets the disable anti-alias mode of the oscilloscope.

When set to DISable, anti-alias is always disabled. This is good for cases where dithered data is not desired.

When set to AUTO, the oscilloscope turns off anti-alias control as needed. Such cases are when the FFT or differentiate math functions are silent. The :DIGitize command always turns off the anti-alias control as well.

**Query Syntax** :ACQuire:DAALias?

The :ACQuire:DAALias? query returns the oscilloscope's current disable anti-alias mode setting.

**Return Format** <mode><NL>

<mode> ::= {DIS | AUTO}

**See Also**

- "[Introduction to :ACQuire Commands](#)" on page 300
- "[":ACQuire:AALias](#)" on page 302

## :ACQuire:DIGitizer

**N** (see [page 1666](#))

**Command Syntax** `:ACQuire:DIGitizer {{0 | OFF} | {1 | ON}}`

The :ACQuire:DIGitizer command turns Digitizer mode on or off.

Normally, when Digitizer mode is disabled (Automatic mode), the oscilloscope's time per division setting determines the sample rate and memory depth so as to fill the waveform display with data while the oscilloscope is running (continuously making acquisitions). For single acquisitions, the time/division setting still determines the sample rate, but the maximum amount of acquisition memory is used.

In Digitizer mode, you choose the acquisition sample rate and memory depth, and those settings are used even though the captured data may extend way beyond the edges of, or take up just a small portion of, the waveform display, depending on the oscilloscope's time/div setting.

Digitizer mode cannot be used along with these other oscilloscope features: XY and Roll time modes, horizontal Zoom display, time references other than Center, segmented memory, serial decode, digital channels, frequency response analysis, mask test, and the power application. In most cases, enabling one of these features when Digitizer mode is enabled will automatically disable Digitizer mode, and then disabling the feature will automatically reenable Digitizer mode.

Digitizer mode primarily aids external software that controls and combines data from multiple instruments.

**Query Syntax** `:ACQuire:DIGitizer?`

The :ACQuire:DIGitizer? query returns whether Digitizer mode is off or on.

**Return Format** `<setting><NL>`

`<setting> ::= {0 | 1}`

- See Also**
- "[:ACQuire:SRATe\[:ANALog\]](#)" on page 315
  - "[:ACQuire:SRATe\[:ANALog\]:AUTO](#)" on page 316
  - "[:ACQuire:POINTs\[:ANALog\]](#)" on page 308
  - "[:ACQuire:POINTs\[:ANALog\]:AUTO](#)" on page 309

## :ACQuire:MODE

**C** (see [page 1666](#))

**Command Syntax** :ACQuire:MODE <mode>

<mode> ::= {RTIMe | SEGmented}

The :ACQuire:MODE command sets the acquisition mode of the oscilloscope.

- The :ACQuire:MODE RTIMe command sets the oscilloscope in real time mode.

### NOTE

The obsolete command ACQuire:TYPE:REALtime is functionally equivalent to sending ACQuire:MODE RTIMe; TYPE NORMAl.

- The :ACQuire:MODE SEGmented command sets the oscilloscope in segmented memory mode.

**Query Syntax** :ACQuire:MODE?

The :ACQuire:MODE? query returns the acquisition mode of the oscilloscope.

**Return Format** <mode\_argument><NL>

<mode\_argument> ::= {RTIM | SEGM}

- See Also**
- "[Introduction to :ACQuire Commands](#)" on page 300
  - "[":ACQuire:TYPE"](#) on page 317

## :ACQuire:POINts[:ANALog]

 (see [page 1666](#))

### Command Syntax

```
:ACQuire:POINts[:ANALog] <points>
<points> ::= {AUTO | <points_value>}
```

<points\_value> ::= desired analog memory depth in integer NR1 format

Sets the desired acquisition memory depth.

- AUTO – puts the oscilloscope into Automatic (default) mode where the optimal memory depth is selected automatically by the oscilloscope.
- <points\_value> – If a numerical memory depth is entered, this puts the oscilloscope into Digitizer (manual) Mode with the desired number of points.

The Automatic or Digitizer mode setting also affects the sample rate (see the :ACQuire:SRATe[:ANALog] command).

The actual memory depth used is returned by the :ACQuire:POINts[:ANALog]? query.

For :SINGle acquisitions, the requested memory depth is used.

When the oscilloscope is running (:RUN command, continuously making acquisitions) or when the :DIGitize command is used, the requested amount of memory is halved.

The maximum amount of memory available is halved when both channels in a pair are turned on. Channels 1 and 2 are one pair, channels 3 and 4 are the other.

### Query Syntax

```
:ACQuire:POINts[:ANALog] ?
```

The :ACQuire:POINts[:ANALog]? query returns the number of data points that the hardware will acquire from the input signal. The number of points acquired is not directly controllable. To set the number of points to be transferred from the oscilloscope, use the command :WAVeform:POINts. The :WAVeform:POINts? query will return the number of points available to be transferred from the oscilloscope.

### Return Format

```
<points_argument><NL>
<points_argument> ::= an integer in NR1 format
```

### See Also

- "[Introduction to :ACQuire Commands](#)" on page 300
- "[:ACQuire:SRATe\[:ANALog\]](#)" on page 315
- "[:ACQuire:POINts\[:ANALog\]:AUTO](#)" on page 309
- "[:ACQuire:DIGitizer](#)" on page 306
- "[:DIGITIZE](#)" on page 268
- "[:WAVeform:POINts](#)" on page 1466

## :ACQuire:POINts[:ANALog]:AUTO

**N** (see [page 1666](#))

**Command Syntax** :ACQuire:POINts[:ANALog]:AUTO {{0 | OFF} | {1 | ON}}

The :ACQuire:POINts[:ANALog]:AUTO command enables or disables Automatic determination of the analog channel memory depth:

- ON – the analog channel memory depth is automatically determined by the oscilloscope based on the horizontal time/div setting (Automatic mode, the oscilloscope's default).

This is equivalent to turning Digitizer mode off using the :ACQuire:DIGitizer command.

- OFF – the analog channel memory depth is set using the :ACQuire:POINts[:ANALog] command.

This is equivalent to turning Digitizer mode on using the :ACQuire:DIGitizer command.

The Automatic or Digitizer mode setting also affects the sample rate (see the :ACQuire:SRATe[:ANALog] command).

**Query Syntax** :ACQuire:POINts[:ANALog]:AUTO?

The :ACQuire:POINts[:ANALog]:AUTO? query returns the automatic analog memory depth setting.

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

**See Also**

- "[:ACQuire:DIGitizer](#)" on page 306
- "[:ACQuire:POINts\[:ANALog\]](#)" on page 308
- "[:ACQuire:SRATe\[:ANALog\]](#)" on page 315

## :ACQuire:SEGmented:ANALyze

**N** (see [page 1666](#))

**Command Syntax** :ACQuire:SEGmented:ANALyze

This command calculates measurement statistics and/or infinite persistence over all segments that have been acquired. It corresponds to the front panel **Analyze Segments** softkey which appears in both the Measurement Statistics and Segmented Memory Menus.

In order to use this command, the oscilloscope must be stopped and in segmented acquisition mode, with either quick measurements or infinite persistence on.

**See Also**

- [":ACQuire:MODE"](#) on page 307
- [":ACQuire:SEGmented:COUNt"](#) on page 311
- ["Introduction to :ACQuire Commands"](#) on page 300

## :ACQuire:SEGmented:COUNt

**N** (see [page 1666](#))

Command Syntax	<code>:ACQuire:SEGmented:COUNt &lt;count&gt;</code> <code>&lt;count&gt; ::= an integer from 2 to 1000 (w/4M memory) in NR1 format</code>
	The :ACQuire:SEGmented:COUNt command sets the number of memory segments to acquire.
	The segmented memory acquisition mode is enabled with the :ACQuire:MODE command, and data is acquired using the :DIGitize, :SINGle, or :RUN commands. The number of memory segments in the current acquisition is returned by the :WAVeform:SEGmented:COUNt? query.
	The maximum number of segments may be limited by the memory depth of your oscilloscope. For example, an oscilloscope with 1M memory allows a maximum of 250 segments.
Query Syntax	<code>:ACQuire:SEGmented:COUNt?</code>
	The :ACQuire:SEGmented:COUNt? query returns the current count setting.
Return Format	<code>&lt;count&gt;&lt;NL&gt;</code> <code>&lt;count&gt; ::= an integer from 2 to 1000 (w/4M memory) in NR1 format</code>
See Also	<ul style="list-style-type: none"> <li>· "<a href="#">:ACQuire:MODE</a>" on page 307</li> <li>· "<a href="#">:DIGITIZE</a>" on page 268</li> <li>· "<a href="#">:SINGLE</a>" on page 294</li> <li>· "<a href="#">:RUN</a>" on page 292</li> <li>· "<a href="#">:WAVeform:SEGmented:COUNt</a>" on page 1474</li> <li>· "<a href="#">:ACQuire:SEGmented:ANALyze</a>" on page 310</li> <li>· "<a href="#">Introduction to :ACQuire Commands</a>" on page 300</li> </ul>
Example Code	<ul style="list-style-type: none"> <li>· "<a href="#">Example Code</a>" on page 312</li> </ul>

## :ACQuire:SEGmented:INDEX

**N** (see [page 1666](#))

**Command Syntax**    `:ACQuire:SEGmented:INDEX <index>`  
`<index> ::= an integer from 1 to 1000 (w/4M memory) in NR1 format`

The :ACQuire:SEGmented:INDEX command sets the index into the memory segments that have been acquired.

The segmented memory acquisition mode is enabled with the :ACQuire:MODE command. The number of segments to acquire is set using the :ACQuire:SEGmented:COUNt command, and data is acquired using the :DIGitize, :SINGle, or :RUN commands. The number of memory segments that have been acquired is returned by the :WAVeform:SEGmented:COUNt? query. The time tag of the currently indexed memory segment is returned by the :WAVeform:SEGmented:TTAG? query.

The maximum number of segments may be limited by the memory depth of your oscilloscope. For example, an oscilloscope with 1M memory allows a maximum of 250 segments.

**Query Syntax**    `:ACQuire:SEGmented:INDEX?`

The :ACQuire:SEGmented:INDEX? query returns the current segmented memory index setting.

**Return Format**    `<index><NL>`  
`<index> ::= an integer from 1 to 1000 (w/4M memory) in NR1 format`

**See Also**

- "[:ACQuire:MODE](#)" on page 307
- "[:ACQuire:SEGmented:COUNt](#)" on page 311
- "[:DIGITIZE](#)" on page 268
- "[:SINGLE](#)" on page 294
- "[:RUN](#)" on page 292
- "[:WAVeform:SEGmented:COUNt](#)" on page 1474
- "[:WAVeform:SEGmented:TTAG](#)" on page 1475
- "[:ACQuire:SEGmented:ANALyze](#)" on page 310
- "[Introduction to :ACQuire Commands](#)" on page 300

**Example Code**

```
' Segmented memory commands example.
' -----
```

Option Explicit

```
Public myMgr As VisaComLib.ResourceManager
Public myScope As VisaComLib.FormattedIO488
Public varQueryResult As Variant
```

```

Public strQueryResult As String

Private Declare Sub Sleep Lib "kernel32" (ByVal dwMilliseconds As Long)

Sub Main()

On Error GoTo VisaComError

' Create the VISA COM I/O resource.
Set myMgr = New VisaComLib.ResourceManager
Set myScope = New VisaComLib.FormattedIO488
Set myScope.IO =
    myMgr.Open("USB0::0x0957::0x17A6::US50210029::0::INSTR")
myScope.IO.Clear      ' Clear the interface.

' Turn on segmented memory acquisition mode.
myScope.WriteString ":ACQuire:MODE SEGmented"
myScope.WriteString ":ACQuire:MODE?"
strQueryResult = myScope.ReadString
Debug.Print "Acquisition mode: " + strQueryResult

' Set the number of segments to 25.
myScope.WriteString ":ACQuire:SEGmented:COUNT 25"
myScope.WriteString ":ACQuire:SEGmented:COUNT?"
strQueryResult = myScope.ReadString
Debug.Print "Acquisition memory segments: " + strQueryResult

' If data will be acquired within the IO timeout:
'myScope.IO.Timeout = 10000
'myScope.WriteString ":DIGitize"
'Debug.Print ":DIGITIZE blocks until all segments acquired."
'myScope.WriteString ":WAVEform:SEGmented:COUNT?"
'varQueryResult = myScope.ReadNumber

' Or, to poll until the desired number of segments acquired:
myScope.WriteString ":SINGle"
Debug.Print ":SINGle does not block until all segments acquired."
Do
    Sleep 100      ' Small wait to prevent excessive queries.
    myScope.WriteString ":WAVEform:SEGmented:COUNT?"
    varQueryResult = myScope.ReadNumber
Loop Until varQueryResult = 25

Debug.Print "Number of segments in acquired data: " _
    + FormatNumber(varQueryResult)

Dim lngSegments As Long
lngSegments = varQueryResult

' For each segment:
Dim dblTimeTag As Double
Dim lngI As Long

For lngI = lngSegments To 1 Step -1

' Set the segmented memory index.
myScope.WriteString ":ACQuire:SEGmented:INDEX " + CStr(lngI)

```

```
myScope.WriteString ":ACQuire:SEGmented:INDEX?"
strQueryResult = myScope.ReadString
Debug.Print "Acquisition memory segment index: " + strQueryResult

' Display the segment time tag.
myScope.WriteString ":WAVEform:SEGmented:TTAG?"
dblTimeTag = myScope.ReadNumber
Debug.Print "Segment " + CStr(lngI) + " time tag: " _
+ FormatNumber(dblTimeTag, 12)

Next lngI

Exit Sub

VisaComError:
MsgBox "VISA COM Error:" + vbCrLf + Err.Description

End Sub
```

## :ACQuire:SRATe[:ANALog]

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:ACQuire:SRATe [:ANALog] &lt;rate&gt;</code> <code>&lt;rate&gt; ::= {AUTO   &lt;sample_rate&gt;}</code> <code>&lt;sample_rate&gt; ::= desired analog sample rate in NR3 format</code>
	Sets the desired acquisition sample rate:
	<ul style="list-style-type: none"> <li>• AUTO – puts the oscilloscope into Automatic (default) mode where the optimal sample rate is selected automatically by the oscilloscope.</li> <li>• &lt;sample_rate&gt; – If a numerical sample rate value is entered, this puts the oscilloscope into Digitizer (manual) mode with the desired sample rate.</li> </ul>
	The Automatic or Digitizer mode setting also affects the memory depth (see the :ACQuire:POINTS[:ANALog] command).
	The actual sample rate used is returned by the :ACQuire:SRATe[:ANALog]? query.
<b>Query Syntax</b>	<code>:ACQuire:SRATe [:ANALog] ? [MAXimum]</code>
	The :ACQuire:SRATe[:ANALog]? query returns the current oscilloscope acquisition sample rate. The sample rate is not directly controllable.
	When the MAXimum parameter is used, the oscilloscope's maximum possible sample rate is returned.
<b>Return Format</b>	<code>&lt;sample_rate&gt;&lt;NL&gt;</code> <code>&lt;sample_rate&gt; ::= sample rate in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :ACQuire Commands</a>" on page 300</li> <li>• "<a href="#">":ACQuire:POINTS[:ANALog]"</a> on page 308</li> <li>• "<a href="#">":ACQuire:SRATe[:ANALog]:AUTO"</a> on page 316</li> <li>• "<a href="#">":ACQuire:DIGitizer"</a> on page 306</li> </ul>

## :ACQuire:SRATe[:ANALog]:AUTO

**N** (see [page 1666](#))

**Command Syntax** :ACQuire:SRATe [:ANALog] :AUTO {{0 | OFF} | {1 | ON}}

The :ACQuire:SRATe[:ANALog]:AUTO command enables or disables Automatic determination of the analog channel sample rate:

- ON – the analog channel sample rate is automatically determined by the oscilloscope based on the horizontal time/div setting (Automatic mode, the oscilloscope's default).

This is equivalent to turning Digitizer mode off using the :ACQuire:DIGItizer command.

- OFF – the analog channel sample rate is set using the :ACQuire:SRATe[:ANALog] command.

This is equivalent to turning Digitizer mode on using the :ACQuire:DIGItizer command.

The Automatic or Digitizer mode setting also affects the memory depth (see the :ACQuire:POINts[:ANALog] command).

**Query Syntax** :ACQuire:SRATe [:ANALog] :AUTO?

The :ACQuire:SRATe[:ANALog]:AUTO? query returns the automatic analog sample rate setting.

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

**See Also**

- "[:ACQuire:DIGItizer](#)" on page 306
- "[:ACQuire:SRATe\[:ANALog\]](#)" on page 315
- "[:ACQuire:POINts\[:ANALog\]](#)" on page 308

## :ACQuire:TYPE

**C** (see [page 1666](#))

### Command Syntax

```
:ACQuire:TYPE <type>
<type> ::= {NORMAL | AVERage | HRESolution | PEAK}
```

The :ACQuire:TYPE command selects the type of data acquisition that is to take place. The acquisition types are:

- NORMAL – sets the oscilloscope in the normal mode.
- AVERage – sets the oscilloscope in the averaging mode. You can set the count by sending the :ACQuire:COUNt command followed by the number of averages. In this mode, the value for averages is an integer from 1 to 65536. The COUNt value determines the number of averages that must be acquired.

The AVERage type is not available when in segmented memory mode (:ACQuire:MODE SEGmented).

- HRESolution – sets the oscilloscope in the high-resolution mode (also known as *smoothing*). This mode is used to reduce noise at slower sweep speeds where the digitizer samples faster than needed to fill memory for the displayed time range.

For example, if the digitizer samples at 200 MSa/s, but the effective sample rate is 1 MSa/s (because of a slower sweep speed), only 1 out of every 200 samples needs to be stored. Instead of storing one sample (and throwing others away), the 200 samples are averaged together to provide the value for one display point. The slower the sweep speed, the greater the number of samples that are averaged together for each display point.

- PEAK – sets the oscilloscope in the peak detect mode. In this mode, :ACQuire:COUNt has no meaning.

The AVERage and HRESolution types can give you extra bits of vertical resolution. See the *User's Guide* for an explanation. When getting waveform data acquired using the AVERage and HRESolution types, be sure to use the WORD or ASCII waveform data formats to get the extra bits of vertical resolution.

### NOTE

The obsolete command ACQuire:TYPE:REALtime is functionally equivalent to sending ACQuire:MODE RTIME; TYPE NORMAL.

### Query Syntax

```
:ACQuire:TYPE?
```

The :ACQuire:TYPE? query returns the current acquisition type.

### Return Format

```
<acq_type><NL>
<acq_type> ::= {NORM | AVER | HRES | PEAK}
```

- See Also**
- "[Introduction to :ACQuire Commands](#)" on page 300
  - "[":ACQuire:COUNT](#)" on page 304
  - "[":ACQuire:MODE](#)" on page 307
  - "[":DIGItize](#)" on page 268
  - "[":WAveform:FORMat](#)" on page 1465
  - "[":WAveform:TYPE](#)" on page 1482
  - "[":WAveform:PREamble](#)" on page 1470
- Example Code**
- ```
' AQUIRE_TYPE - Sets the acquisition mode, which can be NORMAL,  
' PEAK, or AVERAGE.  
myScope.WriteString ":ACQuire:TYPE NORMAl"
```

See complete example programs at: [Chapter 46](#), “Programming Examples,” starting on page 1675

## 9 :BUS<n> Commands

Control all oscilloscope functions associated with buses made up of digital channels. See "[Introduction to :BUS<n> Commands](#)" on page 320.

**Table 98** :BUS<n> Commands Summary

| Command   | Query  | Options and Query Returns   |
|---|--|---|
| :BUS<n>:BIT<m> {{0   OFF}   {1   ON}} (see <a href="#">page 321</a> )               | :BUS<n>:BIT<m>? (see <a href="#">page 321</a> )  | {0   1}<br><n> ::= 1 or 2; an integer in NR1 format<br><br><m> ::= 0-15; an integer in NR1 format   |
| :BUS<n>:BITS <channel_list>, {{0   OFF}   {1   ON}} (see <a href="#">page 322</a> ) | :BUS<n>:BITS? (see <a href="#">page 322</a> )    | <channel_list>, {0   1}<br><channel_list> ::= (@<m>,<m>:<m> ... ) where "," is separator and ":" is range<br><br><n> ::= 1 or 2; an integer in NR1 format<br><br><m> ::= 0-15; an integer in NR1 format |
| :BUS<n>:CLEar (see <a href="#">page 324</a> )                                       | n/a  | <n> ::= 1 or 2; an integer in NR1 format  |
| :BUS<n>:DISPlay {{0   OFF}   {1   ON}} (see <a href="#">page 325</a> )              | :BUS<n>:DISPlay? (see <a href="#">page 325</a> ) | {0   1}<br><n> ::= 1 or 2; an integer in NR1 format   |

**Table 98** :BUS<n> Commands Summary (continued)

| Command  | Query   | Options and Query Returns   |
|--|---|---|
| :BUS<n>:LABEL<br><string> (see<br><a href="#">page 326</a> ) | :BUS<n>:LABEL? (see<br><a href="#">page 326</a> ) | <string> ::= quoted ASCII string<br>up to 10 characters<br><br><n> ::= 1 or 2; an integer in NR1<br>format  |
| :BUS<n>:MASK <mask><br>(see <a href="#">page 327</a> )       | :BUS<n>:MASK? (see<br><a href="#">page 327</a> )  | <mask> ::= 32-bit integer in<br>decimal, <nondecimal>, or<br><string><br><br><nondecimal> ::= #Hnn...n where n<br>::= {0,...,9   A,...,F} for<br>hexadecimal<br><br><nondecimal> ::= #Bnn...n where n<br>::= {0   1} for binary<br><br><string> ::= "0xnn...n" where n<br>::= {0,...,9   A,...,F} for<br>hexadecimal<br><br><n> ::= 1 or 2; an integer in NR1<br>format |

**Introduction to  
:BUS<n>  
Commands**

<n> ::= {1 | 2}

The BUS subsystem commands control the viewing, labeling, and digital channel makeup of two possible buses.

**NOTE**

These commands are only valid for the MSO models.

### Reporting the Setup

Use :BUS<n>? to query setup information for the BUS subsystem.

### Return Format

The following is a sample response from the :BUS1? query. In this case, the query was issued following a \*RST command.

```
:BUS1:DISP 0;LAB "BUS1";MASK +255
```

## :BUS<n>:BIT<m>

**N** (see [page 1666](#))

### Command Syntax

```
:BUS<n>:BIT<m> <display>
<display> ::= {{1 | ON} | {0 | OFF}}
<n> ::= An integer, 1 or 2, is attached as a suffix to BUS
and defines the bus that is affected by the command.
<m> ::= An integer, 0,...,15, is attached as a suffix to BIT
and defines the digital channel that is affected by the command.
```

The :BUS<n>:BIT<m> command includes or excludes the selected bit as part of the definition for the selected bus. If the parameter is a 1 (ON), the bit is included in the definition. If the parameter is a 0 (OFF), the bit is excluded from the definition. Note: BIT0-15 correspond to DIGital0-15.

### NOTE

This command is only valid for the MSO models.

### Query Syntax

```
:BUS<n>:BIT<m>?
```

The :BUS<n>:BIT<m>? query returns the value indicating whether the specified bit is included or excluded from the specified bus definition.

### Return Format

```
<display><NL>
<display> ::= {0 | 1}
```

### See Also

- "[Introduction to :BUS<n> Commands](#)" on page 320
- "[":BUS<n>:BITS](#)" on page 322
- "[":BUS<n>:CLEar](#)" on page 324
- "[":BUS<n>:DISPlay](#)" on page 325
- "[":BUS<n>:LABEL](#)" on page 326
- "[":BUS<n>:MASK](#)" on page 327

### Example Code

```
' Include digital channel 1 in bus 1:
myScope.WriteString ":BUS1:BIT1 ON"
```

## :BUS<n>:BITS

**N** (see [page 1666](#))

|                       |   |
|-----------------------|---|
| <b>Command Syntax</b> | <code>:BUS&lt;n&gt;:BITS &lt;channel_list&gt;, &lt;display&gt;</code>   |
|                       | <code>&lt;channel_list&gt; ::= (@&lt;m&gt;, &lt;m&gt;:&lt;m&gt;, ...)</code> where commas separate bits and colons define bit ranges. |
|                       | <code>&lt;m&gt; ::= An integer, 0,...,15, defines a digital channel affected by the command.</code>                                   |
|                       | <code>&lt;display&gt; ::= {{1   ON}   {0   OFF}}</code>   |
|                       | <code>&lt;n&gt; ::= An integer, 1 or 2, is attached as a suffix to BUS and defines the bus that is affected by the command.</code>    |

The :BUS<n>:BITS command includes or excludes the selected bits in the channel list in the definition of the selected bus. If the parameter is a 1 (ON) then the bits in the channel list are included as part of the selected bus definition. If the parameter is a 0 (OFF) then the bits in the channel list are excluded from the definition of the selected bus.

### NOTE

This command is only valid for the MSO models.

|                      |   |
|----------------------|---|
| <b>Query Syntax</b>  | <code>:BUS&lt;n&gt;:BITS?</code>  |
|                      | The :BUS<n>:BITS? query returns the definition for the specified bus.   |
| <b>Return Format</b> | <code>&lt;channel_list&gt;, &lt;display&gt;&lt;NL&gt;</code><br><code>&lt;channel_list&gt; ::= (@&lt;m&gt;, &lt;m&gt;:&lt;m&gt;, ...)</code> where commas separate bits and colons define bit ranges.<br><code>&lt;display&gt; ::= {0   1}</code>   |
| <b>See Also</b>      | <ul style="list-style-type: none"> <li>· "<a href="#">Introduction to :BUS&lt;n&gt; Commands</a>" on page 320</li> <li>· "<a href="#">:BUS&lt;n&gt;:BIT&lt;m&gt;</a>" on page 321</li> <li>· "<a href="#">:BUS&lt;n&gt;:CLEar</a>" on page 324</li> <li>· "<a href="#">:BUS&lt;n&gt;:DISPlay</a>" on page 325</li> <li>· "<a href="#">:BUS&lt;n&gt;:LABEL</a>" on page 326</li> <li>· "<a href="#">:BUS&lt;n&gt;:MASK</a>" on page 327</li> </ul> |
| <b>Example Code</b>  | <pre>' Include digital channels 1, 2, 4, 5, 6, 7, 8, and 9 in bus 1:<br/>myScope.WriteString ":BUS1:BITS (@1,2,4:9), ON"<br/><br/>' Include digital channels 1, 5, 7, and 9 in bus 1:<br/>myScope.WriteString ":BUS1:BITS (@1,5,7,9), ON"<br/><br/>' Include digital channels 1 through 15 in bus 1:<br/>myScope.WriteString ":BUS1:BITS (@1,15), ON"</pre>   |

```
myScope.WriteString ":BUS1:BITS (@1:15), ON"  
' Include digital channels 1 through 5, 8, and 14 in bus 1:  
myScope.WriteString ":BUS1:BITS (@1:5,8,14), ON"
```

## :BUS<n>:CLEar

**N** (see [page 1666](#))

**Command Syntax** :BUS<n>:CLEar

<n> ::= An integer, 1 or 2, is attached as a suffix to BUS and defines the bus that is affected by the command.

The :BUS<n>:CLEar command excludes all of the digital channels from the selected bus definition.

### NOTE

This command is only valid for the MSO models.

### See Also

- "[Introduction to :BUS<n> Commands](#)" on page 320
- "[":BUS<n>:BIT<m>"](#) on page 321
- "[":BUS<n>:BITS"](#) on page 322
- "[":BUS<n>:DISPlay"](#) on page 325
- "[":BUS<n>:LABEL"](#) on page 326
- "[":BUS<n>:MASK"](#) on page 327

## :BUS<n>:DISPlay

**N** (see [page 1666](#))

**Command Syntax** :BUS<n>:DISPlay <value>

<value> ::= {{1 | ON} | {0 | OFF}}

<n> ::= An integer, 1 or 2, is attached as a suffix to BUS and defines the bus that is affected by the command.

The :BUS<n>:DISPlay command enables or disables the view of the selected bus.

### NOTE

This command is only valid for the MSO models.

**Query Syntax** :BUS<n>:DISPlay?

The :BUS<n>:DISPlay? query returns the display value of the selected bus.

**Return Format** <value><NL>

<value> ::= {0 | 1}

- See Also**
- "[Introduction to :BUS<n> Commands](#)" on page 320
  - "[":BUS<n>:BIT<m>"](#) on page 321
  - "[":BUS<n>:BITS"](#) on page 322
  - "[":BUS<n>:CLEar"](#) on page 324
  - "[":BUS<n>:LABEL"](#) on page 326
  - "[":BUS<n>:MASK"](#) on page 327

## :BUS<n>:LABEL

**N** (see [page 1666](#))

**Command Syntax**    `:BUS<n>:LABEL <quoted_string>`

`<quoted_string>` ::= any series of 10 or less characters as a quoted ASCII string.

`<n>` ::= An integer, 1 or 2, is attached as a suffix to BUS and defines the bus that is affected by the command.

The :BUS<n>:LABEL command sets the bus label to the quoted string. Setting a label for a bus will also result in the name being added to the label list.

### NOTE

This command is only valid for the MSO models.

### NOTE

Label strings are 10 characters or less, and may contain any commonly used ASCII characters. Labels with more than 10 characters are truncated to 10 characters.

#### Query Syntax

`:BUS<n>:LABEL?`

The :BUS<n>:LABEL? query returns the name of the specified bus.

#### Return Format

`<quoted_string><NL>`

`<quoted_string>` ::= any series of 10 or less characters as a quoted ASCII string.

#### See Also

- ["Introduction to :BUS<n> Commands"](#) on page 320
- [":BUS<n>:BIT<m>"](#) on page 321
- [":BUS<n>:BITS"](#) on page 322
- [":BUS<n>:CLEAR"](#) on page 324
- [":BUS<n>:DISPLAY"](#) on page 325
- [":BUS<n>:MASK"](#) on page 327
- [":CHANNEL<n>:LABEL"](#) on page 350
- [":DISPLAY:LABELLIST"](#) on page 429
- [":DIGITAL<d>:LABEL"](#) on page 406

#### Example Code

```
' Set the bus 1 label to "Data":  
myScope.WriteString ":BUS1:LABEL 'Data'"
```

## :BUS<n>:MASK

**N** (see [page 1666](#))

**Command Syntax**

```
:BUS<n>:MASK <mask>
<mask> ::= 32-bit integer in decimal, <nondecimal>, or <string>
<nondecimal> ::= #Hnn...n where n ::= {0,...,9 | A,...,F} for hexadecimal
<nondecimal> ::= #Bnn...n where n ::= {0 | 1} for binary
<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F} for hexadecimal
<n> ::= An integer, 1 or 2, is attached as a suffix to BUS
and defines the bus that is affected by the command.
```

The :BUS<n>:MASK command defines the bits included and excluded in the selected bus according to the mask. Set a mask bit to a "1" to include that bit in the selected bus, and set a mask bit to a "0" to exclude it.

### NOTE

This command is only valid for the MSO models.

**Query Syntax**

:BUS<n>:MASK?

The :BUS<n>:MASK? query returns the mask value for the specified bus.

**Return Format**

<mask><NL> in decimal format

**See Also**

- "[Introduction to :BUS<n> Commands](#)" on page 320
- "[":BUS<n>:BIT<m>"](#) on page 321
- "[":BUS<n>:BITS"](#) on page 322
- "[":BUS<n>:CLEar"](#) on page 324
- "[":BUS<n>:DISPlay"](#) on page 325
- "[":BUS<n>:LABel"](#) on page 326



# 10 :CALibrate Commands

Utility commands for viewing calibration status and for starting the user calibration procedure. See "[Introduction to :CALibrate Commands](#)" on page 330.

**Table 99** :CALibrate Commands Summary

| Command   | Query   | Options and Query Returns  |
|---|---|--|
| n/a   | :CALibrate:DATE? (see <a href="#">page 331</a> )      | <return value> ::= <year>,<month>,<day>; all in NR1 format   |
| :CALibrate:LABEL<br><string> (see <a href="#">page 332</a> )  | :CALibrate:LABEL?                                     | <string> ::= quoted ASCII string up to 32 characters   |
| :CALibrate:OUTPut<br><signal> (see <a href="#">page 333</a> ) | :CALibrate:OUTPut?                                    | <signal> ::= {TRIGgers   MASK   WAVEgen   WGEN1   WGEN2   TSource}<br><br>Note: WAVE and WGEN1 are equivalent.<br><br>Note: WGEN2 only available on models with 2 WaveGen outputs. |
| n/a   | :CALibrate:PROTected? (see <a href="#">page 335</a> ) | {"PROTected"   "UNPROtected"}  |
| :CALibrate:START (see <a href="#">page 336</a> )              | n/a   | n/a  |
| n/a   | :CALibrate:STATUS? (see <a href="#">page 337</a> )    | <return value> ::= <status_code>,<status_string><br><status_code> ::= an integer status code<br><status_string> ::= an ASCII status string   |

**Table 99** :CALibrate Commands Summary (continued)

| Command | Query   | Options and Query Returns   |
|---------|---|---|
| n/a     | :CALibrate:TEMPERATUR<br>e? (see <a href="#">page 338</a> ) | <return value> ::= degrees C<br>delta since last cal in NR3<br>format   |
| n/a     | :CALibrate:TIME? (see<br><a href="#">page 339</a> )         | <return value> ::=<br><hours>,<minutes>,<seconds>; all<br>in NR1 format |

**Introduction to  
:CALibrate  
Commands**

The CALibrate subsystem provides utility commands for:

- Determining the state of the calibration factor protection switch (CAL PROTECT).
- Saving and querying the calibration label string.
- Reporting the calibration time and date.
- Reporting changes in the temperature since the last calibration.
- Starting the user calibration procedure.

## :CALibrate:DATE

**N** (see [page 1666](#))

**Query Syntax** :CALibrate:DATE?

The :CALibrate:DATE? query returns the date of the last calibration.

**Return Format** <date><NL>

<date> ::= year,month,day in NR1 format<NL>

**See Also** • ["Introduction to :CALibrate Commands"](#) on page 330

## :CALibrate:LABel

**N** (see [page 1666](#))

**Command Syntax**    `:CALibrate:LABel <string>`

`<string>` ::= quoted ASCII string of up to 32 characters in length, not including the quotes

The CALibrate:LABel command saves a string that is up to 32 characters in length into the instrument's non-volatile memory. The string may be used to record calibration dates or other information as needed.

**Query Syntax**    `:CALibrate:LABel?`

The :CALibrate:LABel? query returns the contents of the calibration label string.

**Return Format**    `<string><NL>`

`<string>` ::= unquoted ASCII string of up to 32 characters in length

**See Also**    · "Introduction to :CALibrate Commands" on page 330

## :CALibrate:OUTPut

**N** (see [page 1666](#))

### Command Syntax

```
:CALibrate:OUTPut <signal>
<signal> ::= {TRIGgers | MASK | WAVEgen | WGEN1 | NFC | TSource}
```

Note: WAVE and WGEN1 are equivalent.

The CALibrate:OUTPut command sets the signal that is available on the rear panel TRIG OUT BNC:

- TRIGgers – pulse when a trigger event occurs. The output level is 0-5 V into an open circuit, and 0-2.5 V into  $50\ \Omega$ .
- MASK – signal from mask test indicating a failure.
- WAVEgen, WGEN1 – waveform generator sync output signal. This signal depends on the :WGEN<w>:FUNCTION setting:

| Waveform Type   | Sync Signal Characteristics  |
|---|--|
| SINusoid,<br>SQUare,<br>RAMP, PULSe,<br>SINC,<br>EXPRise,<br>EXPFall,<br>GAUSSian | The Sync signal is a TTL positive pulse that occurs when the waveform rises above zero volts (or the DC offset value). |
| DC, NOISe,<br>CARDiac   | N/A  |

- NFC – This option is available in the Near Field Communication (NFC) trigger mode when the ATRigger (Arm & Trigger) trigger event is selected (see [":TRIGger:NFC:TEvent" on page 1399](#)). The ATRigger trigger event lets you arm the oscilloscope on one event and then trigger on a second event or after a specified timeout period if the second event does not occur.

When :CALibrate:OUTPut is NFC and the specified event arms, the *TRIG OUTBNC* goes high. The oscilloscope waits until a second event is found or until the specified timeout period expires and then triggers.

- For NFC-A, the second event is SDD\_REQ.
- For NFC-B, the second event is ATTRIB.
- For NFC-F, the second event is ATR\_REQ.

When the oscilloscope triggers, the *TRIG OUTBNC* line goes low.

- TSOurce – The raw trigger signal from the oscilloscope's trigger circuit is output to Trig Out. It produces a rising edge whenever the input source would cause a trigger, even though that might occur multiple times within the time of a single acquisition. The trigger source can be a front panel analog input channel or an external trigger input. The output level is 0–5 V into an open circuit, and 0–2.5 V into 50 Ω. This option is not available in all trigger modes.

**Query Syntax** :CALibrate:OUTPut?

The :CALibrate:OUTPut query returns the current source of the TRIG OUT BNC signal.

**Return Format** <signal><NL>

<signal> ::= {TRIG | MASK | WAVE | NFC | TSO}

**See Also** • "[Introduction to :CALibrate Commands](#)" on page 330

• "[":WGEN<w>:FUNCTION](#)" on page 1506

## :CALibrate:PROTected

**N** (see [page 1666](#))

**Query Syntax** `:CALibrate:PROTected?`

The `:CALibrate:PROTected?` query returns the rear-panel calibration protect (CAL PROTECT) button state. The value PROTected indicates calibration is disabled, and UNPROTECTED indicates calibration is enabled.

**Return Format** `<switch><NL>`

`<switch> ::= { "PROTected" | "UNPROTECTED" }`

**See Also** • ["Introduction to :CALibrate Commands"](#) on page 330

## :CALibrate:STARt

**N** (see [page 1666](#))

**Command Syntax** :CALibrate:STARt

The CALibrate:STARt command starts the user calibration procedure.

### NOTE

Before starting the user calibration procedure, you must set the rear panel CALIBRATION switch to UNPROTECTED, and you must connect BNC cables from the TRIG OUT connector to the analog channel inputs. See the *User's Guide* for details.

### See Also

- "[Introduction to :CALibrate Commands](#)" on page 330
- "[:CALibrate:PROTected](#)" on page 335

## :CALibrate:STATus

**N** (see [page 1666](#))

**Query Syntax** :CALibrate:STATus?

The :CALibrate:STATus? query returns the summary results of the last user calibration procedure.

**Return Format**

```
<return value><NL>
<return value> ::= <status_code>,<status_string>
<status_code> ::= an integer status code
<status_string> ::= an ASCII status string
```

The status codes and strings can be:

| Status Code | Status String  |
|-------------|----------------|
| +0          | Calibrated     |
| -1          | Not Calibrated |

**See Also** • ["Introduction to :CALibrate Commands"](#) on page 330

## :CALibrate:TEMPerature

**N** (see [page 1666](#))

**Query Syntax** :CALibrate:TEMPerature?

The :CALibrate:TEMPerature? query returns the change in temperature since the last user calibration procedure.

**Return Format** <return value><NL>

<return value> ::= degrees C delta since last cal in NR3 format

**See Also** • ["Introduction to :CALibrate Commands" on page 330](#)

## :CALibrate:TIME

**N** (see [page 1666](#))

**Query Syntax** :CALibrate:TIME?

The :CALibrate:TIME? query returns the time of the last calibration.

**Return Format** <date><NL>

<date> ::= hour,minutes,seconds in NR1 format

**See Also** • ["Introduction to :CALibrate Commands"](#) on page 330



# 11 :CHANnel<n> Commands

Control all oscilloscope functions associated with individual analog channels or groups of channels. See "[Introduction to :CHANnel<n> Commands](#)" on page 344.

**Table 100** :CHANnel<n> Commands Summary

| Command   | Query   | Options and Query Returns  |
|---|---|--|
| :CHANnel<n>:BWLimit<br>{ {0   OFF}   {1   ON} } (see <a href="#">page 345</a> ) | :CHANnel<n>:BWLimit?<br>(see <a href="#">page 345</a> )   | {0   1}<br><n> ::= 1 to (# analog channels) in NR1 format  |
| :CHANnel<n>:COUPling<br><coupling> (see <a href="#">page 346</a> )              | :CHANnel<n>:COUPling?<br>(see <a href="#">page 346</a> )  | <coupling> ::= {AC   DC}<br><n> ::= 1 to (# analog channels) in NR1 format   |
| :CHANnel<n>:DISPlay<br>{ {0   OFF}   {1   ON} } (see <a href="#">page 347</a> ) | :CHANnel<n>:DISPlay?<br>(see <a href="#">page 347</a> )   | {0   1}<br><n> ::= 1 to (# analog channels) in NR1 format  |
| :CHANnel<n>:IMPedance<br><impedance> (see <a href="#">page 348</a> )            | :CHANnel<n>:IMPedance?<br>(see <a href="#">page 348</a> ) | <impedance> ::= {ONEMeg   FIFTy}<br><n> ::= 1 to (# analog channels) in NR1 format   |
| :CHANnel<n>:INVert<br>{ {0   OFF}   {1   ON} } (see <a href="#">page 349</a> )  | :CHANnel<n>:INVert?<br>(see <a href="#">page 349</a> )    | {0   1}<br><n> ::= 1 to (# analog channels) in NR1 format  |
| :CHANnel<n>:LABel<br><string> (see <a href="#">page 350</a> )                   | :CHANnel<n>:LABel?<br>(see <a href="#">page 350</a> )     | <string> ::= any series of 32 or less ASCII characters enclosed in quotation marks<br><n> ::= 1 to (# analog channels) in NR1 format |
| :CHANnel<n>:OFFSet<br><offset>[suffix] (see <a href="#">page 351</a> )          | :CHANnel<n>:OFFSet?<br>(see <a href="#">page 351</a> )    | <offset> ::= Vertical offset value in NR3 format<br>[suffix] ::= {V   mV}<br><n> ::= 1-2 or 1-4; in NR1 format                       |

**Table 100** :CHANnel<n> Commands Summary (continued)

| Command  | Query  | Options and Query Returns  |
|--|--|--|
| :CHANnel<n>:PROBe <attenuation> (see page 352)                   | :CHANnel<n>:PROBe? (see page 352)                | <attenuation> ::= Probe attenuation ratio in NR3 format<br><n> ::= 1-2 or 1-4r in NR1 format   |
| :CHANnel<n>:PROBe:BTN <setting> (see page 353)                   | :CHANnel<n>:PROBe:BTN? (see page 353)            | <n> ::= 1 to (# analog channels) in NR1 format<br><setting> ::= {HEADlight   INFinimode   RSTop   SINGLE   CDISplay   AUToscale   FTRigger   QACTION   NACTion   NONE}                 |
| :CHANnel<n>:PROBe:CALibration (see page 354)                     | n/a  | n/a  |
| :CHANnel<n>:PROBe:EXTernal {{0   OFF}   {1   ON}} (see page 355) | :CHANnel<n>:PROBe:EXTernal? (see page 355)       | <n> ::= 1 to (# analog channels) in NR1 format<br><setting> ::= {0   1}  |
| :CHANnel<n>:PROBe:EXTernal:GAIN <gain_factor> (see page 356)     | :CHANnel<n>:PROBe:EXTernal:GAIN? (see page 356)  | <n> ::= 1 to (# analog channels) in NR1 format<br><gain_factor> ::= a real number from 0.0001 to 1000 in NR3 format  |
| :CHANnel<n>:PROBe:EXTernal:UNITS <units> (see page 357)          | :CHANnel<n>:PROBe:EXTernal:UNITS? (see page 357) | <n> ::= 1 to (# analog channels) in NR1 format<br><units> ::= {VOLT   AMPere}  |
| :CHANnel<n>:PROBe:HEAD[:TYPE] <head_param> (see page 358)        | :CHANnel<n>:PROBe:HEAD[:TYPE]? (see page 358)    | <head_param> ::= {SEND0   SEND6   SEND12   SEND20   DIFF0   DIFF6   DIFF12   DIFF20   DSMA   DSMA6   NONE}<br><n> ::= 1 to (# analog channels) in NR1 format                           |
| n/a  | :CHANnel<n>:PROBe:ID? (see page 359)             | <probe id> ::= unquoted ASCII string up to 11 characters<br><n> ::= 1 to (# analog channels) in NR1 format   |
| :CHANnel<n>:PROBe:MMO Del <value> (see page 360)                 | :CHANnel<n>:PROBe:MMO Del? (see page 360)        | <value> ::= {P5205   P5210   P6205   P6241   P6243   P6245   P6246   P6247   P6248   P6249   P6250   P6251   P670X   P671X   TCP202}<br><n> ::= 1 to (# analog channels) in NR1 format |

**Table 100** :CHANnel<n> Commands Summary (continued)

| Command  | Query   | Options and Query Returns  |
|--|---|--|
| :CHANnel<n>:PROBe:MOD<br>E <setting> (see<br><a href="#">page 361</a> )              | :CHANnel<n>:PROBe:MOD<br>E? (see <a href="#">page 361</a> )   | <n> ::= 1 to (# analog channels)<br>in NR1 format<br><br><setting> ::= {DIFFerential  <br>DOFFset   SEA   SEB   CM}                                  |
| :CHANnel<n>:PROBe:RSE<br>Nse <value> (see<br><a href="#">page 362</a> )              | :CHANnel<n>:PROBe:RSE<br>Nse? (see <a href="#">page 362</a> ) | <value> ::= Ohms in NR3 format<br><br><n> ::= 1 to (# analog channels)<br>in NR1 format  |
| :CHANnel<n>:PROBe:SKE<br>W <skew_value> (see<br><a href="#">page 363</a> )           | :CHANnel<n>:PROBe:SKE<br>W? (see <a href="#">page 363</a> )   | <skew_value> ::= -100 ns to +100<br>ns in NR3 format<br><br><n> ::= 1 to (# analog channels)<br>in NR1 format  |
| :CHANnel<n>:PROBe:STY<br>Pe <signal type> (see<br><a href="#">page 364</a> )         | :CHANnel<n>:PROBe:STY<br>Pe? (see <a href="#">page 364</a> )  | <signal type> ::= {DIFFerential  <br>SINGle}<br><br><n> ::= 1 to (# analog channels)<br>in NR1 format  |
| :CHANnel<n>:PROBe:ZOO<br>M {{0   OFF}   {1  <br>ON}} (see <a href="#">page 365</a> ) | :CHANnel<n>:PROBe:ZOO<br>M? (see <a href="#">page 365</a> )   | <setting> ::= {0   1}<br><br><n> ::= 1 to (# analog channels)<br>in NR1 format   |
| :CHANnel<n>:PROTectio<br>n (see <a href="#">page 366</a> )                           | :CHANnel<n>:PROTectio<br>n? (see <a href="#">page 366</a> )   | {NORM   TRIP}<br><br><n> ::= 1 to (# analog channels)<br>in NR1 format   |
| :CHANnel<n>:RANGE<br><range>[suffix] (see<br><a href="#">page 367</a> )              | :CHANnel<n>:RANGE?<br>(see <a href="#">page 367</a> )         | <range> ::= Vertical full-scale<br>range value in NR3 format<br><br>[suffix] ::= {V   mV}<br><br><n> ::= 1 to (# analog channels)<br>in NR1 format   |
| :CHANnel<n>:SCALE<br><scale>[suffix] (see<br><a href="#">page 368</a> )              | :CHANnel<n>:SCALE?<br>(see <a href="#">page 368</a> )         | <scale> ::= Vertical units per<br>division value in NR3 format<br><br>[suffix] ::= {V   mV}<br><br><n> ::= 1 to (# analog channels)<br>in NR1 format |
| :CHANnel<n>:UNITS<br><units> (see <a href="#">page 369</a> )                         | :CHANnel<n>:UNITS?<br>(see <a href="#">page 369</a> )         | <units> ::= {VOLT   AMPere}<br><br><n> ::= 1 to (# analog channels)<br>in NR1 format   |
| :CHANnel<n>:VERNier<br>{{0   OFF}   {1  <br>ON}} (see <a href="#">page 370</a> )     | :CHANnel<n>:VERNier?<br>(see <a href="#">page 370</a> )       | {0   1}<br><br><n> ::= 1 to (# analog channels)<br>in NR1 format   |

**Introduction to  
:CHANnel<n>  
Commands**

<n> ::= 1 to (# analog channels) in NR1 format

The CHANnel<n> subsystem commands control an analog channel (vertical or Y-axis of the oscilloscope). Channels are independently programmable for all offset, probe, coupling, bandwidth limit, inversion, vernier, and range (scale) functions. The channel number (1, 2, 3, or 4) specified in the command selects the analog channel that is affected by the command.

A label command provides identifying annotations of up to 10 characters.

You can toggle the channel displays on and off with the :CHANnel<n>:DISPlay command as well as with the root level commands :VIEW and :BLANK.

**NOTE**

The obsolete CHANnel subsystem is supported.

### Reporting the Setup

Use :CHANnel1?, :CHANnel2?, :CHANnel3? or :CHANnel4? to query setup information for the CHANnel<n> subsystem.

### Return Format

The following are sample responses from the :CHANnel<n>? query. In this case, the query was issued following a \*RST command.

```
:CHAN1:RANG +40.0E+00;OFFS +0.00000E+00;COUP DC;IMP ONEM;DISP 1;BWL 0;
INV 0;LAB "1";UNIT VOLT;PROB +10E+00;PROB:SKEW +0.00E+00;STYP SING
```

## :CHANnel<n>:BWLimit

**C** (see [page 1666](#))

**Command Syntax** :CHANnel<n>:BWLimit <bwlimit>

<bwlimit> ::= {{1 | ON} | {0 | OFF}}

<n> ::= 1 to (# analog channels) in NR1 format

The :CHANnel<n>:BWLimit command controls an internal low-pass filter. When the filter is on, the bandwidth of the specified channel is limited to approximately 25 MHz.

**Query Syntax** :CHANnel<n>:BWLimit?

The :CHANnel<n>:BWLimit? query returns the current setting of the low-pass filter.

**Return Format** <bwlimit><NL>

<bwlimit> ::= {1 | 0}

**See Also** • ["Introduction to :CHANnel<n> Commands"](#) on page 344

## :CHANnel<n>:COUpling

**C** (see [page 1666](#))

**Command Syntax**    `:CHANnel<n>:COUpling <coupling>`

`<coupling> ::= {AC | DC}`

`<n> ::= 1 to (# analog channels) in NR1 format`

The :CHANnel<n>:COUpling command selects the input coupling for the specified channel. The coupling for each analog channel can be set to AC or DC.

**Query Syntax**    `:CHANnel<n>:COUpling?`

The :CHANnel<n>:COUpling? query returns the current coupling for the specified channel.

**Return Format**    `<coupling value><NL>`

`<coupling value> ::= {AC | DC}`

**See Also**    • "Introduction to :CHANnel<n> Commands" on page 344

## :CHANnel<n>:DISPlay

**C** (see [page 1666](#))

|                       |   |
|-----------------------|---|
| <b>Command Syntax</b> | <code>:CHANnel&lt;n&gt;:DISPlay &lt;display value&gt;</code>  |
|                       | <code>&lt;display value&gt; ::= {{1   ON}   {0   OFF}}</code>   |
|                       | <code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>   |
|                       | The :CHANnel<n>:DISPlay command turns the display of the specified channel on or off.   |
| <b>Query Syntax</b>   | <code>:CHANnel&lt;n&gt;:DISPlay?</code>   |
|                       | The :CHANnel<n>:DISPlay? query returns the current display setting for the specified channel.   |
| <b>Return Format</b>  | <code>&lt;display value&gt;&lt;NL&gt;</code><br><code>&lt;display value&gt; ::= {1   0}</code>  |
| <b>See Also</b>       | <ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :CHANnel&lt;n&gt; Commands</a>" on page 344</li> <li>• "<a href="#">":VIEW"</a> on page 298</li> <li>• "<a href="#">":BLANK"</a> on page 266</li> <li>• "<a href="#">":STATus"</a> on page 295</li> <li>• "<a href="#">":POD&lt;n&gt;:DISPlay"</a> on page 753</li> <li>• "<a href="#">":DIGital&lt;d&gt;:DISPlay"</a> on page 405</li> </ul> |

**:CHANnel<n>:IMPedance****C** (see [page 1666](#))**Command Syntax**    `:CHANnel<n>:IMPedance <impedance>`    `<impedance> ::= {ONEMeg | FIFTy}`    `<n> ::= 1 to (# analog channels) in NR1 format`

The :CHANnel<n>:IMPedance command selects the input impedance setting for the specified analog channel. The legal values for this command are ONEMeg (1 MΩ) and FIFTy (50Ω).

**Query Syntax**    `:CHANnel<n>:IMPedance?`

The :CHANnel<n>:IMPedance? query returns the current input impedance setting for the specified channel.

**Return Format**    `<impedance value><NL>`    `<impedance value> ::= {ONEM | FIFT}`**See Also**    · "Introduction to :CHANnel<n> Commands" on page 344

## :CHANnel<n>:INVert

**N** (see [page 1666](#))

**Command Syntax** :CHANnel<n>:INVert <invert value>

<invert value> ::= {{1 | ON} | {0 | OFF}}

<n> ::= 1 to (# analog channels) in NR1 format

The :CHANnel<n>:INVert command selects whether or not to invert the input signal for the specified channel. The inversion may be 1 (ON/inverted) or 0 (OFF/not inverted).

**Query Syntax** :CHANnel<n>:INVert?

The :CHANnel<n>:INVert? query returns the current state of the channel inversion.

**Return Format** <invert value><NL>

<invert value> ::= {0 | 1}

**See Also** • ["Introduction to :CHANnel<n> Commands" on page 344](#)

## :CHANnel<n>:LABel

**N** (see [page 1666](#))

**Command Syntax**

```
:CHANnel<n>:LABel <string>
<string> ::= quoted ASCII string
<n> ::= 1 to (# analog channels) in NR1 format
```

### NOTE

Label strings are 32 characters or less, and may contain any commonly used ASCII characters. Labels with more than 32 characters are truncated to 32 characters. Lower case characters are converted to upper case.

The :CHANnel<n>:LABel command sets the analog channel label to the string that follows. Setting a label for a channel also adds the name to the label list in non-volatile memory (replacing the oldest label in the list).

**Query Syntax**

```
:CHANnel<n>:LABel?
```

The :CHANnel<n>:LABel? query returns the label associated with a particular analog channel.

**Return Format**

```
<string><NL>
```

<string> ::= quoted ASCII string

**See Also**

- ["Introduction to :CHANnel<n> Commands"](#) on page 344
- [":DISPlay:LABel"](#) on page 428
- [":DIGItal<d>:LABel"](#) on page 406
- [":DISPlay:LABList"](#) on page 429
- [":BUS<n>:LABel"](#) on page 326

**Example Code**

```
' LABEL - This command allows you to write a name (32 characters
' maximum) next to the channel number. It is not necessary, but
' can be useful for organizing the display.
myScope.WriteString ":CHANnel1:LABel ""CAL 1""'" Label ch1 "CAL 1".
myScope.WriteString ":CHANnel2:LABel ""CAL2""'" Label ch1 "CAL2".
```

See complete example programs at: [Chapter 46, “Programming Examples,”](#) starting on page 1675

## :CHANnel<n>:OFFSet

**C** (see [page 1666](#))

|                       |  |
|-----------------------|--|
| <b>Command Syntax</b> | <code>:CHANnel&lt;n&gt;:OFFSet &lt;offset&gt; [&lt;suffix&gt;]</code>  |
|                       | <code>&lt;offset&gt;</code> ::= Vertical offset value in NR3 format  |
|                       | <code>&lt;suffix&gt;</code> ::= {v   mV}   |
|                       | <code>&lt;n&gt;</code> ::= 1 to (# analog channels) in NR1 format  |
|                       | The :CHANnel<n>:OFFSet command sets the value that is represented at center screen for the selected channel. The range of legal values varies with the value set by the :CHANnel<n>:RANGE and :CHANnel<n>:SCALE commands. If you set the offset to a value outside of the legal range, the offset value is automatically set to the nearest legal value. Legal values are affected by the probe attenuation setting. |
| <b>Query Syntax</b>   | <code>:CHANnel&lt;n&gt;:OFFSet?</code>   |
|                       | The :CHANnel<n>:OFFSet? query returns the current offset value for the selected channel.   |
| <b>Return Format</b>  | <code>&lt;offset&gt;&lt;NL&gt;</code>  |
|                       | <code>&lt;offset&gt;</code> ::= Vertical offset value in NR3 format  |
| <b>See Also</b>       | <ul style="list-style-type: none"> <li>· <a href="#">"Introduction to :CHANnel&lt;n&gt; Commands"</a> on page 344</li> <li>· <a href="#">":CHANnel&lt;n&gt;:RANGE"</a> on page 367</li> <li>· <a href="#">":CHANnel&lt;n&gt;:SCALE"</a> on page 368</li> <li>· <a href="#">":CHANnel&lt;n&gt;:PROBe"</a> on page 352</li> </ul>  |

## :CHANnel<n>:PROBe

**C** (see [page 1666](#))

|                       |  |
|-----------------------|--|
| <b>Command Syntax</b> | <code>:CHANnel&lt;n&gt;:PROBe &lt;attenuation&gt;</code><br><code>&lt;attenuation&gt; ::= probe attenuation ratio in NR3 format</code><br><code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code><br><code>The obsolete attenuation values X1, X10, X20, X100 are also supported.</code>                               |
|                       | The :CHANnel<n>:PROBe command specifies the probe attenuation factor for the selected channel.   |
|                       | The probe attenuation factor may be from 0.001 to 10000.   |
|                       | This command does not change the actual input sensitivity of the oscilloscope. It changes the reference constants for scaling the display factors, for making automatic measurements, and for setting trigger levels.  |
|                       | If an AutoProbe probe is connected to the oscilloscope, the attenuation value cannot be changed from the sensed value. Attempting to set the oscilloscope to an attenuation value other than the sensed value produces an error.   |
| <b>Query Syntax</b>   | <code>:CHANnel&lt;n&gt;:PROBe?</code>  |
|                       | The :CHANnel<n>:PROBe? query returns the current probe attenuation factor for the selected channel.  |
| <b>Return Format</b>  | <code>&lt;attenuation&gt;&lt;NL&gt;</code><br><code>&lt;attenuation&gt; ::= probe attenuation ratio in NR3 format</code>   |
| <b>See Also</b>       | <ul style="list-style-type: none"> <li>· <a href="#">"Introduction to :CHANnel&lt;n&gt; Commands"</a> on page 344</li> <li>· <a href="#">":CHANnel&lt;n&gt;:RANGE"</a> on page 367</li> <li>· <a href="#">":CHANnel&lt;n&gt;:SCALe"</a> on page 368</li> <li>· <a href="#">":CHANnel&lt;n&gt;:OFFSet"</a> on page 351</li> </ul> |
| <b>Example Code</b>   | <pre>' CHANNEL_PROBE - Sets the probe attenuation factor for the ' selected channel. The probe attenuation factor may be set ' from 0.001 to 10000. myScope.WriteString ":CHANnel1:PROBe 10"    ' Set Probe to 10:1.</pre>   |
|                       | See complete example programs at: <a href="#">Chapter 46</a> , “Programming Examples,” starting on page 1675   |

## :CHANnel<n>:PROBe:BTN

**N** (see [page 1666](#))

**Command Syntax** :CHANnel<n>:PROBe:BTN <setting>  
 <setting> ::= {HEADlight | INFiniemode | RSTop | SINGle | CDISplay  
 | AUToscale | FTRigger | QACTion | NACTion | NONE}  
 <n> ::= 1 to (# analog channels) in NR1 format

For N275xA InfiniiMode probes, the :CHANnel<n>:PROBe:BTN command sets the probe's quick-action button mode:

- HEADlight – Pressing the probe's quick-action button toggles the probe headlight on or off. Holding the quick-action button adjusts the intensity of the probe's headlight.
- INFiniemode – Cycles through the InfiniiMode settings (see :CHANnel<n>:PROBe:MODE).
- RSTop (Run/Stop) – Toggles between continuous data acquisition (running) and stopping data acquisitions (same as the oscilloscope's **[Run/Stop]** key).
- SINGle – Performs a single acquisition on the oscilloscope (same as the oscilloscope's **[Single]** key).
- CDISplay – Clears the oscilloscope display.
- AUToscale – Performs an oscilloscope Autoscale operation.
- FTRigger (Force Trigger) – Performs an oscilloscope "force trigger".
- QACTion (Quick Action) – Performs the quick action configured on the oscilloscope (see the oscilloscope's *user's guide* for more information).
- NACTion (No Action) – Disables the probe's quick-action button.
- NONE – When a probe does not have a quick-action button, this is the only valid setting.

**Query Syntax** :CHANnel<n>:PROBe:BTN?

The :CHANnel<n>:PROBe:BTN? query returns the N275xA InfiniiMode probe's quick-action button setting.

**Return Format** <setting><NL>  
 <setting> ::= {HEAD | INF | RST | SING | CDIS | AUT | FTR | QACT  
 | NACT | NONE}

**See Also** • "[:CHANnel<n>:PROBe:MODE](#)" on page 361

## :CHANnel<n>:PROBe:CALibration

**N** (see [page 1666](#))

**Command Syntax** :CHANnel<n>:PROBe:CALibration

The :CHANnel<n>:PROBe:CALibration command begins the probe degauss operation. For the N7026A and N2893A probes only.

## :CHANnel<n>:PROBe:EXTernal

**N** (see [page 1666](#))

**Command Syntax** :CHANnel<n>:PROBe:EXTernal {{0 | OFF} | {1 | ON}}  
 <n> ::= 1 to (# analog channels) in NR1 format

The :CHANnel<n>:PROBe:EXTernal command enables or disables External Scaling on the analog input channel. External Scaling can apply additional gain to the input channel to account for additional attenuators, adapters, etc., in the probing system.

**Query Syntax** :CHANnel<n>:PROBe:EXTernal?

The :CHANnel<n>:PROBe:EXTernal? query returns whether External Scaling is enabled (1) or disabled (0).

**Return Format** <setting><NL>  
 <setting> ::= {0 | 1}

**See Also** • [":CHANnel<n>:PROBe:EXTernal:GAIN" on page 356](#)  
 • [":CHANnel<n>:PROBe:EXTernal:UNITS" on page 357](#)

**:CHANnel<n>:PROBe:EXTernal:GAIN**

**N** (see [page 1666](#))

|                       |   |
|-----------------------|---|
| <b>Command Syntax</b> | <code>:CHANnel&lt;n&gt;:PROBe:EXTernal:GAIN &lt;gain_factor&gt;</code>  |
|                       | <code>&lt;gain_factor&gt; ::= a real number from 0.0001 to 1000 in NR3 format</code>  |
|                       | <code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>   |
|                       | The :CHANnel<n>:PROBe:EXTernal:GAIN command sets the gain associated with External Scaling.   |
| <b>Query Syntax</b>   | <code>:CHANnel&lt;n&gt;:PROBe:EXTernal:GAIN?</code>   |
|                       | The :CHANnel<n>:PROBe:EXTernal:GAIN? query returns the External Scaling gain setting.   |
| <b>Return Format</b>  | <code>&lt;gain_factor&gt;&lt;NL&gt;</code>  |
| <b>See Also</b>       | <ul style="list-style-type: none"><li><a href="#">":CHANnel&lt;n&gt;:PROBe:EXTernal" on page 355</a></li><li><a href="#">":CHANnel&lt;n&gt;:PROBe:EXTernal:UNITS" on page 357</a></li></ul> |

## :CHANnel<n>:PROBe:EXTernal:UNITS

**N** (see [page 1666](#))

**Command Syntax**

```
:CHANnel<n>:PROBe:EXTernal:UNITS <units>
<units> ::= {VOLT | AMPere}
<n> ::= 1 to (# analog channels) in NR1 format
```

The :CHANnel<n>:PROBe:EXTernal:UNITS command sets the measurement units for the connected probe. Select VOLT for a voltage probe and select AMPere for a current probe. Measurement results, channel sensitivity, and trigger level will reflect the measurement units you select.

**Query Syntax**

```
:CHANnel<n>:PROBe:EXTernal:UNITS?
```

The :CHANnel<n>:PROBe:EXTernal:UNITS? query returns the current units setting for the specified channel.

**Return Format**

```
<units><NL>
<units> ::= {VOLT | AMP}
```

**See Also**

- "[:CHANnel<n>:PROBe:EXTernal](#)" on page 355
- "[:CHANnel<n>:PROBe:EXTernal:GAIN](#)" on page 356

## :CHANnel<n>:PROBe:HEAD[:TYPE]

**C** (see [page 1666](#))

### Command Syntax

#### NOTE

This command is valid only for the 113xA Series probes.

```
:CHANnel<n>:PROBe:HEAD [:TYPE] <head_param>
<head_param> ::= {SEND0 | SEND6 | SEND12 | SEND20 | DIFF0 | DIFF6
                  | DIFF12 | DIFF20 | DSMA | DSMA6 | NONE}
<n> ::= {1 | 2 | 3 | 4}
```

The :CHANnel<n>:PROBe:HEAD[:TYPE] command sets an analog channel probe head type and dB value. You can choose from:

- SEND0 – Single-ended, 0 dB.
- SEND6 – Single-ended, 6 dB.
- SEND12 – Single-ended, 12 dB.
- SEND20 – Single-ended, 20 dB.
- DIFF0 – Differential, 0 dB.
- DIFF6 – Differential, 6 dB.
- DIFF12 – Differential, 12 dB.
- DIFF20 – Differential, 20 dB.
- DSMA – Differential SMA probe head, 0 dB.
- DSMA6 – Differential SMA probe head, 6 dB.

### Query Syntax

```
:CHANnel<n>:PROBe:HEAD [:TYPE] ?
```

The :CHANnel<n>:PROBe:HEAD[:TYPE]? query returns the current probe head type setting for the selected channel.

### Return Format

```
<head_param><NL>
<head_param> ::= {SEND0 | SEND6 | SEND12 | SEND20 | DIFF0 | DIFF6
                  | DIFF12 | DIFF20 | DSMA | DSMA6 | NONE}
```

### See Also

- "[Introduction to :CHANnel<n> Commands](#)" on page 344
- "[":CHANnel<n>:PROBe"](#) on page 352
- "[":CHANnel<n>:PROBe:ID"](#) on page 359
- "[":CHANnel<n>:PROBe:SKEW"](#) on page 363
- "[":CHANnel<n>:PROBe:STYPe"](#) on page 364

## :CHANnel<n>:PROBe:ID

**C** (see [page 1666](#))

**Query Syntax** :CHANnel<n>:PROBe:ID?

<n> ::= 1 to (# analog channels) in NR1 format

The :CHANnel<n>:PROBe:ID? query returns the type of probe attached to the specified oscilloscope channel.

**Return Format** <probe id><NL>

<probe id> ::= unquoted ASCII string up to 11 characters

Some of the possible returned values are:

- 1131A
- 1132A
- 1134A
- 1147A
- 1153A
- 1154A
- 1156A
- 1157A
- 1158A
- 1159A
- AutoProbe
- E2621A
- E2622A
- E2695A
- E2697A
- HP1152A
- HP1153A
- NONE
- Probe
- Unknown
- Unsupported

**See Also** · ["Introduction to :CHANnel<n> Commands" on page 344](#)

## :CHANnel<n>:PROBe:MMODel

**N** (see [page 1666](#))

|                       |   |
|-----------------------|---|
| <b>Command Syntax</b> | <code>:CHANnel&lt;n&gt;:PROBe:MMODel &lt;value&gt;</code>   |
|                       | <code>&lt;value&gt; ::= {P5205   P5210   P6205   P6241   P6243   P6245   P6246<br/>  P6247   P6248   P6249   P6250   P6251   P670X   P671X   TCP202}</code> |
|                       | <code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>   |
|                       | The :CHANnel<n>:PROBe:MMODel command sets the model number of the supported Tektronix probe.  |
| <b>Query Syntax</b>   | <code>:CHANnel&lt;n&gt;:PROBe:MMODel?</code>  |
|                       | The :CHANnel<n>:PROBe:MMODel? query returns the model number setting.   |
| <b>Return Format</b>  | <code>&lt;value&gt;&lt;NL&gt;</code>  |
|                       | <code>&lt;value&gt; ::= {P5205   P5210   P6205   P6241   P6243   P6245   P6246<br/>  P6247   P6248   P6249   P6250   P6251   P670X   P671X   TCP202}</code> |
| <b>See Also</b>       | <ul style="list-style-type: none"> <li>· <a href="#">":CHANnel&lt;n&gt;:PROBe:ID" on page 359</a></li> </ul>  |

## :CHANnel<n>:PROBe:MODE

**N** (see [page 1666](#))

|                       |  |
|-----------------------|--|
| <b>Command Syntax</b> | <code>:CHANnel&lt;n&gt;:PROBe:MODE &lt;setting&gt;</code>  |
|                       | <code>&lt;setting&gt; ::= {DIFFerential   DOFFset   SEA   SEB   CM}</code>   |
|                       | <code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>  |
|                       | For N275xA InfiniiMode probes, the :CHANnel<n>:PROBe:MODE command sets the probe's mode:   |
|                       | <ul style="list-style-type: none"> <li>• DIFFerential – Differential.</li> <li>• DOFFset – Differential with Offset.</li> <li>• SEA – Single-Ended, side A.</li> <li>• SEB – Single-Ended, side B.</li> <li>• CM – Common Mode.</li> </ul> |
| <b>Query Syntax</b>   | <code>:CHANnel&lt;n&gt;:PROBe:MODE?</code>   |
|                       | The :CHANnel<n>:PROBe:MODE? query returns the N275xA InfiniiMode probe's mode setting.   |
| <b>Return Format</b>  | <code>&lt;setting&gt;&lt;NL&gt;</code>   |
|                       | <code>&lt;setting&gt; ::= {DIFF   DOFF   SEA   SEB   CM}</code>  |
| <b>See Also</b>       | <ul style="list-style-type: none"> <li>• "<a href="#">":CHANnel&lt;n&gt;:PROBe:BTN</a>" on page 353</li> </ul>   |

## :CHANnel<n>:PROBe:RSENse

**N** (see [page 1666](#))

|                       |  |
|-----------------------|--|
| <b>Command Syntax</b> | <code>:CHANnel&lt;n&gt;:PROBe:RSENse &lt;value&gt;</code>  |
|                       | <code>&lt;value&gt; ::= Ohms in NR3 format</code>  |
|                       | <code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>  |
|                       | When the N2820A high-sensitivity current probe is used with the N2825A user-defined R-sense head, the :CHANnel<n>:PROBe:RSENse command specifies the value of the R-sense resistor that is being probed in the device under test (DUT). Supported R-sense resistor values are from 1 mΩ to 1MΩ.  |
| <b>Query Syntax</b>   | <code>:CHANnel&lt;n&gt;:PROBe:RSENse?</code>   |
|                       | The :CHANnel<n>:PROBe:RSENse? query returns the R-sense resistor value setting.  |
|                       | When the N2820A high-sensitivity current probe is not attached, the query returns "INF".   |
|                       | When the N2820A high-sensitivity current probe is attached and a special head is attached to the probe, the query returns the value of the special head. For example, if the head is a "20 mΩ" head, the query returns 0.02.   |
| <b>Return Format</b>  | <code>{&lt;value&gt;   INF}&lt;NL&gt;</code><br><code>&lt;value&gt; ::= Ohms in NR3 format</code>  |
| <b>See Also</b>       | <ul style="list-style-type: none"> <li>· <a href="#">":CHANnel&lt;n&gt;:PROBe:ZOOM" on page 365</a></li> <li>· <a href="#">":MEASure:DUAL:CHARge" on page 635</a></li> <li>· <a href="#">":MEASure:DUAL:VAMPLitude" on page 636</a></li> <li>· <a href="#">":MEASure:DUAL:VAVerage" on page 637</a></li> <li>· <a href="#">":MEASure:DUAL:VBASe" on page 638</a></li> <li>· <a href="#">":MEASure:DUAL:VPP" on page 639</a></li> <li>· <a href="#">":MEASure:DUAL:VRMS" on page 640</a></li> </ul> |

## :CHANnel<n>:PROBe:SKEW

**C** (see [page 1666](#))

**Command Syntax** :CHANnel<n>:PROBe:SKEW <skew value>

<skew value> ::= skew time in NR3 format

<skew value> ::= -100 ns to +100 ns

<n> ::= 1 to (# analog channels) in NR1 format

The :CHANnel<n>:PROBe:SKEW command sets the channel-to-channel skew factor for the specified channel. Each analog channel can be adjusted + or -100 ns for a total of 200 ns difference between channels. You can use the oscilloscope's probe skew control to remove cable-delay errors between channels.

**Query Syntax** :CHANnel<n>:PROBe:SKEW?

The :CHANnel<n>:PROBe:SKEW? query returns the current probe skew setting for the selected channel.

**Return Format** <skew value><NL>

<skew value> ::= skew value in NR3 format

**See Also** • "Introduction to :CHANnel<n> Commands" on page 344

## :CHANnel<n>:PROBe:STYPe

**C** (see [page 1666](#))

### Command Syntax

#### NOTE

This command is valid only for the 113xA Series probes.

```
:CHANnel<n>:PROBe:STYPe <signal type>
<signal type> ::= {DIFFerential | SINGle}
<n> ::= 1 to (# analog channels) in NR1 format
```

The :CHANnel<n>:PROBe:STYPe command sets the channel probe signal type (STYPe) to differential or single-ended when using the 113xA Series probes and determines how offset is applied.

When single-ended is selected, the :CHANnel<n>:OFFSet command changes the offset value of the probe amplifier. When differential is selected, the :CHANnel<n>:OFFSet command changes the offset value of the channel amplifier.

### Query Syntax

```
:CHANnel<n>:PROBe:STYPe?
```

The :CHANnel<n>:PROBe:STYPe? query returns the current probe signal type setting for the selected channel.

### Return Format

```
<signal type><NL>
<signal type> ::= {DIFF | SING}
```

### See Also

- "[Introduction to :CHANnel<n> Commands](#)" on page 344
- "[":CHANnel<n>:OFFSet](#)" on page 351

## :CHANnel<n>:PROBe:ZOOM

**N** (see [page 1666](#))

**Command Syntax**    `:CHANnel<n>:PROBe:ZOOM {{0 | OFF} | {1 | ON}}`  
`<n> ::= 1 to (# analog channels) in NR1 format`

When the N2820A high-sensitivity current probe is used with both the Primary and Secondary cables, the :CHANnel<n>:PROBe:ZOOM command specifies whether this cable will have the Zoom In waveform (ON) or the Zoom Out waveform (OFF). The other cable will have the opposite waveform.

**Query Syntax**    `:CHANnel<n>:PROBe:ZOOM?`

The :CHANnel<n>:PROBe:ZOOM? query returns the zoom setting.

**Return Format**    `<setting><NL>`  
`<setting> ::= {0 | 1}`

**See Also**

- "[:CHANnel<n>:PROBe:RSENse](#)" on page 362
- "[:MEASure:DUAL:CHARge](#)" on page 635
- "[:MEASure:DUAL:VAMPLitude](#)" on page 636
- "[:MEASure:DUAL:VAVerage](#)" on page 637
- "[:MEASure:DUAL:VBASe](#)" on page 638
- "[:MEASure:DUAL:VPP](#)" on page 639
- "[:MEASure:DUAL:VRMS](#)" on page 640

## :CHANnel<n>:PROTection

**N** (see [page 1666](#))

**Command Syntax** :CHANnel<n>:PROTection[:CLEAR]

<n> ::= 1 to (# analog channels) in NR1 format | 4}

When the analog channel input impedance is set to  $50\Omega$ , the input channels are protected against overvoltage. When an overvoltage condition is sensed, the input impedance for the channel is automatically changed to  $1 M\Omega$ .

The :CHANnel<n>:PROTection[:CLEAR] command is used to clear (reset) the overload protection. It allows the channel to be used again in  $50\Omega$  mode after the signal that caused the overload has been removed from the channel input.

Reset the analog channel input impedance to  $50\Omega$  (see "[:CHANnel<n>:IMPedance](#)" on page 348) after clearing the overvoltage protection.

**Query Syntax** :CHANnel<n>:PROTection?

The :CHANnel<n>:PROTection query returns the state of the input protection for CHANnel<n>. If a channel input has experienced an overload, TRIP (tripped) will be returned; otherwise NORM (normal) is returned.

**Return Format** {NORM | TRIP}<NL>

**See Also**

- "[Introduction to :CHANnel<n> Commands](#)" on page 344
- "[:CHANnel<n>:COUpling](#)" on page 346
- "[:CHANnel<n>:IMPedance](#)" on page 348
- "[:CHANnel<n>:PROBe](#)" on page 352

## :CHANnel<n>:RANGE

**C** (see [page 1666](#))

|                       |   |
|-----------------------|---|
| <b>Command Syntax</b> | <code>:CHANnel&lt;n&gt;:RANGE &lt;range&gt;[&lt;suffix&gt;]</code>  |
|                       | <code>&lt;range&gt;</code> ::= vertical full-scale range value in NR3 format  |
|                       | <code>&lt;suffix&gt;</code> ::= {V   mV}  |
|                       | <code>&lt;n&gt;</code> ::= 1 to (# analog channels) in NR1 format   |
|                       | The :CHANnel<n>:RANGE command defines the full-scale vertical axis of the selected channel. When using 1:1 probe attenuation, legal values for the range are from 8 mV to 40 V.   |
|                       | If the probe attenuation is changed, the range value is multiplied by the probe attenuation factor.   |
| <b>Query Syntax</b>   | <code>:CHANnel&lt;n&gt;:RANGE?</code>   |
|                       | The :CHANnel<n>:RANGE? query returns the current full-scale range setting for the specified channel.  |
| <b>Return Format</b>  | <code>&lt;range_argument&gt;&lt;NL&gt;</code><br><code>&lt;range_argument&gt;</code> ::= vertical full-scale range value in NR3 format  |
| <b>See Also</b>       | <ul style="list-style-type: none"> <li>· <a href="#">"Introduction to :CHANnel&lt;n&gt; Commands"</a> on page 344</li> <li>· <a href="#">":CHANnel&lt;n&gt;:SCALe"</a> on page 368</li> <li>· <a href="#">":CHANnel&lt;n&gt;:PROBe"</a> on page 352</li> </ul>  |
| <b>Example Code</b>   | <pre>' CHANNEL_RANGE - Sets the full scale vertical range in volts. The ' range value is 8 times the volts per division. myScope.WriteString ":CHANnel1:RANGE 8"    ' Set the vertical range to 8 volts.</pre> <p>See complete example programs at: <a href="#">Chapter 46</a>, “Programming Examples,” starting on page 1675</p> |

## :CHANnel<n>:SCALe

**N** (see [page 1666](#))

|                       |  |
|-----------------------|--|
| <b>Command Syntax</b> | <code>:CHANnel&lt;n&gt;:SCALe &lt;scale&gt;[&lt;suffix&gt;]</code>   |
|                       | <code>&lt;scale&gt;</code> ::= vertical units per division in NR3 format   |
|                       | <code>&lt;suffix&gt;</code> ::= {v   mV}   |
|                       | <code>&lt;n&gt;</code> ::= 1 to (# analog channels) in NR1 format  |
|                       | The :CHANnel<n>:SCALe command sets the vertical scale, or units per division, of the selected channel.   |
|                       | If the probe attenuation is changed, the scale value is multiplied by the probe's attenuation factor.  |
| <b>Query Syntax</b>   | <code>:CHANnel&lt;n&gt;:SCALe?</code>  |
|                       | The :CHANnel<n>:SCALe? query returns the current scale setting for the specified channel.  |
| <b>Return Format</b>  | <code>&lt;scale value&gt;&lt;NL&gt;</code><br><code>&lt;scale value&gt;</code> ::= vertical units per division in NR3 format   |
| <b>See Also</b>       | <ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :CHANnel&lt;n&gt; Commands</a>" on page 344</li> <li>• "<a href="#">":CHANnel&lt;n&gt;:RANGE</a>" on page 367</li> <li>• "<a href="#">":CHANnel&lt;n&gt;:PROBe</a>" on page 352</li> </ul> |

## :CHANnel<n>:UNITS

**N** (see [page 1666](#))

|                       |   |
|-----------------------|---|
| <b>Command Syntax</b> | <code>:CHANnel&lt;n&gt;:UNITS &lt;units&gt;</code>  |
|                       | <code>&lt;units&gt; ::= {VOLT   AMPere}</code>  |
|                       | <code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>   |
|                       | The :CHANnel<n>:UNITS command sets the measurement units for the connected probe. Select VOLT for a voltage probe and select AMPere for a current probe. Measurement results, channel sensitivity, and trigger level will reflect the measurement units you select.   |
| <b>Query Syntax</b>   | <code>:CHANnel&lt;n&gt;:UNITS?</code>   |
|                       | The :CHANnel<n>:UNITS? query returns the current units setting for the specified channel.   |
| <b>Return Format</b>  | <code>&lt;units&gt;&lt;NL&gt;</code>  |
|                       | <code>&lt;units&gt; ::= {VOLT   AMP}</code>   |
| <b>See Also</b>       | <ul style="list-style-type: none"> <li>· <a href="#">"Introduction to :CHANnel&lt;n&gt; Commands"</a> on page 344</li> <li>· <a href="#">":CHANnel&lt;n&gt;:RANGE"</a> on page 367</li> <li>· <a href="#">":CHANnel&lt;n&gt;:PROBe"</a> on page 352</li> <li>· <a href="#">":EXTernal:UNITS"</a> on page 447</li> </ul> |

**:CHANnel<n>:VERNier****N** (see [page 1666](#))

- Command Syntax**    `:CHANnel<n>:VERNier <vernier value>`  
`<vernier value> ::= {{1 | ON} | {0 | OFF}}`  
`<n> ::= 1 to (# analog channels) in NR1 format`
- The :CHANnel<n>:VERNier command specifies whether the channel's vernier (fine vertical adjustment) setting is ON (1) or OFF (0).
- Query Syntax**    `:CHANnel<n>:VERNier?`
- The :CHANnel<n>:VERNier? query returns the current state of the channel's vernier setting.
- Return Format**    `<vernier value><NL>`  
`<vernier value> ::= {0 | 1}`
- See Also**    • "Introduction to :CHANnel<n> Commands" on page 344

# 12 :COMPliance Commands

Control the license-enabled USB 2.0 signal quality analysis feature.

**Table 101** :COMPliance Commands Summary

| Command  | Query  | Options and Query Returns                            |
|--|--|--|
| :COMPliance:USB:AUTosetup (see <a href="#">page 372</a> )                    | n/a  | n/a  |
| :COMPliance:USB:HUBS <number> (see <a href="#">page 373</a> )                | :COMPliance:USB:HUBS? (see <a href="#">page 373</a> )                | <number> ::= 0-5 in NR1 format                       |
| :COMPliance:USB:RUN (see <a href="#">page 374</a> )                          | n/a  | n/a  |
| :COMPliance:USB:SOURce:ADJacent <source> (see <a href="#">page 375</a> )     | :COMPliance:USB:SOURce:ADJacent? (see <a href="#">page 375</a> )     | <source> ::= {CHANnel<n>}                            |
| :COMPliance:USB:SOURce:DIFFerential <source> (see <a href="#">page 376</a> ) | :COMPliance:USB:SOURce:DIFFerential? (see <a href="#">page 376</a> ) | <source> ::= {CHANnel<n>}                            |
| :COMPliance:USB:SOURce:DMINus <source> (see <a href="#">page 377</a> )       | :COMPliance:USB:SOURce:DMINus? (see <a href="#">page 377</a> )       | <source> ::= {CHANnel<n>}                            |
| :COMPliance:USB:SOURce:DPLus <source> (see <a href="#">page 378</a> )        | :COMPliance:USB:SOURce:DPLus? (see <a href="#">page 378</a> )        | <source> ::= {CHANnel<n>}                            |
| :COMPliance:USB:TEST <test> (see <a href="#">page 379</a> )                  | :COMPliance:USB:TEST? (see <a href="#">page 379</a> )                | <test> ::= {DHSS   HHSS   DLSS   HLSS   DFSS   HFSS} |
| :COMPliance:USB:TEST:CONNection <connection> (see <a href="#">page 380</a> ) | :COMPliance:USB:TEST:CONNection? (see <a href="#">page 380</a> )     | <connection> ::= {SINGleended   DIFFerential}        |
| :COMPliance:USB:TEST:TYPE <type> (see <a href="#">page 381</a> )             | :COMPliance:USB:TEST:TYPE? (see <a href="#">page 381</a> )           | <type> ::= {NEARend   FARend}                        |

## :COMPliance:USB:AUTosetup

**N** (see [page 1666](#))

**Command Syntax** :COMPliance:USB:AUTosetup

The :COMPliance:USB:AUTosetup command automatically sets up the oscilloscope for the selected signal quality test and USB compliance test packets. Automatically set are:

- Horizontal scale and delay.
- Analog input channel(s) scale and vertical offset.
- Trigger mode and trigger level.

The :COMPliance:USB:AUTosetup command causes the oscilloscope to run (that is, capture acquisitions that meet the trigger condition).

If you are testing the signal quality of real-world packets (instead of USB compliance test packets), you may need to adjust the auto setup.

Note that gating of measurements can only be done via the oscilloscope's horizontal controls. This can be done after the :COMPliance:USB:AUTosetup command and before the :COMPliance:USB:RUN command. The horizontal controls should be adjusted so that only the data to be tested is on screen when the :COMPliance:USB:RUN command is executed. This is normally one packet of data.

**See Also**

- "[:COMPliance:USB:TEST](#)" on page 379
- "[:COMPliance:USB:TEST:TYPE](#)" on page 381
- "[:COMPliance:USB:TEST:CONNection](#)" on page 380
- "[:COMPliance:USB:RUN](#)" on page 374

## :COMPliance:USB:HUBS

**N** (see [page 1666](#))

**Command Syntax** :COMPliance:USB:HUBS <number>  
 <number> ::= 0-5 in NR1 format

The :COMPliance:USB:HUBS command specifies the number of internal hubs between the host and the test point.

When the Near-end test type is selected, you can specify 0 to 5 hubs.

When the Far-end test type is selected, the number of hubs is set to 0.

The specified number of hubs affects the test limits for the Sync results and the EOP Width results.

**Query Syntax** :COMPliance:USB:HUBS?

The :COMPliance:USB:HUBS? query returns the specified the number of internal hubs.

**Return Format** <number><NL>  
 <number> ::= 0-5 in NR1 format

**See Also**

- "[:COMPliance:USB:TEST](#)" on page 379
- "[:COMPliance:USB:TEST:TYPE](#)" on page 381
- "[:COMPliance:USB:SOURce:DPLus](#)" on page 378
- "[:COMPliance:USB:SOURce:DMINus](#)" on page 377
- "[:COMPliance:USB:SOURce:ADJacent](#)" on page 375
- "[:COMPliance:USB:SOURce:DIFFerential](#)" on page 376

## :COMPliance:USB:RUN

**N** (see [page 1666](#))

**Command Syntax** :COMPliance:USB:RUN

The :COMPliance:USB:RUN command runs the selected signal quality test.

Please be patient as tests can take several minutes to complete.

When tests are run, the oscilloscope stops acquisitions if they are running, analyzes the data on screen, and then displays the results. The analyzed acquisition remains on screen and can be viewed by moving or dismissing the results dialog.

You can run tests when the oscilloscope is already stopped. This is useful in the case of embedded hosts (and other cases) where the device under test (DUT) may not easily be placed in a test mode, and you want to analyze already acquired data.

**See Also**

- "[:COMPliance:USB:TEST](#)" on page 379
- "[:COMPliance:USB:AUTosetup](#)" on page 372
- "[\\*OPC \(Operation Complete\)](#)" on page 240
- "[:SAVE:COMPliance:USB\[:STARt\]](#)" on page 878

## :COMPliance:USB:SOURce:ADJacent

**N** (see [page 1666](#))

|                       |  |
|-----------------------|--|
| <b>Command Syntax</b> | <code>:COMPliance:USB:SOURce:ADJacent &lt;source&gt;</code><br><code>&lt;source&gt; ::= {CHANnel&lt;n&gt;}</code><br><code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code> |
|                       | The :COMPliance:USB:SOURce:ADJacent command specifies the analog input channel that is probing the adjacent D+ or D- signal.   |
|                       | When the Device Full Speed Signal Quality test is selected, the specified channel probes the adjacent D+ signal.   |
|                       | When the Device Low Speed Signal Quality test is selected, this specified channel probes the adjacent D- signal.   |
| <b>Query Syntax</b>   | <code>:COMPliance:USB:SOURce:ADJacent?</code>  |
|                       | The :COMPliance:USB:SOURce:ADJacent? query returns the specified analog input channel.   |
| <b>Return Format</b>  | <code>&lt;source&gt;&lt;NL&gt;</code><br><code>&lt;source&gt; ::= {CHAN&lt;n&gt;}</code>   |
| <b>See Also</b>       | <ul style="list-style-type: none"> <li>· "<a href="#">:COMPliance:USB:SOURce:DPLus</a>" on page 378</li> <li>· "<a href="#">:COMPliance:USB:SOURce:DMINus</a>" on page 377</li> </ul>  |

## :COMPliance:USB:SOURce:DIFFerential

**N** (see [page 1666](#))

**Command Syntax**    `:COMPliance:USB:SOURce:DIFFerential <source>`  
`<source> ::= {CHANnel<n>}`  
`<n> ::= 1 to (# analog channels) in NR1 format`

The :COMPliance:USB:SOURce:DIFFerential command specifies the analog input channel whose differential probe is connected to the Hi-Speed signal to be tested.

**Query Syntax**    `:COMPliance:USB:SOURce:DIFFerential?`

The :COMPliance:USB:SOURce:DIFFerential? query returns the specified analog input channel.

**Return Format**    `<source><NL>`  
`<source> ::= {CHAN<n>}`

**See Also**

- "[":COMPliance:USB:TEST](#)" on page 379
- "[":COMPliance:USB:TEST:CONNnection](#)" on page 380

## :COMPliance:USB:SOURce:DMINus

**N** (see [page 1666](#))

|                       |  |
|-----------------------|--|
| <b>Command Syntax</b> | <code>:COMPliance:USB:SOURce:DMINus &lt;source&gt;</code>  |
|                       | <code>&lt;source&gt; ::= {CHANnel&lt;n&gt;}</code>   |
|                       | <code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>  |
|                       | The :COMPliance:USB:SOURce:DMINus command specifies the analog input channel that is probing the D- signal.  |
|                       | On 4-channel oscilloscopes, you are forced to use different channel pairs for the D+ and D- signals. This provides the maximum sample rate. (Channels 1 and 2 are one pair and channels 3 and 4 are the other pair.) |
| <b>Query Syntax</b>   | <code>:COMPliance:USB:SOURce:DMINus?</code>  |
|                       | The :COMPliance:USB:SOURce:DMINus? query returns the specified analog input channel.   |
| <b>Return Format</b>  | <code>&lt;source&gt;&lt;NL&gt;</code>  |
|                       | <code>&lt;source&gt; ::= {CHAN&lt;n&gt;}</code>  |
| <b>See Also</b>       | <ul style="list-style-type: none"> <li>· "<a href="#">":COMPliance:USB:SOURce:DPLus</a>" on page 378</li> <li>· "<a href="#">":COMPliance:USB:SOURce:ADJacent</a>" on page 375</li> </ul>                            |

## :COMPliance:USB:SOURce:DPLus

**N** (see [page 1666](#))

|                       |  |
|-----------------------|--|
| <b>Command Syntax</b> | <code>:COMPliance:USB:SOURce:DPLus &lt;source&gt;</code>   |
|                       | <code>&lt;source&gt; ::= {CHANnel&lt;n&gt;}</code>   |
|                       | <code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>  |
|                       | The :COMPliance:USB:SOURce:DPLus command specifies the analog input channel that is probing the D+ signal.   |
|                       | On 4-channel oscilloscopes, you are forced to use different channel pairs for the D+ and D- signals. This provides the maximum sample rate. (Channels 1 and 2 are one pair and channels 3 and 4 are the other pair.) |
| <b>Query Syntax</b>   | <code>:COMPliance:USB:SOURce:DPLus?</code>   |
|                       | The :COMPliance:USB:SOURce:DPLus? query returns the specified analog input channel.  |
| <b>Return Format</b>  | <code>&lt;source&gt;&lt;NL&gt;</code>  |
|                       | <code>&lt;source&gt; ::= {CHAN&lt;n&gt;}</code>  |
| <b>See Also</b>       | <ul style="list-style-type: none"> <li>· "<a href="#">":COMPliance:USB:SOURce:DMINus</a>" on page 377</li> <li>· "<a href="#">":COMPliance:USB:SOURce:ADJacent</a>" on page 375</li> </ul>                           |

## :COMPliance:USB:TEST

**N** (see [page 1666](#))

|  |  |
|--|--|
| <b>Command Syntax</b>  | <code>:COMPliance:USB:TEST &lt;test&gt;</code><br><code>&lt;test&gt; ::= {DHSS   HHSS   DLSS   HLSS   DFSS   HFSS}</code>  |
| The :COMPliance:USB:TEST command selects the type of signal quality test to perform:   |  |
| <ul style="list-style-type: none"> <li>• DHSS – Device Hi-Speed Signal Quality.</li> <li>• HHSS – Host Hi-Speed Signal Quality.</li> <li>• DLSS – Device Low Speed Signal Quality.</li> <li>• HLSS – Host Low Speed Signal Quality.</li> <li>• DFSS – Device Full Speed Signal Quality.</li> <li>• HFSS – Host Full Speed Signal Quality.</li> </ul> |  |
| For Hub upstream testing, select the Device tests.   |  |
| For Hub downstream testing, select the Host tests.   |  |
| Low and Full Speed tests require two or three single-ended probes.   |  |
| Hi-Speed tests are available only on 1.5 GHz bandwidth oscilloscopes, and a differential probe or SMA cable connections are required.  |  |
| Note that the N2750A Series InfiniiMode differential probes cannot be used with the Hi-Speed Signal Quality test fixtures because they have damping resistors and the USB test fixture also has damping resistors specifically designed for the E2678A socketed probe heads.   |  |
| <b>Query Syntax</b>  | <code>:COMPliance:USB:TEST?</code>   |
| The :COMPliance:USB:TEST? query returns the selected signal quality test type.   |  |
| <b>Return Format</b>   | <code>&lt;test&gt;&lt;NL&gt;</code><br><code>&lt;test&gt; ::= {DHSS   HHSS   DLSS   HLSS   DFSS   HFSS}</code>   |
| <b>See Also</b>  | <ul style="list-style-type: none"> <li>• "<a href="#">:COMPliance:USB:TEST:TYPE</a>" on page 381</li> <li>• "<a href="#">:COMPliance:USB:SOURce:DPLus</a>" on page 378</li> <li>• "<a href="#">:COMPliance:USB:SOURce:DMINus</a>" on page 377</li> <li>• "<a href="#">:COMPliance:USB:SOURce:ADJacent</a>" on page 375</li> <li>• "<a href="#">:COMPliance:USB:SOURce:DIFFerential</a>" on page 376</li> </ul> |

## :COMPliance:USB:TEST:CONNnection

**N** (see [page 1666](#))

|  |  |
|--|--|
| <b>Command Syntax</b>  | <code>:COMPliance:USB:TEST:CONNnection &lt;connection&gt;</code><br><code>&lt;connection&gt; ::= {SINGleended   DIFFerential}</code> |
| When a Hi-Speed test has been selected, the :COMPliance:USB:TEST:CONNnection command specifies the test fixture connection type:               |  |
| <ul style="list-style-type: none"> <li>• DIFFerential – specifies that a differential probe is used to probe the signal under test.</li> </ul> |  |

In this case, use the :COMPliance:USB:SOURce:DIFFerential command to specify the analog input channel connected to the differential probe.

- SINGleended – specifies that two single-ended SMA cables are used to probe the signal under test.

In this case, use the :COMPliance:USB:SOURce:DPLus command to specify the analog input channel that is probing the D+ signal, and use the :COMPliance:USB:SOURce:DMINus command to specify the analog input channel that is probing the D- signal.

|   |  |
|---|--|
| <b>Query Syntax</b>   | <code>:COMPliance:USB:TEST:CONNnection?</code> |
| The :COMPliance:USB:TEST:CONNnection? query returns the specified the test fixture connection type. |  |

|                      |  |
|----------------------|--|
| <b>Return Format</b> | <code>&lt;connection&gt;&lt;NL&gt;</code><br><code>&lt;connection&gt; ::= {SING   DIFF}</code> |
|----------------------|--|

|                 |   |
|-----------------|---|
| <b>See Also</b> | <ul style="list-style-type: none"> <li>• "<a href="#">":COMPliance:USB:SOURce:DIFFerential</a>" on page 376</li> <li>• "<a href="#">":COMPliance:USB:SOURce:DPLus</a>" on page 378</li> <li>• "<a href="#">":COMPliance:USB:SOURce:DMINus</a>" on page 377</li> </ul> |
|-----------------|---|

## :COMPliance:USB:TEST:TYPE

**N** (see [page 1666](#))

**Command Syntax**    `:COMPliance:USB:TEST:TYPE <type>`  
                  `<type> ::= {NEARend | FARend}`

When a Hi-Speed test has been selected, the :COMPliance:USB:TEST:TYPE command selects whether the test type is near-end or far-end.

**Query Syntax**    `:COMPliance:USB:TEST:TYPE?`  
The :COMPliance:USB:TEST:TYPE? query returns the selected test type.

**Return Format**    `<type><NL>`  
                  `<type> ::= {NEAR | FAR}`

**See Also**    • [":COMPliance:USB:TEST"](#) on page 379



# 13 :COUNTER Commands

These commands control the counter feature. See "[Introduction to :COUNTER Commands](#)" on page 384.

**Table 102** :COUNTER Commands Summary

| Command  | Query  | Options and Query Returns  |
|--|--|--|
| n/a  | :COUNTER:CURREnt? (see <a href="#">page 385</a> )                | <value> ::= current counter value in NR3 format  |
| :COUNTER:ENABLE {{0   OFF}   {1   ON}} (see <a href="#">page 386</a> )               | :COUNTER:ENABLE? (see <a href="#">page 386</a> )                 | {0   1}  |
| :COUNTER:MODE <mode> (see <a href="#">page 387</a> )                                 | :COUNTER:MODE (see <a href="#">page 387</a> )                    | <mode> ::= {FREQuency   PERiod   TOTalize}   |
| :COUNTER:NDIGits <value> (see <a href="#">page 388</a> )                             | :COUNTER:NDIGits (see <a href="#">page 388</a> )                 | <value> ::= 3 to 8 in NR1 format   |
| :COUNTER:SOURce <source> (see <a href="#">page 389</a> )                             | :COUNTER:SOURce? (see <a href="#">page 389</a> )                 | <source> ::= {CHANnel<n>   TQEEvent}<br><n> ::= 1 to (# analog channels) in NR1 format |
| :COUNTER:TOTalize:CLEar (see <a href="#">page 390</a> )                              | n/a  | n/a  |
| :COUNTER:TOTalize:GATE:ENABLE {{0   OFF}   {1   ON}} (see <a href="#">page 391</a> ) | :COUNTER:TOTalize:GATE:ENABLE? (see <a href="#">page 391</a> )   | {0   1}  |
| :COUNTER:TOTalize:GATE:POLarity <polarity> (see <a href="#">page 392</a> )           | :COUNTER:TOTalize:GATE:POLarity? (see <a href="#">page 392</a> ) | <polarity> ::= {{NEGative   FALLing}   {POSitive   RISing}}                            |

**Table 102** :COUNter Commands Summary (continued)

| Command   | Query   | Options and Query Returns  |
|---|---|--|
| :COUNTER:TOTalize:GAT<br>E:SOURce <source><br>(see <a href="#">page 393</a> ) | :COUNTER:TOTalize:GAT<br>E:SOURce? (see<br><a href="#">page 393</a> ) | <source> ::= CHANnel<n><br><n> ::= 1 to (# analog channels)<br>in NR1 format |
| :COUNTER:TOTalize:SLO<br>Pe <slope> (see<br><a href="#">page 394</a> )        | :COUNTER:TOTalize:SLO<br>Pe? (see <a href="#">page 394</a> )          | <slope> ::= {{NEGative   FALLing}<br>  {POSitive   RISing}}                  |

**Introduction to :COUNter Commands** The :COUNter subsystem provides commands to control the counter feature.

#### Reporting the Setup

Use :COUNter? to query setup information for the COUNter subsystem.

#### Return Format

The following is a sample response from the :COUNter? query. In this case, the query was issued following the \*RST command.

```
:COUN:ENAB 0;SOUR CHAN1;MODE FREQ;NDIG 5
```

## :COUNter:CURRent

**N** (see [page 1666](#))

**Query Syntax** :COUNter:CURRent?

The :COUNter:CURRent? query returns the current counter value.

**Return Format** <value><NL>

<value> ::= current counter value in NR3 format

- See Also**
- "[:COUNter:ENABLE](#)" on page 386
  - "[:COUNter:MODE](#)" on page 387
  - "[:COUNter:NDIGits](#)" on page 388
  - "[:COUNter:SOURce](#)" on page 389

## :COUNter:ENABle

**N** (see [page 1666](#))

**Command Syntax** :COUNter:ENABle {{0 | OFF} | {1 | ON}}

The :COUNter:ENABle command enables or disables the counter feature.

**Query Syntax** :COUNter:ENABle?

The :COUNter:ENABle? query returns whether the counter is enabled or disabled.

**Return Format** <off\_on><NL>

{0 | 1}

- See Also**
- "[:COUNter:CURRent](#)" on page 385
  - "[:COUNter:MODE](#)" on page 387
  - "[:COUNter:NDIGits](#)" on page 388
  - "[:COUNter:SOURce](#)" on page 389

## :COUNter:MODE

**N** (see [page 1666](#))

|  |   |
|--|---|
| <b>Command Syntax</b>                                      | <code>:COUNter:MODE &lt;mode&gt;</code><br><code>&lt;mode&gt; ::= {FREQuency   PERiod   TOTalize}</code>  |
| The :COUNter:MODE command sets the counter mode:           |   |
|  | <ul style="list-style-type: none"> <li>• FREQuency – the cycles per second (Hz) of the signal.</li> <li>• PERiod – the time periods of the signal's cycles.</li> <li>• TOTalize – the count of edge events on the signal.</li> </ul>  |
| <b>Query Syntax</b>  | <code>:COUNter:MODE</code>  |
| The :COUNter:MODE? query returns the counter mode setting. |   |
| <b>Return Format</b>                                       | <code>&lt;mode&gt;&lt;NL&gt;</code><br><code>&lt;mode&gt; ::= {FREQ   PER   TOT}</code>   |
| <b>See Also</b>  | <ul style="list-style-type: none"> <li>• "<a href="#">:COUNter:CURRent</a>" on page 385</li> <li>• "<a href="#">:COUNter:ENABLE</a>" on page 386</li> <li>• "<a href="#">:COUNter:NDIGits</a>" on page 388</li> <li>• "<a href="#">:COUNter:SOURce</a>" on page 389</li> <li>• "<a href="#">:COUNter:TOTalize:CLEar</a>" on page 390</li> <li>• "<a href="#">:COUNter:TOTalize:GATE:ENABLE</a>" on page 391</li> <li>• "<a href="#">:COUNter:TOTalize:GATE:POLarity</a>" on page 392</li> <li>• "<a href="#">:COUNter:TOTalize:GATE:SOURce</a>" on page 393</li> <li>• "<a href="#">:COUNter:TOTalize:SLOPe</a>" on page 394</li> </ul> |

## :COUNter:NDIGits

**N** (see [page 1666](#))

**Command Syntax**    `:COUNter:NDIGits <value>`

`<value> ::= 3 to 8 in NR1 format`

The :COUNter:NDIGits command sets the number of digits of resolution used for the frequency or period counter.

Higher resolutions require longer gate times, which cause the measurement times to be longer as well.

**Query Syntax**    `:COUNter:NDIGits`

The :COUNter:NDIGits? query returns the currently set number of digits of resolution.

**Return Format**    `<value><NL>`

`<value> ::= 3 to 8 in NR1 format`

- See Also**
- "[:COUNter:CURRent](#)" on page 385
  - "[:COUNter:ENABLE](#)" on page 386
  - "[:COUNter:MODE](#)" on page 387
  - "[:COUNter:SOURce](#)" on page 389
  - "[:COUNter:TOTalize:CLEar](#)" on page 390
  - "[:COUNter:TOTalize:GATE:ENABLE](#)" on page 391
  - "[:COUNter:TOTalize:GATE:POLarity](#)" on page 392
  - "[:COUNter:TOTalize:GATE:SOURce](#)" on page 393
  - "[:COUNter:TOTalize:SLOPe](#)" on page 394

## :COUNter:SOURce

**N** (see [page 1666](#))

### Command Syntax

```
:COUNter:SOURce <source>
<source> ::= {CHANnel<n> | TQEEvent}
<n> ::= 1 to (# analog channels) in NR1 format
```

The :COUNter:SOURce command selects the waveform source that the counter measures. You can select one of the analog input channels or the trigger qualified event signal.

With the TQEEvent (trigger qualified event) source (available when the trigger mode is not EDGE), you can see how often trigger events are detected. This can be more often than when triggers actually occur, due to the oscilloscope's acquisition time or update rate capabilities. The TRIG OUT signal shows when triggers actually occur. Remember that the oscilloscope's trigger circuitry does not re-arm until the holdoff time occurs (:TRIGger:HOLDoff) and that the minimum holdoff time is 40 ns; therefore, the maximum trigger qualified event frequency that can be counted is 25 MHz.

### Query Syntax

```
:COUNter:SOURce?
```

The :COUNter:SOURce? query returns the currently set counter source channel.

### Return Format

```
<source><NL>
```

### See Also

- "[:COUNter:CURRent](#)" on page 385
- "[:COUNter:ENABLE](#)" on page 386
- "[:COUNter:MODE](#)" on page 387
- "[:COUNter:NDIGits](#)" on page 388

## :COUNter:TOTalize:CLEar

**N** (see [page 1666](#))

**Command Syntax** :COUNter:TOTalize:CLEar

The :COUNter:TOTalize:CLEar command zeros the edge event counter.

**See Also**

- "[:COUNter:CURRent](#)" on page 385
- "[:COUNter:ENABLE](#)" on page 386
- "[:COUNter:MODE](#)" on page 387
- "[:COUNter:NDIGits](#)" on page 388
- "[:COUNter:SOURce](#)" on page 389
- "[:COUNter:TOTalize:GATE:ENABLE](#)" on page 391
- "[:COUNter:TOTalize:GATE:POLarity](#)" on page 392
- "[:COUNter:TOTalize:GATE:SOURce](#)" on page 393
- "[:COUNter:TOTalize:SLOPe](#)" on page 394

## :COUNter:TOTalize:GATE:ENABLE

**N** (see [page 1666](#))

**Command Syntax** :COUNter:TOTalize:GATE:ENABLE {{0 | OFF} | {1 | ON}}

The :COUNter:TOTalize:GATE:ENABLE command enables or disables totalizer gating.

When totalizer gating is enabled, the totalizer only counts edges when a second gating signal polarity is true. The second gating signal can be one of the remaining analog channel inputs.

**Query Syntax** :COUNter:TOTalize:GATE:ENABLE?

The :COUNter:TOTalize:GATE:ENABLE? query returns whether totalizer gating is enabled or disabled.

**Return Format** <off\_on><NL>

{0 | 1}

- See Also**
- "[:COUNter:CURRent](#)" on page 385
  - "[:COUNter:ENABLE](#)" on page 386
  - "[:COUNter:MODE](#)" on page 387
  - "[:COUNter:NDIGits](#)" on page 388
  - "[:COUNter:SOURce](#)" on page 389
  - "[:COUNter:TOTalize:CLEar](#)" on page 390
  - "[:COUNter:TOTalize:GATE:POLarity](#)" on page 392
  - "[:COUNter:TOTalize:GATE:SOURce](#)" on page 393
  - "[:COUNter:TOTalize:SLOPe](#)" on page 394

## :COUNter:TOTalize:GATE:POLarity

**N** (see [page 1666](#))

**Command Syntax**    `:COUNter:TOTalize:GATE:POLarity <polarity>`

`<polarity> ::= {{NEGative | FALLing} | {POSitive | RISing}}`

The :COUNter:TOTalize:GATE:POLarity command specifies the gating signal condition under which totalizer edges are counted.

The gating signal is specified with the :COUNter:TOTalize:GATE:SOURce command.

**Query Syntax**    `:COUNter:TOTalize:GATE:POLarity?`

The :COUNter:TOTalize:GATE:POLarity? query returns the currently specified gating signal condition.

**Return Format**    `<polarity><NL>`

`<polarity> ::= {NEG | POS}`

**See Also**

- [":COUNter:CURRent"](#) on page 385
- [":COUNter:ENABLE"](#) on page 386
- [":COUNter:MODE"](#) on page 387
- [":COUNter:NDIGits"](#) on page 388
- [":COUNter:SOURce"](#) on page 389
- [":COUNter:TOTalize:CLEar"](#) on page 390
- [":COUNter:TOTalize:GATE:ENABLE"](#) on page 391
- [":COUNter:TOTalize:GATE:SOURce"](#) on page 393
- [":COUNter:TOTalize:SLOPe"](#) on page 394

## :COUNter:TOTalize:GATE:SOURce

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:COUNter:TOTalize:GATE:SOURce &lt;source&gt;</code>
	<code>&lt;source&gt; ::= CHANnel&lt;n&gt;</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	The :COUNter:TOTalize:GATE:SOURce command selects the analog channel that has the totalizer gating signal.
<b>Query Syntax</b>	<code>:COUNter:TOTalize:GATE:SOURce?</code>
	The :COUNter:TOTalize:GATE:SOURce? query returns the current totalizer gating signal source.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:COUNter:CURRent</a>" on page 385</li> <li>· "<a href="#">:COUNter:ENABLE</a>" on page 386</li> <li>· "<a href="#">:COUNter:MODE</a>" on page 387</li> <li>· "<a href="#">:COUNter:NDIGits</a>" on page 388</li> <li>· "<a href="#">:COUNter:SOURce</a>" on page 389</li> <li>· "<a href="#">:COUNter:TOTalize:CLEar</a>" on page 390</li> <li>· "<a href="#">:COUNter:TOTalize:GATE:ENABLE</a>" on page 391</li> <li>· "<a href="#">:COUNter:TOTalize:GATE:POLarity</a>" on page 392</li> <li>· "<a href="#">:COUNter:TOTalize:SLOPe</a>" on page 394</li> </ul>

## :COUNter:TOTalize:SLOPe

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:COUNter:TOTalize:SLOPe &lt;slope&gt;</code>
	<code>&lt;slope&gt; ::= {{NEGative   FALLing}   {POSitive   RISing}}</code>
	The :COUNter:TOTalize:SLOPe command specifies whether positive or negative edges are counted.
<b>Query Syntax</b>	<code>:COUNter:TOTalize:SLOPe?</code>
	The :COUNter:TOTalize:SLOPe? query returns the currently set slope specification.
<b>Return Format</b>	<code>&lt;slope&gt;&lt;NL&gt;</code>
	<code>&lt;slope&gt; ::= {NEG   POS}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":COUNter:CURRent"</a> on page 385</li> <li>· <a href="#">":COUNter:ENABLE"</a> on page 386</li> <li>· <a href="#">":COUNter:MODE"</a> on page 387</li> <li>· <a href="#">":COUNter:NDIGits"</a> on page 388</li> <li>· <a href="#">":COUNter:SOURce"</a> on page 389</li> <li>· <a href="#">":COUNter:TOTalize:CLEar"</a> on page 390</li> <li>· <a href="#">":COUNter:TOTalize:GATE:ENABLE"</a> on page 391</li> <li>· <a href="#">":COUNter:TOTalize:GATE:Polarity"</a> on page 392</li> <li>· <a href="#">":COUNter:TOTalize:GATE:SOURce"</a> on page 393</li> </ul>

# 14 :DEMO Commands

You can output demonstration signals on the oscilloscope's Demo 1 and Demo 2 terminals. See "[Introduction to :DEMO Commands](#)" on page 395.

**Table 103** :DEMO Commands Summary

Command	Query	Options and Query Returns
:DEMO:FUNCTION <signal> (see <a href="#">page 396</a> )	:DEMO:FUNCTION? (see <a href="#">page 399</a> )	<signal> ::= {SINusoid   NOisy   PHASE   RINGing   SINGLE   AM   CLK   GLITCH   BURSt   MSO   RUNT   TRANSition   RFBURst   SHOLD   LFSine   FMBurst   ETE   NFC   CAN   LIN   UART   I2C   SPI   I2S   CANLin   CXPI   ARINC   FLEXray   MANchester   MIL   MIL2   USB   NMONotonic   DCMotor   HARMonics   COUpling   CFD   SENT   USBPD   KEYSight}
:DEMO:FUNCTION:PHASE: PHASE <angle> (see <a href="#">page 401</a> )	:DEMO:FUNCTION:PHASE: PHASE? (see <a href="#">page 401</a> )	<angle> ::= angle in degrees from 0 to 360 in NR3 format
:DEMO:OUTPut {{0   OFF}   {1   ON}} (see <a href="#">page 402</a> )	:DEMO:OUTPut? (see <a href="#">page 402</a> )	{0   1}

**Introduction to :DEMO Commands** The :DEMO subsystem provides commands to output demonstration signals on the oscilloscope's Demo 1 and Demo 2 terminals.

## Reporting the Setup

Use :DEMO? to query setup information for the DEMO subsystem.

## Return Format

The following is a sample response from the :DEMO? query. In this case, the query was issued following the \*RST command.

```
:DEMO:FUNC SIN;OUTP 0
```

## :DEMO:FUNCTION

**N** (see [page 1666](#))

**Command Syntax** :DEMO:FUNCTION <signal>

```
<signal> ::= {SINusoid | NOISy | PHASe | RINGing | SINGle | AM | CLK
| GLITch | BURSt | MSO | RUNT | TRANSition | RFBurst | SHOLD
| LFSine | FMBurst | ETE | NFC | CAN | LIN | UART | I2C | SPI | I2S
| CANLin | CXPI | ARINc | FLEXray | MANchester | MIL | MIL2 | USB
| NMONotonic | DCMotor | HARMonics | COUPLing | CFD | SENT
| USBPd | KEYSight}
```

The :DEMO:FUNCTION command selects the type of demo signal:

Demo Signal Function	Demo 1 Terminal	Demo 2 Terminal
SINusoid	5 MHz sine wave @ ~ 6 Vpp, 0 V offset	Off
NOISy	1 kHz sine wave @ ~ 2.4 Vpp, 0.0 V offset, with ~ 0.5 Vpp of random noise added	Off
PHASe	1 kHz sine wave @ 2.4 Vpp, 0.0 V offset	1 kHz sine wave @ 2.4 Vpp, 0.0 V offset , phase shifted by the amount entered using the " <a href="#">":DEMO:FUNCTION:PHASE:PHASE</a> " on page 401 command
RINGing	500 kHz digital pulse @ ~ 3 Vpp, 1.5 V offset, and ~500 ns pulse width with ringing	Off
SINGle	~500 ns wide digital pulse with ringing @ ~ 3 Vpp, 1.5 V offset Press the front panel <b>Set Off</b> <b>Single-Shot</b> softkey to cause the selected single-shot signal to be output.	Off
AM	26 kHz sine wave, ~ 7 Vpp, 0 V offset	Amplitude modulated signal, ~ 3 Vpp, 0 V offset, with ~13 MHz carrier and sine envelope
CLK	3.6 MHz clock @ ~2 Vpp, 1 V offset, with infrequent glitch (1 glitch per 1,000,000 clocks)	Off
GLITch	Burst of 6 digital pulses (plus infrequent glitch) that occurs once every 80 µs @ ~3.6 Vpp, ~1.8 V offset	Off

Demo Signal Function	Demo 1 Terminal	Demo 2 Terminal
BURSt	Burst of digital pulses that occur every 50 µs @ ~ 3.6 Vpp, ~1.5 V offset	Off
MSO	3.1 kHz stair-step sine wave output of DAC @ ~1.5 Vpp, 0.75 V offset DAC input signals are internally routed to digital channels D0 through D7	~3.1 kHz sine wave filtered from DAC output @ ~ 600 mVpp, 300 mV offset
RUNT	Digital pulse train with positive and negative runt pulses @ ~ 2.9 Vpp, 1.5 V offset	Off
TRANSition	Digital pulse train with two different edge speeds @ ~ 3.5 Vpp, 1.75 V offset	Off
RFBurst	5-cycle burst of a 10 MHz amplitude modulated sine wave @ ~ 2.6 Vpp, 0 V offset occurring once every 4 ms	Off
SHOLD	6.25 MHz digital clock @ ~ 3.5 Vpp, 1.75 V offset	Data signal @ ~3.5 Vpp, 1.75 V offset
LFSine	30 Hz sine wave @ ~2.7 Vpp, 0 V offset, with very narrow glitch near each positive peak	Off
FMBurst	FM burst, modulated from ~100 kHz to ~1 MHz, ~5.0 Vpp, ~600 mV offset.	Off
ETE	100 kHz pulse, 400 ns wide @ ~3.3 Vpp, 1.65 V offset	600 ns analog burst (@ ~3.3 Vpp, 0.7 V offset) followed by 3.6 µs digital burst @ ~3.3 Vpp, 1.65 V offset) at a 100 kHz repetitive rate
NFC	~2.4 Vpp unmodulated carrier amplitude, ~1.8 Vpp maximum modulated amplitude, ~0.0 V offset	Off
CAN	CAN_L, 125 kbps dominant-low, ~2.8 Vpp, ~1.4 V offset	Off
LIN	LIN, 19.2 kbs, ~2.8 Vpp, ~1.4 V offset	Off
UART	Receive data (RX) with odd parity, 19.2 kbps, 8-bit words, LSB out 1st, low idle @ ~2.8 Vpp, 1.4 V offset	Transmit data (TX) with odd parity, 19.2 kbps, 8-bit words, LSB out 1st, low idle @ ~ 2.8 Vpp, 1.4 V offset
I2C	I2C serial clock signal (SCL) @ ~2.8 Vpp, 1.4 V offset	I2C serial data signal (SDA) @ ~ 2.8 Vpp, 1.4 V offset

Demo Signal Function	Demo 1 Terminal	Demo 2 Terminal
SPI	<p>Off</p> <p>Signals are internally routed to digital channels D6 through D9:</p> <ul style="list-style-type: none"> <li>▪ D9 – MOSI, TTL level, with MSB out 1st (internally routed to digital input).</li> <li>▪ D8 – MISO, TTL level, with MSB out 1st (internally routed to digital input).</li> <li>▪ D7 – CLK, TTL level (internally routed to digital input).</li> <li>▪ D6 – ~CS, low-enable, TTL level (internally routed to digital input).</li> </ul>	Off
I2S	<p>Off</p> <p>Signals are internally routed to digital channels D7 through D9:</p> <ul style="list-style-type: none"> <li>▪ D9 – SDATA, TTL level, with "standard" alignment (internally routed to digital input).</li> <li>▪ D8 – SCLK, TTL level, (internally routed to digital input).</li> <li>▪ D7 – WS, TTL level, low for left channel, high for right channel (internally routed to digital input)</li> </ul>	Off
CANLin	CAN_L, 250 kbps dominant-low, ~2.8 Vpp, ~1.4 V offset	LIN, 19.2 kbps, ~2.8 Vpp, ~1.4 V offset
CXPI	CXPI, ~2.5 Vpp, ~1.25 V offset, frame IDs: 20, 21, and 29 (with a frame error).	Off
ARINC	ARINC 429, 100 kbps, ~5 Vpp, ~0 V offset.	Off
FLEXray	FlexRay @ 10 Mbps, ~2.8 Vpp, ~0 V offset	Off
MANchester	Manchester/NRZ @ 125 kbps, ~2.5 Vpp, 1.25 V offset, a 125 kb/s 10-bit PSI5-like signal	Off
MIL	MIL-STD-1553 RT to RT transfer, received ~1.3 Vpp, transmitted ~4.8 Vpp, 0 V offset	Off

Demo Signal Function	Demo 1 Terminal	Demo 2 Terminal
MIL2	MIL-STD-1553 RT to RT transfer, received ~1.3 Vpp, transmitted ~4.8 Vpp, 0 V offset	MIL-STD-1553 RT to BC transfer, received ~1.3 Vpp, transmitted ~4.8 Vpp, 0 V offset
USB	USB Low Speed D+ signal, ~2.8 Vpp, 1.4 V offset	USB Low Speed D- signal, ~2.8 Vpp, 1.4 V offset
NMOnotonic	Digital pulse train with infrequent non-monotonic rising edges @ ~ 2.85 Vpp, 1.42 V offset	Off
DCMotor	Output of DAC controlling a DC motor: 800 mV pulse, 1 µs wide, every 10 µs, runt pulse every 100 ms.	Off
HARMonics	1 kHz sine wave @ ~3.5 Vpp, 0.0 V offset, with a ~2 kHz sine wave coupled in	Off
COUPling	1 kHz square wave @ ~1 Vpp, 0.0 V offset, with a ~90 kHz sine wave with ~180 mVpp riding on top	Off
CFD	CAN FD, ~2.4 Vpp, ~-1.2 V offset, 500 kb/s standard baud rate (sample point at 80%), 10 Mb/s FD baud rate (sample point at 50%)	Off
SENT	SENT, ~2.7 Vpp, ~1.35 V offset, 3 µs clock period, 6 nibbles in a Fast Channel Message, Slow Channel Messages in enhanced format, idle state high, with pause pulse	Off
USBPd	USB PD, ~2.5 Vpp, ~1.25 V offset, with vendor-defined data message packet and Good CRC control message packet	Off
KEYSight	Series of positive and negative pulses, 125 µs wide, amplitude modulated, ~2.6 Vpp, ~0 V offset	Off

**Query Syntax** :DEMO:FUNCTION?

The :DEMO:FUNCTION? query returns the currently selected demo signal type.

**Return Format** <signal><NL>

```
<signal> ::= {SIN | NOIS | PHAS | RING | SING | AM | CLK | GLIT | BURS
| MSO | RUNT | TRAN | RFB | SHOL | LFS | FMB | ETE | NFC | CAN
| LIN | UART | I2C | SPI | I2S | CANL | CXPI | ARIN | FLEX | MANC}
```

| MIL | MIL2 | USB | NMON | DCM | HARM | COUP | CFD | SENT | USBP  
| KEYS}

See Also · ["Introduction to :DEMO Commands"](#) on page 395

## :DEMO:FUNCTION:PHASE:PHASE

**N** (see [page 1666](#))

- Command Syntax**    `:DEMO:FUNCTION:PHASE:PHASE <angle>`  
`<angle> ::= angle in degrees from 0 to 360 in NR3 format`  
For the phase shifted sine demo signals, the :DEMO:FUNCTION:PHASE:PHASE command specifies the phase shift in the second sine waveform.
- Query Syntax**    `:DEMO:FUNCTION:PHASE:PHASE?`  
The :DEMO:FUNCTION:PHASE:PHASE? query returns the currently set phase shift.
- Return Format**    `<angle><NL>`  
`<angle> ::= angle in degrees from 0 to 360 in NR3 format`
- See Also**
  - ["Introduction to :DEMO Commands"](#) on page 395
  - [":DEMO:FUNCTION"](#) on page 396

## :DEMO:OUTPut

**N** (see [page 1666](#))

**Command Syntax**    `:DEMO:OUTPut <on_off>`

`<on_off>` ::= { {1 | ON} | {0 | OFF} }

The :DEMO:OUTPut command specifies whether the demo signal output is ON (1) or OFF (0).

**Query Syntax**    `:DEMO:OUTPut?`

The :DEMO:OUTPut? query returns the current state of the demo signal output setting.

**Return Format**    `<on_off><NL>`

`<on_off>` ::= {1 | 0}

**See Also**

- "[Introduction to :DEMO Commands](#)" on page 395
- "[":DEMO:FUNCTION](#)" on page 396

# 15 :DIGItal<d> Commands

Control all oscilloscope functions associated with individual digital channels. See "[Introduction to :DIGItal<d> Commands](#)" on page 404.

**Table 104** :DIGItal<d> Commands Summary

Command	Query	Options and Query Returns
:DIGItal<d>:DISPLAY { {0   OFF}   {1   ON} } (see <a href="#">page 405</a> )	:DIGItal<d>:DISPLAY? (see <a href="#">page 405</a> )	<d> ::= 0 to (# digital channels - 1) in NR1 format {0   1}
:DIGItal<d>:LABEL <string> (see <a href="#">page 406</a> )	:DIGItal<d>:LABEL? (see <a href="#">page 406</a> )	<d> ::= 0 to (# digital channels - 1) in NR1 format <string> ::= any series of 10 or less ASCII characters enclosed in quotation marks
:DIGItal<d>:POSITION <position> (see <a href="#">page 407</a> )	:DIGItal<d>:POSITION? (see <a href="#">page 407</a> )	<d> ::= 0 to (# digital channels - 1) in NR1 format <position> ::= 0-7 if display size = large, 0-15 if size = medium, 0-31 if size = small Returns -1 when there is no space to display the digital waveform.
:DIGItal<d>:SIZE <value> (see <a href="#">page 408</a> )	:DIGItal<d>:SIZE? (see <a href="#">page 408</a> )	<d> ::= 0 to (# digital channels - 1) in NR1 format <value> ::= {SMALL   MEDIUM   LARGe}
:DIGItal<d>:THRESHOLD <value>[suffix] (see <a href="#">page 409</a> )	:DIGItal<d>:THRESHOLD? (see <a href="#">page 409</a> )	<d> ::= 0 to (# digital channels - 1) in NR1 format <value> ::= {CMOS   ECL   TTL   <user defined value>} <user defined value> ::= value in NR3 format from -8.00 to +8.00 [suffix] ::= {V   mV   uV}

<b>Introduction to :DIGital&lt;d&gt; Commands</b>	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code> The DIGital subsystem commands control the viewing, labeling, and positioning of digital channels. They also control threshold settings for groups of digital channels, or <i>pods</i> .
---	--

**NOTE**

These commands are only valid for the MSO models.

---

### Reporting the Setup

Use :DIGital<d>? to query setup information for the DIGital subsystem.

### Return Format

The following is a sample response from the :DIGital0? query. In this case, the query was issued following a \*RST command.

```
:DIG0:DISP 0;THR +1.40E+00;LAB 'D0';POS +0
```

## :DIGItal<d>:DISPlay

**N** (see [page 1666](#))

**Command Syntax** :DIGItal<d>:DISPlay <display>

<d> ::= 0 to (# digital channels - 1) in NR1 format

<display> ::= {{1 | ON} | {0 | OFF}}

The :DIGItal<d>:DISPlay command turns digital display on or off for the specified channel.

### NOTE

This command is only valid for the MSO models.

**Query Syntax** :DIGItal<d>:DISPlay?

The :DIGItal<d>:DISPlay? query returns the current digital display setting for the specified channel.

**Return Format** <display><NL>

<display> ::= {0 | 1}

- See Also**
- "[Introduction to :DIGItal<d> Commands](#)" on page 404
  - "[:POD<n>:DISPlay](#)" on page 753
  - "[:CHANnel<n>:DISPlay](#)" on page 347
  - "[:VIEW](#)" on page 298
  - "[:BLANK](#)" on page 266
  - "[:STATus](#)" on page 295

## :DIGital<d>:LABel

**N** (see [page 1666](#))

**Command Syntax**

```
:DIGital<d>:LABel <string>
<d> ::= 0 to (# digital channels - 1) in NR1 format
<string> ::= any series of 10 or less characters as quoted ASCII string.
```

The :DIGital<d>:LABel command sets the channel label to the string that follows. Setting a label for a channel also adds the name to the label list in non-volatile memory (replacing the oldest label in the list).

**NOTE**

This command is only valid for the MSO models.

**NOTE**

Label strings are 10 characters or less, and may contain any commonly used ASCII characters. Labels with more than 10 characters are truncated to 10 characters.

**Query Syntax**

```
:DIGital<d>:LABel?
```

The :DIGital<d>:LABel? query returns the name of the specified channel.

**Return Format**

```
<label string><NL>
```

```
<label string> ::= any series of 10 or less characters as a quoted
ASCII string.
```

**See Also**

- "[Introduction to :DIGital<d> Commands](#)" on page 404
- "[:CHANnel<n>:LABEL](#)" on page 350
- "[:DISPlay:LABList](#)" on page 429
- "[:BUS<n>:LABEL](#)" on page 326

## :DIGItal<d>:POSIon

**N** (see [page 1666](#))

**Command Syntax** :DIGItal<d>:POSIon <position>

```
<d> ::= 0 to (# digital channels - 1) in NR1 format
<position> ::= integer in NR1 format.
```

Channel Size	Position	Top	Bottom
Large	0-7	7	0
Medium	0-15	15	0
Small	0-31	31	0

The :DIGItal<d>:POSIon command sets the position of the specified channel. Note that bottom positions might not be valid depending on whether digital buses, serial decode waveforms, or the zoomed time base are displayed.

### NOTE

This command is only valid for the MSO models.

### Query Syntax

:DIGItal<d>:POSIon?

The :DIGItal<d>:POSIon? query returns the position of the specified channel.

If the returned value is "-1", this indicates there is no space to display the digital waveform (for example, when all serial lanes, digital buses, and the zoomed time base are displayed).

### Return Format

<position><NL>

<position> ::= integer in NR1 format.

### See Also

- ["Introduction to :DIGItal<d> Commands" on page 404](#)

## :DIGital<d>:SIZE

**N** (see [page 1666](#))

**Command Syntax**    `:DIGital<d>:SIZE <value>`

```
<d> ::= 0 to (# digital channels - 1) in NR1 format
<value> ::= {SMALL | MEDium | LARGe}
```

The :DIGital<d>:SIZE command specifies the size of digital channels on the display. Sizes are set for all digital channels. Therefore, if you set the size on digital channel 0 (for example), the same size is set on all other as well.

### NOTE

This command is only valid for the MSO models.

**Query Syntax**    `:DIGital<d>:SIZE?`

The :DIGital<d>:SIZE? query returns the size setting for the specified digital channels.

**Return Format**    `<size_value><NL>`

```
<size_value> ::= {SMAL | MED | LARG}
```

**See Also**

- "[Introduction to :DIGital<d> Commands](#)" on page 404
- "[":POD<n>:SIZE](#)" on page 754
- "[":DIGital<d>:POSITION](#)" on page 407

## :DIGital<d>:THreshold

**N** (see [page 1666](#))

**Command Syntax**

```
:DIGital<d>:THreshold <value>
<d> ::= 0 to (# digital channels - 1) in NR1 format
<value> ::= {CMOS | ECL | TTL | <user defined value>[<suffix>] }
<user defined value> ::= -8.00 to +8.00 in NR3 format
<suffix> ::= {V | mV | uV}
· TTL = 1.4V
· CMOS = 2.5V
· ECL = -1.3V
```

The :DIGital<d>:THreshold command sets the logic threshold value for all channels in the same *pod* as the specified channel. The threshold is used for triggering purposes and for displaying the digital data as high (above the threshold) or low (below the threshold).

### NOTE

This command is only valid for the MSO models.

**Query Syntax**

```
:DIGital<d>:THreshold?
```

The :DIGital<d>:THreshold? query returns the threshold value for the specified channel.

**Return Format**

```
<value><NL>
<value> ::= threshold value in NR3 format
```

**See Also**

- "[Introduction to :DIGital<d> Commands](#)" on page 404
- "[":POD<n>:THreshold](#)" on page 755
- "[":TRIGger\[:EDGE\]:LEVel](#)" on page 1380



# 16 :DISPlay Commands

Control how waveforms, graticule, and text are displayed and written on the screen. See "[Introduction to :DISPlay Commands](#)" on page 413.

**Table 105** :DISPlay Commands Summary

Command	Query	Options and Query Returns
:DISPlay:ANNotation<n> {{0   OFF}   {1   ON}} (see <a href="#">page 414</a> )	:DISPlay:ANNotation<n>? (see <a href="#">page 414</a> )	{0   1} <n> ::= an integer from 1 to 4 in NR1 format.
:DISPlay:ANNotation<n>:BACKground <mode> (see <a href="#">page 415</a> )	:DISPlay:ANNotation<n>:BACKground? (see <a href="#">page 415</a> )	<mode> ::= {OPAQue   INVerted   TRANsparent} <n> ::= an integer from 1 to 4 in NR1 format.
:DISPlay:ANNotation<n>:COLOR <color> (see <a href="#">page 416</a> )	:DISPlay:ANNotation<n>:COLOR? (see <a href="#">page 416</a> )	<color> ::= {CH1   CH2   CH3   CH4   DIG   MATH   REF   MARKer   WHITe   RED} <n> ::= an integer from 1 to 4 in NR1 format.
:DISPlay:ANNotation<n>:TEXT <string> (see <a href="#">page 417</a> )	:DISPlay:ANNotation<n>:TEXT? (see <a href="#">page 417</a> )	<string> ::= quoted ASCII string (up to 254 characters) <n> ::= an integer from 1 to 4 in NR1 format.
:DISPlay:ANNotation<n>:X1Position <value> (see <a href="#">page 418</a> )	:DISPlay:ANNotation<n>:X1Position? (see <a href="#">page 418</a> )	<value> ::= an integer from 0 to (800 - width of annotation) in NR1 format. <n> ::= an integer from 1 to 4 in NR1 format.
:DISPlay:ANNotation<n>:Y1Position <value> (see <a href="#">page 419</a> )	:DISPlay:ANNotation<n>:Y1Position? (see <a href="#">page 419</a> )	<value> ::= an integer from 0 to (480 - height of annotation) in NR1 format. <n> ::= an integer from 1 to 4 in NR1 format.

**Table 105** :DISPlay Commands Summary (continued)

Command	Query	Options and Query Returns
:DISPlay:BACKlight {{0   OFF}   {1   ON}} (see <a href="#">page 420</a> )	n/a	n/a
:DISPlay:CLEar (see <a href="#">page 421</a> )	n/a	n/a
n/a	:DISPlay:DATA? [<format>] [,] [<palett e>] (see <a href="#">page 422</a> )	<format> ::= {BMP   BMP8bit   PNG} <palette> ::= {COLOR   GRAYscale} <display data> ::= data in IEEE 488.2 # format
:DISPlay:GRATICule:ALABels {{0   OFF}   {1   ON}} (see <a href="#">page 424</a> )	:DISPlay:GRATICule:ALABels? (see <a href="#">page 424</a> )	<setting> ::= {0   1}
:DISPlay:GRATICule:INTensity <value> (see <a href="#">page 425</a> )	:DISPlay:GRATICule:INTensity? (see <a href="#">page 425</a> )	<value> ::= an integer from 0 to 100 in NR1 format.
:DISPlay:GRATICule:TYPE <type> (see <a href="#">page 426</a> )	:DISPlay:GRATICule:TYPE? (see <a href="#">page 426</a> )	<type> ::= {FULL   MVOLT   IRE}
:DISPlay:INTensity:WAVeform <value> (see <a href="#">page 427</a> )	:DISPlay:INTensity:WAVeform? (see <a href="#">page 427</a> )	<value> ::= an integer from 0 to 100 in NR1 format.
:DISPlay:LABEL {{0   OFF}   {1   ON}} (see <a href="#">page 428</a> )	:DISPlay:LABEL? (see <a href="#">page 428</a> )	{0   1}
:DISPlay:LABList <binary block> (see <a href="#">page 429</a> )	:DISPlay:LABList? (see <a href="#">page 429</a> )	<binary block> ::= an ordered list of up to 75 labels, each 10 characters maximum, separated by newline characters
:DISPlay:MENU <menu> (see <a href="#">page 430</a> )	n/a	<menu> ::= {MASK   MEASure   SEGmented   LISTer   POWER}
:DISPlay:MESSAGE:CLEar (see <a href="#">page 431</a> )	n/a	n/a
:DISPlay:PERSISTence <value> (see <a href="#">page 432</a> )	:DISPlay:PERSISTence? (see <a href="#">page 432</a> )	<value> ::= {MINimum   INFinite   <time>} <time> ::= seconds in in NR3 format from 100E-3 to 60E0
:DISPlay:PERSISTence:CLEar (see <a href="#">page 433</a> )	n/a	n/a

**Table 105** :DISPlay Commands Summary (continued)

Command	Query	Options and Query Returns
:DISPlay:SIDebar <sidebar> (see <a href="#">page 434</a> )	n/a	<sidebar> ::= {SUMMarry   CURSors   MEASurements   DVM   NAVigate   CONTrols   EVENTS   COUNTER}
:DISPlay:TRANsparent {OFF   ON} (see <a href="#">page 435</a> )	:DISPlay:TRANsparent? (see <a href="#">page 435</a> )	{OFF   ON}
:DISPlay:VECTors {1   ON} (see <a href="#">page 436</a> )	:DISPlay:VECTors? (see <a href="#">page 436</a> )	1

- Introduction to :DISPlay Commands** The DISPlay subsystem is used to control the display storage and retrieval of waveform data, labels, and text. This subsystem allows the following actions:
- Clear the waveform area on the display.
  - Turn vectors on or off.
  - Set waveform persistence.
  - Specify labels.
  - Save and Recall display data.

#### Reporting the Setup

Use :DISPlay? to query the setup information for the DISPlay subsystem.

#### Return Format

The following is a sample response from the :DISPlay? query. In this case, the query was issued following a \*RST command.

```
:DISP:LAB 0;VECT 1;PERS MIN
```

**:DISPlay:ANNotation<n>****N** (see [page 1666](#))**Command Syntax**    `:DISPlay:ANNotation<n> <setting>``<setting> ::= {{1 | ON} | {0 | OFF}}``<n> ::= an integer from 1 to 10 in NR1 format.`

The `:DISPlay:ANNotation<n>` command turns the annotation on and off. When on, the annotation appears in the upper left corner of the oscilloscope's display.

The annotation is useful for documentation purposes, to add notes before capturing screens.

**Query Syntax**    `:DISPlay:ANNotation<n>?`

The `:DISPlay:ANNotation<n>?` query returns the annotation setting.

**Return Format**    `<value><NL>``<value> ::= {0 | 1}`

- See Also**
- "[":DISPlay:ANNotation<n>:TEXT](#)" on page 417
  - "[":DISPlay:ANNotation<n>:COLor](#)" on page 416
  - "[":DISPlay:ANNotation<n>:BACKground](#)" on page 415
  - "[":DISPlay:ANNotation<n>:X1Position](#)" on page 418
  - "[":DISPlay:ANNotation<n>:Y1Position](#)" on page 419
  - "[Introduction to :DISPlay Commands](#)" on page 413

## :DISPlay:ANNotation<n>:BACKground

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:DISPlay:ANNotation&lt;n&gt;:BACKground &lt;mode&gt;</code> <code>&lt;mode&gt; ::= {OPAQue   INVerted   TRANsparent}</code> <code>&lt;n&gt; ::= an integer from 1 to 10 in NR1 format.</code>
	The :DISPlay:ANNotation<n>:BACKground command specifies the background of the annotation:
	<ul style="list-style-type: none"> <li>• OPAQue – the annotation has a solid background.</li> <li>• INVerted – the annotation's foreground and background colors are switched.</li> <li>• TRANsparent – the annotation has a transparent background.</li> </ul>
<b>Query Syntax</b>	<code>:DISPlay:ANNotation&lt;n&gt;:BACKground?</code>
	The :DISPlay:ANNotation<n>:BACKground? query returns the specified annotation background mode.
<b>Return Format</b>	<code>&lt;mode&gt;&lt;NL&gt;</code> <code>&lt;mode&gt; ::= {OPAQ   INV   TRAN}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">:DISPlay:ANNotation&lt;n&gt;</a>" on page 414</li> <li>• "<a href="#">:DISPlay:ANNotation&lt;n&gt;:TEXT</a>" on page 417</li> <li>• "<a href="#">:DISPlay:ANNotation&lt;n&gt;:COLOR</a>" on page 416</li> <li>• "<a href="#">:DISPlay:ANNotation&lt;n&gt;:X1Position</a>" on page 418</li> <li>• "<a href="#">:DISPlay:ANNotation&lt;n&gt;:Y1Position</a>" on page 419</li> <li>• "<a href="#">Introduction to :DISPlay Commands</a>" on page 413</li> </ul>

## :DISPlay:ANNotation<n>:COLor

**N** (see [page 1666](#))

**Command Syntax**    `:DISPlay:ANNotation<n>:COLor <color>`

```
<color> ::= {CH1 | CH2 | CH3 | CH4 | DIG | MATH | REF | MARKer | WHIT
           | RED}
```

<n> ::= an integer from 1 to 10 in NR1 format.

The :DISPlay:ANNotation<n>:COLor command specifies the annotation color. You can choose white, red, or colors that match analog channels, digital channels, math waveforms, reference waveforms, or markers.

**Query Syntax**    `:DISPlay:ANNotation<n>:COLor?`

The :DISPlay:ANNotation<n>:COLor? query returns the specified annotation color.

**Return Format**    `<color><NL>`

```
<color> ::= {CH1 | CH2 | CH3 | CH4 | DIG | MATH | REF | MARK | WHIT
           | RED}
```

**See Also**

- "[:DISPlay:ANNotation<n>](#)" on page 414
- "[:DISPlay:ANNotation<n>:TEXT](#)" on page 417
- "[:DISPlay:ANNotation<n>:BACKground](#)" on page 415
- "[:DISPlay:ANNotation<n>:X1Position](#)" on page 418
- "[:DISPlay:ANNotation<n>:Y1Position](#)" on page 419
- "[Introduction to :DISPlay Commands](#)" on page 413

## :DISPlay:ANAnnotation<n>:TEXT

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:DISPlay:ANAnnotation&lt;n&gt;:TEXT &lt;string&gt;</code> <code>&lt;string&gt; ::= quoted ASCII string (up to 254 characters)</code> <code>&lt;n&gt; ::= an integer from 1 to 10 in NR1 format.</code>
	The :DISPlay:ANAnnotation<n>:TEXT command specifies the annotation string. The annotation string can contain as many characters as will fit in the Edit Annotation box on the oscilloscope's screen, up to 254 characters.
	You can include a carriage return in the annotation string using the characters "\n". Note that this is not a new line character but the actual "\" (backslash) and "n" characters in the string. Carriage returns lessen the number of characters available for the annotation string.
	Use :DISPlay:ANAnnotation<n>:TEXT "" to remotely clear the annotation text. (Two sets of quote marks without a space between them creates a NULL string.)
<b>Query Syntax</b>	<code>:DISPlay:ANAnnotation&lt;n&gt;:TEXT?</code>
	The :DISPlay:ANAnnotation<n>:TEXT? query returns the specified annotation text. When carriage returns are present in the annotation text, they are returned as the actual carriage return character (ASCII 0x0D).
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code> <code>&lt;string&gt; ::= quoted ASCII string</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:DISPlay:ANAnnotation&lt;n&gt;</a>" on page 414</li> <li>· "<a href="#">:DISPlay:ANAnnotation&lt;n&gt;:COLor</a>" on page 416</li> <li>· "<a href="#">:DISPlay:ANAnnotation&lt;n&gt;:BACKground</a>" on page 415</li> <li>· "<a href="#">:DISPlay:ANAnnotation&lt;n&gt;:X1Position</a>" on page 418</li> <li>· "<a href="#">:DISPlay:ANAnnotation&lt;n&gt;:Y1Position</a>" on page 419</li> <li>· "<a href="#">Introduction to :DISPlay Commands</a>" on page 413</li> </ul>

## :DISPlay:ANAnnotation<n>:X1Position

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:DISPlay:ANAnnotation&lt;n&gt;:X1Position &lt;value&gt;</code>
	<code>&lt;value&gt;</code> ::= an integer from 0 to (800 - width of annotation) in NR1 format at.
	<code>&lt;n&gt;</code> ::= an integer from 1 to 10 in NR1 format.
	The <code>:DISPlay:ANAnnotation&lt;n&gt;:X1Position</code> command sets the annotation's horizontal X1 position.
<b>Query Syntax</b>	<code>:DISPlay:ANAnnotation&lt;n&gt;:X1Position?</code>
	The <code>:DISPlay:ANAnnotation&lt;n&gt;:X1Position?</code> query returns the annotation's horizontal X1 position.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code>
	<code>&lt;value&gt;</code> ::= an integer from 0 to (800 - width of annotation) in NR1 format at.
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":DISPlay:ANAnnotation&lt;n&gt;:Y1Position" on page 419</a></li><li><a href="#">":DISPlay:ANAnnotation&lt;n&gt;" on page 414</a></li><li><a href="#">":DISPlay:ANAnnotation&lt;n&gt;:COLOr" on page 416</a></li><li><a href="#">":DISPlay:ANAnnotation&lt;n&gt;:BACKground" on page 415</a></li><li><a href="#">":DISPlay:ANAnnotation&lt;n&gt;:TEXT" on page 417</a></li></ul>

## :DISPlay:ANNotation<n>:Y1Position

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:DISPlay:ANNotation&lt;n&gt;:Y1Position &lt;value&gt;</code>
	<code>&lt;value&gt;</code> ::= an integer from 0 to (480 - height of annotation) in NR1 format.
	<code>&lt;n&gt;</code> ::= an integer from 1 to 10 in NR1 format.
	The :DISPlay:ANNotation<n>:Y1Position command sets the annotation's vertical Y1 position.
<b>Query Syntax</b>	<code>:DISPlay:ANNotation&lt;n&gt;:Y1Position?</code>
	The :DISPlay:ANNotation<n>:Y1Position? query returns the annotation's vertical Y1 position.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code>
	<code>&lt;value&gt;</code> ::= an integer from 0 to (480 - height of annotation) in NR1 format.
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:DISPlay:ANNotation&lt;n&gt;:X1Position</a>" on page 418</li> <li>· "<a href="#">:DISPlay:ANNotation&lt;n&gt;</a>" on page 414</li> <li>· "<a href="#">:DISPlay:ANNotation&lt;n&gt;:COLor</a>" on page 416</li> <li>· "<a href="#">:DISPlay:ANNotation&lt;n&gt;:BACKground</a>" on page 415</li> <li>· "<a href="#">:DISPlay:ANNotation&lt;n&gt;:TEXT</a>" on page 417</li> </ul>

## :DISPlay:BACKlight

**N** (see [page 1666](#))

**Command Syntax** :DISPLAY:BACKlight {{0 | OFF} | {1 | ON}}

The :DISPLAY:BACKlight command turns the display's backlight off or on.

## :DISPlay:CLEar

**N** (see [page 1666](#))

**Command Syntax** :DISPlay:CLEar

The :DISPlay:CLEar command clears the display and resets all associated measurements. If the oscilloscope is stopped, all currently displayed data is erased. If the oscilloscope is running, all of the data for active channels and functions is erased; however, new data is displayed on the next acquisition.

**See Also** • ["Introduction to :DISPlay Commands"](#) on page 413

## :DISPlay:DATA

**N** (see [page 1666](#))

**Query Syntax**

```
:DISPlay:DATA? [<format> [,<palette>]
<format> ::= {BMP | BMP8bit | PNG}
<palette> ::= {COLor | GRAYscale}
```

The :DISPlay:DATA? query reads screen image data. You can choose 24-bit BMP, 8-bit BMP8bit, or 24-bit PNG formats in color or grayscale.

Note that the returned image is also affected by the :HARDcopy:INKSaver command, which is ON by default and returns an inverted image. To get a non-inverted image, send the ":HARDcopy:INKSaver OFF" command before the DATA? query.

If no format or palette option is specified, the screen image is returned in whatever image format is selected by the front panel's [**Save/Recall**] > **Save** > **Format** softkey. If the **Format** softkey does not select an image format (in other words, it selects a setup or data format), the BMP, COLor format is used.

Screen image data is returned in the IEEE-488.2 # binary block data format.

**Return Format**

```
<display data><NL>
<display data> ::= binary block data in IEEE-488.2 # format.
```

**See Also**

- "[Introduction to :DISPlay Commands](#)" on page 413
- "[":HARDcopy:INKSaver](#)" on page 548
- "[":HCOPY:SDUMp:DATA](#)" on page 559
- "[":HCOPY:SDUMp:FORMAT](#)" on page 560
- "[":PRINT](#)" on page 290
- "[":RCL \(Recall\)](#)" on page 243
- "[":SAV \(Save\)](#)" on page 247
- "[":VIEW](#)" on page 298

**Example Code**

```
' IMAGE_TRANSFER - In this example, we will query for the image data
' with ":DISPlay:DATA?", read the data, and then save it to a file.
Dim byteData() As Byte
myScope.IO.Timeout = 15000
myScope.WriteString ":DISPlay:DATA? BMP, COLOR"
byteData = myScope.ReadIEEEBlock(BinaryType_UI1)
' Output display data to a file:
strPath = "c:\scope\data\screen.bmp"
' Remove file if it exists.
If Len(Dir(strPath)) Then
    Kill strPath
End If
Close #1      ' If #1 is open, close it.
```

```
Open strPath For Binary Access Write Lock Write As #1      ' Open file f
or output.
Put #1, , byteData      ' Write data.
Close #1      ' Close file.
myScope.IO.Timeout = 5000
```

See complete example programs at: [Chapter 46](#), “Programming Examples,” starting on page 1675

## :DISPlay:GRATicule:ALABels

**N** (see [page 1666](#))

**Command Syntax** :DISPlay:GRATicule:ALABels {{0 | OFF} | {1 | ON}}

The :DISPlay:GRATicule:ALABels command turns graticule (grid) axis labels on or off.

**Query Syntax** :DISPlay:GRATicule:ALABels?

The :DISPlay:GRATicule:ALABels? query returns the graticule (grid) axis labels setting

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

**See Also** • "[:DISPlay:GRATicule:INTensity](#)" on page 425  
• "[:DISPlay:GRATicule:TYPE](#)" on page 426

## :DISPlay:GRATicule:INTensity

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:DISPlay:GRATicule:INTensity &lt;value&gt;</code> <code>&lt;value&gt; ::= an integer from 0 to 100 in NR1 format.</code>
	The :DISPlay:GRATicule:INTensity command sets the graticule (grid) intensity.
<b>Query Syntax</b>	<code>:DISPlay:GRATicule:INTensity?</code>
	The :DISPlay:GRATicule:INTensity? query returns the graticule (grid) intensity setting.

**Return Format** `<value><NL>`

**See Also** • "[:DISPlay:GRATicule:ALABels](#)" on page 424  
• "[:DISPlay:GRATicule:TYPE](#)" on page 426

## :DISPlay:GRATicule:TYPE

**N** (see [page 1666](#))

**Command Syntax**    `:DISPlay:GRATicule:TYPE <type>`  
`<type> ::= {FULL | MVOLt | IRE}`

The :DISPlay:GRATicule:TYPE command sets the graticule (grid) type.

When the TV trigger type is selected (see "[:TRIGger:MODE](#)" on page 1362), and the vertical scaling of at least one displayed channel is 140 mV/div, the :DISPlay:GRATicule:TYPE command lets you select from these grid types:

- FULL – the normal oscilloscope grid.
- MVOLt – shows vertical grids, labeled on the left, from -0.3 V to 0.8 V.
- IRE – (Institute of Radio Engineers) shows vertical grids in IRE units, labeled on the left, from -40 to 100 IRE. The 0.35 V and 0.7 V levels from the MVOLt grid are also shown and labeled at the right. When the IRE grid is selected, cursor values on the display are also shown in IRE units. However, cursor values via the remote interface are not in IRE units.

The MVOLt and IRE grid values are accurate when the vertical scaling is 140 mV/division and the vertical offset is 245 mV.

**Query Syntax**    `:DISPlay:GRATicule:TYPE?`

The :DISPlay:GRATicule:TYPE? query returns the graticule (grid) type setting.

**Return Format**    `<type><NL>`  
`<type> ::= {FULL | MVOL | IRE}`

**See Also**

- "[:TRIGger:MODE](#)" on page 1362
- "[:CHANnel<n>:SCALe](#)" on page 368
- "[:CHANnel<n>:OFFSet](#)" on page 351
- "[:DISPlay:GRATicule:ALABels](#)" on page 424
- "[:DISPlay:GRATicule:INTensity](#)" on page 425

## :DISPlay:INTensity:WAveform

**N** (see [page 1666](#))

- Command Syntax** :DISPlay:INTensity:WAveform <value>  
<value> ::= an integer from 0 to 100 in NR1 format.  
The :DISPlay:INTensity:WAveform command sets the waveform intensity.  
This is the same as adjusting the front panel [**Intensity**] knob.
- Query Syntax** :DISPlay:INTensity:WAveform?  
The :DISPlay:INTensity:WAveform? query returns the waveform intensity setting.
- Return Format** <value><NL>  
<value> ::= an integer from 0 to 100 in NR1 format.
- See Also** • ["Introduction to :DISPlay Commands"](#) on page 413

**:DISPlay:LABel**

**N** (see [page 1666](#))

**Command Syntax**    `:DISPlay:LABel <value>`

`<value> ::= {{1 | ON} | {0 | OFF}}`

The :DISPlay:LABel command turns the analog and digital channel labels on and off.

**Query Syntax**    `:DISPlay:LABel?`

The :DISPlay:LABel? query returns the display mode of the analog and digital labels.

**Return Format**    `<value><NL>`

`<value> ::= {0 | 1}`

**See Also**

- "Introduction to :DISPlay Commands" on page 413
- "`:CHANnel<n>:LABEL`" on page 350

**Example Code**

```
' DISP_LABEL  
' - Turns label names ON or OFF on the analyzer display.  
myScope.WriteString ":DISPlay:LABel ON" ' Turn on labels.
```

See complete example programs at: [Chapter 46, “Programming Examples,”](#) starting on page 1675

## :DISPlay:LABList

**N** (see [page 1666](#))

**Command Syntax** :DISPlay:LABList <binary block data>  
 <binary block> ::= an ordered list of up to 75 labels, a maximum of 32 characters each, separated by newline characters.

The :DISPlay:LABList command adds labels to the label list. Labels are added in alphabetical order.

### NOTE

Labels that begin with the same alphabetic base string followed by decimal digits are considered duplicate labels. Duplicate labels are not added to the label list. For example, if label "A0" is in the list and you try to add a new label called "A1234567890123456789012345678901", the new label is not added.

**Query Syntax** :DISPlay:LABList?

The :DISPlay:LABList? query returns the label list.

**Return Format** <binary block><NL>  
 <binary block> ::= an ordered list of up to 75 labels, a maximum of 32 characters each, separated by newline characters.

**See Also**

- "[Introduction to :DISPlay Commands](#)" on page 413
- "[":DISPlay:LABel](#)" on page 428
- "[":CHANnel<n>:LABel](#)" on page 350
- "[":DIGital<d>:LABel](#)" on page 406
- "[":BUS<n>:LABel](#)" on page 326

## :DISPlay:MENU

**N** (see [page 1666](#))

**Command Syntax**    `:DISPlay:MENU <menu>`

`<menu> ::= {MASK | MEASure | SEGmented | LISTer | POWER | OFF}`

The :DISPlay:MENU command changes the front panel softkey menu or turns it off. When off, channel setup information is displayed instead.

## :DISPlay:MESSAge:CLEar

**N** (see [page 1666](#))

**Command Syntax** :DISPlay:MESSAge:CLEar

The :DISPlay:MESSAge:CLEar command removes all user messages that are currently on screen.

**See Also** • [":SYSTem:DSP"](#) on page 1316

## :DISPlay:PERStance

**N** (see [page 1666](#))

**Command Syntax**    `:DISPlay:PERStance <value>`

`<value> ::= {MINimum | INFinite | <time>}`

`<time> ::= seconds in in NR3 format from 100E-3 to 60E0`

The :DISPlay:PERStance command specifies the persistence setting:

- MINimum – indicates zero persistence.
- INFinite – indicates infinite persistence.
- <time> – for variable persistence, that is, you can specify how long acquisitions remain on the screen.

Use the :DISPlay:PERStance:CLEar command to erase points stored by persistence.

**Query Syntax**    `:DISPlay:PERStance?`

The :DISPlay:PERStance? query returns the specified persistence setting.

**Return Format**    `<value><NL>`

`<value> ::= {MIN | INF | <time>}`

**See Also**

- "[Introduction to :DISPlay Commands](#)" on page 413
- "[":DISPlay:PERStance:CLEar](#)" on page 433

## :DISPlay:PERSistence:CLEar

**N** (see [page 1666](#))

**Command Syntax** :DISPlay:PERsistence:CLEar

The :DISPlay:PERsistence:CLEar command erases all persistence data from the display, leaving the data from the last acquisition.

If the oscilloscope is running, the display will begin to accumulate waveform and persistence data again.

The :DISPlay:CLEar command clears all waveform data from the display, including the data from the last acquisition.

**See Also**

- [":DISPlay:PERsistence"](#) on page 432
- [":DISPlay:CLEar"](#) on page 421

## :DISPlay:SIDebar

**N** (see [page 1666](#))

**Command Syntax**    `:DISPlay:SIDebar <sidebar>`

```
<sidebar> ::= {SUMMary | CURSors | MEASurements | DVM | NAVigate  
              | CONTrols | EVENTS | COUNTER}
```

The :DISPlay:SIDebar command specifies the sidebar dialog to display on the screen.

## :DISPlay:TRANsparent

**N** (see [page 1666](#))

**Command Syntax**    `:DISPlay:TRANsparent <setting>`  
                      `<setting> ::= {OFF | ON}`

The :DISPlay:TRANsparent command enables or disables transparent mode for dialog box backgrounds in the front panel graphical user interface.

This command maps to the **Transparent** softkey that appears in the front panel user interface under **[Utility] > Options > Preferences**.

**Query Syntax**    `:DISPlay:TRANsparent?`

The :DISPlay:TRANsparent? query returns the transparent setting.

**Return Format**    `<setting><NL>`  
                      `<setting> ::= {OFF | ON}`

**See Also**    • "Introduction to :DISPlay Commands" on page 413

## :DISPlay:VECTors

**N** (see [page 1666](#))

**Command Syntax**    `:DISPlay:VECTors <vectors>`

`<vectors> ::= {1 | ON}`

Vector display is always ON in the 3000T X-Series oscilloscopes.

When vectors are turned on, the oscilloscope displays lines connecting sampled data points.

**Query Syntax**    `:DISPlay:VECTors?`

The `:DISPlay:VECTors?` query returns the vectors setting.

**Return Format**    `<vectors><NL>`

`<vectors> ::= 1`

**See Also**    · ["Introduction to :DISPlay Commands"](#) on page 413

# 17 :DVM Commands

These commands control the digital voltmeter (DVM) feature.

**Table 106** :DVM Commands Summary

Command	Query	Options and Query Returns
:DVM:ARAnge {{0   OFF}   {1   ON}} (see page 438)	:DVM:ARAnge? (see page 438)	{0   1}
n/a	:DVM:CURREnt? (see page 439)	<dvm_value> ::= floating-point number in NR3 format
:DVM:ENABLE {{0   OFF}   {1   ON}} (see page 440)	:DVM:ENABLE? (see page 440)	{0   1}
:DVM:MODE <mode> (see page 441)	:DVM:MODE? (see page 441)	<dvm_mode> ::= {ACRMs   DC   DCRMs}
:DVM:SOURce <source> (see page 442)	:DVM:SOURce? (see page 442)	<source> ::= {CHANnel<n>} <n> ::= 1-2 or 1-4 in NR1 format

## :DVM:ARAnge

**N** (see [page 1666](#))

**Command Syntax**    `:DVM:ARAnge <setting>`

`<setting> ::= {{OFF | 0} | {ON | 1}}`

If the selected digital voltmeter (DVM) source channel is not used in oscilloscope triggering, the :DVM:ARAnge command turns the digital voltmeter's Auto Range capability on or off.

- When on, the DVM channel's vertical scale, vertical (ground level) position, and trigger (threshold voltage) level (used for the counter frequency measurement) are automatically adjusted.

The Auto Range capability overrides attempted adjustments of the channel's vertical scale and position.

- When off, you can adjust the channel's vertical scale and position normally.

**Query Syntax**    `:DVM:ARAnge?`

The :DVM:ARAnge? query returns a flag indicating whether the digital voltmeter's Auto Range capability is on or off.

**Return Format**    `<setting><NL>`

`<setting> ::= {0 | 1}`

**See Also**

- [":DVM:SOURce"](#) on page 442
- [":DVM:ENABLE"](#) on page 440
- [":DVM:MODE"](#) on page 441

## :DVM:CURRent

**N** (see [page 1666](#))

**Query Syntax** :DVM:CURREnt?

The :DVM:CURREnt? query returns the displayed 3-digit DVM value based on the current mode.

### NOTE

It can take up to a few seconds after DVM analysis is enabled before this query starts to produce good results, that is, results other than +9.9E+37. To wait for good values after DVM analysis is enabled, programs should loop until a value less than +9.9E+37 is returned.

**Return Format** <dvm\_value><NL>

<dvm\_value> ::= floating-point number in NR3 format

**See Also**

- "[:DVM:SOURce](#)" on page 442
- "[:DVM:ENABLE](#)" on page 440
- "[:DVM:MODE](#)" on page 441

## :DVM:ENABLE

**N** (see [page 1666](#))

**Command Syntax**    `:DVM:ENABLE <setting>`

`<setting> ::= {{OFF | 0} | {ON | 1}}`

The :DVM:ENABLE command turns the digital voltmeter (DVM) analysis feature on or off.

**Query Syntax**    `:DVM:ENABLE?`

The :DVM:ENABLE? query returns a flag indicating whether the digital voltmeter (DVM) analysis feature is on or off.

**Return Format**    `<setting><NL>`

`<setting> ::= {0 | 1}`

**See Also**

- [":DVM:SOURce" on page 442](#)
- [":DVM:MODE" on page 441](#)
- [":DVM:ARAnge" on page 438](#)

## :DVM:MODE

**N** (see [page 1666](#))

**Command Syntax** :DVM:MODE <dvm\_mode>

<dvm\_mode> ::= {ACRMs | DC | DCRMs}

The :DVM:MODE command sets the digital voltmeter (DVM) mode:

- ACRMs – displays the root-mean-square value of the acquired data, with the DC component removed.
- DC – displays the DC value of the acquired data.
- DCRMs – displays the root-mean-square value of the acquired data.

**Query Syntax** :DVM:MODE?

The :DVM:MODE? query returns the selected DVM mode.

**Return Format** <dvm\_mode><NL>

<dvm\_mode> ::= {ACRM | DC | DCRM}

**See Also**

- "[:DVM:ENABLE](#)" on page 440
- "[:DVM:SOURce](#)" on page 442
- "[:DVM:ARAnge](#)" on page 438
- "[:DVM:CURREnt](#)" on page 439

## :DVM:SOURce

**N** (see [page 1666](#))

**Command Syntax**    `:DVM:SOURce <source>`

```
<source> ::= {CHANnel<n>}  
<n> ::= 1-2 or 1-4 in NR1 format
```

The :DVM:SOURce command sets the select the analog channel on which digital voltmeter (DVM) measurements are made.

The selected channel does not have to be on (displaying a waveform) in order for DVM measurements to be made.

**Query Syntax**    `:DVM:SOURce?`

The :DVM:SOURce? query returns the selected DVM input source.

**Return Format**    `<source><NL>`

```
<source> ::= {CHAN<n>}  
<n> ::= 1-2 or 1-4 in NR1 format
```

- See Also**
- "[:DVM:ENABLE](#)" on page 440
  - "[:DVM:MODE](#)" on page 441
  - "[:DVM:ARAnge](#)" on page 438
  - "[:DVM:CURREnt](#)" on page 439

# 18 :EXternal Trigger Commands

Control the input characteristics of the external trigger input. See "[Introduction to :EXternal Trigger Commands](#)" on page 443.

**Table 107** :EXternal Trigger Commands Summary

Command	Query	Options and Query Returns
:EXternal:BWLimit <bwlimit> (see <a href="#">page 444</a> )	:EXternal:BWLimit? (see <a href="#">page 444</a> )	<bwlimit> ::= {0   OFF}
:EXternal:PROBe <attenuation> (see <a href="#">page 445</a> )	:EXternal:PROBe? (see <a href="#">page 445</a> )	<attenuation> ::= probe attenuation ratio in NR3 format
:EXternal:RANGE <range>[<suffix>] (see <a href="#">page 446</a> )	:EXternal:RANGE? (see <a href="#">page 446</a> )	<range> ::= vertical full-scale range value in NR3 format <suffix> ::= {V   mV}
:EXternal:UNITS <units> (see <a href="#">page 447</a> )	:EXternal:UNITS? (see <a href="#">page 447</a> )	<units> ::= {VOLT   AMPere}

**Introduction to :EXternal Trigger Commands** The EXternal trigger subsystem commands control the input characteristics of the external trigger input. The probe factor, impedance, input range, input protection state, units, and bandwidth limit settings may all be queried. Depending on the instrument type, some settings may be changeable.

## Reporting the Setup

Use :EXternal? to query setup information for the EXternal subsystem.

## Return Format

The following is a sample response from the :EXternal query. In this case, the query was issued following a \*RST command.

```
:EXT:BWL 0;RANG +8.0E+00;UNIT VOLT;PROB +1.000E+00
```

## :EXTernal:BWLimits

 (see [page 1666](#))

**Command Syntax**    `:EXTernal:BWLimits <bwlimits>`

`<bwlimits> ::= {0 | OFF}`

The :EXTernal:BWLimits command is provided for product compatibility. The only legal value is 0 or OFF. Use the :TRIGger:HFReject command to limit bandwidth on the external trigger input.

**Query Syntax**    `:EXTernal:BWLimits?`

The :EXTernal:BWLimits? query returns the current setting of the low-pass filter (always 0).

**Return Format**    `<bwlimits><NL>`

`<bwlimits> ::= 0`

**See Also**

- ["Introduction to :EXTernal Trigger Commands"](#) on page 443
- ["Introduction to :TRIGger Commands"](#) on page 1349
- [":TRIGger:HFReject"](#) on page 1354

## :EXTernal:PROBe

 (see [page 1666](#))

Command Syntax	<code>:EXTernal:PROBe &lt;attenuation&gt;</code>
	<code>&lt;attenuation&gt; ::= probe attenuation ratio in NR3 format</code>
	The :EXTernal:PROBe command specifies the probe attenuation factor for the external trigger. The probe attenuation factor may be 0.1 to 1000. This command does not change the actual input sensitivity of the oscilloscope. It changes the reference constants for scaling the display factors and for setting trigger levels.
	If an AutoProbe probe is connected to the oscilloscope, the attenuation value cannot be changed from the sensed value. Attempting to set the oscilloscope to an attenuation value other than the sensed value produces an error.
Query Syntax	<code>:EXTernal:PROBe?</code>
	The :EXTernal:PROBe? query returns the current probe attenuation factor for the external trigger.
Return Format	<code>&lt;attenuation&gt;&lt;NL&gt;</code>
	<code>&lt;attenuation&gt; ::= probe attenuation ratio in NR3 format</code>
See Also	<ul style="list-style-type: none"> <li>· "<a href="#">Introduction to :EXTernal Trigger Commands</a>" on page 443</li> <li>· "<a href="#">:EXTernal:RANGE</a>" on page 446</li> <li>· "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>· "<a href="#">:CHANnel&lt;n&gt;:PROBe</a>" on page 352</li> </ul>

## :EXTernal:RANGE

**C** (see [page 1666](#))

<b>Command Syntax</b>	<code>:EXTernal:RANGE &lt;range&gt;[&lt;suffix&gt;]</code>
	<code>&lt;range&gt; ::= vertical full-scale range value in NR3 format</code>
	<code>&lt;suffix&gt; ::= {V   mV}</code>
	The :EXTernal:RANGE command is provided for product compatibility. When using 1:1 probe attenuation, the range can only be set to 8.0 V.
	If the probe attenuation is changed, the range value is multiplied by the probe attenuation factor.
<b>Query Syntax</b>	<code>:EXTernal:RANGE?</code>
	The :EXTernal:RANGE? query returns the current full-scale range setting for the external trigger.
<b>Return Format</b>	<code>&lt;range_argument&gt;&lt;NL&gt;</code>
	<code>&lt;range_argument&gt; ::= external trigger range value in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"><li>· "<a href="#">Introduction to :EXTernal Trigger Commands</a>" on page 443</li><li>· "<a href="#">":EXTernal:PROBe</a>" on page 445</li><li>· "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li></ul>

## :EXExternal:UNITS

**N** (see [page 1666](#))

**Command Syntax** :EXExternal:UNITS <units>

<units> ::= {VOLT | AMPere}

The :EXExternal:UNITS command sets the measurement units for the probe connected to the external trigger input. Select VOLT for a voltage probe and select AMPere for a current probe. Measurement results, channel sensitivity, and trigger level will reflect the measurement units you select.

**Query Syntax** :EXExternal:UNITS?

The :CHANnel<n>:UNITS? query returns the current units setting for the external trigger.

**Return Format** <units><NL>

<units> ::= {VOLT | AMP}

- See Also**
- "[Introduction to :EXExternal Trigger Commands](#)" on page 443
  - "[Introduction to :TRIGger Commands](#)" on page 1349
  - "[:EXExternal:RANGE](#)" on page 446
  - "[:EXExternal:PROBe](#)" on page 445
  - "[:CHANnel<n>:UNITS](#)" on page 369



# 19 :FFT Commands

Control the FFT function in the oscilloscope. See "[Introduction to :FFT Commands](#)" on page 450.

**Table 108** :FFT Commands Summary

Command	Query	Options and Query Returns
:FFT:AVERage:COUNT <count> (see <a href="#">page 451</a> )	:FFT:AVERage:COUNT? (see <a href="#">page 451</a> )	<count> ::= an integer from 2 to 65536 in NR1 format.
:FFT:CENTER <frequency> (see <a href="#">page 452</a> )	:FFT:CENTER? (see <a href="#">page 452</a> )	<frequency> ::= the current center frequency in NR3 format. The range of legal values is from -25 GHz to 25 GHz.
:FFT:CLEar (see <a href="#">page 453</a> )	n/a	n/a
:FFT:DISPLAY {{0   OFF}   {1   ON}} (see <a href="#">page 454</a> )	:FFT:DISPLAY? (see <a href="#">page 454</a> )	<s> ::= 1-6, in NR1 format. {0   1}
:FFT:DMDMode <display_mode> (see <a href="#">page 455</a> )	:FFT:DMDMode? (see <a href="#">page 455</a> )	<display_mode> ::= {NORMal   AVERage   MAXHold   MINHold}
:FFT:FREQuency:STARt <frequency> (see <a href="#">page 457</a> )	:FFT:FREQuency:STARt? (see <a href="#">page 457</a> )	<frequency> ::= the start frequency in NR3 format.
:FFT:FREQuency:STOP <frequency> (see <a href="#">page 458</a> )	:FFT:FREQuency:STOP? (see <a href="#">page 458</a> )	<frequency> ::= the stop frequency in NR3 format.
:FFT:GATE <gating> (see <a href="#">page 459</a> )	:FFT:GATE? (see <a href="#">page 459</a> )	<gating> ::= {NONE   ZOOM}
:FFT:OFFSet <offset> (see <a href="#">page 460</a> )	:FFT:OFFSet? (see <a href="#">page 460</a> )	<offset> ::= the value at center screen in NR3 format.
:FFT:RANGE <range> (see <a href="#">page 461</a> )	:FFT:RANGE? (see <a href="#">page 461</a> )	<range> ::= the full-scale vertical axis value in NR3 format.

**Table 108** :FFT Commands Summary (continued)

Command	Query	Options and Query Returns
:FFT:REFerence <level> (see <a href="#">page 462</a> )	:FFT:REFerence? (see <a href="#">page 462</a> )	<level> ::= the current reference level in NR3 format.
:FFT:SCALe <scale value>[<suffix>] (see <a href="#">page 463</a> )	:FFT:SCALe? (see <a href="#">page 463</a> )	<scale_value> ::= integer in NR1 format. <suffix> ::= dB
:FFT:SOURce1 <source> (see <a href="#">page 464</a> )	:FFT:SOURce1? (see <a href="#">page 464</a> )	<source> ::= {CHANnel<n>   FUNCTION<c>   MATH<c>} <n> ::= 1 to (# analog channels) in NR1 format. <c> ::= {1   2}
:FFT:SPAN <span> (see <a href="#">page 465</a> )	:FFT:SPAN? (see <a href="#">page 465</a> )	<span> ::= the current frequency span in NR3 format. Legal values are 1 Hz to 100 GHz.
:FFT:VTYPe <units> (see <a href="#">page 466</a> )	:FFT:VTYPe? (see <a href="#">page 466</a> )	<units> ::= {DECibel   VRMS}
:FFT:WINDOW <window> (see <a href="#">page 467</a> )	:FFT:WINDOW? (see <a href="#">page 467</a> )	<window> ::= {RECTangular   HANNing   FLATtop   BHARris   BARTlett}

## Introduction to :FFT Commands

The FFT subsystem controls the FFT function in the oscilloscope.

### Reporting the Setup

Use :FFT? to query setup information for the FFT subsystem.

### Return Format

The following is a sample response from the :FFT? query. In this case, the query was issued following a \*RST command.

```
:FFT:DISP 0;SOUR1 CHAN1;RANG +160E+00;OFFS -60.0000E+00;SPAN
+100.0000E+03;CENT +50.000000E+03;WIND HANN;VTYP DEC;DMODE
NORM;AVER:COUN 8
```

## :FFT:AVERage:COUNt

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:FFT:AVERage:COUNt &lt;count&gt;</code>
	<code>&lt;count&gt;</code> ::= an integer from 2 to 65536 in NR1 format.
	The :FFT:AVERage:COUNt command sets the number of waveforms to be averaged together.
	The number of averages can be set from 2 to 65536 in increments of powers of 2.
	Increasing the number of averages will increase resolution and reduce noise.
<b>Query Syntax</b>	<code>:FFT:AVERage:COUNt?</code>
	The :FFT:AVERage:COUNt? query returns the number of waveforms to be averaged together.
<b>Return Format</b>	<code>&lt;count&gt;&lt;NL&gt;</code>
	<code>&lt;count&gt;</code> ::= an integer from 2 to 65536 in NR1 format.
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":FFT:CENTer" on page 452</a></li> <li>· <a href="#">":FFT:CLEar" on page 453</a></li> <li>· <a href="#">":FFT:DISPlay" on page 454</a></li> <li>· <a href="#">":FFT:DMDe" on page 455</a></li> <li>· <a href="#">":FFT:OFFSet" on page 460</a></li> <li>· <a href="#">":FFT:RANGE" on page 461</a></li> <li>· <a href="#">":FFT:REFERENCE" on page 462</a></li> <li>· <a href="#">":FFT:SCALE" on page 463</a></li> <li>· <a href="#">":FFT:SOURce1" on page 464</a></li> <li>· <a href="#">":FFT:SPAN" on page 465</a></li> <li>· <a href="#">":FFT:FREQuency:START" on page 457</a></li> <li>· <a href="#">":FFT:FREQuency:STOP" on page 458</a></li> <li>· <a href="#">":FFT:VTPe" on page 466</a></li> <li>· <a href="#">":FFT:WINDow" on page 467</a></li> </ul>

## :FFT:CENTer

**N** (see [page 1666](#))

**Command Syntax**    `:FFT:CENTer <frequency>`  
`<frequency> ::= the current center frequency in NR3 format. The range  
of legal values is from -25 GHz to 25 GHz.`

The :FFT:CENTer command sets the center frequency when FFT (Fast Fourier Transform) is selected.

**Query Syntax**    `:FFT:CENTer?`  
The :FFT:CENTer? query returns the current center frequency in Hertz.  
**Return Format**    `<frequency><NL>`  
`<frequency> ::= the current center frequency in NR3 format. The range  
of legal values is from -25 GHz to 25 GHz.`

**NOTE** After a \*RST (Reset) or :AUToscale command, the values returned by the :FFT:CENTer? and :FFT:SPAN? queries depend on the current :TIMEbase:RANGE value. Once you change either the :FFT:CENTer or :FFT:SPAN value, they no longer track the :TIMEbase:RANGE value.

- See Also**
- [":FFT:AVERage:COUNT"](#) on page 451
  - [":FFT:CENTER"](#) on page 452
  - [":FFT:DISPLAY"](#) on page 454
  - [":FFT:DMODE"](#) on page 455
  - [":FFT:OFFSet"](#) on page 460
  - [":FFT:RANGE"](#) on page 461
  - [":FFT:REFERENCE"](#) on page 462
  - [":FFT:SCALe"](#) on page 463
  - [":FFT:SOURce1"](#) on page 464
  - [":FFT:SPAN"](#) on page 465
  - [":FFT:FREQuency:STARt"](#) on page 457
  - [":FFT:FREQuency:STOP"](#) on page 458
  - [":FFT:VTPe"](#) on page 466
  - [":FFT:WINDOW"](#) on page 467

## :FFT:CLEar

**N** (see [page 1666](#))

**Command Syntax** :FFT:CLEar

When the FFT display mode is AVERage, MAXHold, or MINHold, the :FFT:CLEar command clears the number of evaluated waveforms.

- See Also**
- [":FFT:AVERage:COUNt"](#) on page 451
  - [":FFT:CENTer"](#) on page 452
  - [":FFT:DISPlay"](#) on page 454
  - [":FFT:DModE"](#) on page 455
  - [":FFT:OFFSet"](#) on page 460
  - [":FFT:RANGe"](#) on page 461
  - [":FFT:REFerence"](#) on page 462
  - [":FFT:SCALe"](#) on page 463
  - [":FFT:SOURce1"](#) on page 464
  - [":FFT:SPAN"](#) on page 465
  - [":FFT:FREQuency:START"](#) on page 457
  - [":FFT:FREQuency:STOP"](#) on page 458
  - [":FFT:VTPe"](#) on page 466
  - [":FFT:WINDow"](#) on page 467

## :FFT:DISPlay

**N** (see [page 1666](#))

**Command Syntax**    `:FFT:DISPLAY {{0 | OFF} | {1 | ON}}`

The :FFT:DISPLAY command turns the display of the FFT function on or off.

When ON is selected, the FFT function is calculated and displayed.

When OFF is selected, the FFT function is neither calculated nor displayed.

**Query Syntax**    `:FFT:DISPLAY?`

The :FFT:DISPLAY? query returns whether the function display is on or off.

**Return Format**    `<display><NL>`

`<display> ::= {0 | 1}`

**See Also**

- [":FFT:AVERage:COUNT"](#) on page 451

- [":FFT:CENTER"](#) on page 452

- [":FFT:CLEar"](#) on page 453

- [":FFT:DMODE"](#) on page 455

- [":FFT:OFFSet"](#) on page 460

- [":FFT:RANGE"](#) on page 461

- [":FFT:REFerence"](#) on page 462

- [":FFT:SCALe"](#) on page 463

- [":FFT:SOURce1"](#) on page 464

- [":FFT:SPAN"](#) on page 465

- [":FFT:FREQuency:STARt"](#) on page 457

- [":FFT:FREQuency:STOP"](#) on page 458

- [":FFT:VTPe"](#) on page 466

- [":FFT:WINDOW"](#) on page 467

## :FFT:DMODE

**N** (see [page 1666](#))

<b>Command Syntax</b>	: <b>FFT:DMODE &lt;display_mode&gt;</b>  <b>&lt;display_mode&gt;</b> ::= {NORMal   AVERage   MAXHold   MINHold}
The :FFT:DMODE command selects one of the FFT waveform display modes:	
	<ul style="list-style-type: none"> <li>• NORMal – this is the FFT waveform without any averaging or hold functions applied. This is how FFT math function waveforms are displayed.</li> <li>• AVERage – the FFT waveform is averaged the selected number of times. Averages are calculated using a "decaying average" approximation, where:</li> </ul>
	$\text{next\_average} = \text{current\_average} + (\text{new\_data} - \text{current\_average})/N$
	<p>Where N starts at 1 for the first acquisition and increments for each following acquisition until it reaches the selected number of averages, where it holds.</p>
	<ul style="list-style-type: none"> <li>• MAXHold – records the maximum vertical values found at each horizontal bucket across multiple analysis cycles and uses those values to build a waveform. This display mode is often referred to as Max Envelope.</li> <li>• MINHold – records the minimum vertical values found at each horizontal bucket across multiple analysis cycles and uses those values to build a waveform. This display mode is often referred to as Min Envelope.</li> </ul>
<b>Query Syntax</b>	: <b>FFT:DMODE?</b>
	<p>The :FFT:DMODE? query returns the currently set FFT display mode.</p>
<b>Return Format</b>	<b>&lt;display_mode&gt;&lt;NL&gt;</b> <b>&lt;display_mode&gt;</b> ::= {NORM   AVER   MAXH   MINH}
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">:FFT:AVERage:COUNT</a>" on page 451</li> <li>• "<a href="#">:FFT:CENTER</a>" on page 452</li> <li>• "<a href="#">:FFT:CLEar</a>" on page 453</li> <li>• "<a href="#">:FFT:DISPlay</a>" on page 454</li> <li>• "<a href="#">:FFT:OFFSet</a>" on page 460</li> <li>• "<a href="#">:FFT:RANGE</a>" on page 461</li> <li>• "<a href="#">:FFT:REFERENCE</a>" on page 462</li> <li>• "<a href="#">:FFT:SCALE</a>" on page 463</li> <li>• "<a href="#">:FFT:SOURce1</a>" on page 464</li> <li>• "<a href="#">:FFT:SPAN</a>" on page 465</li> <li>• "<a href="#">:FFT:FREQuency:START</a>" on page 457</li> <li>• "<a href="#">:FFT:FREQuency:STOP</a>" on page 458</li> </ul>

- [":FFT:VTPe"](#) on page 466
- [":FFT:WINDOW"](#) on page 467

## :FFT:FREQuency:STARt

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:FFT:FREQuency:STARt &lt;frequency&gt;</code> <code>&lt;frequency&gt; ::= the start frequency in NR3 format.</code>
	The :FFT:FREQuency:STARt command sets the start frequency in the FFT (Fast Fourier Transform) math function's displayed range.
	The FFT (Fast Fourier Transform) math function's displayed range can also be set with the :FFT:CENTER and :FFT:SPAN commands.
<b>Query Syntax</b>	<code>:FFT:FREQuency:STARt?</code>
	The :FFT:FREQuency:STARt? query returns the current start frequency in Hertz.
<b>Return Format</b>	<code>&lt;frequency&gt;&lt;NL&gt;</code> <code>&lt;frequency&gt; ::= the start frequency in NR3 format.</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":FFT:AVERage:COUNT"</a> on page 451</li> <li>· <a href="#">":FFT:CENTER"</a> on page 452</li> <li>· <a href="#">":FFT:CLEar"</a> on page 453</li> <li>· <a href="#">":FFT:DISPlay"</a> on page 454</li> <li>· <a href="#">":FFT:DMODE"</a> on page 455</li> <li>· <a href="#">":FFT:OFFSet"</a> on page 460</li> <li>· <a href="#">":FFT:RANGE"</a> on page 461</li> <li>· <a href="#">":FFT:REFerence"</a> on page 462</li> <li>· <a href="#">":FFT:SCALe"</a> on page 463</li> <li>· <a href="#">":FFT:SOURce1"</a> on page 464</li> <li>· <a href="#">":FFT:SPAN"</a> on page 465</li> <li>· <a href="#">":FFT:FREQuency:STOP"</a> on page 458</li> <li>· <a href="#">":FFT:VTPe"</a> on page 466</li> <li>· <a href="#">":FFT:WINDOW"</a> on page 467</li> </ul>

## :FFT:FREQuency:STOP

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:FFT:FREQuency:STOP &lt;frequency&gt;</code> <code>&lt;frequency&gt; ::= the stop frequency in NR3 format.</code>
	The :FFT:FREQuency:STOP command sets the stop frequency in the FFT (Fast Fourier Transform) math function's displayed range.
	The FFT (Fast Fourier Transform) math function's displayed range can also be set with the :FFT:CENTER and :FFT:SPAN commands.
<b>Query Syntax</b>	<code>:FFT:FREQuency:STOP?</code>
	The :FFT:FREQuency:STOP? query returns the current stop frequency in Hertz.
<b>Return Format</b>	<code>&lt;frequency&gt;&lt;NL&gt;</code> <code>&lt;frequency&gt; ::= the stop frequency in NR3 format.</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:FFT:AVERage:COUNT</a>" on page 451</li> <li>· "<a href="#">:FFT:CENTER</a>" on page 452</li> <li>· "<a href="#">:FFT:CLEar</a>" on page 453</li> <li>· "<a href="#">:FFT:DISPlay</a>" on page 454</li> <li>· "<a href="#">:FFT:DMode</a>" on page 455</li> <li>· "<a href="#">:FFT:OFFSet</a>" on page 460</li> <li>· "<a href="#">:FFT:RANGE</a>" on page 461</li> <li>· "<a href="#">:FFT:REFERENCE</a>" on page 462</li> <li>· "<a href="#">:FFT:SCALE</a>" on page 463</li> <li>· "<a href="#">:FFT:SOURce1</a>" on page 464</li> <li>· "<a href="#">:FFT:SPAN</a>" on page 465</li> <li>· "<a href="#">:FFT:FREQuency:STARt</a>" on page 457</li> <li>· "<a href="#">:FFT:VTPe</a>" on page 466</li> <li>· "<a href="#">:FFT:WINDOW</a>" on page 467</li> </ul>

## :FFT:GATE

**N** (see [page 1666](#))

**Command Syntax**    `:FFT:GATE <gating>`  
`<gating> ::= {NONE | ZOOM}`

The :FFT:GATE command specifies whether the FFT is performed on the Main time base window (NONE) or the ZOOM window when the zoomed time base is displayed.

**Query Syntax**    `:FFT:GATE?`  
The :FFT:GATE? query returns the gate setting.

**Return Format**    `<gating><NL>`  
`<gating> ::= {NONE | ZOOM}`

**See Also**

- "[:FFT:VTPe](#)" on page 466
- "[:FFT:WINDOW](#)" on page 467
- "[Introduction to FFT Commands](#)" on page 450

## :FFT:OFFSet

**N** (see [page 1666](#))

**Command Syntax**    `:FFT:OFFSet <offset>`

`<offset>` ::= the value at center screen in NR3 format.

The :FFT:OFFSet command specifies the FFT vertical value represented at center screen.

If you set the offset to a value outside of the legal range, the offset value is automatically set to the nearest legal value.

### NOTE

The :FFT:OFFSet command is equivalent to the :FFT:REFerence command.

**Query Syntax**    `:FFT:OFFSet?`

The :FFT:OFFSet? query returns the current offset value for the FFT function.

**Return Format**    `<offset><NL>`

`<offset>` ::= the value at center screen in NR3 format.

- See Also**
- "[:FFT:AVERage:COUNT](#)" on page 451
  - "[:FFT:CENTER](#)" on page 452
  - "[:FFT:CLEar](#)" on page 453
  - "[:FFT:DISPlay](#)" on page 454
  - "[:FFT:DMODE](#)" on page 455
  - "[:FFT:RANGe](#)" on page 461
  - "[:FFT:REFerence](#)" on page 462
  - "[:FFT:SCALe](#)" on page 463
  - "[:FFT:SOURce1](#)" on page 464
  - "[:FFT:SPAN](#)" on page 465
  - "[:FFT:FREQuency:START](#)" on page 457
  - "[:FFT:FREQuency:STOP](#)" on page 458
  - "[:FFT:VTPe](#)" on page 466
  - "[:FFT:WINDOW](#)" on page 467

## :FFT:RANGE

**N** (see [page 1666](#))

**Command Syntax**    `:FFT:RANGE <range>`  
`<range> ::= the full-scale vertical axis value in NR3 format.`

The :FFT:RANGE command defines the full-scale vertical axis for the FFT function.

**Query Syntax**    `:FFT:RANGE?`  
The :FFT:RANGE? query returns the current full-scale range value for the FFT function.

**Return Format**    `<range><NL>`  
`<range> ::= the full-scale vertical axis value in NR3 format.`

**See Also**

- [":FFT:AVERage:COUNT"](#) on page 451
- [":FFT:CENTer"](#) on page 452
- [":FFT:CLEar"](#) on page 453
- [":FFT:DISPlay"](#) on page 454
- [":FFT:DModE"](#) on page 455
- [":FFT:OFFSet"](#) on page 460
- [":FFT:REFerence"](#) on page 462
- [":FFT:SCALe"](#) on page 463
- [":FFT:SOURce1"](#) on page 464
- [":FFT:SPAN"](#) on page 465
- [":FFT:FREQuency:STARt"](#) on page 457
- [":FFT:FREQuency:STOP"](#) on page 458
- [":FFT:VTPe"](#) on page 466
- [":FFT:WINDOW"](#) on page 467

## :FFT:REFerence

**N** (see [page 1666](#))

**Command Syntax**    `:FFT:REFerence <level>`

`<level>` ::= the current reference level in NR3 format.

The :FFT:REFerence command specifies the FFT vertical value represented at center screen.

If you set the reference level to a value outside of the legal range, the level is automatically set to the nearest legal value.

### NOTE

The :FFT:REFerence command is equivalent to the :FFT:OFFSet command.

**Query Syntax**    `:FFT:REFerence?`

The :FFT:REFerence? query returns the current reference level value for the FFT function.

**Return Format**    `<level><NL>`

`<level>` ::= the current reference level in NR3 format.

**See Also**

- [":FFT:AVERage:COUNt"](#) on page 451
- [":FFT:CENTER"](#) on page 452
- [":FFT:CLEar"](#) on page 453
- [":FFT:DISPlay"](#) on page 454
- [":FFT:DMDe"](#) on page 455
- [":FFT:OFFSet"](#) on page 460
- [":FFT:RANGe"](#) on page 461
- [":FFT:SCALe"](#) on page 463
- [":FFT:SOURce1"](#) on page 464
- [":FFT:SPAN"](#) on page 465
- [":FFT:FREQuency:STARt"](#) on page 457
- [":FFT:FREQuency:STOP"](#) on page 458
- [":FFT:VTPe"](#) on page 466
- [":FFT:WINDOW"](#) on page 467

## :FFT:SCALe

**N** (see [page 1666](#))

Command Syntax	<code>:FFT:SCALe &lt;scale_value&gt;[&lt;suffix&gt;]</code>
	<code>&lt;scale_value&gt;</code> ::= floating-point value in NR3 format.
	<code>&lt;suffix&gt;</code> ::= dB
	The :FFT:SCALe command sets the vertical scale, or units per division, of the FFT function. Legal values for the scale depend on the selected function.
Query Syntax	<code>:FFT:SCALe?</code>
	The :FFT:SCALe? query returns the current scale value for the FFT function.
Return Format	<code>&lt;scale_value&gt;&lt;NL&gt;</code> <code>&lt;scale_value&gt;</code> ::= floating-point value in NR3 format.
See Also	<ul style="list-style-type: none"> <li>· "<a href="#">:FFT:AVERage:COUNT</a>" on page 451</li> <li>· "<a href="#">:FFT:CENTer</a>" on page 452</li> <li>· "<a href="#">:FFT:CLEar</a>" on page 453</li> <li>· "<a href="#">:FFT:DISPlay</a>" on page 454</li> <li>· "<a href="#">:FFT:DMDMode</a>" on page 455</li> <li>· "<a href="#">:FFT:OFFSet</a>" on page 460</li> <li>· "<a href="#">:FFT:RANGE</a>" on page 461</li> <li>· "<a href="#">:FFT:REFerence</a>" on page 462</li> <li>· "<a href="#">:FFT:SOURce1</a>" on page 464</li> <li>· "<a href="#">:FFT:SPAN</a>" on page 465</li> <li>· "<a href="#">:FFT:FREQuency:STARt</a>" on page 457</li> <li>· "<a href="#">:FFT:FREQuency:STOP</a>" on page 458</li> <li>· "<a href="#">:FFT:VTYPe</a>" on page 466</li> <li>· "<a href="#">:FFT:WINDOW</a>" on page 467</li> </ul>

## :FFT:SOURce1

**N** (see [page 1666](#))

**Command Syntax**    `:FFT:SOURce1 <offset>`

```
<source> ::= {CHANnel<n> | FUNCTion<c> | MATH<c>}
<n> ::= 1 to (# analog channels) in NR1 format.
<c> ::= {1 | 2}
```

The :FFT:SOURce1 command selects the source for the FFT function.

**NOTE**

Another shorthand notation for SOURce1 in this command/query (besides SOUR1) is SOUR.

**Query Syntax**    `:FFT:SOURce1?`

The :FFT:SOURce1? query returns the current source1 for the FFT function.

**Return Format**    `<source><NL>`

```
<source> ::= {CHANnel<n> | FUNCTion<c> | MATH<c>}
<n> ::= 1 to (# analog channels) in NR1 format.
<c> ::= {1 | 2}
```

**See Also**

- "[:FFT:AVERage:COUNT](#)" on page 451
- "[:FFT:CENTer](#)" on page 452
- "[:FFT:CLEar](#)" on page 453
- "[:FFT:DISPlay](#)" on page 454
- "[:FFT:DMDe](#)" on page 455
- "[:FFT:OFFSet](#)" on page 460
- "[:FFT:RANGe](#)" on page 461
- "[:FFT:REFERENCE](#)" on page 462
- "[:FFT:SCALE](#)" on page 463
- "[:FFT:SPAN](#)" on page 465
- "[:FFT:FREQuency:STARt](#)" on page 457
- "[:FFT:FREQuency:STOP](#)" on page 458
- "[:FFT:VTPe](#)" on page 466
- "[:FFT:WINDOW](#)" on page 467

## :FFT:SPAN

**N** (see [page 1666](#))

**Command Syntax**    `:FFT:SPAN <span>`  
`<span> ::= the current frequency span in NR3 format. Legal values are 1 Hz to 100 GHz.`

If you set the frequency span to a value outside of the legal range, the step size is automatically set to the nearest legal value.

The :FFT:SPAN command sets the frequency span of the display (left graticule to right graticule) when FFT (Fast Fourier Transform) is selected.

**Query Syntax**    `:FFT:SPAN?`  
The :FFT:SPAN? query returns the current frequency span in Hertz.

**NOTE** After a \*RST (Reset) or :AUToscale command, the values returned by the :FFT:CENTER? and :FFT:SPAN? queries depend on the current :TIMEbase:RANGE value. Once you change either the :FFT:CENTER or :FFT:SPAN value, they no longer track the :TIMEbase:RANGE value.

---

**Return Format**    `<span><NL>`  
`<span> ::= the current frequency span in NR3 format. Legal values are 1 Hz to 100 GHz.`

**See Also**

- [":FFT:AVERage:COUNT"](#) on page 451
- [":FFT:CENTER"](#) on page 452
- [":FFT:CLEar"](#) on page 453
- [":FFT:DISPlay"](#) on page 454
- [":FFT:DMODE"](#) on page 455
- [":FFT:OFFSet"](#) on page 460
- [":FFT:RANGE"](#) on page 461
- [":FFT:REFERENCE"](#) on page 462
- [":FFT:SCALe"](#) on page 463
- [":FFT:SOURce1"](#) on page 464
- [":FFT:FREQuency:STARt"](#) on page 457
- [":FFT:FREQuency:STOP"](#) on page 458
- [":FFT:VTPe"](#) on page 466
- [":FFT:WINDOW"](#) on page 467

**:FFT:VTYPe****N** (see [page 1666](#))**Command Syntax**    `:FFT:VTYPe <units>``<units> ::= {DECibel | VRMS}`

The :FFT:VTYPe command specifies FFT vertical units as DECibel or VRMS.

**Query Syntax**    `:FFT:VTYPe?`

The :FFT:VTYPe? query returns the current FFT vertical units.

**Return Format**    `<units><NL>``<units> ::= {DEC | VRMS}`

- See Also**
- [":FFT:AVERage:COUNt" on page 451](#)
  - [":FFT:CENTer" on page 452](#)
  - [":FFT:CLEar" on page 453](#)
  - [":FFT:DISPlay" on page 454](#)
  - [":FFT:DMODE" on page 455](#)
  - [":FFT:OFFSet" on page 460](#)
  - [":FFT:RANGE" on page 461](#)
  - [":FFT:REFERENCE" on page 462](#)
  - [":FFT:SCALe" on page 463](#)
  - [":FFT:SOURce1" on page 464](#)
  - [":FFT:SPAN" on page 465](#)
  - [":FFT:FREQuency:STARt" on page 457](#)
  - [":FFT:FREQuency:STOP" on page 458](#)
  - [":FFT:WINDow" on page 467](#)

## :FFT:WINDOW

**N** (see [page 1666](#))

**Command Syntax**

```
:FFT:WINDOW <window>
<window> ::= {RECTangular | HANNing | FLATtop | BHARris | BARTlett}
```

The :FFT:WINDOW command allows the selection of different windowing transforms or operations for the FFT (Fast Fourier Transform) function.

The FFT operation assumes that the time record repeats. Unless an integral number of sampled waveform cycles exist in the record, a discontinuity is created between the end of one record and the beginning of the next. This discontinuity introduces additional frequency components about the peaks into the spectrum. This is referred to as leakage. To minimize leakage, windows that approach zero smoothly at the start and end of the record are employed as filters to the FFTs. Each window is useful for certain classes of input signals.

- RECTangular – useful for transient signals, and signals where there are an integral number of cycles in the time record.
- HANNing – useful for frequency resolution and general purpose use. It is good for resolving two frequencies that are close together, or for making frequency measurements. This is the default window.
- FLATtop – best for making accurate amplitude measurements of frequency peaks.
- BHARris (Blackman-Harris) – reduces time resolution compared to the rectangular window, but it improves the capacity to detect smaller impulses due to lower secondary lobes (provides minimal spectral leakage).
- BARTlett – (triangular, with end points at zero) window is similar to the Hanning window in that it is good for making accurate frequency measurements, but its higher and wider secondary lobes make it not quite as good for resolving frequencies that are close together.

**Query Syntax**

```
:FFT:WINDOW?
```

The :FFT:WINDOW? query returns the value of the window selected for the FFT function.

**Return Format**

```
<window><NL>
<window> ::= {RECT | HANN | FLAT | BHAR | BART}
```

**See Also**

- "[:FFT:AVERage:COUNT](#)" on page 451
- "[:FFT:CENTER](#)" on page 452
- "[:FFT:CLEar](#)" on page 453
- "[:FFT:DISPLAY](#)" on page 454
- "[:FFT:DMDe](#)" on page 455

- [":FFT:OFFSet" on page 460](#)
- [":FFT:RANGE" on page 461](#)
- [":FFT:REFerence" on page 462](#)
- [":FFT:SCALe" on page 463](#)
- [":FFT:SOURce1" on page 464](#)
- [":FFT:SPAN" on page 465](#)
- [":FFT:FREQuency:START" on page 457](#)
- [":FFT:FREQuency:STOP" on page 458](#)
- [":FFT:VTPe" on page 466](#)

## 20 :FRANalysis Commands

Control oscilloscope functions associated with the Frequency Response Analysis (FRA) feature, which is available in oscilloscope models that have a license-enabled built-in waveform generator. See "[Introduction to :FRANalysis Commands](#)" on page 470.

**Table 109** :FRANalysis Commands Summary

Command	Query	Options and Query Returns
n/a	:FRANalysis:DATA? [SWEep   SINGle] (see <a href="#">page 471</a> )	<binary_block> ::= comma-separated data with newlines at the end of each row
:FRANalysis:ENABLE { {0   OFF}   {1   ON} } (see <a href="#">page 472</a> )	:FRANalysis:ENABLE? (see <a href="#">page 472</a> )	{0   1}
:FRANalysis:FREQuency :MODE <setting> (see <a href="#">page 473</a> )	:FRANalysis:FREQuency :MODE? (see <a href="#">page 473</a> )	<setting> ::= {SWEep   SINGLE}
:FRANalysis:FREQuency :SINGle <value>[suffix] (see <a href="#">page 474</a> )	:FRANalysis:FREQuency :SINGle? (see <a href="#">page 474</a> )	<value> ::= {20   100   1000   10000   100000   1000000   10000000   2000000} [suffix] ::= {Hz   kHz   MHz}
:FRANalysis:FREQuency :STARt <value>[suffix] (see <a href="#">page 475</a> )	:FRANalysis:FREQuency :STARt? (see <a href="#">page 475</a> )	<value> ::= {20   100   1000   10000   100000   1000000   10000000} [suffix] ::= {Hz   kHz   MHz}
:FRANalysis:FREQuency :STOP <value>[suffix] (see <a href="#">page 476</a> )	:FRANalysis:FREQuency :STOP? (see <a href="#">page 476</a> )	<value> ::= {100   1000   10000   100000   1000000   10000000   20000000} [suffix] ::= {Hz   kHz   MHz}
:FRANalysis:PPDecade <value> (see <a href="#">page 477</a> )	:FRANalysis:PPDecade? (see <a href="#">page 477</a> )	<value> ::= {10   20   30   40   50   60   70   80   90   100}
:FRANalysis:RUN (see <a href="#">page 478</a> )	n/a	n/a

**Table 109** :FRANalysis Commands Summary (continued)

Command	Query	Options and Query Returns
:FRANalysis:SOURce:IN Put <source> (see <a href="#">page 479</a> )	:FRANalysis:SOURce:IN Put? (see <a href="#">page 479</a> )	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:FRANalysis:SOURce:OU TPut <source> (see <a href="#">page 480</a> )	:FRANalysis:SOURce:OU TPut? (see <a href="#">page 480</a> )	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:FRANalysis:TRACe <selection> (see <a href="#">page 481</a> )	:FRANalysis:TRACe? (see <a href="#">page 481</a> )	<selection> ::= {NONE   ALL   GAIN   PHASE} [, {GAIN   PHASE}]
:FRANalysis:WGEN:LOAD <impedance> (see <a href="#">page 482</a> )	:FRANalysis:WGEN:LOAD ? (see <a href="#">page 482</a> )	<impedance> ::= {ONEMeg   FIFTy}
:FRANalysis:WGEN:VOLT age <amplitude>, [<range>] (see <a href="#">page 483</a> )	:FRANalysis:WGEN:VOLT age? [<range>] (see <a href="#">page 483</a> )	<amplitude> ::= amplitude in volts in NR3 format  <range> ::= {F20HZ   F100HZ   F1KHZ   F10KHZ   F100KHZ   F1MHZ   F10MHZ   F20MHZ}
:FRANalysis:WGEN:VOLT age:PROFile {{0   OFF}   {1   ON}} (see <a href="#">page 484</a> )	:FRANalysis:WGEN:VOLT age:PROFile? (see <a href="#">page 484</a> )	{0   1}

### Introduction to :FRANalysis Commands

The FRANalysis subsystem controls the Frequency Response Analysis feature in the oscilloscope.

The Frequency Response Analysis (FRA) feature controls the built-in waveform generator to sweep a sine wave across a range of frequencies while measuring the input to and output from a device under test (DUT). At each frequency, gain (A) and phase are measured and plotted on a frequency response chart.

### Reporting the Setup

Use :FRANalysis? to query setup information for the FRANalysis subsystem.

### Return Format

The following is a sample response from the :FRANalysis? query. In this case, the query was issued following a \*RST command.

```
:FRAN:SOUR:INP CHAN1;OUTP CHAN2;:FRAN:FREQ:STAR +100E+00;  
STOP +20.000000E+06;:FRAN:WGEN:VOLT +200.0E-03;LOAD FIFT
```

## :FRANalysis:DATA

**N** (see [page 1666](#))

**Query Syntax** :FRANalysis:DATA? [SWEep | SINGLE]

The :FRANalysis:DATA? query returns the frequency response analysis data.

The data is returned in four comma-separated columns of data for each step in the sweep: Frequency (Hz), Amplitude (Vpp), Gain (dB), and Phase (°).

You can use the :FRANalysis:TRACe command to specify whether to include gain, phase, both gain and phase, or neither in the frequency response analysis results.

The SWEep or SINGLE option specifies whether to get the data from a sweep or single-frequency analysis (see :FRANalysis:FREQuency:MODE). If this option is not specified, the data from the sweep analysis is returned by default.

**Return Format**

```
<binary_block><NL>
<binary_block> ::= comma-separated data with newlines at the end of each
row
```

**See Also**

- "[:FRANalysis:ENABLE](#)" on page 472
- "[:FRANalysis:FREQuency:MODE](#)" on page 473
- "[:FRANalysis:FREQuency:SINGLe](#)" on page 474
- "[:FRANalysis:FREQuency:STARt](#)" on page 475
- "[:FRANalysis:FREQuency:STOP](#)" on page 476
- "[:FRANalysis:RUN](#)" on page 478
- "[:FRANalysis:SOURce:INPut](#)" on page 479
- "[:FRANalysis:SOURce:OUTPut](#)" on page 480
- "[:FRANalysis:TRACe](#)" on page 481
- "[:FRANalysis:WGEN:LOAD](#)" on page 482
- "[:FRANalysis:WGEN:VOLTage](#)" on page 483

## :FRANalysis:ENABLE

**N** (see [page 1666](#))

**Command Syntax**    `:FRANalysis:ENABLE <setting>`  
`<setting> ::= {{0 | OFF} | {1 | ON}}`

The :FRANalysis:ENABLE command turns the Frequency Response Analysis (FRA) feature on or off.

**Query Syntax**    `:FRANalysis:ENABLE?`

The :FRANalysis:ENABLE? query returns a flag indicating whether the Frequency Response Analysis (FRA) feature is on or off.

**Return Format**    `<setting><NL>`  
`<setting> ::= {0 | 1}`

**See Also**

- [":FRANalysis:DATA"](#) on page 471
- [":FRANalysis:FREQuency:STARt"](#) on page 475
- [":FRANalysis:FREQuency:STOP"](#) on page 476
- [":FRANalysis:RUN"](#) on page 478
- [":FRANalysis:SOURce:INPut"](#) on page 479
- [":FRANalysis:SOURce:OUTPut"](#) on page 480
- [":FRANalysis:WGEN:LOAD"](#) on page 482
- [":FRANalysis:WGEN:VOLTage"](#) on page 483

## :FRANalysis:FREQuency:MODE

**N** (see [page 1666](#))

**Command Syntax**    `:FRANalysis:FREQuency:MODE <setting>`  
`<setting> ::= {SWEep | SINGLE}`

The :FRANalysis:FREQuency:MODE command lets you select between the normal swept frequency response analysis or analysis at a single frequency, which can be useful when debugging.

**Query Syntax**    `:FRANalysis:FREQuency:MODE?`

The :FRANalysis:FREQuency:MODE? query returns the frequency mode setting.

**Return Format**    `<setting><NL>`  
`<setting> ::= {SWEep | SINGLE}`

**See Also**

- [":FRANalysis:RUN"](#) on page 478
- [":FRANalysis:FREQuency:SINGle"](#) on page 474
- [":FRANalysis:FREQuency:STARt"](#) on page 475
- [":FRANalysis:FREQuency:STOP"](#) on page 476
- [":FRANalysis:PPDecade"](#) on page 477
- [":FRANalysis:WGEN:VOLTage:PROFile"](#) on page 484

## :FRANalysis:FREQuency:SINGle

**N** (see [page 1666](#))

**Command Syntax**    `:FRANalysis:FREQuency:SINGle <value>[suffix]`

```
<value> ::= {20 | 100 | 1000 | 10000 | 100000 | 1000000 | 10000000
             | 2000000}
```

```
[suffix] ::= {Hz | kHz | MHz}
```

The :FRANalysis:FREQuency:SINGle command sets the single frequency value. The frequency response analysis is displayed on a log scale Bode plot, so you can select from decade values in addition to the minimum frequency of 20 Hz.

**Query Syntax**    `:FRANalysis:FREQuency:SINGle?`

The :FRANalysis:FREQuency:SINGle? query returns the single frequency setting.

**Return Format**    `<value><NL>`

```
<value> ::= {20 | 100 | 1000 | 10000 | 100000 | 1000000 | 10000000
             | 2000000}
```

**See Also**

- "[:FRANalysis:DATA](#)" on page 471
- "[:FRANalysis:ENABLE](#)" on page 472
- "[:FRANalysis:PPDecade](#)" on page 477
- "[:FRANalysis:FREQuency:MODE](#)" on page 473
- "[:FRANalysis:RUN](#)" on page 478
- "[:FRANalysis:SOURce:INPUT](#)" on page 479
- "[:FRANalysis:SOURce:OUTPut](#)" on page 480
- "[:FRANalysis:WGEN:LOAD](#)" on page 482
- "[:FRANalysis:WGEN:VOLTage](#)" on page 483
- "[:FRANalysis:WGEN:VOLTage:PROFile](#)" on page 484

## :FRANalysis:FREQuency:STARt

**N** (see [page 1666](#))

**Command Syntax**

```
:FRANalysis:FREQuency:STARt <value>[suffix]
<value> ::= {20 | 100 | 1000 | 10000 | 100000 | 1000000 | 10000000}
[suffix] ::= {Hz | kHz | MHz}
```

The :FRANalysis:FREQuency:STARt command sets the frequency sweep start value. The frequency response analysis is displayed on a log scale Bode plot, so you can select from decade values in addition to the minimum frequency of 20 Hz.

**Query Syntax**

```
:FRANalysis:FREQuency:STARt?
```

The :FRANalysis:FREQuency:STARt? query returns the frequency sweep start setting.

**Return Format**

```
<value><NL>
<value> ::= {20 | 100 | 1000 | 10000 | 100000 | 1000000 | 10000000}
```

**See Also**

- [":FRANalysis:DATA"](#) on page 471
- [":FRANalysis:ENABLE"](#) on page 472
- [":FRANalysis:FREQuency:STOP"](#) on page 476
- [":FRANalysis:PPDecade"](#) on page 477
- [":FRANalysis:FREQuency:MODE"](#) on page 473
- [":FRANalysis:RUN"](#) on page 478
- [":FRANalysis:SOURce:INPut"](#) on page 479
- [":FRANalysis:SOURce:OUTPut"](#) on page 480
- [":FRANalysis:WGEN:LOAD"](#) on page 482
- [":FRANalysis:WGEN:VOLTage"](#) on page 483
- [":FRANalysis:WGEN:VOLTage:PROFile"](#) on page 484

## :FRANalysis:FREQuency:STOP

**N** (see [page 1666](#))

**Command Syntax**    `:FRANalysis:FREQuency:STOP <value>[suffix]`

`<value> ::= {100 | 1000 | 10000 | 100000 | 1000000 | 10000000 | 20000000}`

`[suffix] ::= {Hz | kHz | MHz}`

The :FRANalysis:FREQuency:STOP command sets the frequency sweep stop value. The frequency response analysis is displayed on a log scale Bode plot, so you can select from decade values in addition to the maximum frequency of 20 MHz.

**Query Syntax**    `:FRANalysis:FREQuency:STOP?`

The :FRANalysis:FREQuency:STOP? query returns the frequency sweep stop setting.

**Return Format**    `<value><NL>`

`<value> ::= {100 | 1000 | 10000 | 100000 | 1000000 | 10000000 | 20000000}`

**See Also**

- "[:FRANalysis:DATA](#)" on page 471
- "[:FRANalysis:ENABLE](#)" on page 472
- "[:FRANalysis:FREQuency:START](#)" on page 475
- "[:FRANalysis:PPDecade](#)" on page 477
- "[:FRANalysis:FREQuency:MODE](#)" on page 473
- "[:FRANalysis:RUN](#)" on page 478
- "[:FRANalysis:SOURce:INPut](#)" on page 479
- "[:FRANalysis:SOURce:OUTPut](#)" on page 480
- "[:FRANalysis:WGEN:LOAD](#)" on page 482
- "[:FRANalysis:WGEN:VOLTage](#)" on page 483
- "[:FRANalysis:WGEN:VOLTage:PROFile](#)" on page 484

## :FRANalysis:PPDecade

**N** (see [page 1666](#))

**Command Syntax** :FRANalysis:PPDecade <value>

<value> ::= {10 | 20 | 30 | 40 | 50 | 60 | 70 | 80 | 90 | 100}

The :FRANalysis:PPDecade command specifies the number of points per decade in the frequency response analysis.

**Query Syntax** :FRANalysis:PPDecade?

The :FRANalysis:PPDecade? query returns the points per decade setting.

**Return Format** <value><NL>

**See Also**

- "[:FRANalysis:FREQuency:START](#)" on page 475
- "[:FRANalysis:FREQuency:STOP](#)" on page 476
- "[:FRANalysis:WGEN:VOLTage:PROFile](#)" on page 484

## :FRANalysis:RUN

**N** (see [page 1666](#))

### Command Syntax

`:FRANalysis:RUN`

The `:FRANalysis:RUN` command performs the Frequency Response Analysis. This analysis controls the built-in waveform generator to sweep a sine wave across a range of frequencies while measuring the input to and output from a device under test (DUT). At each frequency, gain (A) and phase are measured and plotted on a Bode frequency response chart.

The `:FRANalysis:APPLy` command is a valid compatible alias for the `:FRANalysis:RUN` command.

When the frequency response analysis completes, you can use the `:FRANalysis:DATA?` query to get four comma-separated columns of data for each step in the sweep: Frequency (Hz), Amplitude (Vpp), Gain (dB), and Phase (°).

You can use the `:FRANalysis:TRACe` command to specify whether to include gain, phase, both gain and phase, or neither in the frequency response analysis results.

It takes some time for the frequency sweep analysis to complete. You can query bit 0 of the Standard Event Status Register (\*ESR?) to find out when the analysis is complete.

### See Also

- [":FRANalysis:DATA"](#) on page 471
- [":FRANalysis:ENABLE"](#) on page 472
- [":FRANalysis:FREQuency:MODE"](#) on page 473
- [":FRANalysis:FREQuency:SINGle"](#) on page 474
- [":FRANalysis:FREQuency:STARt"](#) on page 475
- [":FRANalysis:FREQuency:STOP"](#) on page 476
- [":FRANalysis:SOURce:INPut"](#) on page 479
- [":FRANalysis:SOURce:OUTPut"](#) on page 480
- [":FRANalysis:TRACe"](#) on page 481
- [":FRANalysis:WGEN:LOAD"](#) on page 482
- [":FRANalysis:WGEN:VOLTage"](#) on page 483
- ["\\*ESR \(Standard Event Status Register\)"](#) on page 236

## :FRANalysis:SOURce:INPut

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:FRANalysis:SOURce:INPut &lt;source&gt;</code>
	<code>&lt;source&gt; ::= CHANnel&lt;n&gt;</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	The :FRANalysis:SOURce:INPut command specifies the analog input channel that is probing the input voltage to the device under test (DUT) in the frequency response analysis.
<b>Query Syntax</b>	<code>:FRANalysis:SOURce:INPut?</code>
	The :FRANalysis:SOURce:INPut? query returns the currently selected channel probing the input voltage.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
	<code>&lt;source&gt; ::= CHAN&lt;n&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":FRANalysis:DATA"</a> on page 471</li> <li>· <a href="#">":FRANalysis:ENABLE"</a> on page 472</li> <li>· <a href="#">":FRANalysis:FREQuency:STARt"</a> on page 475</li> <li>· <a href="#">":FRANalysis:FREQuency:STOP"</a> on page 476</li> <li>· <a href="#">":FRANalysis:RUN"</a> on page 478</li> <li>· <a href="#">":FRANalysis:SOURce:OUTPut"</a> on page 480</li> <li>· <a href="#">":FRANalysis:WGEN:LOAD"</a> on page 482</li> <li>· <a href="#">":FRANalysis:WGEN:VOLTage"</a> on page 483</li> </ul>

## :FRANalysis:SOURce:OUTPut

**N** (see [page 1666](#))

**Command Syntax**    `:FRANalysis:SOURce:OUTPut <source>`

`<source> ::= CHANnel<n>`

`<n> ::= 1 to (# analog channels) in NR1 format`

The :FRANalysis:SOURce:OUTPut command specifies the analog input channel that is probing the output voltage from the device under test (DUT) in the frequency response analysis.

**Query Syntax**    `:FRANalysis:SOURce:OUTPut?`

The :FRANalysis:SOURce:OUTPut? query returns the currently selected channel probing the output voltage.

**Return Format**    `<source><NL>`

`<source> ::= CHAN<n>`

- See Also**
- "[:FRANalysis:DATA](#)" on page 471
  - "[:FRANalysis:ENABLE](#)" on page 472
  - "[:FRANalysis:FREQuency:STARt](#)" on page 475
  - "[:FRANalysis:FREQuency:STOP](#)" on page 476
  - "[:FRANalysis:RUN](#)" on page 478
  - "[:FRANalysis:SOURce:INPut](#)" on page 479
  - "[:FRANalysis:WGEN:LOAD](#)" on page 482
  - "[:FRANalysis:WGEN:VOLTage](#)" on page 483

## :FRANalysis:TRACe

**N** (see [page 1666](#))

**Command Syntax** :FRANalysis:TRACe <selection>

```
<selection> ::= {NONE | ALL | GAIN | PHASE} [, {GAIN | PHASE}]
```

The :FRANalysis:TRACe command specifies whether to include gain, phase, both gain and phase, or neither in the frequency response analysis results.

### NOTE

This command affects the oscilloscope's front panel graphical user interface (plot and table) as well as when saving analysis data.

**Query Syntax** :FRANalysis:TRACe?

The :FRANalysis:TRACe? query returns a comma-separated list of the types of data that are currently included in the frequency response analysis results, or "NONE" if neither gain nor phase data is included.

**Return Format** <selection\_list><NL>

```
<selection_list> ::= {"NONE" | "GAIN" | "PHASE" | "GAIN, PHASE"}
```

**See Also**

- [":FRANalysis:RUN"](#) on page 478
- [":FRANalysis:DATA"](#) on page 471

## :FRANalysis:WGEN:LOAD

**N** (see [page 1666](#))

**Command Syntax**    `:FRANalysis:WGEN:LOAD <impedance>`  
`<impedance> ::= {ONEMeg | FIFTy}`

The :FRANalysis:WGEN:LOAD command selects the expected output load impedance.

The output impedance of the Gen Out BNC is fixed at 50 ohms. However, the output load selection lets the waveform generator display the correct amplitude and offset levels for the expected output load.

If the actual load impedance is different than the selected value, the displayed amplitude and offset levels will be incorrect.

**Query Syntax**    `:FRANalysis:WGEN:LOAD?`

The :FRANalysis:WGEN:LOAD? query returns the current expected output load impedance.

**Return Format**    `<impedance><NL>`

`<impedance> ::= {ONEM | FIFT}`

- See Also**
- "[:FRANalysis:DATA](#)" on page 471
  - "[:FRANalysis:ENABLE](#)" on page 472
  - "[:FRANalysis:FREQuency:STARt](#)" on page 475
  - "[:FRANalysis:FREQuency:STOP](#)" on page 476
  - "[:FRANalysis:RUN](#)" on page 478
  - "[:FRANalysis:SOURce:INPut](#)" on page 479
  - "[:FRANalysis:SOURce:OUTPut](#)" on page 480
  - "[:FRANalysis:WGEN:VOLTage](#)" on page 483

## :FRANalysis:WGEN:VOLTage

**N** (see [page 1666](#))

### Command Syntax

```
:FRANalysis:WGEN:VOLTage <amplitude>, [<range>]
<amplitude> ::= amplitude in volts in NR3 format
<range> ::= {F20HZ | F100HZ | F1KHZ | F10KHZ | F100KHZ | F1MHZ
| F10MHZ | F20MHZ}
```

The :FRANalysis:WGEN:VOLTage command specifies the waveform generator's output sine wave amplitude.

Use the :WGEN:VOLTage:OFFSet command to specify the offset voltage or DC level.

You can also specify the amplitude and offset indirectly using the :WGEN:VOLTage:HIGH and :WGEN:VOLTage:LOW commands. For example, an amplitude of 5 V and an offset of 1 V is the same as a high-level voltage of 4 V and a low-level voltage of -1 V.

When the amplitude profile setting is on (:FRANalysis:WGEN:VOLTage:PROFile ON), the <range> option specifies the initial ramp amplitude at the frequency setting. Amplitudes ramp between the settings specified for individual frequencies.

### Query Syntax

```
:FRANalysis:WGEN:VOLTage? [<range>]
```

The :FRANalysis:WGEN:VOLTage? query returns the currently specified waveform generator amplitude.

When the amplitude profile setting is on (:FRANalysis:WGEN:VOLTage:PROFile ON), the <range> option specifies the frequency whose initial ramp amplitude is returned.

### Return Format

```
<amplitude><NL>
<amplitude> ::= amplitude in volts in NR3 format
```

### See Also

- [":FRANalysis:WGEN:VOLTage:PROFile" on page 484](#)
- [":FRANalysis:DATA" on page 471](#)
- [":FRANalysis:ENABLE" on page 472](#)
- [":FRANalysis:FREQuency:START" on page 475](#)
- [":FRANalysis:FREQuency:STOP" on page 476](#)
- [":FRANalysis:PPDecade" on page 477](#)
- [":FRANalysis:RUN" on page 478](#)
- [":FRANalysis:SOURce:INPut" on page 479](#)
- [":FRANalysis:SOURce:OUTPut" on page 480](#)
- [":FRANalysis:WGEN:LOAD" on page 482](#)

## :FRANalysis:WGEN:VOLTage:PROFile

**N** (see [page 1666](#))

**Command Syntax**    `:FRANalysis:WGEN:VOLTage:PROFile {{0 | OFF} | {1 | ON}}`

The :FRANalysis:WGEN:VOLTage:PROFile command enables or disables the ability to specify amplitude ramping within different decades.

**Query Syntax**    `:FRANalysis:WGEN:VOLTage:PROFile?`

The :FRANalysis:WGEN:VOLTage:PROFile? query returns the voltage profile setting.

**Return Format**    `<setting><NL>`

`<setting> ::= {0 | 1}`

**See Also**

- "[:FRANalysis:WGEN:VOLTage](#)" on page 483
- "[:FRANalysis:PPDecade](#)" on page 477
- "[:FRANalysis:FREQuency:STARt](#)" on page 475
- "[:FRANalysis:FREQuency:STOP](#)" on page 476

## 21 :FUNCTION<m> Commands

Control math functions in the oscilloscope. See "[Introduction to :FUNCTION<m> Commands](#)" on page 491.

**Table 110** :FUNCTION<m> Commands Summary

Command	Query	Options and Query Returns
:FUNCTION<m>:AVERage:COUNT <count> (see <a href="#">page 492</a> )	:FUNCTION<m>:AVERage:COUNT? (see <a href="#">page 492</a> )	<count> ::= an integer from 2 to 65536 in NR1 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:BUS:CLOCK <source> (see <a href="#">page 493</a> )	:FUNCTION<m>:BUS:CLOCK? (see <a href="#">page 493</a> )	<source> ::= {CHANnel<n>   DIGital<d>} <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:BUS:SLOPE <slope> (see <a href="#">page 494</a> )	:FUNCTION<m>:BUS:SLOPE? (see <a href="#">page 494</a> )	<slope> ::= {NEGative   POSitive   EITHER} <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:BUS:YINCREMENT <value> (see <a href="#">page 495</a> )	:FUNCTION<m>:BUS:YINCREMENT? (see <a href="#">page 495</a> )	<value> ::= value per bus code, in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:BUS:YORIGIN <value> (see <a href="#">page 496</a> )	:FUNCTION<m>:BUS:YORIGIN? (see <a href="#">page 496</a> )	<value> ::= value at bus code = 0, in NR3 format <m> ::= 1 to (# math functions) in NR1 format

**Table 110** :FUNCTION<m> Commands Summary (continued)

Command	Query	Options and Query Returns
:FUNCTION<m>:BUS:YUNits <units> (see page 497)	:FUNCTION<m>:BUS:YUNits? (see page 497)	<units> ::= {VOLT   AMPere   NONE} <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:CLEAR (see page 498)	n/a	n/a
:FUNCTION<m>:DISPLAY {{0   OFF}   {1   ON}} (see page 499)	:FUNCTION<m>:DISPLAY? (see page 499)	{0   1} <m> ::= 1 to (# math functions) in NR1 format
n/a	:FUNCTION<m>[:FFT]:BSIZE? (see page 500)	<bin_size> ::= Hz in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:CENTER <frequency> (see page 501)	:FUNCTION<m>[:FFT]:CENTER? (see page 501)	<frequency> ::= the current center frequency in NR3 format. The range of legal values is from -25 GHz to 25 GHz. <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:DETECTION:POINTS <number_of_buckets> (see page 502)	:FUNCTION<m>[:FFT]:DETECTION:POINTS? (see page 502)	<number_of_buckets> ::= an integer from 640 to 64K in NR1 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:DETECTION:TYPE <type> (see page 503)	:FUNCTION<m>[:FFT]:DETECTION:TYPE? (see page 503)	<type> ::= {OFF   SAMPLE   PPOSitive   PNENegative   NORMAL   AVERAGE} <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:FREQUENCY:START <frequency> (see page 504)	:FUNCTION<m>[:FFT]:FREQUENCY:START? (see page 504)	<frequency> ::= the start frequency in NR3 format. <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:FREQUENCY:STOP <frequency> (see page 505)	:FUNCTION<m>[:FFT]:FREQUENCY:STOP? (see page 505)	<frequency> ::= the stop frequency in NR3 format. <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:GATE <gating> (see page 506)	:FUNCTION<m>[:FFT]:GATE? (see page 506)	<gating> ::= {NONE   ZOOM} <m> ::= 1-4 in NR1 format

**Table 110** :FUNCTION<m> Commands Summary (continued)

Command	Query	Options and Query Returns
:FUNCTION<m>[:FFT]:PH ASe:REference <ref_point> (see <a href="#">page 507</a> )	:FUNCTION<m>[:FFT]:PH ASe:REference? (see <a href="#">page 507</a> )	<ref_point> ::= {TRIGger   DISPLAY} <m> ::= 1-4 in NR1 format
n/a	:FUNCTION<m>[:FFT]:RB Width? (see <a href="#">page 508</a> )	<resolution_bw> ::= Hz in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:RE ADout<n> <readout_type> (see <a href="#">page 509</a> )	:FUNCTION<m>[:FFT]:RE ADout<n>? (see <a href="#">page 509</a> )	<readout_type> ::= {SRATE   BSIZE   RBWidth} <m> ::= 1 to (# math functions) in NR1 format <n> ::= 1-2 in NR1 format, 2 is for dedicated FFT function
:FUNCTION<m>[:FFT]:SP AN <span> (see <a href="#">page 510</a> )	:FUNCTION<m>[:FFT]:SP AN? (see <a href="#">page 510</a> )	<span> ::= the current frequency span in NR3 format. Legal values are 1 Hz to 100 GHz. <m> ::= 1 to (# math functions) in NR1 format
n/a	:FUNCTION<m>[:FFT]:SR ATe? (see <a href="#">page 511</a> )	<sample_rate> ::= Hz in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:VT YPe <units> (see <a href="#">page 512</a> )	:FUNCTION<m>[:FFT]:VT YPe? (see <a href="#">page 512</a> )	<units> ::= {DECibel   VRMS} for the FFT (magnitude) operation <units> ::= {DEGREes   RADians} for the FFTPhase operation <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>[:FFT]:WI NDow <window> (see <a href="#">page 513</a> )	:FUNCTION<m>[:FFT]:WI NDow? (see <a href="#">page 513</a> )	<>window> ::= {RECTangular   HANNing   FLATtop   BHARris   BARTlett} <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:FREQuenc y:BANDpass:CENTER <center_freq> (see <a href="#">page 514</a> )	:FUNCTION<m>:FREQuenc y:BANDpass:CENTER? (see <a href="#">page 514</a> )	<center_freq> ::= center frequency of band-pass filter in NR3 format

**Table 110** :FUNCTION<m> Commands Summary (continued)

Command	Query	Options and Query Returns
:FUNCTION<m>:FREQuency:BANDpass:WIDTh <freq_width> (see page 515)	:FUNCTION<m>:FREQuency:BANDpass:WIDTh? (see <a href="#">page 515</a> )	<freq_width> ::= frequency width of band-pass filter in NR3 format
:FUNCTION<m>:FREQuency:HIGHpass <3dB_freq> (see <a href="#">page 516</a> )	:FUNCTION<m>:FREQuency:HIGHpass? (see <a href="#">page 516</a> )	<3dB_freq> ::= 3dB cutoff frequency value in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:FREQuency:LOWPass <3dB_freq> (see <a href="#">page 517</a> )	:FUNCTION<m>:FREQuency:LOWPass? (see <a href="#">page 517</a> )	<3dB_freq> ::= 3dB cutoff frequency value in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:INTegrat>e:IICondition {{0   OFF}   {1   ON}} (see <a href="#">page 518</a> )	:FUNCTION<m>:INTegrat>e:IICondition? (see <a href="#">page 518</a> )	{0   1} <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:INTegrat>e:IOFFset <input_offset> (see <a href="#">page 519</a> )	:FUNCTION<m>:INTegrat>e:IOFFset? (see <a href="#">page 519</a> )	<input_offset> ::= DC offset correction in NR3 format. <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:LINear:GAIN <value> (see <a href="#">page 520</a> )	:FUNCTION<m>:LINear:GAIN? (see <a href="#">page 520</a> )	<value> ::= 'A' in Ax + B, value in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:LINear:OFFSet <value> (see <a href="#">page 521</a> )	:FUNCTION<m>:LINear:OFFSet? (see <a href="#">page 521</a> )	<value> ::= 'B' in Ax + B, value in NR3 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:OFFSET <offset> (see <a href="#">page 522</a> )	:FUNCTION<m>:OFFSET? (see <a href="#">page 522</a> )	<offset> ::= the value at center screen in NR3 format. The range of legal values is +/-10 times the current sensitivity of the selected function. <m> ::= 1 to (# math functions) in NR1 format

**Table 110** :FUNCTION<m> Commands Summary (continued)

Command	Query	Options and Query Returns
:FUNCTION<m>:OPERation <operation> (see page 523)	:FUNCTION<m>:OPERation? (see page 526)	<p>&lt;operation&gt; ::= {ADD   SUBTract   MULTIPLY   DIVide   INTegrate   DIFF   FFT   FFTPhase   SQRT   MAGNify   ABSolute   SQUare   LN   LOG   EXP   TEN   LOWPass   HIGHpass   BANDpass   AVERage   LINEar   MAXimum   MINimum   PEAK   MAXhold   MINhold   TRENd   BTIMing   BSTate   SERChart}</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p>
:FUNCTION<m>:RANGE <range> (see page 528)	:FUNCTION<m>:RANGE? (see page 528)	<p>&lt;range&gt; ::= the full-scale vertical axis value in NR3 format.</p> <p>The range for ADD, SUBT, MULT is 8E-6 to 800E+3. The range for the INTegrate function is 8E-9 to 400E+3.</p> <p>The range for the DIFF function is 80E-3 to 8.0E12 (depends on current sweep speed).</p> <p>The range for the FFT function is 8 to 800 dBV.</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p>
:FUNCTION<m>:REFERenc e <level> (see page 529)	:FUNCTION<m>:REFERenc e? (see page 529)	<p>&lt;level&gt; ::= the value at center screen in NR3 format.</p> <p>The range of legal values is +/-10 times the current sensitivity of the selected function.</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p>
:FUNCTION<m>:SCALE <scale value>[<suffix>] (see page 530)	:FUNCTION<m>:SCALE? (see page 530)	<p>&lt;scale value&gt; ::= integer in NR1 format</p> <p>&lt;suffix&gt; ::= {V   dB}</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p>

**Table 110** :FUNCTION<m> Commands Summary (continued)

Command	Query	Options and Query Returns
:FUNCTION<m>:SERChart :SOURce <serialbus> (see <a href="#">page 531</a> )	:FUNCTION<m>:SERChart :SOURce? (see <a href="#">page 531</a> )	<m> ::= 1 to (# math functions) in NR1 format <serialbus> ::= {SBUS<n>} <n> :: 1 to (# of serial bus) in NR1 format
:FUNCTION<m>:SERChart :TIME:MODE <value> (see <a href="#">page 532</a> )	:FUNCTION<m>:SERChart :TIME:MODE? (see <a href="#">page 532</a> )	<m> ::= 1 to (# math functions) in NR1 format <value> ::= {MAIN   ROLL}
:FUNCTION<m>:SERChart :TIME:RANGE <range_value> (see <a href="#">page 534</a> )	:FUNCTION<m>:SERChart :TIME:RANGE? (see <a href="#">page 534</a> )	<m> ::= 1 to (# math functions) in NR1 format <range_value> ::= time value in NR3 format
:FUNCTION<m>:SERChart :TIME:OFFSET <offset> (see <a href="#">page 535</a> )	:FUNCTION<m>:SERChart :TIME:OFFSET? (see <a href="#">page 535</a> )	<m> ::= 1 to (# math functions) in NR1 format <offset> ::= vertical offset value in NR3 format
:FUNCTION<m>:SMOoth:POINTs <points> (see <a href="#">page 536</a> )	:FUNCTION<m>:SMOoth:POINTs? (see <a href="#">page 536</a> )	<points> ::= odd integer in NR1 format
:FUNCTION<m>:SOURcel <source> (see <a href="#">page 537</a> )	:FUNCTION<m>:SOURcel? (see <a href="#">page 537</a> )	<source> ::= {CHANnel<n>   FUNCTION<c>   MATH<c>   WMMemory<r>   BUS<b>} <n> ::= 1 to (# analog channels) in NR1 format <c> ::= {1}, must be lower than <m> <r> ::= 1 to (# ref waveforms) in NR1 format <b> ::= {1   2} <m> ::= 1 to (# math functions) in NR1 format

**Table 110** :FUNCTION<m> Commands Summary (continued)

Command	Query	Options and Query Returns
:FUNCTION<m>:SOURCE2<source> (see page 539)	:FUNCTION<m>:SOURCE2? (see page 539)	<source> ::= {CHANNEL<n>   WMEMORY<r>   NONE} <n> ::= 1 to (# analog channels) in NR1 format <r> ::= 1 to (# ref waveforms) in NR1 format <m> ::= 1 to (# math functions) in NR1 format
:FUNCTION<m>:TREND:NM EASUREMENT MEAS<n> (see page 540)	:FUNCTION<m>:TREND:NM EASUREMENT? (see page 540)	<n> ::= # of installed measurement, from 1 to 8 <m> ::= 1 to (# math functions) in NR1 format

**Introduction to :FUNCTION<m> Commands** The FUNCtion subsystem controls the math functions in the oscilloscope. Two math functions are available – the <m> in :FUNCTION<m> can be from 1 to 2. However, a dedicated FFT function is also available, see [Chapter 19, “:FFT Commands,” starting on page 449](#).

The math function operator, transform, filter, or visualization is selected using the :FUNCTION<m>:OPERation command. Depending on the selected operation, there may be other commands for specifying options for that operation. See [":FUNCTION<m>:OPERation" on page 523](#).

The SOURCE1, DISPLAY, RANGE, and OFFSet (or REFERENCE) commands apply to any function.

### Reporting the Setup

Use :FUNCTION<m>? to query setup information for the FUNCtion subsystem.

### Return Format

The following is a sample response from the :FUNCTION1? query. In this case, the query was issued following a \*RST command.

```
:FUNC1:OPER ADD;DISP 0;SOUR1 CHAN1;SOUR2 CHAN2;RANG +8.00E+00;OFFS +0.0E+00
```

## :FUNCTION<m>:AVERage:COUNT

**N** (see [page 1666](#))

- Command Syntax**    `:FUNCTION<m>:AVERage:COUNT <count>`  
`<count> ::= an integer from 2 to 65536 in NR1 format`  
`<m> ::= 1 to (# math functions) in NR1 format`
- The :FUNCTION<m>:AVERage:COUNT command sets the number of waveforms to be averaged together.
- The number of averages can be set from 2 to 65536 in increments of powers of 2. Increasing the number of averages will increase resolution and reduce noise.
- Query Syntax**    `:FUNCTION<m>:AVERage:COUNT?`
- The :FUNCTION<m>:AVERage:COUNT? query returns the number of waveforms to be averaged together.
- Return Format**    `<count><NL>`  
`<count> ::= an integer from 2 to 65536 in NR1 format`
- See Also**    • [":FUNCTION<m>:OPERation"](#) on page 523

## :FUNCTION<m>:BUS:CLOCK

**N** (see [page 1666](#))

**Command Syntax** :FUNCTION<m>:BUS:CLOCK <source>

```
<m> ::= 1 to (# math functions) in NR1 format
<source> ::= {DIGItal<d>}
<d> ::= 0 to (# digital channels - 1) in NR1 format
```

The :FUNCTION<m>:BUS:CLOCK command selects the clock signal source for the Chart Logic Bus State operation.

**Query Syntax** :FUNCTION<m>:BUS:CLOCK?

The :FUNCTION<m>:BUS:CLOCK query returns the source selected for the clock signal.

**Return Format** <source><NL>

```
<source> ::= {DIGItal<d>}
<d> ::= 0 to (# digital channels - 1) in NR1 format
```

**See Also** • "[:FUNCTION<m>:OPERation](#)" on page 523

## :FUNCTION<m>:BUS:SLOPe

**N** (see [page 1666](#))

**Command Syntax**    `:FUNCTION<m>:BUS:SLOPe <slope>`

`<m> ::= 1 to (# math functions) in NR1 format`

`<slope> ::= {NEGative | POSitive | EITHer}`

The :FUNCTION<m>:BUS:SLOPe command specifies the clock signal edge for the Chart Logic Bus State operation.

**Query Syntax**    `:FUNCTION<m>:BUS:SLOPe?`

The :FUNCTION<m>:BUS:SLOPe query returns the clock edge setting.

**Return Format**    `<slope><NL>`

`<slope> ::= {NEGative | POSitive | EITHer}`

**See Also**    · [":FUNCTION<m>:OPERation" on page 523](#)

## :FUNCTION<m>:BUS:YINCrement

**N** (see [page 1666](#))

- Command Syntax**    :FUNCTION<m>:BUS:YINCrement <value>  
                  <m> ::= 1 to (# math functions) in NR1 format  
                  <value> ::= value per bus code, in NR3 format
- The :FUNCTION<m>:BUS:YINCrement command specifies the value associated with each increment in Chart Logic Bus data.
- Query Syntax**    :FUNCTION<m>:BUS:YINCrement?
- The :FUNCTION<m>:BUS:YINCrement query returns the value associated with each increment in Chart Logic Bus data.
- Return Format**    <value><NL>  
                  <value> ::= value per bus code, in NR3 format
- See Also**    • [":FUNCTION<m>:OPERation"](#) on page 523

## :FUNCTION<m>:BUS:YORigin

**N** (see [page 1666](#))

**Command Syntax**    `:FUNCTION<m>:BUS:YORigin <value>`

`<m> ::= 1 to (# math functions) in NR1 format`

`<value> ::= value at bus code = 0, in NR3 format`

The :FUNCTION<m>:BUS:YORigin command specifies the value associated with Chart Logic Bus data equal to zero.

**Query Syntax**    `:FUNCTION<m>:BUS:YORigin?`

The :FUNCTION<m>:BUS:YORigin query returns the value for associated with data equal to zero.

**Return Format**    `<value><NL>`

`<value> ::= value at bus code = 0, in NR3 format`

**See Also**    • [":FUNCTION<m>:OPERation"](#) on page 523

## :FUNCTION<m>:BUS:YUNits

**N** (see [page 1666](#))

**Command Syntax** :FUNCTION<m>:BUS:YUNits <units>

<m> ::= 1 to (# math functions) in NR1 format

<units> ::= {VOLT | AMPere | NONE}

The :FUNCTION<m>:BUS:YUNits command specifies the vertical units for the Chart Logic Bus operations.

**Query Syntax** :FUNCTION<m>:BUS:YUNits?

The :FUNCTION<m>:BUS:YUNits query returns the Chart Logic Bus vertical units.

**Return Format** <units><NL>

<units> ::= {VOLT | AMP | NONE}

**See Also** · [":FUNCTION<m>:OPERation"](#) on page 523

## :FUNCTION<m>:CLEar

**N** (see [page 1666](#))

**Command Syntax**    `:FUNCTION<m>:CLEar`

When the :FUNCTION<m>:OPERation is AVERage, MAXHold, or MINHold, the :FUNCTION<m>:CLEar command clears the number of evaluated waveforms.

**See Also**    • [":FUNCTION<m>:AVERage:COUNT"](#) on page 492

## :FUNCTION<m>:DISPLAY

**N** (see [page 1666](#))

**Command Syntax** :FUNCTION<m>:DISPLAY <display>

```
<m> ::= 1 to (# math functions) in NR1 format
<display> ::= {{1 | ON} | {0 | OFF}}
```

The :FUNCTION<m>:DISPLAY command turns the display of the function on or off. When ON is selected, the function operates as specified by the other :FUNCTION<m> commands.

### NOTE

Automatic vertical scaling of the math function waveform occurs when the function display is turned from off to on. If you wait for the operation to complete (with an \*OPC? query for example), then query the math functions's scale, you can see the vertical scaling that was automatically determined.

One math function can be displayed at a time. If one math function is on and then another math function is turned on, the first math function will be turned off.

When math functions are off, they are still calculated so that they can be cascaded, that is, used as a source for a higher math function.

**Query Syntax** :FUNCTION<m>:DISPLAY?

The :FUNCTION<m>:DISPLAY? query returns whether the function display is on or off.

**Return Format** <display><NL>

```
<display> ::= {1 | 0}
```

**See Also** ["Introduction to :FUNCTION<m> Commands"](#) on page 491

- ["\\*OPC \(Operation Complete\)"](#) on page 240
- [":FUNCTION<m>:SCALe"](#) on page 530
- [":VIEW"](#) on page 298
- [":BLANK"](#) on page 266
- [":STATus"](#) on page 295

## :FUNCTION<m>[:FFT]:BSIZE

**N** (see [page 1666](#))

**Query Syntax**    `:FUNCTION<m>[:FFT]:BSIZE?`

`<m> ::= 1-4 in NR1 format`

The `:FUNCTION<m>[:FFT]:BSIZE?` query returns the Bin Size setting for the FFT.

**Return Format**    `<bin_size><NL>`

`<bin_size> ::= Hz in NR3 format`

**See Also**    • [":FUNCTION<m>\[:FFT\]:READout<n>" on page 509](#)

## :FUNCTION<m>[:FFT]:CENTer

**N** (see [page 1666](#))

**Command Syntax**

```
:FUNCTION<m> [:FFT] :CENTer <frequency>
<m> ::= 1 to (# math functions) in NR1 format
<frequency> ::= the current center frequency in NR3 format. The range
of legal values is from -25 GHz to 25 GHz.
```

The :FUNCTION<m>[:FFT]:CENTer command sets the center frequency when FFT (Fast Fourier Transform) is selected.

**Query Syntax**

```
:FUNCTION<m> [:FFT] :CENTer?
```

The :FUNCTION<m>[:FFT]:CENTer? query returns the current center frequency in Hertz.

**Return Format**

```
<frequency><NL>
<frequency> ::= the current center frequency in NR3 format. The range
of legal values is from -25 GHz to 25 GHz.
```

### NOTE

After a \*RST (Reset) or :AUToscale command, the values returned by the :FUNCTION<m>[:FFT]:CENTer? and :FUNCTION<m>:SPAN? queries depend on the current :TIMEbase:RANGe value. Once you change either the :FUNCTION<m>[:FFT]:CENTer or :FUNCTION<m>:SPAN value, they no longer track the :TIMEbase:RANGe value.

### See Also

- "[Introduction to :FUNCTION<m> Commands](#)" on page 491
- "[:FUNCTION<m>\[:FFT\]:SPAN](#)" on page 510
- "[:TIMEbase:RANGE](#)" on page 1341
- "[:TIMEbase:SCALE](#)" on page 1344

## :FUNCTION<m>[:FFT]:DETecTION:POINts

**N** (see [page 1666](#))

**Command Syntax**    `:FUNCTION<m>[:FFT]:DETecTION:POINts <number_of_buckets>`

`<number_of_buckets>` ::= an integer from 640 to 64K in NR1 format

`<m>` ::= 1-4 in NR1 format

The :FUNCTION<m>[:FFT]:DETecTION:POINts command specifies the maximum number of points that the FFT detector should decimate to. This is also the number of buckets that sampled FFT points are grouped into before the selected detection type reduction (decimation) is applied.

The minimum number of points is 640.

The maximum number of points, 64K, is the measurement record limit.

**Query Syntax**    `:FUNCTION<m>[:FFT]:DETecTION:POINts?`

The :FUNCTION<m>[:FFT]:DETecTION:POINts? query returns the FFT detector points setting.

**Return Format**    `<number_of_buckets><NL>`

`<number_of_buckets>` ::= an integer from 640 to 64K in NR1 format

**See Also**    • [":FUNCTION<m>\[:FFT\]:DETecTION:TYPE"](#) on page 503

## :FUNCTION<m>[:FFT]:DETecTION:TYPE

**N** (see [page 1666](#))

### Command Syntax

```
:FUNCTION<m> [:FFT] :DETecTION:TYPE <type>
<type> ::= {OFF | SAMPlE | PPOSitive | PNENegative | NORMAl | AVERage}
<m> ::= 1-4 in NR1 format
```

The :FUNCTION<m>[:FFT]:DETecTION:TYPE command sets the FFT detector decimation type.

Detectors give you a way of manipulating the acquired data to emphasize different features of the data. Detectors reduce (decimate) the number of FFT points to at most the number of specified detector points. In this reduction, sampled FFT points are bucketized, that is, split into a number of groups that equals the specified number of detector points. Then, the points in each bucket are reduced to a single point according to the selected detection type. The detector types are:

- OFF – No detector is used.
- SAMPlE – Takes the point nearest to the center of every bucket.
- PPOSitive (+ Peak) – Takes the most positive point in every bucket.
- PNENegative (- Peak) – Takes the most negative point in every bucket.
- AVERage – Takes the average of all points in every bucket.
- NORMAl – Implements a rosenfell algorithm. This method to picks either the minimum or maximum sample in every bucket depending on whether the data is monotonically increasing, decreasing, or varying. For details, see the [Spectrum Analysis Basics application note](#) at [www.keysight.com](http://www.keysight.com).

When detectors are used, the FFT's output is decimated, and any analysis is performed on the reduced or detected data set.

### Query Syntax

```
:FUNCTION<m> [:FFT] :DETecTION:TYPE?
```

The :FUNCTION<m>[:FFT]:DETecTION:TYPE? query returns the FFT detector type setting

### Return Format

```
<type><NL>
```

```
<type> ::= {OFF | SAMPlE | PPOSitive | PNENegative | NORMAl | AVERage}
```

### See Also

- "[:FUNCTION<m>\[:FFT\]:DETecTION:POINts](#)" on page 502

## :FUNCTION<m>[:FFT]:FREQuency:STARt

**N** (see [page 1666](#))

**Command Syntax**

```
:FUNCTION<m> [:FFT] :FREQuency:STARt <frequency>
<m> ::= 1 to (# math functions) in NR1 format
<frequency> ::= the start frequency in NR3 format.
```

The :FUNCTION<m>[:FFT]:FREQuency:STARt command sets the start frequency in the FFT (Fast Fourier Transform) math function's displayed range.

The FFT (Fast Fourier Transform) math function's displayed range can also be set with the :FUNCTION<m>[:FFT]:CENTer and :FUNCTION<m>[:FFT]:SPAN commands.

**Query Syntax**

```
:FUNCTION<m> [:FFT] :FREQuency:STARt?
```

The :FUNCTION<m>[:FFT]:FREQuency:STARt? query returns the current start frequency in Hertz.

**Return Format**

```
<frequency><NL>
<frequency> ::= the start frequency in NR3 format.
```

**See Also**

- "[:FUNCTION<m>\[:FFT\]:FREQuency:STOP](#)" on page 505
- "[:FUNCTION<m>\[:FFT\]:CENTer](#)" on page 501
- "[:FUNCTION<m>\[:FFT\]:SPAN](#)" on page 510

## :FUNCTION<m>[:FFT]:FREQuency:STOP

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:FUNCTION&lt;m&gt; [:FFT] :FREQuency:STOP &lt;frequency&gt;</code> <code>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</code> <code>&lt;frequency&gt; ::= the stop frequency in NR3 format.</code>
	The :FUNCTION<m>[:FFT]:FREQuency:STOP command sets the stop frequency in the FFT (Fast Fourier Transform) math function's displayed range.
	The FFT (Fast Fourier Transform) math function's displayed range can also be set with the :FUNCTION<m>[:FFT]:CENTer and :FUNCTION<m>[:FFT]:SPAN commands.
<b>Query Syntax</b>	<code>:FUNCTION&lt;m&gt; [:FFT] :FREQuency:STOP?</code>
	The :FUNCTION<m>[:FFT]:FREQuency:STOP? query returns the current stop frequency in Hertz.
<b>Return Format</b>	<code>&lt;frequency&gt;&lt;NL&gt;</code> <code>&lt;frequency&gt; ::= the stop frequency in NR3 format.</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:FUNCTION&lt;m&gt;[:FFT]:FREQuency:START</a>" on page 504</li> <li>· "<a href="#">:FUNCTION&lt;m&gt;[:FFT]:CENTer</a>" on page 501</li> <li>· "<a href="#">:FUNCTION&lt;m&gt;[:FFT]:SPAN</a>" on page 510</li> </ul>

## :FUNCTION<m>[:FFT]:GATE

**N** (see [page 1666](#))

**Command Syntax**    `:FUNCTION<m> [:FFT] :GATE <gating>`

`<m> ::= 1-4 in NR1 format`

`<gating> ::= {NONE | ZOOM}`

The `:FUNCTION<m>[:FFT]:GATE` command specifies whether the FFT is performed on the Main time base window (NONE) or the ZOOM window when the zoomed time base is displayed.

**Query Syntax**    `:FUNCTION<m> [:FFT] :GATE?`

The `:FUNCTION<m>[:FFT]:GATE?` query returns the gate setting.

**Return Format**    `<gating><NL>`

`<gating> ::= {NONE | ZOOM}`

**See Also**

- "[:FUNCTION<m>\[:FFT\]:VTPe](#)" on page 512
- "[:FUNCTION<m>\[:FFT\]:WINDow](#)" on page 513
- "[Introduction to :FUNCTION<m> Commands](#)" on page 491
- "[:FUNCTION<m>:OPERation](#)" on page 523

## :FUNCTION<m>[:FFT]:PHASE:REFERENCE

**N** (see [page 1666](#))

**Command Syntax**

```
:FUNCTION<m> [:FFT] :PHASE:REFERENCE <ref_point>
<ref_point> ::= {TRIGger | DISPLAY}
<m> ::= 1-4 in NR1 format
```

The :FUNCTION<m>[:FFT]:PHASE:REFERENCE command sets the reference point for calculating the FFT Phase function to either the trigger point or beginning of the displayed waveform.

**Query Syntax**

```
:FUNCTION<m> [:FFT] :PHASE:REFERENCE?
```

The :FUNCTION<m>[:FFT]:PHASE:REFERENCE? query returns the selected reference point.

**Return Format**

```
<ref_point><NL>
<ref_point> ::= {TRIGger | DISPLAY}
```

**See Also**

- [":FUNCTION<m>:OPERation" on page 523](#)
- ["Introduction to :FUNCTION<m> Commands" on page 491](#)

## :FUNCTION<m>[:FFT]:RBWidth

**N** (see [page 1666](#))

**Query Syntax**    `:FUNCTION<m> [:FFT] :RBWidth?`

`<m> ::= 1-4 in NR1 format`

The `:FUNCTION<m>[:FFT]:RBWidth?` query returns the Resolution Bandwidth setting for the FFT.

**Return Format**    `<resolution_bw><NL>`

`<resolution_bw> ::= Hz in NR3 format`

**See Also**    • [":FUNCTION<m>\[:FFT\]:READout<n>" on page 509](#)

## :FUNCTION<m>[:FFT]:READout<n>

**N** (see [page 1666](#))

**Command Syntax**

```
:FUNCTION<m> [:FFT] :READout<n> <readout_type>
<readout_type> ::= {SRATE | BSIZE | RBWidth}
<m> ::= 1-4 in NR1 format
<n> ::= 1-2 in NR1 format, 2 is valid only on oscilloscopes that have
the dedicated FFT function
```

The :FUNCTION<m>[:FFT]:READout<n> command selects from these types of readouts for the FFT:

- SRATE – Sample Rate
- BSIZE – Bin Size
- RBWidth – Resolution Bandwidth

Note that READout1 is used for both the dedicated FFT and the general-purpose math FFT function and READout2 is used only for oscilloscopes that have a dedicated FFT function (like the 3000T X-Series).

**Query Syntax**

The :FUNCTION<m>[:FFT]:READout<n>? query returns the readout selection.

**Return Format**

```
<readout_type><NL>
```

```
<readout_type> ::= {SRAT | BSIZ | RBW}
```

**See Also**

- "[:FUNCTION<m>\[:FFT\]:BSIZE](#)" on page 500
- "[:FUNCTION<m>\[:FFT\]:RBWidth](#)" on page 508
- "[:FUNCTION<m>\[:FFT\]:SRATE](#)" on page 511

## :FUNCTION<m>[:FFT]:SPAN

**N** (see [page 1666](#))

**Command Syntax**

```
:FUNCTION<m>[:FFT]:SPAN <span>
<m> ::= 1 to (# math functions) in NR1 format
<span> ::= the current frequency span in NR3 format. Legal values are
          1 Hz to 100 GHz.

If you set the frequency span to a value outside of the legal range, the
step size is automatically set to the nearest legal value.
```

The :FUNCTION<m>[:FFT]:SPAN command sets the frequency span of the display (left graticule to right graticule) when FFT (Fast Fourier Transform) is selected.

**Query Syntax**

```
:FUNCTION<m>[:FFT]:SPAN?
```

The :FUNCTION<m>[:FFT]:SPAN? query returns the current frequency span in Hertz.

### NOTE

After a \*RST (Reset) or :AUToscale command, the values returned by the :FUNCTION<m>[:FFT]:CENTer? and :FUNCTION<m>:SPAN? queries depend on the current :TIMEbase:RANGe value. Once you change either the :FUNCTION<m>[:FFT]:CENTer or :FUNCTION<m>:SPAN value, they no longer track the :TIMEbase:RANGe value.

**Return Format**

```
<span><NL>
<span> ::= the current frequency span in NR3 format. Legal values are 1
          Hz to 100 GHz.
```

**See Also**

- "[Introduction to :FUNCTION<m> Commands](#)" on page 491
- "[":FUNCTION<m>\[:FFT\]:CENTer](#)" on page 501
- "[":TIMEbase:RANGE](#)" on page 1341
- "[":TIMEbase:SCALE](#)" on page 1344

## :FUNCTION<m>[:FFT]:SRATE

**N** (see [page 1666](#))

**Query Syntax** :FUNCTION<m> [:FFT] :SRATE?

<m> ::= 1-4 in NR1 format

The :FUNCTION<m>[:FFT]:SRATE? query returns the Sample Rate setting for the FFT.

**Return Format** <sample\_rate><NL>

<sample\_rate> ::= Hz in NR3 format

**See Also** • "[:FUNCTION<m>\[:FFT\]:READout<n>](#)" on page 509

## :FUNCTION<m>[:FFT]:VTYPe

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:FUNCTION&lt;m&gt; [:FFT] :VTYPe &lt;units&gt;</code>
	<code>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</code>
	<code>&lt;units&gt; ::= {DECibel   VRMS} for the FFT (magnitude) operation</code>
	<code>&lt;units&gt; ::= {DEGRees   RADians} for the FFTPhase operation</code>
	The :FUNCTION<m>[:FFT]:VTYPe command specifies FFT vertical units.
	For the FFT (Magnitude) operation units, DECibel equates to the user interface's Logarithmic selection, and VRMS equates to the user interface's Linear selection.
<b>Query Syntax</b>	<code>:FUNCTION&lt;m&gt; [:FFT] :VTYPe?</code>
	The :FUNCTION<m>[:FFT]:VTYPe? query returns the current FFT vertical units.
<b>Return Format</b>	<code>&lt;units&gt;&lt;NL&gt;</code>
	<code>&lt;units&gt; ::= {DEC   VRMS} for the FFT (magnitude) operation</code>
	<code>&lt;units&gt; ::= {DEGR   RAD} for the FFTPhase operation</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:FUNCTION&lt;m&gt;[:FFT]:GATE</a>" on page 506</li> <li>· "<a href="#">Introduction to :FUNCTION&lt;m&gt; Commands</a>" on page 491</li> <li>· "<a href="#">:FUNCTION&lt;m&gt;:OPERation</a>" on page 523</li> </ul>

## :FUNCTION<m>[:FFT]:WINDOW

**N** (see [page 1666](#))

- Command Syntax**
- ```
:FUNCTION<m> [:FFT] :WINDOW <window>
<m> ::= 1 to (# math functions) in NR1 format
<window> ::= {RECTangular | HANNing | FLATtop | BHARris | BARTlett}
```
- The :FUNCTION<m>[:FFT]:WINDOW command allows the selection of different windowing transforms or operations for the FFT (Fast Fourier Transform) function.
- The FFT operation assumes that the time record repeats. Unless an integral number of sampled waveform cycles exist in the record, a discontinuity is created between the end of one record and the beginning of the next. This discontinuity introduces additional frequency components about the peaks into the spectrum. This is referred to as leakage. To minimize leakage, windows that approach zero smoothly at the start and end of the record are employed as filters to the FFTs. Each window is useful for certain classes of input signals.
- RECTangular – useful for transient signals, and signals where there are an integral number of cycles in the time record.
  - HANNing – useful for frequency resolution and general purpose use. It is good for resolving two frequencies that are close together, or for making frequency measurements. This is the default window.
  - FLATtop – best for making accurate amplitude measurements of frequency peaks.
  - BHARris (Blackman-Harris) – reduces time resolution compared to the rectangular window, but it improves the capacity to detect smaller impulses due to lower secondary lobes (provides minimal spectral leakage).
  - BARTlett – (triangular, with end points at zero) window is similar to the Hanning window in that it is good for making accurate frequency measurements, but its higher and wider secondary lobes make it not quite as good for resolving frequencies that are close together.

**Query Syntax**

```
:FUNCTION<m> [:FFT] :WINDOW?
```

The :FUNCTION<m>[:FFT]:WINDOW? query returns the value of the window selected for the FFT function.

**Return Format**

```
<window><NL>
```

```
<window> ::= {RECT | HANN | FLAT | BHAR | BART}
```

**See Also**

- "[:FUNCTION<m>\[:FFT\]:GATE](#)" on page 506
- "[Introduction to :FUNCTION<m> Commands](#)" on page 491

**:FUNCTION<m>:FREQuency:BANDpass:CENTER**

**N** (see [page 1666](#))

**Command Syntax**    `:FUNCTION<m>:FREQuency:BANDpass:CENTER <center_freq>`  
`<center_freq> ::= center frequency of band-pass filter in NR3 format`

The :FUNCTION<m>:FREQuency:BANDpass:CENTER command sets the center frequency of the band-pass filter.

**Query Syntax**    `:FUNCTION<m>:FREQuency:BANDpass:CENTER?`  
The :FUNCTION<m>:FREQuency:BANDpass:CENTER? query returns the band-pass filter's center frequency setting.

**Return Format**    `<center_freq><NL>`

**See Also**

- [":FUNCTION<m>:FREQuency:BANDpass:WIDTH"](#) on page 515
- [":FUNCTION<m>:OPERation"](#) on page 523

## :FUNCTION<m>:FREQuency:BANDpass:WIDTH

**N** (see [page 1666](#))

|                       |                                                                                                                                                                                                                                                 |
|-----------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Command Syntax</b> | <code>:FUNCTION&lt;m&gt;:FREQuency:BANDpass:WIDTH &lt;freq_width&gt;</code><br><code>&lt;freq_width&gt; ::= frequency width of band-pass filter in NR3 format</code>                                                                            |
|                       | The :FUNCTION<m>:FREQuency:BANDpass:WIDTH command sets the frequency width of the band-pass filter. The width specifies the filter's -3 dB cutoff frequencies (center frequency minus half the width and center frequency plus half the width). |
| <b>Query Syntax</b>   | <code>:FUNCTION&lt;m&gt;:FREQuency:BANDpass:WIDTH?</code>                                                                                                                                                                                       |
|                       | The :FUNCTION<m>:FREQuency:BANDpass:WIDTH? query returns the band-pass filter's frequency width setting.                                                                                                                                        |
| <b>Return Format</b>  | <code>&lt;freq_width&gt;&lt;NL&gt;</code>                                                                                                                                                                                                       |
| <b>See Also</b>       | <ul style="list-style-type: none"><li><a href="#">":FUNCTION&lt;m&gt;:FREQuency:BANDpass:CENTER"</a> on page 514</li><li><a href="#">":FUNCTION&lt;m&gt;:OPERation"</a> on page 523</li></ul>                                                   |

## :FUNCTION<m>:FREQuency:HIGHpass

**N** (see [page 1666](#))

- Command Syntax**    `:FUNCTION<m>:FREQuency:HIGHpass <3dB_freq>`  
`<m> ::= 1 to (# math functions) in NR1 format`  
`<3dB_freq> ::= -3dB cutoff frequency value in NR3 format`
- The :FUNCTION<m>:FREQuency:HIGHpass command sets the high-pass filter's -3 dB cutoff frequency.
- The high-pass filter is a single-pole high pass filter.
- Query Syntax**    `:FUNCTION<m>:FREQuency:HIGHpass?`
- The :FUNCTION<m>:FREQuency:HIGHpass query returns the high-pass filter's cutoff frequency.
- Return Format**    `<3dB_freq><NL>`  
`<3dB_freq> ::= -3dB cutoff frequency value in NR3 format`
- See Also**    • [":FUNCTION<m>:OPERation"](#) on page 523

## :FUNCTION<m>:FREQuency:LOWPass

**N** (see [page 1666](#))

**Command Syntax**    `:FUNCTION<m>:FREQuency:LOWPass <3dB_freq>`  
`<m> ::= 1 to (# math functions) in NR1 format`  
`<3dB_freq> ::= -3dB cutoff frequency value in NR3 format`

The :FUNCTION<m>:FREQuency:LOWPass command sets the low-pass filter's -3 dB cutoff frequency.

The low-pass filter is a 4th order Bessel-Thompson filter.

**Query Syntax**    `:FUNCTION<m>:FREQuency:LOWPass?`

The :FUNCTION<m>:FREQuency:LOWPass query returns the low-pass filter's cutoff frequency.

**Return Format**    `<3dB_freq><NL>`  
`<3dB_freq> ::= -3dB cutoff frequency value in NR3 format`

**See Also**    • [":FUNCTION<m>:OPERation"](#) on page 523

## :FUNCTION<m>:INTegrate:IICondition

**N** (see [page 1666](#))

**Command Syntax**    `:FUNCTION<m>:INTegrate:IICondition {{0 | OFF} | {1 | ON}}`  
`<m> ::= 1 to (# math functions) in NR1 format`

The :FUNCTION<m>:INTegrate:IICondition command sets the Initial Condition of the Integrate math function waveform:

- ON – the integrate math waveform is vertically centered in the screen. In other words, the top and bottom of the math waveform are equal distances from the top and bottom of the screen.
- OFF – the integrate math waveform starts at the zero-level reference on the left side of the screen.

**Query Syntax**    `:FUNCTION<m>:INTegrate:IICondition?`

The :FUNCTION<m>:INTegrate:IICondition? query returns Initial Condition setting for the Integrate math function.

**Return Format**    `<setting><NL>`  
`<setting> ::= {0 | 1}`

**See Also**

- "[:FUNCTION<m>:OPERation](#)" on page 523
- "[:FUNCTION<m>:INTegrate:IOFFset](#)" on page 519

## :FUNCTION<m>:INTegrate:IOFFset

**N** (see [page 1666](#))

**Command Syntax** :FUNCTION<m>:INTegrate:IOFFset <input\_offset>

<m> ::= 1 to (# math functions) in NR1 format

<input\_offset> ::= DC offset correction in NR3 format.

The :FUNCTION<m>:INTegrate:IOFFset command lets you enter a DC offset correction factor for the integrate math waveform input signal. This DC offset correction lets you level a "ramp"ed waveform.

**Query Syntax** :FUNCTION<m>:INTegrate:IOFFset?

The :FUNCTION<m>:INTegrate:IOFFset? query returns the current input offset value.

**Return Format** <input\_offset><NL>

<input\_offset> ::= DC offset correction in NR3 format.

**See Also** • ["Introduction to :FUNCTION<m> Commands"](#) on page 491

• [":FUNCTION<m>:OPERation"](#) on page 523

• [":FUNCTION<m>:INTegrate:ICCondition"](#) on page 518

## :FUNCTION<m>:LINear:GAIN

**N** (see [page 1666](#))

- Command Syntax**    `:FUNCTION<m>:LINear:GAIN <value>`
- `<m> ::= 1 to (# math functions) in NR1 format`
- `<value> ::= 'A' in Ax + B, value in NR3 format`
- The :FUNCTION<m>:LINear:GAIN command specifies the 'A' value in the Ax + B operation.
- Query Syntax**    `:FUNCTION<m>:LINear:GAIN?`
- The :FUNCTION<m>:LINear:GAIN query returns the gain value.
- Return Format**    `<value><NL>`
- `<value> ::= 'A' in Ax + B, value in NR3 format`
- See Also**    · [":FUNCTION<m>:OPERation"](#) on page 523

## :FUNCTION<m>:LINear:OFFSet

**N** (see [page 1666](#))

- Command Syntax**    `:FUNCTION<m>:LINear:OFFSet <value>`  
`<m> ::= 1 to (# math functions) in NR1 format`  
`<value> ::= 'B' in Ax + B, value in NR3 format`
- The :FUNCTION<m>:LINear:OFFSet command specifies the 'B' value in the Ax + B operation.
- Query Syntax**    `:FUNCTION<m>:LINear:OFFSet?`
- The :FUNCTION<m>:LINear:OFFSet query returns the offset value.
- Return Format**    `<value><NL>`  
`<value> ::= 'B' in Ax + B, value in NR3 format`
- See Also**    · [":FUNCTION<m>:OPERation"](#) on page 523

## :FUNCTION<m>:OFFSet

**N** (see [page 1666](#))

**Command Syntax**    `:FUNCTION<m>:OFFSet <offset>`

`<m> ::= 1 to (# math functions) in NR1 format`

`<offset> ::= the value at center screen in NR3 format.`

The :FUNCTION<m>:OFFSet command sets the voltage or vertical value represented at center screen for the selected function. The range of legal values is generally +/-10 times the current scale of the selected function, but will vary by function. If you set the offset to a value outside of the legal range, the offset value is automatically set to the nearest legal value.

### NOTE

The :FUNCTION<m>:OFFSet command is equivalent to the :FUNCTION<m>:REFerence command.

**Query Syntax**    `:FUNCTION<m>:OFFSet?`

The :FUNCTION<m>:OFFSet? query outputs the current offset value for the selected function.

**Return Format**    `<offset><NL>`

`<offset> ::= the value at center screen in NR3 format.`

**See Also**

- "[Introduction to :FUNCTION<m> Commands](#)" on page 491
- "[":FUNCTION<m>:RANGE](#)" on page 528
- "[":FUNCTION<m>:REFerence](#)" on page 529
- "[":FUNCTION<m>:SCALE](#)" on page 530

## :FUNCTION<m>:OPERation

**N** (see [page 1666](#))

### Command Syntax

```
:FUNCTION<m>:OPERation <operation>
<m> ::= 1 to (# math functions) in NR1 format
<operation> ::= {ADD | SUBTract | MULTIply | DIVide | DIFF | INTegrate
| FFT | FFTPhase | SQRT | MAGNify | ABSolute | SQUare | LN | LOG
| EXP | TEN | LOWPass | HIGHpass | BANDpass | AVERage | SMOoth
| ENVelope | LINEar | MAXimum | MINimum | PEAK | MAXHold | MINHold
| TRENd | BTIMing | BSTate | SERChart}
```

The :FUNCTION<m>:OPERation command sets the desired waveform math operator, transform, filter or visualization:

- Operators:

- ADD – Source1 + source2.
- SUBTract – Source1 - source2.
- MULTIply – Source1 \* source2.
- DIVide – Source1 / source2.

Operators perform their function on two analog channel sources.

- Transforms:

- DIFF – Differentiate
- INTegrate – The :FUNCTION<m>:INTegrate:IOFFset command lets you specify a DC offset correction factor. The :FUNCTION<m>:INTegrate:ICCondition command lets you sets the Initial Condition of the Integrate math function waveform.
- FFT (magnitude) – Using the Fast Fourier Transform (FFT), this operation displays the magnitudes of the frequency content that makes up the source waveform. The FFT takes the digitized time record of the specified source and transforms it to the frequency domain.

The SPAN, CENTer, VTYPe, and WINDOW commands are used for FFT functions. When FFT is selected, the horizontal cursors change from time to frequency (Hz), and the vertical cursors change from volts to decibels or V RMS.

- FFTPhase – Using the Fast Fourier Transform (FFT), this operation shows the phase relationships of the frequency content that makes up the source waveform. The FFT takes the digitized time record of the specified source and transforms it to the frequency domain.

The SPAN, CENTer, VTYPe, and WINDOW commands are used for FFT functions. When FFTPhase is selected, the horizontal cursors change from time to frequency (Hz), and the vertical cursors change from volts to degrees or radians.

- LINear – Ax + B – The LINear commands set the gain (A) and offset (B) values for this function.
- SQUare
- SQRT – Square root
- ABSolute – Absolute Value
- LOG – Common Logarithm
- LN – Natural Logarithm
- EXP – Exponential ( $e^x$ )
- TEN – Base 10 exponential ( $10^x$ )

Transforms operate on a single analog channel source or on lower math functions.

- Filters:
  - LOWPass – Low pass filter – The FREQuency:LOWPass command sets the -3 dB cutoff frequency.
  - HIGHpass – High pass filter – The FREQuency:HIGHpass command sets the -3 dB cutoff frequency.
  - BANDpass – Band pass filter – The FREQuency:BANDpass:CENTER and FREQuency:BANDpass:WIDTH commands set the center frequency and width of the filter.
  - AVERage – Averaged value – The AVERage:COUNT command specifies the number of averages.

Unlike acquisition averaging, the math averaging operator can be used to average the data on a single analog input channel or math function.

If acquisition averaging is also used, the analog input channel data is averaged and the math function averages it again. You can use both types of averaging to get a certain number of averages on all waveforms and an increased number of averages on a particular waveform.

Averages are calculated using a "decaying average" approximation, where:

$$\text{next\_average} = \text{current\_average} + (\text{new\_data} - \text{current\_average})/N$$

Where N starts at 1 for the first acquisition and increments for each following acquisition until it reaches the selected number of averages, where it holds.

- SMOoth – Smoothing – The resulting math waveform is the selected source with a normalized rectangular (boxcar) FIR filter applied.

The boxcar filter is a moving average of adjacent waveform points, where the number of adjacent points is specified by the SMOoth:POINts command. You can choose an odd number of points, from 3 to 999.

The smoothing operator limits the bandwidth of the source waveform. The smoothing operator can be used, for example, to smooth measurement trend waveforms.

- ENVelope – Envelope – The resulting math waveform is the amplitude envelope for an amplitude modulated (AM) input signal.

This function uses a Hilbert transform to get the real (in-phase, I) and imaginary (quadrature, Q) parts of the input signal and then performs a square root of the sum of the real and imaginary parts to get the demodulated amplitude envelope waveform.

Filters operate on a single analog channel source or on a lower math function.

- Visualizations:
  - MAGNify – Operates on a single analog channel source or on a lower math function.
  - MAXimum – This operator is like the MAXHold operator without the hold. The maximum vertical values found at each horizontal bucket are used to build a waveform.
  - MINimum – This operator is like the MINHold operator without the hold. The minimum vertical values found at each horizontal bucket are used to build a waveform.
  - PEAK – The PEAK operator is like the MAXimum operator minus the MINimum operator. At each horizontal bucket, the minimum vertical values found are subtracted from the maximum vertical values found to build a waveform.
  - MAXHold – Operates on a single analog channel source or on a lower math function. The Max Hold (or Max Envelope) operator records the maximum vertical values found at each horizontal bucket across multiple analysis cycles and uses those values to build a waveform.
  - MINHold – Operates on a single analog channel source or on a lower math function. The Min Hold (or Min Envelope) operator records the minimum vertical values found at each horizontal bucket across multiple analysis cycles and uses those values to build a waveform.
  - TRENd – Measurement trend – Operates on a single analog channel source. The TRENd:NMEasurement command selects the measurement whose trend you want to measure.
  - BTIMing – Chart logic bus timing – Operates on a bus made up of digital channels. The BUS:YINCREMENT, BUS:YORIGIN, and BUS:YUNITS commands specify function values.
  - BSTate – Chart logic bus state – Operates on a bus made up of digital channels. The BUS:YINCREMENT, BUS:YORIGIN, and BUS:YUNIT commands specify function values. The BUS:CLOCK and BUS:SLOPe commands specify the clock source and edge.

- SERChart – Chart serial signal – Operates on a serial decode that is displaying symbolic data values. For example, CAN or LIN symbolic display or the SENT transfer function display allow charting of serial data values.

**NOTE**

If a math function is on (see :FUNCTION<m>:DISPLAY), changing the operator will cause an automatic vertical scaling of the new math function waveform. If you wait for the operation to complete (with an \*OPC? query for example), then query the math functions's scale, you can see the vertical scaling that was automatically determined.

**Query Syntax**    `:FUNCTION<m>:OPERation?`

The :FUNCTION<m>:OPERation? query returns the current operation for the selected function.

**Return Format**    `<operation><NL>`

```
<operation> ::= {ADD | SUBT | MULT | DIV | INT | DIFF | FFT | FFTP
| SQRT | MAGN | ABS | SQU | LN | LOG | EXP | TEN | LOWP | HIGH
| BAND | AVER | SMO | ENV | LIN | MAX | MIN | PEAK | MAXH | MINH
| TREN | BTIM | BST | SERC}
```

**See Also**

- "[Introduction to :FUNCTION<m> Commands](#)" on page 491
- "[":FUNCTION<m>:DISPLAY](#)" on page 499
- "["\\*OPC \(Operation Complete\)](#)" on page 240
- "[":FUNCTION<m>:SOURCE1](#)" on page 537
- "[":FUNCTION<m>:SOURCE2](#)" on page 539
- "[":FUNCTION<m>:INTegrate:ICCondition](#)" on page 518
- "[":FUNCTION<m>:INTegrate:IOFFset](#)" on page 519
- "[":FUNCTION<m>\[:FFT\]:SPAN](#)" on page 510
- "[":FUNCTION<m>\[:FFT\]:CENTer](#)" on page 501
- "[":FUNCTION<m>\[:FFT\]:PHASE:REFERENCE](#)" on page 507
- "[":FUNCTION<m>\[:FFT\]:VTYPE](#)" on page 512
- "[":FUNCTION<m>\[:FFT\]:WINDOW](#)" on page 513
- "[":FUNCTION<m>:LINEAR:GAIN](#)" on page 520
- "[":FUNCTION<m>:LINEAR:OFFSet](#)" on page 521
- "[":FUNCTION<m>:FREQUENCY:BANDpass:CENTER](#)" on page 514
- "[":FUNCTION<m>:FREQUENCY:BANDpass:WIDTH](#)" on page 515
- "[":FUNCTION<m>:FREQUENCY:LOWPass](#)" on page 517
- "[":FUNCTION<m>:FREQUENCY:HIGHpass](#)" on page 516
- "[":FUNCTION<m>:AVERage:COUNT](#)" on page 492
- "[":FUNCTION<m>:SMOoth:POINTS](#)" on page 536

- "[:FUNCTION<m>:TRENd:NMEasurement](#)" on page 540
- "[:FUNCTION<m>:SERChart:SOURce](#)" on page 531
- "[:FUNCTION<m>:SERChart:TIME:MODE](#)" on page 532
- "[:FUNCTION<m>:SERChart:TIME:RANGE](#)" on page 534
- "[:FUNCTION<m>:SERChart:TIME:OFFSet](#)" on page 535
- "[:FUNCTION<m>:BUS:YINCREMENT](#)" on page 495
- "[:FUNCTION<m>:BUS:YORIGIN](#)" on page 496
- "[:FUNCTION<m>:BUS:YUNITS](#)" on page 497
- "[:FUNCTION<m>:BUS:CLOCK](#)" on page 493
- "[:FUNCTION<m>:BUS:SLOPe](#)" on page 494

## :FUNCTION<m>:RANGE

**N** (see [page 1666](#))

|                       |                                                                                                                                                                                          |
|-----------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Command Syntax</b> | <code>:FUNCTION&lt;m&gt;:RANGE &lt;range&gt;</code>                                                                                                                                      |
|                       | <code>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</code>                                                                                                                         |
|                       | <code>&lt;range&gt; ::= the full-scale vertical axis value in NR3 format.</code>                                                                                                         |
|                       | The :FUNCTION<m>:RANGE command defines the full-scale vertical axis for the selected function.                                                                                           |
| <b>Query Syntax</b>   | <code>:FUNCTION&lt;m&gt;:RANGE?</code>                                                                                                                                                   |
|                       | The :FUNCTION<m>:RANGE? query returns the current full-scale range value for the selected function.                                                                                      |
| <b>Return Format</b>  | <code>&lt;range&gt;&lt;NL&gt;</code>                                                                                                                                                     |
|                       | <code>&lt;range&gt; ::= the full-scale vertical axis value in NR3 format.</code>                                                                                                         |
| <b>See Also</b>       | <ul style="list-style-type: none"><li><a href="#">"Introduction to :FUNCTION&lt;m&gt; Commands"</a> on page 491</li><li><a href="#">":FUNCTION&lt;m&gt;:SCALe"</a> on page 530</li></ul> |

## :FUNCTION<m>:REFerence

**N** (see [page 1666](#))

**Command Syntax** :FUNCTION<m>:REFerence <level>

<m> ::= 1 to (# math functions) in NR1 format

<level> ::= the current reference level in NR3 format.

The :FUNCTION<m>:REFerence command sets the voltage or vertical value represented at center screen for the selected function. The range of legal values is generally +/-10 times the current scale of the selected function, but will vary by function. If you set the reference level to a value outside of the legal range, the level is automatically set to the nearest legal value.

### NOTE

The FUNCTION:REFerence command is equivalent to the :FUNCTION<m>:OFFSet command.

**Query Syntax** :FUNCTION<m>:REFerence?

The :FUNCTION<m>:REFerence? query outputs the current reference level value for the selected function.

**Return Format** <level><NL>

<level> ::= the current reference level in NR3 format.

**See Also**

- "[Introduction to :FUNCTION<m> Commands](#)" on page 491
- "[":FUNCTION<m>:OFFSet](#)" on page 522
- "[":FUNCTION<m>:RANGE](#)" on page 528
- "[":FUNCTION<m>:SCALE](#)" on page 530

## :FUNCTION<m>:SCALE

**N** (see [page 1666](#))

**Command Syntax**    `:FUNCTION<m>:SCALE <scale value>[<suffix>]`

`<m> ::= 1 to (# math functions) in NR1 format`

`<scale value> ::= vertical units/div value in NR3 format`

`<suffix> ::= {V | dB}`

The :FUNCTION<m>:SCALE command sets the vertical scale, or units per division, of the selected function. Legal values for the scale depend on the selected function.

### NOTE

Automatic vertical scaling of the math function waveform occurs when the function display is turned from off to on (see :FUNCTION<m>:DISPLAY) or, if the function is already on, when the operation is changed (see :FUNCTION<m>:OPERATION). If you want to change the math function's vertical scaling, you should do it after the math function display is turned on or after the operation is changed.

**Query Syntax**    `:FUNCTION<m>:SCALE?`

The :FUNCTION<m>:SCALE? query returns the current scale value for the selected function.

**Return Format**    `<scale value><NL>`

`<scale value> ::= vertical units/div value in NR3 format`

**See Also**

- "[Introduction to :FUNCTION<m> Commands](#)" on page 491
- "[":FUNCTION<m>:DISPLAY](#)" on page 499
- "[":FUNCTION<m>:OPERATION](#)" on page 523
- "[":FUNCTION<m>:RANGE](#)" on page 528

## :FUNCTION<m>:SERChart:SOURce

**N** (see [page 1666](#))

**Command Syntax**    `:FUNCTION<m>:SERChart:SOURce <serialbus>`

```
<m> ::= 1 to (# math functions) in NR1 format
<serialbus> ::= {SBUS<n>}
<n> :: 1 to (# of serial bus) in NR1 format
```

The :FUNCTION<m>:SERChart:SOURce command sets the serial bus source for the Chart Serial Signal math function.

**Query Syntax**    `:FUNCTION<m>:SERChart:SOURce?`

The :FUNCTION<m>:SERChart:SOURce? query returns the serial bus source.

**Return Format**    `<serialbus><NL>`

```
<serialbus> ::= {SBUS<n>}
```

**See Also**

- "[:FUNCTION<m>:OPERation](#)" on page 523
- "[:FUNCTION<m>:SERChart:TIME:MODE](#)" on page 532
- "[:FUNCTION<m>:SERChart:TIME:RANGE](#)" on page 534
- "[:FUNCTION<m>:SERChart:TIME:OFFSET](#)" on page 535

## :FUNCTION<m>:SERChart:TIME:MODE

**N** (see [page 1666](#))

### Command Syntax

```
:FUNCTION<m>:SERChart:TIME:MODE <value>
<m> ::= 1 to (# math functions) in NR1 format
<value> ::= {MAIN | ROLL}
```

The :FUNCTION<m>:SERChart:TIME:MODE command sets the time mode for the Chart Serial Signal math function:

- MAIN – The signal data values are plotted per acquisition, in the same horizontal time scale as the other waveforms, and all waveform data is time-correlated.

In this mode, the oscilloscope's timebase (time/div) is typically set for a long acquisition time to capture multiple occurrences of the message/frame/packet that contains the signal to be charted.

If the timebase is set to longer than 200 ms/div for high-speed CAN or SENT, undersampling may occur due to limited acquisition memory and reduced sample rate. Timebase settings for LIN can usually be much longer.

- ROLL – The signal data values are plotted at the right side of the display and roll across the display for a specified amount of time. This resulting math function waveform is not time-correlated with other waveforms on the display.

Roll mode establishes a second and typically much slower timebase and is useful for charting very slow changing signals (up to 1 hour), such as temperature or pressure.

Signal values are typically under-sampled (not every occurrence of a signal will be plotted). Signal values roll across the display as new signal values are received and plotted.

If charting a CAN or LIN signal in this mode, you should set up the oscilloscope to trigger on the message/frame that contains the signal.

If charting SENT, the oscilloscope should be set up to trigger on the start of any Fast Channel Message (":SBUS<n>:SENT:TRIGger SFCMessage").

In Roll mode, the oscilloscope's main timebase setting is typically set to capture just a few messages.

### Query Syntax

```
:FUNCTION<m>:SERChart:TIME:MODE?
```

The :FUNCTION<m>:SERChart:TIME:MODE? query returns the time mode setting.

### Return Format

```
<value><NL>
<value> ::= {MAIN | ROLL}
```

### See Also

- "[:FUNCTION<m>:OPERation](#)" on page 523

- "[:FUNCTION<m>:SERChart:SOURce](#)" on page 531
- "[:FUNCTION<m>:SERChart:TIME:RANGE](#)" on page 534
- "[:FUNCTION<m>:SERChart:TIME:OFFSet](#)" on page 535
- "[:SBUS<n>:SENT:TRIGger](#)" on page 1116

## :FUNCTION<m>:SERChart:TIME:RANGE

**N** (see [page 1666](#))

**Command Syntax**    `:FUNCTION<m>:SERChart:TIME:RANGE <range_value>`

`<m> ::= 1 to (# math functions) in NR1 format`

`<range_value> ::= time value in NR3 format`

When the ROLL serial chart time mode is selected (see [:FUNCTION<m>:SERChart:TIME:MODE](#)), the [:FUNCTION<m>:SERChart:TIME:RANGE](#) command sets the full-scale time range value for the Chart Serial Signal math function.

The time range defines the width across the display for the charted serial signal waveform.

When oscilloscope acquisitions are stopped, you can adjust the time offset and time range to scroll and zoom the plotted signal values.

**Query Syntax**    `:FUNCTION<m>:SERChart:TIME:RANGE?`

The [:FUNCTION<m>:SERChart:TIME:RANGE?](#) query returns the time range setting.

**Return Format**    `<range_value><NL>`

`<range_value> ::= time value in NR3 format`

**See Also**

- [":FUNCTION<m>:OPERATION"](#) on page 523
- [":FUNCTION<m>:SERChart:SOURce"](#) on page 531
- [":FUNCTION<m>:SERChart:TIME:MODE"](#) on page 532
- [":FUNCTION<m>:SERChart:TIME:OFFSet"](#) on page 535

## :FUNCTION<m>:SERChart:TIME:OFFSet

**N** (see [page 1666](#))

|                       |                                                                                                                                                                                                                                                                                                                                                           |
|-----------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Command Syntax</b> | <code>:FUNCTION&lt;m&gt;:SERChart:TIME:OFFSet &lt;offset&gt;</code><br><code>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</code><br><code>&lt;offset&gt; ::= time offset value in NR3 format</code>                                                                                                                                                |
|                       | When the ROLL serial chart time mode is selected (see <a href="#">:FUNCTION&lt;m&gt;:SERChart:TIME:MODE</a> ), the <a href="#">:FUNCTION&lt;m&gt;:SERChart:TIME:OFFSet</a> command sets the time offset for the Chart Serial Signal math function.                                                                                                        |
|                       | The time offset shows the time value of the center of the display. When oscilloscope acquisitions are running, the time offset is automatically set to the middle of the time range.                                                                                                                                                                      |
|                       | When oscilloscope acquisitions are stopped, you can adjust the time offset and time range to scroll and zoom the plotted signal values.                                                                                                                                                                                                                   |
| <b>Query Syntax</b>   | <code>:FUNCTION&lt;m&gt;:SERChart:TIME:OFFSet?</code>                                                                                                                                                                                                                                                                                                     |
|                       | The <code>:FUNCTION&lt;m&gt;:SERChart:TIME:OFFSet?</code> query returns the time offset setting.                                                                                                                                                                                                                                                          |
| <b>Return Format</b>  | <code>&lt;offset&gt;&lt;NL&gt;</code><br><code>&lt;offset&gt; ::= time offset value in NR3 format</code>                                                                                                                                                                                                                                                  |
| <b>See Also</b>       | <ul style="list-style-type: none"> <li>• "<a href="#">:FUNCTION&lt;m&gt;:OPERation</a>" on page 523</li> <li>• "<a href="#">:FUNCTION&lt;m&gt;:SERChart:SOURce</a>" on page 531</li> <li>• "<a href="#">:FUNCTION&lt;m&gt;:SERChart:TIME:MODE</a>" on page 532</li> <li>• "<a href="#">:FUNCTION&lt;m&gt;:SERChart:TIME:RANGE</a>" on page 534</li> </ul> |

## :FUNCTION<m>:SMOoth:POINTs

**N** (see [page 1666](#))

- Command Syntax**    `:FUNCTION<m>:SMOoth:POINTs <points>`  
`<points> ::= odd integer in NR1 format`
- When the :FUNCTION<m>:OPERation is SMOoth, the :FUNCTION<m>:SMOoth:POINTs command sets the number of smoothing points to use.
- You can choose an odd number of points, from 3 up to half of the measurement record or precision analysis record.
- Query Syntax**    `:FUNCTION<m>:SMOoth:POINTs?`
- The :FUNCTION<m>:SMOoth:POINTs? query returns the number of smoothing points specified.
- Return Format**    `<points><NL>`
- See Also**    • [":FUNCTION<m>:OPERation"](#) on page 523

## :FUNCTION<m>:SOURce1

**N** (see [page 1666](#))

**Command Syntax**

```
:FUNCTION<m>:SOURce1 <value>
<m> ::= 1 to (# math functions) in NR1 format
<value> ::= {CHANnel<n> | FUNCTION<c> | MATH<c> | WMEMORY<r> | BUS<b>}
<n> ::= 1 to (# analog channels) in NR1 format
<c> ::= {1}, must be lower than <m>
<r> ::= 1 to (# ref waveforms) in NR1 format
<b> ::= {1 | 2}
```

The :FUNCTION<m>:SOURce1 command is used for any :FUNCTION<m>:OPERation selection. This command selects the first source for the operator math functions or the single source for the transform functions, filter functions, or visualization functions.

The FUNCTION<c> or MATH<c> parameters are available for the transform functions, filter functions, and the magnify visualization function (see ["Introduction to :FUNCTION<m> Commands" on page 491](#)) when <c> is lower than <m>.

In other words, higher math functions can operate on lower math functions when using operators other than the simple arithmetic operations (+, -, \*, /). For example, if :FUNCTION1:OPERation is a SUBTract of CHANnel1 and CHANnel2, the :FUNCTION2:OPERation could be set up as a FFT operation on the FUNCTION1 source. These are called cascaded math functions.

To cascade math functions, select the lower math function using the :FUNCTION<m>:SOURce1 command.

When cascading math functions, to get the most accurate results, be sure to vertically scale lower math functions so that their waveforms take up the full screen without being clipped.

The BUS<m> parameter is available for the bus charting visualization functions.

### NOTE

Another shorthand notation for SOURce1 in this command/query (besides SOUR1) is SOUR.

---

When :FUNCTION<m>:OPERation is TRENd, the :FUNCTION<m>:SOURce1 command reports error -221, "Settings conflict" because the TRENd function operates on a measurement and not a source waveform.

**Query Syntax**

```
:FUNCTION<m>:SOURce1?
```

The :FUNCTION<m>:SOURce1? query returns the current source1 for function operations.

When :FUNCTION<m>:OPERation is TRENd, the :FUNCTION<m>:SOURce1? query returns the source of the measurement.

**Return Format**

```
<value><NL>
<value> ::= {CHAN<n> | FUNC<c> | WMEM<r> | BUS<b>}
```

**See Also**

- "[Introduction to :FUNCTION<m> Commands](#)" on page 491
- "[:FUNCTION<m>:OPERation](#)" on page 523

## :FUNCTION<m>:SOURce2

**N** (see [page 1666](#))

|                       |                                                                                                                                                                                |
|-----------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>Command Syntax</b> | <code>:FUNCTION&lt;m&gt;:SOURce2 &lt;value&gt;</code>                                                                                                                          |
|                       | <code>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</code>                                                                                                               |
|                       | <code>&lt;value&gt; ::= {CHANnel&lt;n&gt;   WMEMory&lt;r&gt;   NONE}</code>                                                                                                    |
|                       | <code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>                                                                                                              |
|                       | <code>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</code>                                                                                                                |
|                       | The :FUNCTION<m>:SOURce2 command specifies the second source for math operator functions that have two sources. (The :FUNCTION<m>:SOURce1 command specifies the first source.) |

The :FUNCTION<m>:SOURce2 setting is not used for the transform functions, filter functions, or visualization functions (except when the measurement trend visualization's measurement requires two sources).

When :FUNCTION<m>:OPERation is TRENd, the :FUNCTION<m>:SOURce2 command reports error -221, "Settings conflict" because the TRENd function operates on a measurement and not a source waveform.

|                     |                                                                                                    |
|---------------------|----------------------------------------------------------------------------------------------------|
| <b>Query Syntax</b> | <code>:FUNCTION&lt;m&gt;:SOURce2?</code>                                                           |
|                     | The :FUNCTION<m>:SOURce2? query returns the currently specified second source for math operations. |

When :FUNCTION<m>:OPERation is TRENd, the :FUNCTION<m>:SOURce2? query returns the source of the measurement.

|                      |                                                                       |
|----------------------|-----------------------------------------------------------------------|
| <b>Return Format</b> | <code>&lt;value&gt;&lt;NL&gt;</code>                                  |
|                      | <code>&lt;value&gt; ::= {CHAN&lt;n&gt;   WMEM&lt;r&gt;   NONE}</code> |

|                 |                                                                                                                                                                                                                                                                           |
|-----------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>See Also</b> | <ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :FUNCTION&lt;m&gt; Commands</a>" on page 491</li> <li>• "<a href="#">":FUNCTION&lt;m&gt;:OPERation</a>" on page 523</li> <li>• "<a href="#">":FUNCTION&lt;m&gt;:SOURce1</a>" on page 537</li> </ul> |
|-----------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

## :FUNCTION<m>:TREND:NMEasurement

**N** (see [page 1666](#))

- Command Syntax**
- ```
:FUNCTION<m>:TREND:NMEasurement MEAS<n>
<n> ::= # of installed measurement, from 1 to 8
<m> ::= 1 to (# math functions) in NR1 format
```
- The :FUNCTION<m>:TREND:NMEasurement command selects the measurement whose trend is shown in the math waveform.
- There are 8 locations (or slots) that installed measurements can occupy. The MEAS<n> parameter specifies the location of the measurement whose trend you want to analyze.

You can view the trend math function waveform for these installed measurements:

- :MEASure:VAVerage, <interval> ::= CYCLE
- :MEASure:VRMS, <type> ::= AC (AC RMS)
- :MEASure:VRATio, <interval> ::= CYCLE
- :MEASure:PERiod
- :MEASure:FREQuency
- :MEASure:PWIDTH
- :MEASure:NWIDTH
- :MEASure:DUTYcycle
- :MEASure:NDUTy
- :MEASure:RISetime
- :MEASure:FALLtime

- Query Syntax**
- ```
:FUNCTION<m>:TREND:NMEasurement?
```

The :FUNCTION<m>:TREND:NMEasurement? query returns the selected measurement.

If no measurements are installed, the :FUNCTION<m>:TREND:NMEasurement? query will return NONE.

- Return Format**
- ```
MEAS<n><NL>
<n> ::= # of installed measurement, from 1 to 8
```
- See Also**
- "[:FUNCTION<m>:OPERation](#)" on page 523

# 22 :HARDcopy/:HCOPY Commands

Set and query the selection of hardcopy device and formatting options. See "Introduction to :HARDcopy Commands" on page 542.

**Table 111** :HARDcopy/:HCOPY Commands Summary

Command	Query	Options and Query Returns
:HARDcopy:AREA <area> (see <a href="#">page 544</a> )	:HARDcopy:AREA? (see <a href="#">page 544</a> )	<area> ::= SCReen
:HARDcopy:APRinter <active_printer> (see <a href="#">page 545</a> )	:HARDcopy:APRinter? (see <a href="#">page 545</a> )	<active_printer> ::= {<index>   <name>} <index> ::= integer index of printer in list <name> ::= name of printer in list
:HARDcopy:FACTors {{0   OFF}   {1   ON}} (see <a href="#">page 546</a> )	:HARDcopy:FACTors? (see <a href="#">page 546</a> )	{0   1}
:HARDcopy:FFEed {{0   OFF}   {1   ON}} (see <a href="#">page 547</a> )	:HARDcopy:FFEed? (see <a href="#">page 547</a> )	{0   1}
:HARDcopy:INKSaver { {0   OFF}   {1   ON} } (see <a href="#">page 548</a> )	:HARDcopy:INKSaver? (see <a href="#">page 548</a> )	{0   1}
:HARDcopy:LAYout <layout> (see <a href="#">page 549</a> )	:HARDcopy:LAYout? (see <a href="#">page 549</a> )	<layout> ::= {LANDscape   PORTRait}
:HARDcopy:NETWork:ADD Ress <address> (see <a href="#">page 550</a> )	:HARDcopy:NETWork:ADD Ress? (see <a href="#">page 550</a> )	<address> ::= quoted ASCII string
:HARDcopy:NETWork:APP Ly (see <a href="#">page 551</a> )	n/a	n/a

**Table 111** :HARDcopy/:HCOPY Commands Summary (continued)

Command	Query	Options and Query Returns
:HARDcopy:NETWork:DOMain <domain> (see <a href="#">page 552</a> )	:HARDcopy:NETWork:DOMain? (see <a href="#">page 552</a> )	<domain> ::= quoted ASCII string
:HARDcopy:NETWork:PASWord <password> (see <a href="#">page 553</a> )	n/a	<password> ::= quoted ASCII string
:HARDcopy:NETWork:SLOT <slot> (see <a href="#">page 554</a> )	:HARDcopy:NETWork:SLOT? (see <a href="#">page 554</a> )	<slot> ::= {NET0   NET1}
:HARDcopy:NETWork:USERname <username> (see <a href="#">page 555</a> )	:HARDcopy:NETWork:USERname? (see <a href="#">page 555</a> )	<username> ::= quoted ASCII string
:HARDcopy:PALETTE <palette> (see <a href="#">page 556</a> )	:HARDcopy:PALETTE? (see <a href="#">page 556</a> )	<palette> ::= {COLOR   GRAYscale   NONE}
n/a	:HARDcopy:PRINTER:LISIT? (see <a href="#">page 557</a> )	<list> ::= [<printer_spec>] ... <printer_spec> ::= "<index>,<active>,<name>;" <index> ::= integer index of printer <active> ::= {Y   N} <name> ::= name of printer
:HARDcopy:STARt (see <a href="#">page 558</a> )	n/a	n/a
n/a	:HCOPY:SDUMp:DATA? (see <a href="#">page 559</a> )	<display_data> ::= binary block data in IEEE-488.2 # format.
:HCOPY:SDUMp:FORMAT <format> (see <a href="#">page 560</a> )	:HCOPY:SDUMp:FORMAT? (see <a href="#">page 560</a> )	<format> ::= {BMP   BMP8bit   PNG}

**Introduction to :HARDcopy Commands** The HARDcopy subsystem provides commands to set and query the selection of hardcopy device and formatting options such as inclusion of instrument settings (FACTors) and generation of formfeed (FFEed).

:HARDC or :HCOPY are acceptable short forms for :HARDcopy.

#### Reporting the Setup

Use :HARDcopy? to query setup information for the HARDcopy subsystem.

### Return Format

The following is a sample response from the :HARDcopy? query. In this case, the query was issued following the \*RST command.

```
:HARD:APR "";AREA SCR;FACT 0;FFE 0;INKS 1;PAL NONE;LAY PORT
```

## :HARDcopy:AREA

**N** (see [page 1666](#))

**Command Syntax**    `:HARDcopy:AREA <area>`  
                      `<area> ::= SCReen`

The :HARDcopy:AREA command controls what part of the display area is printed. Currently, the only legal choice is SCReen.

**Query Syntax**    `:HARDcopy:AREA?`  
The :HARDcopy:AREA? query returns the selected display area.

**Return Format**    `<area><NL>`  
                      `<area> ::= SCR`

**See Also**

- "[Introduction to :HARDcopy Commands](#)" on page 542
- "[":HARDcopy:STARt](#)" on page 558
- "[":HARDcopy:APRinter](#)" on page 545
- "[":HARDcopy:PRINTER:LIST](#)" on page 557
- "[":HARDcopy:FACTors](#)" on page 546
- "[":HARDcopy:FFEed](#)" on page 547
- "[":HARDcopy:INKSaver](#)" on page 548
- "[":HARDcopy:LAYOUT](#)" on page 549
- "[":HARDcopy:PALETTE](#)" on page 556

## :HARDcopy:APRinter

**N** (see [page 1666](#))

**Command Syntax**    :HARDcopy:APRinter <active\_printer>  
                  <active\_printer> ::= {<index> | <name>}  
                  <index> ::= integer index of printer in list  
                  <name> ::= name of printer in list

The :HARDcopy:APRinter command sets the active printer.

**Query Syntax**    :HARDcopy:APRinter?

The :HARDcopy:APRinter? query returns the name of the active printer.

**Return Format**    <name><NL>  
                  <name> ::= name of printer in list

**See Also**    · "Introduction to :HARDcopy Commands" on page 542  
                  · ":HARDcopy:PRINTER:LIST" on page 557  
                  · ":HARDcopy:START" on page 558

## :HARDcopy:FACTors

**N** (see [page 1666](#))

**Command Syntax**    `:HARDcopy:FACTors <factors>`

`<factors> ::= {{OFF | 0} | {ON | 1}}`

The HARDcopy:FACTors command controls whether the scale factors are output on the hardcopy dump.

**Query Syntax**    `:HARDcopy:FACTors?`

The :HARDcopy:FACTors? query returns a flag indicating whether oscilloscope instrument settings are output on the hardcopy.

**Return Format**    `<factors><NL>`

`<factors> ::= {0 | 1}`

**See Also**

- "Introduction to :HARDcopy Commands" on page 542
- "[:HARDcopy:STARt](#)" on page 558
- "[:HARDcopy:FFEed](#)" on page 547
- "[:HARDcopy:INKSaver](#)" on page 548
- "[:HARDcopy:LAYout](#)" on page 549
- "[:HARDcopy:PAlette](#)" on page 556

## :HARDcopy:FFEed

**N** (see [page 1666](#))

**Command Syntax** :HARDcopy:FFEed <ffeed>

<ffeed> ::= {{OFF | 0} | {ON | 1}}

The HARDcopy:FFEed command controls whether a formfeed is output between the screen image and factors of a hardcopy dump.

**Query Syntax** :HARDcopy:FFEed?

The :HARDcopy:FFEed? query returns a flag indicating whether a formfeed is output at the end of the hardcopy dump.

**Return Format** <ffeed><NL>

<ffeed> ::= {0 | 1}

**See Also**

- "[Introduction to :HARDcopy Commands](#)" on page 542
- "[":HARDcopy:STARt](#)" on page 558
- "[":HARDcopy:FACTors](#)" on page 546
- "[":HARDcopy:INKSaver](#)" on page 548
- "[":HARDcopy:LAYout](#)" on page 549
- "[":HARDcopy:PAlette](#)" on page 556

## :HARDcopy:INKSaver

**N** (see [page 1666](#))

**Command Syntax**    `:HARDcopy:INKSaver <value>`

`<value> ::= {{OFF | 0} | {ON | 1}}`

The HARDcopy:INKSaver command controls whether the graticule colors are inverted or not.

**Query Syntax**    `:HARDcopy:INKSaver?`

The :HARDcopy:INKSaver? query returns a flag indicating whether graticule colors are inverted or not.

**Return Format**    `<value><NL>`

`<value> ::= {0 | 1}`

**See Also**

- "[Introduction to :HARDcopy Commands](#)" on page 542
- "[":HARDcopy:STARt](#)" on page 558
- "[":HARDcopy:FACTors](#)" on page 546
- "[":HARDcopy:FFEed](#)" on page 547
- "[":HARDcopy:LAYout](#)" on page 549
- "[":HARDcopy:PAlette](#)" on page 556

## :HARDcopy:LAYout

**N** (see [page 1666](#))

**Command Syntax** :HARDcopy:LAYout <layout>

<layout> ::= {LANDscape | PORTrait}

The :HARDcopy:LAYout command sets the hardcopy layout mode.

**Query Syntax** :HARDcopy:LAYout?

The :HARDcopy:LAYout? query returns the selected hardcopy layout mode.

**Return Format** <layout><NL>

<layout> ::= {LAND | PORT}

**See Also**

- "[Introduction to :HARDcopy Commands](#)" on page 542
- "[":HARDcopy:STARt](#)" on page 558
- "[":HARDcopy:FACTors](#)" on page 546
- "[":HARDcopy:PAlette](#)" on page 556
- "[":HARDcopy:FFEed](#)" on page 547
- "[":HARDcopy:INKSaver](#)" on page 548

## :HARDcopy:NETWork:ADDRess

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:HARDcopy:NETWork:ADDRess &lt;address&gt;</code> <code>&lt;address&gt; ::= quoted ASCII string</code>
	The :HARDcopy:NETWork:ADDRess command sets the address for a network printer slot. The address is the server/computer name and the printer's share name in the \\server\\share format.
	The network printer slot is selected by the :HARDcopy:NETWork:SLOT command.
	To apply the entered address, use the :HARDcopy:NETWork:APPLy command.
<b>Query Syntax</b>	<code>:HARDcopy:NETWork:ADDRess?</code>
	The :HARDcopy:NETWork:ADDRess? query returns the specified address for the currently selected network printer slot.
<b>Return Format</b>	<code>&lt;address&gt;&lt;NL&gt;</code> <code>&lt;address&gt; ::= quoted ASCII string</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">"Introduction to :HARDcopy Commands" on page 542</a></li><li><a href="#">":HARDcopy:NETWork:SLOT" on page 554</a></li><li><a href="#">":HARDcopy:NETWork:APPLy" on page 551</a></li><li><a href="#">":HARDcopy:NETWork:DOMain" on page 552</a></li><li><a href="#">":HARDcopy:NETWork:USERname" on page 555</a></li><li><a href="#">":HARDcopy:NETWork:PASSword" on page 553</a></li></ul>

## :HARDcopy:NETWork:APPLy

**N** (see [page 1666](#))

**Command Syntax** :HARDcopy:NETWork:APPLy

The :HARDcopy:NETWork:APPLy command applies the network printer settings and makes the printer connection.

**See Also**

- "[Introduction to :HARDcopy Commands](#)" on page 542
- "[":HARDcopy:NETWork:SLOT](#)" on page 554
- "[":HARDcopy:NETWork:ADDResS](#)" on page 550
- "[":HARDcopy:NETWork:DOMain](#)" on page 552
- "[":HARDcopy:NETWork:USERname](#)" on page 555
- "[":HARDcopy:NETWork:PASSword](#)" on page 553

## :HARDcopy:NETWork:DOMain

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:HARDcopy:NETWork:DOMain &lt;domain&gt;</code> <code>&lt;domain&gt; ::= quoted ASCII string</code>
	The :HARDcopy:NETWork:DOMain command sets the Windows network domain name.
	The domain name setting is a common setting for both network printer slots.
<b>Query Syntax</b>	<code>:HARDcopy:NETWork:DOMain?</code>
	The :HARDcopy:NETWork:DOMain? query returns the current Windows network domain name.
<b>Return Format</b>	<code>&lt;domain&gt;&lt;NL&gt;</code> <code>&lt;domain&gt; ::= quoted ASCII string</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">"Introduction to :HARDcopy Commands"</a> on page 542</li><li><a href="#">":HARDcopy:NETWork:SLOT"</a> on page 554</li><li><a href="#">":HARDcopy:NETWork:APPLy"</a> on page 551</li><li><a href="#">":HARDcopy:NETWork:ADDRess"</a> on page 550</li><li><a href="#">":HARDcopy:NETWork:USERname"</a> on page 555</li><li><a href="#">":HARDcopy:NETWork:PASSword"</a> on page 553</li></ul>

## :HARDcopy:NETWork:PASSword

**N** (see [page 1666](#))

**Command Syntax** :HARDcopy:NETWork:PASSword <password>

<password> ::= quoted ASCII string

The :HARDcopy:NETWork:PASSword command sets the password for the specified Windows network domain and user name.

The password setting is a common setting for both network printer slots.

**See Also**

- "[Introduction to :HARDcopy Commands](#)" on page 542
- "[":HARDcopy:NETWork:USERname](#)" on page 555
- "[":HARDcopy:NETWork:DOMain](#)" on page 552
- "[":HARDcopy:NETWork:SLOT](#)" on page 554
- "[":HARDcopy:NETWork:APPLy](#)" on page 551
- "[":HARDcopy:NETWork:ADDRess](#)" on page 550

## :HARDcopy:NETWork:SLOT

**N** (see [page 1666](#))

**Command Syntax**    `:HARDcopy:NETWork:SLOT <slot>`  
                  `<slot> ::= {NET0 | NET1}`

The :HARDcopy:NETWork:SLOT command selects the network printer slot used for the address and apply commands. There are two network printer slots to choose from.

**Query Syntax**    `:HARDcopy:NETWork:SLOT?`

The :HARDcopy:NETWork:SLOT? query returns the currently selected network printer slot.

**Return Format**    `<slot><NL>`  
                  `<slot> ::= {NET0 | NET1}`

**See Also**

- "[Introduction to :HARDcopy Commands](#)" on page 542
- "[":HARDcopy:NETWork:APPLy](#)" on page 551
- "[":HARDcopy:NETWork:ADDRess](#)" on page 550
- "[":HARDcopy:NETWork:DOMain](#)" on page 552
- "[":HARDcopy:NETWork:USERname](#)" on page 555
- "[":HARDcopy:NETWork:PASSword](#)" on page 553

## :HARDcopy:NETWork:USERname

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:HARDcopy:NETWork:USERname &lt;username&gt;</code> <code>&lt;username&gt; ::= quoted ASCII string</code>
	The :HARDcopy:NETWork:USERname command sets the user name to use when connecting to the Windows network domain.
	The user name setting is a common setting for both network printer slots.
<b>Query Syntax</b>	<code>:HARDcopy:NETWork:USERname?</code>
	The :HARDcopy:NETWork:USERname? query returns the currently set user name.
<b>Return Format</b>	<code>&lt;username&gt;&lt;NL&gt;</code> <code>&lt;username&gt; ::= quoted ASCII string</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">Introduction to :HARDcopy Commands</a>" on page 542</li> <li>· "<a href="#">":HARDcopy:NETWork:DOMain</a>" on page 552</li> <li>· "<a href="#">":HARDcopy:NETWork:PASSword</a>" on page 553</li> <li>· "<a href="#">":HARDcopy:NETWork:SLOT</a>" on page 554</li> <li>· "<a href="#">":HARDcopy:NETWork:APPLy</a>" on page 551</li> <li>· "<a href="#">":HARDcopy:NETWork:ADDRess</a>" on page 550</li> </ul>

## :HARDcopy:PAlette

**N** (see [page 1666](#))

**Command Syntax**    `:HARDcopy:PAlette <palette>`

`<palette> ::= {COLor | GRAYscale | NONE}`

The :HARDcopy:PAlette command sets the hardcopy palette color.

The oscilloscope's print driver cannot print color images to color laser printers, so the COLor option is not available when connected to laser printers.

**Query Syntax**    `:HARDcopy:PAlette?`

The :HARDcopy:PAlette? query returns the selected hardcopy palette color.

**Return Format**    `<palette><NL>`

`<palette> ::= {COL | GRAY | NONE}`

- See Also**
- "Introduction to :HARDcopy Commands" on page 542
  - "[:HARDcopy:STARt](#)" on page 558
  - "[:HARDcopy:FACTors](#)" on page 546
  - "[:HARDcopy:LAYOUT](#)" on page 549
  - "[:HARDcopy:FFEed](#)" on page 547
  - "[:HARDcopy:INKSaver](#)" on page 548

## :HARDcopy:PRINTER:LIST

**N** (see [page 1666](#))

**Query Syntax** :HARDcopy:PRINTER:LIST?

The :HARDcopy:PRINTER:LIST? query returns a list of available printers. The list can be empty.

**Return Format**

```
<list><NL>
<list> ::= [<printer_spec>] ... [<printer_spec>]
<printer_spec> ::= "<index>,<active>,<name>;"
<index> ::= integer index of printer
<active> ::= {Y | N}
<name> ::= name of printer (for example "DESKJET 950C")
```

**See Also**

- "[Introduction to :HARDcopy Commands](#)" on page 542
- "[":HARDcopy:APRINTER](#)" on page 545
- "[":HARDcopy:STARt](#)" on page 558

## :HARDcopy:STARt

**N** (see [page 1666](#))

**Command Syntax** :HARDcopy:STARt

The :HARDcopy:STARt command starts a print job.

**See Also**

- "[Introduction to :HARDcopy Commands](#)" on page 542
- "[:HARDcopy:APRinter](#)" on page 545
- "[:HARDcopy:PRINter:LIST](#)" on page 557
- "[:HARDcopy:FACTors](#)" on page 546
- "[:HARDcopy:FFEed](#)" on page 547
- "[:HARDcopy:INKSaver](#)" on page 548
- "[:HARDcopy:LAYOUT](#)" on page 549
- "[:HARDcopy:PALETTE](#)" on page 556

## :HCOPY:SDUMp:DATA

**N** (see [page 1666](#))

**Query Syntax**

```
:HCOPY:SDUMp:DATA? [<format>]
<format> ::= {PNG | BMP | BMP8bit}
```

The :HCOPY:SDUMp:DATA? query reads and returns screen image data. You can choose 24-bit BMP, 8-bit BMP8bit, or 24-bit PNG formats.

Note that the returned image is also affected by the :HARDcopy:INKSaver command, which is ON by default and returns an inverted image. To get a non-inverted image, send the ":HARDcopy:INKSaver OFF" command before the DATA? query.

In addition to the <format> option of this query, the screen image data format can also be set by the :HCOPY:SDUMp:FORMAT command or the front panel's **[Save/Recall] > Save > Format** softkey, when an image format (instead of a setup or data format) is selected.

If no <format> option is specified with this query, the screen image data is returned in the currently selected format. After a \*RST (factory default) command, the PNG format is selected by default.

If the <format> option is specified with this query, the format setting will affect the front panel's **[Save/Recall] > Save > Format** softkey setting if the **Format** softkey currently selects an image format (instead of a setup or data format).

Screen image data is returned in the IEEE-488.2 # binary block data format.

**Return Format**

```
<display_data><NL>
<display_data> ::= binary block data in IEEE-488.2 # format.
```

**See Also**

- "[:HCOPY:SDUMp:FORMAT](#)" on page 560
- "[:DISPlay:DATA](#)" on page 422
- "[:HARDcopy:INKSaver](#)" on page 548

## :HCOPY:SDUMp:FORMAT

**N** (see [page 1666](#))

**Command Syntax**

```
:HCOPY:SDUMp:FORMAT <format>
<format> ::= {PNG | BMP | BMP8bit}
```

The :HCOPY:SDUMp:FORMAT command specifies the format for screen image data: 24-bit PNG, 24-bit BMP, or 8-bit BMP8bit.

Note that the screen image data is also affected by the :HARDcopy:INKSaver command, which is ON by default and results in an inverted image. To get a non-inverted image, send the ":HARDcopy:INKSaver OFF" command before querying the screen image data.

The :HCOPY:SDUMp:FORMAT setting will persist when cycling power but will be reset to PNG after a \*RST (factory default) command.

The :HCOPY:SDUMp:FORMAT setting will affect the front panel's [**Save/Recall**] > **Save** > **Format** softkey setting if the **Format** softkey currently selects an image format (instead of a setup or data format).

**Query Syntax**

```
:HCOPY:SDUMp:FORMAT?
```

The :HCOPY:SDUMp:FORMAT? query returns the specified screen image data format.

The screen image data format can be set by the :HCOPY:SDUMp:FORMAT command or the front panel's [**Save/Recall**] > **Save** > **Format** softkey, when it selects an image format (instead of a setup or data format).

**Return Format**

```
<format><NL>
<format> ::= {PNG | BMP | BMP8}
```

**See Also**

- "[:HCOPY:SDUMp:DATA](#)" on page 559
- "[:DISPlay:DATA](#)" on page 422
- "[:HARDcopy:INKSaver](#)" on page 548
- "[\\*RST \(Reset\)](#)" on page 244

## 23 :LISTer Commands

**Table 112** :LISTer Commands Summary

Command	Query	Options and Query Returns
n/a	:LISTer:DATA? (see <a href="#">page 562</a> )	<binary_block> ::= comma-separated data with newlines at the end of each row
:LISTer:DISPlay {{OFF   0}   {SBUS1   ON   1}   {SBUS2   2}   ALL} (see <a href="#">page 563</a> )	:LISTer:DISPlay? (see <a href="#">page 563</a> )	{OFF   SBUS1   SBUS2   ALL}
:LISTer:REFerence <time_ref> (see <a href="#">page 564</a> )	:LISTer:REFerence? (see <a href="#">page 564</a> )	<time_ref> ::= {TRIGger   PREVIOUS}

**Introduction to :LISTer Commands** The LISTER subsystem is used to turn on/off the serial decode Lister display and return data from the Lister display.

## :LISTer:DATA

**N** (see [page 1666](#))

**Query Syntax** :LISTer:DATA?

The :LISTer:DATA? query returns the lister data.

**Return Format** <binary block><NL>

<binary\_block> ::= comma-separated data with newlines at the  
end of each row

**See Also**

- ["Introduction to :LISTer Commands"](#) on page 561
- [":LISTer:DISPlay"](#) on page 563
- ["Definite-Length Block Response Data"](#) on page 225

## :LISTer:DISPlay

**N** (see [page 1666](#))

**Command Syntax** :LISTer:DISPlay <value>

<value> ::= {{OFF | 0} | {SBUS1 | ON | 1} | {SBUS2 | 2} | ALL}

The :LISTer:DISPlay command configures which of the serial buses to display in the Lister, or whether the Lister is off. "ON" or "1" is the same as "SBUS1".

When set to "ALL", the decode information for different buses is interleaved in time.

Serial bus decode must be on before it can be displayed in the Lister.

**Query Syntax** :LISTer:DISPlay?

The :LISTer:DISPlay? query returns the Lister display setting.

**Return Format** <value><NL>

<value> ::= {OFF | SBUS1 | SBUS2 | ALL}

**See Also**

- "[Introduction to :LISTer Commands](#)" on page 561
- "[:SBUS<n>:DISPLAY](#)" on page 908
- "[:LISTer:DATA](#)" on page 562

## :LISTER:REFerence

**N** (see [page 1666](#))

**Command Syntax**    `:LISTER:REFERENCE <time_ref>`

`<time_ref> ::= {TRIGger | PREVIOUS}`

The :LISTER:REFerence command selects whether the time value for a Lister row is relative to the trigger or the previous Lister row.

**Query Syntax**    `:LISTER:REFERENCE?`

The :LISTER:REFerence? query returns the Lister time reference setting.

**Return Format**    `<time_ref><NL>`

`<time_ref> ::= {TRIGger | PREVIOUS}`

- See Also**
- "[Introduction to :LISTER Commands](#)" on page 561
  - "[":SBUS<n>:DISPLAY](#)" on page 908
  - "[":LISTER:DATA](#)" on page 562
  - "[":LISTER:DISPLAY](#)" on page 563

## 24 :LTEST Commands

**Table 113** :LTEST Commands Summary

Command	Query	Options and Query Returns
:LTEST:COPY (see page 567)	n/a	n/a
:LTEST:COPY:ALL (see page 568)	n/a	n/a
:LTEST:COPY:MARGIN <percent> (see page 569)	:LTEST:COPY:MARGIN? (see page 569)	<percent> ::= copy margin percent in NR1 format
:LTEST:ENABLE {{0   OFF}   {1   ON}} (see page 570)	:LTEST:ENABLE? (see page 570)	<setting> ::= {0   1}
:LTEST:FAIL <condition> (see page 571)	:LTEST:FAIL? (see page 571)	<condition> ::= {INSide   OUTSide}
:LTEST:LLIMit <lower_value> (see page 572)	:LTEST:LLIMit? (see page 572)	<lower_value> ::= a real number in NR3 format
:LTEST:MEASurement {MEAS<n>} (see page 573)	:LTEST:MEASurement? (see page 573)	<n> ::= # of installed measurement, from 1 to 10
n/a	:LTEST:RESults? [{MEAS<n>}] (see page 574)	<n> ::= # of installed measurement, from 1 to 10
:LTEST:RUMode:SOFailure {{0   OFF}   {1   ON}} (see page 575)	:LTEST:RUMode:SOFailure? (see page 575)	<setting> ::= {0   1}

**Table 113** :LTEST Commands Summary (continued)

Command	Query	Options and Query Returns
:LTEST:TEST {{0   OFF}   {1   ON}} (see page 576)	:LTEST:TEST? (see page 576)	<setting> ::= {0   1}
:LTEST:ULIMit <upper_value> (see page 577)	:LTEST:ULIMit? (see page 577)	<upper_value> ::= a real number in NR3 format

**Introduction to :LTEST Commands** The LTEST subsystem is used for the Measurement Limit Test feature.

## :LTESt:COPY

**N** (see [page 1666](#))

**Command Syntax** :LTESt:COPY

For the measurement selected by :LTESt:MEASurement, the :LTESt:COPY command sets upper and lower limits to the last measurement result plus or minus a percent margin (see :LTESt:COPY:MARGin).

- See Also**
- "[:LTESt:COPY:ALL](#)" on page 568
  - "[:LTESt:COPY:MARGin](#)" on page 569
  - "[:LTESt:ENABLE](#)" on page 570
  - "[:LTESt:FAIL](#)" on page 571
  - "[:LTESt:LLIMit](#)" on page 572
  - "[:LTESt:MEASurement](#)" on page 573
  - "[:LTESt:RESults](#)" on page 574
  - "[:LTESt:RUMode:SOFailure](#)" on page 575
  - "[:LTESt:TEST](#)" on page 576
  - "[:LTESt:ULIMit](#)" on page 577

## :LTEST:COPY:ALL

**N** (see [page 1666](#))

**Command Syntax** `:LTEST:COPY:ALL`

For all measurements whose limits are being tested, the :LTEST:COPY:ALL command sets upper and lower limits to the last measurement result plus or minus a percent margin (see :LTEST:COPY:MARGin).

In essence, this command performs the :LTEST:COPY operation on all measurements whose limits are being tested.

**See Also**

- [":LTEST:COPY"](#) on page 567
- [":LTEST:COPY:MARGin"](#) on page 569
- [":LTEST:ENABLE"](#) on page 570
- [":LTEST:FAIL"](#) on page 571
- [":LTEST:LLIMit"](#) on page 572
- [":LTEST:MEASurement"](#) on page 573
- [":LTEST:RESults"](#) on page 574
- [":LTEST:RUMode:SOFailure"](#) on page 575
- [":LTEST:TEST"](#) on page 576
- [":LTEST:ULIMit"](#) on page 577

## :LTESt:COPY:MARGin

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:LTESt:COPY:MARGin &lt;percent&gt;</code> <code>&lt;percent&gt; ::= copy margin percent in NR1 format</code>
	For the measurement selected by :LTESt:MEASurement, the :LTESt:COPY:MARGin command specifies the percent margin used when setting upper and lower limits by copying from measurement results.
<b>Query Syntax</b>	<code>:LTESt:COPY:MARGin?</code>
	The :LTESt:COPY:MARGin? query returns the percent margin setting for the measurement selected by :LTESt:MEASurement.
<b>Return Format</b>	<code>&lt;percent&gt;&lt;NL&gt;</code> <code>&lt;percent&gt; ::= copy margin percent in NR1 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":LTESt:COPY"</a> on page 567</li> <li>· <a href="#">":LTESt:COPY:ALL"</a> on page 568</li> <li>· <a href="#">":LTESt:ENABLE"</a> on page 570</li> <li>· <a href="#">":LTESt:FAIL"</a> on page 571</li> <li>· <a href="#">":LTESt:LLIMit"</a> on page 572</li> <li>· <a href="#">":LTESt:MEASurement"</a> on page 573</li> <li>· <a href="#">":LTESt:RESults"</a> on page 574</li> <li>· <a href="#">":LTESt:RUMode:SOFailure"</a> on page 575</li> <li>· <a href="#">":LTESt:TEST"</a> on page 576</li> <li>· <a href="#">":LTESt:ULIMit"</a> on page 577</li> </ul>

## :LTEST:ENABLE

**N** (see [page 1666](#))

**Command Syntax** `:LTEST:ENABLE {{0 | OFF} | {1 | ON}}`

The :LTEST:ENABLE command turns the measurement limit test feature on or off.

**Query Syntax** `:LTEST:ENABLE?`

The :LTEST:ENABLE? query returns whether the measurement limit test feature is on or off.

**Return Format** `<setting><NL>`

`<setting> ::= {0 | 1}`

**See Also**

- "[:LTEST:COPY](#)" on page 567
- "[:LTEST:COPY:ALL](#)" on page 568
- "[:LTEST:COPY:MARGIN](#)" on page 569
- "[:LTEST:FAIL](#)" on page 571
- "[:LTEST:LLIMIT](#)" on page 572
- "[:LTEST:MEASUREMENT](#)" on page 573
- "[:LTEST:RESULTS](#)" on page 574
- "[:LTEST:RUMODE:SOFailure](#)" on page 575
- "[:LTEST:TEST](#)" on page 576
- "[:LTEST:ULIMIT](#)" on page 577

## :LTESt:FAIL

**N** (see [page 1666](#))

**Command Syntax** `:LTESt:FAIL <condition>`

`<condition> ::= {INSide | OUTSide}`

For the active measurement currently selected by the :LTESt:MEASurement command, the :LTESt:FAIL command sets the fail condition for the measurement.

When a measurement failure is detected by the limit test, the fail action conditions are executed, and there is the potential to generate an SRQ.

- INSide – causes the oscilloscope to fail a test when the measurement results are within the parameters set by the :LLTESt:LIMit and :LTESt:ULIMit commands.
- OUTSide – causes the oscilloscope to fail a test when the measurement results exceed the parameters set by :LTESt:LLIMit and :LTESt:ULIMit commands.

**Query Syntax** `:LTESt:FAIL?`

The :LTESt:FAIL? query returns the currently set fail condition.

**Return Format** `<condition><NL>`

`<condition> ::= {INS | OUTS}`

- See Also**
- "[:LTESt:COPY](#)" on page 567
  - "[:LTESt:COPY:ALL](#)" on page 568
  - "[:LTESt:COPY:MARGin](#)" on page 569
  - "[:LTESt:ENABLE](#)" on page 570
  - "[:LTESt:LLIMit](#)" on page 572
  - "[:LTESt:MEASurement](#)" on page 573
  - "[:LTESt:RESults](#)" on page 574
  - "[:LTESt:RUMode:SOFailure](#)" on page 575
  - "[:LTESt:TEST](#)" on page 576
  - "[:LTESt:ULIMit](#)" on page 577

## :LTEST:LLIMit

**N** (see [page 1666](#))

**Command Syntax**    `:LTEST:LLIMit <lower_value>`

`<lower_value>` ::= a real number in NR3 format

For the active measurement currently selected by the :LTEST:MEASurement command, the :LTEST:LLIMit (Lower LIMit) command sets the lower test limit.

**Query Syntax**    `:LTEST:LLIMit?`

The :LTEST:LLIMit? query returns the current lower limit setting.

**Return Format**    `<lower_value><NL>`

- See Also**
- "[:LTEST:COPY](#)" on page 567
  - "[:LTEST:COPY:ALL](#)" on page 568
  - "[:LTEST:COPY:MARGIN](#)" on page 569
  - "[:LTEST:ENABLE](#)" on page 570
  - "[:LTEST:FAIL](#)" on page 571
  - "[:LTEST:MEASUREMENT](#)" on page 573
  - "[:LTEST:RESULTS](#)" on page 574
  - "[:LTEST:RUMode:SOFailure](#)" on page 575
  - "[:LTEST:TEST](#)" on page 576
  - "[:LTEST:ULIMIT](#)" on page 577

## :LTESt:MEASurement

**N** (see [page 1666](#))

**Command Syntax** :LTESt:MEASurement {MEAS<n>}

<n> ::= # of installed measurement, from 1 to 10

The :LTESt:MEASurement command selects the measurement source for the :LTESt:FAIL, :LTESt:LLIMit, :LTESt:ULIMit, and :LTESt:TEST commands. It selects one of the active measurements by its number, where MEAS1 is the first added measurement. When you add more than 10 measurements, measurement numbering starts again from MEAS1.

**Query Syntax** :LTESt:MEASurement?

The :LTESt:MEASurement? query returns the currently selected measurement source.

**Return Format** MEAS<n><NL>

**See Also**

- "[:LTESt:COPY](#)" on page 567
- "[:LTESt:COPY:ALL](#)" on page 568
- "[:LTESt:COPY:MARGIN](#)" on page 569
- "[:LTESt:ENABLE](#)" on page 570
- "[:LTESt:FAIL](#)" on page 571
- "[:LTESt:LLIMIT](#)" on page 572
- "[:LTESt:RESults](#)" on page 574
- "[:LTESt:RUMode:SOFailure](#)" on page 575
- "[:LTESt:TEST](#)" on page 576
- "[:LTESt:ULIMIT](#)" on page 577

## :LTEST:RESUltS

**N** (see [page 1666](#))

**Query Syntax** `:LTEST:RESUltS? [{MEAS<n>}]`

`<n> ::= # of installed measurement, from 1 to 10`

The :LTEST:RESUltS? query returns the measurement results for selected measurement.

When :LTEST:TEST is ON, the :LTEST:RESUltS? query returns the failed minimum value (Fail Min), the failed maximum value (Fail Max), and the total number of measurements made (# of Meas).

When :LTEST:TEST is OFF, the :LTEST:RESUltS? query returns nothing.

**Return Format** `<fail_min>, <fail_max>, <num_meas><NL>`

- `<fail_min>` – A real number representing the total number of measurements that have failed the minimum limit.
- `<fail_max>` – A real number representing the total number of measurements that have failed the maximum limit.
- `<num_meas>` – A real number representing the total number of measurements that have been made.

**See Also**

- [":LTEST:COPY" on page 567](#)
- [":LTEST:COPY:ALL" on page 568](#)
- [":LTEST:COPY:MARGIN" on page 569](#)
- [":LTEST:ENABLE" on page 570](#)
- [":LTEST:FAIL" on page 571](#)
- [":LTEST:LLIMIT" on page 572](#)
- [":LTEST:MEASurement" on page 573](#)
- [":LTEST:RUMode:SOFailure" on page 575](#)
- [":LTEST:TEST" on page 576](#)
- [":LTEST:ULIMIT" on page 577](#)

## :LTESt:RUMode:SOFailure

**N** (see [page 1666](#))

**Command Syntax** :LTESt:RUMode:SOFailure {0 | OFF} | {1 | ON}

The :LTESt:RUMode:SOFailure command enables or disables the limit test "stop on failure" option.

When ON, the oscilloscope acquisition system stops once a limit failure is detected. If more than one measurement limit test is enabled, a failure of any of the measurements stops the oscilloscope from acquiring new waveforms.

**Query Syntax** :LTESt:RUMode:SOFailure?

The :LTESt:RUMode:SOFailure? query returns the "stop on failure" setting.

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

- See Also**
- [":LTESt:COPY"](#) on page 567
  - [":LTESt:COPY:ALL"](#) on page 568
  - [":LTESt:COPY:MARGIN"](#) on page 569
  - [":LTESt:ENABLE"](#) on page 570
  - [":LTESt:FAIL"](#) on page 571
  - [":LTESt:LLIMit"](#) on page 572
  - [":LTESt:MEASurement"](#) on page 573
  - [":LTESt:RESults"](#) on page 574
  - [":LTESt:TEST"](#) on page 576
  - [":LTESt:ULIMit"](#) on page 577

## :LTEST:TEST

**N** (see [page 1666](#))

**Command Syntax** `:LTEST:TEST {{0 | OFF} | {1 | ON}}`

For the active measurement currently selected by the :LTEST:MEASurement command, the :LTEST:TEST command enables or disables the limit test function on that measurement.

When any measurement has its limit test function enabled, the overall Limit Test feature is enabled.

The :LTEST:RESults? query returns nothing when :LTEST:TEST is OFF.

**Query Syntax** `:LTEST:TEST?`

The :LTEST:TEST? query returns the state of the TEST control for the active measurement currently selected by the :LTEST:MEASurement command.

**Return Format** `<setting><NL>`

`<setting> ::= {0 | 1}`

**See Also**

- [":LTEST:COPY" on page 567](#)
- [":LTEST:COPY:ALL" on page 568](#)
- [":LTEST:COPY:MARGIN" on page 569](#)
- [":LTEST:ENABLE" on page 570](#)
- [":LTEST:FAIL" on page 571](#)
- [":LTEST:LLIMIT" on page 572](#)
- [":LTEST:MEASUREMENT" on page 573](#)
- [":LTEST:RESULTS" on page 574](#)
- [":LTEST:RUMode:SOFailure" on page 575](#)
- [":LTEST:ULIMIT" on page 577](#)

## :LTEST:ULIMit

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:LTEST:ULIMit &lt;upper_value&gt;</code> <code>&lt;upper_value&gt; ::= a real number in NR3 format</code>
	For the active measurement currently selected by the :LTEST:MEASurement command, the :LTEST:ULIMit (Upper LIMit) command sets the upper test limit.
<b>Query Syntax</b>	<code>:LTEST:ULIMit?</code>
	The :LTEST:ULIMit? query returns the current upper limit setting.
<b>Return Format</b>	<code>&lt;upper_value&gt;&lt;NL&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:LTEST:COPY</a>" on page 567</li> <li>· "<a href="#">:LTEST:COPY:ALL</a>" on page 568</li> <li>· "<a href="#">:LTEST:COPY:MARGIN</a>" on page 569</li> <li>· "<a href="#">:LTEST:ENABLE</a>" on page 570</li> <li>· "<a href="#">:LTEST:FAIL</a>" on page 571</li> <li>· "<a href="#">:LTEST:LLIMit</a>" on page 572</li> <li>· "<a href="#">:LTEST:MEASurement</a>" on page 573</li> <li>· "<a href="#">:LTEST:RESults</a>" on page 574</li> <li>· "<a href="#">:LTEST:RUMode:SOFailure</a>" on page 575</li> <li>· "<a href="#">:LTEST:TEST</a>" on page 576</li> </ul>



## 25 :MARKer Commands

Set and query the settings of X-axis markers (X1 and X2 cursors) and the Y-axis markers (Y1 and Y2 cursors). See "[Introduction to :MARKer Commands](#)" on page 581.

**Table 114** :MARKer Commands Summary

Command	Query	Options and Query Returns
n/a	:MARKer:DYDX? (see <a href="#">page 582</a> )	<return_value> ::= •Y/•X value in NR3 format
:MARKer:MODE <mode> (see <a href="#">page 583</a> )	:MARKer:MODE? (see <a href="#">page 583</a> )	<mode> ::= {OFF   MEASurement   MANual   WAVEform   BINARY   HEX}
:MARKer:X1:DISPLAY {{0   OFF}   {1   ON}} (see <a href="#">page 584</a> )	:MARKer:X1:DISPLAY? (see <a href="#">page 584</a> )	<setting> ::= {0   1}
:MARKer:X1Position <position>[suffix] (see <a href="#">page 585</a> )	:MARKer:X1Position? (see <a href="#">page 585</a> )	<position> ::= X1 cursor position value in NR3 format [suffix] ::= {s   ms   us   ns   ps   Hz   kHz   MHz} <return_value> ::= X1 cursor position value in NR3 format
:MARKer:X1Y1source <source> (see <a href="#">page 586</a> )	:MARKer:X1Y1source? (see <a href="#">page 586</a> )	<source> ::= {CHANnel<n>   FUNCTION<m>   FFT   MATH<m>   WMEMORY<r>} <n> ::= 1 to (# analog channels) in NR1 format <m> ::= 1 to (# math functions) in NR1 format <r> ::= 1 to (# ref waveforms) in NR1 format <return_value> ::= <source>
:MARKer:X2:DISPLAY {{0   OFF}   {1   ON}} (see <a href="#">page 587</a> )	:MARKer:X2:DISPLAY? (see <a href="#">page 587</a> )	<setting> ::= {0   1}

**Table 114** :MARKer Commands Summary (continued)

Command	Query	Options and Query Returns
:MARKer:X2Position <position>[suffix] (see <a href="#">page 588</a> )	:MARKer:X2Position? (see <a href="#">page 588</a> )	<p>&lt;position&gt; ::= X2 cursor position value in NR3 format</p> <p>[suffix] ::= {s   ms   us   ns   ps   Hz   kHz   MHz}</p> <p>&lt;return_value&gt; ::= X2 cursor position value in NR3 format</p>
:MARKer:X2Y2source <source> (see <a href="#">page 589</a> )	:MARKer:X2Y2source? (see <a href="#">page 589</a> )	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTion&lt;m&gt;   FFT   MATH&lt;m&gt;   WMEMORY&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= &lt;source&gt;</p>
n/a	:MARKer:XDELta? (see <a href="#">page 590</a> )	<return_value> ::= X cursors delta value in NR3 format
:MARKer:XUNits <mode> (see <a href="#">page 591</a> )	:MARKer:XUNits? (see <a href="#">page 591</a> )	<units> ::= {SEConds   HERTz   DEGRees   PERCent}
:MARKer:XUNits:USE (see <a href="#">page 592</a> )	n/a	n/a
:MARKer:Y1:DISPlay { {0   OFF}   {1   ON} } (see <a href="#">page 593</a> )	:MARKer:Y1:DISPLAY? (see <a href="#">page 593</a> )	<setting> ::= {0   1}
:MARKer:Y1Position <position>[suffix] (see <a href="#">page 594</a> )	:MARKer:Y1Position? (see <a href="#">page 594</a> )	<p>&lt;position&gt; ::= Y1 cursor position value in NR3 format</p> <p>[suffix] ::= {V   mV   dB}</p> <p>&lt;return_value&gt; ::= Y1 cursor position value in NR3 format</p>
:MARKer:Y2:DISPlay { {0   OFF}   {1   ON} } (see <a href="#">page 595</a> )	:MARKer:Y2:DISPLAY? (see <a href="#">page 595</a> )	<setting> ::= {0   1}
:MARKer:Y2Position <position>[suffix] (see <a href="#">page 596</a> )	:MARKer:Y2Position? (see <a href="#">page 596</a> )	<p>&lt;position&gt; ::= Y2 cursor position value in NR3 format</p> <p>[suffix] ::= {V   mV   dB}</p> <p>&lt;return_value&gt; ::= Y2 cursor position value in NR3 format</p>

**Table 114** :MARKer Commands Summary (continued)

Command	Query	Options and Query Returns
n/a	:MARKer:YDELta? (see <a href="#">page 597</a> )	<return_value> ::= Y cursors delta value in NR3 format
:MARKer:YUNits <mode> (see <a href="#">page 598</a> )	:MARKer:YUNits? (see <a href="#">page 598</a> )	<units> ::= {BASE   PERCent}
:MARKer:YUNits:USE (see <a href="#">page 599</a> )	n/a	n/a

**Introduction to :MARKer Commands** The MARKer subsystem commands set and query the settings of X-axis markers (X1 and X2 cursors) and the Y-axis markers (Y1 and Y2 cursors). You can set and query the marker mode and source, the position of the X and Y cursors, and query delta X and delta Y cursor values.

#### Reporting the Setup

Use :MARKer? to query setup information for the MARKer subsystem.

#### Return Format

The following is a sample response from the :MARKer? query. In this case, the query was issued following a \*RST and ":MARKer:MODE MANual" command.

```
:MARK:X1Y1 CHAN1;X2Y2 CHAN1;MODE MAN
```

## :MARKer:DYDX

**N** (see [page 1666](#))

**Query Syntax** `:MARKer:DYDX?`

The MARKer:DYDX? query returns the cursor  $\Delta Y/\Delta X$  value.

X cursor units are set by the :MARKer:XUNits command.

**NOTE**

If the front-panel cursors are off, the marker position values are not defined. Make sure to set :MARKer:MODE to MANual or WAveform to put the cursors in the front-panel Normal mode.

**Return Format**

`<value><NL>`

`<value> ::= •Y/•X value in NR3 format.`

**See Also**

- "[Introduction to :MARKer Commands](#)" on page 581
- "[:MARKer:MODE](#)" on page 583
- "[:MARKer:X1Position](#)" on page 585
- "[:MARKer:X2Position](#)" on page 588
- "[:MARKer:X1Y1source](#)" on page 586
- "[:MARKer:X2Y2source](#)" on page 589
- "[:MARKer:XUNits](#)" on page 591

## :MARKer:MODE

**N** (see [page 1666](#))

**Command Syntax**    `:MARKer:MODE <mode>`  
`<mode> ::= {OFF | MEASurement | MANual | WAVEform | BINary | HEX}`

The :MARKer:MODE command sets the cursors mode:

- OFF – removes the cursor information from the display.
- MANual – enables manual placement of the X and Y cursors.

If the front-panel cursors are off, or are set to the front-panel Hex or Binary mode, setting :MARKer:MODE MANual will put the cursors in the front-panel Normal mode.

- MEASurement – cursors track the most recent measurement.

Setting the mode to MEASurement sets the marker sources (:MARKer:X1Y1source and :MARKer:X2Y2source) to the measurement source (:MEASure:SOURce). Setting the measurement source remotely always sets the marker sources.

- WAVEform – the Y1 cursor tracks the voltage value at the X1 cursor of the waveform specified by the X1Y1source, and the Y2 cursor does the same for the X2 cursor and its X2Y2source.
- BINary – logic levels of displayed waveforms at the current X1 and X2 cursor positions are displayed in the Cursor sidebar dialog in binary.
- HEX – logic levels of displayed waveforms at the current X1 and X2 cursor positions are displayed in the Cursor sidebar dialog in hexadecimal.

**Query Syntax**    `:MARKer:MODE?`

The :MARKer:MODE? query returns the current cursors mode.

**Return Format**    `<mode><NL>`  
`<mode> ::= {OFF | MEAS | MAN | WAV | BIN | HEX}`

**See Also**    ["Introduction to :MARKer Commands" on page 581](#)  
[":MARKer:X1Y1source" on page 586](#)  
[":MARKer:X2Y2source" on page 589](#)  
[":MEASure:SOURce" on page 667](#)  
[":MARKer:X1Position" on page 585](#)  
[":MARKer:X2Position" on page 588](#)  
[":MARKer:Y1Position" on page 594](#)  
[":MARKer:Y2Position" on page 596](#)

## :MARKer:X1:DISPLAY

**N** (see [page 1666](#))

**Command Syntax** `:MARKer:X1:DISPLAY {{0 | OFF} | {1 | ON}}`

The :MARKer:X1:DISPLAY command specifies whether the X1 cursor is displayed.

**Query Syntax** `:MARKer:X1:DISPLAY?`

The :MARKer:X1:DISPLAY? query returns the X1 cursor display setting.

**Return Format** `<setting><NL>`

`<setting> ::= {0 | 1}`

**See Also** • [":MARKer:X1:DISPLAY"](#) on page 584

## :MARKer:X1Position

**N** (see [page 1666](#))

- Command Syntax**    `:MARKer:X1Position <position> [suffix]`
- <position> ::= X1 cursor position in NR3 format
- <suffix> ::= {s | ms | us | ns | ps | Hz | kHz | MHz}
- The :MARKer:X1Position command:
- Sets :MARKer:MODE to MANual if it is not currently set to WAVEform (see "[:MARKer:MODE](#)" on page 583).
  - Sets the X1 cursor position to the specified value.
- X cursor units are set by the :MARKer:XUNits command.

**Query Syntax**    `:MARKer:X1Position?`

The :MARKer:X1Position? query returns the current X1 cursor position. This is functionally equivalent to the obsolete :MEASure:TSTArt command/query.

### NOTE

If the front-panel cursors are off, the marker position values are not defined and an error is generated. Make sure to set :MARKer:MODE to MANual or WAVEform to put the cursors in the front-panel Normal mode.

- 
- Return Format**    `<position><NL>`
- <position> ::= X1 cursor position in NR3 format
- See Also**
- "[Introduction to :MARKer Commands](#)" on page 581
  - "[:MARKer:MODE](#)" on page 583
  - "[:MARKer:X2Position](#)" on page 588
  - "[:MARKer:X1Y1source](#)" on page 586
  - "[:MARKer:X2Y2source](#)" on page 589
  - "[:MARKer:XUNits](#)" on page 591
  - "[:MEASure:TSTArt](#)" on page 1580

## :MARKer:X1Y1source

**N** (see [page 1666](#))

### Command Syntax

```
:MARKer:X1Y1source <source>
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | FFT | WMEMory<r>}
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MARKer:X1Y1source command sets the source for the cursors. The channel you specify must be enabled for cursors to be displayed. If the channel or function is not on, an error message is issued.

If the marker mode is not currently WAVEform (see "[:MARKer:MODE](#)" on page 583):

- Sending a :MARKer:X1Y1source command will put the cursors in the MANual mode.
- Setting the source for one pair of markers (for example, X1Y1) sets the source for the other (for example, X2Y2).

If the marker mode is currently WAVEform, the X1Y1 source can be set separate from the X2Y2 source.

If :MARKer:MODE is set to OFF or MANUAL, setting :MEASure:SOURce to CHANnel<n>, FUNCTION, MATH, or WMEMory<r> will also set :MARKer:X1Y1source and :MARKer:X2Y2source to this value.

### NOTE

MATH is an alias for FUNCtion. The query will return FUNC if the source is FUNCtion or MATH.

### Query Syntax

```
:MARKer:X1Y1source?
```

The :MARKer:X1Y1source? query returns the current source for the cursors. If all channels are off or if :MARKer:MODE is set to OFF, the query returns NONE.

### Return Format

```
<source><NL>
<source> ::= {CHAN<n> | FUNC | WMEM<r> | NONE}
```

### See Also

- "[Introduction to :MARKer Commands](#)" on page 581
- "[:MARKer:MODE](#)" on page 583
- "[:MARKer:X2Y2source](#)" on page 589
- "[:MEASure:SOURce](#)" on page 667

## :MARKer:X2:DISPLAY

**N** (see [page 1666](#))

**Command Syntax** :MARKer:X2:DISPLAY {{0 | OFF} | {1 | ON}}

The :MARKer:X2:DISPLAY command specifies whether the X2 cursor is displayed.

**Query Syntax** :MARKer:X2:DISPLAY?

The :MARKer:X2:DISPLAY? query returns the X2 cursor display setting.

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

**See Also** • [":MARKer:X2:DISPLAY"](#) on page 587

## :MARKer:X2Position

**N** (see [page 1666](#))

**Command Syntax**    `:MARKer:X2Position <position> [suffix]`

`<position> ::= X2 cursor position in NR3 format`

`<suffix> ::= {s | ms | us | ns | ps | Hz | kHz | MHz}`

The :MARKer:X2Position command:

- Sets :MARKer:MODE to MANual if it is not currently set to WAVEform (see "[:MARKer:MODE](#)" on page 583).
- Sets the X2 cursor position to the specified value.

X cursor units are set by the :MARKer:XUNits command.

**Query Syntax**    `:MARKer:X2Position?`

The :MARKer:X2Position? query returns current X2 cursor position. This is functionally equivalent to the obsolete :MEASure:TSTOp command/query.

### NOTE

If the front-panel cursors are off, the marker position values are not defined and an error is generated. Make sure to set :MARKer:MODE to MANual or WAVEform to put the cursors in the front-panel Normal mode.

**Return Format**    `<position><NL>`

`<position> ::= X2 cursor position in NR3 format`

**See Also**

- "[Introduction to :MARKer Commands](#)" on page 581
- "[:MARKer:MODE](#)" on page 583
- "[:MARKer:X1Position](#)" on page 585
- "[:MARKer:X2Y2source](#)" on page 589
- "[:MARKer:XUNits](#)" on page 591
- "[:MEASure:TSTOp](#)" on page 1581

## :MARKer:X2Y2source

**N** (see [page 1666](#))

### Command Syntax

```
:MARKer:X2Y2source <source>
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | FFT | WMEMory<r>}
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MARKer:X2Y2source command sets the source for the cursors. The channel you specify must be enabled for cursors to be displayed. If the channel or function is not on, an error message is issued.

If the marker mode is not currently WAVEform (see "[:MARKer:MODE](#)" on page 583):

- Sending a :MARKer:X2Y2source command will put the cursors in the MANual mode.
- Setting the source for one pair of markers (for example, X2Y2) sets the source for the other (for example, X1Y1).

If the marker mode is currently WAVEform, the X2Y2 source can be set separate from the X1Y1 source.

If :MARKer:MODE is set to OFF or MANUAL, setting :MEASure:SOURce to CHANnel<n>, FUNCTION, MATH, or WMEMory<r> will also set :MARKer:X1Y1source and :MARKer:X2Y2source to this value.

### NOTE

MATH is an alias for FUNCtion. The query will return FUNC if the source is FUNCtion or MATH.

### Query Syntax

```
:MARKer:X2Y2source?
```

The :MARKer:X2Y2source? query returns the current source for the cursors. If all channels are off or if :MARKer:MODE is set to OFF, the query returns NONE.

### Return Format

```
<source><NL>
<source> ::= {CHAN<n> | FUNC | WMEM<r> | NONE}
```

### See Also

- "[Introduction to :MARKer Commands](#)" on page 581
- "[:MARKer:MODE](#)" on page 583
- "[:MARKer:X1Y1source](#)" on page 586
- "[:MEASure:SOURce](#)" on page 667

## :MARKer:XDELta

**N** (see [page 1666](#))

**Query Syntax** `:MARKer:XDELta?`

The MARKer:XDELta? query returns the value difference between the current X1 and X2 cursor positions.

Xdelta = (Value at X2 cursor) - (Value at X1 cursor)

X cursor units are set by the :MARKer:XUNits command.

### NOTE

If the front-panel cursors are off, the marker position values are not defined. Make sure to set :MARKer:MODE to MANual or WAVEform to put the cursors in the front-panel Normal mode.

**Return Format** `<value><NL>`

`<value>` ::= difference value in NR3 format.

**See Also**

- ["Introduction to :MARKer Commands"](#) on page 581
- [":MARKer:MODE"](#) on page 583
- [":MARKer:X1Position"](#) on page 585
- [":MARKer:X2Position"](#) on page 588
- [":MARKer:X1Y1source"](#) on page 586
- [":MARKer:X2Y2source"](#) on page 589
- [":MARKer:XUNits"](#) on page 591

## :MARKer:XUNits

**N** (see [page 1666](#))

**Command Syntax**    `:MARKer:XUNits <units>`

`<units> ::= {SEConds | HERTz | DEGRees | PERCent}`

The :MARKer:XUNits command sets the X cursors units:

- SEConds – for making time measurements.
- HERTz – for making frequency measurements.
- DEGRees – for making phase measurements. Use the :MARKer:XUNits:USE command to set the current X1 location as 0 degrees and the current X2 location as 360 degrees.
- PERCent – for making ratio measurements. Use the :MARKer:XUNits:USE command to set the current X1 location as 0 percent and the current X2 location as 100 percent.

Changing X units affects the input and output values of the :MARKer:X1Position, :MARKer:X2Position, and :MARKer:XDELta commands/queries.

**Query Syntax**    `:MARKer:XUNits?`

The :MARKer:XUNits? query returns the current X cursors units.

**Return Format**    `<units><NL>`

`<units> ::= {SEC | HERT | DEGR | PERC}`

- See Also**
- "[Introduction to :MARKer Commands](#)" on page 581
  - "[":MARKer:XUNits:USE](#)" on page 592
  - "[":MARKer:X1Y1source](#)" on page 586
  - "[":MARKer:X2Y2source](#)" on page 589
  - "[":MEASure:SOURce](#)" on page 667
  - "[":MARKer:X1Position](#)" on page 585
  - "[":MARKer:X2Position](#)" on page 588

## :MARKer:XUNits:USE

**N** (see [page 1666](#))

### Command Syntax

`:MARKer:XUNits:USE`

When DEGRees is selected for :MARKer:XUNits, the :MARKer:XUNits:USE command sets the current X1 location as 0 degrees and the current X2 location as 360 degrees.

When PERCent is selected for :MARKer:XUNits, the :MARKer:XUNits:USE command sets the current X1 location as 0 percent and the current X2 location as 100 percent.

Once the 0 and 360 degree or 0 and 100 percent locations are set, inputs to and outputs from the :MARKer:X1Position, :MARKer:X2Position, and :MARKer:XDELta commands/queries are relative to the set locations.

### See Also

- ["Introduction to :MARKer Commands"](#) on page 581
- [":MARKer:XUNits"](#) on page 591
- [":MARKer:X1Y1source"](#) on page 586
- [":MARKer:X2Y2source"](#) on page 589
- [":MEASure:SOURce"](#) on page 667
- [":MARKer:X1Position"](#) on page 585
- [":MARKer:X2Position"](#) on page 588
- [":MARKer:XDELta"](#) on page 590

## :MARKer:Y1:DISPlay

**N** (see [page 1666](#))

**Command Syntax** :MARKer:Y1:DISPlay {{0 | OFF} | {1 | ON}}

The :MARKer:Y1:DISPlay command specifies whether the Y1 cursor is displayed.

**Query Syntax** :MARKer:Y1:DISPlay?

The :MARKer:Y1:DISPlay? query returns the Y1 cursor display setting.

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

**See Also** • [":MARKer:Y1:DISPlay"](#) on page 593

## :MARKer:Y1Position

**N** (see [page 1666](#))

**Command Syntax**    `:MARKer:Y1Position <position> [suffix]`

`<position> ::= Y1 cursor position in NR3 format`

`<suffix> ::= {mV | V | dB}`

If the :MARKer:MODE is not currently set to WAVEform (see "[:MARKer:MODE](#)" on page 583), the :MARKer:Y1Position command:

- Sets :MARKer:MODE to MANual.
- Sets the Y1 cursor position to the specified value.

Y cursor units are set by the :MARKer:YUNits command.

When the :MARKer:MODE is set to WAVEform, Y positions cannot be set.

**Query Syntax**    `:MARKer:Y1Position?`

The :MARKer:Y1Position? query returns current Y1 cursor position. This is functionally equivalent to the obsolete :MEASure:VSTArt command/query.

### NOTE

If the front-panel cursors are off or are set to Binary or Hex Mode, the marker position values are not defined and an error is generated. Make sure to set :MARKer:MODE to MANual or WAVEform to put the cursors in the front-panel Normal mode.

---

<b>Return Format</b>	<code>&lt;position&gt;&lt;NL&gt;</code>
	<code>&lt;position&gt; ::= Y1 cursor position in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :MARKer Commands</a>" on page 581</li> <li>• "<a href="#">:MARKer:MODE</a>" on page 583</li> <li>• "<a href="#">:MARKer:X1Y1source</a>" on page 586</li> <li>• "<a href="#">:MARKer:X2Y2source</a>" on page 589</li> <li>• "<a href="#">:MARKer:Y2Position</a>" on page 596</li> <li>• "<a href="#">:MARKer:YUNits</a>" on page 598</li> <li>• "<a href="#">:MEASure:VSTArt</a>" on page 1585</li> </ul>

## :MARKer:Y2:DISPlay

**N** (see [page 1666](#))

**Command Syntax** :MARKer:Y2:DISPlay {{0 | OFF} | {1 | ON}}

The :MARKer:Y2:DISPlay command specifies whether the Y2 cursor is displayed.

**Query Syntax** :MARKer:Y2:DISPlay?

The :MARKer:Y2:DISPlay? query returns the Y2 cursor display setting.

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

**See Also** • [":MARKer:Y2:DISPlay"](#) on page 595

## :MARKer:Y2Position

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MARKer:Y2Position &lt;position&gt; [suffix]</code>
	<code>&lt;position&gt; ::= Y2 cursor position in NR3 format</code>
	<code>&lt;suffix&gt; ::= {mV   V   dB}</code>
	If the :MARKer:MODE is not currently set to WAVEform (see " <a href="#">:MARKer:MODE</a> " on page 583), the :MARKer:Y1Position command:
	<ul style="list-style-type: none"> <li>• Sets :MARKer:MODE to MANual.</li> <li>• Sets the Y2 cursor position to the specified value.</li> </ul>
	Y cursor units are set by the :MARKer:YUNits command.
	When the :MARKer:MODE is set to WAVEform, Y positions cannot be set.
<b>Query Syntax</b>	<code>:MARKer:Y2Position?</code>
	The :MARKer:Y2Position? query returns current Y2 cursor position. This is functionally equivalent to the obsolete :MEASure:VSTOp command/query.

### NOTE

If the front-panel cursors are off or are set to Binary or Hex Mode, the marker position values are not defined and an error is generated. Make sure to set :MARKer:MODE to MANual or WAVEform to put the cursors in the front-panel Normal mode.

---

<b>Return Format</b>	<code>&lt;position&gt;&lt;NL&gt;</code>
	<code>&lt;position&gt; ::= Y2 cursor position in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :MARKer Commands</a>" on page 581</li> <li>• "<a href="#">:MARKer:MODE</a>" on page 583</li> <li>• "<a href="#">:MARKer:X1Y1source</a>" on page 586</li> <li>• "<a href="#">:MARKer:X2Y2source</a>" on page 589</li> <li>• "<a href="#">:MARKer:Y1Position</a>" on page 594</li> <li>• "<a href="#">:MARKer:YUNits</a>" on page 598</li> <li>• "<a href="#">:MEASure:VSTOp</a>" on page 1586</li> </ul>

## :MARKer:YDELta

**N** (see [page 1666](#))

**Query Syntax** :MARKer:YDELta?

The :MARKer:YDELta? query returns the value difference between the current Y1 and Y2 cursor positions.

$$\text{Ydelta} = (\text{Value at Y2 cursor}) - (\text{Value at Y1 cursor})$$

### NOTE

If the front-panel cursors are off or are set to Binary or Hex Mode, the marker position values are not defined. Make sure to set :MARKer:MODE to MANual or WAveform to put the cursors in the front-panel Normal mode.

Y cursor units are set by the :MARKer:YUNits command.

**Return Format** <value><NL>

<value> ::= difference value in NR3 format

**See Also**

- "[Introduction to :MARKer Commands](#)" on page 581
- "[":MARKer:MODE"](#) on page 583
- "[":MARKer:X1Y1source"](#) on page 586
- "[":MARKer:X2Y2source"](#) on page 589
- "[":MARKer:Y1Position"](#) on page 594
- "[":MARKer:Y2Position"](#) on page 596
- "[":MARKer:YUNits"](#) on page 598

## :MARKer:YUNits

**N** (see [page 1666](#))

**Command Syntax**    `:MARKer:YUNits <units>`

`<units> ::= {BASE | PERCent}`

The :MARKer:YUNits command sets the Y cursors units:

- BASE – for making measurements in the units associated with the cursors source.
- PERCent – for making ratio measurements. Use the :MARKer:YUNits:USE command to set the current Y1 location as 0 percent and the current Y2 location as 100 percent.

Changing Y units affects the input and output values of the :MARKer:Y1Position, :MARKer:Y2Position, and :MARKer:YDELta commands/queries.

**Query Syntax**    `:MARKer:YUNits?`

The :MARKer:YUNits? query returns the current Y cursors units.

**Return Format**    `<units><NL>`

`<units> ::= {BASE | PERC}`

**See Also**    ["Introduction to :MARKer Commands" on page 581](#)

- [":MARKer:YUNits:USE" on page 599](#)
- [":MARKer:X1Y1source" on page 586](#)
- [":MARKer:X2Y2source" on page 589](#)
- [":MEASure:SOURce" on page 667](#)
- [":MARKer:Y1Position" on page 594](#)
- [":MARKer:Y2Position" on page 596](#)
- [":MARKer:YDELta" on page 597](#)

## :MARKer:YUNits:USE

**N** (see [page 1666](#))

### Command Syntax

`:MARKer:YUNits:USE`

When PERCent is selected for :MARKer:YUNits, the :MARKer:YUNits:USE command sets the current Y1 location as 0 percent and the current Y2 location as 100 percent.

Once the 0 and 100 percent locations are set, inputs to and outputs from the :MARKer:Y1Position, :MARKer:Y2Position, and :MARKer:YDELta commands/queries are relative to the set locations.

### See Also

- ["Introduction to :MARKer Commands"](#) on page 581
- [":MARKer:YUNits"](#) on page 598
- [":MARKer:X1Y1source"](#) on page 586
- [":MARKer:X2Y2source"](#) on page 589
- [":MEASure:SOURce"](#) on page 667
- [":MARKer:Y1Position"](#) on page 594
- [":MARKer:Y2Position"](#) on page 596
- [":MARKer:YDELta"](#) on page 597



## 26 :MEASure Commands

Select automatic measurements to be made and control time markers. See "[Introduction to :MEASure Commands](#)" on page 620.

**Table 115** :MEASure Commands Summary

Command	Query	Options and Query Returns
:MEASure:ALL (see <a href="#">page 622</a> )	n/a	n/a
:MEASure:AREA [ <i>&lt;interval&gt;</i> ] [,<source>] (see <a href="#">page 623</a> )	:MEASure:AREA? [<interval>] [,<source>] (see <a href="#">page 623</a> )	<i>&lt;interval&gt;</i> ::= {CYCLE   DISPLAY} <i>&lt;source&gt;</i> ::= {CHANNEL<n>   FUNCTION<m>   MATH<m>   WMEMORY<r>} <i>&lt;n&gt;</i> ::= 1 to (# analog channels) in NR1 format <i>&lt;m&gt;</i> ::= 1 to (# math functions) in NR1 format <i>&lt;r&gt;</i> ::= 1 to (# ref waveforms) in NR1 format <i>&lt;return_value&gt;</i> ::= area in volt-seconds, NR3 format

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:BRATE [<source>] (see page 624)	:MEASure:BRATE? [<source>] (see page 624)	<p>&lt;source&gt; ::= {&lt;digital channels&gt;   CHANNEL&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMORY&lt;r&gt;}</p> <p>&lt;digital channels&gt; ::= DIGITAL&lt;d&gt; for the MSO models</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;n&gt; ::= 1 to (# of analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= bit rate in Hz, NR3 format</p>
:MEASure:BWIDth [<source>] (see page 625)	:MEASure:BWIDth? [<source>] (see page 625)	<p>&lt;source&gt; ::= {CHANNEL&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMORY&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= burst width in seconds, NR3 format</p>
:MEASure:CLEar (see page 626)	n/a	n/a
:MEASure:COUNTER [<source>] (see page 627)	:MEASure:COUNTER? [<source>] (see page 627)	<p>&lt;source&gt; ::= {CHANNEL&lt;n&gt;   EXTERNAL} for DSO models</p> <p>&lt;source&gt; ::= {CHANNEL&lt;n&gt;   DIGITAL&lt;d&gt;   EXTERNAL} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= counter frequency in Hertz in NR3 format</p>

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:DEFIne DELay, <delay spec> (see <a href="#">page 629</a> )	:MEASure:DEFIne? DELay (see <a href="#">page 631</a> )	<delay spec> ::= <edge_spec1>, <edge_spec2> <edge_spec1> ::= [<slope>] <occurrence> <edge_spec2> ::= [<slope>] <occurrence> <slope> ::= {+   -} <occurrence> ::= integer
:MEASure:DEFIne THRESHolds, <threshold spec> (see <a href="#">page 629</a> )	:MEASure:DEFIne? THRESHolds (see <a href="#">page 631</a> )	<threshold spec> ::= {STANDARD}   {<threshold mode>, <upper>, <middle>, <lower>} <threshold mode> ::= {PERCent   ABSolute}
:MEASure:DELay [<source1>] [<source2>] (see <a href="#">page 632</a> )	:MEASure:DELay? [<source1>] [<source2>] (see <a href="#">page 632</a> )	<source1,2> ::= {CHANnel<n>   FUNCtion<m>   MATH<m>   WMEMory<r>   <digital channels>} <n> ::= 1 to (# analog channels) in NR1 format <m> ::= 1 to (# math functions) in NR1 format <r> ::= 1 to (# ref waveforms) in NR1 format <digital channels> ::= DIGItal<d> for the MSO models <d> ::= 0 to (# digital channels - 1) in NR1 format <return_value> ::= floating-point number delay time in seconds in NR3 format
:MEASure:DELay:DEFIne <source1_edge_slope>, <source1_edge_number>, <source1_edge_threshold>, <source2_edge_slope>, <source2_edge_number>, <source2_edge_threshold> (see <a href="#">page 634</a> )	:MEASure:DELay:DEFIne? (see <a href="#">page 634</a> )	<source1_edge_slope>, <source2_edge_slope> ::= {RISING   FALLING} <source1_edge_number>, <source2_edge_number> ::= 0 to 1000 in NR1 format <source1_edge_threshold>, <source2_edge_threshold> ::= {LOWER   MIDDLE   UPPER}

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:DUAL:CHARge [<interval>] [,<source1>] [,<source2>] (see <a href="#">page 635</a> )	:MEASure:DUAL:CHARge? [<interval>] [,<source1>] [,<source2>] (see <a href="#">page 635</a> )	<interval> ::= {CYCLE   DISPLAY} <source1>, <source2> ::= CHANnel<n> with N2820A probe connected <n> ::= 1 to (# analog channels) in NR1 format <return_value> ::= area in Amp-hours, NR3 format
:MEASure:DUAL:VAMPulse [<source1>] [,<source2>] (see <a href="#">page 636</a> )	:MEASure:DUAL:VAMPulse? [<source1>] [,<source2>] (see <a href="#">page 636</a> )	<source1>, <source2> ::= CHANnel<n> with N2820A probe connected <n> ::= 1 to (# analog channels) in NR1 format <return_value> ::= the amplitude of the selected waveform in volts in NR3 format
:MEASure:DUAL:VAVerag e [<interval>] [,<source1>] [,<source2>] (see <a href="#">page 637</a> )	:MEASure:DUAL:VAVerag e? [<interval>] [,<source1>] [,<source2>] (see <a href="#">page 637</a> )	<interval> ::= {CYCLE   DISPLAY} <source1>, <source2> ::= CHANnel<n> with N2820A probe connected <n> ::= 1 to (# analog channels) in NR1 format <return_value> ::= calculated average voltage in NR3 format
:MEASure:DUAL:VBASe [<source1>] [,<source2>] (see <a href="#">page 638</a> )	:MEASure:DUAL:VBASe? [<source1>] [,<source2>] (see <a href="#">page 638</a> )	<source1>, <source2> ::= CHANnel<n> with N2820A probe connected <n> ::= 1 to (# analog channels) in NR1 format <base_voltage> ::= voltage at the base of the selected waveform in NR3 format
:MEASure:DUAL:VPP [<source1>] [,<source2>] (see <a href="#">page 639</a> )	:MEASure:DUAL:VPP? [<source1>] [,<source2>] (see <a href="#">page 639</a> )	<source1>, <source2> ::= CHANnel<n> with N2820A probe connected <n> ::= 1 to (# analog channels) in NR1 format <return_value> ::= voltage peak-to-peak of the selected waveform in NR3 format

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:DUAL:VRMS [<interval>] [,<type>] [,<source1>] [,<source2>] (see <a href="#">page 640</a> )	:MEASure:DUAL:VRMS? [<interval>] [,<type>] [,<source1>] [,<source2>] (see <a href="#">page 640</a> )	<interval> ::= {CYCLE   DISPLAY} <type> ::= {AC   DC} <source1>, <source2> ::= CHANNEL<n> with N2820A probe connected <n> ::= 1 to (# analog channels) in NR1 format <return_value> ::= calculated RMS voltage in NR3 format
:MEASure:DUTYcycle [<source>] (see <a href="#">page 641</a> )	:MEASure:DUTYcycle? [<source>] (see <a href="#">page 641</a> )	<source> ::= {CHANNEL<n>   FUNCTION<m>   MATH<m>   WMEMORY<r>} for DSO models <source> ::= {CHANNEL<n>   DIGITAL<d>   FUNCTION<m>   MATH<m>   WMEMORY<r>} for MSO models <n> ::= 1 to (# analog channels) in NR1 format <m> ::= 1 to (# math functions) in NR1 format <r> ::= 1 to (# ref waveforms) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format <return_value> ::= ratio of positive pulse width to period in NR3 format

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:FALLtime [<source>] (see page 642)	:MEASure:FALLtime? [<source>] (see page 642)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= time in seconds between the lower and upper thresholds in NR3 format</p>
:MEASure:FFT:ACPR <chan_width>, <chan_spacing>, <chan>[,<source>] (see page 643)	:MEASure:FFT:ACPR? <chan_width>, <chan_spacing>, <chan>[,<source>] (see page 643)	<p>&lt;chan_width&gt; ::= width of main range and sideband channels, Hz in NR3 format</p> <p>&lt;chan_spacing&gt; ::= spacing between main range and sideband channels, Hz in NR3 format</p> <p>&lt;chan&gt; ::= {CENTer   HIGH&lt;sb&gt;   LOW&lt;sb&gt;}</p> <p>&lt;sb&gt; ::= sideband 1 to 5</p> <p>&lt;source&gt; ::= {FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT} (source must be an FFT waveform)</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;return_value&gt; ::= adjacent channel power ratio, dBV in NR3 format</p>
:MEASure:FFT:CPOWer [<source>] (see page 644)	:MEASure:FFT:CPOWer? [<source>] (see page 644)	<p>&lt;source&gt; ::= {FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT} (source must be an FFT waveform)</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;return_value&gt; ::= spectral channel power, dBV in NR3 format</p>

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:FFT:OBW <percentage>[,<source>] (see page 645)	:MEASure:FFT:OBW? <percentage>[,<source>] (see page 645)	<p>&lt;percentage&gt; ::= percent of spectral power occupied bandwidth is measured for in NR3 format</p> <p>&lt;source&gt; ::= {FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT} (source must be an FFT waveform)</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;return_value&gt; ::= occupied bandwidth, Hz in NR3 format</p>
:MEASure:FFT:THD [<source>] (see page 646)	:MEASure:FFT:THD? [<source>] (see page 646)	<p>&lt;source&gt; ::= {FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT} (source must be an FFT waveform)</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;return_value&gt; ::= total harmonic distortion ratio percent in NR3 format</p>
:MEASure:FREQuency [<source>] (see page 647)	:MEASure:FREQuency? [<source>] (see page 647)	<p>&lt;source&gt; ::= {CHANNEL&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMORY&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANNEL&lt;n&gt;   DIGITAL&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMORY&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= frequency in Hertz in NR3 format</p>

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:NDUTy [<source>] (see page 648)	:MEASure:NDUTy? [<source>] (see page 648)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= ratio of negative pulse width to period in NR3 format</p>
:MEASure:NEDGes [<source>] (see page 649)	:MEASure:NEDGes? [<source>] (see page 649)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the falling edge count in NR3 format</p>

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:NPULses [<source>] (see page 650)	:MEASure:NPULses? [<source>] (see page 650)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;   &lt;digital channels&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;digital channels&gt; ::= DIGItal&lt;d&gt; for the MSO models</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= the falling pulse count in NR3 format</p>
:MEASure:NWIDth [<source>] (see page 651)	:MEASure:NWIDth? [<source>] (see page 651)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= negative pulse width in seconds-NR3 format</p>

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:OVERshoot [<source>] (see page 652)	:MEASure:OVERshoot? [<source>] (see page 652)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the percent of the overshoot of the selected waveform in NR3 format</p>
:MEASure:PEDGes [<source>] (see page 654)	:MEASure:PEDGes? [<source>] (see page 654)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the rising edge count in NR3 format</p>
:MEASure:PERiod [<source>] (see page 655)	:MEASure:PERiod? [<source>] (see page 655)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= waveform period in seconds in NR3 format</p>

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:PHASE [<source1>] [,<source2>] (see page 656)	:MEASure:PHASE? [<source1>] [,<source2>] (see page 656)	<p>&lt;source1,2&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the phase angle value in degrees in NR3 format</p>
:MEASure:PPULses [<source>] (see page 657)	:MEASure:PPULses? [<source>] (see page 657)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;   &lt;digital channels&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;digital channels&gt; ::= DIGItal&lt;d&gt; for the MSO models</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= the rising pulse count in NR3 format</p>
:MEASure:PREShoot [<source>] (see page 658)	:MEASure:PREShoot? [<source>] (see page 658)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the percent of preshoot of the selected waveform in NR3 format</p>

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:PWIDth [<source>] (see page 659)	:MEASure:PWIDth? [<source>] (see page 659)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= width of positive pulse in seconds in NR3 format</p>
n/a	:MEASure:RESults? <result_list> (see page 660)	<result_list> ::= comma-separated list of measurement results
:MEASure:RISetime [<source>] (see page 663)	:MEASure:RISetime? [<source>] (see page 663)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= rise time in seconds in NR3 format</p>

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:SDEViation [ <source/> ] (see page 664)	:MEASure:SDEViation? [ <source/> ] (see page 664)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= calculated std deviation in NR3 format</p>
:MEASure:SHOW {{0   OFF}   {1   ON}} (see page 665)	:MEASure:SHOW? (see page 665)	{0   1}
:MEASure:SLEWrate [ <source/> [,<slope>]] (see page 666)	:MEASure:SLEWrate? [ <source/> [,<slope>]] (see page 666)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# of analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p>
:MEASure:SOURce <source1> [,<source2>] (see page 667)	:MEASure:SOURce? (see page 667)	<p>&lt;source1,2&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;   EXTERNAL} for DSO models</p> <p>&lt;source1,2&gt; ::= {CHANnel&lt;n&gt;   DIGITAL&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMORY&lt;r&gt;   EXTERNAL} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= {&lt;source&gt;   NONE}</p>

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:STATistics <type> (see <a href="#">page 669</a> )	:MEASure:STATistics? (see <a href="#">page 669</a> )	<type> ::= {{ON   1}   CURRent   MEAN   MINimum   MAXimum   STDDev   COUNT} ON ::= all statistics returned
:MEASure:STATistics:D ISPlay {{0   OFF}   {1   ON}} (see <a href="#">page 670</a> )	:MEASure:STATistics:D ISPlay? (see <a href="#">page 670</a> )	{0   1}
:MEASure:STATistics:I NCREMENT (see <a href="#">page 671</a> )	n/a	n/a
:MEASure:STATistics:M COunt <setting> (see <a href="#">page 672</a> )	:MEASure:STATistics:M COunt? (see <a href="#">page 672</a> )	<setting> ::= {INFinite   <count>} <count> ::= 2 to 2000 in NR1 format
:MEASure:STATistics:R ESet (see <a href="#">page 673</a> )	n/a	n/a
:MEASure:STATistics:R SDeviation {{0   OFF}   {1   ON}} (see <a href="#">page 674</a> )	:MEASure:STATistics:R SDeviation? (see <a href="#">page 674</a> )	{0   1}

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:TEDGE [<slope>,<occurrence>] >[,<source>] (see <a href="#">page 675</a> )	:MEASure:TEDGE? [<slope>,<occurrence>] >[,<source>] (see <a href="#">page 676</a> )	<p>&lt;slope&gt; ::= {RISing   FALLing   EITHer}</p> <p>&lt;occurrence&gt; ::= [+   -]&lt;number&gt;</p> <p>&lt;number&gt; ::= the edge number in NR1 format</p> <p>&lt;source&gt; ::= {&lt;digital channels&gt;   CHANNEL&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;digital channels&gt; ::= DIGItal&lt;d&gt; for the MSO models</p> <p>&lt;n&gt; ::= 1 to (# of analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= time in seconds of the specified transition</p>

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
n/a	:MEASure:TValue? <value>, [<>slope>]<occurrence> [, <source>] (see page 678)	<p>&lt;value&gt; ::= voltage level that the waveform must cross.</p> <p>&lt;slope&gt; ::= direction of the waveform when &lt;value&gt; is crossed.</p> <p>&lt;occurrence&gt; ::= transitions reported.</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= time in seconds of specified voltage crossing in NR3 format</p>
:MEASure:VAMplitude [<source>] (see page 680)	:MEASure:VAMplitude? [<source>] (see page 680)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the amplitude of the selected waveform in volts in NR3 format</p>

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:VAverage [<interval>] [,<source>] (see page 681)	:MEASure:VAverage? [<interval>] [,<source>] (see page 681)	<p>&lt;interval&gt; ::= {CYCLE   DISPLAY}</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT   WMMemory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= calculated average voltage in NR3 format</p>
:MEASure:VBASe [<source>] (see page 682)	:MEASure:VBASe? [<source>] (see page 682)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMMemory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;base_voltage&gt; ::= voltage at the base of the selected waveform in NR3 format</p>
:MEASure:VMAX [<source>] (see page 683)	:MEASure:VMAX? [<source>] (see page 683)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   FFT   MATH&lt;m&gt;   WMMemory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= maximum voltage of the selected waveform in NR3 format</p>

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:VMIN [<source>] (see page 684)	:MEASure:VMIN? [<source>] (see page 684)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   FFT   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= minimum voltage of the selected waveform in NR3 format</p>
:MEASure:VPP [<source>] (see page 685)	:MEASure:VPP? [<source>] (see page 685)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   FFT   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= voltage peak-to-peak of the selected waveform in NR3 format</p>
:MEASure:VRATio [<interval>] [, <source 1>] [, <source2>] (see page 686)	:MEASure:VRATio? [<interval>] [, <source 1>] [, <source2>] (see page 686)	<p>&lt;interval&gt; ::= {CYCLE   DISPLAY}</p> <p>&lt;source1,2&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the ratio value in dB in NR3 format</p>

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:VRMS [<interval>] [,<type>] [,<source>] (see page 687)	:MEASure:VRMS? [<interval>] [,<type>] [,<source>] (see page 687)	<interval> ::= {CYCLE   DISPLAY} <type> ::= {AC   DC} <source> ::= {CHANnel<n>   FUNCTION<m>   MATH<m>   WMEMORY<r>}  <n> ::= 1 to (# analog channels) in NR1 format  <m> ::= 1 to (# math functions) in NR1 format  <r> ::= 1 to (# ref waveforms) in NR1 format  <return_value> ::= calculated dc RMS voltage in NR3 format
:MEASure:VTOP [<source>] (see page 688)	:MEASure:VTOP? [<source>] (see page 688)	<source> ::= {CHANnel<n>   FUNCTION<m>   MATH<m>   WMEMORY<r>}  <n> ::= 1 to (# analog channels) in NR1 format  <m> ::= 1 to (# math functions) in NR1 format  <r> ::= 1 to (# ref waveforms) in NR1 format  <return_value> ::= voltage at the top of the waveform in NR3 format
:MEASure:WINDOW <type> (see page 689)	:MEASure:WINDOW? (see page 689)	<type> ::= {MAIN   ZOOM   AUTO   GATE}
:MEASure:XMAX [<source>] (see page 690)	:MEASure:XMAX? [<source>] (see page 690)	<source> ::= {CHANnel<n>   FUNCTION<m>   FFT   MATH<m>   WMEMORY<r>}  <n> ::= 1 to (# analog channels) in NR1 format  <m> ::= 1 to (# math functions) in NR1 format  <r> ::= 1 to (# ref waveforms) in NR1 format  <return_value> ::= horizontal value of the maximum in NR3 format

**Table 115** :MEASure Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:XMIN [<source>] (see page 691)	:MEASure:XMIN? [<source>] (see page 691)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   FFT   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= horizontal value of the minimum in NR3 format</p>
:MEASure:YATX <horiz_location>[,<source>] (see page 692)	:MEASure:YATX? <horiz_location>[,<source>] (see page 692)	<p>&lt;horiz_location&gt; ::= displayed time from trigger in seconds in NR3 format</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;return_value&gt; ::= voltage at the specified time in NR3 format</p>

**Introduction to :MEASure Commands** The commands in the MEASure subsystem are used to make parametric measurements on displayed waveforms.

#### Measurement Setup

To make a measurement, the portion of the waveform required for that measurement must be displayed on the oscilloscope screen.

Measurement Type	Portion of waveform that must be displayed
period, duty cycle, or frequency	at least one complete cycle
pulse width	the entire pulse
rise time	rising edge, top and bottom of pulse
fall time	falling edge, top and bottom of pulse

### Measurement Error

If a measurement cannot be made (typically because the proper portion of the waveform is not displayed), the value +9.9E+37 is returned for that measurement.

### Making Measurements

If more than one waveform, edge, or pulse is displayed, time measurements are made on the portion of the displayed waveform closest to the trigger reference (left, center, or right).

When making measurements in the zoomed (delayed) time base mode (:TIMEbase:MODE WINDOW), the oscilloscope will attempt to make the measurement inside the zoomed sweep window. If the measurement is an average and there are not three edges, the oscilloscope will revert to the mode of making the measurement at the start of the main sweep.

When the command form is used, the measurement result is displayed on the instrument. When the query form of these measurements is used, the measurement is made one time, and the measurement result is returned over the bus.

Measurements are made on the displayed waveforms specified by the :MEASure:SOURce command. The MATH source is an alias for the FUNCtion source.

Not all measurements are available on the digital channels or FFT (Fast Fourier Transform).

### Reporting the Setup

Use the :MEASure? query to obtain setup information for the MEASure subsystem. (Currently, this is only :MEASure:SOURce.)

### Return Format

The following is a sample response from the :MEASure? query. In this case, the query was issued following a \*RST command.

```
:MEAS:SOUR CHAN1,CHAN2;STAT ON
```

## :MEASure:ALL

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:ALL`

This command installs a Snapshot All measurement on the screen.

**See Also**    · ["Introduction to :MEASure Commands"](#) on page 620

## :MEASure:AREa

**N** (see [page 1666](#))

**Command Syntax**

```
:MEASure:AREa [<interval>] [,<source>]
<interval> ::= {CYCLE | DISPlay}
<source> ::= {CHANnel<n> | FUNCTion<m> | MATH<m> | WMMEMory<r>}
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:AREa command installs an area measurement on screen. Area measurements show the area between the waveform and the ground level.

The <interval> option lets you specify the measurement interval: either an integral number of cycles, or the full screen. If <interval> is not specified, DISPlay is implied.

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

**Query Syntax**

```
:MEASure:AREa? [<interval>] [,<source>]
```

The :MEASure:AREa? query measures and returns the area value.

**Return Format**

```
<value><NL>
<value> ::= the area value in volt-seconds in NR3 format
```

**See Also**

- ["Introduction to :MEASure Commands"](#) on page 620
- [":MEASure:SOURce"](#) on page 667

## :MEASure:BRATe

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:BRATe [<source>]`

```

<source> ::= {<digital channels> | CHANnel<n> | FUNCtion<m> | MATH<m>
              | WMMEmory<r>}

<digital channels> ::= DIGItal<d> for the MSO models

<d> ::= 0 to (# digital channels - 1) in NR1 format

<n> ::= 1 to (# of analog channels) in NR1 format

<m> ::= 1 to (# math functions) in NR1 format

<r> ::= 1 to (# ref waveforms) in NR1 format

```

The :MEASure:BRATe command installs a screen measurement and starts the bit rate measurement. If the optional source parameter is specified, the currently specified source is modified.

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

**Query Syntax**    `:MEASure:BRATe? [<source>]`

The :MEASure:BRATe? query measures all positive and negative pulse widths on the waveform, takes the minimum value found of either width type and inverts that minimum width to give a value in Hertz.

**Return Format**    `<value><NL>`

`<value>` ::= the bit rate value in Hertz

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:SOURce](#)" on page 667
- "[":MEASure:FREQuency](#)" on page 647
- "[":MEASure:PERiod](#)" on page 655

## :MEASure:BWIDth

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:BWIDth [<source>]`

```
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | WMMEmory<r>}

<n> ::= 1 to (# analog channels) in NR1 format

<m> ::= 1 to (# math functions) in NR1 format

<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:BWIDth command installs a burst width measurement on screen. If the optional source parameter is not specified, the current measurement source is used.

**NOTE**

This command is not available if the source is FFT (Fast Fourier Transform).

**Query Syntax**    `:MEASure:BWIDth? [<source>]`

The :MEASure:BWIDth? query measures and returns the width of the burst on the screen.

The burst width is calculated as follows:

burst width = (last edge on screen - first edge on screen)

**Return Format**    `<value><NL>`

```
<value> ::= burst width in seconds in NR3 format
```

**See Also**

- "Introduction to :MEASure Commands" on page 620

- "[:MEASure:SOURce](#)" on page 667

## :MEASure:CLEar

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:CLEar`

This command clears all selected measurements and markers from the screen.

**See Also**    · ["Introduction to :MEASure Commands"](#) on page 620

## :MEASure:COUNter

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MEASure:COUNter [&lt;source&gt;]</code>
	<code>&lt;source&gt; ::= {&lt;digital channels&gt;   CHANnel&lt;n&gt;   EXTernal}</code>
	<code>&lt;digital channels&gt; ::= DIGItal&lt;d&gt; for the MSO models</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	The :MEASure:COUNter command installs a screen measurement and starts a counter measurement. If the optional source parameter is specified, the current source is modified. Any channel except Math or Reference Waveforms may be selected for the source.
	The counter measurement counts trigger level crossings within a certain amount of time (gate time) and displays the results in Hz.
	The gate time is the horizontal range of the oscilloscope but is limited to $\geq 0.1$ s and $\leq 10$ s. Unlike other measurements, the Zoom horizontal timebase window does not gate the Counter measurement.
	The Counter measurement can measure frequencies up to the bandwidth of the oscilloscope. The minimum frequency supported is $2.0 / \text{gateTime}$ .
	Only one counter measurement may be displayed at a time.

### NOTE

This command is not available if the source is MATH.

---

### Query Syntax

`:MEASure:COUNTER? [<source>]`

The :MEASure:COUNTER? query measures and outputs the counter frequency of the specified source.

### NOTE

The :MEASure:COUNTER? query times out if the counter measurement is installed on the front panel. Use :MEASure:CLEar to remove the front-panel measurement before executing the :MEASure:COUNTER? query.

---

### Return Format

`<source><NL>`  
`<source> ::= count in Hertz in NR3 format`

### See Also

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:SOURce](#)" on page 667

- "[:MEASure:FREQuency](#)" on page 647
- "[:MEASure:CLEar](#)" on page 626

## :MEASure:DEFIne

**N** (see [page 1666](#))

### Command Syntax

```
:MEASure:DEFIne <meas_spec>[,<source>]
```

```
<meas_spec> ::= {DEDelay | THReSholds}
```

The :MEASure:DEFIne command sets up the definition for measurements by specifying the delta time or threshold values. Changing these values may affect the results of other measure commands. The table below identifies which measurement results that can be affected by redefining the DEDelay specification or the THReSholds values. For example, changing the THReSholds definition from the default 10%, 50%, and 90% values may change the returned measurement result.

MEASure Command	DEDelay	THReSholds
DUTYcycle		x
DEDelay	x	x
FALLtime		x
FREQuency		x
NWIDth		x
OVERshoot		x
PERiod		x
PHASE		x
PRESHoot		x
PWIDth		x
RISetime		x
VAVerage		x
VRMS		x

### :MEASure:DEFIne DEDelay Command Syntax

#### NOTE

The DEDelay portion of the MEASure:DEFIne command has been deprecated, and you should instead use the :MEASure:DEDelay:DEFIne command to specify delay measurement parameters. The delay measurement now allows an edge occurrence of zero (0) to specify automatic edge selection. The limitation of this command is that you cannot specify a negative slope with an occurrence count of zero (0).

---

```
:MEASure:DEFIne DELay,<delay spec>[,<source>]
```

```

<delay spec> ::= <edge_spec1>,<edge_spec2>
<edge_spec1> ::= [<slope>]<occurrence>
<edge_spec2> ::= [<slope>]<occurrence>
<slope> ::= {+ | -}
<occurrence> ::= integer
<source> ::= {CHANnel<n> | FUNCTion<m> | MATH<m> | WMEMory<r>}
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format

```

This command defines the behavior of the :MEASure:DELay command/query by specifying the start and stop edge to be used. <edge\_spec1> specifies the slope and edge number on source1. <edge\_spec2> specifies the slope and edge number on source2. The measurement is taken as:

$$\text{delay} = t(\text{edge\_spec2}) - t(\text{edge\_spec1})$$

#### :MEASure:DEFine THresholds Command Syntax

```

:MEASure:DEFine THresholds,<threshold spec>[,<source>]
<threshold spec> ::= {STANDARD
                      | {<threshold mode>,<upper>,<middle>,<lower>}}
<threshold mode> ::= {PERCENT | ABSOLUTE}
for <threshold mode> = PERCENT:

```

<upper>, <middle>, <lower> ::= A number specifying the upper, middle, and lower threshold percentage values between Vbase and Vtop in NR3 format.

for <threshold mode> = ABSOLUTE:

<upper>, <middle>, <lower> ::= A number specifying the upper, middle, and lower threshold absolute values in NR3 format.

<source> ::= {CHANnel<n> | FUNCTion<m> | MATH<m> | FFT | WMEMory<r>}

<n> ::= 1 to (# analog channels) in NR1 format

<m> ::= 1 to (# math functions) in NR1 format

<r> ::= 1 to (# ref waveforms) in NR1 format

- STANDARD threshold specification sets the lower, middle, and upper measurement thresholds to 10%, 50%, and 90% values between Vbase and Vtop.
- Threshold mode PERCENT sets the measurement thresholds to any user-defined percentages between 5% and 95% of values between Vbase and Vtop.

- Threshold mode ABSolute sets the measurement thresholds to absolute values. ABSolute thresholds are dependent on channel scaling (:CHANnel<n>:RANGE or "[:CHANnel<n>:SCALe](#)" on page 368:CHANnel<n>:SCALe), probe attenuation (:CHANnel<n>:PROBe), and probe units (:CHANnel<n>:UNITs). Always set these values first before setting ABSolute thresholds.

**Query Syntax**

```
:MEASure:DEFine? <meas_spec>[,<source>]
<meas_spec> ::= {DELay | THresholds}
```

The :MEASure:DEFine? query returns the current edge specification for the delay measurements setup or the current specification for the thresholds setup.

**Return Format**

for <meas\_spec> = DELay:

```
{ <edge_spec1> | <edge_spec2> | <edge_spec1>,<edge_spec2>} <NL>
```

for <meas\_spec> = THresholds and <threshold mode> = PERCent:

```
THR,PERC,<upper>,<middle>,<lower><NL>
<upper>,<middle>,<lower> ::= A number specifying the upper, middle,
and lower threshold percentage values
between Vbase and Vtop in NR3 format.
```

for <meas\_spec> = THresholds and <threshold mode> = ABSolute:

```
THR,ABS,<upper>,<middle>,<lower><NL>
<upper>,<middle>,<lower> ::= A number specifying the upper, middle,
and lower threshold voltages in NR3
format.
```

for <threshold spec> = STAndard:

```
THR,PERC,+90.0,+50.0,+10.0
```

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[:MEASure:DELay](#)" on page 632
- "[:MEASure:DELay:DEFine](#)" on page 634
- "[:MEASure:SOURce](#)" on page 667
- "[:CHANnel<n>:RANGE](#)" on page 367
- "[:CHANnel<n>:SCALe](#)" on page 368
- "[:CHANnel<n>:PROBe](#)" on page 352
- "[:CHANnel<n>:UNITs](#)" on page 369

## :MEASure:DElay

**N** (see [page 1666](#))

### Command Syntax

```
:MEASure:DElay [<edge_select_mode> [,] [<source1> [,<source2>]]  
<edge_select_mode> ::= {MANual | AUTO}  
<source1>, <source2> ::= {CHANnel<n> | FUNCtion<m> | MATH<m>  
| WMEMory<r> | <digital channels>}  
<n> ::= 1 to (# analog channels) in NR1 format  
<m> ::= 1 to (# math functions) in NR1 format  
<r> ::= 1 to (# ref waveforms) in NR1 format  
<digital channels> ::= DIGital<d> for the MSO models  
<d> ::= 0 to (# digital channels - 1) in NR1 format
```

The :MEASure:DElay command places the instrument in the continuous measurement mode and starts a delay measurement.

The measurement is taken as:

$$\text{delay} = t(<\text{edge\_spec\_2}>) - t(<\text{edge\_spec\_1}>)$$

where the <edge\_spec> definitions are determined by the <edge\_select\_mode> and the :MEASure:DElay:DEFine command.

When the <edge\_select\_mode> is:

- AUTO – edges are automatically selected: the source1 edge closest to the timebase reference point is used, and the source2 edge closest to the source1 edge is used.
- MANual – edge numbers are determined by the :MEASure:DElay:DEFine settings.

Edge numbers greater than zero (0) are counted from the left side of the display for both sources.

Edge thresholds and slopes are always determined by the :MEASure:DElay:DEFine settings.

If the <edge\_select\_mode> is not included with the command, AUTO is the default.

### Query Syntax

```
:MEASure:DElay? [<edge_select_mode> [,] [<source1> [,<source2>]]
```

The :MEASure:DElay? query measures and returns the delay between source1 and source2. Delay measurement threshold, slope, and edge count parameters are determined by the <edge\_select\_mode> and the :MEASure:DElay:DEFine command.

The <edge\_select\_mode> definitions are the same as with the command syntax.

However, if the <edge\_select\_mode> is not included with the query, MANual is the default.

In the :MEASure:DEFine command, you can set upper, middle, and lower threshold values. The standard upper, middle, and lower measurement thresholds are 90%, 50%, and 10% values between Vbase and Vtop.

<b>Return Format</b>	<value><NL>
	<value> ::= floating-point number delay time in seconds in NR3 format
<b>See Also</b>	<ul style="list-style-type: none"><li>· "<a href="#">Introduction to :MEASure Commands</a>" on page 620</li><li>· "<a href="#">":MEASure:DELay:DEFine</a>" on page 634</li><li>· "<a href="#">":MEASure:DEFine</a>" on page 629</li><li>· "<a href="#">":MEASure:PHASe</a>" on page 656</li></ul>

## :MEASure:DELay:DEFine

**N** (see [page 1666](#))

### Command Syntax

```
:MEASure:DELay:DEFine <source1_edge_slope>, <source1_edge_number>,
<source1_edge_threshold>, <source2_edge_slope>,
<source2_edge_number>, <source2_edge_threshold>

<source1_edge_slope>,
<source2_edge_slope> ::= {RISing | FALLing}

<source1_edge_number>,
<source2_edge_number> ::= 0 to 1000 in NR1 format

<source1_edge_threshold>,
<source2_edge_threshold> ::= {LOWER | MIDDLE | UPPER}
```

The :MEASure:DELay:DEFine command defines slope directions and edge numbers for the delay measurement started or returned by the :MEASure:DELay command. The :MEASure:DELay:DEFine command also defines edge position parameters.

A <source1\_edge\_number> setting of zero (0) specifies that the edge closest to the timebase reference point automatically be selected. In this case, the <source2\_edge\_number> setting must also be zero (0), and the source2 edge closest to the selected source1 edge is used.

When edge numbers greater than zero (0) are specified, edges are counted from the left side of the display for both sources.

The selection of the source1 and source2 waveforms is made in the :MEASure:DELay or :MEASure:SOURce commands.

### Query Syntax

```
:MEASure:DELay:DEFine?
```

The :MEASure:DELay:DEFine? query returns the specified delay measurement parameter definitions.

### Return Format

```
<source1_edge_slope>, <source1_edge_number>,
<source1_edge_threshold>, <source2_edge_slope>,
<source2_edge_number>, <source2_edge_threshold><NL>

<source1_edge_slope>,
<source2_edge_slope> ::= {RIS | FALL}

<source1_edge_number>,
<source2_edge_number> ::= 0 to 1000 in NR1 format

<source1_edge_threshold>,
<source2_edge_threshold> ::= {LOW | MIDD | UPP}
```

### See Also

- [":MEASure:DELay"](#) on page 632
- [":MEASure:SOURce"](#) on page 667
- [":MEASure:DEFine"](#) on page 629

## :MEASure:DUAL:CHARge

**N** (see [page 1666](#))

**Overview** This measurement is available with the N2820A high sensitivity current probe when both the Primary and Secondary probe cables are used. This measurement joins the Zoom In waveform data below the probe's clamp level with Zoom Out waveform data above the probe's clamp level to create the waveform on which the measurement is made.

**Command Syntax**

```
:MEASure:DUAL:CHARge [<interval>[,<source1>][,<source2>]
<interval> ::= {CYCLE | DISPLAY}
<source1>,<source2> ::= CHANnel<n> with N2820A probe connected
<n> ::= 1 to (# analog channels) in NR1 format
```

The :MEASure:DUAL:CHARge command installs a charge measurement on screen. Charge measurements show the area between the waveform and the ground level.

The <interval> option lets you specify the measurement interval: either an integral number of cycles, or the full screen. If <interval> is not specified, DISPLAY is implied.

If the optional source parameter(s) are specified, the currently specified source(s) are modified.

**Query Syntax**

```
:MEASure:DUAL:CHARge? [<interval>[,<source1>][,<source2>]
```

The :MEASure:DUAL:CHARge? query measures and returns the charge measurement value.

**Return Format**

```
<value><NL>
<value> ::= the charge value in Amp-hours in NR3 format
```

**See Also**

- "[:MEASure:DUAL:VAMplitude](#)" on page 636
- "[:MEASure:DUAL:VAverage](#)" on page 637
- "[:MEASure:DUAL:VBASe](#)" on page 638
- "[:MEASure:DUAL:VPP](#)" on page 639
- "[:MEASure:DUAL:VRMS](#)" on page 640
- "[Introduction to :MEASure Commands](#)" on page 620
- "[:MEASure:SOURce](#)" on page 667

## :MEASure:DUAL:VAMPlitude

**N** (see [page 1666](#))

**Overview** This measurement is available with the N2820A high sensitivity current probe when both the Primary and Secondary probe cables are used. This measurement joins the Zoom In waveform data below the probe's clamp level with Zoom Out waveform data above the probe's clamp level to create the waveform on which the measurement is made.

**Command Syntax**

```
:MEASure:DUAL:VAMPlitude [<source1>] [,<source2>]
<source1>,<source2> ::= CHANnel<n> with N2820A probe connected
<n> ::= 1 to (# analog channels) in NR1 format
```

The :MEASure:DUAL:VAMPlitude command installs a screen measurement and starts a vertical amplitude measurement.

If the optional source parameter(s) are specified, the currently specified source(s) are modified.

**Query Syntax**

```
:MEASure:DUAL:VAMPlitude? [<source1>] [,<source2>]
```

The :MEASure:DUAL:VAMPlitude? query measures and returns the vertical amplitude of the waveform. To determine the amplitude, the instrument measures Vtop and Vbase, then calculates the amplitude as follows:

$$\text{vertical amplitude} = \text{Vtop} - \text{Vbase}$$

**Return Format**

```
<value><NL>
<value> ::= the amplitude of the selected waveform in NR3 format
```

**See Also**

- "[:MEASure:DUAL:CHARge](#)" on page 635
- "[:MEASure:DUAL:VAverage](#)" on page 637
- "[:MEASure:DUAL:VBASe](#)" on page 638
- "[:MEASure:DUAL:VPP](#)" on page 639
- "[:MEASure:DUAL:VRMS](#)" on page 640
- "[Introduction to :MEASure Commands](#)" on page 620
- "[:MEASure:SOURce](#)" on page 667
- "[:MEASure:VTOP](#)" on page 688

## :MEASure:DUAL:VAverage

**N** (see [page 1666](#))

**Overview** This measurement is available with the N2820A high sensitivity current probe when both the Primary and Secondary probe cables are used. This measurement joins the Zoom In waveform data below the probe's clamp level with Zoom Out waveform data above the probe's clamp level to create the waveform on which the measurement is made.

**Command Syntax** `:MEASure:DUAL:VAverage [<interval> [, <source1>] [, <source2>]`

```
<interval> ::= {CYCLE | DISPLAY}
<source1>, <source2> ::= CHANnel<n> with N2820A probe connected
<n> ::= 1 to (# analog channels) in NR1 format
```

The :MEASure:DUAL:VAverage command installs a screen measurement and starts an average value measurement.

The <interval> option lets you specify the measurement interval: either an integral number of cycles, or the full screen. If <interval> is not specified, DISPLAY is implied.

If the optional source parameter(s) are specified, the currently specified source(s) are modified.

**Query Syntax** `:MEASure:DUAL:VAverage? [<interval>] [, <source1>] [, <source2>]`

The :MEASure:DUAL:VAverage? query returns the average value measurement.

**Return Format** `<value><NL>`  
`<value> ::= calculated average value in NR3 format`

- See Also**
- "[:MEASure:DUAL:CHARge](#)" on page 635
  - "[:MEASure:DUAL:VAMplitude](#)" on page 636
  - "[:MEASure:DUAL:VBASe](#)" on page 638
  - "[:MEASure:DUAL:VPP](#)" on page 639
  - "[:MEASure:DUAL:VRMS](#)" on page 640
  - "[Introduction to :MEASure Commands](#)" on page 620
  - "[:MEASure:SOURce](#)" on page 667

## :MEASure:DUAL:VBASe

**N** (see [page 1666](#))

**Overview** This measurement is available with the N2820A high sensitivity current probe when both the Primary and Secondary probe cables are used. This measurement joins the Zoom In waveform data below the probe's clamp level with Zoom Out waveform data above the probe's clamp level to create the waveform on which the measurement is made.

**Command Syntax**

```
:MEASure:DUAL:VBASe [<source1>] [,<source2>]
<source1>,<source2> ::= CHANnel<n> with N2820A probe connected
<n> ::= 1 to (# analog channels) in NR1 format
```

The :MEASure:DUAL:VBASe command installs a screen measurement and starts a waveform base value measurement.

If the optional source parameter(s) are specified, the currently specified source(s) are modified.

**Query Syntax**

```
:MEASure:DUAL:VBASe? [<source1>] [,<source2>]
```

The :MEASure:DUAL:VBASe? query returns the vertical value at the base of the waveform. The base value of a pulse is normally not the same as the minimum value.

**Return Format**

```
<base_voltage><NL>
<base_voltage> ::= value at the base of the selected waveform in
NR3 format
```

**See Also**

- "[:MEASure:DUAL:CHARge](#)" on page 635
- "[:MEASure:DUAL:VAMplitude](#)" on page 636
- "[:MEASure:DUAL:VAverage](#)" on page 637
- "[:MEASure:DUAL:VPP](#)" on page 639
- "[:MEASure:DUAL:VRMS](#)" on page 640
- "[Introduction to :MEASure Commands](#)" on page 620
- "[:MEASure:SOURce](#)" on page 667
- "[:MEASure:VTOP](#)" on page 688
- "[:MEASure:VMIN](#)" on page 684

## :MEASure:DUAL:VPP

**N** (see [page 1666](#))

<b>Overview</b>	This measurement is available with the N2820A high sensitivity current probe when both the Primary and Secondary probe cables are used. This measurement joins the Zoom In waveform data below the probe's clamp level with Zoom Out waveform data above the probe's clamp level to create the waveform on which the measurement is made.
<b>Command Syntax</b>	<pre>:MEASure:DUAL:VPP [&lt;source1&gt;] [,&lt;source2&gt;] &lt;source1&gt;,&lt;source2&gt; ::= CHANnel&lt;n&gt; with N2820A probe connected &lt;n&gt; ::= 1 to (# analog channels) in NR1 format</pre> <p>The :MEASure:DUAL:VPP command installs a screen measurement and starts a vertical peak-to-peak measurement.</p> <p>If the optional source parameter(s) are specified, the currently specified source(s) are modified.</p>
<b>Query Syntax</b>	<pre>:MEASure:DUAL:VPP? [&lt;source1&gt;] [,&lt;source2&gt;]</pre> <p>The :MEASure:DUAL:VPP? query measures the maximum and minimum vertical value for the selected source, then calculates the vertical peak-to-peak value and returns that value. The peak-to-peak value (Vpp) is calculated with the following formula:</p> $V_{pp} = V_{max} - V_{min}$ <p>Vmax and Vmin are the vertical maximum and minimum values present on the selected source.</p>
<b>Return Format</b>	<pre>&lt;value&gt;&lt;NL&gt; &lt;value&gt; ::= vertical peak to peak value in NR3 format</pre>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:MEASure:DUAL:CHARge</a>" on page 635</li> <li>· "<a href="#">:MEASure:DUAL:VAMPLitude</a>" on page 636</li> <li>· "<a href="#">:MEASure:DUAL:VAverage</a>" on page 637</li> <li>· "<a href="#">:MEASure:DUAL:VBASe</a>" on page 638</li> <li>· "<a href="#">:MEASure:DUAL:VRMS</a>" on page 640</li> <li>· "<a href="#">Introduction to :MEASure Commands</a>" on page 620</li> <li>· "<a href="#">:MEASure:SOURce</a>" on page 667</li> <li>· "<a href="#">:MEASure:VMAX</a>" on page 683</li> <li>· "<a href="#">:MEASure:VMIN</a>" on page 684</li> </ul>

## :MEASure:DUAL:VRMS

**N** (see [page 1666](#))

**Overview** This measurement is available with the N2820A high sensitivity current probe when both the Primary and Secondary probe cables are used. This measurement joins the Zoom In waveform data below the probe's clamp level with Zoom Out waveform data above the probe's clamp level to create the waveform on which the measurement is made.

**Command Syntax**

```
:MEASure:DUAL:VRMS [<interval>[,<type>][,<source1>][,<source2>]
<interval> ::= {CYCLE | DISPLAY}
<type> ::= {AC | DC}
<source1>,<source2> ::= CHANnel<n> with N2820A probe connected
<n> ::= 1 to (# analog channels) in NR1 format
```

The :MEASure:DUAL:VRMS command installs a screen measurement and starts an RMS value measurement.

The <interval> option lets you specify the measurement interval: either an integral number of cycles, or the full screen. If <interval> is not specified, DISPLAY is implied.

The <type> option lets you choose between a DC RMS measurement and an AC RMS measurement. If <type> is not specified, DC is implied.

If the optional source parameter(s) are specified, the currently specified source(s) are modified.

**Query Syntax**

```
:MEASure:DUAL:VRMS? [<interval>[,<type>][,<source1>][,<source2>]
```

The :MEASure:DUAL:VRMS? query measures and outputs the RMS value measurement.

**Return Format**

```
<value><NL>
<value> ::= calculated dc RMS value in NR3 format
```

**See Also**

- "[:MEASure:DUAL:CHARge](#)" on page 635
- "[:MEASure:DUAL:VAMPLitude](#)" on page 636
- "[:MEASure:DUAL:VAVerage](#)" on page 637
- "[:MEASure:DUAL:VBASe](#)" on page 638
- "[:MEASure:DUAL:VPP](#)" on page 639
- "[Introduction to :MEASure Commands](#)" on page 620
- "[:MEASure:SOURce](#)" on page 667

## :MEASure:DUTYcycle

**C** (see [page 1666](#))

**Command Syntax**

```
:MEASure:DUTYcycle [<source>]
<source> ::= {<digital channels> | CHANnel<n> | FUNCtion<m> | MATH<m>
              | WMEMory<r>}
<digital channels> ::= DIGItal<d> for the MSO models
<d> ::= 0 to (# digital channels - 1) in NR1 format
<n> ::= 1 to (# of analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:DUTYcycle command installs a screen measurement and starts a positive duty cycle measurement on the current :MEASure:SOURce. If the optional source parameter is specified, the current source is modified.

### NOTE

The signal must be displayed to make the measurement. This command is not available if the source is FFT (Fast Fourier Transform).

**Query Syntax**

The :MEASure:DUTYcycle? query measures and outputs the positive duty cycle of the signal specified by the :MEASure:SOURce command. The value returned for the duty cycle is the ratio of the positive pulse width to the period. The positive pulse width and the period of the specified signal are measured, then the duty cycle is calculated with the following formula:

$$\text{duty cycle} = (\text{pulse width}/\text{period}) * 100$$

**Return Format**

<value><NL>

<value> ::= ratio of positive pulse width to period in NR3 format

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[:MEASure:PERiod](#)" on page 655
- "[:MEASure:PWidth](#)" on page 659
- "[:MEASure:SOURce](#)" on page 667
- "[:MEASure:NDUTy](#)" on page 648

**Example Code**

- "[Example Code](#)" on page 668

## :MEASure:FALLtime

**C** (see [page 1666](#))

**Command Syntax**    `:MEASure:FALLtime [<source>]`

```
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | WMEMory<r>}
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:FALLtime command installs a screen measurement and starts a fall-time measurement. For highest measurement accuracy, set the sweep speed as fast as possible, while leaving the falling edge of the waveform on the display. If the optional source parameter is specified, the current source is modified.

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

**Query Syntax**    `:MEASure:FALLtime? [<source>]`

The :MEASure:FALLtime? query measures and outputs the fall time of the displayed falling (negative-going) edge closest to the timebase reference. The fall time is determined by measuring the time at the upper threshold of the falling edge, then measuring the time at the lower threshold of the falling edge, and calculating the fall time with the following formula:

$$\text{fall time} = \text{time at lower threshold} - \text{time at upper threshold}$$

**Return Format**    `<value><NL>`

```
<value> ::= time in seconds between the lower threshold and upper
           threshold in NR3 format
```

**See Also**

- ["Introduction to :MEASure Commands"](#) on page 620
- [":MEASure:RISetime"](#) on page 663
- [":MEASure:SOURce"](#) on page 667
- [":MEASure:SLEWrate"](#) on page 666

## :MEASure:FFT:ACPR

**N** (see [page 1666](#))

### Command Syntax

```
:MEASure:FFT:ACPR <chan_width>,<chan_spacing>,<chan>[,<source>]
<chan_width> ::= of main range and sideband channels, Hz in NR3 format
<chan_spacing> ::= spacing between main range and sideband channels,
    Hz in NR3 format
<chan> ::= {CENTer | HIGH<sb> | LOW<sb>}
<sb> ::= sideband 1 to 5
<source> ::= {FUNCTION<m> | MATH<m> | FFT} (must be an FFT waveform)
<m> ::= 1 to (# math functions) in NR1 format
```

The :MEASure:FFT:ACPR command installs an FFT analysis Adjacent Channel Power Ratio (ACPR) measurement on screen.

Adjacent Channel Power Ratio (or channel leakage ratio) measures the ratio of the power in the main frequency range to the power contained in one or more sidebands.

The main range is specified by a channel width and a center frequency. The center frequency used in the measurement is the one defined for the FFT function.

Sidebands (with the same width as the main range) exist above and below the main range separated by the channel spacing width.

The sideband used for the measurement is selected with the <chan> parameter. You can select the first through fifth sidebands above or below the main range (HIGH1 through HIGH5 above and LOW1 through LOW5 below). The full sideband must be in the graticule (on screen) to be measured. Otherwise, the measurement results will be "Incomplete".

When this measurement is tracked with cursors, the cursors show the sideband being measured.

### Query Syntax

```
:MEASure:FFT:ACPR? <chan_width>,<chan_spacing>,<chan>[,<source>]
```

The :MEASure:FFT:ACPR? query returns the measured Adjacent Channel Power Ratio (ACPR) value.

### Return Format

```
<return_value><NL>
<return_value> ::= adjacent channel power ratio, dBV in NR3 format
```

### See Also

- [":MEASure:FFT:CPOWer"](#) on page 644
- [":MEASure:FFT:OBW"](#) on page 645
- [":MEASure:FFT:THD"](#) on page 646

## :MEASure:FFT:CPOWer

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:FFT:CPOWer [<source>]`

```
<source> ::= {FUNCTION<m> | MATH<m> | FFT} (must be an FFT waveform)
<m> ::= 1 to (# math functions) in NR1 format
```

The :MEASure:FFT:CPOWer command installs an FFT analysis Channel Power measurement on screen.

Channel Power measures the spectral power across a frequency range.

The center frequency used in the measurement is the one defined for the FFT function, and the FFT span specifies the frequency range.

When this measurement is tracked with cursors, the cursors are at the left and right edges of the frequency span.

**Query Syntax**    `:MEASure:FFT:CPOWer? [<source>]`

The :MEASure:FFT:CPOWer? query returns the measured Channel Power value.

**Return Format**    `<return_value><NL>`

```
<return_value> ::= spectral channel power, dBV in NR3 format
```

**See Also**

- "[:MEASure:FFT:ACPR](#)" on page 643
- "[:MEASure:FFT:OBW](#)" on page 645
- "[:MEASure:FFT:THD](#)" on page 646

## :MEASure:FFT:OBW

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:FFT:OBW <percentage>[,<source>]`

`<percentage>` ::= percent of spectral power occupied bandwidth is measured for (in NR3 format)

`<source>` ::= {`FUNCTION<m>` | `MATH<m>` | `FFT`} (must be an FFT waveform)

`<m>` ::= 1 to (# math functions) in NR1 format

The :MEASure:FFT:OBW command installs an FFT analysis Occupied Bandwidth measurement on screen.

Occupied Bandwidth measures the bandwidth (frequency range) containing some percent (usually 99%) of the total spectral power. While 99% is the industry norm, you can specify the percent you want to use in the measurement.

The center frequency used in the measurement is the one defined for the FFT function, and the FFT span represents the total spectral power.

When this measurement is tracked with cursors, the cursors show the measured bandwidth (frequency range).

**Query Syntax**    `:MEASure:FFT:OBW? <percentage>[,<source>]`

The :MEASure:FFT:OBW? query returns the measured Occupied Bandwidth value.

**Return Format**    `<return_value><NL>`

`<return_value>` ::= occupied bandwidth, Hz in NR3 format

**See Also**

- "[:MEASure:FFT:ACPR](#)" on page 643
- "[:MEASure:FFT:CPOWER](#)" on page 644
- "[:MEASure:FFT:THD](#)" on page 646

## :MEASure:FFT:THD

**N** (see [page 1666](#))

**Command Syntax**

```
:MEASure:FFT:THD <tracking>[,<fundamental_freq>][,<source>]
<tracking> ::= {AUTO | MANUAL}
<fundamental_freq> ::= in NR3 format, required if <tracking> is MANUAL
<source> ::= {FUNCTION<m> | MATH<m> | FFT} (must be an FFT waveform)
<m> ::= 1 to (# math functions) in NR1 format
```

The :MEASure:FFT:THD command installs an FFT analysis Total Harmonic Distortion measurement on screen.

Total Harmonic Distortion (THD) is the ratio of power in the fundamental frequency to the power contained in the rest of the harmonics and noise. THD is a measure of signal purity.

Total Harmonic Distortion (THD) measures the power contained in the bands surrounding each harmonic and compares it to the power in the band surrounding the fundamental frequency. The width of the bands measured is the same for the fundamental frequency and each harmonic. That width is 1/2 of the fundamental frequency.

You can either enter the fundamental frequency as a measurement parameter and have the fundamental frequency and harmonics be tracked manually, or you can allow the fundamental frequency and harmonics to be tracked automatically, where the highest peak is assumed to be the fundamental frequency.

When this measurement is tracked with cursors, the cursors show the band surrounding the fundamental frequency that is being measured (at  $\pm 1/4$  of the fundamental frequency).

**Query Syntax**

```
:MEASure:FFT:THD? <tracking>[,<fundamental_freq>][,<source>]
```

The :MEASure:FFT:THD? query returns the measured Total Harmonic Distortion value.

**Return Format**

```
<return_value><NL>
```

```
<return_value> ::= total harmonic distortion ratio percent in NR3 format
```

**See Also**

- [":MEASure:FFT:ACPR"](#) on page 643
- [":MEASure:FFT:CPOWER"](#) on page 644
- [":MEASure:FFT:OBW"](#) on page 645

## :MEASure:FREQuency

**C** (see [page 1666](#))

**Command Syntax**

```
:MEASure:FREQuency [<source>]
<source> ::= {<digital channels> | CHANnel<n> | FUNCtion<m> | MATH<m>
              | WMEMory<r>}
<digital channels> ::= DIGItal<d> for the MSO models
<d> ::= 0 to (# digital channels - 1) in NR1 format
<n> ::= 1 to (# of analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:FREQuency command installs a screen measurement and starts a frequency measurement. If the optional source parameter is specified, the current source is modified.

IF the edge on the screen closest to the trigger reference is rising:

THEN frequency = 1/(time at trailing rising edge - time at leading rising edge)

ELSE frequency = 1/(time at trailing falling edge - time at leading falling edge)

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

**Query Syntax**

:MEASure:FREQuency? [<source>]

The :MEASure:FREQuency? query measures and outputs the frequency of the cycle on the screen closest to the trigger reference.

**Return Format**

<source><NL>

<source> ::= frequency in Hertz in NR3 format

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[:MEASure:SOURce](#)" on page 667
- "[:MEASure:PERiod](#)" on page 655

**Example Code**

- "[Example Code](#)" on page 668

## :MEASure:NDUTy

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:NDUTy [<source>]`

```

<source> ::= {<digital channels> | CHANnel<n> | FUNCtion<m> | MATH<m>
              | WMEMory<r>}

<digital channels> ::= DIGItal<d> for the MSO models

<d> ::= 0 to (# digital channels - 1) in NR1 format

<n> ::= 1 to (# of analog channels) in NR1 format

<m> ::= 1 to (# math functions) in NR1 format

<r> ::= 1 to (# ref waveforms) in NR1 format

```

The :MEASure:NDUTy command installs a screen measurement and starts a negative duty cycle measurement on the current :MEASure:SOURce. If the optional source parameter is specified, the current source is modified.

### NOTE

The signal must be displayed to make the measurement. This command is not available if the source is FFT (Fast Fourier Transform).

### Query Syntax

`:MEASure:NDUTy? [<source>]`

The :MEASure:NDUTy? query measures and outputs the negative duty cycle of the signal specified by the :MEASure:SOURce command. The value returned for the duty cycle is the ratio of the negative pulse width to the period. The negative pulse width and the period of the specified signal are measured, then the duty cycle is calculated with the following formula:

$$\text{-duty cycle} = (-\text{pulse width}/\text{period}) * 100$$

### Return Format

`<value><NL>`

`<value> ::= ratio of negative pulse width to period in NR3 format`

### See Also

- "[Introduction to :MEASure Commands](#)" on page 620
- "[:MEASure:PERiod](#)" on page 655
- "[:MEASure:NWIDth](#)" on page 651
- "[:MEASure:SOURce](#)" on page 667
- "[:MEASure:DUTYcycle](#)" on page 641

## :MEASure:NEDGes

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:NEDGes [<source>]`

```
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | WMMEmory<r>}
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:NEDGes command installs a falling edge count measurement on screen. If the optional source parameter is not specified, the current source is measured.

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

**Query Syntax**    `:MEASure:NEDGes? [<source>]`

The :MEASure:NEDGes? query measures and returns the on-screen falling edge count.

**Return Format**    `<value><NL>`

`<value>` ::= the falling edge count in NR3 format

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:SOURce](#)" on page 667

## :MEASure:NPULses

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:NPULses [<source>]`

```
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | WMMEmory<r>
              | <digital channels>}

<n> ::= 1 to (# analog channels) in NR1 format

<m> ::= 1 to (# math functions) in NR1 format

<r> ::= 1 to (# ref waveforms) in NR1 format

<digital channels> ::= DIGItal<d> for the MSO models

<d> ::= 0 to (# digital channels - 1) in NR1 format
```

The :MEASure:NPULses command installs a falling pulse count measurement on screen. If the optional source parameter is not specified, the current source is measured.

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

**Query Syntax**    `:MEASure:NPULses? [<source>]`

The :MEASure:NPULses? query measures and returns the on-screen falling pulse count.

**Return Format**    `<value><NL>`

```
<value> ::= the falling pulse count in NR3 format
```

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:SOURce](#)" on page 667

## :MEASure:NWIDth

**C** (see [page 1666](#))

**Command Syntax**    `:MEASure:NWIDth [<source>]`

```

<source> ::= {<digital channels> | CHANnel<n> | FUNCtion<m> | MATH<m>
              | WMEMory<r>}

<digital channels> ::= DIGItal<d> for the MSO models

<d> ::= 0 to (# digital channels - 1) in NR1 format

<n> ::= 1 to (# of analog channels) in NR1 format

<m> ::= 1 to (# math functions) in NR1 format

<r> ::= 1 to (# ref waveforms) in NR1 format

```

The :MEASure:NWIDth command installs a screen measurement and starts a negative pulse width measurement. If the optional source parameter is not specified, the current source is modified.

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

**Query Syntax**    `:MEASure:NWIDth? [<source>]`

The :MEASure:NWIDth? query measures and outputs the width of the negative pulse on the screen closest to the trigger reference using the midpoint between the upper and lower thresholds.

FOR the negative pulse closest to the trigger point:

width = (time at trailing rising edge - time at leading falling edge)

**Return Format**    `<value><NL>`

`<value> ::= negative pulse width in seconds in NR3 format`

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:SOURce](#)" on page 667
- "[":MEASure:PWIDth](#)" on page 659
- "[":MEASure:PERiod](#)" on page 655

## :MEASure:OVERshoot

**C** (see [page 1666](#))

**Command Syntax**

```
:MEASure:OVERshoot [<source>]
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | WMMEmory<r>}
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:OVERshoot command installs a screen measurement and starts an overshoot measurement. If the optional source parameter is specified, the current source is modified.

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

**Query Syntax**

```
:MEASure:OVERshoot? [<source>]
```

The :MEASure:OVERshoot? query measures and returns the overshoot of the edge closest to the trigger reference, displayed on the screen. The method used to determine overshoot is to make three different vertical value measurements: Vtop, Vbase, and either Vmax or Vmin, depending on whether the edge is rising or falling.

For a rising edge:

$$\text{overshoot} = ((\text{Vmax}-\text{Vtop}) / (\text{Vtop}-\text{Vbase})) \times 100$$

For a falling edge:

$$\text{overshoot} = ((\text{Vbase}-\text{Vmin}) / (\text{Vtop}-\text{Vbase})) \times 100$$

Vtop and Vbase are taken from the normal histogram of all waveform vertical values. The extremum of Vmax or Vmin is taken from the waveform interval right after the chosen edge, halfway to the next edge. This more restricted definition is used instead of the normal one, because it is conceivable that a signal may have more preshoot than overshoot, and the normal extremum would then be dominated by the preshoot of the following edge.

**Return Format**

```
<overshoot><NL>
<overshoot> ::= the percent of the overshoot of the selected waveform in
NR3 format
```

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:PREShoot](#)" on page 658
- "[":MEASure:SOURce](#)" on page 667

- [":MEASure:VMAX" on page 683](#)
- [":MEASure:VTOP" on page 688](#)
- [":MEASure:VBASe" on page 682](#)
- [":MEASure:VMIN" on page 684](#)

## :MEASure:PEDGes

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MEASure:PEDGes [&lt;source&gt;]</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMMemory&lt;r&gt;}</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</code>
	<code>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</code>
	The :MEASure:PEDGes command installs a rising edge count measurement on screen. If the optional source parameter is not specified, the current source is measured.

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

<b>Query Syntax</b>	<code>:MEASure:PEDGes? [&lt;source&gt;]</code>
	The :MEASure:NEDGes? query measures and returns the on-screen rising edge count.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code> <code>&lt;value&gt; ::= the rising edge count in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :MEASure Commands</a>" on page 620</li> <li>• "<a href="#">":MEASure:SOURce</a>" on page 667</li> </ul>

## :MEASure:PERiod

**C** (see [page 1666](#))

**Command Syntax**

```
:MEASure:PERiod [<source>]
<source> ::= {<digital channels> | CHANnel<n> | FUNCtion<m> | MATH<m>
              | WMEMory<r>}
<digital channels> ::= DIGItal<d> for the MSO models
<d> ::= 0 to (# digital channels - 1) in NR1 format
<n> ::= 1 to (# of analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:PERiod command installs a screen measurement and starts the period measurement. If the optional source parameter is specified, the current source is modified.

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

## Query Syntax

:MEASure:PERiod? [<source>]

The :MEASure:PERiod? query measures and outputs the period of the cycle closest to the trigger reference on the screen. The period is measured at the midpoint of the upper and lower thresholds.

IF the edge closest to the trigger reference on screen is rising:

THEN period = (time at trailing rising edge - time at leading rising edge)

ELSE period = (time at trailing falling edge - time at leading falling edge)

## Return Format

<value><NL>

<value> ::= waveform period in seconds in NR3 format

## See Also

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:SOURce](#)" on page 667
- "[":MEASure:NWIDth](#)" on page 651
- "[":MEASure:PWIDth](#)" on page 659
- "[":MEASure:FREQuency](#)" on page 647

## Example Code

- "[":Example Code](#)" on page 668

## :MEASure:PHASe

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MEASure:PHASe [&lt;source1&gt; [,&lt;source2&gt;]</code>
	<code>&lt;source1&gt;, &lt;source2&gt; ::= {CHANnel&lt;n&gt;   FUNCTion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</code>
	<code>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</code>
	The :MEASure:PHASe command places the instrument in the continuous measurement mode and starts a phase measurement.

<b>Query Syntax</b>	<code>:MEASure:PHASe? [&lt;source1&gt; [,&lt;source2&gt;]</code>
	The :MEASure:PHASe? query measures and returns the phase between the specified sources.

A phase measurement is a combination of the period and delay measurements. First, the period is measured on source1. Then the delay is measured between source1 and source2. The edges used for delay are the source1 rising edge used for the period measurement closest to the horizontal reference and the rising edge on source 2. See :MEASure:DElay for more detail on selecting the 2nd edge.

The phase is calculated as follows:

$$\text{phase} = (\text{delay} / \text{period of input 1}) \times 360$$

<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code>
	<code>&lt;value&gt; ::= the phase angle value in degrees in NR3 format</code>

<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">Introduction to :MEASure Commands</a>" on page 620</li> <li>· "<a href="#">":MEASure:DElay</a>" on page 632</li> <li>· "<a href="#">":MEASure:PERiod</a>" on page 655</li> <li>· "<a href="#">":MEASure:SOURce</a>" on page 667</li> </ul>
-----------------	--

## :MEASure:PPULses

**N** (see [page 1666](#))

### Command Syntax

```
:MEASure:PPULses [<source>]

<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | WMEMory<r>
              | <digital channels>}

<n> ::= 1 to (# analog channels) in NR1 format

<m> ::= 1 to (# math functions) in NR1 format

<r> ::= 1 to (# ref waveforms) in NR1 format

<digital channels> ::= DIGItal<d> for the MSO models

<d> ::= 0 to (# digital channels - 1) in NR1 format
```

The :MEASure:PPULses command installs a rising pulse count measurement on screen. If the optional source parameter is not specified, the current source is measured.

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

### Query Syntax

```
:MEASure:PPULses? [<source>]
```

The :MEASure:PPULses? query measures and returns the on-screen rising pulse count.

### Return Format

```
<value><NL>

<value> ::= the rising pulse count in NR3 format
```

### See Also

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:SOURce](#)" on page 667

## :MEASure:PRESHoot

**C** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MEASure:PRESHoot [&lt;source&gt;]</code>
	<pre>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMMemory&lt;r&gt;}</pre>
	<pre>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</pre>
	<pre>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</pre>
	<p>The :MEASure:PRESHoot command installs a screen measurement and starts a preshoot measurement. If the optional source parameter is specified, the current source is modified.</p>
<b>Query Syntax</b>	<code>:MEASure:PRESHoot? [&lt;source&gt;]</code>
	<p>The :MEASure:PRESHoot? query measures and returns the preshoot of the edge closest to the trigger, displayed on the screen. The method used to determine preshoot is to make three different vertical value measurements: Vtop, Vbase, and either Vmin or Vmax, depending on whether the edge is rising or falling.</p> <p>For a rising edge:</p> $\text{preshoot} = ((\text{Vmin}-\text{Vbase}) / (\text{Vtop}-\text{Vbase})) \times 100$ <p>For a falling edge:</p> $\text{preshoot} = ((\text{Vmax}-\text{Vtop}) / (\text{Vtop}-\text{Vbase})) \times 100$ <p>Vtop and Vbase are taken from the normal histogram of all waveform vertical values. The extremum of Vmax or Vmin is taken from the waveform interval right before the chosen edge, halfway back to the previous edge. This more restricted definition is used instead of the normal one, because it is likely that a signal may have more overshoot than preshoot, and the normal extremum would then be dominated by the overshoot of the preceding edge.</p>
<b>Return Format</b>	<pre>&lt;value&gt;&lt;NL&gt;</pre> <p>&lt;value&gt; ::= the percent of preshoot of the selected waveform in NR3 format</p>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">"Introduction to :MEASure Commands"</a> on page 620</li> <li>· <a href="#">":MEASure:SOURce"</a> on page 667</li> <li>· <a href="#">":MEASure:VMIN"</a> on page 684</li> <li>· <a href="#">":MEASure:VMAX"</a> on page 683</li> <li>· <a href="#">":MEASure:VTOP"</a> on page 688</li> <li>· <a href="#">":MEASure:VBASE"</a> on page 682</li> </ul>

## :MEASure:PWIDth

**C** (see [page 1666](#))

**Command Syntax**    `:MEASure:PWIDth [<source>]`

```
<source> ::= {<digital channels> | CHANnel<n> | FUNCtion<m> | MATH<m>
              | WMEMory<r>}

<digital channels> ::= DIGItal<d> for the MSO models

<d> ::= 0 to (# digital channels - 1) in NR1 format

<n> ::= 1 to (# of analog channels) in NR1 format

<m> ::= 1 to (# math functions) in NR1 format

<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:PWIDth command installs a screen measurement and starts the positive pulse width measurement. If the optional source parameter is specified, the current source is modified.

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

**Query Syntax**    `:MEASure:PWIDth? [<source>]`

The :MEASure:PWIDth? query measures and outputs the width of the displayed positive pulse closest to the trigger reference. Pulse width is measured at the midpoint of the upper and lower thresholds.

IF the edge on the screen closest to the trigger is falling:

THEN width = (time at trailing falling edge - time at leading rising edge)

ELSE width = (time at leading falling edge - time at leading rising edge)

**Return Format**    `<value><NL>`

`<value> ::= width of positive pulse in seconds in NR3 format`

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:SOURce](#)" on page 667
- "[":MEASure:NWIDth](#)" on page 651
- "[":MEASure:PERiod](#)" on page 655

## :MEASure:RESults

**N** (see [page 1666](#))

**Query Syntax** `:MEASure:RESults?`

The `:MEASure:RESults?` query returns the results of the continuously displayed measurements. The response to the `MEASure:RESults?` query is a list of comma-separated values.

If more than one measurement is running continuously, the `:MEASure:RESults` return values are duplicated for each continuous measurement from the first to last (top to bottom) result displayed. Each result returned is separated from the previous result by a comma. There is a maximum of 10 continuous measurements that can be continuously displayed at a time.

When no quick measurements are installed, the `:MEASure:RESults?` query returns nothing (empty string). When the count for any of the measurements is 0, the value of infinity (9.9E+37) is returned for the min, max, mean, and standard deviation.

**Return Format** `<result_list><NL>`

```
<result_list> ::= comma-separated list of measurement results
```

The following shows the order of values received for a single measurement if `:MEASure:STATistics` is set to ON.

Measureme nt label	current	min	max	mean	std dev	count
--------------------	---------	-----	-----	------	---------	-------

Measurement label, current, min, max, mean, std dev, and count are only returned if `:MEASure:STATistics` is ON.

If `:MEASure:STATistics` is set to CURRent, MIN, MAX, MEAN, STDDev, or COUNT only that particular statistic value is returned for each measurement that is on.

**See Also**

- ["Introduction to :MEASure Commands"](#) on page 620
- [":MEASure:STATistics"](#) on page 669

**Example Code**

```
' This program shows the InfiniiVision oscilloscopes' measurement
' statistics commands.
' -----

```

**Option Explicit**

```
Public myMgr As VisaComLib.ResourceManager
Public myScope As VisaComLib.FormattedIO488
Public varQueryResult As Variant
Public strQueryResult As String
```

```

Private Declare Sub Sleep Lib "kernel32" (ByVal dwMilliseconds As Long)

Sub Main()

    On Error GoTo VisaComError

    ' Create the VISA COM I/O resource.
    Set myMgr = New VisaComLib.ResourceManager
    Set myScope = New VisaComLib.FormattedIO488
    Set myScope.IO = myMgr.Open("TCPIP0::130.29.70.228::inst0::INSTR")

    ' Initialize.
    myScope.IO.Clear      ' Clear the interface.
    myScope.WriteString "*RST"      ' Reset to the defaults.
    myScope.WriteString "*CLS"      ' Clear the status data structures.
    myScope.WriteString ":AUToscale"

    ' Install some measurements.
    myScope.WriteString ":MEASure:SOURce CHANnel1"      ' Input source.

    Dim MeasurementArray(3) As String
    MeasurementArray(0) = "FREQuency"
    MeasurementArray(1) = "DUTYcycle"
    MeasurementArray(2) = "VAMPplitude"
    MeasurementArray(3) = "VPP"
    Dim Measurement As Variant

    For Each Measurement In MeasurementArray
        myScope.WriteString ":MEASure:" + Measurement
        myScope.WriteString ":MEASure:" + Measurement + "?"
        varQueryResult = myScope.ReadNumber      ' Read measurement value.
        Debug.Print Measurement + ":" + FormatNumber(varQueryResult, 4)
    Next

    myScope.WriteString ":MEASure:STATistics:RESet"      ' Reset stats.
    Sleep 5000      ' Wait for 5 seconds.

    ' Select the statistics results type.
    Dim ResultsTypeArray(6) As String
    ResultsTypeArray(0) = "CURRent"
    ResultsTypeArray(1) = "MINimum"
    ResultsTypeArray(2) = "MAXimum"
    ResultsTypeArray(3) = "MEAN"
    ResultsTypeArray(4) = "STDDev"
    ResultsTypeArray(5) = "COUNT"
    ResultsTypeArray(6) = "ON"      ' All results.
    Dim ResultType As Variant

    Dim ResultsList()

    Dim ValueColumnArray(6) As String
    ValueColumnArray(0) = "Meas_Lbl"
    ValueColumnArray(1) = "Current"
    ValueColumnArray(2) = "Min"
    ValueColumnArray(3) = "Max"
    ValueColumnArray(4) = "Mean"
    ValueColumnArray(5) = "Std_Dev"

```

```

ValueColumnArray(6) = "Count"
Dim ValueColumn As Variant

For Each ResultType In ResultsTypeArray
    myScope.WriteString ":MEASure:STATistics " + ResultType

        ' Get the statistics results.
        Dim intCounter As Integer
        intCounter = 0
        myScope.WriteString ":MEASure:REsults?"
        ResultsList() = myScope.ReadList

        For Each Measurement In MeasurementArray

            If ResultType = "ON" Then      ' All statistics.

                For Each ValueColumn In ValueColumnArray
                    If VarType(ResultsList(intCounter)) <> vbString Then
                        Debug.Print "Measure statistics result CH1, " +
                            Measurement + ", "; ValueColumn + ":" + -
                            FormatNumber(ResultsList(intCounter), 4)

                    Else      ' Result is a string (e.g., measurement label).
                        Debug.Print "Measure statistics result CH1, " +
                            Measurement + ", "; ValueColumn + ":" + -
                            ResultsList(intCounter)

                End If

                intCounter = intCounter + 1

            Next

            Else      ' Specific statistic (e.g., Current, Max, Min, etc.).

                Debug.Print "Measure statistics result CH1, " +
                    Measurement + ", "; ResultType + ":" + -
                    FormatNumber(ResultsList(intCounter), 4)

                intCounter = intCounter + 1

            End If

        Next

        Exit Sub

    VisaComError:
        MsgBox "VISA COM Error:" + vbCrLf + Err.Description

    End Sub

```

## :MEASure:RISetime

**C** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MEASure:RISetime [&lt;source&gt;]</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</code>
	<code>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</code>
	The :MEASure:RISetime command installs a screen measurement and starts a rise-time measurement. If the optional source parameter is specified, the current source is modified.

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

<b>Query Syntax</b>	<code>:MEASure:RISetime? [&lt;source&gt;]</code>
	The :MEASure:RISetime? query measures and outputs the rise time of the displayed rising (positive-going) edge closest to the timebase reference. For maximum measurement accuracy, set the sweep speed as fast as possible while leaving the leading edge of the waveform on the display. The rise time is determined by measuring the time at the lower threshold of the rising edge and the time at the upper threshold of the rising edge, then calculating the rise time with the following formula:
	rise time = time at upper threshold - time at lower threshold
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code> <code>&lt;value&gt; ::= rise time in seconds in NR3 format</code>

- See Also**
- "[Introduction to :MEASure Commands](#)" on page 620
  - "[:MEASure:SOURce](#)" on page 667
  - "[:MEASure:FALLtime](#)" on page 642
  - "[:MEASure:SLEWrate](#)" on page 666

## :MEASure:SDEViation

**N** (see [page 1666](#))

**Command Syntax**

```
:MEASure:SDEViation [<source>]
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | WMMemory<r>}
<n> ::= 1-2 or 1-4 (# of analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

**NOTE**

This ":MEASure:VRMS DISPLAY, AC" command is the preferred syntax for making standard deviation measurements.

The :MEASure:SDEViation command installs a screen measurement and starts std deviation measurement. If the optional source parameter is specified, the current source is modified.

**NOTE**

This command is not available if the source is FFT (Fast Fourier Transform).

**Query Syntax**

```
:MEASure:SDEViation? [<source>]
```

The :MEASure:SDEViation? query measures and outputs the std deviation of the selected waveform. The oscilloscope computes the std deviation on all displayed data points.

**Return Format**

```
<value><NL>
<value> ::= calculated std deviation value in NR3 format
```

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:VRMS"](#) on page 687
- "[":MEASure:SOURce"](#) on page 667

## :MEASure:SHOW

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:SHOW <on_off>`

`<on_off> ::= {{0 | OFF} | {1 | ON}}`

The :MEASure:SHOW command enables markers for tracking measurements on the display.

**Query Syntax**    `:MEASure:SHOW?`

The :MEASure:SHOW? query returns the current state of the markers.

This can return OFF when :MARKer:MODE selects a mode other than MEASurement.

**Return Format**    `<on_off><NL>`

`<on_off> ::= {1 | 0}`

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MARKer:MODE](#)" on page 583

## :MEASure:SLEWrate

**N** (see [page 1666](#))

**Command Syntax**

```
:MEASure:SLEWrate [<source>[,<slope>]]  
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | WMEMory<r>}  
<n> ::= 1 to (# of analog channels) in NR1 format  
<m> ::= 1 to (# math functions) in NR1 format  
<r> ::= 1 to (# ref waveforms) in NR1 format  
<slope> ::= {RISing | FALLing | EITHER}
```

The :MEASure:SLEWrate command installs a slew rate measurement on the oscilloscope's front-panel screen.

The slew rate of an edge is the change in vertical value between the lower and upper thresholds of a waveform source (typically volts) divided by the change in time between where the waveform threshold crossings take place.

The lower and upper thresholds for the measurement are specified by the measurement threshold settings for the source waveform (see :MEASure:DEFine). If the <source> parameter is not specified, the current :MEASure:SOURce setting is used

The on-screen edge closest to the timebase reference is measured.

You can specify that a RISing edge be measured, a FALLing edge be measured, or either a rising or a falling edge be measured (EITHER). If the <slope> is not specified, a rising edge is measured.

### NOTE

This command is not available if the source is a FFT (Fast Fourier Transform) waveform.

### Query Syntax

```
:MEASure:SLEWrate? [<source>[,<slope>]]
```

The :MEASure:SLEWrate? query returns the measured slew rate of the specified edge closest to the timebase reference.

### Return Format

```
<value><NL>  
<value> ::= slew rate in vertical units/second in NR3 format
```

### See Also

- [":MEASure:DEFine"](#) on page 629
- [":MEASure:SOURce"](#) on page 667
- [":MEASure:RISetime"](#) on page 663
- [":MEASure:FALLtime"](#) on page 642
- ["Introduction to :MEASure Commands"](#) on page 620

## :MEASure:SOURce

**C** (see [page 1666](#))

**Command Syntax**

```
:MEASure:SOURce <source1>[,<source2>]
<source1>,<source2> ::= {<digital channels> | CHANnel<n> | FUNCtion<m>
| MATH<m> | WMEMory<r>}
<digital channels> ::= DIGItal<d> for the MSO models
<n> ::= 1 to (# of analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1-2 in NR1 format
<d> ::= 0 to (# digital channels - 1) in NR1 format
```

The :MEASure:SOURce command sets the default sources for measurements. The specified sources are used as the sources for the MEASure subsystem commands if the sources are not explicitly set with the command.

If a source is specified for any measurement, the current source is changed to this new value.

If :MARKer:MODE is set to OFF or MANUAL, setting :MEASure:SOURce to CHANnel<n>, FUNCtion<m>, or MATH<m> will also set :MARKer:X1Y1source to source1 and :MARKer:X2Y2source to source2.

**Query Syntax**

The :MEASure:SOURce? query returns the current source selections. If source2 is not specified, the query returns "NONE" for source2. If all channels are off, the query returns "NONE,NONE". Source2 applies only to :MEASure:DELay and :MEASure:PHASE measurements.

### NOTE

MATH<m> is an alias for FUNCtion<m>. The query will return FUNC<m> if the source is FUNCtion<m> or MATH<m>.

### NOTE

FUNCtion or MATH (without the "<m>" math function number) is an alias for FUNCtion2 or MATH2. The query will return FUNC2 if the source is FUNCtion or MATH.

### Return Format

```
<source1>,<source2><NL>
<source1>,<source2> ::= {<digital channels> | CHAN<n> | FUNC<m>
| WMEM<r> | NONE}
```

### See Also:

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MARKer:MODE"](#) on page 583

- [":MARKer:X1Y1source" on page 586](#)
- [":MARKer:X2Y2source" on page 589](#)
- [":MEASure:DElay" on page 632](#)
- [":MEASure:PHASE" on page 656](#)

**Example Code**

```
' MEASURE - The commands in the MEASure subsystem are used to make
' measurements on displayed waveforms.
myScope.WriteString ":MEASure:SOURce CHANnel1"      ' Source to measure.
myScope.WriteString ":MEASure:FREQuency?"      ' Query for frequency.
varQueryResult = myScope.ReadNumber      ' Read frequency.
MsgBox "Frequency:" + vbCrLf _
      + FormatNumber(varQueryResult / 1000, 4) + " kHz"
myScope.WriteString ":MEASure:DUTYcycle?"      ' Query for duty cycle.
varQueryResult = myScope.ReadNumber      ' Read duty cycle.
MsgBox "Duty cycle:" + vbCrLf _
      + FormatNumber(varQueryResult, 3) + "%"
myScope.WriteString ":MEASure:RISetime?"      ' Query for risetime.
varQueryResult = myScope.ReadNumber      ' Read risetime.
MsgBox "Risetime:" + vbCrLf _
      + FormatNumber(varQueryResult * 1000000, 4) + " us"
myScope.WriteString ":MEASure:VPP?"      ' Query for Pk to Pk voltage.
varQueryResult = myScope.ReadNumber      ' Read VPP.
MsgBox "Peak to peak voltage:" + vbCrLf _
      + FormatNumber(varQueryResult, 4) + " V"
myScope.WriteString ":MEASure:VMAX?"      ' Query for Vmax.
varQueryResult = myScope.ReadNumber      ' Read Vmax.
MsgBox "Maximum voltage:" + vbCrLf _
      + FormatNumber(varQueryResult, 4) + " V"
```

See complete example programs at: [Chapter 46, “Programming Examples,”](#) starting on page 1675

## :MEASure:STATistics

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:STATistics <type>`

$$<\text{type}> ::= \{\{\text{ON} \mid 1\} \mid \text{CURRent} \mid \text{MINimum} \mid \text{MAXimum} \mid \text{MEAN} \mid \text{STDDev} \mid \text{COUNt}\}$$

The :MEASure:STATistics command determines the type of information returned by the :MEASure:RESults? query. ON means all the statistics are on.

**Query Syntax**    `:MEASure:STATistics?`

The :MEASure:STATistics? query returns the current statistics mode.

**Return Format**    `<type><NL>`

$$<\text{type}> ::= \{\text{ON} \mid \text{CURR} \mid \text{MIN} \mid \text{MAX} \mid \text{MEAN} \mid \text{STDD} \mid \text{COUN}\}$$

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:RESults](#)" on page 660
- "[":MEASure:STATistics:DISPlay](#)" on page 670
- "[":MEASure:STATistics:RESet](#)" on page 673
- "[":MEASure:STATistics:INCRelement](#)" on page 671

**Example Code**

- "[Example Code](#)" on page 660

## :MEASure:STATistics:DISPlay

**N** (see [page 1666](#))

**Command Syntax** `:MEASure:STATistics:DISPlay {{0 | OFF} | {1 | ON}}`

The :MEASure:STATistics:DISPlay command disables or enables the display of the measurement statistics.

**Query Syntax** `:MEASure:STATistics:DISPlay?`

The :MEASure:STATistics:DISPlay? query returns the state of the measurement statistics display.

**Return Format** `{0 | 1}<NL>`

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[:MEASure:RESults](#)" on page 660
- "[:MEASure:STATistics](#)" on page 669
- "[:MEASure:STATistics:MCCount](#)" on page 672
- "[:MEASure:STATistics:RESet](#)" on page 673
- "[:MEASure:STATistics:INCRement](#)" on page 671
- "[:MEASure:STATistics:RSDeviation](#)" on page 674

## :MEASure:STATistics:INCRement

**N** (see [page 1666](#))

**Command Syntax** :MEASure:STATistics:INCRement

This command updates the statistics once (incrementing the count by one) using the current measurement values. It corresponds to the front panel **Increment Statistics** softkey in the Measurement Statistics Menu. This command lets you, for example, gather statistics over multiple pulses captured in a single acquisition. To do this, change the horizontal position and enter the command for each new pulse that is measured.

This command is only allowed when the oscilloscope is stopped and quick measurements are on.

The command is allowed in segmented acquisition mode even though the corresponding front panel softkey is not available.

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:STATistics](#)" on page 669
- "[":MEASure:STATistics:DISPlay](#)" on page 670
- "[":MEASure:STATistics:RESet](#)" on page 673
- "[":MEASure:RESULTS](#)" on page 660

## :MEASure:STATistics:MCOUNT

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:STATistics:MCOUNT <setting>`  
`<setting> ::= {INFinite | <count>}`  
`<count> ::= 2 to 2000 in NR1 format`

The :MEASure:STATistics:MCOUNT command specifies the maximum number of values used when calculating measurement statistics.

**Query Syntax**    `:MEASure:STATistics:MCOUNT?`

The :MEASure:STATistics:MCOUNT? query returns the current measurement statistics max count setting.

**Return Format**    `<setting><NL>`  
`<setting> ::= {INF | <count>}`  
`<count> ::= 2 to 2000`

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:REsults](#)" on page 660
- "[":MEASure:STATistics](#)" on page 669
- "[":MEASure:STATistics:DISPLAY](#)" on page 670
- "[":MEASure:STATistics:RSDeviation](#)" on page 674
- "[":MEASure:STATistics:RESET](#)" on page 673
- "[":MEASure:STATistics:INCREMENT](#)" on page 671

## :MEASure:STATistics:RESet

**N** (see [page 1666](#))

**Command Syntax** :MEASure:STATistics:RESet

This command resets the measurement statistics, zeroing the counts.

Note that the measurement (statistics) configuration is not deleted.

- See Also**
- "[Introduction to :MEASure Commands](#)" on page 620
  - "[:MEASure:STATistics](#)" on page 669
  - "[:MEASure:STATistics:DISPlay](#)" on page 670
  - "[:MEASure:RESULTS](#)" on page 660
  - "[:MEASure:STATistics:INCRelement](#)" on page 671

**Example Code**

- "[Example Code](#)" on page 660

## :MEASure:STATistics:RSDeviation

**N** (see [page 1666](#))

**Command Syntax** `:MEASure:STATistics:RSDeviation {{0 | OFF} | {1 | ON}}`

The `:MEASure:STATistics:RSDeviation` command disables or enables relative standard deviations, that is, standard deviation/mean, in the measurement statistics.

**Query Syntax** `:MEASure:STATistics:RSDeviation?`

The `:MEASure:STATistics:RSDeviation?` query returns the current relative standard deviation setting.

**Return Format** `{0 | 1}<NL>`

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:REsults](#)" on page 660
- "[":MEASure:STATistics](#)" on page 669
- "[":MEASure:STATistics:DISPLAY](#)" on page 670
- "[":MEASure:STATistics:MCOunt](#)" on page 672
- "[":MEASure:STATistics:RESET](#)" on page 673
- "[":MEASure:STATistics:INCREMENT](#)" on page 671

## :MEASure:TEDGE

**N** (see [page 1666](#))

### Command Syntax

```
:MEASure:TEDGE [<slope>,<occurrence>[,<source>]
<slope> ::= {RISing | FALLing | EITHer}
<occurrence> ::= [+ | -]<number>
<number> ::= the edge number in NR1 format
<source> ::= {<digital channels> | CHANnel<n> | FUNCtion<m> | MATH<m>
| WMEMory<r>}
<digital channels> ::= DIGItal<d> for the MSO models
<n> ::= 1 to (# of analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
<d> ::= 0 to (# digital channels - 1) in NR1 format
```

The :MEASure:TEDGE command installs a screen measurement whose result is the time of the specified edge transition relative to the trigger edge (time=zero).

The threshold voltage used for this measurement is at the 50% point with a small amount of hysteresis added. You cannot change the threshold voltage used for this measurement with the :MEASure:DEFine command.

The optional <slope> parameter specifies whether to look for RISing edges or FALLing edges. If not otherwise specified, rising edges are assumed.

The <occurrence> parameter specifies the Nth edge to identify.

An <occurrence> value of zero (0) means the edge closest to the timebase reference; it is equivalent to the **Auto** selection for the **Edge #** in the front panel user interface. The EITHer (either edge) <slope> option can be used only when the <occurrence> count is zero (0).

Any other <occurrence> value means the Nth edge from the left side of the display.

The <occurrence> parameter can optionally have a plus sign (+) or a minus sign (-) to specify a rising or falling slope. Plus or minus signs cannot be used when the <slope> parameter is used.

If the optional <source> parameter is not specified, the current :MEASure:SOURce setting is used.

### NOTE

This command is not available if the source is a FFT (Fast Fourier Transform) waveform.

**Query Syntax**    `:MEASure:TEDGE? [<slope>,<occurrence>[,<source>]`

When the :MEASure:TEDGE query is sent, the displayed signal is searched for the specified transition.

The time interval between the trigger event and the edge occurrence is returned.

If the specified crossing cannot be found, the oscilloscope returns +9.9E+37. This value is returned if the waveform does not cross the specified vertical value, or if the waveform does not cross the specified vertical value for the specific number of times in the direction specified.

**Return Format**    `<value><NL>`

`<value>` ::= time in seconds of the specified transition in NR3 format

**:MEASure:TEDGE Code** You can use multiple :MEASure:TEDGE? measurements to form delay and phase measurements:

Delay = time at the Nth rising or falling edge of the channel - time at the same edge of another channel

Phase = (delay between channels / period of channel) x 360

For example:

```
' Make a delay measurement between channel 1 and 2.
Dim dblChan1Edge1 As Double
Dim dblChan2Edge1 As Double
Dim dblChan1Edge2 As Double
Dim dblDelay As Double
Dim dblPeriod As Double
Dim dblPhase As Double

' Query time at 1st rising edge on ch1.
myScope.WriteString ":MEASURE:TEDGE? +1, CHAN1"

' Read time at edge 1 on ch 1.
dblChan1Edge1 = myScope.ReadNumber

' Query time at 1st rising edge on ch2.
myScope.WriteString ":MEASURE:TEDGE? +1, CHAN2"

' Read time at edge 1 on ch 2.
dblChan2Edge1 = myScope.ReadNumber

' Calculate delay time between ch1 and ch2.
dblDelay = dblChan2Edge1 - dblChan1Edge1

' Write calculated delay time to screen.
MsgBox "Delay = " + vbCrLf + CStr(dblDelay)

' Make a phase difference measurement between channel 1 and 2.
' Query time at 1st rising edge on ch1.
myScope.WriteString ":MEASURE:TEDGE? +2, CHAN1"

' Read time at edge 2 on ch 1.
```

```
dblChan1Edge2 = myScope.ReadNumber  
  
' Calculate period of ch 1.  
dblPeriod = dblChan1Edge2 - dblChan1Edge1  
  
' Calculate phase difference between ch1 and ch2.  
dblPhase = (dblDelay / dblPeriod) * 360  
MsgBox "Phase = " + vbCrLf + CStr(dblPhase)
```

See complete example programs at: [Chapter 46](#), “Programming Examples,” starting on page 1675

**See Also**

- ["Introduction to :MEASure Commands"](#) on page 620
- [":MEASure:TVALUE"](#) on page 678
- [":MEASure:VTIMe"](#) on page 1587

## :MEASure:TVALue

**C** (see [page 1666](#))

**Query Syntax**    `:MEASure:TVALue? <value>, [<slope>]<occurrence>[,<source>]`

`<value>` ::= the vertical value that the waveform must cross. The value can be volts or a math function value such as dB, Vs, or V/s.

`<slope>` ::= direction of the waveform. A rising slope is indicated by a plus sign (+). A falling edge is indicated by a minus sign (-).

`<occurrence>` ::= the transition to be reported. If the occurrence number is one, the first crossing is reported. If the number is two, the second crossing is reported, etc.

`<source>` ::= {CHANnel<n> | FUNCTion<m> | MATH<m> | WMMemory<r>}

`<n>` ::= 1 to (# analog channels) in NR1 format

`<m>` ::= 1 to (# math functions) in NR1 format

`<r>` ::= 1 to (# ref waveforms) in NR1 format

When the :MEASure:TVALue? query is sent, the displayed signal is searched for the specified value level and transition. The time interval between the trigger event and this defined occurrence is returned as the response to the query.

The specified value can be negative or positive. To specify a negative value, use a minus sign (-). The sign of the slope selects a rising (+) or falling (-) edge. If no sign is specified for the slope, it is assumed to be the rising edge.

The magnitude of the occurrence defines the occurrence to be reported. For example, +3 returns the time for the third time the waveform crosses the specified value level in the positive direction. Once this value crossing is found, the oscilloscope reports the time at that crossing in seconds, with the trigger point (time zero) as the reference.

If the specified crossing cannot be found, the oscilloscope reports +9.9E+37. This value is returned if the waveform does not cross the specified value, or if the waveform does not cross the specified value for the specified number of times in the direction specified.

If the optional source parameter is specified, the current source is modified.

### NOTE

This query is not available if the source is FFT (Fast Fourier Transform).

**Return Format**    `<value><NL>`

<value> ::= time in seconds of the specified value crossing in  
NR3 format

See Also

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:TEDGE](#)" on page 675
- "[":MEASure:VTIMe](#)" on page 1587

## :MEASure:VAMplitude

**C** (see [page 1666](#))

**Command Syntax**    `:MEASure:VAMplitude [<source>]`

```
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | WMMemory<r>}
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:VAMplitude command installs a screen measurement and starts a vertical amplitude measurement. If the optional source parameter is specified, the current source is modified.

**Query Syntax**    `:MEASure:VAMplitude? [<source>]`

The :MEASure:VAMplitude? query measures and returns the vertical amplitude of the waveform. To determine the amplitude, the instrument measures Vtop and Vbase, then calculates the amplitude as follows:

$$\text{vertical amplitude} = \text{Vtop} - \text{Vbase}$$

**Return Format**    `<value><NL>`

```
<value> ::= the amplitude of the selected waveform in NR3 format
```

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[:MEASure:SOURce](#)" on page 667
- "[:MEASure:VBASe](#)" on page 682
- "[:MEASure:VTOP](#)" on page 688
- "[:MEASure:VPP](#)" on page 685

## :MEASure:VAverage

**C** (see [page 1666](#))

**Command Syntax**

```
:MEASure:VAverage [<interval>] [,<source>]
<interval> ::= {CYCLE | DISPlay}
<source> ::= {CHANnel<n> | FUNCTion<m> | MATH<m> | FFT | WMEMORY<r>}
<n> ::= 1-2 or 1-4 (# of analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:VAverage command installs a screen measurement and starts an average value measurement.

The <interval> option lets you specify the measurement interval: either an integral number of cycles, or the full screen. If <interval> is not specified, DISPlay is implied.

If the optional source parameter is specified, the current source is modified.

**Query Syntax**

```
:MEASure:VAverage? [<interval>] [,<source>]
```

The :MEASure:VAverage? query returns the average value of an integral number of periods of the signal.

**Return Format**

```
<value><NL>
<value> ::= calculated average value in NR3 format
```

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:SOURce](#)" on page 667

## :MEASure:VBASE

**C** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MEASure:VBASE [&lt;source&gt;]</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMMemory&lt;r&gt;}</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</code>
	<code>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</code>
	The :MEASure:VBASE command installs a screen measurement and starts a waveform base value measurement. If the optional source parameter is specified, the current source is modified.

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

<b>Query Syntax</b>	<code>:MEASure:VBASE? [&lt;source&gt;]</code>
	The :MEASure:VBASE? query returns the vertical value at the base of the waveform. The base value of a pulse is normally not the same as the minimum value.
<b>Return Format</b>	<code>&lt;base_voltage&gt;&lt;NL&gt;</code>  <code>&lt;base_voltage&gt; ::= value at the base of the selected waveform in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">"Introduction to :MEASure Commands"</a> on page 620</li> <li>· <a href="#">":MEASure:SOURce"</a> on page 667</li> <li>· <a href="#">":MEASure:VTOP"</a> on page 688</li> <li>· <a href="#">":MEASure:VAMPLitude"</a> on page 680</li> <li>· <a href="#">":MEASure:VMIN"</a> on page 684</li> </ul>

## :MEASure:VMAX

**C** (see [page 1666](#))

**Command Syntax**    `:MEASure:VMAX [<source>]`

```
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | FFT | WMEMory<r>}
<n> ::= 1-2 or 1-4 (# of analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:VMAX command installs a screen measurement and starts a maximum vertical value measurement. If the optional source parameter is specified, the current source is modified.

**Query Syntax**    `:MEASure:VMAX? [<source>]`

The :MEASure:VMAX? query measures and outputs the maximum vertical value present on the selected waveform.

**Return Format**    `<value><NL>`

```
<value> ::= maximum vertical value of the selected waveform in
           NR3 format
```

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:SOURce](#)" on page 667
- "[":MEASure:VMIN](#)" on page 684
- "[":MEASure:VPP](#)" on page 685
- "[":MEASure:VTOP](#)" on page 688

## :MEASure:VMIN

**C** (see [page 1666](#))

**Command Syntax**    `:MEASure:VMIN [<source>]`

```
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | FFT | WMEMORY<r>}
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:VMIN command installs a screen measurement and starts a minimum vertical value measurement. If the optional source parameter is specified, the current source is modified.

**Query Syntax**    `:MEASure:VMIN? [<source>]`

The :MEASure:VMIN? query measures and outputs the minimum vertical value present on the selected waveform.

**Return Format**    `<value><NL>`

```
<value> ::= minimum vertical value of the selected waveform in
NR3 format
```

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:SOURce](#)" on page 667
- "[":MEASure:VBASe](#)" on page 682
- "[":MEASure:VMAX](#)" on page 683
- "[":MEASure:VPP](#)" on page 685

## :MEASure:VPP

**C** (see [page 1666](#))

**Command Syntax**    `:MEASure:VPP [<source>]`

```
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | FFT | WMEMORY<r>}
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:VPP command installs a screen measurement and starts a vertical peak-to-peak measurement. If the optional source parameter is specified, the current source is modified.

**Query Syntax**    `:MEASure:VPP? [<source>]`

The :MEASure:VPP? query measures the maximum and minimum vertical value for the selected source, then calculates the vertical peak-to-peak value and returns that value. The peak-to-peak value (Vpp) is calculated with the following formula:

$$V_{pp} = V_{max} - V_{min}$$

Vmax and Vmin are the vertical maximum and minimum values present on the selected source.

**Return Format**    `<value><NL>`

```
<value> ::= vertical peak to peak value in NR3 format
```

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:SOURce](#)" on page 667
- "[":MEASure:VMAX](#)" on page 683
- "[":MEASure:VMIN](#)" on page 684
- "[":MEASure:VAMPLitude](#)" on page 680

## :MEASure:VRATio

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:VRATio [<interval>] [,<source1>] [,<source2>]`

```
<interval> ::= {CYCLE | DISPLAY}
<source1,2> ::= {CHANnel<n> | FUNCTION<m> | MATH<m> | WMEMORY<r>}
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:VRATio command installs a ratio measurement on screen. Ratio measurements show the ratio of the ACRMS value of source1 to that of source2, expressed in dB.

The <interval> option lets you specify the measurement interval: either an integral number of cycles, or the full screen. If <interval> is not specified, DISPLAY is implied.

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

### Query Syntax

`:MEASure:VRATio? [<interval>] [<source1>] [,<source2>]`

The :MEASure:VRATio? query measures and returns the ratio of AC RMS values of the specified sources expressed as dB.

### Return Format

`<value><NL>`  
`<value> ::= the ratio value in dB in NR3 format`

### See Also

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:VRMS](#)" on page 687
- "[":MEASure:SOURce](#)" on page 667

## :MEASure:VRMS

**C** (see [page 1666](#))

- Command Syntax**
- ```
:MEASure:VRMS [<interval>[,<type>][,<source>]
<interval> ::= {CYCLE | DISPlay}
<type> ::= {AC | DC}
<source> ::= {CHANnel<n> | FUNCTion<m> | MATH<m> | WMEMory<r>}
<n> ::= 1-2 or 1-4 (# of analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```
- The :MEASure:VRMS command installs a screen measurement and starts an RMS value measurement.
- The <interval> option lets you specify the measurement interval: either an integral number of cycles, or the full screen. If <interval> is not specified, DISPlay is implied.
- The <type> option lets you choose between a DC RMS measurement and an AC RMS measurement. If <type> is not specified, DC is implied.
- If the optional source parameter is specified, the current source is modified.

### NOTE

This command is not available if the source is FFT (Fast Fourier Transform).

- Query Syntax**
- ```
:MEASure:VRMS? [<interval>][,<type>][,<source>]
```
- The :MEASure:VRMS? query measures and outputs the RMS measurement value.
- Return Format**
- ```
<value><NL>
<value> ::= calculated dc RMS value in NR3 format
```
- See Also**
- ["Introduction to :MEASure Commands" on page 620](#)
  - [":MEASure:SOURce" on page 667](#)

## :MEASure:VTOP

**C** (see [page 1666](#))

**Command Syntax**    `:MEASure:VTOP [<source>]`

```
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m>}

<n> ::= 1-2 or 1-4 (# of analog channels) in NR1 format

<m> ::= 1 to (# math functions) in NR1 format

<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:VTOP command installs a screen measurement and starts a waveform top value measurement.

### NOTE

This query is not available if the source is FFT (Fast Fourier Transform).

**Query Syntax**    `:MEASure:VTOP? [<source>]`

The :MEASure:VTOP? query returns the vertical value at the top of the waveform. The top value of the pulse is normally not the same as the maximum value.

**Return Format**    `<value><NL>`

```
<value> ::= vertical value at the top of the waveform in NR3 format
```

### See Also

- "[Introduction to :MEASure Commands](#)" on page 620
- "[:MEASure:SOURce](#)" on page 667
- "[:MEASure:VMAX](#)" on page 683
- "[:MEASure:VAMPLitude](#)" on page 680
- "[:MEASure:VBASE](#)" on page 682

## :MEASure:WINDOW

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:WINDOW <type>`

`<type> ::= {MAIN | ZOOM | AUTO | GATE}`

The :MEASure:WINDOW command lets you choose whether measurements are made in the Main window portion of the display, the Zoom window portion of the display (when the zoomed time base is displayed), or gated by the X1 and X2 cursors.

- MAIN – the measurement window is the Main window.
- ZOOM – the measurement window is the lower, Zoom window.
- AUTO – when the zoomed time base is displayed, the measurement is attempted in the lower, Zoom window; if it cannot be made there, or if the zoomed time base is not displayed, the Main window is used.
- GATE – the measurement window is between the X1 and X2 cursors. When the zoomed time base is displayed, the X1 and X2 cursors in the Zoom window portion of the display are used.

**Query Syntax**    `:MEASure:WINDOW?`

The :MEASure:WINDOW? query returns the current measurement window setting.

**Return Format**    `<type><NL>`

`<type> ::= {MAIN | ZOOM | AUTO | GATE}`

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:SOURce](#)" on page 667

## :MEASure:XMAX

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:XMAX [<source>]`

```
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | FFT | WMEMORY<r>}
<n> ::= 1-2 or 1-4 (# of analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:XMAX command installs a screen measurement and starts an X-at-Max-Y measurement on the selected window. If the optional source parameter is specified, the current source is modified.

**NOTE**

:MEASure:XMAX is an alias for :MEASure:TMAX.

**Query Syntax**    `:MEASure:XMAX? [<source>]`

The :MEASure:XMAX? query measures and returns the horizontal axis value at which the maximum vertical value occurs. If the optional source is specified, the current source is modified.

**Return Format**    `<value><NL>`

```
<value> ::= horizontal value of the maximum in NR3 format
```

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:XMIN"](#) on page 691
- "[":MEASure:TMAX"](#) on page 1578

## :MEASure:XMIN

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:XMIN [<source>]`

```
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | FFT | WMEMORY<r>}
<n> ::= 1-2 or 1-4 (# of analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:XMIN command installs a screen measurement and starts an X-at-Min-Y measurement on the selected window. If the optional source parameter is specified, the current source is modified.

**NOTE**

:MEASure:XMIN is an alias for :MEASure:TMIN.

**Query Syntax**    `:MEASure:XMIN? [<source>]`

The :MEASure:XMIN? query measures and returns the horizontal axis value at which the minimum vertical value occurs. If the optional source is specified, the current source is modified.

**Return Format**    `<value><NL>`

```
<value> ::= horizontal value of the minimum in NR3 format
```

**See Also**

- "Introduction to :MEASure Commands" on page 620
- "[:MEASure:XMAX](#)" on page 690
- "[:MEASure:TMIN](#)" on page 1579

## :MEASure:YATX

**N** (see [page 1666](#))

**Command Syntax**

```
:MEASure:YATX <horiz_location>[,<source>]
<horiz_location> ::= time from trigger in seconds
<source> ::= {<digital channels> | CHANnel<n> | FUNCtion<m> | MATH<m>
              | FFT | WMEMory<r>}
<digital channels> ::= DIGItal<d> for the MSO models
<d> ::= 0 to (# digital channels - 1) in NR1 format
<n> ::= 1 to (# of analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:YATX command installs a screen measurement of the vertical value at a specified horizontal value on the source specified (see also :MEASure:SOURce).

The specified horizontal value must be on the screen; when it is a time value, it is referenced to the trigger event. If the optional source parameter is specified, the measurement source is modified.

### NOTE

When the source is an FFT (Fast Fourier Transform) waveform, the <horiz\_location> is a frequency value instead of a time value.

**Query Syntax**

```
:MEASure:YATX? <horiz_location>[,<source>]
```

The :MEASure:YATX? query returns the vertical value at a specified horizontal value on the source specified (see also :MEASure:SOURce).

**Return Format**

```
<value><NL>
<value> ::= vertical value at the specified horizontal location
           in NR3 format
```

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:SOURce](#)" on page 667
- "[":MEASure:TEDGE](#)" on page 675
- "[":MEASure:TVALue](#)" on page 678

## 27 :MEASure Power Commands

These :MEASure commands are available when the power measurements and analysis application is licensed and enabled.

**Table 116** :MEASure Power Commands Summary

Command	Query	Options and Query Returns
:MEASure:ANGLE [<source1> [, <source2>] (see <a href="#">page 698</a> )	:MEASure:ANGLE? [<source1> [, <source2>] (see <a href="#">page 698</a> )	<source1>, <source2> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format  <return_value> ::= the power phase angle in degrees in NR3 format
:MEASure:APPARENT [<source1> [, <source2>] (see <a href="#">page 699</a> )	:MEASure:APPARENT? [<source1> [, <source2>] (see <a href="#">page 699</a> )	<source1>, <source2> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format  <return_value> ::= the apparent power value in NR3 format
:MEASure:CPLoss [<source1> [, <source2>] (see <a href="#">page 700</a> )	:MEASure:CPLoss? [<source1> [, <source2>] (see <a href="#">page 700</a> )	<source1>, <source2> <source1> ::= {FUNCTION<m>   MATH<m>}  <source2> ::= {CHANnel<n>} <m> ::= 1 to (# math functions) in NR1 format  <n> ::= 1 to (# analog channels) in NR1 format  <return_value> ::= the switching loss per cycle watts value in NR3 format

**Table 116** :MEASure Power Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:CRESt [<source>] (see page 701)	:MEASure:CRESt? [<source>] (see page 701)	<source> ::= {CHANnel<n>   FUNCtion<m>   MATH<m>} <n> ::= 1 to (# analog channels) in NR1 format <m> ::= 1 to (# math functions) in NR1 format <return_value> ::= the crest factor value in NR3 format
:MEASure:EFFiciency (see page 702)	:MEASure:EFFiciency? (see page 702)	<return_value> ::= percent value in NR3 format
:MEASure:ELOSS [<source>] (see page 703)	:MEASure:ELOSS? [<source>] (see page 703)	<source> ::= {CHANnel<n>   FUNCtion<m>   MATH<m>   WMEMory<r>} <n> ::= 1 to (# analog channels) in NR1 format <m> ::= 1 to (# math functions) in NR1 format <r> ::= 1 to (# ref waveforms) in NR1 format <return_value> ::= the energy loss value in NR3 format
:MEASure:FACTOr [<source1> [, <source2>] (see page 704)	:MEASure:FACTOr? [<source1> [, <source2>] (see page 704)	<source1>, <source2> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format <return_value> ::= the power factor value in NR3 format
:MEASure:IPOWER (see page 705)	:MEASure:IPOWER? (see page 705)	<return_value> ::= the input power value in NR3 format
:MEASure:OFFTime [<source1> [, <source2>] (see page 706)	:MEASure:OFFTime? [<source1> [, <source2>] (see page 706)	<source1>, <source2> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format <return_value> ::= the time in seconds in NR3 format

**Table 116** :MEASure Power Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:ONTime [<source1>] [,<source2>] (see page 707)	:MEASure:ONTime? [<source1>] [,<source2>] (see page 707)	<source1>, <source2> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format <return_value> ::= the time in seconds in NR3 format
:MEASure:OPOWer (see page 708)	:MEASure:OPOWer? (see page 708)	<return_value> ::= the output power value in NR3 format
:MEASure:PCURrent [<source>] (see page 709)	:MEASure:PCURrent? [<source>] (see page 709)	<source> ::= {CHANnel<n>   FUNCTion<m>   MATH<m>   WMEMory<r>} <n> ::= 1 to (# analog channels) in NR1 format <m> ::= 1 to (# math functions) in NR1 format <r> ::= 1 to (# ref waveforms) in NR1 format <return_value> ::= the peak current value in NR3 format
:MEASure:PLOSS [<source>] (see page 710)	:MEASure:PLOSS? [<source>] (see page 710)	<source> ::= {CHANnel<n>   FUNCTion<m>   MATH<m>   WMEMory<r>} <n> ::= 1 to (# analog channels) in NR1 format <m> ::= 1 to (# math functions) in NR1 format <r> ::= 1 to (# ref waveforms) in NR1 format <return_value> ::= the power loss value in NR3 format

**Table 116** :MEASure Power Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:RDSon [<source1> [, <source2>] (see <a href="#">page 711</a> )	:MEASure:RDSon? [<source1> [, <source2>] (see <a href="#">page 711</a> )	<p>&lt;source1&gt;, &lt;source2&gt; ::= {CHANnel&lt;n&gt;  FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the Rds(on) value in NR3 format</p>
:MEASure:REAactive [<source1> [, <source2>] (see <a href="#">page 712</a> )	:MEASure:REAactive? [<source1> [, <source2>] (see <a href="#">page 712</a> )	<p>&lt;source1&gt;, &lt;source2&gt; ::= {CHANnel&lt;n&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;return_value&gt; ::= the reactive power value in NR3 format</p>
:MEASure:REAL [<source>] (see <a href="#">page 713</a> )	:MEASure:REAL? [<source>] (see <a href="#">page 713</a> )	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;  FUNCtion&lt;m&gt;   MATH&lt;m&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;return_value&gt; ::= the real power value in NR3 format</p>
:MEASure:RIPPle [<source>] (see <a href="#">page 714</a> )	:MEASure:RIPPle? [<source>] (see <a href="#">page 714</a> )	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;  FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the output ripple value in NR3 format</p>

**Table 116** :MEASure Power Commands Summary (continued)

Command	Query	Options and Query Returns
:MEASure:TRESPonse [<source>] (see page 715)	:MEASure:TRESPonse? [<source>] (see page 715)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= time in seconds for the overshoot to settle back into the band in NR3 format</p>
:MEASure:VCESat [<source>] (see page 716)	:MEASure:VCESat? [<source>] (see page 716)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;return_value&gt; ::= the Vce(sat) value in NR3 format</p>

## :MEASure:ANGLE

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MEASure:ANGLE [&lt;source1&gt; [, &lt;source2&gt;] &lt;source1&gt;, &lt;source2&gt; ::= {CHANnel&lt;n&gt;} &lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	The :MEASure:ANGLE command installs a power phase angle measurement on screen.

The <source1> parameter is the channel probing voltage and the <source2> parameter is the channel probing current. These sources can also be specified by the :MEASure:SOURce command.

Phase angle is a measure of power quality. In the *power triangle* (the right triangle where  $\text{apparent\_power}^2 = \text{real\_power}^2 + \text{reactive\_power}^2$ ), phase angle is the angle between the apparent power and the real power, indicating the amount of reactive power. Small phase angles equate to less reactive power.

<b>Query Syntax</b>	<code>:MEASure:ANGLE? [&lt;source1&gt; [, &lt;source2&gt;]</code>
	The :MEASure:ANGLE query returns the measured power phase angle in degrees.
<b>Return Format</b>	<code>&lt;return_value&gt;&lt;NL&gt;</code> <code>&lt;return_value&gt; ::= the power phase angle in degrees in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":MEASure:SOURce"</a> on page 667</li> <li>· <a href="#">":POWER:QUALITY:APPLy"</a> on page 826</li> </ul>

## :MEASure:APPARENT

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MEASure:APPARENT [&lt;source1&gt; [,&lt;source2&gt;] &lt;source1&gt;, &lt;source2&gt; ::= {CHANnel&lt;n&gt;} &lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	The :MEASure:APPARENT command installs an apparent power measurement on screen.
	The <source1> parameter is the channel probing voltage and the <source2> parameter is the channel probing current. These sources can also be specified by the :MEASure:SOURce command.
	Apparent power is a measure of power quality. It is the portion of AC line power flow due to stored energy which returns to the source in each cycle.
	IRMS * VRMS
<b>Query Syntax</b>	<code>:MEASure:APPARENT? [&lt;source1&gt; [,&lt;source2&gt;]</code>
	The :MEASure:APPARENT query returns the measured apparent power.
<b>Return Format</b>	<code>&lt;return_value&gt;&lt;NL&gt; &lt;return_value&gt; ::= the apparent power value in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:MEASure:SOURce</a>" on page 667</li> <li>· "<a href="#">:POWER:QUALITY:APPLY</a>" on page 826</li> </ul>

## :MEASure:CPLoss

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MEASure:CPLoss [&lt;source1&gt; [, &lt;source2&gt;]</code>
	<code>&lt;source1&gt; ::= {FUNCTION&lt;m&gt;   MATH&lt;m&gt;}</code>
	<code>&lt;source2&gt; ::= {CHANnel&lt;n&gt;}</code>
	<code>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	The :MEASure:CPLoss command installs a power loss per cycle measurement on screen.
	The <source1> parameter is typically a math multiply waveform or other waveform that represents power (voltage * current). This source can also be specified by the :MEASure:SOURce command.
	Power loss per cycle is $P_n = (V_{dsn} * I_{dn}) * (\text{Time range of zoom window}) * (\text{Counter measurement of the voltage of the switching signal})$ , where n is each sample.
	This measurement operates when in zoom mode and the counter measurement is installed on the voltage of the switching signal.
<b>Query Syntax</b>	<code>:MEASure:CPLoss? [&lt;source1&gt; [, &lt;source2&gt;]</code>
	The :MEASure:CPLoss query returns the switching loss per cycle in watts.
<b>Return Format</b>	<code>&lt;return_value&gt;&lt;NL&gt;</code> <code>&lt;return_value&gt; ::= the switching loss per cycle value in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:MEASure:SOURce</a>" on page 667</li> <li>· "<a href="#">:POWER:SWITch:APPLy</a>" on page 849</li> </ul>

## :MEASure:CRESt

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:CRESt [<source>]`

```
<source> ::= {CHANnel<n>| FUNCtion<m> | MATH<m>}
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
```

The :MEASure:CRESt command installs a crest factor measurement on screen.

The <source> parameter is the channel probing current or voltage. This source can also be specified by the :MEASure:SOURce command.

Crest factor is a measure of power quality. It is the ratio between the instantaneous peak AC line current (or voltage) required by the load and the RMS current (or voltage). For example: Ipeak / IRMS or Vpeak / VRMS.

**Query Syntax**    `:MEASure:CRESt? [<source>]`

The :MEASure:CRESt query returns the measured crest factor.

**Return Format**    `<return_value><NL>`

```
<return_value> ::= the crest factor value in NR3 format
```

**See Also**

- [":MEASure:SOURce" on page 667](#)
- [":POWER:QUALITY:APPLy" on page 826](#)

## :MEASure:EFFiciency

**N** (see [page 1666](#))

**Command Syntax** `:MEASure:EFFiciency`

The `:MEASure:EFFiciency` command installs an efficiency (output power / input power) measurement on screen.

Before sending this command or query, you must specify the channels probing the input voltage, input current, output voltage, and output current (using the `:POWer:SIGNals:SOURce:VOLTage<i>` and `:POWer:SIGNals:SOURce:CURRent<i>` commands) and you must perform the automated signals setup (using the `:POWer:SIGNals:AUTosetup` `EFFiciency` command).

**Query Syntax** `:MEASure:EFFiciency?`

The `:MEASure:EFFiciency` query returns the measured efficiency as a percent value.

**Return Format** `<return_value><NL>`

`<return_value>` ::= percent value in NR3 format

**See Also**

- "[":POWer:SIGNals:SOURce:VOLTage<i>](#)" on page 846
- "[":POWer:SIGNals:SOURce:CURRent<i>](#)" on page 845
- "[":POWer:SIGNals:AUTosetup](#)" on page 828
- "[":POWer:EFFiciency:APPLy](#)" on page 784

## :MEASure:ELOSSs

**N** (see [page 1666](#))

**Command Syntax** :MEASure:ELOSSs [<source>]

```
<source> ::= {CHANnel<n>| FUNCtion<m> | MATH<m> | WMMEMory<r>}
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:ELOSSs command installs an energy loss measurement on screen.

The <source> parameter is typically a math multiply waveform or other waveform that represents power (voltage \* current). This source can also be specified by the :MEASure:SOURce command.

Energy loss =  $\sum (V_{ds_n} * I_{d_n}) * \text{sample size}$ , where n is each sample.

**Query Syntax** :MEASure:ELOSSs? [<source>]

The :MEASure:ELOSSs query returns the switching loss in joules.

**Return Format** <return\_value><NL>

```
<return_value> ::= the energy loss value in NR3 format
```

**See Also**

- "[:MEASure:SOURce](#)" on page 667
- "[:POWER:SWITch:APPLy](#)" on page 849

## :MEASure:FACTOr

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MEASure:FACTOr [&lt;source1&gt; [, &lt;source2&gt;] &lt;source1&gt;, &lt;source2&gt; ::= {CHANnel&lt;n&gt;} &lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	The :MEASure:FACTOr command installs a power factor measurement on screen.
	The <source1> parameter is the channel probing voltage and the <source2> parameter is the channel probing current. These sources can also be specified by the :MEASure:SOURce command.
	Power factor is a measure of power quality. It is the ratio of the actual AC line power to the apparent power:
	Real Power / Apparent Power
<b>Query Syntax</b>	<code>:MEASure:FACTOr? [&lt;source1&gt; [, &lt;source2&gt;]</code>
	The :MEASure:FACTOr query returns the measured power factor.
<b>Return Format</b>	<code>&lt;return_value&gt;&lt;NL&gt; &lt;return_value&gt; ::= the power factor value in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:MEASure:SOURce</a>" on page 667</li> <li>· "<a href="#">:POWER:QUALITY:APPLy</a>" on page 826</li> </ul>

## :MEASure:IPower

**N** (see [page 1666](#))

**Command Syntax** `:MEASure:IPower`

The :MEASure:IPower command installs an input power measurement on screen.

Before sending this command or query, you must specify the channels probing the input voltage, input current, output voltage, and output current (using the :POWER:SIGNals:SOURce:VOLTage<i> and :POWER:SIGNals:SOURce:CURRent<i> commands) and you must perform the automated signals setup (using the :POWER:SIGNals:AUTosetup EFFiciency command).

**Query Syntax** `:MEASure:IPower?`

The :MEASure:IPower query returns the measured input power.

**Return Format** `<return_value><NL>`

`<return_value>` ::= the input power value in NR3 format

- See Also**
- "[":POWER:SIGNals:SOURce:VOLTage<i>](#)" on page 846
  - "[":POWER:SIGNals:SOURce:CURRent<i>](#)" on page 845
  - "[":POWER:SIGNals:AUTosetup](#)" on page 828
  - "[":POWER:EFFiciency:APPLy](#)" on page 784

## :MEASure:OFFTime

**N** (see [page 1666](#))

**Command Syntax**

```
:MEASure:OFFTime [<source1>[,<source2>]
<source1>, <source2> ::= {CHANnel<n>}
<n> ::= 1 to (# analog channels) in NR1 format
```

The :MEASure:OFFTime command installs an "off time" measurement on screen.

Turn off time measures the difference of time between when the input AC Voltage last falls to 10% of its maximum amplitude to the time when the output DC Voltage last falls to 10% of its maximum amplitude.

The <source1> parameter is the AC Voltage and the <source2> parameter is the DC Voltage. These sources can also be specified by the :MEASure:SOURce command.

**Query Syntax**

```
:MEASure:OFFTime? [<source1>[,<source2>]
```

The :MEASure:OFFTime query returns the measured turn off time.

**Return Format**

```
<return_value><NL>
<return_value> ::= the time in seconds in NR3 format
```

**See Also**

- "[:MEASure:SOURce](#)" on page 667
- "[:POWER:ONOFF:TEST](#)" on page 809
- "[:POWER:ONOFF:APPLy](#)" on page 806

## :MEASure:ONTime

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MEASure:ONTime [&lt;source1&gt; [, &lt;source2&gt;]</code> <code>&lt;source1&gt;, &lt;source2&gt; ::= {CHANnel&lt;n&gt;}</code> <code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	The :MEASure:ONTime command installs an "on time" measurement on screen.
	Turn on time measures the difference of time between when the input AC Voltage first rises to 10% of its maximum amplitude to the time when the output DC Voltage rises to 90% of its maximum amplitude.
	The <source1> parameter is the AC Voltage and the <source2> parameter is the DC Voltage. These sources can also be specified by the :MEASure:SOURce command.
<b>Query Syntax</b>	<code>:MEASure:ONTime? [&lt;source1&gt; [, &lt;source2&gt;]</code>
	The :MEASure:ONTime query returns the measured turn off time.
<b>Return Format</b>	<code>&lt;return_value&gt;&lt;NL&gt;</code> <code>&lt;return_value&gt; ::= the time in seconds in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">:MEASure:SOURce</a>" on page 667</li> <li>• "<a href="#">:POWER:ONOFF:TEST</a>" on page 809</li> <li>• "<a href="#">:POWER:ONOFF:APPLy</a>" on page 806</li> </ul>

## :MEASure:OPOWer

**N** (see [page 1666](#))

**Command Syntax** `:MEASure:OPOWer`

The `:MEASure:OPOWer` command installs an output power measurement on screen.

Before sending this command or query, you must specify the channels probing the input voltage, input current, output voltage, and output current (using the `:POWer:SIGNals:SOURce:VOLTage<i>` and `:POWer:SIGNals:SOURce:CURRent<i>` commands) and you must perform the automated signals setup (using the `:POWer:SIGNals:AUTosetup EFFiciency` command).

**Query Syntax** `:MEASure:OPOWer?`

The `:MEASure:OPOWer` query returns the measured output power.

**Return Format** `<return_value><NL>`

`<return_value> ::= the output power value in NR3 format`

- See Also**
- "[":POWer:SIGNals:SOURce:VOLTage<i>](#)" on page 846
  - "[":POWer:SIGNals:SOURce:CURRent<i>](#)" on page 845
  - "[":POWer:SIGNals:AUTosetup](#)" on page 828
  - "[":POWer:EFFiciency:APPLY](#)" on page 784

## :MEASure:PCURrent

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:PCURrent [<source>]`

```
<source> ::= {CHANnel<n>| FUNCtion<m> | MATH<m> | WMMEMory<r>}
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:PCURrent command installs a peak current measurement on screen.

The <source> parameter is the channel probing the current. This source can also be specified by the :MEASure:SOURce command.

This command measures the peak current when the power supply first turned on.

**Query Syntax**    `:MEASure:PCURrent? [<source>]`

The :MEASure:PCURrent query returns the measured peak current.

**Return Format**    `<return_value><NL>`

```
<return_value> ::= the peak current value in NR3 format
```

**See Also**

- "[:MEASure:SOURce](#)" on page 667
- "[:POWER:INRush:APPLy](#)" on page 799

## :MEASure:PLOSSs

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:PLOSS [<source>]`

```
<source> ::= {CHANnel<n>| FUNCtion<m> | MATH<m> | WMMEMory<r>}
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:PLOSSs command installs a power loss measurement on screen.

The <source> parameter is typically a math multiply waveform or other waveform that represents power (voltage \* current). This source can also be specified by the :MEASure:SOURce command.

Power loss is  $P_n = V_{ds,n} * I_{d,n}$ , where n is each sample.

**Query Syntax**    `:MEASure:PLOSS? [<source>]`

The :MEASure:PLOSSs query returns the switching loss in watts.

**Return Format**    `<return_value><NL>`

```
<return_value> ::= the power loss value in NR3 format
```

**See Also**

- "[:MEASure:SOURce](#)" on page 667
- "[:POWER:SWITch:APPLy](#)" on page 849

## :MEASure:RDSon

**N** (see [page 1666](#))

- Command Syntax**    `:MEASure:RDSon [<source1> [,<source2>]`
- ```
<source1>, <source2> ::= {CHANnel<n>| FUNCTION<m> | MATH<m>
| WMMemory<r>}

<n> ::= 1 to (# analog channels) in NR1 format

<m> ::= 1 to (# math functions) in NR1 format

<r> ::= 1 to (# ref waveforms) in NR1 format
```
- The :MEASure:RDSon command installs a power Rds(on) measurement on screen.
- Rds(on) is the ON resistance between the drain and source of MOSFET. The Rds(on) characteristic is also published in the switching device data sheet.
- Query Syntax**    `:MEASure:RDSon? [<source1> [,<source2>]`
- The :MEASure:RDSon? query returns the measured Rds(on) value.
- Return Format**    `<return_value><NL>`
- ```
<return_value> ::= the Rds(on) value in NR3 format
```
- See Also**    • [":MEASure:VCESat"](#) on page 716

## :MEASure:REACTive

**N** (see [page 1666](#))

**Command Syntax**

```
:MEASure:REACTive [<source1> [,<source2>]
<source1>, <source2> ::= {CHANnel<n>}
<n> ::= 1 to (# analog channels) in NR1 format
```

The :MEASure:REACTive command installs a reactive power measurement on screen.

The <source1> parameter is the channel probing voltage and the <source2> parameter is the channel probing current. These sources can also be specified by the :MEASure:SOURce command.

Reactive power is a measure of power quality. It is the difference between apparent power and real power due to reactance. Using the *power triangle* (the right triangle where  $\text{apparent\_power}^2 = \text{real\_power}^2 + \text{reactive\_power}^2$ ):

$$\text{Reactive Power} = \sqrt{\text{Apparent Power}^2 - \text{Real Power}^2}$$

Reactive power is measured in VAR (Volts-Amps-Reactive).

**Query Syntax**

```
:MEASure:REACTive? [<source1> [,<source2>]
```

The :MEASure:REACTive query returns the measured reactive power.

**Return Format**

```
<return_value><NL>
<return_value> ::= the reactive power value in NR3 format
```

**See Also**

- "[:MEASure:SOURce](#)" on page 667
- "[:POWER:QUALITY:APPLY](#)" on page 826

## :MEASure:REAL

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:REAL [<source>]`

```
<source> ::= {CHANnel<n>| FUNCtion<m> | MATH<m>}

<n> ::= 1 to (# analog channels) in NR1 format

<m> ::= 1 to (# math functions) in NR1 format
```

The :MEASure:REAL command installs a real power measurement on screen.

The <source> parameter is typically a math multiply waveform or other waveform that represents power (voltage \* current). This source can also be specified by the :MEASure:SOURce command.

Real power is a measure of power quality. It is the portion of power flow that, averaged over a complete cycle of the AC waveform, results in net transfer of energy in one direction.

$$\text{Real Power} = \sqrt{\frac{1}{N} \sum_{n=0}^{N-1} V_n I_n}$$

**Query Syntax**    `:MEASure:REAL? [<source>]`

The :MEASure:REAL query returns the measured real power.

**Return Format**    `<return_value><NL>`

```
<return_value> ::= the real power value in NR3 format
```

**See Also**

- [":MEASure:SOURce" on page 667](#)
- [":POWER:QUALity:APPLy" on page 826](#)

## :MEASure:RIPPle

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:RIPPle [<source>]`

```
<source> ::= {CHANnel<n>| FUNCtion<m> | MATH<m> | WMEMory<r>}

<n> ::= 1 to (# analog channels) in NR1 format

<m> ::= 1 to (# math functions) in NR1 format

<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:RIPPle command installs an output ripple measurement on screen.

The <source> parameter is the channel probing the output voltage. This source can also be specified by the :MEASure:SOURce command.

Output ripple is: Vmax - Vmin.

**Query Syntax**    `:MEASure:RIPPle? [<source>]`

The :MEASure:RIPPle query returns the measured output ripple.

**Return Format**    `<return_value><NL>`

```
<return_value> ::= the output ripple value in NR3 format
```

**See Also**

- [":MEASure:SOURce"](#) on page 667
- [":POWER:RIPPLE:APPLY"](#) on page 827

## :MEASure:TRESPonse

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MEASure:TRESPonse [&lt;source&gt;]</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;  FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMMemory&lt;r&gt;}</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</code>
	<code>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</code>
	The :MEASure:TRESPonse command installs a transient response time measurement on screen.
	The <source> parameter is the channel probing the output voltage. This source can also be specified by the :MEASure:SOURce command.
	Transient response time = t2 – t1, where:
	<ul style="list-style-type: none"> <li>• t1 = The first time a voltage waveform exits the settling band.</li> <li>• t2 = The last time it enters into the settling band.</li> <li>• Settling band = +/-overshoot % of the steady state output voltage.</li> </ul>
<b>Query Syntax</b>	<code>:MEASure:TRESPonse? [&lt;source&gt;]</code>
	The :MEASure:TRESPonse query returns the measured transient response time.
<b>Return Format</b>	<code>&lt;return_value&gt;&lt;NL&gt;</code> <code>&lt;return_value&gt; ::= time in seconds for the overshoot to settle back into the band in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">:MEASure:SOURce</a>" on page 667</li> <li>• "<a href="#">:POWER:TRANsient:APPLy</a>" on page 855</li> </ul>

## :MEASure:VCESat

**N** (see [page 1666](#))

**Command Syntax**    `:MEASure:VCESat [<source>]`

```
<source> ::= {CHANnel<n>| FUNCtion<m> | MATH<m> | WMMEMory<r>}

<n> ::= 1 to (# analog channels) in NR1 format

<m> ::= 1 to (# math functions) in NR1 format

<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:VCESat command installs a power Vce(sat) measurement on screen.

Vce(sat) is the saturation voltage between the collector and emitter of a BJT. The Vce(sat) characteristic is also published in the switching device data sheet.

**Query Syntax**    `:MEASure:VCESat? [<source>]`

The :MEASure:VCESat? query returns the measured Vce(sat) value.

**Return Format**    `<return_value><NL>`

```
<return_value> ::= the VCE(sat) value in NR3 format
```

**See Also**    • [":MEASure:RDSon"](#) on page 711

## 28 :MTEST Commands

The MTEST subsystem commands and queries control the mask test features. See "Introduction to :MTEST Commands" on page 719.

**Table 117** :MTEST Commands Summary

Command	Query	Options and Query Returns
:MTEST:ALL {{0   OFF}   {1   ON}} (see <a href="#">page 722</a> )	:MTEST:ALL? (see <a href="#">page 722</a> )	{0   1}
:MTEST:AMASK:CREAtE (see <a href="#">page 723</a> )	n/a	n/a
:MTEST:AMASK:SOURce <source> (see <a href="#">page 724</a> )	:MTEST:AMASK:SOURce? (see <a href="#">page 724</a> )	<source> ::= CHANnel<n> <n> ::= {1   2   3   4} for 4ch models <n> ::= {1   2} for 2ch models
:MTEST:AMASK:UNITS <units> (see <a href="#">page 725</a> )	:MTEST:AMASK:UNITS? (see <a href="#">page 725</a> )	<units> ::= {CURRent   DIVisions}
:MTEST:AMASK:XDELta <value> (see <a href="#">page 726</a> )	:MTEST:AMASK:XDELta? (see <a href="#">page 726</a> )	<value> ::= X delta value in NR3 format
:MTEST:AMASK:YDELta <value> (see <a href="#">page 727</a> )	:MTEST:AMASK:YDELta? (see <a href="#">page 727</a> )	<value> ::= Y delta value in NR3 format
n/a	:MTEST:COUNT:FWAvefor ms? [CHANnel<n>] (see <a href="#">page 728</a> )	<failed> ::= number of failed waveforms in NR1 format
:MTEST:COUNT:RESet (see <a href="#">page 729</a> )	n/a	n/a
n/a	:MTEST:COUNT:TIME? (see <a href="#">page 730</a> )	<time> ::= elapsed seconds in NR3 format
n/a	:MTEST:COUNT:WAVeform s? (see <a href="#">page 731</a> )	<count> ::= number of waveforms in NR1 format
:MTEST:DATA <mask> (see <a href="#">page 732</a> )	:MTEST:DATA? (see <a href="#">page 732</a> )	<mask> ::= data in IEEE 488.2 # format.

**Table 117** :MTEST Commands Summary (continued)

Command	Query	Options and Query Returns
:MTEST:DELETE (see page 733)	n/a	n/a
:MTEST:ENABLE {{0   OFF}   {1   ON}} (see page 734)	:MTEST:ENABLE? (see page 734)	{0   1}
:MTEST:LOCK {{0   OFF}   {1   ON}} (see page 735)	:MTEST:LOCK? (see page 735)	{0   1}
:MTEST:RMODE <rmode> (see page 736)	:MTEST:RMODE? (see page 736)	<rmode> ::= {FORever   TIME   SIGMa   WAVEforms}
:MTEST:RMODE:FACTion:MEASure {{0   OFF}   {1   ON}} (see page 737)	:MTEST:RMODE:FACTion:MEASure? (see page 737)	{0   1}
:MTEST:RMODE:FACTion:PRINT {{0   OFF}   {1   ON}} (see page 738)	:MTEST:RMODE:FACTion:PRINT? (see page 738)	{0   1}
:MTEST:RMODE:FACTion:SAVE {{0   OFF}   {1   ON}} (see page 739)	:MTEST:RMODE:FACTion:SAVE? (see page 739)	{0   1}
:MTEST:RMODE:FACTion:STOP {{0   OFF}   {1   ON}} (see page 740)	:MTEST:RMODE:FACTion:STOP? (see page 740)	{0   1}
:MTEST:RMODE:SIGMa <level> (see page 741)	:MTEST:RMODE:SIGMa? (see page 741)	<level> ::= from 0.1 to 9.3 in NR3 format
:MTEST:RMODE:TIME <seconds> (see page 742)	:MTEST:RMODE:TIME? (see page 742)	<seconds> ::= from 1 to 86400 in NR3 format
:MTEST:RMODE:WAVEforms <count> (see page 743)	:MTEST:RMODE:WAVEforms? (see page 743)	<count> ::= number of waveforms in NR1 format
:MTEST:SCALe:BIND {{0   OFF}   {1   ON}} (see page 744)	:MTEST:SCALe:BIND? (see page 744)	{0   1}
:MTEST:SCALe:X1 <x1_value> (see page 745)	:MTEST:SCALe:X1? (see page 745)	<x1_value> ::= X1 value in NR3 format
:MTEST:SCALe:XDELta <xdelta_value> (see page 746)	:MTEST:SCALe:XDELta? (see page 746)	<xdelta_value> ::= X delta value in NR3 format

**Table 117** :MTEST Commands Summary (continued)

Command	Query	Options and Query Returns
:MTEST:SCALe:Y1 <y1_value> (see page 747)	:MTEST:SCALe:Y1? (see page 747)	<y1_value> ::= Y1 value in NR3 format
:MTEST:SCALe:Y2 <y2_value> (see page 748)	:MTEST:SCALe:Y2? (see page 748)	<y2_value> ::= Y2 value in NR3 format
:MTEST:SOURce <source> (see page 749)	:MTEST:SOURce? (see page 749)	<source> ::= {CHANnel<n>   NONE} <n> ::= {1   2   3   4} for 4ch models <n> ::= {1   2} for 2ch models
n/a	:MTEST:TITLE? (see page 750)	<title> ::= a string of up to 128 ASCII characters

**Introduction to :MTEST Commands** Mask testing automatically compares the current displayed waveform with the boundaries of a set of polygons that you define. Any waveform or sample that falls within the boundaries of one or more polygons is recorded as a failure.

### Reporting the Setup

Use :MTEST? to query setup information for the MTEST subsystem.

### Return Format

The following is a sample response from the :MTEST? query. In this case, the query was issued following a \*RST command.

```
:MTES:SOUR CHAN1,ENAB 0;LOCK 1,:MTES:AMAS:SOUR CHAN1,UNIT DIV,XDEL
+2.5000000E-001,YDEL +2.5000000E-001,:MTES:SCAL:X1 +200.000E-06,XDEL
+400.000E-06;Y1 -3.00000E+00;Y2 +3.00000E+00;BIND 0,:MTES:RMOD
FOR;RMOD:TIME +1E+00;WAV 1000;SIGM +6.0E+00,:MTES:RMOD:FACT:STOP
0;PRIN 0;SAVE 0
```

### Example Code

```
' Mask testing commands example.
' -----
Option Explicit

Public myMgr As VisaComLib.ResourceManager
Public myScope As VisaComLib.FormattedIO488
Public varQueryResult As Variant
Public strQueryResult As String

Private Declare Sub Sleep Lib "kernel32" (ByVal dwMilliseconds As Long)

Sub Main()
```

```

On Error GoTo VisaComError

' Create the VISA COM I/O resource.
Set myMgr = New VisaComLib.ResourceManager
Set myScope = New VisaComLib.FormattedIO488
Set myScope.IO =
    myMgr.Open("USB0::0x0957::0x17A6::US50210029::0::INSTR")
myScope.IO.Clear      ' Clear the interface.

' Make sure oscilloscope is running.
myScope.WriteString ":RUN"

' Set mask test termination conditions.
myScope.WriteString ":MTEST:RMODE SIGMA"
myScope.WriteString ":MTEST:RMODE?"
strQueryResult = myScope.ReadString
Debug.Print "Mask test termination mode: " + strQueryResult

myScope.WriteString ":MTEST:RMODE:SIGMA 4.2"
myScope.WriteString ":MTEST:RMODE:SIGMA?"
varQueryResult = myScope.ReadNumber
Debug.Print "Mask test termination 'test sigma': " + _
    FormatNumber(varQueryResult)

' Use auto-mask to create mask.
myScope.WriteString ":MTEST:AMASK:SOURce CHANnel1"
myScope.WriteString ":MTEST:AMASK:SOURce?"
strQueryResult = myScope.ReadString
Debug.Print "Mask test auto-mask source: " + strQueryResult

myScope.WriteString ":MTEST:AMASK:UNITS DIVisions"
myScope.WriteString ":MTEST:AMASK:UNITS?"
strQueryResult = myScope.ReadString
Debug.Print "Mask test auto-mask units: " + strQueryResult

myScope.WriteString ":MTEST:AMASK:XDELta 0.1"
myScope.WriteString ":MTEST:AMASK:XDELta?"
varQueryResult = myScope.ReadNumber
Debug.Print "Mask test auto-mask X delta: " + _
    FormatNumber(varQueryResult)

myScope.WriteString ":MTEST:AMASK:YDELta 0.1"
myScope.WriteString ":MTEST:AMASK:YDELta?"
varQueryResult = myScope.ReadNumber
Debug.Print "Mask test auto-mask Y delta: " + _
    FormatNumber(varQueryResult)

' Enable "Auto Mask Created" event (bit 10, &H400)
myScope.WriteString "*CLS"
myScope.WriteString ":MTEenable " + CStr(CInt("&H400"))

' Create mask.
myScope.WriteString ":MTEST:AMASK:CREATE"
Debug.Print "Auto-mask created, mask test automatically enabled."

' Set up timeout variables.

```

```

Dim lngTimeout As Long      ' Max millisecs to wait.
Dim lngElapsed As Long
lngTimeout = 60000          ' 60 seconds.

' Wait until mask is created.
lngElapsed = 0
Do While lngElapsed <= lngTimeout
    myScope.WriteString ":OPERRegister:CONDITION?"
    varQueryResult = myScope.ReadNumber
    ' Operation Status Condition Register MTE bit (bit 9, &H200).
    If (varQueryResult And &H200) <> 0 Then
        Exit Do
    Else
        Sleep 100      ' Small wait to prevent excessive queries.
        lngElapsed = lngElapsed + 100
    End If
Loop

' Look for RUN bit = stopped (mask test termination).
lngElapsed = 0
Do While lngElapsed <= lngTimeout
    myScope.WriteString ":OPERRegister:CONDITION?"
    varQueryResult = myScope.ReadNumber
    ' Operation Status Condition Register RUN bit (bit 3, &H8).
    If (varQueryResult And &H8) = 0 Then
        Exit Do
    Else
        Sleep 100      ' Small wait to prevent excessive queries.
        lngElapsed = lngElapsed + 100
    End If
Loop

' Get total waveforms, failed waveforms, and test time.
myScope.WriteString ":MTEST:COUNT:WAVEforms?"
strQueryResult = myScope.ReadString
Debug.Print "Mask test total waveforms: " + strQueryResult

myScope.WriteString ":MTEST:COUNT:FWAveforms?"
strQueryResult = myScope.ReadString
Debug.Print "Mask test failed waveforms: " + strQueryResult

myScope.WriteString ":MTEST:COUNT:TIME?"
strQueryResult = myScope.ReadString
Debug.Print "Mask test elapsed seconds: " + strQueryResult

Exit Sub

VisaComError:
MsgBox "VISA COM Error:" + vbCrLf + Err.Description

End Sub

```

## :MTEST:ALL

**N** (see [page 1666](#))

**Command Syntax**    `:MTEST:ALL <on_off>`

`<on_off> ::= {{1 | ON} | {0 | OFF}}`

The :MTEST:ALL command specifies the channel(s) that are included in the mask test:

- ON – All displayed analog channels are included in the mask test.
- OFF – Just the selected source channel is included in the test.

**Query Syntax**    `:MTEST:ENABLE?`

The :MTEST:ENABLE? query returns the current setting.

**Return Format**    `<on_off><NL>`

`<on_off> ::= {1 | 0}`

**See Also**    • "Introduction to :MTEST Commands" on page 719

## :MTEST:AMASK:CREate

**N** (see [page 1666](#))

### Command Syntax

`:MTEST :AMASK :CREate`

The :MTEST:AMASK:CREate command automatically constructs a mask around the current selected channel, using the tolerance parameters defined by the :MTEST:AMASK:XDELta, :MTEST:AMASK:YDELta, and :MTEST:AMASK:UNITS commands. The mask only encompasses the portion of the waveform visible on the display, so you must ensure that the waveform is acquired and displayed consistently to obtain repeatable results.

The :MTEST:SOURce command selects the channel and should be set before using this command.

### See Also

- ["Introduction to :MTEST Commands"](#) on page 719
- [":MTEST:AMASK:XDELta"](#) on page 726
- [":MTEST:AMASK:YDELta"](#) on page 727
- [":MTEST:AMASK:UNITS"](#) on page 725
- [":MTEST:AMASK:SOURce"](#) on page 724
- [":MTEST:SOURce"](#) on page 749

### Example Code

- ["Example Code"](#) on page 719

## :MTEST:AMASK:SOURce

**N** (see [page 1666](#))

**Command Syntax**    `:MTEST:AMASK:SOURce <source>`

```
<source> ::= CHANnel<n>
<n> ::= 1 to (# analog channels) in NR1 format
```

The :MTEST:AMASK:SOURce command selects the source for the interpretation of the :MTEST:AMASK:XDELta and :MTEST:AMASK:YDELta parameters when :MTEST:AMASK:UNITS is set to CURRent.

When UNITS are CURRent, the XDELta and YDELta parameters are defined in terms of the channel units, as set by the :CHANnel<n>:UNITS command, of the selected source.

Suppose that UNITS are CURRent and that you set SOURce to CHANNEL1, which is using units of volts. Then you can define AMASK:XDELta in terms of volts and AMASK:YDELta in terms of seconds.

This command is the same as the :MTEST:SOURce command.

**Query Syntax**    `:MTEST:AMASK:SOURce?`

The :MTEST:AMASK:SOURce? query returns the currently set source.

**Return Format**

```
<source> ::= CHAN<n>
<n> ::= 1 to (# analog channels) in NR1 format
```

**See Also**

- ["Introduction to :MTEST Commands"](#) on page 719
- [":MTEST:AMASK:XDELta"](#) on page 726
- [":MTEST:AMASK:YDELta"](#) on page 727
- [":MTEST:AMASK:UNITS"](#) on page 725
- [":MTEST:SOURce"](#) on page 749

**Example Code**

- ["Example Code"](#) on page 719

## :MTEST:AMASK:UNITs

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MTEST:AMASK:UNITs &lt;units&gt;</code> <code>&lt;units&gt; ::= {CURREnt   DIVisions}</code>
	The :MTEST:AMASK:UNITs command alters the way the mask test subsystem interprets the tolerance parameters for automasking as defined by :MTEST:AMASK:XDELta and :MTEST:AMASK:YDELta commands.
	<ul style="list-style-type: none"> <li>• CURREnt – the mask test subsystem uses the units as set by the :CHANnel&lt;n&gt;:UNITs command, usually time for <math>\Delta X</math> and voltage for <math>\Delta Y</math>.</li> <li>• DIVisions – the mask test subsystem uses the graticule as the measurement system, so tolerance settings are specified as parts of a screen division. The mask test subsystem maintains separate XDELta and YDELta settings for CURREnt and DIVisions. Thus, XDELta and YDELta are not converted to new values when the UNITs setting is changed.</li> </ul>
<b>Query Syntax</b>	<code>:MTEST:AMASK:UNITs?</code>
	The :MTEST:AMASK:UNITs query returns the current measurement units setting for the mask test automask feature.
<b>Return Format</b>	<code>&lt;units&gt;&lt;NL&gt;</code> <code>&lt;units&gt; ::= {CURREnt   DIVisions}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :MTEST Commands</a>" on page 719</li> <li>• "<a href="#">":MTEST:AMASK:XDELta</a>" on page 726</li> <li>• "<a href="#">":MTEST:AMASK:YDELta</a>" on page 727</li> <li>• "<a href="#">":CHANnel&lt;n&gt;:UNITs</a>" on page 369</li> <li>• "<a href="#">":MTEST:AMASK:SOURce</a>" on page 724</li> <li>• "<a href="#">":MTEST:SOURce</a>" on page 749</li> </ul>
<b>Example Code</b>	<ul style="list-style-type: none"> <li>• "<a href="#">":Example Code</a>" on page 719</li> </ul>

## :MTEST:AMASK:XDELta

**N** (see [page 1666](#))

**Command Syntax**

```
:MTEST:AMASK:XDELta <value>
<value> ::= X delta value in NR3 format
```

The :MTEST:AMASK:XDELta command sets the tolerance in the X direction around the waveform for the automasking feature. The absolute value of the tolerance will be added and subtracted to horizontal values of the waveform to determine the boundaries of the mask.

The horizontal tolerance value is interpreted based on the setting specified by the :MTEST:AMASK:UNITs command; thus, if you specify 250-E3, the setting for :MTEST:AMASK:UNITs is CURRent, and the current setting specifies time in the horizontal direction, the tolerance will be  $\pm 250$  ms. If the setting for :MTEST:AMASK:UNITs is DIVisions, the same X delta value will set the tolerance to  $\pm 250$  millidivisions, or 1/4 of a division.

**Query Syntax**

```
:MTEST:AMASK:XDELta?
```

The :MTEST:AMASK:XDELta? query returns the current setting of the  $\Delta X$  tolerance for automasking. If your computer program will interpret this value, it should also request the current measurement system using the :MTEST:AMASK:UNITs query.

**Return Format**

```
<value><NL>
<value> ::= X delta value in NR3 format
```

**See Also**

- "[Introduction to :MTEST Commands](#)" on page 719
- "[":MTEST:AMASK:UNITs](#)" on page 725
- "[":MTEST:AMASK:YDELta](#)" on page 727
- "[":MTEST:AMASK:SOURce](#)" on page 724
- "[":MTEST:SOURce](#)" on page 749

**Example Code**

- "[Example Code](#)" on page 719

## :MTEST:AMASK:YDELta

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MTEST:AMASK:YDELta &lt;value&gt;</code> <code>&lt;value&gt; ::= Y delta value in NR3 format</code>
	The :MTEST:AMASK:YDELta command sets the vertical tolerance around the waveform for the automasking feature. The absolute value of the tolerance will be added and subtracted to vertical values of the waveform to determine the boundaries of the mask.
	The vertical tolerance value is interpreted based on the setting specified by the :MTEST:AMASK:UNITs command; thus, if you specify 250-E3, the setting for :MTEST:AMASK:UNITs is CURRent, and the current setting specifies voltage in the vertical direction, the tolerance will be $\pm 250$ mV. If the setting for :MTEST:AMASK:UNITs is DIVisions, the same Y delta value will set the tolerance to $\pm 250$ millidivisions, or 1/4 of a division.
<b>Query Syntax</b>	<code>:MTEST:AMASK:YDELta?</code>
	The :MTEST:AMASK:YDELta? query returns the current setting of the $\Delta Y$ tolerance for automasking. If your computer program will interpret this value, it should also request the current measurement system using the :MTEST:AMASK:UNITs query.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code> <code>&lt;value&gt; ::= Y delta value in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">Introduction to :MTEST Commands</a>" on page 719</li> <li>· "<a href="#">:MTEST:AMASK:UNITs</a>" on page 725</li> <li>· "<a href="#">:MTEST:AMASK:XDELta</a>" on page 726</li> <li>· "<a href="#">:MTEST:AMASK:SOURce</a>" on page 724</li> <li>· "<a href="#">:MTEST:SOURce</a>" on page 749</li> </ul>
<b>Example Code</b>	<ul style="list-style-type: none"> <li>· "<a href="#">Example Code</a>" on page 719</li> </ul>

## :MTESt:COUNt:FWAVeforms

**N** (see [page 1666](#))

**Query Syntax** `:MTESt:COUNt:FWAVeforms? [CHANnel<n>]`

`<n> ::= 1 to (# analog channels) in NR1 format`

The :MTESt:COUNt:FWAVeforms? query returns the total number of failed waveforms in the current mask test run. This count is for all regions and all waveforms collected on the channel specified by the optional parameter or collected on the currently specified source channel (:MTESt:SOURce) if there is no parameter.

**Return Format** `<failed><NL>`

`<failed> ::= number of failed waveforms in NR1 format.`

**See Also**

- "[Introduction to :MTESt Commands](#)" on page 719
- "[:MTESt:COUNt:WAVEforms](#)" on page 731
- "[:MTESt:COUNt:TIME](#)" on page 730
- "[:MTESt:COUNt:RESet](#)" on page 729
- "[:MTESt:SOURce](#)" on page 749

**Example Code** · "[Example Code](#)" on page 719

## :MTEST:COUNt:RESet

**N** (see [page 1666](#))

**Command Syntax** :MTEST:COUNt:RESet

The :MTEST:COUNt:RESet command resets the mask statistics.

**See Also**

- "[Introduction to :MTEST Commands](#)" on page 719
- "[:MTEST:COUNt:WAVeforms](#)" on page 731
- "[:MTEST:COUNt:FWAveforms](#)" on page 728
- "[:MTEST:COUNt:TIME](#)" on page 730

## :MTEST:COUNt:TIME

**N** (see [page 1666](#))

**Query Syntax** `:MTEST:COUNt:TIME?`

The `:MTEST:COUNt:TIME?` query returns the elapsed time in the current mask test run.

**Return Format** `<time><NL>`

`<time>` ::= elapsed seconds in NR3 format.

**See Also**

- ["Introduction to :MTEST Commands" on page 719](#)

- [":MTEST:COUNt:WAVEforms" on page 731](#)

- [":MTEST:COUNt:FWAVEforms" on page 728](#)

- [":MTEST:COUNt:RESet" on page 729](#)

**Example Code**

- ["Example Code" on page 719](#)

## :MTEST:COUNt:WAveforms

**N** (see [page 1666](#))

**Query Syntax** `:MTEST:COUNt:WAveforms?`

The `:MTEST:COUNt:WAveforms?` query returns the total number of waveforms acquired in the current mask test run.

**Return Format** `<count><NL>`

`<count>` ::= number of waveforms in NR1 format.

**See Also**

- ["Introduction to :MTEST Commands"](#) on page 719

- [":MTEST:COUNt:FWAveforms"](#) on page 728

- [":MTEST:COUNt:TIME"](#) on page 730

- [":MTEST:COUNt:RESet"](#) on page 729

**Example Code**

- ["Example Code"](#) on page 719

## :MTEST:DATA

**N** (see [page 1666](#))

**Command Syntax**    `:MTEST:DATA <mask>`

`<mask>` ::= binary block data in IEEE 488.2 # format.

The :MTEST:DATA command loads a mask from binary block data.

**Query Syntax**    `:MTEST:DATA?`

The :MTEST:DATA? query returns a mask in binary block data format. The format for the data transmission is the # format defined in the IEEE 488.2 specification.

**Return Format**    `<mask><NL>`

`<mask>` ::= binary block data in IEEE 488.2 # format

**See Also**

- [":SAVE:MASK\[:STARt\]" on page 886](#)
- [":RECall:MASK\[:STARt\]" on page 868](#)

## :MTEST:DELetE

**N** (see [page 1666](#))

**Command Syntax** :MTEST:DELetE

The :MTEST:DELetE command clears the currently loaded mask.

**See Also**

- "[Introduction to :MTEST Commands](#)" on page 719
- "[":MTEST:AMASK:CREAtE](#)" on page 723

## :MTEST:ENABLE

**N** (see [page 1666](#))

**Command Syntax**    `:MTEST:ENABLE <on_off>`

`<on_off> ::= {{1 | ON} | {0 | OFF}}`

The :MTEST:ENABLE command enables or disables the mask test features.

- ON – Enables the mask test features.
- OFF – Disables the mask test features.

**Query Syntax**    `:MTEST:ENABLE?`

The :MTEST:ENABLE? query returns the current state of mask test features.

**Return Format**    `<on_off><NL>`

`<on_off> ::= {1 | 0}`

**See Also**    • ["Introduction to :MTEST Commands" on page 719](#)

## :MTEST:LOCK

**N** (see [page 1666](#))

**Command Syntax** :MTEST:LOCK <on\_off>

<on\_off> ::= {{1 | ON} | {0 | OFF}}

The :MTEST:LOCK command enables or disables the mask lock feature:

- ON – Locks a mask to the SOURce. As the vertical or horizontal scaling or position of the SOURce changes, the mask is redrawn accordingly.
- OFF – The mask is static and does not move.

**Query Syntax** :MTEST:LOCK?

The :MTEST:LOCK? query returns the current mask lock setting.

**Return Format** <on\_off><NL>

<on\_off> ::= {1 | 0}

**See Also** • "[Introduction to :MTEST Commands](#)" on page 719  
• "[":MTEST:SOURce](#)" on page 749

## :MTEST:RMODE

**N** (see [page 1666](#))

**Command Syntax** `:MTEST:RMODE <rmode>`

```
<rmode> ::= {FORever | SIGMa | TIME | WAVEforms}
```

The :MTEST:RMODE command specifies the termination conditions for the mask test:

- FORever – the mask test runs until it is turned off.
- SIGMa – the mask test runs until the Sigma level is reached. This level is set by the "[:MTEST:RMODE:SIGMA](#)" on page 741 command.
- TIME – the mask test runs for a fixed amount of time. The amount of time is set by the "[:MTEST:RMODE:TIME](#)" on page 742 command.
- WAVEforms – the mask test runs until a fixed number of waveforms are acquired. The number of waveforms is set by the "[:MTEST:RMODE:WAVEforms](#)" on page 743 command.

**Query Syntax** `:MTEST:RMODE?`

The :MTEST:RMODE? query returns the currently set termination condition.

**Return Format** `<rmode><NL>`

```
<rmode> ::= {FOR | SIGM | TIME | WAV}
```

**See Also**

- "[Introduction to :MTEST Commands](#)" on page 719
- "[:MTEST:RMODE:SIGMA](#)" on page 741
- "[:MTEST:RMODE:TIME](#)" on page 742
- "[:MTEST:RMODE:WAVEforms](#)" on page 743

**Example Code**

- "[Example Code](#)" on page 719

## :MTEST:RMODE:FACTion:MEASure

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MTEST:RMODE:FACTion:MEASure &lt;on_off&gt;</code> <code>&lt;on_off&gt; ::= {{1   ON}   {0   OFF}}</code>
The :MTEST:RMODE:FACTion:MEASure command sets measuring only mask failures on or off.	

When ON, measurements and measurement statistics run only on waveforms that contain a mask violation; passing waveforms do not affect measurements and measurement statistics.

This mode is not available when the acquisition mode is set to Averaging.

<b>Query Syntax</b>	<code>:MTEST:RMODE:FACTion:MEASure?</code>
The :MTEST:RMODE:FACTion:MEASure? query returns the current mask failure measure setting.	

<b>Return Format</b>	<code>&lt;on_off&gt;&lt;NL&gt;</code> <code>&lt;on_off&gt; ::= {1   0}</code>
<b>See Also</b>	

- ["Introduction to :MTEST Commands"](#) on page 719
- [":MTEST:RMODE:FACTion:PRINT"](#) on page 738
- [":MTEST:RMODE:FACTion:SAVE"](#) on page 739
- [":MTEST:RMODE:FACTion:STOP"](#) on page 740

## :MTEST:RMODE:FACTion:PRINT

**N** (see [page 1666](#))

**Command Syntax**    `:MTEST:RMODE:FACTion:PRINT <on_off>`  
`<on_off> ::= {{1 | ON} | {0 | OFF}}`

The :MTEST:RMODE:FACTion:PRINT command sets printing on mask failures on or off.

**NOTE**

Setting :MTEST:RMODE:FACTion:PRINT ON automatically sets :MTEST:RMODE:FACTion:SAVE OFF.

See [Chapter 22](#), “:HARDcopy/:HCOPY Commands,” starting on page 541 for more information on setting the hardcopy device and formatting options.

**Query Syntax**    `:MTEST:RMODE:FACTion:PRINT?`

The :MTEST:RMODE:FACTion:PRINT? query returns the current mask failure print setting.

**Return Format**    `<on_off><NL>`  
`<on_off> ::= {1 | 0}`

**See Also**

- ["Introduction to :MTEST Commands"](#) on page 719
- [":MTEST:RMODE:FACTion:MEASure"](#) on page 737
- [":MTEST:RMODE:FACTion:SAVE"](#) on page 739
- [":MTEST:RMODE:FACTion:STOP"](#) on page 740

## :MTEST:RMODE:FACTion:SAVE

**N** (see [page 1666](#))

**Command Syntax** :MTEST:RMODE:FACTion:SAVE <on\_off>  
 <on\_off> ::= {{1 | ON} | {0 | OFF}}

The :MTEST:RMODE:FACTion:SAVE command sets saving on mask failures on or off.

### NOTE

Setting :MTEST:RMODE:FACTion:SAVE ON automatically sets :MTEST:RMODE:FACTion:PRINT OFF.

See [Chapter 32](#), “:SAVE Commands,” starting on page 873 for more information on save options.

**Query Syntax** :MTEST:RMODE:FACTion:SAVE?

The :MTEST:RMODE:FACTion:SAVE? query returns the current mask failure save setting.

**Return Format** <on\_off><NL>  
 <on\_off> ::= {1 | 0}

**See Also**

- ["Introduction to :MTEST Commands"](#) on page 719
- [":MTEST:RMODE:FACTion:MEASure"](#) on page 737
- [":MTEST:RMODE:FACTion:PRINT"](#) on page 738
- [":MTEST:RMODE:FACTion:STOP"](#) on page 740

## :MTEST:RMODE:FACTion:STOP

**N** (see [page 1666](#))

**Command Syntax**    `:MTEST:RMODE:FACTion:STOP <on_off>`  
`<on_off> ::= {{1 | ON} | {0 | OFF}}`

The :MTEST:RMODE:FACTion:STOP command sets stopping on a mask failure on or off. When this setting is ON and a mask violation is detected, the mask test is stopped and the acquisition system is stopped.

**Query Syntax**    `:MTEST:RMODE:FACTion:STOP?`

The :MTEST:RMODE:FACTion:STOP? query returns the current mask failure stop setting.

**Return Format**    `<on_off><NL>`  
`<on_off> ::= {1 | 0}`

**See Also**

- "[Introduction to :MTEST Commands](#)" on page 719
- "[":MTEST:RMODE:FACTion:MEASure](#)" on page 737
- "[":MTEST:RMODE:FACTion:PRINT](#)" on page 738
- "[":MTEST:RMODE:FACTion:SAVE](#)" on page 739

## :MTEST:RMODE:SIGMa

**N** (see [page 1666](#))

**Command Syntax** :MTEST:RMODE:SIGMa <level>

<level> ::= from 0.1 to 9.3 in NR3 format

When the :MTEST:RMODE command is set to SIGMa, the :MTEST:RMODE:SIGMa command sets the *test sigma* level to which a mask test runs. *Test sigma* is the best achievable process sigma, assuming no failures. (*Process sigma* is calculated using the number of failures per test.) The *test sigma* level indirectly specifies the number of waveforms that must be tested (in order to reach the sigma level).

**Query Syntax** :MTEST:RMODE:SIGMa?

The :MTEST:RMODE:SIGMa? query returns the current Sigma level setting.

**Return Format** <level><NL>

<level> ::= from 0.1 to 9.3 in NR3 format

**See Also**

- "[Introduction to :MTEST Commands](#)" on page 719
- "[":MTEST:RMODE"](#) on page 736

**Example Code**

- "[":Example Code"](#) on page 719

## :MTEST:RMODE:TIME

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:MTEST:RMODE:TIME &lt;seconds&gt;</code>  <code>&lt;seconds&gt; ::= from 1 to 86400 in NR3 format</code>
	When the :MTEST:RMODE command is set to TIME, the :MTEST:RMODE:TIME command sets the number of seconds for a mask test to run.
<b>Query Syntax</b>	<code>:MTEST:RMODE:TIME?</code>
	The :MTEST:RMODE:TIME? query returns the number of seconds currently set.
<b>Return Format</b>	<code>&lt;seconds&gt;&lt;NL&gt;</code>  <code>&lt;seconds&gt; ::= from 1 to 86400 in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">"Introduction to :MTEST Commands"</a> on page 719</li><li><a href="#">":MTEST:RMODE"</a> on page 736</li></ul>

## :MTEST:RMODE:WAVEforms

**N** (see [page 1666](#))

**Command Syntax** :MTEST:RMODE:WAVEforms <count>

<count> ::= number of waveforms in NR1 format  
from 1 to 2,000,000,000

When the :MTEST:RMODE command is set to WAVEforms, the :MTEST:RMODE:WAVEforms command sets the number of waveform acquisitions that are mask tested.

**Query Syntax** :MTEST:RMODE:WAVEforms?

The :MTEST:RMODE:WAVEforms? query returns the number of waveforms currently set.

**Return Format** <count><NL>

<count> ::= number of waveforms in NR1 format  
from 1 to 2,000,000,000

**See Also** • ["Introduction to :MTEST Commands"](#) on page 719  
• [":MTEST:RMODE"](#) on page 736

## :MTESt:SCALe:BIND

**N** (see [page 1666](#))

**Command Syntax**    `:MTESt:SCALe:BIND <on_off>`

`<on_off>` ::= {{1 | ON} | {0 | OFF}}

The :MTESt:SCALe:BIND command enables or disables Bind 1 & 0 Levels (Bind -1 & 0 Levels for inverted masks) control:

- ON –

If the Bind 1 & 0 Levels control is enabled, the 1 Level and the 0 Level controls track each other. Adjusting either the 1 Level or the 0 Level control shifts the position of the mask up or down without changing its size.

If the Bind -1 & 0 Levels control is enabled, the -1 Level and the 0 Level controls track each other. Adjusting either the -1 Level or the 0 Level control shifts the position of the mask up or down without changing its size.

- OFF –

If the Bind 1 & 0 Levels control is disabled, adjusting either the 1 Level or the 0 Level control changes the vertical height of the mask.

If the Bind -1 & 0 Levels control is disabled, adjusting either the -1 Level or the 0 Level control changes the vertical height of the mask.

**Query Syntax**    `:MTESt:SCALe:BIND?`

The :MTESt:SCALe:BIND? query returns the value of the Bind 1&0 control (Bind -1&0 for inverted masks).

**Return Format**    `<on_off><NL>`

`<on_off>` ::= {1 | 0}

**See Also**    ["Introduction to :MTESt Commands"](#) on page 719

- [":MTESt:SCALe:X1"](#) on page 745
- [":MTESt:SCALe:XDELta"](#) on page 746
- [":MTESt:SCALe:Y1"](#) on page 747
- [":MTESt:SCALe:Y2"](#) on page 748

## :MTEST:SCALe:X1

**N** (see [page 1666](#))

### Command Syntax

```
:MTEST:SCALe:X1 <x1_value>
<x1_value> ::= X1 value in NR3 format
```

The :MTEST:SCALe:X1 command defines where X=0 in the base coordinate system used for mask testing. The other X-coordinate is defined by the :MTEST:SCALe:XDELta command. Once the X1 and XDELta coordinates are set, all X values of vertices in the mask regions are defined with respect to this value, according to the equation:

$$x = (x * \Delta x) + x_1$$

Thus, if you set X1 to 100 ms, and XDELta to 100 ms, an X value of 0.100 is a vertex at 110 ms.

The oscilloscope uses this equation to normalize vertices. This simplifies reprogramming to handle different data rates. For example, if you halve the period of the waveform of interest, you need only to adjust the XDELta value to set up the mask for the new waveform.

The X1 value is a time value specifying the location of the X1 coordinate, which will then be treated as X=0 for mask regions coordinates.

### Query Syntax

```
:MTEST:SCALe:X1?
```

The :MTEST:SCALe:X1? query returns the current X1 coordinate setting.

### Return Format

```
<x1_value><NL>
<x1_value> ::= X1 value in NR3 format
```

### See Also

- ["Introduction to :MTEST Commands"](#) on page 719
- [":MTEST:SCALe:BIND"](#) on page 744
- [":MTEST:SCALe:XDELta"](#) on page 746
- [":MTEST:SCALe:Y1"](#) on page 747
- [":MTEST:SCALe:Y2"](#) on page 748

## :MTEST:SCALe:XDELta

**N** (see [page 1666](#))

**Command Syntax** `:MTEST:SCALe:XDELta <xdelta_value>`

`<xdelta_value> ::= X delta value in NR3 format`

The :MTEST:SCALe:XDELta command defines the position of the X2 marker with respect to the X1 marker. In the mask test coordinate system, the X1 marker defines where X=0; thus, the X2 marker defines where X=1.

Because all X vertices of the regions defined for mask testing are normalized with respect to X1 and  $\Delta X$ , redefining  $\Delta X$  also moves those vertices to stay in the same locations with respect to X1 and  $\Delta X$ . Thus, in many applications, it is best if you define XDELta as a pulse width or bit period. Then, a change in data rate without corresponding changes in the waveform can easily be handled by changing  $\Delta X$ .

The X-coordinate of polygon vertices is normalized using this equation:

$$x = (x * \Delta X) + x_1$$

The X delta value is a time value specifying the distance of the X2 marker with respect to the X1 marker.

For example, if the period of the waveform you wish to test is 1 ms, setting  $\Delta X$  to 1 ms ensures that the waveform's period is between the X1 and X2 markers.

**Query Syntax** `:MTEST:SCALe:XDELta?`

The :MTEST:SCALe:XDELta? query returns the current value of  $\Delta X$ .

**Return Format** `<xdelta_value><NL>`

`<xdelta_value> ::= X delta value in NR3 format`

- See Also**
- ["Introduction to :MTEST Commands" on page 719](#)
  - [":MTEST:SCALe:BIND" on page 744](#)
  - [":MTEST:SCALe:X1" on page 745](#)
  - [":MTEST:SCALe:Y1" on page 747](#)
  - [":MTEST:SCALe:Y2" on page 748](#)

## :MTEST:SCALe:Y1

**N** (see [page 1666](#))

**Command Syntax** :MTEST:SCALe:Y1 <y1\_value>

<y1\_value> ::= Y1 value in NR3 format

The :MTEST:SCALe:Y1 command defines where Y=0 in the coordinate system for mask testing. All Y values of vertices in the coordinate system are defined with respect to the boundaries set by SCALe:Y1 and SCALe:Y2 according to the equation:

$$Y = (Y * (Y2 - Y1)) + Y1$$

Thus, if you set Y1 to 100 mV, and Y2 to 1 V, a Y value of 0.100 in a vertex is at 190 mV.

The Y1 value is a voltage value specifying the point at which Y=0.

**Query Syntax** :MTEST:SCALe:Y1?

The :MTEST:SCALe:Y1? query returns the current setting of the Y1 marker.

**Return Format** <y1\_value><NL>

<y1\_value> ::= Y1 value in NR3 format

**See Also**

- ["Introduction to :MTEST Commands"](#) on page 719
- [":MTEST:SCALe:BIND"](#) on page 744
- [":MTEST:SCALe:X1"](#) on page 745
- [":MTEST:SCALe:XDELta"](#) on page 746
- [":MTEST:SCALe:Y2"](#) on page 748

## :MTEST:SCALe:Y2

**N** (see [page 1666](#))

**Command Syntax**    `:MTEST:SCALe:Y2 <y2_value>`

`<y2_value>` ::= Y2 value in NR3 format

The :MTEST:SCALe:Y2 command defines the Y2 marker in the coordinate system for mask testing. All Y values of vertices in the coordinate system are defined with respect to the boundaries defined by SCALe:Y1 and SCALe:Y2 according to the following equation:

$$Y = (Y * (Y2 - Y1)) + Y1$$

Thus, if you set Y1 to 100 mV, and Y2 to 1 V, a Y value of 0.100 in a vertex is at 190 mV.

The Y2 value is a voltage value specifying the location of the Y2 marker.

**Query Syntax**    `:MTEST:SCALe:Y2?`

The :MTEST:SCALe:Y2? query returns the current setting of the Y2 marker.

**Return Format**    `<y2_value><NL>`

`<y2_value>` ::= Y2 value in NR3 format

**See Also**

- "[Introduction to :MTEST Commands](#)" on page 719
- "[":MTEST:SCALe:BIND](#)" on page 744
- "[":MTEST:SCALe:X1](#)" on page 745
- "[":MTEST:SCALe:XDELta](#)" on page 746
- "[":MTEST:SCALe:Y1](#)" on page 747

## :MTEST:SOURce

**N** (see [page 1666](#))

**Command Syntax** :MTEST:SOURce <source>

<source> ::= CHANnel<n>

<n> ::= 1 to (# analog channels) in NR1 format

The :MTEST:SOURce command selects the channel which is configured by the commands contained in a mask file when it is loaded.

**Query Syntax** :MTEST:SOURce?

The :MTEST:SOURce? query returns the channel which is configured by the commands contained in the current mask file.

**Return Format** <source><NL>

<source> ::= {CHAN<n> | NONE}

<n> ::= 1 to (# analog channels) in NR1 format

**See Also**

- "[Introduction to :MTEST Commands](#)" on page 719
- "[":MTEST:AMASK:SOURce](#)" on page 724

## :MTESt:TITLe

**N** (see [page 1666](#))

**Query Syntax**    `:MTESt:TITLe?`

The `:MTESt:TITLe?` query returns the mask title which is a string of up to 128 characters. The title is displayed in the mask test dialog box and mask test tab when a mask file is loaded.

**Return Format**    `<title><NL>`

`<title>` ::= a string of up to 128 ASCII characters.

**See Also**    • "Introduction to [:MTESt Commands](#)" on page 719

## 29 :POD Commands

Control all oscilloscope functions associated with groups of digital channels. See "[Introduction to :POD<n> Commands](#)" on page 751.

**Table 118** :POD<n> Commands Summary

Command	Query	Options and Query Returns
:POD<n>:DISPlay { {0   OFF}   {1   ON} } (see <a href="#">page 753</a> )	:POD<n>:DISPlay? (see <a href="#">page 753</a> )	{0   1} <n> ::= 1-2 in NR1 format
:POD<n>:SIZE <value> (see <a href="#">page 754</a> )	:POD<n>:SIZE? (see <a href="#">page 754</a> )	<value> ::= {SMALL   MEDIUM   LARGe}
:POD<n>:THreshold <type>[suffix] (see <a href="#">page 755</a> )	:POD<n>:THreshold? (see <a href="#">page 755</a> )	<n> ::= 1-2 in NR1 format <type> ::= {CMOS   ECL   TTL   <user defined value>} <user defined value> ::= value in NR3 format [suffix] ::= {V   mV   uV }

**Introduction to :POD<n> Commands**    <n> ::= {1 | 2}

The POD subsystem commands control the viewing and threshold of groups of digital channels.

POD1 ::= D0-D7

POD2 ::= D8-D15

**NOTE**

These commands are only valid for the MSO models.

---

### Reporting the Setup

Use :POD1? or :POD2? to query setup information for the POD subsystem.

### Return Format

The following is a sample response from the :POD1? query. In this case, the query was issued following a \*RST command.

```
:POD1:DISP 0;THR +1.40E+00
```

## :POD<n>:DISPlay

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POD&lt;n&gt;:DISPlay &lt;display&gt;</code>
	<code>&lt;display&gt; ::= {{1   ON}   {0   OFF}}</code>
	<code>&lt;n&gt; ::= An integer, 1 or 2, is attached as a suffix to the command and defines the group of channels that are affected by the command.</code>
	<code>POD1 ::= D0-D7</code>
	<code>POD2 ::= D8-D15</code>
	The :POD<n>:DISPlay command turns displaying of the specified group of channels on or off.

### NOTE

This command is only valid for the MSO models.

<b>Query Syntax</b>	<code>:POD&lt;n&gt;:DISPlay?</code>
	The :POD<n>:DISPlay? query returns the current display setting of the specified group of channels.
<b>Return Format</b>	<code>&lt;display&gt;&lt;NL&gt;</code> <code>&lt;display&gt; ::= {0   1}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">Introduction to :POD&lt;n&gt; Commands</a>" on page 751</li> <li>· "<a href="#">:DIGItal&lt;d&gt;:DISPlay</a>" on page 405</li> <li>· "<a href="#">:CHANnel&lt;n&gt;:DISPlay</a>" on page 347</li> <li>· "<a href="#">:VIEW</a>" on page 298</li> <li>· "<a href="#">:BLANK</a>" on page 266</li> <li>· "<a href="#">:STATus</a>" on page 295</li> </ul>

## :POD<n>:SIZE

**N** (see [page 1666](#))

**Command Syntax**    `:POD<n>:SIZE <value>`

`<n>` ::= An integer, 1 or 2, is attached as a suffix to the command and defines the group of channels that are affected by the command.

`POD1` ::= D0-D7

`POD2` ::= D8-D15

`<value>` ::= {SMALL | MEDium | LARGe}

The :POD<n>:SIZE command specifies the size of digital channels on the display. Sizes are set for all pods. Therefore, if you set the size on pod 1 (for example), the same size is set on pod 2 as well.

### NOTE

This command is only valid for the MSO models.

**Query Syntax**    `:POD<n>:SIZE?`

The :POD<n>:SIZE? query returns the digital channels size setting.

**Return Format**    `<size_value><NL>`

`<size_value>` ::= {SMAL | MED | LARG}

**See Also**

- "Introduction to :POD<n> Commands" on page 751
- "[:DIGital<d>:SIZE](#)" on page 408
- "[:DIGital<d>:POStion](#)" on page 407

## :POD<n>:THreshold

**N** (see [page 1666](#))

### Command Syntax

```
:POD<n>:THreshold <type>[<suffix>]
<n> ::= An integer, 1 or 2, is attached as a suffix to the command and
       defines the group of channels that are affected by the command.

<type> ::= {CMOS | ECL | TTL | <user defined value>}

<user defined value> ::= -8.00 to +8.00 in NR3 format

<suffix> ::= {V | mV | uV}

POD1 ::= D0-D7

POD2 ::= D8-D15

TTL ::= 1.4V

CMOS ::= 2.5V

ECL ::= -1.3V
```

The :POD<n>:THreshold command sets the threshold for the specified group of channels. The threshold is used for triggering purposes and for displaying the digital data as high (above the threshold) or low (below the threshold).

### NOTE

This command is only valid for the MSO models.

### Query Syntax

```
:POD<n>:THreshold?
```

The :POD<n>:THreshold? query returns the threshold value for the specified group of channels.

### Return Format

```
<threshold><NL>
<threshold> ::= Floating point number in NR3 format
```

### See Also

- "[Introduction to :POD<n> Commands](#)" on page 751
- "[":DIGItal<d>:THreshold](#)" on page 409
- "[":TRIGger\[:EDGE\]:LEVel](#)" on page 1380

### Example Code

```
' THRESHOLD - This command is used to set the voltage threshold for
' the waveforms. There are three preset values (TTL, CMOS, and ECL)
' and you can also set a user-defined threshold value between
' -8.0 volts and +8.0 volts.
'
' In this example, we set channels 0-7 to CMOS, then set channels
' 8-15 to a user-defined 2.0 volts, and then set the external trigger
' to TTL. Of course, you only need to set the thresholds for the
' channels you will be using in your program.
```

```
' Set channels 0-7 to CMOS threshold.  
myScope.WriteString ":POD1:THRESHOLD CMOS"  
  
' Set channels 8-15 to 2.0 volts.  
myScope.WriteString ":POD2:THRESHOLD 2.0"  
  
' Set external channel to TTL threshold (short form).  
myScope.WriteString ":TRIG:LEV TTL,EXT"
```

See complete example programs at: [Chapter 46](#), “Programming Examples,” starting on page 1675

## 30 :POWer Commands

These :POWer commands are available when the power measurements and analysis application is licensed and enabled.

**Table 119** :POWer Commands Summary

Command	Query	Options and Query Returns
n/a	:POWer:CLResponse? (see <a href="#">page 765</a> )	n/a
:POWer:CLResponse:APP Ly (see <a href="#">page 766</a> )	n/a	n/a
n/a	:POWer:CLResponse:DAT A? [SWEep   SINGle] (see <a href="#">page 767</a> )	<binary_block> ::= comma-separated data with newlines at the end of each row
n/a	:POWer:CLResponse:DAT A:GMARgin? (see <a href="#">page 768</a> )	<gain_margin> ::= gain margin in dB in NR3 format.
n/a	:POWer:CLResponse:DAT A:GMARgin:FREQuency? (see <a href="#">page 769</a> )	<frequency> ::= 0 degrees phase crossover frequency in Hz in NR3 format
n/a	:POWer:CLResponse:DAT A:PMARgin? (see <a href="#">page 770</a> )	<phase_margin> ::= phase margin in degrees in NR3 format.
n/a	:POWer:CLResponse:DAT A:PMARgin:FREQuency? (see <a href="#">page 771</a> )	<frequency> ::= 0dB gain crossover frequency in Hz in NR3 format.
:POWer:CLResponse:FRE Quency:MODE <mode> (see <a href="#">page 772</a> )	:POWer:CLResponse:FRE Quency:MODE? (see <a href="#">page 772</a> )	<mode> ::= {SWEep   SINGle}
:POWer:CLResponse:FRE Quency:SINGLE <value>[suffix] (see <a href="#">page 773</a> )	:POWer:CLResponse:FRE Quency:SINGLE? (see <a href="#">page 773</a> )	<value> ::= {20   100   1000   10000   100000   1000000   10000000   2000000} [suffix] ::= {Hz   kHz   MHz}

**Table 119** :POWer Commands Summary (continued)

Command	Query	Options and Query Returns
:POWer:CLResponse:FREQuency:STARt <value>[suffix] (see page 774)	:POWer:CLResponse:FREQuency:STARt? (see page 774)	<value> ::= {20   100   1000   10000   100000   1000000   10000000} [suffix] ::= {Hz   kHz   MHz}
:POWer:CLResponse:FREQuency:STOP <value>[suffix] (see page 775)	:POWer:CLResponse:FREQuency:STOP? (see page 775)	<value> ::= {100   1000   10000   100000   1000000   10000000   20000000} [suffix] ::= {Hz   kHz   MHz}
:POWer:CLResponse:PPDecade <pts> (see page 776)	:POWer:CLResponse:PPDecade? (see page 776)	<pts> ::= {10   20   30   40   50   60   70   80   90   100}
:POWer:CLResponse:SOURce:INPUT <source> (see page 777)	:POWer:CLResponse:SOURce:INPUT? (see page 777)	<source> ::= CHANNEL<n> <n> ::= 1 to (# analog channels) in NR1 format
:POWer:CLResponse:SOURce:OUTPUT <source> (see page 778)	:POWer:CLResponse:SOURce:OUTPUT? (see page 778)	<source> ::= CHANNEL<n> <n> ::= 1 to (# analog channels) in NR1 format
:POWer:CLResponse:TRACe <selection> (see page 779)	:POWer:CLResponse:TRACe? (see page 779)	<selection> ::= {NONE   ALL   GAIN   PHASE} [, {GAIN   PHASE}]
:POWer:CLResponse:WGEN:LOAD <impedance> (see page 780)	:POWer:CLResponse:WGEN:LOAD? (see page 780)	<impedance> ::= {ONEMeg   FIFTy}
:POWer:CLResponse:WGEN:VOLTage <amplitude>[,<range>] (see page 781)	:POWer:CLResponse:WGEN:VOLTage? [<range>] (see page 781)	<amplitude> ::= amplitude in volts in NR3 format <range> ::= {F20HZ   F100HZ   F1KHZ   F10KHZ   F100KHZ   F1MHZ   F10MHZ   F20MHZ}
:POWer:CLResponse:WGEN:VOLTage:PROFILE {{0   OFF}   {1   ON}} (see page 782)	:POWer:CLResponse:WGEN:VOLTage:PROFILE? (see page 782)	{0   1}
:POWer:DESKew (see page 783)	n/a	n/a
:POWer:EFFiciency:APPly (see page 784)	n/a	n/a
:POWer:EFFiciency:TYPE <type> (see page 785)	:POWer:EFFiciency:TYPE? (see page 785)	<type> ::= {DCDC   DCAC   ACDC   ACAC}

**Table 119** :POWer Commands Summary (continued)

Command	Query	Options and Query Returns
:POWer:ENABLE {{0   OFF}   {1   ON}} (see page 786)	:POWer:ENABLE? (see page 786)	{0   1}
:POWer:HARMonics:APPLy (see page 787)	n/a	n/a
n/a	:POWer:HARMonics:DATA? (see page 788)	<binary_block> ::= comma-separated data with newlines at the end of each row
:POWer:HARMonics:DISPLAY <display> (see page 789)	:POWer:HARMonics:DISPLAY? (see page 789)	<display> ::= {TABLE   BAR   OFF}
n/a	:POWer:HARMonics:FAILCOUNT? (see page 790)	<count> ::= integer in NR1 format
:POWer:HARMonics:LINE <frequency> (see page 791)	:POWer:HARMonics:LINE? (see page 791)	<frequency> ::= {F50   F60   F400   AUTO}
n/a	:POWer:HARMonics:POWERFACtor? (see page 792)	<value> ::= Class C power factor in NR3 format
:POWer:HARMonics:RPOWER <source> (see page 793)	:POWer:HARMonics:RPOWER? (see page 793)	<source> ::= {MEASured   USER}
:POWer:HARMonics:RPOWER:USER <value> (see page 794)	:POWer:HARMonics:RPOWER:USER? (see page 794)	<value> ::= Watts from 1.0 to 600.0 in NR3 format
n/a	:POWer:HARMonics:RUNCOUNT? (see page 795)	<count> ::= integer in NR1 format
:POWer:HARMonics:STANDARD <class> (see page 796)	:POWer:HARMonics:STANDARD? (see page 796)	<class> ::= {A   B   C   D}
n/a	:POWer:HARMonics:STATUS? (see page 797)	<status> ::= {PASS   FAIL   UNTESTED}
n/a	:POWer:HARMonics:THD? (see page 798)	<value> ::= Total Harmonics Distortion in NR3 format
:POWer:INRUSH:APPLY (see page 799)	n/a	n/a
:POWer:INRUSH:EXIT (see page 800)	n/a	n/a

**Table 119** :POWer Commands Summary (continued)

Command	Query	Options and Query Returns
:POWer:INRush:NEXT (see <a href="#">page 801</a> )	n/a	n/a
:POWer:ITYPe <type> (see <a href="#">page 802</a> )	:POWer:ITYPe? (see <a href="#">page 802</a> )	<type> ::= {DC   AC}
:POWer:MODulation:APP Ly (see <a href="#">page 803</a> )	n/a	n/a
:POWer:MODulation:SOU Rce <source> (see <a href="#">page 804</a> )	:POWer:MODulation:SOU Rce? (see <a href="#">page 804</a> )	<source> ::= {V   I}
:POWer:MODulation:TYP E <modulation> (see <a href="#">page 805</a> )	:POWer:MODulation:TYP E? (see <a href="#">page 805</a> )	<modulation> ::= {VAverage   ACRMs   VRATio   PERiod   FREQuency   PWIDith   NWIDth   DUTYcycle   RISetime   FALLtime}
:POWer:ONOFF:APPLY (see <a href="#">page 806</a> )	n/a	n/a
:POWer:ONOFF:EXIT (see <a href="#">page 807</a> )	n/a	n/a
:POWer:ONOFF:NEXT (see <a href="#">page 808</a> )	n/a	n/a
:POWer:ONOFF:TEST {{0   OFF}   {1   ON}} (see <a href="#">page 809</a> )	:POWer:ONOFF:TEST? (see <a href="#">page 809</a> )	{0   1}
:POWer:ONOFF:THReshol ds <type>, <input_thr>, <output_thr> (see <a href="#">page 810</a> )	:POWer:ONOFF:THReshol ds? <type> (see <a href="#">page 810</a> )	<type> ::= {0   1} <input_thr> ::= percent from 0-100 in NR1 format <output_thr> ::= percent from 0-100 in NR1 format
n/a	:POWer:PSRR? (see <a href="#">page 812</a> )	n/a
:POWer:PSRR:APPLy (see <a href="#">page 813</a> )	n/a	n/a
n/a	:POWer:PSRR:DATA? [SWEep   SINGle] (see <a href="#">page 814</a> )	<binary_block> ::= comma-separated data with newlines at the end of each row
:POWer:PSRR:FREQuency :MAXimum <value>[suffix] (see <a href="#">page 815</a> )	:POWer:PSRR:FREQuency :MAXimum? (see <a href="#">page 815</a> )	<value> ::= {10   100   1000   10000   100000   1000000   10000000   20000000} [suffix] ::= {Hz   kHz   MHz}

**Table 119** :POWer Commands Summary (continued)

Command	Query	Options and Query Returns
:POWer:PSRR:FREQuency :MINimum <value>[suffix] (see page 816)	:POWer:PSRR:FREQuency :MINimum? (see page 816)	<value> ::= {1   10   100   1000   10000   100000   1000000   10000000} [suffix] ::= {Hz   kHz   MHz}
:POWer:PSRR:FREQuency :MODE <mode> (see page 817)	:POWer:PSRR:FREQuency :MODE? (see page 817)	<mode> ::= {SWEep   SINGLE}
:POWer:PSRR:FREQuency :SINGle <value>[suffix] (see page 818)	:POWer:PSRR:FREQuency :SINGle? (see page 818)	<value> ::= {1   10   100   1000   10000   100000   1000000   10000000   2000000} [suffix] ::= {Hz   kHz   MHz}
:POWer:PSRR:PPDecade <pts> (see page 819)	:POWer:PSRR:PPDecade? (see page 819)	<pts> ::= {10   20   30   40   50   60   70   80   90   100}
:POWer:PSRR:SOURce:IN Put <source> (see page 820)	:POWer:PSRR:SOURce:IN Put? (see page 820)	<source> ::= CHANNEL<n> <n> ::= 1 to (# analog channels) in NR1 format
:POWer:PSRR:SOURce:OU TPut <source> (see page 821)	:POWer:PSRR:SOURce:OU TPut? (see page 821)	<source> ::= CHANNEL<n> <n> ::= 1 to (# analog channels) in NR1 format
:POWer:PSRR:TRACe <selection> (see page 822)	:POWer:PSRR:TRACe? (see page 822)	<selection> ::= {NONE   GAIN}
:POWer:PSRR:WGEN:LOAD <impedance> (see page 823)	:POWer:PSRR:WGEN:LOAD ? (see page 823)	<impedance> ::= {ONEMeg   FIFTy}
:POWer:PSRR:WGEN:VOLTage <amplitude>[,<range>] (see page 824)	:POWer:PSRR:WGEN:VOLTage? [<range>] (see page 824)	<amplitude> ::= amplitude in volts in NR3 format <range> ::= {F20HZ   F100HZ   F1KHZ   F10KHZ   F100KHZ   F1MHZ   F10MHZ   F20MHZ}
:POWer:PSRR:WGEN:VOLTage:PROFILE {0   OFF}   {1   ON} (see page 825)	:POWer:PSRR:WGEN:VOLTage:PROFILE? (see page 825)	{0   1}
:POWer:QUALity:APPLy (see page 826)	n/a	n/a
:POWer:RIPple:APPLy (see page 827)	n/a	n/a

**Table 119** :POWer Commands Summary (continued)

Command	Query	Options and Query Returns
:POWer:SIGNals:AUToSetup <analysis> (see page 828)	n/a	<analysis> ::= {HARMonics   EFFiciency   RIPPLE   MODulation   QUALity   SLEW   SWITch   RDSVce}
:POWer:SIGNals:CYCLes:HARMonics <count> (see page 829)	:POWer:SIGNals:CYCLes:HARMonics? (see page 829)	<count> ::= integer in NR1 format Legal values are 1 to 100.
:POWer:SIGNals:CYCLes:QUALity <count> (see page 830)	:POWer:SIGNals:CYCLes:QUALity? (see page 830)	<count> ::= integer in NR1 format Legal values are 1 to 100.
:POWer:SIGNals:DURatiOn:EFFiciency <value>[suffix] (see page 831)	:POWer:SIGNals:DURatiOn:EFFiciency? (see page 831)	<value> ::= value in NR3 format [suffix] ::= {s   ms   us   ns}
:POWer:SIGNals:DURatiOn:MODulation <value>[suffix] (see page 832)	:POWer:SIGNals:DURatiOn:MODulation? (see page 832)	<value> ::= value in NR3 format [suffix] ::= {s   ms   us   ns}
:POWer:SIGNals:DURatiOn:ONOFF:OFF <value>[suffix] (see page 833)	:POWer:SIGNals:DURatiOn:ONOFF:OFF? (see page 833)	<value> ::= value in NR3 format [suffix] ::= {s   ms   us   ns}
:POWer:SIGNals:DURatiOn:ONOFF:ON <value>[suffix] (see page 834)	:POWer:SIGNals:DURatiOn:ONOFF:ON? (see page 834)	<value> ::= value in NR3 format [suffix] ::= {s   ms   us   ns}
:POWer:SIGNals:DURatiOn:RIPPLE <value>[suffix] (see page 835)	:POWer:SIGNals:DURatiOn:RIPPLE? (see page 835)	<value> ::= value in NR3 format [suffix] ::= {s   ms   us   ns}
:POWer:SIGNals:DURatiOn:TRANsient <value>[suffix] (see page 836)	:POWer:SIGNals:DURatiOn:TRANsient? (see page 836)	<value> ::= value in NR3 format [suffix] ::= {s   ms   us   ns}
:POWer:SIGNals:IEXPected <value>[suffix] (see page 837)	:POWer:SIGNals:IEXPected? (see page 837)	<value> ::= Expected current value in NR3 format [suffix] ::= {A   mA}
:POWer:SIGNals:OVERshoot <percent> (see page 838)	:POWer:SIGNals:OVERshoot? (see page 838)	<percent> ::= percent of overshoot value in NR1 format [suffix] ::= {V   mV}}

**Table 119** :POWer Commands Summary (continued)

Command	Query	Options and Query Returns
:POWer:SIGNals:VMAXim um:INRush <value>[suffix] (see page 839)	:POWer:SIGNals:VMAXim um:INRush? (see page 839)	<value> ::= Maximum expected input Voltage in NR3 format [suffix] ::= {V   mV}
:POWer:SIGNals:VMAXim um:ONOFF:OFF <value>[suffix] (see page 840)	:POWer:SIGNals:VMAXim um:ONOFF:OFF? (see page 840)	<value> ::= Maximum expected input Voltage in NR3 format [suffix] ::= {V   mV}
:POWer:SIGNals:VMAXim um:ONOFF:ON <value>[suffix] (see page 841)	:POWer:SIGNals:VMAXim um:ONOFF:ON? (see page 841)	<value> ::= Maximum expected input Voltage in NR3 format [suffix] ::= {V   mV}
:POWer:SIGNals:VSTead y:ONOFF:OFF <value>[suffix] (see page 842)	:POWer:SIGNals:VSTead y:ONOFF:OFF? (see page 842)	<value> ::= Expected steady stage output Voltage value in NR3 format [suffix] ::= {V   mV}
:POWer:SIGNals:VSTead y:ONOFF:ON <value>[suffix] (see page 843)	:POWer:SIGNals:VSTead y:ONOFF:ON? (see page 843)	<value> ::= Expected steady stage output Voltage value in NR3 format [suffix] ::= {V   mV}
:POWer:SIGNals:VSTead y:TRANSient <value>[suffix] (see page 844)	:POWer:SIGNals:VSTead y:TRANSient? (see page 844)	<value> ::= Expected steady stage output Voltage value in NR3 format [suffix] ::= {V   mV}
:POWer:SIGNals:SOURce :CURRent<i> <source> (see page 845)	:POWer:SIGNals:SOURce :CURRent<i>? (see page 845)	<i> ::= 1, 2 in NR1 format <source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:POWer:SIGNals:SOURce :VOLTage<i> <source> (see page 846)	:POWer:SIGNals:SOURce :VOLTage<i>? (see page 846)	<i> ::= 1, 2 in NR1 format <source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:POWer:SLEW:APPLY (see page 847)	n/a	n/a
:POWer:SLEW:SOURce <source> (see page 848)	:POWer:SLEW:SOURce? (see page 848)	<source> ::= {V   I}
:POWer:SWITch:APPLY (see page 849)	n/a	n/a

**Table 119** :POWer Commands Summary (continued)

Command	Query	Options and Query Returns
:POWer:SWITch:CONDuct ion <conduction> (see page 850)	:POWer:SWITch:CONDuct ion? (see page 850)	<conduction> ::= {WAveform   RDS   VCE}
:POWer:SWITch:IREFere nce <percent> (see page 851)	:POWer:SWITch:IREFere nce? (see page 851)	<percent> ::= percent in NR1 format
:POWer:SWITch:RDS <value>[suffix] (see page 852)	:POWer:SWITch:RDS? (see page 852)	<value> ::= Rds(on) value in NR3 format [suffix] ::= {OHM   mOHM}
:POWer:SWITch:VCE <value>[suffix] (see page 853)	:POWer:SWITch:VCE? (see page 853)	<value> ::= Vce(sat) value in NR3 format [suffix] ::= {V   mV}
:POWer:SWITch:VREFere nce <percent> (see page 854)	:POWer:SWITch:VREFere nce? (see page 854)	<percent> ::= percent in NR1 format
:POWer:TRANSient:APPL y (see page 855)	n/a	n/a
:POWer:TRANSient:EXIT (see page 856)	n/a	n/a
:POWer:TRANSient:IINI tial <value>[suffix] (see page 857)	:POWer:TRANSient:IINI tial? (see page 857)	<value> ::= Initial current value in NR3 format [suffix] ::= {A   mA}
:POWer:TRANSient:INEW <value>[suffix] (see page 858)	:POWer:TRANSient:INEW ? (see page 858)	<value> ::= New current value in NR3 format [suffix] ::= {A   mA}
:POWer:TRANSient:NEXT (see page 859)	n/a	n/a

## :POWer:CLResponse

**N** (see [page 1666](#))

**Query Syntax** `:POWer:CLResponse?`

The `:POWer:CLResponse?` query returns the Control Loop Response (Bode) power analysis settings.

**Return Format** `<settings_string><NL>`

For example, the query returns the following string when issued after the `*RST` command.

```
:POW:CLR:SOUR:INP CHAN1;OUTP CHAN2;:POW:CLR:FREQ:STAR +100E+00;
STOP +20.000000E+06;:POW:CLR:WGEN:VOLT +200.0E-03;LOAD FIFT
```

**See Also**

- [":POWer:CLResponse:APPLy" on page 766](#)
- [":POWer:CLResponse:DATA" on page 767](#)
- [":POWer:CLResponse:FREQuency:MODE" on page 772](#)
- [":POWer:CLResponse:FREQuency:STARt" on page 774](#)
- [":POWer:CLResponse:FREQuency:STOP" on page 775](#)
- [":POWer:CLResponse:PPDecade" on page 776](#)
- [":POWer:CLResponse:SOURce:INPut" on page 777](#)
- [":POWer:CLResponse:SOURce:OUTPut" on page 778](#)
- [":POWer:CLResponse:WGEN:LOAD" on page 780](#)
- [":POWer:CLResponse:WGEN:VOLTage" on page 781](#)
- [":POWer:CLResponse:WGEN:VOLTage:PROFle" on page 782](#)

## :POWer:CLResponse:APPLy

**N** (see [page 1666](#))

### Command Syntax

`:POWer:CLResponse:APPLy`

The :POWer:CLResponse:APPLy command performs the control loop response (Bode) analysis to help you determine the margin of a control loop.

A Bode plot measurement plots gain and/or phase as a function of frequency.

You can use the :POWer:CLResponse:TRACe command to specify whether to include gain, phase, both gain and phase, or neither in the frequency response analysis results.

This control loop response analysis requires an input sine wave (from the oscilloscope's waveform generator, Vi) be swept from a low to a high frequency while measuring Vi and Vo RMS voltages at each step frequency, using two channels of the oscilloscope.

For a gain plot, gain (A, in dB units) at each step frequency is computed as  $20\log(V_o/V_i)$  and plotted using a math function waveform.

For a phase plot, the phase difference between the channels is measured at each step frequency. Phase measurements and plots are only possible if the input and output waveforms exceed 1 division peak-to-peak (>1 mVpp).

It takes some time for the frequency sweep analysis to complete. You can query bit 0 of the Standard Event Status Register (\*ESR?) to find out when the analysis is complete.

### See Also

- ["\\*\\*ESR \(Standard Event Status Register\)" on page 236](#)
- [":POWer:CLResponse" on page 765](#)
- [":POWer:CLResponse:DATA" on page 767](#)
- [":POWer:CLResponse:FREQuency:MODE" on page 772](#)
- [":POWer:CLResponse:FREQuency:SINGLe" on page 773](#)
- [":POWer:CLResponse:FREQuency:STARt" on page 774](#)
- [":POWer:CLResponse:FREQuency:STOP" on page 775](#)
- [":POWer:CLResponse:PPDecade" on page 776](#)
- [":POWer:CLResponse:SOURce:INPUT" on page 777](#)
- [":POWer:CLResponse:SOURce:OUTPut" on page 778](#)
- [":POWer:CLResponse:TRACe" on page 779](#)
- [":POWer:CLResponse:WGEN:LOAD" on page 780](#)
- [":POWer:CLResponse:WGEN:VOLTage" on page 781](#)
- [":POWer:CLResponse:WGEN:VOLTage:PROFile" on page 782](#)

## :POWER:CLResponse:DATA

**N** (see [page 1666](#))

**Query Syntax** `:POWER:CLResponse:DATA? [SWEep | SINGLE]`

The :POWER:CLResponse:DATA? query returns data from the Control Loop Response (Bode) power analysis.

The comma-separated value format is suitable for spreadsheet analysis.

You can use the :POWER:CLResponse:TRACe command to specify whether to include gain, phase, both gain and phase, or neither in the frequency response analysis results.

The SWEep or SINGLE option specifies whether to get the data from a sweep or single-frequency analysis (see :POWER:CLResponse:FREQuency:MODE). If this option is not specified, the data from the sweep analysis is returned by default.

**Return Format** `<binary_block><NL>`

```
<binary_block> ::= comma-separated data with newlines at the end of each
row
```

**See Also**

- "[":POWER:CLResponse"](#) on page 765
- "[":POWER:CLResponse:APPLy"](#) on page 766
- "[":POWER:CLResponse:DATA:GMARgin"](#) on page 768
- "[":POWER:CLResponse:DATA:GMARgin:FREQuency"](#) on page 769
- "[":POWER:CLResponse:DATA:PMARgin"](#) on page 770
- "[":POWER:CLResponse:DATA:PMARgin:FREQuency"](#) on page 771
- "[":POWER:CLResponse:FREQuency:MODE"](#) on page 772
- "[":POWER:CLResponse:FREQuency:SINGle"](#) on page 773
- "[":POWER:CLResponse:FREQuency:STARt"](#) on page 774
- "[":POWER:CLResponse:FREQuency:STOP"](#) on page 775
- "[":POWER:CLResponse:PPDecade"](#) on page 776
- "[":POWER:CLResponse:SOURce:INPUT"](#) on page 777
- "[":POWER:CLResponse:SOURce:OUTPut"](#) on page 778
- "[":POWER:CLResponse:TRACe"](#) on page 779
- "[":POWER:CLResponse:WGEN:LOAD"](#) on page 780
- "[":POWER:CLResponse:WGEN:VOLTage"](#) on page 781
- "[":POWER:CLResponse:WGEN:VOLTage:PROFile"](#) on page 782

## :POWer:CLResponse:DATA:GMARgin

**N** (see [page 1666](#))

**Query Syntax** `:POWer:CLResponse:DATA:GMARgin?`

After the Control Loop Response (Bode) power analysis has been performed (see `:POWer:CLResponse:APPLy`), the `:POWer:CLResponse:DATA:GMARgin?` query returns the gain margin in dB.

**Return Format** `<gain_margin><NL>`

`<gain_margin>` ::= gain margin in dB in NR3 format.

The query returns +9.9E+37 if the value cannot be calculated from the last sweep (that is, if there are no crossover points).

**See Also**

- "[":POWer:CLResponse:APPLy](#)" on page 766
- "[":POWer:CLResponse:DATA](#)" on page 767
- "[":POWer:CLResponse:DATA:GMARgin:FREQuency](#)" on page 769
- "[":POWer:CLResponse:DATA:PMARgin](#)" on page 770
- "[":POWer:CLResponse:DATA:PMARgin:FREQuency](#)" on page 771

## :POWer:CLResponse:DATA:GMARgin:FREQuency

**N** (see [page 1666](#))

<b>Query Syntax</b>	<code>:POWer:CLResponse:DATA:GMARgin:FREQuency?</code>
	After the Control Loop Response (Bode) power analysis has been performed (see :POWer:CLResponse:APPLy), the :POWer:CLResponse:DATA:GMARgin:FREQuency? query returns the 0° phase crossover frequency in Hz.
<b>Return Format</b>	<code>&lt;frequency&gt;&lt;NL&gt;</code> <code>&lt;frequency&gt; ::= 0 degrees phase crossover frequency in Hz in NR3 format</code> The query returns +9.9E+37 if the value cannot be calculated from the last sweep (that is, if there are no crossover points).
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":POWer:CLResponse:APPLy" on page 766</a></li><li><a href="#">":POWer:CLResponse:DATA" on page 767</a></li><li><a href="#">":POWer:CLResponse:DATA:GMARgin" on page 768</a></li><li><a href="#">":POWer:CLResponse:DATA:PMARgin" on page 770</a></li><li><a href="#">":POWer:CLResponse:DATA:PMARgin:FREQuency" on page 771</a></li></ul>

## :POWer:CLResponse:DATA:PMARgin

**N** (see [page 1666](#))

**Query Syntax** `:POWer:CLResponse:DATA:PMARgin?`

After the Control Loop Response (Bode) power analysis has been performed (see `:POWer:CLResponse:APPLy`), the `:POWer:CLResponse:DATA:PMARgin?` query returns the phase margin in degrees.

**Return Format** `<phase_margin><NL>`

`<phase_margin> ::= phase margin in degrees in NR3 format.`

The query returns +9.9E+37 if the value cannot be calculated from the last sweep (that is, if there are no crossover points).

**See Also**

- "[":POWer:CLResponse:APPLy](#)" on page 766
- "[":POWer:CLResponse:DATA](#)" on page 767
- "[":POWer:CLResponse:DATA:GMARgin](#)" on page 768
- "[":POWer:CLResponse:DATA:GMARgin:FREQuency](#)" on page 769
- "[":POWer:CLResponse:DATA:PMARgin:FREQuency](#)" on page 771

## :POWer:CLResponse:DATA:PMARgin:FREQuency

**N** (see [page 1666](#))

**Query Syntax** `:POWer:CLResponse:DATA:PMARgin:FREQuency?`

After the Control Loop Response (Bode) power analysis has been performed (see `:POWer:CLResponse:APPLy`), the `:POWer:CLResponse:DATA:PMARgin:FREQuency?` query returns the 0 dB gain crossover frequency in Hz.

**Return Format** `<frequency><NL>`

`<frequency> ::= 0dB gain crossover frequency in Hz in NR3 format.`

The query returns +9.9E+37 if the value cannot be calculated from the last sweep (that is, if there are no crossover points).

**See Also**

- [":POWer:CLResponse:APPLy" on page 766](#)
- [":POWer:CLResponse:DATA" on page 767](#)
- [":POWer:CLResponse:DATA:GMARgin" on page 768](#)
- [":POWer:CLResponse:DATA:GMARgin:FREQuency" on page 769](#)
- [":POWer:CLResponse:DATA:PMARgin" on page 770](#)

## :POWER:CLResponse:FREQuency:MODE

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWER:CLResponse:FREQuency:MODE &lt;mode&gt;</code> <code>&lt;mode&gt; ::= {SWEep   SINGle}</code>
	The :POWER:CLResponse:FREQuency:MODE command specifies whether the analysis should be performed by sweeping through a range of frequencies (SWEep) or at a single frequency (SINGle).
	The SINGle mode is useful for evaluating amplitudes at a single frequency, for example, near the expected 0 dB cross-over frequency. After running the test at a single frequency, you can manually adjust (increase) the waveform generator's amplitude until you begin to observe distortion in the waveforms on the oscilloscope's display. You can then use that amplitude at all frequencies in SWEep mode, or you can evaluate amplitudes at other frequencies in order to determine an optimized amplitude profile (see :POWER:CLResponse:WGEN:VOLTage:PROFile).
<b>Query Syntax</b>	<code>:POWER:CLResponse:FREQuency:MODE?</code>
	The :POWER:CLResponse:FREQuency:MODE? query returns the frequency mode setting.
<b>Return Format</b>	<code>&lt;mode&gt;&lt;NL&gt;</code> <code>&lt;mode&gt; ::= {SWE   SING}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":POWER:CLResponse"</a> on page 765</li> <li>· <a href="#">":POWER:CLResponse:APPLy"</a> on page 766</li> <li>· <a href="#">":POWER:CLResponse:DATA"</a> on page 767</li> <li>· <a href="#">":POWER:CLResponse:FREQuency:SINGle"</a> on page 773</li> <li>· <a href="#">":POWER:CLResponse:FREQuency:STARt"</a> on page 774</li> <li>· <a href="#">":POWER:CLResponse:FREQuency:STOP"</a> on page 775</li> <li>· <a href="#">":POWER:CLResponse:PPDecade"</a> on page 776</li> <li>· <a href="#">":POWER:CLResponse:SOURce:INPUT"</a> on page 777</li> <li>· <a href="#">":POWER:CLResponse:SOURce:OUTPUT"</a> on page 778</li> <li>· <a href="#">":POWER:CLResponse:WGEN:LOAD"</a> on page 780</li> <li>· <a href="#">":POWER:CLResponse:WGEN:VOLTage"</a> on page 781</li> <li>· <a href="#">":POWER:CLResponse:WGEN:VOLTage:PROFile"</a> on page 782</li> </ul>

## :POWer:CLResponse:FREQuency:SINGle

**N** (see [page 1666](#))

**Command Syntax**

```
:POWer:CLResponse:FREQuency:SINGle <value>[suffix]
<value> ::= {20 | 100 | 1000 | 10000 | 100000 | 1000000 | 10000000
              | 2000000}
[suffix] ::= {Hz | kHz | MHz}
```

The :POWer:CLResponse:FREQuency:SINGle command sets the single frequency value. The control loop response analysis is displayed on a log scale Bode plot, so you can select from decade values in addition to the minimum frequency of 20 Hz.

**Query Syntax**

```
:POWer:CLResponse:FREQuency:SINGle?
```

The :POWer:CLResponse:FREQuency:SINGle? query returns the single frequency setting.

**Return Format**

```
<value><NL>
<value> ::= {20 | 100 | 1000 | 10000 | 100000 | 1000000 | 10000000
              | 2000000}
```

**See Also**

- "[:POWer:CLResponse](#)" on page 765
- "[:POWer:CLResponse:APPLy](#)" on page 766
- "[:POWer:CLResponse:DATA](#)" on page 767
- "[:POWer:CLResponse:FREQuency:MODE](#)" on page 772
- "[:POWer:CLResponse:PPDecade](#)" on page 776
- "[:POWer:CLResponse:SOURce:INPut](#)" on page 777
- "[:POWer:CLResponse:SOURce:OUTPut](#)" on page 778
- "[:POWer:CLResponse:WGEN:LOAD](#)" on page 780
- "[:POWer:CLResponse:WGEN:VOLTage](#)" on page 781
- "[:POWer:CLResponse:WGEN:VOLTage:PROFile](#)" on page 782

## :POWer:CLResponse:FREQuency:STARt

**N** (see [page 1666](#))

**Command Syntax**

```
:POWer:CLResponse:FREQuency:STARt <value>[suffix]
<value> ::= {20 | 100 | 1000 | 10000 | 100000 | 1000000 | 10000000}
[suffix] ::= {Hz | kHz | MHz}
```

The :POWer:CLResponse:FREQuency:STARt command sets the frequency sweep start value. The control loop response analysis is displayed on a log scale Bode plot, so you can select from decade values in addition to the minimum frequency of 20 Hz.

**Query Syntax**

```
:POWer:CLResponse:FREQuency:STARt?
```

The :POWer:CLResponse:FREQuency:STARt? query returns the frequency sweep start setting.

**Return Format**

```
<value><NL>
<value> ::= {20 | 100 | 1000 | 10000 | 100000 | 1000000 | 10000000}
```

**See Also**

- "[":POWer:CLResponse"](#) on page 765
- "[":POWer:CLResponse:APPLy"](#) on page 766
- "[":POWer:CLResponse:DATA"](#) on page 767
- "[":POWer:CLResponse:FREQuency:MODE"](#) on page 772
- "[":POWer:CLResponse:FREQuency:STOP"](#) on page 775
- "[":POWer:CLResponse:PPDecade"](#) on page 776
- "[":POWer:CLResponse:SOURce:INPut"](#) on page 777
- "[":POWer:CLResponse:SOURce:OUTPut"](#) on page 778
- "[":POWer:CLResponse:WGEN:LOAD"](#) on page 780
- "[":POWer:CLResponse:WGEN:VOLTage"](#) on page 781
- "[":POWer:CLResponse:WGEN:VOLTage:PROFile"](#) on page 782

## :POWer:CLResponse:FREQuency:STOP

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWer:CLResponse:FREQuency:STOP &lt;value&gt;[suffix]</code>
	<code>&lt;value&gt; ::= {100   1000   10000   100000   1000000   10000000   20000000}</code>
	<code>[suffix] ::= {Hz   kHz   MHz}</code>
	The :POWer:CLResponse:FREQuency:STOP command sets the frequency sweep stop value. The control loop response analysis is displayed on a log scale Bode plot, so you can select from decade values in addition to the maximum frequency of 20 MHz.
<b>Query Syntax</b>	<code>:POWer:CLResponse:FREQuency:STOP?</code>
	The :POWer:CLResponse:FREQuency:STOP? query returns the frequency sweep stop setting.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code>
	<code>&lt;value&gt; ::= {100   1000   10000   100000   1000000   10000000   20000000}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":POWer:CLResponse"</a> on page 765</li> <li>· <a href="#">":POWer:CLResponse:APPLy"</a> on page 766</li> <li>· <a href="#">":POWer:CLResponse:DATA"</a> on page 767</li> <li>· <a href="#">":POWer:CLResponse:FREQuency:MODE"</a> on page 772</li> <li>· <a href="#">":POWer:CLResponse:FREQuency:START"</a> on page 774</li> <li>· <a href="#">":POWer:CLResponse:PPDecade"</a> on page 776</li> <li>· <a href="#">":POWer:CLResponse:SOURce:INPut"</a> on page 777</li> <li>· <a href="#">":POWer:CLResponse:SOURce:OUTPut"</a> on page 778</li> <li>· <a href="#">":POWer:CLResponse:WGEN:LOAD"</a> on page 780</li> <li>· <a href="#">":POWer:CLResponse:WGEN:VOLTage"</a> on page 781</li> <li>· <a href="#">":POWer:CLResponse:WGEN:VOLTage:PROFile"</a> on page 782</li> </ul>

## :POWer:CLResponse:PPDecade

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWer:CLResponse:PPDecade &lt;pts&gt;</code>
	<code>&lt;pts&gt; ::= {10   20   30   40   50   60   70   80   90   100}</code>
	The :POWer:CLResponse:PPDecade command selects the number of frequency test points per decade (in the log scale).
<b>Query Syntax</b>	<code>:POWer:CLResponse:PPDecade?</code>
	The :POWer:CLResponse:PPDecade? query returns the points per decade setting.
<b>Return Format</b>	<code>&lt;pts&gt;&lt;NL&gt;</code>
	<code>&lt;pts&gt; ::= {10   20   30   40   50   60   70   80   90   100}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":POWer:CLResponse"</a> on page 765</li> <li>· <a href="#">":POWer:CLResponse:APPLy"</a> on page 766</li> <li>· <a href="#">":POWer:CLResponse:DATA"</a> on page 767</li> <li>· <a href="#">":POWer:CLResponse:FREQuency:MODE"</a> on page 772</li> <li>· <a href="#">":POWer:CLResponse:FREQuency:STARt"</a> on page 774</li> <li>· <a href="#">":POWer:CLResponse:FREQuency:STOP"</a> on page 775</li> <li>· <a href="#">":POWer:CLResponse:SOURce:INPUT"</a> on page 777</li> <li>· <a href="#">":POWer:CLResponse:SOURce:OUTPut"</a> on page 778</li> <li>· <a href="#">":POWer:CLResponse:WGEN:LOAD"</a> on page 780</li> <li>· <a href="#">":POWer:CLResponse:WGEN:VOLTage"</a> on page 781</li> <li>· <a href="#">":POWer:CLResponse:WGEN:VOLTage:PROFile"</a> on page 782</li> </ul>

## :POWer:CLResponse:SOURce:INPut

**N** (see [page 1666](#))

Command Syntax	<code>:POWer:CLResponse:SOURce:INPut &lt;source&gt;</code> <code>&lt;source&gt; ::= CHANnel&lt;n&gt;</code> <code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	The :POWer:CLResponse:SOURce:INPut command selects the oscilloscope channel that is probing the power supply input.
Query Syntax	<code>:POWer:CLResponse:SOURce:INPut?</code>
	The :POWer:CLResponse:SOURce:INPut? query returns the channel selection.
Return Format	<code>&lt;source&gt;&lt;NL&gt;</code> <code>&lt;source&gt; ::= CHAN&lt;n&gt;</code>
See Also	<ul style="list-style-type: none"> <li>· <a href="#">":POWer:CLResponse"</a> on page 765</li> <li>· <a href="#">":POWer:CLResponse:APPLy"</a> on page 766</li> <li>· <a href="#">":POWer:CLResponse:DATA"</a> on page 767</li> <li>· <a href="#">":POWer:CLResponse:FREQuency:MODE"</a> on page 772</li> <li>· <a href="#">":POWer:CLResponse:FREQuency:STARt"</a> on page 774</li> <li>· <a href="#">":POWer:CLResponse:FREQuency:STOP"</a> on page 775</li> <li>· <a href="#">":POWer:CLResponse:PPDecade"</a> on page 776</li> <li>· <a href="#">":POWer:CLResponse:SOURce:OUTPut"</a> on page 778</li> <li>· <a href="#">":POWer:CLResponse:WGEN:LOAD"</a> on page 780</li> <li>· <a href="#">":POWer:CLResponse:WGEN:VOLTage"</a> on page 781</li> <li>· <a href="#">":POWer:CLResponse:WGEN:VOLTage:PROFile"</a> on page 782</li> </ul>

## :POWer:CLResponse:SOURce:OUTPut

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWer:CLResponse:SOURce:OUTPut &lt;source&gt;</code> <code>&lt;source&gt; ::= CHANnel&lt;n&gt;</code> <code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	The :POWer:CLResponse:SOURce:OUTPut command selects the oscilloscope channel that is probing the power supply output.
<b>Query Syntax</b>	<code>:POWer:CLResponse:SOURce:OUTPut?</code>
	The :POWer:CLResponse:SOURce:OUTPut? query returns the channel selection.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code> <code>&lt;source&gt; ::= CHAN&lt;n&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":POWer:CLResponse"</a> on page 765</li> <li>· <a href="#">":POWer:CLResponse:APPLy"</a> on page 766</li> <li>· <a href="#">":POWer:CLResponse:DATA"</a> on page 767</li> <li>· <a href="#">":POWer:CLResponse:FREQuency:MODE"</a> on page 772</li> <li>· <a href="#">":POWer:CLResponse:FREQuency:START"</a> on page 774</li> <li>· <a href="#">":POWer:CLResponse:FREQuency:STOP"</a> on page 775</li> <li>· <a href="#">":POWer:CLResponse:PPDecade"</a> on page 776</li> <li>· <a href="#">":POWer:CLResponse:SOURce:INPut"</a> on page 777</li> <li>· <a href="#">":POWer:CLResponse:WGEN:LOAD"</a> on page 780</li> <li>· <a href="#">":POWer:CLResponse:WGEN:VOLTage"</a> on page 781</li> <li>· <a href="#">":POWer:CLResponse:WGEN:VOLTage:PROFile"</a> on page 782</li> </ul>

## :POWer:CLResponse:TRACe

**N** (see [page 1666](#))

**Command Syntax** :POWer:CLResponse:TRACe <selection>

<selection> ::= {NONE | ALL | GAIN | PHASE} [, {GAIN | PHASE}]

The :POWer:CLResponse:TRACe command specifies whether to include gain, phase, both gain and phase, or neither in the control loop response analysis results.

### NOTE

This command affects the oscilloscope's front panel graphical user interface (plot and table) as well as when saving analysis data.

**Query Syntax** :POWer:CLResponse:TRACe?

The :POWer:CLResponse:TRACe? query returns a comma-separated list of the types of data that are currently included in the control loop response analysis results, or "NONE" if neither gain nor phase data is included.

**Return Format** <selection\_list><NL>

<selection\_list> ::= { "NONE" | "GAIN" | "PHASE" | "GAIN, PHASE" }

**See Also**

- [":POWer:CLResponse:APPLy" on page 766](#)
- [":POWer:CLResponse:DATA" on page 767](#)

## :POWER:CLResponse:WGEN:LOAD

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWER:CLResponse:WGEN:LOAD &lt;impedance&gt;</code> <code>&lt;impedance&gt; ::= {ONEMeg   FIFTy}</code>
	The :POWER:CLResponse:WGEN:LOAD command sets the waveform generator expected output load impedance.
	The output impedance of the Gen Out signal is fixed at 50 ohms. However, the output load selection lets the waveform generator display the correct amplitude and offset levels for the expected output load. If the actual load impedance is different than the selected value, the displayed amplitude and offset levels will be incorrect.
<b>Query Syntax</b>	<code>:POWER:CLResponse:WGEN:LOAD?</code>
	The :POWER:CLResponse:WGEN:LOAD? query returns the waveform generator expected output load impedance setting.
<b>Return Format</b>	<code>&lt;impedance&gt;&lt;NL&gt;</code> <code>&lt;impedance&gt; ::= {ONEM   FIFT}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":POWER:CLResponse"</a> on page 765</li> <li>· <a href="#">":POWER:CLResponse:APPLy"</a> on page 766</li> <li>· <a href="#">":POWER:CLResponse:DATA"</a> on page 767</li> <li>· <a href="#">":POWER:CLResponse:FREQuency:MODE"</a> on page 772</li> <li>· <a href="#">":POWER:CLResponse:FREQuency:STARt"</a> on page 774</li> <li>· <a href="#">":POWER:CLResponse:FREQuency:STOP"</a> on page 775</li> <li>· <a href="#">":POWER:CLResponse:PPDecade"</a> on page 776</li> <li>· <a href="#">":POWER:CLResponse:SOURce:INPut"</a> on page 777</li> <li>· <a href="#">":POWER:CLResponse:SOURce:OUTPut"</a> on page 778</li> <li>· <a href="#">":POWER:CLResponse:WGEN:VOLTage"</a> on page 781</li> <li>· <a href="#">":POWER:CLResponse:WGEN:VOLTage:PROFile"</a> on page 782</li> </ul>

## :POWER:CLResponse:WGEN:VOLTage

**N** (see [page 1666](#))

### Command Syntax

```
:POWER:CLResponse:WGEN:VOLTage <amplitude>[,<range>]
<amplitude> ::= amplitude in volts in NR3 format
<range> ::= {F20HZ | F100HZ | F1KHZ | F10KHZ | F100KHZ | F1MHZ
| F10MHZ | F20MHZ}
```

The :POWER:CLResponse:WGEN:VOLTage command sets the waveform generator output amplitude(s).

When the waveform generator amplitude profile is enabled (with the :POWER:CLResponse:WGEN:VOLTage:PROFile command), you can set an initial ramp amplitude for each frequency range.

Without the <range> parameter, this command sets the waveform generator output amplitude used when the amplitude profile is disabled.

### Query Syntax

```
:POWER:PSRR:WGEN:VOLTage? [<range>]
```

The :POWER:CLResponse:WGEN:VOLTage? query returns the waveform generator output amplitude setting(s).

### Return Format

```
<amplitude><NL>
<amplitude> ::= amplitude in volts in NR3 format
```

### See Also

- [":POWER:CLResponse"](#) on page 765
- [":POWER:CLResponse:APPLy"](#) on page 766
- [":POWER:CLResponse:DATA"](#) on page 767
- [":POWER:CLResponse:FREQuency:MODE"](#) on page 772
- [":POWER:CLResponse:FREQuency:START"](#) on page 774
- [":POWER:CLResponse:FREQuency:STOP"](#) on page 775
- [":POWER:CLResponse:PPDecade"](#) on page 776
- [":POWER:CLResponse:SOURce:INPUT"](#) on page 777
- [":POWER:CLResponse:SOURce:OUTPut"](#) on page 778
- [":POWER:CLResponse:WGEN:LOAD"](#) on page 780
- [":POWER:CLResponse:WGEN:VOLTage:PROFile"](#) on page 782

## :POWER:CLResponse:WGEN:VOLTage:PROFile

**N** (see [page 1666](#))

### Command Syntax

`:POWER:CLResponse:WGEN:VOLTage:PROFile {{0 | OFF} | {1 | ON}}`

The :POWER:CLResponse:WGEN:VOLTage:PROFile command enables or disables the ability to set initial waveform generator ramp amplitudes for each frequency range.

With amplitude profiling, you can use lower amplitudes at frequencies where the device under test (DUT) is sensitive to distortion and use higher amplitudes where the DUT is less sensitive to distortion. Power supply feedback networks are typically most sensitive near the 0 dB cross-over frequency.

You can often observe distortions during the test. If the input test sine wave begins to look lopsided, clipped, or somewhat triangular in shape (nonsinusoidal), you are probably encountering distortion due to overdriving your DUT. Optimizing test amplitudes to achieve the best dynamic range measurements is often an iterative process of running your frequency response measurements multiple times.

### Query Syntax

`:POWER:CLResponse:WGEN:VOLTage:PROFile?`

The :POWER:CLResponse:WGEN:VOLTage:PROFile? query returns the voltage profile setting.

### Return Format

```
<setting><NL>
<setting> ::= {0 | 1}
```

### See Also

- [":POWER:CLResponse"](#) on page 765
- [":POWER:CLResponse:APPLy"](#) on page 766
- [":POWER:CLResponse:DATA"](#) on page 767
- [":POWER:CLResponse:FREQuency:MODE"](#) on page 772
- [":POWER:CLResponse:FREQuency:STARt"](#) on page 774
- [":POWER:CLResponse:FREQuency:STOP"](#) on page 775
- [":POWER:CLResponse:PPDecade"](#) on page 776
- [":POWER:CLResponse:SOURce:INPut"](#) on page 777
- [":POWER:CLResponse:SOURce:OUTPut"](#) on page 778
- [":POWER:CLResponse:WGEN:LOAD"](#) on page 780
- [":POWER:CLResponse:WGEN:VOLTage"](#) on page 781

## :POWer:DESKew

**N** (see [page 1666](#))

### Command Syntax

`:POWer:DESKew`

The :POWer:DESKew command launches the auto deskew process on the oscilloscope.

Before sending this command:

- 1 Demagnetize and zero-adjust the current probe.  
Refer to the current probe's documentation for instructions on how to do this.
- 2 Make connections to the U1880A deskew fixture as described in the oscilloscope's connection dialog or in the *Power Measurement Application User's Guide*.
- 3 Make sure the voltage probe and current probe channels are specified appropriately using the :POWer:SIGNals:SOURce:VOLTage1 and :POWer:SIGNals:SOURce:CURRent1 commands.

### NOTE

Use the lowest attenuation setting on the high voltage differential probes whenever possible because the voltage levels on the deskew fixture are very small. Using a higher attenuation setting may yield inaccurate skew values (and affect the measurements made) because the noise level is magnified as well.

The deskew values are saved in the oscilloscope until a factory default or secure erase is performed. The next time you run the Power Application, you can use the saved deskew values or perform the deskew again.

Generally, you need to perform the deskew again when part of the test setup changes (for example, a different probe, different oscilloscope channel, etc.) or when the ambient temperature has changed.

### See Also

- "[":POWer:SIGNals:SOURce:VOLTage<i>](#)" on page 846
- "[":POWer:SIGNals:SOURce:CURRent<i>](#)" on page 845

## :POWer:EFFiciency:APPLy

**N** (see [page 1666](#))

**Command Syntax** :POWer:EFFiciency:APPLy

The :POWer:EFFiciency:APPLy command applies the efficiency power analysis.

Efficiency analysis tests the overall efficiency of the power supply by measuring the output power over the input power.

**NOTE**

Efficiency analysis requires a 4-channel oscilloscope because input voltage, input current, output voltage, and output current are measured.

**See Also**

- "[:POWer:EFFiciency:TYPE](#)" on page 785
- "[:MEASure:EFFiciency](#)" on page 702
- "[:MEASure:IPOWer](#)" on page 705
- "[:MEASure:OPOWer](#)" on page 708

## :POWer:EFFiciency:TYPE

**N** (see [page 1666](#))

**Command Syntax**    `:POWer:EFFiciency:TYPE <type>`  
`<type> ::= {DCDC | DCAC | ACDC | ACAC}`

The :POWer:EFFiciency:TYPE command specifies the type of power that is being converted from the input to the output. This selection affects how the efficiency is measured.

**Query Syntax**    `:POWer:EFFiciency:TYPE?`

The :POWer:EFFiciency:TYPE? query returns the currently specified type setting.

**Return Format**    `<type><NL>`  
`<type> ::= {DCDC | DCAC | ACDC | ACAC}`

**See Also**

- [":POWer:EFFiciency:APPLy" on page 784](#)
- [":MEASure:EFFiciency" on page 702](#)
- [":MEASure:IPOWer" on page 705](#)
- [":MEASure:OPOWer" on page 708](#)

## :POWer:ENABLE

**N** (see [page 1666](#))

**Command Syntax** `:POWer:ENABLE {{0 | OFF} | {1 | ON}}`

The :POWer:ENABLE command enables or disables power analysis.

**Query Syntax** `:POWer:ENABLE?`

The :POWer:ENABLE query returns a 1 or a 0 showing whether power analysis is enabled or disabled, respectively.

**Return Format** `{0 | 1}`

**See Also** • [Chapter 27](#), “:MEASure Power Commands,” starting on page 693

## :POWer:HARMonics:APPLy

**N** (see [page 1666](#))

### Command Syntax

`:POWer:HARMonics:APPLy`

The :POWer:HARMonics:APPLy command applies the current harmonics analysis.

Switching power supplies draw a range of harmonics from the AC mains.

Standard limits are set for these harmonics because these harmonics can travel back to the supply grid and cause problems with other devices on the grid.

Use the Current Harmonics analysis to test a switching power supply's current harmonics to pre-compliance standard of IEC61000-3-2 (Class A, B, C, or D). The analysis presents up to 40 harmonics.

### See Also

- [":POWer:HARMonics:DATA"](#) on page 788
- [":POWer:HARMonics:DISPlay"](#) on page 789
- [":POWer:HARMonics:FAILcount"](#) on page 790
- [":POWer:HARMonics:LINE"](#) on page 791
- [":POWer:HARMonics:POWERfactor"](#) on page 792
- [":POWer:HARMonics:STANDARD"](#) on page 796
- [":POWer:HARMonics:STATUS"](#) on page 797
- [":POWer:HARMonics:RUNCount"](#) on page 795
- [":POWer:HARMonics:THD"](#) on page 798

## :POWER:HARMonics:DATA

**N** (see [page 1666](#))

**Query Syntax** `:POWER:HARMonics:DATA?`

The `:POWER:HARMonics:DATA` query returns the power harmonics results table data.

**Return Format** `<binary_block>` ::= comma-separated data with newlines at the end of each row

- See Also**
- [":POWER:HARMonics:APPLy"](#) on page 787
  - [":POWER:HARMonics:DISPlay"](#) on page 789
  - [":POWER:HARMonics:FAILcount"](#) on page 790
  - [":POWER:HARMonics:LINE"](#) on page 791
  - [":POWER:HARMonics:POWERfactor"](#) on page 792
  - [":POWER:HARMonics:RUNCount"](#) on page 795
  - [":POWER:HARMonics:STANDARD"](#) on page 796
  - [":POWER:HARMonics:STATUS"](#) on page 797
  - [":POWER:HARMonics:THD"](#) on page 798

## :POWer:HARMonics:DISPlay

**N** (see [page 1666](#))

**Command Syntax** :POWer:HARMonics:DISPlay <display>

<display> ::= {TABLe | BAR | OFF}

The :POWer:HARMonics:DISPlay command specifies how to display the current harmonics analysis results:

- TABLe
- BAR – Bar chart.
- OFF – Harmonics measurement results are not displayed.

**Query Syntax** :POWer:HARMonics:DISPlay?

The :POWer:HARMonics:DISPlay query returns the display setting.

**Return Format** <display><NL>

<display> ::= {TABL | BAR | OFF}

- See Also**
- "[:POWer:HARMonics:APPLy](#)" on page 787
  - "[:POWer:HARMonics:DATA](#)" on page 788
  - "[:POWer:HARMonics:FAILcount](#)" on page 790
  - "[:POWer:HARMonics:LINE](#)" on page 791
  - "[:POWer:HARMonics:POWERfactor](#)" on page 792
  - "[:POWer:HARMonics:RUNCount](#)" on page 795
  - "[:POWer:HARMonics:STANDARD](#)" on page 796
  - "[:POWer:HARMonics:STATUS](#)" on page 797
  - "[:POWer:HARMonics:THD](#)" on page 798

## :POWer:HARMonics:FAILcount

**N** (see [page 1666](#))

**Query Syntax** `:POWer:HARMonics:FAILcount?`

Returns the current harmonics analysis' fail count. Non Spec values (that is, harmonics values not specified by the selected standard) are not counted.

**Return Format** `<count><NL>`

`<count>` ::= integer in NR1 format

- See Also**
- "[:POWer:HARMonics:RUNCount](#)" on page 795
  - "[:POWer:HARMonics:APPLy](#)" on page 787
  - "[:POWer:HARMonics:DATA](#)" on page 788
  - "[:POWer:HARMonics:DISPlay](#)" on page 789
  - "[:POWer:HARMonics:LINE](#)" on page 791
  - "[:POWer:HARMonics:POWERfactor](#)" on page 792
  - "[:POWer:HARMonics:STANDARD](#)" on page 796
  - "[:POWer:HARMonics:STATUS](#)" on page 797
  - "[:POWer:HARMonics:THD](#)" on page 798

## :POWer:HARMonics:LINE

**N** (see [page 1666](#))

**Command Syntax**    `:POWer:HARMonics:LINE <frequency>`  
`<frequency> ::= {F50 | F60 | F400 | AUTO}`

The :POWer:HARMonics:LINE command specifies the line frequency setting for the current harmonics analysis:

- F50 – 50 Hz.
- F60 – 60 Hz.
- F400 – 400 Hz.
- AUTO – Automatically determines the frequency of the Current waveform.

**Query Syntax**    `:POWer:HARMonics:LINE?`

The :POWer:HARMonics:LINE query returns the line frequency setting.

**Return Format**    `<frequency><NL>`  
`<frequency> ::= {F50 | F60 | F400 | AUTO}`

**See Also**    [":POWer:HARMonics:APPLy"](#) on page 787  
[":POWer:HARMonics:DATA"](#) on page 788  
[":POWer:HARMonics:DISPLAY"](#) on page 789  
[":POWer:HARMonics:FAILcount"](#) on page 790  
[":POWer:HARMonics:POWERfactor"](#) on page 792  
[":POWer:HARMonics:RUNCount"](#) on page 795  
[":POWer:HARMonics:STANDARD"](#) on page 796  
[":POWer:HARMonics:STATUs"](#) on page 797  
[":POWer:HARMonics:THD"](#) on page 798

## :POWER:HARMonics:POWerfactor

**N** (see [page 1666](#))

**Query Syntax** `:POWER:HARMonics:POWerfactor?`

The :POWER:HARMonics:POWerfactor query returns the power factor for IEC 61000-3-2 Standard Class C power factor value.

**Return Format** `<value> ::= Class C power factor in NR3 format`

**See Also**

- "[:POWER:HARMonics:APPLy](#)" on page 787
- "[:POWER:HARMonics:DATA](#)" on page 788
- "[:POWER:HARMonics:DISPlay](#)" on page 789
- "[:POWER:HARMonics:FAILcount](#)" on page 790
- "[:POWER:HARMonics:LINE](#)" on page 791
- "[:POWER:HARMonics:RUNCount](#)" on page 795
- "[:POWER:HARMonics:STANDARD](#)" on page 796
- "[:POWER:HARMonics:STATUS](#)" on page 797
- "[:POWER:HARMonics:THD](#)" on page 798

## :POWer:HARMonics:RPOWer

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWer:HARMonics:RPOWer &lt;source&gt;</code> <code>&lt;source&gt; ::= {MEASured   USER}</code>
	When Class D is selected as the current harmonics analysis standard, the :POWer:HARMonics:RPOWer command specifies whether the Real Power value used for the current-per-watt measurement is measured by the oscilloscope or is defined by the user.
	When USER is selected, use the :POWer:HARMonics:RPOWer:USER command to enter the user-defined value.
<b>Query Syntax</b>	<code>:POWer:HARMonics:RPOWer?</code>
	The :POWer:HARMonics:RPOWer? query returns the Real Power source setting.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code> <code>&lt;source&gt; ::= {MEAS   USER}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">:POWer:HARMonics:STANDARD</a>" on page 796</li> <li>• "<a href="#">:POWer:HARMonics:RPOWer:USER</a>" on page 794</li> </ul>

## :POWer:HARMonics:RPOWer:USER

**N** (see [page 1666](#))

**Command Syntax**    `:POWer:HARMonics:RPOWer:USER <value>`

`<value> ::= Watts from 1.0 to 600.0 in NR3 format`

When Class D is selected as the current harmonics analysis standard and you have chosen to use a user-defined Real Power value (see :POWer:HARMonics:RPOWer), the :POWer:HARMonics:RPOWer:USER command specifies the Real Power value used in the current-per-watt measurement.

**Query Syntax**    `:POWer:HARMonics:RPOWer:USER?`

The :POWer:HARMonics:RPOWer:USER? query returns the user-defined Real Power value.

**Return Format**    `<value><NL>`

`<value> ::= Watts from 1.0 to 600.0 in NR3 format`

**See Also**

- [":POWer:HARMonics:STANDARD"](#) on page 796
- [":POWer:HARMonics:RPOWer"](#) on page 793

## :POWer:HARMonics:RUNCount

**N** (see [page 1666](#))

**Query Syntax** `:POWer:HARMonics:RUNCount?`

Returns the current harmonics analysis' run iteration count. Non Spec values (that is, harmonics values not specified by the selected standard) are not counted.

**Return Format** `<count><NL>`

`<count>` ::= integer in NR1 format

- See Also**
- "[:POWer:HARMonics:FAILcount](#)" on page 790
  - "[:POWer:HARMonics:APPLy](#)" on page 787
  - "[:POWer:HARMonics:DATA](#)" on page 788
  - "[:POWer:HARMonics:DISPlay](#)" on page 789
  - "[:POWer:HARMonics:LINE](#)" on page 791
  - "[:POWer:HARMonics:POWERfactor](#)" on page 792
  - "[:POWer:HARMonics:STANDARD](#)" on page 796
  - "[:POWer:HARMonics:STATUS](#)" on page 797
  - "[:POWer:HARMonics:THD](#)" on page 798

## :POWER:HARMonics:STANDARD

**N** (see [page 1666](#))

**Command Syntax**    `:POWER:HARMonics:STANDARD <class>`  
`<class> ::= {A | B | C | D}`

The :POWER:HARMonics:STANDARD command selects the standard to perform current harmonics compliance testing on.

- A – IEC 61000-3-2 Class A – for balanced three-phase equipment, household appliances (except equipment identified as Class D), tools excluding portable tools, dimmers for incandescent lamps, and audio equipment.
- B – IEC 61000-3-2 Class B – for portable tools.
- C – IEC 61000-3-2 Class C – for lighting equipment.
- D – IEC 61000-3-2 Class D – for equipment having a specified power according less than or equal to 600 W, of the following types: personal computers and personal computer monitors, television receivers.

**Query Syntax**    `:POWER:HARMonics:STANDARD?`

The :POWER:HARMonics:STANDARD query returns the currently set IEC 61000-3-2 standard.

**Return Format**    `<class><NL>`  
`<class> ::= {A | B | C | D}`

**See Also**    [":POWER:HARMonics:APPLy"](#) on page 787  
[":POWER:HARMonics:DATA"](#) on page 788  
[":POWER:HARMonics:DISPLAY"](#) on page 789  
[":POWER:HARMonics:FAILcount"](#) on page 790  
[":POWER:HARMonics:LINE"](#) on page 791  
[":POWER:HARMonics:POWERfactor"](#) on page 792  
[":POWER:HARMonics:RUNCount"](#) on page 795  
[":POWER:HARMonics:STATUs"](#) on page 797  
[":POWER:HARMonics:THD"](#) on page 798

## :POWer:HARMonics:STATUs

**N** (see [page 1666](#))

**Query Syntax** `:POWer:HARMonics:STATUs?`

The `:POWer:HARMonics:STATUs` query returns the overall pass/fail status of the current harmonics analysis.

**Return Format** `<status> ::= {PASS | FAIL | UNTested}`

**See Also**

- [":POWer:HARMonics:RUNCount"](#) on page 795
- [":POWer:HARMonics:FAILcount"](#) on page 790
- [":POWer:HARMonics:APPLy"](#) on page 787
- [":POWer:HARMonics:DATA"](#) on page 788
- [":POWer:HARMonics:DISPlay"](#) on page 789
- [":POWer:HARMonics:LINE"](#) on page 791
- [":POWer:HARMonics:POWERfactor"](#) on page 792
- [":POWer:HARMonics:STANDARD"](#) on page 796
- [":POWer:HARMonics:THD"](#) on page 798

## :POWer:HARMonics:THD

**N** (see [page 1666](#))

**Query Syntax** `:POWer:HARMonics:THD?`

The `:POWer:HARMonics:THD` query returns the Total Harmonics Distortion (THD) results of the current harmonics analysis.

**Return Format** `<value> ::= Total Harmonics Distortion in NR3 format`

**See Also**

- "[:POWer:HARMonics:APPLy](#)" on page 787
- "[:POWer:HARMonics:DATA](#)" on page 788
- "[:POWer:HARMonics:DISPlay](#)" on page 789
- "[:POWer:HARMonics:FAILcount](#)" on page 790
- "[:POWer:HARMonics:LINE](#)" on page 791
- "[:POWer:HARMonics:POWERfactor](#)" on page 792
- "[:POWer:HARMonics:RUNCount](#)" on page 795
- "[:POWer:HARMonics:STANDARD](#)" on page 796
- "[:POWer:HARMonics:STATus](#)" on page 797

## :POWer:INRush:APPLy

**N** (see [page 1666](#))

**Command Syntax** :POWer:INRush:APPLy

The :POWer:INRush:APPLy command applies the inrush current analysis.

The Inrush current analysis measures the peak inrush current of the power supply when the power supply is first turned on.

- See Also**
- [":POWer:ITYPe"](#) on page 802
  - [":POWer:INRush:EXIT"](#) on page 800
  - [":POWer:INRush:NEXT"](#) on page 801
  - [":MEASure:PCURrent"](#) on page 709

## :POWer:INRush:EXIT

**N** (see [page 1666](#))

**Command Syntax** :POWer:INRush:EXIT

The :POWer:INRush:EXIT command exits (stops) the inrush current power analysis.

This command is equivalent to pressing the **Exit** softkey on the oscilloscope front panel during the analysis.

**See Also**

- "[:POWer:INRush:APPLy](#)" on page 799
- "[:POWer:INRush:NEXT](#)" on page 801
- "[:POWer:ITYPe](#)" on page 802

## :POWer:INRush:NEXT

**N** (see [page 1666](#))

**Command Syntax** :POWer:INRush:NEXT

The :POWer:INRush:NEXT command goes to the next step of the inrush current analysis.

This command is equivalent to pressing the **Next** softkey on the oscilloscope front panel when prompted during the analysis.

**See Also**

- "[":POWer:INRush:APPLy](#)" on page 799
- "[":POWer:INRush:EXIT](#)" on page 800
- "[":POWer:ITYPE](#)" on page 802

## :POWer:ITYPE

**N** (see [page 1666](#))

**Command Syntax**    `:POWer:ITYPE <type>`  
                  `<type> ::= {DC | AC}`

The :POWer:ITYPE command specifies the type of power that is being converted from the input (DC or AC). Your selection affects how the measurements are made.

This setting is used in the Inrush Current and Turn On/Turn Off tests.

**Query Syntax**    `:POWer:ITYPE?`

The :POWer:ITYPE? query returns the input power type setting.

**Return Format**    `<type><NL>`  
                  `<type> ::= {DC | AC}`

**See Also**

- [":POWer:INRush:APPLy" on page 799](#)
- [":POWer:ONOFF:APPLy" on page 806](#)

## :POWer:MODulation:APPLy

**N** (see [page 1666](#))

### Command Syntax

`:POWer:MODulation:APPLy`

The :POWer:MODulation:APPLy command applies the selected modulation analysis type (:POWer:MODulation:TYPE).

The Modulation analysis measures the control pulse signal to a switching device (MOSFET) and observes the trending of the pulse width, duty cycle, period, frequency, etc. of the control pulse signal.

### See Also

- [":POWer:MODulation:SOURce"](#) on page 804
- [":POWer:MODulation:TYPE"](#) on page 805
- [":MEASure:VAVerage"](#) on page 681
- [":MEASure:VRMS"](#) on page 687
- [":MEASure:VRATIO"](#) on page 686
- [":MEASure:PERiod"](#) on page 655
- [":MEASure:FREQuency"](#) on page 647
- [":MEASure:PWIDTH"](#) on page 659
- [":MEASure:NWIDTH"](#) on page 651
- [":MEASure:DUTYcycle"](#) on page 641
- [":MEASure:RISetime"](#) on page 663
- [":MEASure:FALLtime"](#) on page 642

## :POWer:MODulation:SOURce

**N** (see [page 1666](#))

**Command Syntax**    `:POWer:MODulation:SOURce <source>`  
                      `<source> ::= {V | I}`

The :POWer:MODulation:SOURce command selects either the voltage source or the current source as the source for the modulation analysis.

**Query Syntax**    `:POWer:MODulation:SOURce?`

The :POWer:MODulation:SOURce query returns the selected source for the modulation analysis.

**Return Format**    `<source><NL>`  
                      `<source> ::= {V | I}`

**See Also**

- [":POWer:MODulation:APPLy" on page 803](#)
- [":POWer:MODulation:TYPE" on page 805](#)

## :POWer:MODulation:TYPE

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWer:MODulation:TYPE &lt;modulation&gt;</code>
	<code>&lt;modulation&gt; ::= {VAVerage   ACRMs   VRATio   PERiod   FREQuency   PWIDth   NWIDth   DUTYcycle   RISetime   FALLtime}</code>

The :POWer:MODulation:TYPE command selects the type of measurement to make in the modulation analysis:

- VAVerage
- ACRMs
- VRATio
- PERiod
- FREQuency
- PWIDth (positive pulse width)
- NWIDth (negative pulse width)
- DUTYcycle
- RISetime
- FALLtime

<b>Query Syntax</b>	<code>:POWer:MODulation:TYPE?</code>
---------------------	--------------------------------------

The :POWer:MODulation:TYPE query returns the modulation type setting.

<b>Return Format</b>	<code>&lt;modulation&gt;&lt;NL&gt;</code>
	<code>&lt;modulation&gt; ::= {VAV   ACRM   VRAT   PER   FREQ   PWID   NWID   DUTY   RIS   FALL}</code>

<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">:POWer:MODulation:SOURce</a>" on page 804</li> <li>• "<a href="#">:POWer:MODulation:APPLy</a>" on page 803</li> <li>• "<a href="#">:MEASure:VAVerage</a>" on page 681</li> <li>• "<a href="#">:MEASure:VRMS</a>" on page 687</li> <li>• "<a href="#">:MEASure:VRATIO</a>" on page 686</li> <li>• "<a href="#">:MEASure:PERiod</a>" on page 655</li> <li>• "<a href="#">:MEASure:FREQuency</a>" on page 647</li> <li>• "<a href="#">:MEASure:PWIDth</a>" on page 659</li> <li>• "<a href="#">:MEASure:NWIDth</a>" on page 651</li> <li>• "<a href="#">:MEASure:DUTYcycle</a>" on page 641</li> <li>• "<a href="#">:MEASure:RISetime</a>" on page 663</li> <li>• "<a href="#">:MEASure:FALLtime</a>" on page 642</li> </ul>
-----------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

## :POWER:ONOOff:APPLy

**N** (see [page 1666](#))

**Command Syntax** :POWER:ONOOff:APPLy

The :POWER:ONOOff:APPLy command applies the selected turn on/off analysis test (:POWER:ONOOff:TEST).

- See Also**
- "[:POWER:SIGNals:VSteady:ONOOff:OFF](#)" on page 842
  - "[:POWER:SIGNals:VSteady:ONOOff:ON](#)" on page 843
  - "[:POWER:ITYPe](#)" on page 802
  - "[:POWER:ONOOff:THResholds](#)" on page 810
  - "[:POWER:ONOOff:TEST](#)" on page 809
  - "[:POWER:ONOOff:EXIT](#)" on page 807
  - "[:POWER:ONOOff:NEXT](#)" on page 808
  - "[:MEASure:ONTIme](#)" on page 707
  - "[:MEASure:OFFTime](#)" on page 706

## :POWer:ONOOff:EXIT

**N** (see [page 1666](#))

**Command Syntax** :POWer:ONOOff:EXIT

The :POWer:ONOOff:EXIT command exits (stops) the turn on time/turn off time analysis.

This command is equivalent to pressing the **Exit** softkey on the oscilloscope front panel during the analysis.

- See Also**
- "[:POWer:ONOOff:THResholds](#)" on page 810
  - "[:POWer:ITYPe](#)" on page 802
  - "[:POWer:ONOOff:APPLy](#)" on page 806
  - "[:POWer:ONOOff:NEXT](#)" on page 808
  - "[:POWer:ONOOff:TEST](#)" on page 809

## :POWer:ONOOff:NEXT

**N** (see [page 1666](#))

**Command Syntax** :POWer:ONOOff:NEXT

The :POWer:ONOOff:NEXT command goes to the next step of the turn on/turn off analysis.

This command is equivalent to pressing the **Next** softkey on the oscilloscope front panel when prompted during the analysis.

- See Also**
- "[:POWer:ONOOff:THResholds](#)" on page 810
  - "[:POWer:ITYPe](#)" on page 802
  - "[:POWer:ONOOff:APPLy](#)" on page 806
  - "[:POWer:ONOOff:EXIT](#)" on page 807
  - "[:POWer:ONOOff:TEST](#)" on page 809

## :POWer:ONOOff:TEST

**N** (see [page 1666](#))

**Command Syntax** :POWer:ONOOff:TEST {{0 | OFF} | {1 | ON}}

The :POWer:ONOOff:TEST command selects whether turn on or turn off analysis is performed:

- ON – Turn On – measures the time taken to get the output voltage of the power supply after the input voltage is applied.
- OFF – Turn Off – measures the time taken for the output voltage of the power supply to turn off after the input voltage is removed.

**Query Syntax** :POWer:ONOOff:TEST?

The :POWer:ONOOff:TEST query returns the selected test type.

**Return Format** {0 | 1}

**See Also**

- "[:POWer:ONOOff:THResholds](#)" on page 810
- "[:POWer:ITYPe](#)" on page 802
- "[:POWer:ONOOff:APPLy](#)" on page 806
- "[:POWer:ONOOff:EXIT](#)" on page 807
- "[:POWer:ONOOff:NEXT](#)" on page 808

## :POWER:ONOFF:THRESHOLDS

**N** (see [page 1666](#))

**Command Syntax**

```
:POWER:ONOFF:THRESHOLDS <type>,<input_thr>,<output_thr>
<type> ::= {ON | OFF}
<input_thr> ::= percent from 0-100 in NR1 format
<output_thr> ::= percent from 0-100 in NR1 format
```

The :POWER:ONOFF:THRESHOLDS command specifies the input and output thresholds used in the Turn On/Turn Off analysis.

Turn On analysis determines how fast a turned on power supply takes to reach some percent of its steady state output. Turn on time is the time between T2 and T1 where:

- T1 = when the input voltage first rises to some percent (typically the 10% threshold) of its maximum amplitude.
- T2 = when the output DC voltage rises to some percent (typically the 90% threshold) of its maximum amplitude.

Turn Off analysis determines how fast a turned off power supply takes to reduce its output voltage to some percent of maximum. Turn off time is the time between T2 and T1 where:

- T1 = when the input voltage last falls to some percent (typically the 10% threshold) of its maximum amplitude.
- T2 = when the output DC voltage last falls to some percent (typically the 10% threshold) of its maximum amplitude.

**Query Syntax**

```
:POWER:ONOFF:THRESHOLDS? <type>
```

The :POWER:ONOFF:THRESHOLDS? query returns the input and output threshold settings for the turn on/turn off analysis type.

**Return Format**

```
<input_thr>,<output_thr><NL>
<input_thr> ::= percent from 0-100 in NR1 format
<output_thr> ::= percent from 0-100 in NR1 format
```

**See Also**

- "[:POWER:SIGNALS:VSTEADY:ONOFF:OFF](#)" on page 842
- "[:POWER:SIGNALS:VSTEADY:ONOFF:ON](#)" on page 843
- "[:POWER:ITYPE](#)" on page 802
- "[:POWER:ONOFF:APPLY](#)" on page 806
- "[:POWER:ONOFF:TEST](#)" on page 809
- "[:POWER:ONOFF:EXIT](#)" on page 807
- "[:POWER:ONOFF:NEXT](#)" on page 808

- [":MEASure:ONTIme"](#) on page 707
- [":MEASure:OFFTime"](#) on page 706

## :POWer:PSRR

**N** (see [page 1666](#))

**Query Syntax** `:POWer:PSRR?`

The `:POWer:PSRR?` query returns the Power Supply Rejection Ratio (PSRR) power analysis settings.

**Return Format** `<settings_string><NL>`

For example, the query returns the following string when issued after the `*RST` command.

```
:POW:PSRR:SOUR:INP CHAN1;OUTP CHAN2,:POW:PSRR:FREQ:STAR +100E+00;
STOP +20.000000E+06,:POW:PSRR:WGEN:VOLT +200.0E-03,LOAD FIFT
```

**See Also**

- [":POWer:PSRR:APPLy" on page 813](#)
- [":POWer:PSRR:DATA" on page 814](#)
- [":POWer:PSRR:FREQuency:MAXimum" on page 815](#)
- [":POWer:PSRR:FREQuency:MINimum" on page 816](#)
- [":POWer:PSRR:FREQuency:MODE" on page 817](#)
- [":POWer:PSRR:PPDecade" on page 819](#)
- [":POWer:PSRR:SOURce:INPut" on page 820](#)
- [":POWer:PSRR:SOURce:OUTPut" on page 821](#)
- [":POWer:PSRR:WGEN:LOAD" on page 823](#)
- [":POWer:PSRR:WGEN:VOLTage" on page 824](#)
- [":POWer:PSRR:WGEN:VOLTage:PROFile" on page 825](#)

## :POWer:PSRR:APPLy

**N** (see [page 1666](#))

### Command Syntax

`:POWer:PSRR:APPLy`

The :POWer:PSRR:APPLy command applies the power supply rejection ratio (PSRR) analysis.

The Power Supply Rejection Ratio (PSRR) test is used to determine how well a voltage regulator rejects ripple noise over different frequency range.

This analysis provides a signal from the oscilloscope's waveform generator that sweeps its frequency. This signal is used to inject ripple to the DC voltage that feeds the voltage regulator.

The AC RMS ratio of the input over the output is measured and is plotted over the range of frequencies.

It takes some time for the frequency sweep analysis to complete. You can query bit 0 of the Standard Event Status Register (\*ESR?) to find out when the analysis is complete.

You can use the :POWer:PSRR:TRACe command to specify whether to include gain data in the PSRR analysis results.

### See Also

- ["\\*ESR \(Standard Event Status Register\)" on page 236](#)
- [":POWer:PSRR" on page 812](#)
- [":POWer:PSRR:DATA" on page 814](#)
- [":POWer:PSRR:FREQuency:MAXimum" on page 815](#)
- [":POWer:PSRR:FREQuency:MINimum" on page 816](#)
- [":POWer:PSRR:FREQuency:MODE" on page 817](#)
- [":POWer:PSRR:FREQuency:SINGle" on page 818](#)
- [":POWer:PSRR:PPDecade" on page 819](#)
- [":POWer:PSRR:SOURce:INPUT" on page 820](#)
- [":POWer:PSRR:SOURce:OUTPUT" on page 821](#)
- [":POWer:PSRR:TRACe" on page 822](#)
- [":POWer:PSRR:WGEN:LOAD" on page 823](#)
- [":POWer:PSRR:WGEN:VOLTage" on page 824](#)
- [":POWer:PSRR:WGEN:VOLTage:PROFile" on page 825](#)

## :POWer:PSRR:DATA

**N** (see [page 1666](#))

**Query Syntax** `:POWer:PSRR:DATA? [SWEep | SINGLE]`

The :POWer:PSRR:DATA? query returns data from the Power Supply Rejection Ratio (PSRR) power analysis.

The comma-separated value format is suitable for spreadsheet analysis.

You can use the :POWer:PSRR:TRACe command to specify whether to include gain data in the PSRR analysis results.

The SWEep or SINGLE option specifies whether to get the data from a sweep or single-frequency analysis (see :POWer:PSRR:FREQuency:MODE). If this option is not specified, the data from the sweep analysis is returned by default.

**Return Format** `<binary_block><NL>`

```
<binary_block> ::= comma-separated data with newlines at the end of each
row
```

**See Also**

- "[":POWer:PSRR](#)" on page 812
- "[":POWer:PSRR:APPLy](#)" on page 813
- "[":POWer:PSRR:FREQuency:MAXimum](#)" on page 815
- "[":POWer:PSRR:FREQuency:MINimum](#)" on page 816
- "[":POWer:PSRR:FREQuency:MODE](#)" on page 817
- "[":POWer:PSRR:FREQuency:SINGle](#)" on page 818
- "[":POWer:PSRR:PPDecade](#)" on page 819
- "[":POWer:PSRR:SOURce:INPut](#)" on page 820
- "[":POWer:PSRR:SOURce:OUTPut](#)" on page 821
- "[":POWer:PSRR:TRACe](#)" on page 822
- "[":POWer:PSRR:WGEN:LOAD](#)" on page 823
- "[":POWer:PSRR:WGEN:VOLTage](#)" on page 824
- "[":POWer:PSRR:WGEN:VOLTage:PROFILE](#)" on page 825

## :POWer:PSRR:FREQuency:MAXimum

**N** (see [page 1666](#))

**Command Syntax**

```
:POWer:PSRR:FREQuency:MAXimum <value>[suffix]
<value> ::= {10 | 100 | 1000 | 10000 | 100000 | 1000000 | 10000000
              | 20000000}
[suffix] ::= {Hz | kHz | MHz}
```

The :POWer:PSRR:FREQuency:MAXimum command sets the end sweep frequency value. The PSRR measurement is displayed on a log scale, so you can select from decade values in addition to the maximum frequency of 20 MHz.

**Query Syntax**

```
:POWer:PSRR:FREQuency:MAXimum?
```

The :POWer:PSRR:FREQuency:MAXimum query returns the maximum sweep frequency setting.

**Return Format**

```
<value><NL>
<value> ::= {10 | 100 | 1000 | 10000 | 100000 | 1000000 | 10000000
              | 20000000}
```

**See Also**

- "[:POWer:PSRR](#)" on page 812
- "[:POWer:PSRR:APPLy](#)" on page 813
- "[:POWer:PSRR:DATA](#)" on page 814
- "[:POWer:PSRR:FREQuency:MINimum](#)" on page 816
- "[:POWer:PSRR:FREQuency:MODE](#)" on page 817
- "[:POWer:PSRR:PPDecade](#)" on page 819
- "[:POWer:PSRR:SOURce:INPut](#)" on page 820
- "[:POWer:PSRR:SOURce:OUTPut](#)" on page 821
- "[:POWer:PSRR:WGEN:LOAD](#)" on page 823
- "[:POWer:PSRR:WGEN:VOLTage](#)" on page 824
- "[:POWer:PSRR:WGEN:VOLTage:PROFile](#)" on page 825

## :POWer:PSRR:FREQuency:MINimum

**N** (see [page 1666](#))

**Command Syntax**

```
:POWer:PSRR:FREQuency:MINimum <value>[suffix]
<value> ::= {1 | 10 | 100 | 1000 | 10000 | 100000 | 1000000 | 10000000}
[suffix] ::= {Hz | kHz | MHz}
```

The :POWer:PSRR:FREQuency:MINimum command sets the start sweep frequency value. The measurement is displayed on a log scale, so you can select from decade values.

**Query Syntax**

```
:POWer:PSRR:FREQuency:MINimum?
```

The :POWer:PSRR:FREQuency:MINimum query returns the minimum sweep frequency setting.

**Return Format**

```
<value><NL>
<value> ::= {1 | 10 | 100 | 1000 | 10000 | 100000 | 1000000 | 10000000}
```

**See Also**

- [":POWer:PSRR"](#) on page 812
- [":POWer:PSRR:APPLy"](#) on page 813
- [":POWer:PSRR:DATA"](#) on page 814
- [":POWer:PSRR:FREQuency:MAXimum"](#) on page 815
- [":POWer:PSRR:FREQuency:MODE"](#) on page 817
- [":POWer:PSRR:PPDecade"](#) on page 819
- [":POWer:PSRR:SOURce:INPut"](#) on page 820
- [":POWer:PSRR:SOURce:OUTPut"](#) on page 821
- [":POWer:PSRR:WGEN:LOAD"](#) on page 823
- [":POWer:PSRR:WGEN:VOLTage"](#) on page 824
- [":POWer:PSRR:WGEN:VOLTage:PROFile"](#) on page 825

## :POWer:PSRR:FREQuency:MODE

**N** (see [page 1666](#))

**Command Syntax**

```
:POWer:PSRR:FREQuency:MODE <mode>
<mode> ::= {SWEep | SINGle}
```

The :POWer:PSRR:FREQuency:MODE command specifies whether the analysis should be performed by sweeping through a range of frequencies (SWEep) or at a single frequency (SINGle).

The SINGle mode is useful for evaluating amplitudes at a single frequency. After running the test at a single frequency, you can manually adjust (increase) the waveform generator's amplitude until you begin to observe distortion in the waveforms on the oscilloscope's display. You can then use that amplitude at all frequencies in SWEep mode, or you can evaluate amplitudes at other frequencies in order to determine an optimized amplitude profile (see :POWer:PSRR:WGEN:VOLTage:PROFile).

**Query Syntax**

```
:POWer:CLResponse:FREQuency:MODE?
```

The :POWer:PSRR:FREQuency:MODE? query returns the frequency mode setting.

**Return Format**

```
<mode><NL>
<mode> ::= {SWE | SING}
```

**See Also**

- "[":POWer:PSRR"](#) on page 812
- "[":POWer:PSRR:APPLy"](#) on page 813
- "[":POWer:PSRR:DATA"](#) on page 814
- "[":POWer:PSRR:FREQuency:MAXimum"](#) on page 815
- "[":POWer:PSRR:FREQuency:MINimum"](#) on page 816
- "[":POWer:PSRR:FREQuency:SINGle"](#) on page 818
- "[":POWer:PSRR:PPDecade"](#) on page 819
- "[":POWer:PSRR:SOURce:INPUT"](#) on page 820
- "[":POWer:PSRR:SOURce:OUTPUT"](#) on page 821
- "[":POWer:PSRR:WGEN:LOAD"](#) on page 823
- "[":POWer:PSRR:WGEN:VOLTage"](#) on page 824
- "[":POWer:PSRR:WGEN:VOLTage:PROFile"](#) on page 825

## :POWER:PSRR:FREQuency:SINGle

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWER:PSRR:FREQuency:SINGle &lt;value&gt;[suffix]</code>
	$<\text{value}> ::= \{1   10   100   1000   10000   100000   1000000   10000000   2000000\}$
	$[\text{suffix}] ::= \{\text{Hz}   \text{kHz}   \text{MHz}\}$
	The :POWER:PSRR:FREQuency:SINGle command sets the single frequency value. The measurement is displayed on a log scale, so you can select from decade values.
<b>Query Syntax</b>	<code>:POWER:PSRR:FREQuency:SINGle?</code>
	The :POWER:PSRR:FREQuency:SINGle query returns the single frequency setting.
<b>Return Format</b>	<code>&lt;value&gt;&lt;\text{NL}&gt;</code>
	$<\text{value}> ::= \{1   10   100   1000   10000   100000   1000000   10000000   2000000\}$
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":POWER:PSRR"</a> on page 812</li> <li>· <a href="#">":POWER:PSRR:APPLy"</a> on page 813</li> <li>· <a href="#">":POWER:PSRR:DATA"</a> on page 814</li> <li>· <a href="#">":POWER:PSRR:FREQuency:MODE"</a> on page 817</li> <li>· <a href="#">":POWER:PSRR:PPDecade"</a> on page 819</li> <li>· <a href="#">":POWER:PSRR:SOURce:INPut"</a> on page 820</li> <li>· <a href="#">":POWER:PSRR:SOURce:OUTPut"</a> on page 821</li> <li>· <a href="#">":POWER:PSRR:WGEN:LOAD"</a> on page 823</li> <li>· <a href="#">":POWER:PSRR:WGEN:VOLTage"</a> on page 824</li> <li>· <a href="#">":POWER:PSRR:WGEN:VOLTage:PROFILE"</a> on page 825</li> </ul>

## :POWer:PSRR:PPDecade

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWer:PSRR:PPDecade &lt;pts&gt;</code>
	<code>&lt;pts&gt; ::= {10   20   30   40   50   60   70   80   90   100}</code>
	The :POWer:PSRR:PPDecade command selects the number of frequency test points per decade (in the log scale).
<b>Query Syntax</b>	<code>:POWer:CLResponse:PPDecade?</code>
	The :POWer:PSRR:PPDecade? query returns the points per decade setting.
<b>Return Format</b>	<code>&lt;pts&gt;&lt;NL&gt;</code>
	<code>&lt;pts&gt; ::= {10   20   30   40   50   60   70   80   90   100}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":POWer:PSRR"</a> on page 812</li> <li>· <a href="#">":POWer:PSRR:APPLy"</a> on page 813</li> <li>· <a href="#">":POWer:PSRR:DATA"</a> on page 814</li> <li>· <a href="#">":POWer:PSRR:FREQuency:MAXimum"</a> on page 815</li> <li>· <a href="#">":POWer:PSRR:FREQuency:MINimum"</a> on page 816</li> <li>· <a href="#">":POWer:PSRR:FREQuency:MODE"</a> on page 817</li> <li>· <a href="#">":POWer:PSRR:SOURce:INPut"</a> on page 820</li> <li>· <a href="#">":POWer:PSRR:SOURce:OUTPut"</a> on page 821</li> <li>· <a href="#">":POWer:PSRR:WGEN:LOAD"</a> on page 823</li> <li>· <a href="#">":POWer:PSRR:WGEN:VOLTage"</a> on page 824</li> <li>· <a href="#">":POWer:PSRR:WGEN:VOLTage:PROFile"</a> on page 825</li> </ul>

## :POWER:PSRR:SOURce:INPut

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWER:PSRR:SOURce:INPut &lt;source&gt;</code>
	<code>&lt;source&gt; ::= CHANnel&lt;n&gt;</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	The :POWER:PSRR:SOURce:INPut command selects the oscilloscope channel that is probing the power supply input.
<b>Query Syntax</b>	<code>:POWER:PSRR:SOURce:INPut?</code>
	The :POWER:PSRR:SOURce:INPut? query returns the channel selection.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
	<code>&lt;source&gt; ::= CHAN&lt;n&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":POWER:PSRR"</a> on page 812</li> <li>· <a href="#">":POWER:PSRR:APPLy"</a> on page 813</li> <li>· <a href="#">":POWER:PSRR:DATA"</a> on page 814</li> <li>· <a href="#">":POWER:PSRR:FREQuency:MAXimum"</a> on page 815</li> <li>· <a href="#">":POWER:PSRR:FREQuency:MINimum"</a> on page 816</li> <li>· <a href="#">":POWER:PSRR:FREQuency:MODE"</a> on page 817</li> <li>· <a href="#">":POWER:PSRR:PPDecade"</a> on page 819</li> <li>· <a href="#">":POWER:PSRR:SOURce:OUTPut"</a> on page 821</li> <li>· <a href="#">":POWER:PSRR:WGEN:LOAD"</a> on page 823</li> <li>· <a href="#">":POWER:PSRR:WGEN:VOLTage"</a> on page 824</li> <li>· <a href="#">":POWER:PSRR:WGEN:VOLTage:PROFile"</a> on page 825</li> </ul>

## :POWer:PSRR:SOURce:OUTPut

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWer:PSRR:SOURce:OUTPut &lt;source&gt;</code>
	<code>&lt;source&gt; ::= CHANnel&lt;n&gt;</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	The :POWer:PSRR:SOURce:OUTPut command selects the oscilloscope channel that is probing the power supply output.
<b>Query Syntax</b>	<code>:POWer:PSRR:SOURce:OUTPut?</code>
	The :POWer:PSRR:SOURce:OUTPut? query returns the channel selection.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
	<code>&lt;source&gt; ::= CHAN&lt;n&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">":POWer:PSRR"</a> on page 812</li> <li>· "<a href="#">":POWer:PSRR:APPLy"</a> on page 813</li> <li>· "<a href="#">":POWer:PSRR:DATA"</a> on page 814</li> <li>· "<a href="#">":POWer:PSRR:FREQuency:MAXimum"</a> on page 815</li> <li>· "<a href="#">":POWer:PSRR:FREQuency:MINimum"</a> on page 816</li> <li>· "<a href="#">":POWer:PSRR:FREQuency:MODE"</a> on page 817</li> <li>· "<a href="#">":POWer:PSRR:PPDecade"</a> on page 819</li> <li>· "<a href="#">":POWer:PSRR:SOURce:INPut"</a> on page 820</li> <li>· "<a href="#">":POWer:PSRR:WGEN:LOAD"</a> on page 823</li> <li>· "<a href="#">":POWer:PSRR:WGEN:VOLTage"</a> on page 824</li> <li>· "<a href="#">":POWer:PSRR:WGEN:VOLTage:PROFile"</a> on page 825</li> </ul>

## :POWer:PSRR:TRACe

**N** (see [page 1666](#))

**Command Syntax**    `:POWer:PSRR:TRACe <selection>`  
`<selection> ::= {NONE | GAIN}`

The :POWer:PSRR:TRACe command specifies whether to include gain (PSRR) data in the power supply rejection ratio analysis results.

**NOTE** This command affects the oscilloscope's front panel graphical user interface (plot and table) as well as when saving analysis data.

---

**Query Syntax**    `:POWer:PSRR:TRACe?`

The :POWer:PSRR:TRACe? query returns the type of data that is currently included in the PSRR analysis results, or "NONE" if the gain data is not included.

**Return Format**    `<selection_list><NL>`  
`<selection_list> ::= { "NONE" | "GAIN" }`

**See Also**

- [":POWer:PSRR:APPLy" on page 813](#)
- [":POWer:PSRR:DATA" on page 814](#)

## :POWer:PSRR:WGEN:LOAD

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWer:PSRR:WGEN:LOAD &lt;impedance&gt;</code> <code>&lt;impedance&gt; ::= {ONEMeg   FIFTy}</code>
	The :POWer:PSRR:WGEN:LOAD command sets the waveform generator expected output load impedance.
	The output impedance of the Gen Out signal is fixed at 50 ohms. However, the output load selection lets the waveform generator display the correct amplitude and offset levels for the expected output load. If the actual load impedance is different than the selected value, the displayed amplitude and offset levels will be incorrect.
<b>Query Syntax</b>	<code>:POWer:PSRR:WGEN:LOAD?</code>
	The :POWer:PSRR:WGEN:LOAD? query returns the waveform generator expected output load impedance setting.
<b>Return Format</b>	<code>&lt;impedance&gt;&lt;NL&gt;</code> <code>&lt;impedance&gt; ::= {ONEM   FIFT}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":POWer:PSRR" on page 812</a></li> <li>· <a href="#">":POWer:PSRR:APPLy" on page 813</a></li> <li>· <a href="#">":POWer:PSRR:DATA" on page 814</a></li> <li>· <a href="#">":POWer:PSRR:FREQuency:MAXimum" on page 815</a></li> <li>· <a href="#">":POWer:PSRR:FREQuency:MINimum" on page 816</a></li> <li>· <a href="#">":POWer:PSRR:FREQuency:MODE" on page 817</a></li> <li>· <a href="#">":POWer:PSRR:PPDecade" on page 819</a></li> <li>· <a href="#">":POWer:PSRR:SOURce:INPut" on page 820</a></li> <li>· <a href="#">":POWer:PSRR:SOURce:OUTPut" on page 821</a></li> <li>· <a href="#">":POWer:PSRR:WGEN:VOLTage" on page 824</a></li> <li>· <a href="#">":POWer:PSRR:WGEN:VOLTage:PROFile" on page 825</a></li> </ul>

## :POWER:PSRR:WGEN:VOLTage

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWER:PSRR:WGEN:VOLTage &lt;amplitude&gt;[,&lt;range&gt;]</code> <code>&lt;amplitude&gt; ::= amplitude in volts in NR3 format</code> <code>&lt;range&gt; ::= {F20HZ   F100HZ   F1KHZ   F10KHZ   F100KHZ   F1MHZ   F10MHZ   F20MHZ}</code>
	The :POWER:PSRR:WGEN:VOLTage command sets the waveform generator output amplitude(s).
	When the waveform generator amplitude profile is enabled (with the :POWER:PSRR:WGEN:VOLTage:PROFile command), you can set an initial ramp amplitude for each frequency range.
	Without the <range> parameter, this command sets the waveform generator output amplitude used when the amplitude profile is disabled.
<b>Query Syntax</b>	<code>:POWER:PSRR:WGEN:VOLTage? [&lt;range&gt;]</code>
	The :POWER:PSRR:WGEN:VOLTage? query returns the waveform generator output amplitude setting(s).
<b>Return Format</b>	<code>&lt;amplitude&gt;&lt;NL&gt;</code> <code>&lt;amplitude&gt; ::= amplitude in volts in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":POWER:PSRR"</a> on page 812</li> <li>· <a href="#">":POWER:PSRR:APPLy"</a> on page 813</li> <li>· <a href="#">":POWER:PSRR:DATA"</a> on page 814</li> <li>· <a href="#">":POWER:PSRR:FREQuency:MAXimum"</a> on page 815</li> <li>· <a href="#">":POWER:PSRR:FREQuency:MINimum"</a> on page 816</li> <li>· <a href="#">":POWER:PSRR:FREQuency:MODE"</a> on page 817</li> <li>· <a href="#">":POWER:PSRR:PPDecade"</a> on page 819</li> <li>· <a href="#">":POWER:PSRR:SOURce:INPUT"</a> on page 820</li> <li>· <a href="#">":POWER:PSRR:SOURce:OUTPut"</a> on page 821</li> <li>· <a href="#">":POWER:PSRR:WGEN:LOAD"</a> on page 823</li> <li>· <a href="#">":POWER:PSRR:WGEN:VOLTage:PROFile"</a> on page 825</li> </ul>

## :POWER:PSRR:WGEN:VOLTage:PROFile

**N** (see [page 1666](#))

**Command Syntax** :POWER:PSRR:WGEN:VOLTage:PROFile {{0 | OFF} | {1 | ON}}

The :POWER:PSRR:WGEN:VOLTage:PROFile command enables or disables the ability to set initial waveform generator ramp amplitudes for each frequency range.

With amplitude profiling, you can use lower amplitudes at frequencies where the device under test (DUT) is sensitive to distortion and use higher amplitudes where the DUT is less sensitive to distortion.

You can often observe distortions during the test. If the input test sine wave begins to look lopsided, clipped, or somewhat triangular in shape (nonsinusoidal), you are probably encountering distortion due to overdriving your DUT. Optimizing test amplitudes to achieve the best dynamic range measurements is often an iterative process of running your frequency response measurements multiple times.

**Query Syntax** :POWER:CLResponse:WGEN:VOLTage:PROFile?

The :POWER:PSRR:WGEN:VOLTage:PROFile? query returns the voltage profile setting.

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

**See Also**

- "[:POWER:PSRR](#)" on page 812
- "[:POWER:PSRR:APPLy](#)" on page 813
- "[:POWER:PSRR:DATA](#)" on page 814
- "[:POWER:PSRR:FREQuency:MAXimum](#)" on page 815
- "[:POWER:PSRR:FREQuency:MINimum](#)" on page 816
- "[:POWER:PSRR:FREQuency:MODE](#)" on page 817
- "[:POWER:PSRR:PPDecade](#)" on page 819
- "[:POWER:PSRR:SOURce:INPut](#)" on page 820
- "[:POWER:PSRR:SOURce:OUTPut](#)" on page 821
- "[:POWER:PSRR:WGEN:LOAD](#)" on page 823
- "[:POWER:PSRR:WGEN:VOLTage](#)" on page 824

## :POWer:QUALity:APPLy

**N** (see [page 1666](#))

**Command Syntax** :POWer:QUALity:APPLy

The :POWer:QUALity:APPLy command applies the selected power quality analysis type (:POWer:QUALity:TYPE).

The power quality analysis shows the quality of the AC input line.

Some AC current may flow back into and back out of the load without delivering energy. This current, called reactive or harmonic current, gives rise to an "apparent" power which is larger than the actual power consumed. Power quality is gauged by these measurements: power factor, apparent power, true power, reactive power, crest factor, and phase angle of the current and voltage of the AC line.

- See Also**
- "[:MEASure:FACTOr](#)" on page 704
  - "[:MEASure:REAL](#)" on page 713
  - "[:MEASure:APPARENT](#)" on page 699
  - "[:MEASure:REACTIVE](#)" on page 712
  - "[:MEASure:CREST](#)" on page 701
  - "[:MEASure:ANGLE](#)" on page 698

## :POWer:RIPPLe:APPLy

**N** (see [page 1666](#))

**Command Syntax** :POWer:RIPPLe:APPLy

The :POWer:RIPPLe:APPLy command applies the output ripple analysis.

**See Also** • [":MEASure:RIPPLe"](#) on page 714

## :POWER:SIGNals:AUTosetup

**N** (see [page 1666](#))

**Command Syntax**

```
:POWER:SIGNals:AUTosetup <analysis>
<analysis> ::= {HARMonics | EFFiciency | RIPPLE | MODulation | QUALity
    | SLEW | SWITch | RDSVce}
```

The :POWER:SIGNals:AUTosetup command performs automated oscilloscope setup for the signals in the specified type of power analysis.

**See Also**

- "[":POWER:HARMonics:DISPLAY](#)" on page 789
- "[":POWER:EFFiciency:APPLy](#)" on page 784
- "[":POWER:RIPPLE:APPLy](#)" on page 827
- "[":POWER:MODulation:APPLy](#)" on page 803
- "[":POWER:QUALity:APPLy](#)" on page 826
- "[":POWER:SLEW:APPLy](#)" on page 847
- "[":POWER:SWITch:APPLy](#)" on page 849
- "[":POWER:SIGNals:CYCLES:HARMonics](#)" on page 829
- "[":POWER:SIGNals:CYCLES:QUALity](#)" on page 830
- "[":POWER:SIGNals:DURation:EFFiciency](#)" on page 831
- "[":POWER:SIGNals:DURation:MODulation](#)" on page 832
- "[":POWER:SIGNals:DURation:RIPPLE](#)" on page 835
- "[":POWER:SIGNals:IEXPected](#)" on page 837
- "[":POWER:SIGNals:OVERshoot](#)" on page 838
- "[":POWER:SIGNals:SOURce:CURREnt<i>](#)" on page 845
- "[":POWER:SIGNals:SOURce:VOLTage<i>](#)" on page 846

## :POWer:SIGNals:CYCLes:HARMonics

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWer:SIGNals:CYCLes:HARMonics &lt;count&gt;</code> <code>&lt;count&gt; ::= integer in NR1 format</code> <code>Legal values are 1 to 100.</code>
	The :POWer:SIGNals:CYCLes:HARMonics command specifies the number of cycles to include in the current harmonics analysis.
<b>Query Syntax</b>	<code>:POWer:SIGNals:CYCLes:HARMonics?</code>
	The :POWer:SIGNals:CYCLes:HARMonics query returns the number of cycles currently set.
<b>Return Format</b>	<code>&lt;count&gt;&lt;NL&gt;</code> <code>&lt;count&gt; ::= integer in NR1 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:POWer:HARMonics:DISPlay</a>" on page 789</li> <li>· "<a href="#">:POWer:HARMonics:APPLy</a>" on page 787</li> <li>· "<a href="#">:POWer:SIGNals:AUTosetup</a>" on page 828</li> <li>· "<a href="#">:POWer:SIGNals:IEXPected</a>" on page 837</li> <li>· "<a href="#">:POWer:SIGNals:OVERshoot</a>" on page 838</li> <li>· "<a href="#">:POWer:SIGNals:SOURce:CURREnt&lt;i&gt;</a>" on page 845</li> <li>· "<a href="#">:POWer:SIGNals:SOURce:VOLTage&lt;i&gt;</a>" on page 846</li> </ul>

## :POWER:SIGNals:CYCLeS:QUALity

**N** (see [page 1666](#))

**Command Syntax**    `:POWER:SIGNals:CYCLeS:QUALity <count>`  
`<count> ::= integer in NR1 format`  
Legal values are 1 to 100.

The :POWER:SIGNals:CYCLeS:QUALity command specifies the number of cycles to include in the power quality analysis.

**Query Syntax**    `:POWER:SIGNals:CYCLeS:QUALity?`

The :POWER:SIGNals:CYCLeS:QUALity query returns the number of cycles currently set.

**Return Format**    `<count><NL>`  
`<count> ::= integer in NR1 format`

**See Also**

- "[":POWER:QUALity:APPLy](#)" on page 826
- "[":POWER:SIGNals:AUTosetup](#)" on page 828
- "[":POWER:SIGNals:IEXPected](#)" on page 837
- "[":POWER:SIGNals:OVERshoot](#)" on page 838
- "[":POWER:SIGNals:SOURce:CURREnt<i>](#)" on page 845
- "[":POWER:SIGNals:SOURce:VOLTage<i>](#)" on page 846

## :POWer:SIGNals:DURation:EFFiciency

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWer:SIGNals:DURation:EFFiciency &lt;value&gt;[suffix]</code>
	<code>&lt;value&gt; ::= value in NR3 format</code>
	<code>[suffix] ::= {s   ms   us   ns}</code>
	The :POWer:SIGNals:DURation:EFFiciency command specifies the duration of the efficiency analysis.
<b>Query Syntax</b>	<code>:POWer:SIGNals:DURation:EFFiciency?</code>
	The :POWer:SIGNals:DURation:EFFiciency query returns the set duration time value.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code>
	<code>&lt;value&gt; ::= value in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:POWer:EFFiciency:APPLy</a>" on page 784</li> <li>· "<a href="#">:POWer:SIGNals:AUTosetup</a>" on page 828</li> <li>· "<a href="#">:POWer:SIGNals:IEXPected</a>" on page 837</li> <li>· "<a href="#">:POWer:SIGNals:OVERshoot</a>" on page 838</li> <li>· "<a href="#">:POWer:SIGNals:SOURce:CURREnt&lt;i&gt;</a>" on page 845</li> <li>· "<a href="#">:POWer:SIGNals:SOURce:VOLTage&lt;i&gt;</a>" on page 846</li> </ul>

## :POWER:SIGNals:DURation:MODulation

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWER:SIGNals:DURation:MODulation &lt;value&gt;[suffix]</code>
	<code>&lt;value&gt; ::= value in NR3 format</code>
	<code>[suffix] ::= {s   ms   us   ns}</code>
	The :POWER:SIGNals:DURation:MODulation command specifies the duration of the modulation analysis.
<b>Query Syntax</b>	<code>:POWER:SIGNals:DURation:MODulation?</code>
	The :POWER:SIGNals:DURation:MODulation query returns the set duration time value.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code>
	<code>&lt;value&gt; ::= value in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:POWER:MODulation:APPLy</a>" on page 803</li> <li>· "<a href="#">:POWER:SIGNals:AUTosetup</a>" on page 828</li> <li>· "<a href="#">:POWER:SIGNals:IEXPected</a>" on page 837</li> <li>· "<a href="#">:POWER:SIGNals:OVERshoot</a>" on page 838</li> <li>· "<a href="#">:POWER:SIGNals:SOURce:CURREnt&lt;i&gt;</a>" on page 845</li> <li>· "<a href="#">:POWER:SIGNals:SOURce:VOLTage&lt;i&gt;</a>" on page 846</li> </ul>

## :POWer:SIGNals:DURation:ONOFF:OFF

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWer:SIGNals:DURation:ONOFF:OFF &lt;value&gt;[suffix]</code>
	<code>&lt;value&gt; ::= value in NR3 format</code>
	<code>[suffix] ::= {s   ms   us   ns}</code>
	The :POWer:SIGNals:DURation:ONOFF:OFF command specifies the duration of the turn off analysis.
<b>Query Syntax</b>	<code>:POWer:SIGNals:DURation:ONOFF:OFF?</code>
	The :POWer:SIGNals:DURation:ONOFF:OFF query returns the set duration time value.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code>
	<code>&lt;value&gt; ::= value in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:POWer:ONOFF:APPLy</a>" on page 806</li> <li>· "<a href="#">:POWer:SIGNals:AUTosetup</a>" on page 828</li> <li>· "<a href="#">:POWer:SIGNals:IEXPected</a>" on page 837</li> <li>· "<a href="#">:POWer:SIGNals:OVERshoot</a>" on page 838</li> <li>· "<a href="#">:POWer:SIGNals:VMAXimum:ONOFF:OFF</a>" on page 840</li> <li>· "<a href="#">:POWer:SIGNals:VSTeady:ONOFF:OFF</a>" on page 842</li> <li>· "<a href="#">:POWer:SIGNals:SOURce:CURREnt&lt;i&gt;</a>" on page 845</li> <li>· "<a href="#">:POWer:SIGNals:SOURce:VOLTage&lt;i&gt;</a>" on page 846</li> </ul>

## :POWER:SIGNals:DURation:ONOFF:ON

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWER:SIGNals:DURation:ONOFF:ON &lt;value&gt;[suffix]</code>
	<code>&lt;value&gt;</code> ::= value in NR3 format
	<code>[suffix]</code> ::= {s   ms   us   ns}
	The :POWER:SIGNals:DURation:ONOFF:ON command specifies the duration of the turn on analysis.
<b>Query Syntax</b>	<code>:POWER:SIGNals:DURation:ONOFF:ON?</code>
	The :POWER:SIGNals:DURation:ONOFF:ON query returns the set duration time value.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code>
	<code>&lt;value&gt;</code> ::= value in NR3 format
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:POWER:ONOFF:APPLy</a>" on page 806</li> <li>· "<a href="#">:POWER:SIGNals:AUTosetup</a>" on page 828</li> <li>· "<a href="#">:POWER:SIGNals:IEXPected</a>" on page 837</li> <li>· "<a href="#">:POWER:SIGNals:OVERshoot</a>" on page 838</li> <li>· "<a href="#">:POWER:SIGNals:VMAXimum:ONOFF:ON</a>" on page 841</li> <li>· "<a href="#">:POWER:SIGNals:VSTeady:ONOFF:ON</a>" on page 843</li> <li>· "<a href="#">:POWER:SIGNals:SOURce:CURREnt&lt;i&gt;</a>" on page 845</li> <li>· "<a href="#">:POWER:SIGNals:SOURce:VOLTage&lt;i&gt;</a>" on page 846</li> </ul>

## :POWer:SIGNals:DURation:RIPPle

**N** (see [page 1666](#))

**Command Syntax**    `:POWer:SIGNals:DURation:RIPPle <value>[suffix]`

`<value>` ::= value in NR3 format

`[suffix]` ::= {s | ms | us | ns}

The :POWer:SIGNals:DURation:RIPPle command specifies the duration of the output ripple analysis.

**Query Syntax**    `:POWer:SIGNals:DURation:RIPPle?`

The :POWer:SIGNals:DURation:RIPPle query returns the set duration time value.

**Return Format**    `<value><NL>`

`<value>` ::= value in NR3 format

- See Also**
- "[":POWer:RIPPle:APPLy](#)" on page 827
  - "[":POWer:SIGNals:AUTosetup](#)" on page 828
  - "[":POWer:SIGNals:IEXPected](#)" on page 837
  - "[":POWer:SIGNals:OVERshoot](#)" on page 838
  - "[":POWer:SIGNals:SOURce:CURREnt<i>](#)" on page 845
  - "[":POWer:SIGNals:SOURce:VOLTage<i>](#)" on page 846

## :POWER:SIGNals:DURation:TRANsient

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWER:SIGNals:DURation:TRANsient &lt;value&gt;[suffix]</code>
	<code>&lt;value&gt; ::= value in NR3 format</code>
	<code>[suffix] ::= {s   ms   us   ns}</code>
	The :POWER:SIGNals:DURation:TRANsient command specifies the duration of the transient response analysis.
<b>Query Syntax</b>	<code>:POWER:SIGNals:DURation:TRANsient?</code>
	The :POWER:SIGNals:DURation:TRANsient query returns the set duration time value.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code>
	<code>&lt;value&gt; ::= value in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"><li>· "<a href="#">:POWER:TRANsient:APPLy</a>" on page 855</li><li>· "<a href="#">:POWER:SIGNals:AUTosetup</a>" on page 828</li><li>· "<a href="#">:POWER:SIGNals:IEXPected</a>" on page 837</li><li>· "<a href="#">:POWER:SIGNals:OVERshoot</a>" on page 838</li><li>· "<a href="#">:POWER:SIGNals:VSTeady:TRANsient</a>" on page 844</li><li>· "<a href="#">:POWER:SIGNals:SOURce:CURREnt&lt;i&gt;</a>" on page 845</li><li>· "<a href="#">:POWER:SIGNals:SOURce:VOLTage&lt;i&gt;</a>" on page 846</li></ul>

## :POWer:SIGNals:IEXPected

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWer:SIGNals:IEXPected &lt;value&gt;[suffix]</code>
	<code>&lt;value&gt;</code> ::= Expected current value in NR3 format
	<code>[suffix]</code> ::= {A   mA}
	The :POWer:SIGNals:IEXPected command specifies the expected inrush current amplitude. This value is used to set the vertical scale of the channel probing current.
<b>Query Syntax</b>	<code>:POWer:SIGNals:IEXPected?</code>
	The :POWer:SIGNals:IEXPected query returns the expected inrush current setting.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code>
	<code>&lt;value&gt;</code> ::= Expected current value in NR3 format
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:POWer:INRush:APPLy</a>" on page 799</li> <li>· "<a href="#">:POWer:SIGNals:AUTosetup</a>" on page 828</li> <li>· "<a href="#">:POWer:SIGNals:OVERshoot</a>" on page 838</li> <li>· "<a href="#">:POWer:SIGNals:VMAXimum:INRush</a>" on page 839</li> <li>· "<a href="#">:POWer:SIGNals:SOURce:CURREnt&lt;i&gt;</a>" on page 845</li> <li>· "<a href="#">:POWer:SIGNals:SOURce:VOLTage&lt;i&gt;</a>" on page 846</li> </ul>

## :POWER:SIGNals:OVERshoot

**N** (see [page 1666](#))

**Command Syntax**    `:POWER:SIGNals:OVERshoot <percent>`

`<percent>` ::= percent of overshoot value in NR1 format

The :POWER:SIGNals:OVERshoot command specifies the percent of overshoot of the output voltage. This value is used to determine the settling band value for the transient response and to adjust the vertical scale of the oscilloscope.

**Query Syntax**    `:POWER:SIGNals:OVERshoot?`

The :POWER:SIGNals:OVERshoot query returns the overshoot percent setting.

**Return Format**    `<percent><NL>`

`<percent>` ::= percent of overshoot value in NR1 format

- See Also**
- "[:POWER:TRANsient:APPLy](#)" on page 855
  - "[:POWER:SIGNals:AUTosetup](#)" on page 828
  - "[:POWER:SIGNals:DURation:TRANsient](#)" on page 836
  - "[:POWER:SIGNals:IEXPected](#)" on page 837
  - "[:POWER:SIGNals:VSTeady:TRANsient](#)" on page 844
  - "[:POWER:SIGNals:SOURce:CURREnt<i>](#)" on page 845
  - "[:POWER:SIGNals:SOURce:VOLTage<i>](#)" on page 846

## :POWer:SIGNals:VMAXimum:INRush

**N** (see [page 1666](#))

**Command Syntax** :POWer:SIGNals:VMAXimum:INRush <value>[suffix]

<value> ::= Maximum expected input Voltage in NR3 format  
 [suffix] ::= {v | mV}

The :POWer:SIGNals:VMAXimum:INRush command specifies the maximum expected input voltage. This value is used to set the vertical scale of the channel probing voltage for inrush current analysis.

When the :POWer:ITYPE is DC, this command defines the maximum DC input voltage amplitude value. The values can be negative.

When the :POWer:ITYPE is AC, this command defines the maximum peak-to-peak input voltage. Only positive values are allowed.

**Query Syntax** :POWer:SIGNals:VMAXimum:INRush?

The :POWer:SIGNals:VMAXimum:INRush query returns the expected maximum input voltage setting.

**Return Format** <value><NL>

<value> ::= Maximum expected input Voltage in NR3 format

**See Also**

- "[:POWer:ITYPE](#)" on page 802
- "[:POWer:INRush:APPLy](#)" on page 799
- "[:POWer:SIGNals:AUTosetup](#)" on page 828
- "[:POWer:SIGNals:IEXPected](#)" on page 837
- "[:POWer:SIGNals:OVERshoot](#)" on page 838
- "[:POWer:SIGNals:SOURce:CURREnt<i>](#)" on page 845
- "[:POWer:SIGNals:SOURce:VOLTage<i>](#)" on page 846

## :POWER:SIGNals:VMAXimum:ONOFF:OFF

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWER:SIGNals:VMAXimum:ONOFF:OFF &lt;value&gt;[suffix]</code>
	<code>&lt;value&gt;</code> ::= Maximum expected input Voltage in NR3 format
	<code>[suffix]</code> ::= {v   mV}
	The :POWER:SIGNals:VMAXimum:ONOFF:OFF command specifies the maximum expected input voltage. This value is used to set the vertical scale of the channel probing voltage for turn off analysis.
	When the :POWER:ITYPE is DC, this command defines the maximum DC input voltage amplitude value. The values can be negative.
	When the :POWER:ITYPE is AC, this command defines the maximum peak-to-peak input voltage. Only positive values are allowed.
<b>Query Syntax</b>	<code>:POWER:SIGNals:VMAXimum:ONOFF:OFF?</code>
	The :POWER:SIGNals:VMAXimum:ONOFF:OFF query returns the expected maximum input voltage setting.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code>
	<code>&lt;value&gt;</code> ::= Maximum expected input Voltage in NR3 format
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":POWER:ITYPE"</a> on page 802</li> <li>· <a href="#">":POWER:ONOFF:APPLy"</a> on page 806</li> <li>· <a href="#">":POWER:SIGNals:AUTosetup"</a> on page 828</li> <li>· <a href="#">":POWER:SIGNals:DURation:ONOFF:OFF"</a> on page 833</li> <li>· <a href="#">":POWER:SIGNals:IEXPected"</a> on page 837</li> <li>· <a href="#">":POWER:SIGNals:OVERshoot"</a> on page 838</li> <li>· <a href="#">":POWER:SIGNals:VSteady:ONOFF:OFF"</a> on page 842</li> <li>· <a href="#">":POWER:SIGNals:SOURce:CURREnt&lt;i&gt;"</a> on page 845</li> <li>· <a href="#">":POWER:SIGNals:SOURce:VOLTage&lt;i&gt;"</a> on page 846</li> </ul>

## :POWER:SIGNals:VMAXimum:ONOFF:ON

**N** (see [page 1666](#))

### Command Syntax

```
:POWER:SIGNals:VMAXimum:ONOFF:ON <value>[suffix]
<value> ::= Maximum expected input Voltage in NR3 format
[suffix] ::= {v | mV}
```

The :POWER:SIGNals:VMAXimum:ONOFF:ON command specifies the maximum expected input voltage. This value is used to set the vertical scale of the channel probing voltage for turn on analysis.

When the :POWER:ITYPE is DC, this command defines the maximum DC input voltage amplitude value. The values can be negative.

When the :POWER:ITYPE is AC, this command defines the maximum peak-to-peak input voltage. Only positive values are allowed.

### Query Syntax

```
:POWER:SIGNals:VMAXimum:ONOFF:ON?
```

The :POWER:SIGNals:VMAXimum:ONOFF:ON query returns the expected maximum input voltage setting.

### Return Format

```
<value><NL>
<value> ::= Maximum expected input Voltage in NR3 format
```

### See Also

- [":POWER:ITYPE"](#) on page 802
- [":POWER:ONOFF:APPLy"](#) on page 806
- [":POWER:SIGNals:AUTosetup"](#) on page 828
- [":POWER:SIGNals:DURation:ONOFF:ON"](#) on page 834
- [":POWER:SIGNals:IEXPected"](#) on page 837
- [":POWER:SIGNals:OVERshoot"](#) on page 838
- [":POWER:SIGNals:VSteady:ONOFF:ON"](#) on page 843
- [":POWER:SIGNals:SOURce:CURREnt<i>"](#) on page 845
- [":POWER:SIGNals:SOURce:VOLTage<i>"](#) on page 846

## :POWER:SIGNals:VSteady:ONOFF:OFF

**N** (see [page 1666](#))

**Command Syntax**

```
:POWER:SIGNals:VSteady:ONOFF:OFF <value>[suffix]
<value> ::= Expected steady state output Voltage value in NR3 format
[suffix] ::= {v | mV}
```

The :POWER:SIGNals:VSteady:ONOFF:OFF command specifies the expected steady state output DC voltage of the power supply for turn off analysis.

**Query Syntax**

```
:POWER:SIGNals:VSteady:ONOFF:OFF?
```

The :POWER:SIGNals:VSteady:ONOFF:OFF query returns the expected steady state voltage setting.

**Return Format**

```
<value><NL>
<value> ::= Expected steady state output Voltage value in NR3 format
```

**See Also**

- "[:POWER:ONOFF:APPLy](#)" on page 806
- "[:POWER:SIGNals:AUTosetup](#)" on page 828
- "[:POWER:SIGNals:DURation:ONOFF:OFF](#)" on page 833
- "[:POWER:SIGNals:IEXPected](#)" on page 837
- "[:POWER:SIGNals:OVERshoot](#)" on page 838
- "[:POWER:SIGNals:VMAXimum:ONOFF:OFF](#)" on page 840
- "[:POWER:SIGNals:SOURce:CURREnt<i>](#)" on page 845
- "[:POWER:SIGNals:SOURce:VOLTage<i>](#)" on page 846

## :POWer:SIGNals:VSteady:ONOFF:ON

**N** (see [page 1666](#))

**Command Syntax**

```
:POWer:SIGNals:VSteady:ONOFF:ON <value>[suffix]
<value> ::= Expected steady state output Voltage value in NR3 format
[suffix] ::= {v | mV}
```

The :POWer:SIGNals:VSteady:ONOFF:ON command specifies the expected steady state output DC voltage of the power supply for turn on analysis.

**Query Syntax**

```
:POWer:SIGNals:VSteady:ONOFF:ON?
```

The :POWer:SIGNals:VSteady:ONOFF:ON query returns the expected steady state voltage setting.

**Return Format**

```
<value><NL>
<value> ::= Expected steady state output Voltage value in NR3 format
```

**See Also**

- "[:POWer:ONOFF:APPLy](#)" on page 806
- "[:POWer:SIGNals:AUTosetup](#)" on page 828
- "[:POWer:SIGNals:DURation:ONOFF:ON](#)" on page 834
- "[:POWer:SIGNals:IEXPected](#)" on page 837
- "[:POWer:SIGNals:OVERshoot](#)" on page 838
- "[:POWer:SIGNals:VMAXimum:ONOFF:ON](#)" on page 841
- "[:POWer:SIGNals:SOURce:CURREnt<i>](#)" on page 845
- "[:POWer:SIGNals:SOURce:VOLTage<i>](#)" on page 846

## :POWER:SIGNals:VSteady:TRANSient

**N** (see [page 1666](#))

**Command Syntax**

```
:POWER:SIGNals:VSteady:TRANSient <value>[suffix]
<value> ::= Expected steady state output Voltage value in NR3 format
[suffix] ::= {v | mV}
```

The :POWER:SIGNals:VSteady:TRANSient command specifies the expected steady state output DC voltage of the power supply for transient response analysis.

This value is used along with the overshoot percentage to specify the settling band for the transient response and to adjust the vertical scale of the oscilloscope.

**Query Syntax**

```
:POWER:SIGNals:VSteady:TRANSient?
```

The :POWER:SIGNals:VSteady:TRANSient query returns the expected steady state voltage setting.

**Return Format**

```
<value><NL>
```

<value> ::= Expected steady state output Voltage value in NR3 format

**See Also**

- [":POWER:TRANSient:APPLY"](#) on page 855
- [":POWER:SIGNals:AUTosetup"](#) on page 828
- [":POWER:SIGNals:DURation:TRANSient"](#) on page 836
- [":POWER:SIGNals:IEXPected"](#) on page 837
- [":POWER:SIGNals:OVERshoot"](#) on page 838
- [":POWER:SIGNals:SOURce:CURREnt<i>"](#) on page 845
- [":POWER:SIGNals:SOURce:VOLTage<i>"](#) on page 846

## :POWER:SIGNals:SOURce:CURRent<i>

**N** (see [page 1666](#))

<b>Command Syntax</b>	<pre>:POWER:SIGNals:SOURce:CURRent&lt;i&gt; &lt;source&gt; &lt;i&gt; ::= 1, 2 in NR1 format &lt;source&gt; ::= CHANnel&lt;n&gt; &lt;n&gt; ::= 1 to (# analog channels) in NR1 format</pre>
	The :POWER:SIGNals:SOURce:CURRent<i> command specifies the first, and perhaps second, current source channel to be used in the power analysis.
<b>Query Syntax</b>	<pre>:POWER:SIGNals:SOURce:CURRent&lt;i&gt;?</pre>
	The :POWER:SIGNals:SOURce:CURRent<i> query returns the current source channel setting.
<b>Return Format</b>	<pre>&lt;source&gt;&lt;NL&gt; &lt;source&gt; ::= CHANnel&lt;n&gt; &lt;n&gt; ::= 1 to (# analog channels) in NR1 format</pre>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:POWER:SIGNals:AUTosetup</a>" on page 828</li> <li>· "<a href="#">:POWER:SIGNals:CYCLes:HARMonics</a>" on page 829</li> <li>· "<a href="#">:POWER:SIGNals:CYCLes:QUALity</a>" on page 830</li> <li>· "<a href="#">:POWER:SIGNals:DURation:EFFiciency</a>" on page 831</li> <li>· "<a href="#">:POWER:SIGNals:DURation:MODulation</a>" on page 832</li> <li>· "<a href="#">:POWER:SIGNals:DURation:ONOFF:OFF</a>" on page 833</li> <li>· "<a href="#">:POWER:SIGNals:DURation:ONOFF:ON</a>" on page 834</li> <li>· "<a href="#">:POWER:SIGNals:DURation:RIPPLE</a>" on page 835</li> <li>· "<a href="#">:POWER:SIGNals:DURation:TRANSient</a>" on page 836</li> <li>· "<a href="#">:POWER:SIGNals:IEXPected</a>" on page 837</li> <li>· "<a href="#">:POWER:SIGNals:OVERshoot</a>" on page 838</li> <li>· "<a href="#">:POWER:SIGNals:VMAXimum:INRush</a>" on page 839</li> <li>· "<a href="#">:POWER:SIGNals:VMAXimum:ONOFF:OFF</a>" on page 840</li> <li>· "<a href="#">:POWER:SIGNals:VMAXimum:ONOFF:ON</a>" on page 841</li> <li>· "<a href="#">:POWER:SIGNals:VSTeady:ONOFF:OFF</a>" on page 842</li> <li>· "<a href="#">:POWER:SIGNals:VSTeady:ONOFF:ON</a>" on page 843</li> <li>· "<a href="#">:POWER:SIGNals:VSTeady:TRANSient</a>" on page 844</li> <li>· "<a href="#">:POWER:SIGNals:SOURce:VOLTage&lt;i&gt;</a>" on page 846</li> </ul>

## :POWER:SIGNals:SOURce:VOLTage<i>

**N** (see [page 1666](#))

**Command Syntax**

```
:POWER:SIGNals:SOURce:VOLTage<i> <source>
<i> ::= 1, 2 in NR1 format
<source> ::= CHANnel<n>
<n> ::= 1 to (# analog channels) in NR1 format
```

The :POWER:SIGNals:SOURce:VOLTage<i> command specifies the first, and perhaps second, voltage source channel to be used in the power analysis.

**Query Syntax**

```
:POWER:SIGNals:SOURce:VOLTage<i>?
```

The :POWER:SIGNals:SOURce:VOLTage<i> query returns the voltage source channel setting.

**Return Format**

```
<source><NL>
<source> ::= CHANnel<n>
<n> ::= 1 to (# analog channels) in NR1 format
```

**See Also**

- "[:POWER:SIGNals:AUTosetup](#)" on page 828
- "[:POWER:SIGNals:CYCLES:HARMonics](#)" on page 829
- "[:POWER:SIGNals:CYCLES:QUALity](#)" on page 830
- "[:POWER:SIGNals:DURation:EFFiciency](#)" on page 831
- "[:POWER:SIGNals:DURation:MODulation](#)" on page 832
- "[:POWER:SIGNals:DURation:ONOFF:OFF](#)" on page 833
- "[:POWER:SIGNals:DURation:ONOFF:ON](#)" on page 834
- "[:POWER:SIGNals:DURation:RIPPLE](#)" on page 835
- "[:POWER:SIGNals:DURation:TRANSient](#)" on page 836
- "[:POWER:SIGNals:IEXPected](#)" on page 837
- "[:POWER:SIGNals:OVERshoot](#)" on page 838
- "[:POWER:SIGNals:VMAXimum:INRush](#)" on page 839
- "[:POWER:SIGNals:VMAXimum:ONOFF:OFF](#)" on page 840
- "[:POWER:SIGNals:VMAXimum:ONOFF:ON](#)" on page 841
- "[:POWER:SIGNals:VSTeady:ONOFF:OFF](#)" on page 842
- "[:POWER:SIGNals:VSTeady:ONOFF:ON](#)" on page 843
- "[:POWER:SIGNals:VSTeady:TRANSient](#)" on page 844
- "[:POWER:SIGNals:SOURce:CURREnt<i>](#)" on page 845

## :POWer:SLEW:APPLy

**N** (see [page 1666](#))

**Command Syntax** :POWer:SLEW:APPLy

The :POWer:SLEW:APPLy command applies the slew rate analysis.

**See Also** • [":POWer:SLEW:SOURce"](#) on page 848

## :POWer:SLEW:SOURce

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWer:SLEW:SOURce &lt;source&gt;</code> <code>&lt;source&gt; ::= {V   I}</code>
	The :POWer:SLEW:SOURce command selects either the voltage source or the current source as the source for the slew rate analysis.
<b>Query Syntax</b>	<code>:POWer:SLEW:SOURce?</code>
	The :POWer:SLEW:SOURce query returns the selected source for the slew rate analysis.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code> <code>&lt;source&gt; ::= {V   I}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":POWer:SLEW:APPLy"</a> on page 847</li></ul>

## :POWer:SWITch:APPLy

**N** (see [page 1666](#))

**Command Syntax** :POWer:SWITch:APPLy

The :POWer:SWITch:APPLy command applies the switching loss analysis using the conduction calculation method, V reference, and I reference settings.

- See Also**
- "[:POWer:SWITch:CONDuction](#)" on page 850
  - "[:POWer:SWITch:IREFerence](#)" on page 851
  - "[:POWer:SWITch:RDS](#)" on page 852
  - "[:POWer:SWITch:VCE](#)" on page 853
  - "[:POWer:SWITch:VREFerence](#)" on page 854
  - "[:MEASure:ELOSSs](#)" on page 703
  - "[:MEASure:PLOSSs](#)" on page 710

## :POWER:SWITch:CONDuction

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWER:SWITch:CONDuction &lt;conduction&gt;</code> <code>&lt;conduction&gt; ::= {WAVeform   RDS   VCE}</code>
	The :POWER:SWITch:CONDuction command specifies the conduction calculation method:
	<ul style="list-style-type: none"> <li>• WAVeform – The Power waveform uses the original voltage waveform data, and the calculation is: <math>P = V \times I</math></li> <li>• RDS – Rds(on) – The Power waveform includes error correction: <ul style="list-style-type: none"> <li>• In the On Zone (where the voltage level is below V Ref) – the Power calculation is: <math>P = Id^2 \times Rds(on)</math></li> </ul> Specify Rds(on) using the :POWER:SWITch:RDS command.</li> <li>• In the Off Zone (where the current level is below I Ref) – the Power calculation is: <math>P = 0</math> Watt.</li> </ul>
	<ul style="list-style-type: none"> <li>• VCE – Vce(sat) – The Power waveform includes error correction: <ul style="list-style-type: none"> <li>• In the On Zone (where the voltage level is below V Ref) – the Power calculation is: <math>P = Vce(sat) \times I_c</math></li> </ul> Specify Vce(sat) using the :POWER:SWITch:VCE command.</li> <li>• In the Off Zone (where the current level is below I Ref) – the Power calculation is: <math>P = 0</math> Watt.</li> </ul>
<b>Query Syntax</b>	<code>:POWER:SWITch:CONDuction?</code>
	The :POWER:SWITch:CONDuction query returns the conduction calculation method.
<b>Return Format</b>	<code>&lt;conduction&gt;&lt;NL&gt;</code> <code>&lt;conduction&gt; ::= {WAV   RDS   VCE}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">:POWER:SWITch:APPLy</a>" on page 849</li> <li>• "<a href="#">:POWER:SWITch:IREFerence</a>" on page 851</li> <li>• "<a href="#">:POWER:SWITch:RDS</a>" on page 852</li> <li>• "<a href="#">:POWER:SWITch:VCE</a>" on page 853</li> <li>• "<a href="#">:POWER:SWITch:VREFerence</a>" on page 854</li> </ul>

## :POWer:SWITch:IREFerence

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:POWer:SWITch:IREFerence &lt;percent&gt;</code> <code>&lt;percent&gt; ::= percent in NR1 format</code>
	The :POWer:SWITch:IREFerence command to specify the current switching level for the start of switching edges. The value is in percentage of the maximum switch current.
	You can adjust this value to ignore noise floors or null offset that is difficult to eliminate in current probes.
	This value specifies the threshold that is used to determine the switching edges.
<b>Query Syntax</b>	<code>:POWer:SWITch:IREFerence?</code>
	The :POWer:SWITch:IREFerence query returns the current switching level percent value.
<b>Return Format</b>	<code>&lt;percent&gt;&lt;NL&gt;</code> <code>&lt;percent&gt; ::= percent in NR1 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:POWer:SWITch:APPLy</a>" on page 849</li> <li>· "<a href="#">:POWer:SWITch:CONDuction</a>" on page 850</li> <li>· "<a href="#">:POWer:SWITch:RDS</a>" on page 852</li> <li>· "<a href="#">:POWer:SWITch:VCE</a>" on page 853</li> <li>· "<a href="#">:POWer:SWITch:VREFerence</a>" on page 854</li> </ul>

## :POWer:SWITch:RDS

**N** (see [page 1666](#))

**Command Syntax**    `:POWer:SWITch:RDS <value>[suffix]`  
`<value> ::= Rds(on) value in NR3 format`  
`[suffix] ::= {OHM | mOHM}`

The :POWer:SWITch:RDS command specifies the Rds(on) value when the RDS conduction calculation method is chosen (by :POWer:SWITch:CONDuction).

**Query Syntax**    `:POWer:SWITch:RDS?`

The :POWer:SWITch:RDS query returns the Rds(on) value.

**Return Format**    `<value><NL>`  
`<value> ::= Rds(on) value in NR3 format`

**See Also**

- "[":POWer:SWITch:APPLy](#)" on page 849
- "[":POWer:SWITch:CONDuction](#)" on page 850
- "[":POWer:SWITch:IREFerence](#)" on page 851
- "[":POWer:SWITch:VCE](#)" on page 853
- "[":POWer:SWITch:VREFerence](#)" on page 854

## :POWer:SWITch:VCE

**N** (see [page 1666](#))

**Command Syntax** :POWer:SWITch:VCE <value>[suffix]

```
<value> ::= Vce(sat) value in NR3 format
[suffix] ::= {v | mV}
```

The :POWer:SWITch:VCE command specifies the Vce(sat) value when the VCE conduction calculation method is chosen (by :POWer:SWITch:CONDuction).

**Query Syntax** :POWer:SWITch:VCE?

The :POWer:SWITch:VCE query returns the Vce(sat) value.

**Return Format** <value><NL>

```
<value> ::= Vce(sat) value in NR3 format
```

- See Also**
- "[:POWer:SWITch:APPLy](#)" on page 849
  - "[:POWer:SWITch:CONDuction](#)" on page 850
  - "[:POWer:SWITch:IREFerence](#)" on page 851
  - "[:POWer:SWITch:RDS](#)" on page 852
  - "[:POWer:SWITch:VREFerence](#)" on page 854

## :POWER:SWITch:VREFerence

**N** (see [page 1666](#))

**Command Syntax**    `:POWER:SWITch:VREFerence <percent>`  
`<percent> ::= percent in NR1 format`

The :POWER:SWITch:VREFerence command to specify the voltage switching level for the switching edges. The value is in percentage of the maximum switch voltage.

You can adjust this value to ignore noise floors.

This value specifies the threshold that is used to determine the switching edges.

**Query Syntax**    `:POWER:SWITch:VREFerence?`

The :POWER:SWITch:VREFerence query returns the voltage switching level percent value.

**Return Format**    `<percent><NL>`  
`<percent> ::= percent in NR1 format`

**See Also**

- "[:POWER:SWITch:APPLy](#)" on page 849
- "[:POWER:SWITch:CONduction](#)" on page 850
- "[:POWER:SWITch:IREFerence](#)" on page 851
- "[:POWER:SWITch:RDS](#)" on page 852
- "[:POWER:SWITch:VCE](#)" on page 853

## :POWer:TRANsient:APPLy

**N** (see [page 1666](#))

**Command Syntax** :POWer:TRANsient:APPLy

The :POWer:TRANsient:APPLy command applies the transient analysis using the initial current and new current settings.

**See Also**

- "[":POWer:TRANsient:EXIT](#)" on page 856
- "[":POWer:TRANsient:IINitial](#)" on page 857
- "[":POWer:TRANsient:INEW](#)" on page 858
- "[":POWer:TRANsient:NEXT](#)" on page 859
- "[":MEASure:TRESPonse](#)" on page 715

## :POWer:TRANSient:EXIT

**N** (see [page 1666](#))

**Command Syntax** :POWer:TRANSient:EXIT

The :POWer:TRANSient:EXIT command exits (stops) the transient analysis.

This command is equivalent to pressing the **Exit** softkey on the oscilloscope front panel during the analysis.

- See Also**
- "[":POWer:TRANSient:APPLy](#)" on page 855
  - "[":POWer:TRANSient:IINitial](#)" on page 857
  - "[":POWer:TRANSient:INEW](#)" on page 858
  - "[":POWer:TRANSient:NEXT](#)" on page 859

## :POWer:TRANsient:IINitial

**N** (see [page 1666](#))

**Command Syntax**

```
:POWer:TRANsient:IINInitial <value>[suffix]
<value> ::= Initial current value in NR3 format
[suffix] ::= {A | mA}
```

The :POWer:TRANsient:IINInitial command to specify the initial load current value. The initial load current will be used as a reference and to trigger the oscilloscope.

**Query Syntax**

```
:POWer:TRANsient:IINInitial?
```

The :POWer:TRANsient:IINInitial query returns the initial load current value.

**Return Format**

```
<value><NL>
<value> ::= Initial current value in NR3 format
```

**See Also**

- "[":POWer:SIGNals:VSTeady:TRANsient](#)" on page 844
- "[":POWer:TRANsient:APPLy](#)" on page 855
- "[":POWer:TRANsient:EXIT](#)" on page 856
- "[":POWer:TRANsient:INew](#)" on page 858
- "[":POWer:TRANsient:NEXT](#)" on page 859

## :POWer:TRANsient:INew

**N** (see [page 1666](#))

**Command Syntax**    `:POWer:TRANsient:INew <value>[suffix]`

`<value>` ::= New current value in NR3 format

`[suffix]` ::= {A | mA}

The :POWer:TRANsient:INew command to specify the new load current value. The new load current will be used as a reference and to trigger the oscilloscope.

**Query Syntax**    `:POWer:TRANsient:INew?`

The :POWer:TRANsient:INew query returns the new load current value.

**Return Format**    `<value><NL>`

`<value>` ::= New current value in NR3 format

**See Also**

- "[:POWer:TRANsient:APPLy](#)" on page 855
- "[:POWer:TRANsient:EXIT](#)" on page 856
- "[:POWer:TRANsient:INITial](#)" on page 857
- "[:POWer:TRANsient:NEXT](#)" on page 859

## :POWer:TRANsient:NEXT

**N** (see [page 1666](#))

**Command Syntax** :POWer:TRANsient:NEXT

The :POWer:TRANsient:NEXT command goes to the next step of the transient analysis.

This command is equivalent to pressing the **Next** softkey on the oscilloscope front panel when prompted during the analysis.

**See Also**

- "[":POWer:TRANsient:APPLy](#)" on page 855
- "[":POWer:TRANsient:EXIT](#)" on page 856
- "[":POWer:TRANsient:IINitial](#)" on page 857
- "[":POWer:TRANsient:INew](#)" on page 858



# 31 :RECall Commands

Recall previously saved oscilloscope setups, reference waveforms, and masks.

**Table 120** :RECall Commands Summary

Command	Query	Options and Query Returns
:RECall:ARbitrary[:START] [<file_spec>] [, <column>] [, <wavegen_id>] (see page 864)	n/a	<p>&lt;file_spec&gt; ::= {&lt;internal_loc&gt;   &lt;file_name&gt;}</p> <p>&lt;column&gt; ::= Column in CSV file to load. Column number starts from 1.</p> <p>&lt;internal_loc&gt; ::= 0-3; an integer in NR1 format</p> <p>&lt;file_name&gt; ::= quoted ASCII string</p> <p>&lt;wavegen_id&gt; ::= WGEN1</p>
:RECall:DBC[:START] [<file_name>] [, <serialbus>] (see page 865)	n/a	<p>&lt;file_name&gt; ::= quoted ASCII string</p> <p>If extension included in file name, it must be ".dbc".</p> <p>&lt;serialbus&gt; ::= {SBUS&lt;n&gt;}</p> <p>&lt;n&gt; ::= 1 to (# of serial bus) in NR1 format</p>
:RECall:FILEname <base_name> (see page 866)	:RECall:FILEname? (see page 866)	<p>&lt;base_name&gt; ::= quoted ASCII string</p>
:RECall:LDF[:START] [<file_name>] [, <serialbus>] (see page 867)	n/a	<p>&lt;file_name&gt; ::= quoted ASCII string</p> <p>If extension included in file name, it must be ".ldf".</p> <p>&lt;serialbus&gt; ::= {SBUS&lt;n&gt;}</p> <p>&lt;n&gt; ::= 1 to (# of serial bus) in NR1 format</p>

**Table 120** :RECall Commands Summary (continued)

Command	Query	Options and Query Returns
:RECall:MASK[:START] [<file_spec>] (see <a href="#">page 868</a> )	n/a	<file_spec> ::= {<internal_loc>   <file_name>} <internal_loc> ::= 0-3; an integer in NR1 format <file_name> ::= quoted ASCII string
:RECall:PWD <path_name> (see <a href="#">page 869</a> )	:RECall:PWD? (see <a href="#">page 869</a> )	<path_name> ::= quoted ASCII string
:RECall:SETUp[:START] [<file_spec>] (see <a href="#">page 870</a> )	n/a	<file_spec> ::= {<internal_loc>   <file_name>} <internal_loc> ::= 0-9; an integer in NR1 format <file_name> ::= quoted ASCII string
:RECall:WMEMory<r>[:S TART] [<file_name>   <data>] (see <a href="#">page 871</a> )	n/a	<r> ::= 1 to (# ref waveforms) in NR1 format <file_name> ::= quoted ASCII string If extension included in file name, it must be ".h5". <data> ::= binary block data in IEEE 488.2 # format

**Introduction to :RECall Commands** The :RECall subsystem provides commands to recall previously saved oscilloscope setups, reference waveforms, and masks.

### Reporting the Setup

Use :RECall? to query setup information for the RECall subsystem.

### Return Format

The following is a sample response from the :RECall? query. In this case, the query was issued following the \*RST command.

```
:REC:FIL "scope_0"
```

### Recalling Files From a USB Storage Device

When :RECall commands have a "quoted ASCII string" <file\_name> parameter, you can recall files from a connected USB storage device. For example:

```
' To recall a setup file from a connected USB storage device:  
myScope.WriteString ":RECall:SETup:START \"\"\\usb\\my_setup_file.scp\"""
```

## :RECall:ARBitrary[:STARt]

**N** (see [page 1666](#))

**Command Syntax**

```
:RECall:ARBitrary[:STARt] [<file_spec> [, <column>] [, <wavegen_id>]
<file_spec> ::= {<internal_loc> | <file_name>}
<column> ::= Column in CSV file to load. Column number starts from 1.
<wavegen_id> ::= WGEN1 - specifies which wavegen
<internal_loc> ::= 0-3; an integer in NR1 format
<file_name> ::= quoted ASCII string
```

The :RECall:ARBitrary[:STARt] command recalls an arbitrary waveform.

### NOTE

If a file extension is provided as part of a specified <file\_name>, it must be ".csv".

For internal locations, the <column> parameter is ignored.

For external (USB storage device) files, the column parameter is optional. If no <column> parameter is entered, and it is a 2-column file, the 2nd column (assumed to be voltage) is automatically selected. If the <column> parameter is entered, and that column does not exist in the file, the operation fails.

When recalling arbitrary waveforms (from an external USB storage device) that were not saved from the oscilloscope, be aware that the oscilloscope uses a maximum of 8192 points for an arbitrary waveform. For more efficient recalls, make sure your arbitrary waveforms are 8192 points or less.

The <wavegen\_id> parameter specifies which waveform generator to recall the arbitrary waveform into.

### See Also

- "[Introduction to :RECall Commands](#)" on page 862
- "[":RECall:FILENAME"](#) on page 866
- "[":RECall:PWD"](#) on page 869
- "[":SAVE:ARBitrary\[:STARt\]"](#) on page 877

## :RECall:DBC[:STARt]

**N** (see [page 1666](#))

### Command Syntax

```
:RECall:DBC[:STARt] [<file_name> [, <serialbus>]
<file_name> ::= quoted ASCII string
<serialbus> ::= {SBUS<n>}
<n> ::= 1 to (# of serial bus) in NR1 format
```

The :RECall:DBC[:STARt] command loads a CAN DBC (communication database) symbolic data file into the oscilloscope.

### NOTE

If a file extension is provided as part of a specified <file\_name>, it must be ".dbc".

The <serialbus> parameter specifies which serial decode waveform the CAN symbolic data will be loaded for.

### See Also

- "[Introduction to :RECall Commands](#)" on page 862
- "[:RECall:FILENAME](#)" on page 866
- "[:SBUS<n>:CAN:TRIGGER](#)" on page 946
- "[:SBUS<n>:CAN:TRIGGER:SYMBOLIC:MESSAGE](#)" on page 956
- "[:SBUS<n>:CAN:TRIGGER:SYMBOLIC:SIGNAL](#)" on page 957
- "[:SBUS<n>:CAN:TRIGGER:SYMBOLIC:VALUE](#)" on page 958
- "[:SEARCh:SERIAL:CAN:MODE](#)" on page 1239
- "[:SEARCh:SERIAL:CAN:SYMBOLIC:MESSAGE](#)" on page 1245
- "[:SEARCh:SERIAL:CAN:SYMBOLIC:SIGNAl](#)" on page 1246
- "[:SEARCh:SERIAL:CAN:SYMBOLIC:VALUe](#)" on page 1247

## :RECall:FILEname

**N** (see [page 1666](#))

**Command Syntax**    `:RECall:FILEname <base_name>`  
`<base_name> ::= quoted ASCII string`

The :RECall:FILEname command specifies the source for any RECall operations.

**NOTE** This command specifies a file's base name only, without path information or an extension.

---

**Query Syntax**    `:RECall:FILEname?`

The :RECall:FILEname? query returns the current RECall filename.

**Return Format**    `<base_name><NL>`  
`<base_name> ::= quoted ASCII string`

**See Also**

- "[Introduction to :RECall Commands](#)" on page 862
- "[":RECall:SETup\[:STARt\]](#)" on page 870
- "[":SAVE:FILEname](#)" on page 879

## :RECall:LDF[:START]

**N** (see [page 1666](#))

### Command Syntax

```
:RECall:LDF[:START] [<file_name> [, <serialbus>]
<file_name> ::= quoted ASCII string
<serialbus> ::= {SBUS<n>}
<n> ::= 1 to (# of serial bus) in NR1 format
```

The :RECall:LDF[:START] command loads a LIN description file (LDF) symbolic data file into the oscilloscope.

### NOTE

If a file extension is provided as part of a specified <file\_name>, it must be ".ldf".

The <serialbus> parameter specifies which serial decode waveform the LIN symbolic data will be loaded for.

### See Also

- "[Introduction to :RECall Commands](#)" on page 862
- "[:RECall:FILEname](#)" on page 866
- "[:SBUS<n>:LIN:TRIGger](#)" on page 1034
- "[:SBUS<n>:LIN:TRIGger:SYMBOLic:FRAME](#)" on page 1041
- "[:SBUS<n>:LIN:TRIGger:SYMBOLic:SIGNAl](#)" on page 1042
- "[:SBUS<n>:LIN:TRIGger:SYMBOLic:VALue](#)" on page 1043
- "[:SEARch:SERial:LIN:MODE](#)" on page 1269
- "[:SEARch:SERial:LIN:SYMBOLic:FRAME](#)" on page 1273
- "[:SEARch:SERial:LIN:SYMBOLic:SIGNAl](#)" on page 1274
- "[:SEARch:SERial:LIN:SYMBOLic:VALue](#)" on page 1275

## :RECall:MASK[:STARt]

**N** (see [page 1666](#))

**Command Syntax**    `:RECall:MASK[:STARt] [<file_spec>]`

`<file_spec>` ::= {`<internal_loc>` | `<file_name>`}

`<internal_loc>` ::= 0-3; an integer in NR1 format

`<file_name>` ::= quoted ASCII string

The :RECall:MASK[:STARt] command recalls a mask.

### NOTE

If a file extension is provided as part of a specified `<file_name>`, it must be ".msk".

### See Also

- "[Introduction to :RECall Commands](#)" on page 862
- "[":RECall:FILENAME](#)" on page 866
- "[":RECall:PWD](#)" on page 869
- "[":SAVE:MASK\[:STARt\]](#)" on page 886
- "[":MTESt:DATA](#)" on page 732

## :RECall:PWD

**N** (see [page 1666](#))

**Command Syntax** :RECall:PWD <path\_name>

<path\_name> ::= quoted ASCII string

The :RECall:PWD command sets the present working directory for recall operations.

### NOTE

Presently, the internal "/User Files" directory you see in the oscilloscope's front panel user interface is the "\Agilent Flash" directory you see in the remote interface.

**Query Syntax** :RECall:PWD?

The :RECall:PWD? query returns the currently set working directory for recall operations.

**Return Format** <path\_name><NL>

<path\_name> ::= quoted ASCII string

**See Also**

- "[Introduction to :RECall Commands](#)" on page 862
- "[":SAVE:PWD"](#) on page 889

## :RECall:SETup[:STARt]

**N** (see [page 1666](#))

**Command Syntax**    `:RECall:SETup [:STARt] [<file_spec>]`

`<file_spec>` ::= {`<internal_loc>` | `<file_name>`}

`<internal_loc>` ::= 0-9; an integer in NR1 format

`<file_name>` ::= quoted ASCII string

The :RECall:SETup[:STARt] command recalls an oscilloscope setup.

### NOTE

If a file extension is provided as part of a specified `<file_name>`, it must be ".scp".

### See Also

- "[Introduction to :RECall Commands](#)" on page 862
- "[":RECall:FILENAME](#)" on page 866
- "[":RECall:PWD](#)" on page 869
- "[":SAVE\[SETUP\[:STARt\]\]](#)" on page 896

## :RECall:WMEMory<r>[:STARt]

**N** (see [page 1666](#))

### Command Syntax

```
:RECall:WMEMory<r>[:STARt] [<file_name> | <data>]
<r> ::= 1 to (# ref waveforms) in NR1 format
<file_name> ::= quoted ASCII string
<data> ::= binary block data in IEEE 488.2 # format
```

The :RECall:WMEMory<r>[:STARt] command recalls a reference waveform.

### NOTE

If a file extension is provided as part of a specified <file\_name>, it must be ".h5".

The <data> option lets you recall a reference waveform from a local file on the controller PC (instead of from a USB storage device connected to the oscilloscope). In this case, your remote program reads data from the local ".h5" format reference waveform file in the same way that setup files are restored to the oscilloscope (see "[:SYSTem:SETup](#)" on page 1332).

### See Also

- "[Introduction to :RECall Commands](#)" on page 862
- "[:RECall:FILEname](#)" on page 866
- "[:SAVE:WMEMory\[:STARt\]](#)" on page 903



## 32 :SAVE Commands

Save oscilloscope setups, screen images, and data. See "[Introduction to :SAVE Commands](#)" on page 876.

**Table 121** :SAVE Commands Summary

Command	Query	Options and Query Returns
:SAVE:ARBitrary[:STARt] [<file_spec>] [, <wavegen_id>] (see <a href="#">page 877</a> )	n/a	<p>&lt;file_spec&gt; ::= {&lt;internal_loc&gt;   &lt;file_name&gt;}</p> <p>&lt;internal_loc&gt; ::= 0-3; an integer in NR1 format</p> <p>&lt;file_name&gt; ::= quoted ASCII string</p> <p>&lt;wavegen_id&gt; ::= WGEN1</p>
:SAVE:COMpliance:USB[:START] [<file_name>] (see <a href="#">page 878</a> )	n/a	<file_name> ::= quoted ASCII string
:SAVE:FILEname <base_name> (see <a href="#">page 879</a> )	:SAVE:FILEname? (see <a href="#">page 879</a> )	<base_name> ::= quoted ASCII string
:SAVE:IMAGE[:START] [<file_name>] (see <a href="#">page 880</a> )	n/a	<file_name> ::= quoted ASCII string
:SAVE:IMAGE:FACTors {{0   OFF}   {1   ON}} (see <a href="#">page 881</a> )	:SAVE:IMAGE:FACTors? (see <a href="#">page 881</a> )	{0   1}
:SAVE:IMAGE:FORMAT <format> (see <a href="#">page 882</a> )	:SAVE:IMAGE:FORMAT? (see <a href="#">page 882</a> )	<format> ::= {{BMP   BMP24bit}   BMP8bit   PNG   NONE}
:SAVE:IMAGE:INKSaver {{0   OFF}   {1   ON}} (see <a href="#">page 883</a> )	:SAVE:IMAGE:INKSaver? (see <a href="#">page 883</a> )	{0   1}

**Table 121** :SAVE Commands Summary (continued)

Command	Query	Options and Query Returns
:SAVE:IMAGE:PAlette <palette> (see <a href="#">page 884</a> )	:SAVE:IMAGE:PAlette? (see <a href="#">page 884</a> )	<palette> ::= {COLOR   GRAYscale}
:SAVE:LISTER[:START] [<file_name>] (see <a href="#">page 885</a> )	n/a	<file_name> ::= quoted ASCII string
:SAVE:MASK[:START] [<file_spec>] (see <a href="#">page 886</a> )	n/a	<file_spec> ::= {<internal_loc>   <file_name>} <internal_loc> ::= 0-3; an integer in NR1 format <file_name> ::= quoted ASCII string
:SAVE:MULTi[:START] [<file_name>] (see <a href="#">page 887</a> )	n/a	<file_name> ::= quoted ASCII string
:SAVE:POWER[:START] [<file_name>] (see <a href="#">page 888</a> )	n/a	<file_name> ::= quoted ASCII string
:SAVE:PWD <path_name> (see <a href="#">page 889</a> )	:SAVE:PWD? (see <a href="#">page 889</a> )	<path_name> ::= quoted ASCII string
:SAVE:RESUltS:[START] [<file_spec>] (see <a href="#">page 890</a> )	n/a	<file_name> ::= quoted ASCII string
:SAVE:RESUltS:FORMAT: CURSOR {{0   OFF}   {1   ON}} (see <a href="#">page 891</a> )	:SAVE:RESUltS:FORMAT: CURSOR? (see <a href="#">page 891</a> )	{0   1}
:SAVE:RESUltS:FORMAT: MASK {{0   OFF}   {1   ON}} (see <a href="#">page 892</a> )	:SAVE:RESUltS:FORMAT: MASK? (see <a href="#">page 892</a> )	{0   1}
:SAVE:RESUltS:FORMAT: MEASurement {{0   OFF}   {1   ON}} (see <a href="#">page 893</a> )	:SAVE:RESUltS:FORMAT: MEASurement? (see <a href="#">page 893</a> )	{0   1}
:SAVE:RESUltS:FORMAT: SEARch {{0   OFF}   {1   ON}} (see <a href="#">page 894</a> )	:SAVE:RESUltS:FORMAT: SEARch? (see <a href="#">page 894</a> )	{0   1}

**Table 121** :SAVE Commands Summary (continued)

Command	Query	Options and Query Returns
:SAVE:RESUlt:FORMAT: SEGmented {{0   OFF}   {1   ON}} (see <a href="#">page 895</a> )	:SAVE:RESUlt:FORMAT: SEGmented? (see <a href="#">page 895</a> )	{0   1}
:SAVE:SETup [:START] [<file_spec>] (see <a href="#">page 896</a> )	n/a	<file_spec> ::= {<internal_loc>   <file_name>} <internal_loc> ::= 0-9; an integer in NR1 format <file_name> ::= quoted ASCII string
:SAVE:WAVEform[:STARt] ] [<file_name>] (see <a href="#">page 897</a> )	n/a	<file_name> ::= quoted ASCII string
:SAVE:WAVEform:FORMAT <format> (see <a href="#">page 898</a> )	:SAVE:WAVEform:FORMAT ? (see <a href="#">page 898</a> )	<format> ::= {ASCIixy   CSV   BINary   NONE}
:SAVE:WAVEform:LENGTH <length> (see <a href="#">page 899</a> )	:SAVE:WAVEform:LENGTH ? (see <a href="#">page 899</a> )	<length> ::= 100 to max. length; an integer in NR1 format
:SAVE:WAVEform:LENGTH :MAX {{0   OFF}   {1   ON}} (see <a href="#">page 900</a> )	:SAVE:WAVEform:LENGTH :MAX? (see <a href="#">page 900</a> )	{0   1}
:SAVE:WAVEform:SEGMen ted <option> (see <a href="#">page 901</a> )	:SAVE:WAVEform:SEGMen ted? (see <a href="#">page 901</a> )	<option> ::= {ALL   CURRent}

**Table 121** :SAVE Commands Summary (continued)

Command	Query	Options and Query Returns
:SAVE:WMEMORY:SOURce <source> (see page 902)	:SAVE:WMEMORY:SOURce? (see page 902)	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCTION&lt;m&gt;   MATH&lt;m&gt;   WMEMORY&lt;r&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>NOTE: Only ADD or SUBtract math operations can be saved as reference waveforms.</p> <p>&lt;return_value&gt; ::= &lt;source&gt;</p>
:SAVE:WMEMORY[:START] [<file_name>] (see page 903)	n/a	<p>&lt;file_name&gt; ::= quoted ASCII string</p> <p>If extension included in file name, it must be ".h5".</p>

**Introduction to :SAVE Commands** The :SAVE subsystem provides commands to save oscilloscope setups, screen images, and data.

:SAV is an acceptable short form for :SAVE.

### Reporting the Setup

Use :SAVE? to query setup information for the SAVE subsystem.

### Return Format

The following is a sample response from the :SAVE? query. In this case, the query was issued following the \*RST command.

```
:SAVE:FILE ""; :SAVE:IMAG:AREA GRAT;FACT 0;FORM TIFF;INKS 0;PAL
MON; :SAVE:PWD "C:/setups/"; :SAVE:WAV:FORM NONE;LENG 1000;SEGM CURR
```

### Saving Files to a USB Storage Device

When :SAVE commands have a "quoted ASCII string" <file\_name> parameter, you can save files to a connected USB storage device. For example:

```
' To save a setup file to a connected USB storage device:
myScope.WriteString ":SAVE:SETup:START \"\usb\my_setup_file.scp"""
```

## :SAVE:ARBitrary[:STARt]

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:ARBitrary[:STARt] [<file_spec> [, <wavegen_id>]`

`<file_spec> ::= {<internal_loc> | <file_name>}`

`<internal_loc> ::= 0-3; an integer in NR1 format`

`<file_name> ::= quoted ASCII string`

`<wavegen_id> ::= WGEN1`

The :SAVE:ARBitrary[:STARt] command saves the current arbitrary waveform to an internal location or a file on a USB storage device.

The <wavegen\_id> parameter specifies which waveform generator to save the arbitrary waveform from.

### NOTE

If a file extension is provided as part of a specified <file\_name>, it must be ".csv".

### See Also

- "[Introduction to :SAVE Commands](#)" on page 876
- "[":SAVE:FILEname](#)" on page 879
- "[":SAVE:PWD](#)" on page 889
- "[":RECall:ARBitrary\[:STARt\]](#)" on page 864

## :SAVE:COMPliance:USB[:STARt]

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:COMPliance:USB [:STARt] [<file_name>]`

`<file_name>` ::= quoted ASCII string

The :SAVE:COMPliance:USB[:STARt] command saves USB 2.0 signal quality test results to a file.

### NOTE

If a file extension is provided as part of a specified `<file_name>`, it must be ".html".

---

### See Also

- "[Introduction to :SAVE Commands](#)" on page 876
- "[":SAVE:FILEname](#)" on page 879
- "[":SAVE:PWD](#)" on page 889
- [Chapter 12](#), “:COMPliance Commands,” starting on page 371

## :SAVE:FILEname

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:FILEname <base_name>`

`<base_name>` ::= quoted ASCII string

The :SAVE:FILEname command specifies the source for any SAVE operations.

### NOTE

This command specifies a file's base name only, without path information or an extension.

**Query Syntax**    `:SAVE:FILEname?`

The :SAVE:FILEname? query returns the current SAVE filename.

**Return Format**    `<base_name><NL>`

`<base_name>` ::= quoted ASCII string

**See Also**

- "[Introduction to :SAVE Commands](#)" on page 876
- "[":SAVE:IMAGe\[:STARt\]](#)" on page 880
- "[":SAVE\[:SETup\[:STARt\]\]](#)" on page 896
- "[":SAVE:WAVEform\[:STARt\]](#)" on page 897
- "[":SAVE:PWD](#)" on page 889
- "[":RECall:FILEname](#)" on page 866

## :SAVE:IMAGe[:STARt]

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:IMAGe [:STARt] [<file_name>]`

`<file_name>` ::= quoted ASCII string

The :SAVE:IMAGe[:STARt] command saves an image.

**NOTE**

Be sure to set the :SAVE:IMAGe:FORMAT before saving an image. If the format is NONE, the save image command will not succeed.

**NOTE**

If a file extension is provided as part of a specified <file\_name>, and it does not match the extension expected by the format specified in :SAVE:IMAGe:FORMAT, the format will be changed if the extension is a valid image file extension.

**NOTE**

If the extension ".bmp" is used and the current :SAVE:IMAGe:FORMAT is not BMP or BMP8, the format will be changed to BMP.

**See Also**

- "[Introduction to :SAVE Commands](#)" on page 876
- "[":SAVE:IMAGe:FACTors](#)" on page 881
- "[":SAVE:IMAGe:FORMAT](#)" on page 882
- "[":SAVE:IMAGe:INKSaver](#)" on page 883
- "[":SAVE:IMAGe:PALETTE](#)" on page 884
- "[":SAVE:FILEname](#)" on page 879

## :SAVE:IMAGe:FACTOrs

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:IMAGe:FACTOrs <factors>`  
`<factors> ::= {{OFF | 0} | {ON | 1}}`

The :SAVE:IMAGe:FACTOrs command controls whether the oscilloscope factors are output along with the image.

**NOTE** Factors are written to a separate file with the same path and base name but with the ".txt" extension.

**Query Syntax**    `:SAVE:IMAGe:FACTOrs?`

The :SAVE:IMAGe:FACTOrs? query returns a flag indicating whether oscilloscope factors are output along with the image.

**Return Format**    `<factors><NL>`

`<factors> ::= {0 | 1}`

**See Also**

- "[Introduction to :SAVE Commands](#)" on page 876
- "[":SAVE:IMAGe\[:STARt\]](#)" on page 880
- "[":SAVE:IMAGe:FORMAT](#)" on page 882
- "[":SAVE:IMAGe:INKSaver](#)" on page 883
- "[":SAVE:IMAGe:PALETTE](#)" on page 884

## :SAVE:IMAGe:FORMAT

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:IMAGe:FORMAT <format>`

`<format> ::= { {BMP | BMP24bit} | BMP8bit | PNG}`

The :SAVE:IMAGe:FORMAT command sets the image format type.

**Query Syntax**    `:SAVE:IMAGe:FORMAT?`

The :SAVE:IMAGe:FORMAT? query returns the selected image format type.

**Return Format**    `<format><NL>`

`<format> ::= {BMP | BMP8 | PNG | NONE}`

When NONE is returned, it indicates that a waveform data file format is currently selected.

**See Also**

- "[Introduction to :SAVE Commands](#)" on page 876
- "[":SAVE:IMAGe\[:STARt\]](#)" on page 880
- "[":SAVE:IMAGe:FACTors](#)" on page 881
- "[":SAVE:IMAGe:INKSaver](#)" on page 883
- "[":SAVE:IMAGe:PALETTE](#)" on page 884
- "[":SAVE:WAVeform:FORMAT](#)" on page 898

## :SAVE:IMAGe:INKSaver

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:IMAGe:INKSaver <value>`  
`<value> ::= {{OFF | 0} | {ON | 1}}`

The :SAVE:IMAGe:INKSaver command controls whether the graticule colors are inverted or not.

**Query Syntax**    `:SAVE:IMAGe:INKSaver?`

The :SAVE:IMAGe:INKSaver? query returns a flag indicating whether graticule colors are inverted or not.

**Return Format**    `<value><NL>`  
`<value> ::= {0 | 1}`

**See Also**

- "[Introduction to :SAVE Commands](#)" on page 876
- "[":SAVE:IMAGe\[:STARt\]](#)" on page 880
- "[":SAVE:IMAGe:FACTors](#)" on page 881
- "[":SAVE:IMAGe:FORMAT](#)" on page 882
- "[":SAVE:IMAGe:PALETTE](#)" on page 884

## :SAVE:IMAGe:PALETTE

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:IMAGe:PALETTE <palette>`  
`<palette> ::= {COLor | GRAYscale}`

The :SAVE:IMAGe:PALETTE command sets the image palette color.

**Query Syntax**    `:SAVE:IMAGe:PALETTE?`

The :SAVE:IMAGe:PALETTE? query returns the selected image palette color.

**Return Format**    `<palette><NL>`  
`<palette> ::= {COL | GRAY}`

**See Also**

- "[Introduction to :SAVE Commands](#)" on page 876
- "[":SAVE:IMAGe\[:STARt\]](#)" on page 880
- "[":SAVE:IMAGe:FACTors](#)" on page 881
- "[":SAVE:IMAGe:FORMAT](#)" on page 882
- "[":SAVE:IMAGe:INKSaver](#)" on page 883

## :SAVE:LISTER[:STARt]

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:LISTER [:STARt] [<file_name>]`  
`<file_name>` ::= quoted ASCII string

The :SAVE:LISTER[:STARt] command saves the Lister display data to a file.

### NOTE

If a file extension is provided as part of a specified <file\_name>, it must be ".csv".

- 
- See Also**
- ["Introduction to :SAVE Commands"](#) on page 876
  - [":SAVE:FILEname"](#) on page 879
  - [Chapter 23, “:LISTER Commands,”](#) starting on page 561

## :SAVE:MASK[:STARt]

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:MASK[:STARt] [<file_spec>]`  
`<file_spec> ::= {<internal_loc> | <file_name>}`  
`<internal_loc> ::= 0-3; an integer in NR1 format`  
`<file_name> ::= quoted ASCII string`

The :SAVE:MASK[:STARt] command saves a mask.

### NOTE

If a file extension is provided as part of a specified <file\_name>, it must be ".msk".

### See Also

- "[Introduction to :SAVE Commands](#)" on page 876
- "[":SAVE:FILENAME](#)" on page 879
- "[":SAVE:PWD](#)" on page 889
- "[":RECALL:MASK\[:STARt\]](#)" on page 868
- "[":MTEST:DATA](#)" on page 732

## :SAVE:MULTi[:STARt]

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:MULTi [:STARt] [<file_name>]`  
                  `<file_name> ::= quoted ASCII string`

The :SAVE:MULTi[:STARt] command saves multi-channel waveform data to a file. This file can be opened by the N8900A Infinium Offline oscilloscope analysis software.

### NOTE

If a file extension is provided as part of a specified <file\_name>, it must be ".h5".

---

**See Also**

- ["Introduction to :SAVE Commands"](#) on page 876
- [":SAVE:FILEname"](#) on page 879
- [":SAVE:PWD"](#) on page 889

## :SAVE:POWer[:STARt]

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:POWer [:STARt] [<file_name>]`  
`<file_name>` ::= quoted ASCII string

The :SAVE:POWer[:STARt] command saves the power measurement application's current harmonics analysis results to a file.

**NOTE**

If a file extension is provided as part of a specified <file\_name>, it must be ".csv".

---

**See Also**

- "[Introduction to :SAVE Commands](#)" on page 876
- "[":SAVE:FILEname](#)" on page 879
- [Chapter 30](#), “:POWer Commands,” starting on page 757

## :SAVE:PWD

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:PWD <path_name>`

`<path_name>` ::= quoted ASCII string

The :SAVE:PWD command sets the present working directory for save operations.

### NOTE

Presently, the internal "/User Files" directory you see in the oscilloscope's front panel user interface is the "\Agilent Flash" directory you see in the remote interface.

**Query Syntax**    `:SAVE:PWD?`

The :SAVE:PWD? query returns the currently set working directory for save operations.

**Return Format**    `<path_name><NL>`

`<path_name>` ::= quoted ASCII string

**See Also**

- "[Introduction to :SAVE Commands](#)" on page 876
- "[":SAVE:FILENAME](#)" on page 879
- "[":RECALL:PWD](#)" on page 869

## :SAVE:RESults:[STARt]

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:RESults: [STARt] [<file_spec>]  
<file_name> ::= quoted ASCII string`

The :SAVE:RESults:[STARt] command saves analysis results to a comma-separated values (\*.csv) file on a USB storage device.

Use the :SAVE:RESults:FORMAT commands to specify the analysis types whose results are saved to the file.

When multiple types of analysis results are selected, they are all saved to the same file and separated by a blank line.

- See Also**
- "[:SAVE:RESults:FORMAT:CURSor](#)" on page 891
  - "[:SAVE:RESults:FORMAT:MASK](#)" on page 892
  - "[:SAVE:RESults:FORMAT:MEASurement](#)" on page 893
  - "[:SAVE:RESults:FORMAT:SEARch](#)" on page 894
  - "[:SAVE:RESults:FORMAT:SEGmented](#)" on page 895

## :SAVE:RESults:FORMat:CURSor

**N** (see [page 1666](#))

**Command Syntax** :SAVE:RESults:FORMat:CURSor {{0 | OFF} | {1 | ON}}

The :SAVE:RESults:FORMat:CURSor command specifies whether cursor values will be included when analysis results are saved.

Analysis results are saved using the :SAVE:RESults:[STARt] command.

Other :SAVE:RESults:FORMat commands specify whether other types of analysis results are also saved.

When multiple types of analysis results are saved, they are all saved to the same file and separated by a blank line.

**Query Syntax** :SAVE:RESults:FORMat:CURSor?

The :SAVE:RESults:FORMat:CURSor? query returns whether cursor values will be included when analysis results are saved.

**Return Format** <off\_on><NL>

{0 | 1}

- See Also**
- "[":SAVE:RESults:\[STARt\]](#)" on page 890
  - "[":SAVE:RESults:FORMat:MASK](#)" on page 892
  - "[":SAVE:RESults:FORMat:MEASurement](#)" on page 893
  - "[":SAVE:RESults:FORMat:SEARch](#)" on page 894
  - "[":SAVE:RESults:FORMat:SEGmented](#)" on page 895

## :SAVE:RESults:FORMat:MASK

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:RESults:FORMat:MASK {{0 | OFF} | {1 | ON}}`

The :SAVE:RESults:FORMat:MASK command specifies whether mask statistics will be included when analysis results are saved.

Analysis results are saved using the :SAVE:RESULTS:[STARt] command.

Other :SAVE:RESults:FORMat commands specify whether other types of analysis results are also saved.

When multiple types of analysis results are saved, they are all saved to the same file and separated by a blank line.

**Query Syntax**    `:SAVE:RESults:FORMat:MASK?`

The :SAVE:RESults:FORMat:MASK? query returns whether mask statistics will be included when analysis results are saved.

**Return Format**    `<off_on><NL>`

`{0 | 1}`

- See Also**
- "[":SAVE:RESults:\[STARt\]](#)" on page 890
  - "[":SAVE:RESults:FORMat:CURSor](#)" on page 891
  - "[":SAVE:RESults:FORMat:MEASurement](#)" on page 893
  - "[":SAVE:RESults:FORMat:SEARch](#)" on page 894
  - "[":SAVE:RESults:FORMat:SEGmented](#)" on page 895

## :SAVE:RESults:FORMat:MEASurement

**N** (see [page 1666](#))

### Command Syntax

`:SAVE:RESults:FORMat:MEASurement {{0 | OFF} | {1 | ON}}`

The :SAVE:RESults:FORMat:MEASurement command specifies whether measurement results will be included when analysis results are saved.

Analysis results are saved using the :SAVE:RESults:[STARt] command.

Other :SAVE:RESults:FORMat commands specify whether other types of analysis results are also saved.

When multiple types of analysis results are saved, they are all saved to the same file and separated by a blank line.

### Query Syntax

`:SAVE:RESults:FORMat:MEASurement?`

The :SAVE:RESults:FORMat:MEASurement? query returns whether measurement results will be included when analysis results are saved.

### Return Format

`<off_on><NL>`

`{0 | 1}`

### See Also

- "[":SAVE:RESults:\[STARt\]](#)" on page 890
- "[":SAVE:RESults:FORMat:CURSor](#)" on page 891
- "[":SAVE:RESults:FORMat:MASK](#)" on page 892
- "[":SAVE:RESults:FORMat:SEARch](#)" on page 894
- "[":SAVE:RESults:FORMat:SEGmented](#)" on page 895

## :SAVE:RESults:FORMat:SEARch

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:RESults:FORMat:SEARch {{0 | OFF} | {1 | ON}}`

The :SAVE:RESults:FORMat:SEARch command specifies whether found search event times will be included when analysis results are saved.

Analysis results are saved using the :SAVE:RESults:[STARt] command.

Other :SAVE:RESults:FORMat commands specify whether other types of analysis results are also saved.

When multiple types of analysis results are saved, they are all saved to the same file and separated by a blank line.

**Query Syntax**    `:SAVE:RESults:FORMat:SEARch?`

The :SAVE:RESults:FORMat:SEARch? query returns whether found search event times will be included when analysis results are saved.

**Return Format**    `<off_on><NL>`

`{0 | 1}`

- See Also**
- "[":SAVE:RESults:\[STARt\]](#)" on page 890
  - "[":SAVE:RESults:FORMat:CURSor](#)" on page 891
  - "[":SAVE:RESults:FORMat:MASK](#)" on page 892
  - "[":SAVE:RESults:FORMat:MEASurement](#)" on page 893
  - "[":SAVE:RESults:FORMat:SEGmented](#)" on page 895

## :SAVE:RESults:FORMat:SEGmented

**N** (see [page 1666](#))

### Command Syntax

`:SAVE:RESults:FORMat:SEGmented {{0 | OFF} | {1 | ON}}`

The :SAVE:RESults:FORMat:SEGmented command specifies whether segmented memory acquisition times will be included when analysis results are saved.

Analysis results are saved using the :SAVE:RESults:[STARt] command.

Other :SAVE:RESults:FORMat commands specify whether other types of analysis results are also saved.

When multiple types of analysis results are saved, they are all saved to the same file and separated by a blank line.

### Query Syntax

`:SAVE:RESults:FORMat:SEGmented?`

The :SAVE:RESults:FORMat:SEGmented? query returns whether segmented memory acquisition times will be included when analysis results are saved.

### Return Format

`<off_on><NL>`

`{0 | 1}`

### See Also

- "[":SAVE:RESults:\[STARt\]](#)" on page 890
- "[":SAVE:RESults:FORMat:CURSor](#)" on page 891
- "[":SAVE:RESults:FORMat:MASK](#)" on page 892
- "[":SAVE:RESults:FORMat:MEASurement](#)" on page 893
- "[":SAVE:RESults:FORMat:SEARch](#)" on page 894

## :SAVE[:SETUp[:STARt]]

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE [:SETUp [:STARt]] [<file_spec>]`

`<file_spec>` ::= {`<internal_loc>` | `<file_name>`}

`<internal_loc>` ::= 0-9; an integer in NR1 format

`<file_name>` ::= quoted ASCII string

The :SAVE[:SETUp[:STARt]] command saves an oscilloscope setup.

### NOTE

If a file extension is provided as part of a specified `<file_name>`, it must be ".scp".

### See Also

- "[Introduction to :SAVE Commands](#)" on page 876
- "[":SAVE:FILENAME](#)" on page 879
- "[":SAVE:PWD](#)" on page 889
- "[":RECALL:SETUP\[:STARt\]](#)" on page 870

## :SAVE:WAVeform[:STARt]

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:WAVeform[:STARt] [<file_name>]`  
                  `<file_name> ::= quoted ASCII string`

The :SAVE:WAVeform[:STARt] command saves oscilloscope waveform data to a file.

**NOTE**

Be sure to set the :SAVE:WAVeform:FORMat before saving waveform data. If the format is NONE, the save waveform command will not succeed.

**NOTE**

If a file extension is provided as part of a specified <file\_name>, and it does not match the extension expected by the format specified in :SAVE:WAVeform:FORMat, the format will be changed if the extension is a valid waveform file extension.

**See Also**

- "[Introduction to :SAVE Commands](#)" on page 876
- "[":SAVE:WAVeform:FORMat](#)" on page 898
- "[":SAVE:WAVeform:LENGth](#)" on page 899
- "[":SAVE:FILEname](#)" on page 879
- "[":RECall:SETup\[:STARt\]](#)" on page 870

## :SAVE:WAveform:FORMAT

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:WAveform:FORMAT <format>`

`<format> ::= {ASCIiXY | CSV | BINARY}`

The :SAVE:WAveform:FORMAT command sets the waveform data format type:

- ASCIiXY – creates comma-separated value files for each analog channel that is displayed (turned on). The proper file extension for this format is ".csv".
- CSV – creates one comma-separated value file that contains information for all analog channels that are displayed (turned on). The proper file extension for this format is ".csv".
- BINARY – creates an oscilloscope binary data format file. See the *User's Guide* for a description of this format. The proper file extension for this format is ".bin".

**Query Syntax**    `:SAVE:WAveform:FORMAT?`

The :SAVE:WAveform:FORMAT? query returns the selected waveform data format type.

**Return Format**    `<format><NL>`

`<format> ::= {ASC | CSV | BIN | NONE}`

When NONE is returned, it indicates that an image file format is currently selected.

**See Also**    ["Introduction to :SAVE Commands" on page 876](#)

- [":SAVE:WAveform\[:START\]" on page 897](#)
- [":SAVE:WAveform:LENGTH" on page 899](#)
- [":SAVE:IMAGe:FORMAT" on page 882](#)

## :SAVE:WAveform:LENGth

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SAVE:WAveform:LENGth &lt;length&gt;</code> <code>&lt;length&gt; ::= 100 to max. length; an integer in NR1 format</code>
	When the :SAVE:WAveform:LENGth:MAX setting is OFF, the :SAVE:WAveform:LENGth command sets the waveform data length (that is, the number of points saved).
	When the :SAVE:WAveform:LENGth:MAX setting is ON, the :SAVE:WAveform:LENGth setting has no effect.
<b>Query Syntax</b>	<code>:SAVE:WAveform:LENGth?</code>
	The :SAVE:WAveform:LENGth? query returns the current waveform data length setting.
<b>Return Format</b>	<code>&lt;length&gt;&lt;NL&gt;</code> <code>&lt;length&gt; ::= 100 to max. length; an integer in NR1 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">Introduction to :SAVE Commands</a>" on page 876</li> <li>· "<a href="#">":SAVE:WAveform:LENGth:MAX</a>" on page 900</li> <li>· "<a href="#">":SAVE:WAveform[:STARt]</a>" on page 897</li> <li>· "<a href="#">":WAveform:POINts</a>" on page 1466</li> <li>· "<a href="#">":SAVE:WAveform:FORMAT</a>" on page 898</li> </ul>

## :SAVE:WAVeform:LENGth:MAX

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:WAVeform:LENGth:MAX <setting>`  
`<setting> ::= {{OFF | 0} | {ON | 1}}`

The :SAVE:WAVeform:LENGth:MAX command specifies whether maximum number of waveform data points is saved.

When OFF, the :SAVE:WAVeform:LENGth command specifies the number of waveform data points saved.

**Query Syntax**    `:SAVE:WAVeform:LENGth:MAX?`

The :SAVE:WAVeform:LENGth:MAX? query returns the current setting.

**Return Format**    `<setting><NL>`  
`<setting> ::= {0 | 1}`

**See Also**

- ["Introduction to :SAVE Commands"](#) on page 876
- [":SAVE:WAVeform\[:STARt\]"](#) on page 897
- [":SAVE:WAVeform:LENGth"](#) on page 899

## :SAVE:WAveform:SEGmented

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:WAveform:SEGmented <option>`  
`<option> ::= {ALL | CURR}`

When segmented memory is used for acquisitions, the :SAVE:WAveform:SEGmented command specifies which segments are included when the waveform is saved:

- ALL – all acquired segments are saved.
- CURR – only the currently selected segment is saved.

**Query Syntax**    `:SAVE:WAveform:SEGmented?`

The :SAVE:WAveform:SEGmented? query returns the current segmented waveform save option setting.

**Return Format**    `<option><NL>`  
`<option> ::= {ALL | CURR}`

**See Also**    ["Introduction to :SAVE Commands"](#) on page 876  
[":SAVE:WAveform\[:START\]"](#) on page 897  
[":SAVE:WAveform:FORMAT"](#) on page 898  
[":SAVE:WAveform:LENGTH"](#) on page 899

## :SAVE:WMEMORY:SOURce

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SAVE:WMEMORY:SOURce &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   FUNCtion&lt;m&gt;   MATH&lt;m&gt;   WMEMory&lt;r&gt;}</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</code>
	<code>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</code>
	The :SAVE:WMEMORY:SOURce command selects the source to be saved as a reference waveform file.

**NOTE**

Only ADD or SUBtract math operations can be saved as reference waveforms.

**NOTE**

MATH is an alias for FUNCtion. The query will return FUNC if the source is FUNCtion or MATH.

**Query Syntax**

`:SAVE:WMEMORY:SOURce?`

The :SAVE:WMEMORY:SOURce? query returns the source to be saved as a reference waveform file.

**Return Format**

`<source><NL>`  
`<source> ::= {CHAN<n> | FUNC | WMEM<r> | NONE}`

**See Also**

- "[Introduction to :SAVE Commands](#)" on page 876
- "[":SAVE:WMEMORY\[:START\]"](#) on page 903
- "[":RECall:WMEMORY<r>\[:START\]"](#) on page 871

## :SAVE:WMEMory[:STARt]

**N** (see [page 1666](#))

**Command Syntax**    `:SAVE:WMEMory [:STARt] [<file_name>]`  
                  `<file_name> ::= quoted ASCII string`

The :SAVE:WMEMory[:STARt] command saves oscilloscope waveform data to a reference waveform file.

### NOTE

If a file extension is provided as part of a specified <file\_name>, it must be ".h5".

---

**See Also**

- "[Introduction to :SAVE Commands](#)" on page 876
- "[:SAVE:WMEMory:SOURce](#)" on page 902
- "[:RECall:WMEMory<r>\[:STARt\]](#)" on page 871



## 33 :SBUS<n> Commands

Control the modes and parameters for each serial bus decode/trigger type. See:

- ["Introduction to :SBUS<n> Commands" on page 905](#)
- ["General :SBUS<n> Commands" on page 907](#)
- [":SBUS<n>:A429 Commands" on page 910](#)
- [":SBUS<n>:CAN Commands" on page 929](#)
- [":SBUS<n>:CXPI Commands" on page 959](#)
- [":SBUS<n>:FLEXray Commands" on page 976](#)
- [":SBUS<n>:I2S Commands" on page 995](#)
- [":SBUS<n>:IIC Commands" on page 1014](#)
- [":SBUS<n>:LIN Commands" on page 1025](#)
- [":SBUS<n>:M1553 Commands" on page 1044](#)
- [":SBUS<n>:MANChester Commands" on page 1051](#)
- [":SBUS<n>:NRZ Commands" on page 1070](#)
- [":SBUS<n>:SENT Commands" on page 1089](#)
- [":SBUS<n>:SPI Commands" on page 1125](#)
- [":SBUS<n>:UART Commands" on page 1142](#)
- [":SBUS<n>:USB Commands" on page 1164](#)
- [":SBUS<n>:USBPd Commands" on page 1189](#)

Introduction to  
:SBUS<n>  
Commands

The :SBUS subsystem commands control the serial decode bus viewing, mode, and other options.

**NOTE**

These commands are only valid on oscilloscope models when a serial decode option has been licensed.

---

The following serial bus decode/trigger types are available (see [":TRIGger:MODE" on page 1362](#)).

- **CAN (Controller Area Network) triggering**— will trigger on CAN version 2.0A and 2.0B signals. Setup consists of connecting the oscilloscope to a CAN signal. Baud rate, signal source, and signal polarity, and type of data to trigger on can be specified. You can trigger on CAN data and identifier patterns and you can set the bit sample point.
- **CXPI triggering**— lets you trigger on CXPI serial data.
- **I2S (Inter-IC Sound or Integrated Interchip Sound bus) triggering**— consists of connecting the oscilloscope to the serial clock, word select, and serial data lines, then triggering on a data value.
- **IIC (Inter-IC bus) triggering**— consists of connecting the oscilloscope to the serial data (SDA) line and the serial clock (SCL) line, then triggering on a stop/start condition, a restart, a missing acknowledge, or on a read/write frame with a specific device address and data value.
- **LIN (Local Interconnect Network) triggering**— will trigger on LIN sync break at the beginning of a message frame. You can trigger on Sync Break, Frame IDs, or Frame IDs and Data.
- **SPI (Serial Peripheral Interface) triggering**— consists of connecting the oscilloscope to a clock, data (MOSI or MISO), and framing signal. You can then trigger on a data pattern during a specific framing period. The serial data string can be specified to be from 4 to 64 bits long.
- **UART/RS-232 triggering**— lets you trigger on RS-232 serial data.
- **SENT triggering**— lets you trigger on SENT serial data.
- **USB PD triggering**— lets you trigger on USB PD serial data.

**NOTE**

Two I2S buses or two SPI buses cannot be decoded on both SBUS1 and SBUS2 at the same time.

### Reporting the Setup

Use :SBUS<n>? to query setup information for the :SBUS<n> subsystem.

### Return Format

The following is a sample response from the :SBUS1? query. In this case, the query was issued following a \*RST command.

```
:SBUS1:DISP 0;MODE IIC;:SBUS1:IIC:ASIZ BIT7;:SBUS1:IIC:TRIG:TYPE
STAR;QUAL EQU; :SBUS1:IIC:SOUR:CLOC CHAN1;DATA
CHAN2; :SBUS1:IIC:TRIG:PATT:ADDR -1;DATA -1;DATA2 -1
```

## General :SBUS<n> Commands

**Table 122** General :SBUS<n> Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:DISPlay {{0   OFF}   {1   ON}} (see <a href="#">page 908</a> )	:SBUS<n>:DISPlay? (see <a href="#">page 908</a> )	{0   1}
:SBUS<n>:MODE <mode> (see <a href="#">page 909</a> )	:SBUS<n>:MODE? (see <a href="#">page 909</a> )	<mode> ::= {A429   CAN   CXPI   FLEXray   I2S   IIC   LIN   M1553   Manchester   NRZ   SENT   SPI   UART   USB   USBPd}

## :SBUS<n>:DISPlay

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:DISPlay <display>`

`<display> ::= {{1 | ON} | {0 | OFF}}`

The :SBUS<n>:DISPlay command turns displaying of the serial decode bus on or off.

### NOTE

This command is only valid when a serial decode option has been licensed.

### NOTE

Two I<sub>2</sub>S buses or two SPI buses cannot be decoded on both SBUS1 and SBUS2 at the same time.

#### Query Syntax

`:SBUS<n>:DISPlay?`

The :SBUS<n>:DISPlay? query returns the current display setting of the serial decode bus.

#### Return Format

`<display><NL>`

`<display> ::= {0 | 1}`

- Errors    · ["-241, Hardware missing" on page 1607](#)

#### See Also

- ["Introduction to :SBUS<n> Commands" on page 905](#)
- [":CHANnel<n>:DISPlay" on page 347](#)
- [":DIGItal<d>:DISPlay" on page 405](#)
- [":POD<n>:DISPlay" on page 753](#)
- [":VIEW" on page 298](#)
- [":BLANK" on page 266](#)
- [":STATus" on page 295](#)

## :SBUS<n>:MODE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:MODE <mode>`

```
<mode> ::= {A429 | FLEXray | CAN | CXPI | I2S | IIC | LIN | M1553
             | MANchester | NRZ | SENT | SPI | UART | USB | USBPd}
```

The :SBUS<n>:MODE command determines the decode mode for the serial bus.

### NOTE

This command is only valid when a serial decode option has been licensed.

**Query Syntax**    `:SBUS<n>:MODE?`

The :SBUS<n>:MODE? query returns the current serial bus decode mode setting.

**Return Format**    `<mode><NL>`

```
<mode> ::= {A429 | FLEX | CAN | CXPI | I2S | IIC | LIN | M1553 | MANC
             | NRZ | SENT | SPI | UART | USB | USBP | NONE}
```

**Errors**

- ["-241, Hardware missing" on page 1607](#)

**See Also**

- ["Introduction to :SBUS<n> Commands" on page 905](#)
- [":SBUS<n>:A429 Commands" on page 910](#)
- [":SBUS<n>:CAN Commands" on page 929](#)
- [":SBUS<n>:FLEXray Commands" on page 976](#)
- [":SBUS<n>:I2S Commands" on page 995](#)
- [":SBUS<n>:IIC Commands" on page 1014](#)
- [":SBUS<n>:LIN Commands" on page 1025](#)
- [":SBUS<n>:M1553 Commands" on page 1044](#)
- [":SBUS<n>:SENT Commands" on page 1089](#)
- [":SBUS<n>:SPI Commands" on page 1125](#)
- [":SBUS<n>:UART Commands" on page 1142](#)
- [":SBUS<n>:USB Commands" on page 1164](#)

## :SBUS<n>:A429 Commands

**NOTE**

These commands are valid when the MIL-STD-1553 and ARINC 429 triggering and serial decode license has been enabled.

**Table 123** :SBUS<n>:A429 Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:A429:AUTOset up (see <a href="#">page 912</a> )	n/a	n/a
:SBUS<n>:A429:BASE <base> (see <a href="#">page 913</a> )	:SBUS<n>:A429:BASE? (see <a href="#">page 913</a> )	<base> ::= {BINary   HEX}
:SBUS<n>:A429:BAUDrat e <baudrate> (see <a href="#">page 914</a> )	:SBUS<n>:A429:BAUDrat e? (see <a href="#">page 914</a> )	<baudrate> ::= integer from 10000 to 1000000
n/a	:SBUS<n>:A429:COUNT:E RRor? (see <a href="#">page 915</a> )	<error_count> ::= integer in NR1 format
:SBUS<n>:A429:COUNT:R ESet (see <a href="#">page 916</a> )	n/a	n/a
n/a	:SBUS<n>:A429:COUNT:W ORD? (see <a href="#">page 917</a> )	<word_count> ::= integer in NR1 format
:SBUS<n>:A429:FORMAT <format> (see <a href="#">page 918</a> )	:SBUS<n>:A429:FORMAT? (see <a href="#">page 918</a> )	<format> ::= {LDSDi   LDSSm   LDATA}
:SBUS<n>:A429:SIGNAl <signal> (see <a href="#">page 919</a> )	:SBUS<n>:A429:SIGNAl? (see <a href="#">page 919</a> )	<signal> ::= {A   B   DIFFerential}
:SBUS<n>:A429:SOURce <source> (see <a href="#">page 920</a> )	:SBUS<n>:A429:SOURce? (see <a href="#">page 920</a> )	<source> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format
:SBUS<n>:A429:SPEed <speed> (see <a href="#">page 921</a> )	:SBUS<n>:A429:SPEed? (see <a href="#">page 921</a> )	<speed> ::= {LOW   HIGH   USER}

**Table 123** :SBUS<n>:A429 Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:A429:TRIGger :LABEL <value> (see <a href="#">page 922</a> )	:SBUS<n>:A429:TRIGger :LABEL? (see <a href="#">page 922</a> )	<value> ::= 8-bit integer in decimal, <hex>, <octal>, or <string> from 0-255 or "0xXX" (don't care)  <hex> ::= #Hnn where n ::= {0,...,9   A,...,F}  <octal> ::= #Qnnn where n ::= {0,...,7}  <string> ::= "0xnn" where n ::= {0,...,9   A,...,F}
:SBUS<n>:A429:TRIGger :PATTern:DATA <string> (see <a href="#">page 923</a> )	:SBUS<n>:A429:TRIGger :PATTern:DATA? (see <a href="#">page 923</a> )	<string> ::= "nn...n" where n ::= {0   1   X}, length depends on FORMat
:SBUS<n>:A429:TRIGger :PATTern:SDI <string> (see <a href="#">page 924</a> )	:SBUS<n>:A429:TRIGger :PATTern:SDI? (see <a href="#">page 924</a> )	<string> ::= "nn" where n ::= {0   1   X}, length always 2 bits
:SBUS<n>:A429:TRIGger :PATTern:SSM <string> (see <a href="#">page 925</a> )	:SBUS<n>:A429:TRIGger :PATTern:SSM? (see <a href="#">page 925</a> )	<string> ::= "nn" where n ::= {0   1   X}, length always 2 bits
:SBUS<n>:A429:TRIGger :RANGE <min>,<max> (see <a href="#">page 926</a> )	:SBUS<n>:A429:TRIGger :RANGE? (see <a href="#">page 926</a> )	<min> ::= 8-bit integer in decimal, <hex>, <octal>, or <string> from 0-255  <max> ::= 8-bit integer in decimal, <hex>, <octal>, or <string> from 0-255  <hex> ::= #Hnn where n ::= {0,...,9   A,...,F}  <octal> ::= #Qnnn where n ::= {0,...,7}  <string> ::= "0xnn" where n ::= {0,...,9   A,...,F}
:SBUS<n>:A429:TRIGger :TYPE <condition> (see <a href="#">page 927</a> )	:SBUS<n>:A429:TRIGger :TYPE? (see <a href="#">page 927</a> )	<condition> ::= {WSTArt   WSTOp   LABEL   LBITS   PERRor   WERRor   GERRor   WGERRors   ALLerrors   LRANGE   ABITS   AOBits   AZBits}

## :SBUS<n>:A429:AUTosetup

**N** (see [page 1666](#))

**Command Syntax** `:SBUS<n>:A429:AUTosetup`

The `:SBUS<n>:A429:AUTosetup` command automatically sets these options for decoding and triggering on ARINC 429 signals:

- High Trigger Threshold: 3.0 V.
- Low Trigger Threshold: -3.0 V.
- Noise Reject: Off.
- Probe Attenuation: 10.0.
- Vertical Scale: 4 V/div.
- Serial Decode: On.
- Base (`:SBUS<n>:A429:BASE`): HEX.
- Word Format (`:SBUS<n>:A429:FORMAT`): LDSDI (Label/SDI/Data/SSM).
- Trigger: the specified serial bus (n of `:SBUS<n>`).
- Trigger Mode (`:SBUS<n>:A429:TRIGger:TYPE`): WSTArt.

**Errors** • ["-241, Hardware missing" on page 1607](#)

**See Also** • [":SBUS<n>:A429:BASE" on page 913](#)  
• [":SBUS<n>:A429:FORMAT" on page 918](#)  
• [":SBUS<n>:A429:TRIGger:TYPE" on page 927](#)  
• ["Introduction to :SBUS<n> Commands" on page 905](#)  
• [":SBUS<n>:MODE" on page 909](#)  
• [":SBUS<n>:A429 Commands" on page 910](#)

## :SBUS<n>:A429:BASE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:A429:BASE <base>`  
`<base> ::= {BINary | HEX}`

The :SBUS<n>:A429:BASE command selects between hexadecimal and binary display of the decoded data.

The BASE command has no effect on the SDI and SSM fields, which are always displayed in binary, nor the Label field, which is always displayed in octal.

**Query Syntax**    `:SBUS<n>:A429:BASE?`  
The :SBUS<n>:A429:BASE? query returns the current ARINC 429 base setting.

**Return Format**    `<base><NL>`  
`<base> ::= {BIN | HEX}`

**Errors**    • ["-241, Hardware missing" on page 1607](#)

**See Also**    • ["Introduction to :SBUS<n> Commands" on page 905](#)  
• [":SBUS<n>:MODE" on page 909](#)  
• [":SBUS<n>:A429:FORMat" on page 918](#)

## :SBUS<n>:A429:BAUDrate

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:A429:BAUDrate <baudrate>`

`<baudrate> ::= integer from 10000 to 1000000`

When a user-defined baud rate is selected (with the ":SBUS<n>:A429:SPEEd USER" command), the :SBUS<n>:A429:BAUDrate command specifies the user-defined baud rate. The baud rate can be set in 100 b/s increments between 10000 and 100000 and in 1000 b/s increments between 100000 and 1000000.

**Query Syntax**    `:SBUS<n>:A429:BAUDrate?`

The :SBUS<n>:A429:BAUDrate? query returns the user-defined baud rate setting.

**Return Format**    `<baudrate><NL>`

**See Also**

- [":SBUS<n>:A429:SPEEd" on page 921](#)

**:SBUS<n>:A429:COUNt:ERRor**

**N** (see [page 1666](#))

**Query Syntax** :SBUS<n>:A429:COUNt:ERRor?

Returns the error count.

**Return Format** <error\_count><NL>

<error\_count> ::= integer in NR1 format

**Errors** • ["-241, Hardware missing" on page 1607](#)

**See Also** • [":SBUS<n>:A429:COUNt:RESet" on page 916](#)  
• [":SBUS<n>:A429:COUNt:WORD" on page 917](#)  
• ["Introduction to :SBUS<n> Commands" on page 905](#)  
• [":SBUS<n>:MODE" on page 909](#)  
• [":SBUS<n>:A429 Commands" on page 910](#)

## :SBUS<n>:A429:COUNt:RESet

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:A429:COUNt:RESet

Resets the word and error counters.

**Errors** • ["-241, Hardware missing" on page 1607](#)

**See Also** • [":SBUS<n>:A429:COUNt:WORD" on page 917](#)  
• [":SBUS<n>:A429:COUNt:ERRor" on page 915](#)  
• ["Introduction to :SBUS<n> Commands" on page 905](#)  
• [":SBUS<n>:MODE" on page 909](#)  
• [":SBUS<n>:A429 Commands" on page 910](#)

**:SBUS<n>:A429:COUNt:WORD****N** (see [page 1666](#))**Query Syntax** :SBUS<n>:A429:COUNt:WORD?

Returns the word count.

**Return Format** <word\_count><NL>

&lt;word\_count&gt; ::= integer in NR1 format

**Errors** • ["-241, Hardware missing" on page 1607](#)**See Also** • [":SBUS<n>:A429:COUNt:RESet" on page 916](#)• [":SBUS<n>:A429:COUNt:ERRor" on page 915](#)• ["Introduction to :SBUS<n> Commands" on page 905](#)• [":SBUS<n>:MODE" on page 909](#)• [":SBUS<n>:A429 Commands" on page 910](#)

## :SBUS<n>:A429:FORMat

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:A429:FORMAT <format>`  
`<format> ::= {LDSDi | LDSSm | LDATA}`

The :SBUS<n>:A429:FORMat command specifies the word decode format:

- LDSDi:
  - Label - 8 bits.
  - SDI - 2 bits.
  - Data - 19 bits.
  - SSM - 2 bits.
- LDSSm:
  - Label - 8 bits.
  - Data - 21 bits.
  - SSM - 2 bits.
- LDATA:
  - Label - 8 bits.
  - Data - 23 bits.

**Query Syntax**    `:SBUS<n>:A429:FORMAT?`

The :SBUS<n>:A429:FORMat? query returns the current ARINC 429 word decode format setting.

**Return Format**    `<format><NL>`  
`<format> ::= {LDSD | LDSS | LDAT}`

- Errors**    • ["-241, Hardware missing" on page 1607](#)

**See Also**    • ["Introduction to :SBUS<n> Commands" on page 905](#)  
 • [":SBUS<n>:MODE" on page 909](#)  
 • [":SBUS<n>:A429:TRIGger:PATTERn:DATA" on page 923](#)  
 • [":SBUS<n>:A429:TRIGger:PATTERn:SDI" on page 924](#)  
 • [":SBUS<n>:A429:TRIGger:PATTERn:SSM" on page 925](#)  
 • [":SBUS<n>:A429:TRIGger:TYPE" on page 927](#)  
 • [":SBUS<n>:A429:SIGNal" on page 919](#)  
 • [":SBUS<n>:A429:SPEEd" on page 921](#)  
 • [":SBUS<n>:A429:BASE" on page 913](#)  
 • [":SBUS<n>:A429:SOURce" on page 920](#)

## :SBUS<n>:A429:SIGNAl

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:A429:SIGNAl <signal>`  
`<signal> ::= {A | B | DIFFerential}`

The :SBUS<n>:A429:SIGNAl command specifies the signal type:

- A – Line A (non-inverted).
- B – Line B (inverted).
- DIFFerential – Differential (A-B).

**Query Syntax**    `:SBUS<n>:A429:SIGNAl?`

The :SBUS<n>:A429:SIGNAl? query returns the current ARINC 429 signal type setting.

**Return Format**    `<signal><NL>`  
`<signal> ::= {A | B | DIFF}`

**Errors**    • ["-241, Hardware missing" on page 1607](#)

**See Also**    • ["Introduction to :SBUS<n> Commands" on page 905](#)  
• [":SBUS<n>:MODE" on page 909](#)  
• [":SBUS<n>:A429:FORMat" on page 918](#)  
• [":SBUS<n>:A429:SPEEd" on page 921](#)  
• [":SBUS<n>:A429:SOURce" on page 920](#)

## :SBUS<n>:A429:SOURce

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:A429:SOURce &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;}</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	The :SBUS<n>:A429:SOURce command sets the source of the ARINC 429 signal.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:A429:SOURce?</code>
	The :SBUS<n>:A429:SOURce? query returns the currently set source of the ARINC 429 signal.
	Use the :TRIGger:LEVel:HIGH and :TRIGger:LEVel:LOW commands to set the threshold levels for the selected source.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:TRIGger:LEVel:HIGH</a>" on page 1360</li> <li>· "<a href="#">:TRIGger:LEVel:LOW</a>" on page 1361</li> <li>· "<a href="#">:TRIGger:MODE</a>" on page 1362</li> <li>· "<a href="#">:SBUS&lt;n&gt;:MODE</a>" on page 909</li> <li>· "<a href="#">:SBUS&lt;n&gt;:A429:TRIGger:TYPE</a>" on page 927</li> <li>· "<a href="#">:SBUS&lt;n&gt;:A429:SIGNal</a>" on page 919</li> <li>· "<a href="#">:SBUS&lt;n&gt;:A429:SPEed</a>" on page 921</li> <li>· "<a href="#">:SBUS&lt;n&gt;:A429:FORMAT</a>" on page 918</li> <li>· "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> </ul>

## :SBUS<n>:A429:SPEed

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:A429:SPEed <speed>`  
`<speed> ::= {LOW | HIGH | USER}`

The :SBUS<n>:A429:SPEed command specifies the signal speed:

- LOW – 12.5 kb/s.
- HIGH – 100 kb/s.
- USER – lets you specify a user-defined baud rate using the :SBUS<n>:A429:BAUDrate command.

**Query Syntax**    `:SBUS<n>:A429:SPEed?`

The :SBUS<n>:A429:SPEed? query returns the current ARINC 429 signal speed setting.

**Return Format**    `<speed><NL>`  
`<speed> ::= {LOW | HIGH | USER}`

- Errors**    • ["-241, Hardware missing" on page 1607](#)

**See Also**    • [":SBUS<n>:A429:BAUDrate" on page 914](#)  
• ["Introduction to :SBUS<n> Commands" on page 905](#)  
• [":SBUS<n>:MODE" on page 909](#)  
• [":SBUS<n>:A429:SIGNal" on page 919](#)  
• [":SBUS<n>:A429:FORMAT" on page 918](#)  
• [":SBUS<n>:A429:SOURce" on page 920](#)

## :SBUS<n>:A429:TRIGger:LABEL

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:A429:TRIGger:LABEL <value>`

`<value> ::= 8-bit integer in decimal, <hex>, <octal>, or <string>`  
`from 0-255 or "0xXX" (don't care)`

`<hex> ::= #Hnn where n ::= {0,...,9 | A,...,F}`

`<octal> ::= #Qnnn where n ::= {0,...,7}`

`<string> ::= "0xnn" where n ::= {0,...,9 | A,...,F}`

The :SBUS<n>:A429:TRIGger:LABEL command defines the ARINC 429 label value when labels are used in the selected trigger type.

To set the label value to don't cares (0xXX), set the value to -1.

**Query Syntax**    `:SBUS<n>:A429:TRIGger:LABEL?`

The :SBUS<n>:A429:TRIGger:LABEL? query returns the current label value in decimal format.

**Return Format**    `<value><NL>` in decimal format

**Errors**    • ["-241, Hardware missing" on page 1607](#)

**See Also**    • ["Introduction to :TRIGger Commands" on page 1349](#)  
• [":SBUS<n>:A429:TRIGger:TYPE" on page 927](#)

## :SBUS<n>:A429:TRIGger:PATTERn:DATA

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:A429:TRIGger:PATTERn:DATA <string>`  
`<string> ::= "nn...n" where n ::= {0 | 1 | X}, length depends on FORMat`

The :SBUS<n>:A429:TRIGger:PATTERn:DATA command defines the ARINC 429 data pattern resource according to the string parameter. This pattern controls the data pattern searched for in each ARINC 429 word.

### NOTE

If more bits are sent for <string> than specified by the :SBUS<n>:A429:FORMat command, the most significant bits will be truncated.

**Query Syntax**    `:SBUS<n>:A429:TRIGger:PATTERn:DATA?`

The :SBUS<n>:A429:TRIGger:PATTERn:DATA? query returns the current settings of the specified ARINC 429 data pattern resource in the binary string format.

**Return Format**    `<string><NL> in nondecimal format`

**Errors**

- ["-241, Hardware missing" on page 1607](#)

**See Also**

- ["Introduction to :TRIGger Commands" on page 1349](#)
- [":SBUS<n>:A429:TRIGger:TYPE" on page 927](#)
- [":SBUS<n>:A429:TRIGger:PATTERn:SDI" on page 924](#)
- [":SBUS<n>:A429:TRIGger:PATTERn:SSM" on page 925](#)

## :SBUS<n>:A429:TRIGger:PATTERn:SDI

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:A429:TRIGger:PATTERn:SDI &lt;string&gt;</code> <code>&lt;string&gt; ::= "nn" where n ::= {0   1   X}, length always 2 bits</code>
The :SBUS<n>:A429:TRIGger:PATTERn:SDI command defines the ARINC 429 two-bit SDI pattern resource according to the string parameter. This pattern controls the SDI pattern searched for in each ARINC 429 word.	
The specified SDI is only used if the :SBUS<n>:A429:FORMAT includes the SDI field.	

<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:A429:TRIGger:PATTERn:SDI?</code>
The :SBUS<n>:A429:TRIGger:PATTERn:SDI? query returns the current settings of the specified ARINC 429 two-bit SDI pattern resource in the binary string format.	
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code> in nondecimal format
<b>Errors</b>	<ul style="list-style-type: none"> <li>• <a href="#">"-241, Hardware missing" on page 1607</a></li> </ul>

<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">"Introduction to :TRIGger Commands" on page 1349</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:A429:FORMAT" on page 918</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:A429:TRIGger:TYPE" on page 927</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:A429:TRIGger:PATTERn:DATA" on page 923</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:A429:TRIGger:PATTERn:SSM" on page 925</a></li> </ul>
-----------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

## :SBUS<n>:A429:TRIGger:PATTERn:SSM

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:A429:TRIGger:PATTERn:SSM &lt;string&gt;</code> <code>&lt;string&gt; ::= "nn" where n ::= {0   1   X}, length always 2 bits</code>
	The :SBUS<n>:A429:TRIGger:PATTERn:SSM command defines the ARINC 429 two-bit SSM pattern resource according to the string parameter. This pattern controls the SSM pattern searched for in each ARINC 429 word.
	The specified SSM is only used if the :SBUS<n>:A429:FORMat includes the SSM field.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:A429:TRIGger:PATTERn:SSM?</code>
	The :SBUS<n>:A429:TRIGger:PATTERn:SSM? query returns the current settings of the specified ARINC 429 two-bit SSM pattern resource in the binary string format.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code> in nondecimal format
<b>Errors</b>	<ul style="list-style-type: none"> <li>• <a href="#">"-241, Hardware missing" on page 1607</a></li> </ul>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">"Introduction to :TRIGger Commands" on page 1349</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:A429:FORMat" on page 918</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:A429:TRIGger:TYPE" on page 927</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:A429:TRIGger:PATTERn:DATA" on page 923</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:A429:TRIGger:PATTERn:SDI" on page 924</a></li> </ul>

## :SBUS<n>:A429:TRIGger:RANGE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:A429:TRIGger:RANGE <min>,<max>`

```

<min> ::= 8-bit integer in decimal, <hex>, <octal>, or <string>
          from 0-255

<max> ::= 8-bit integer in decimal, <hex>, <octal>, or <string>
          from 0-255

<hex> ::= #Hnn where n ::= {0,...,9 | A,...,F}

<octal> ::= #Qnnn where n ::= {0,...,7}

<string> ::= "0xnn" where n ::= {0,...,9 | A,...,F}
```

The :SBUS<n>:A429:TRIGger:RANGE command defines a range of ARINC 429 label values. This range is used when the LRANGE trigger type is selected.

**Query Syntax**    `:SBUS<n>:A429:TRIGger:RANGE?`

The :SBUS<n>:A429:TRIGger:RANGE? query returns the current label values in decimal format.

**Return Format**    `<min>,<max><NL>` in decimal format

**Errors**    • ["-241, Hardware missing" on page 1607](#)

**See Also**    • ["Introduction to :TRIGger Commands" on page 1349](#)  
               • [":SBUS<n>:A429:TRIGger:TYPE" on page 927](#)

## :SBUS<n>:A429:TRIGger:TYPE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:A429:TRIGger:TYPE <condition>`

```
<condition> ::= {WSTArt | WSTOp | LABel | LBITS | PERRor | WERRor
                  | GERRor | WGERrors | ALLerrors | LRANge | ABITs
                  | AOBits | AZBits}
```

The :SBUS<n>:A429:TRIGger command sets the ARINC 429 trigger on condition:

- WSTArt – triggers on the start of a word.
- WSTOp – triggers at the end of a word.
- LABel – triggers on the specified label value.
- LBITS – triggers on the label and the other word fields as specified.
- LRANge – triggers on a label within a min/max range.
- PERRor – triggers on words with a parity error.
- WERRor – triggers on an intra-word coding error.
- GERRor – triggers on an inter-word gap error.
- WGERrors – triggers on either a Word or Gap Error.
- ALLerrors – triggers on any of the above errors.
- ABITs – triggers on any bit, which will therefore form an eye diagram.
- AZBits – triggers on any bit with a value of zero.
- AOBits – triggers on any bit with a value of one.

**Query Syntax**    `:SBUS<n>:A429:TRIGger:TYPE?`

The :SBUS<n>:A429:TRIGger:TYPE? query returns the current ARINC 429 trigger on condition.

**Return Format**    `<condition><NL>`

```
<condition> ::= {WSTA | WSTO | LAB | LBIT | PERR | WERR | GERR | WGER
                  | ALL | LRAN | ABIT | AOB | AZB}
```

- Errors**
  - ["-241, Hardware missing"](#) on page 1607

**See Also**

- ["Introduction to :SBUS<n> Commands"](#) on page 905
- [":SBUS<n>:MODE"](#) on page 909
- [":SBUS<n>:A429:TRIGger:LABEL"](#) on page 922
- [":SBUS<n>:A429:TRIGger:PATTERn:DATA"](#) on page 923
- [":SBUS<n>:A429:TRIGger:PATTERn:SDI"](#) on page 924
- [":SBUS<n>:A429:TRIGger:PATTERn:SSM"](#) on page 925
- [":SBUS<n>:A429:TRIGger:RANGE"](#) on page 926

33 :SBUS<n> Commands

- [":SBUS<n>:A429:SOURce" on page 920](#)

## :SBUS<n>:CAN Commands

**NOTE**

These commands are valid when the CAN and LIN serial decode license has been enabled.

**Table 124** :SBUS<n>:CAN Commands Summary

Command	Query	Options and Query Returns
n/a	:SBUS<n>:CAN:COUNT:ER Ror? (see <a href="#">page 932</a> )	<frame_count> ::= integer in NR1 format
n/a	:SBUS<n>:CAN:COUNT:OV ERload? (see <a href="#">page 933</a> )	<frame_count> ::= 0 in NR1 format
:SBUS<n>:CAN:COUNT:RE Set (see <a href="#">page 934</a> )	n/a	n/a
n/a	:SBUS<n>:CAN:COUNT:SP EC? (see <a href="#">page 935</a> )	<spec_error_count> ::= integer in NR1 format
n/a	:SBUS<n>:CAN:COUNT:TO Tal? (see <a href="#">page 936</a> )	<frame_count> ::= integer in NR1 format
n/a	:SBUS<n>:CAN:COUNT:UT ILization? (see <a href="#">page 937</a> )	<percent> ::= floating-point in NR3 format
:SBUS<n>:CAN:DISPLAY <type> (see <a href="#">page 938</a> )	:SBUS<n>:CAN:DISPLAY? (see <a href="#">page 938</a> )	<type> ::= {HEXadecimal   SYMBOLic}
:SBUS<n>:CAN:FDSPoint <value> (see <a href="#">page 939</a> )	:SBUS<n>:CAN:FDSPoint ? (see <a href="#">page 939</a> )	<value> ::= even numbered percentages from 30 to 90 in NR3 format.
:SBUS<n>:CAN:FDSTanda rd <std> (see <a href="#">page 940</a> )	:SBUS<n>:CAN:FDSTanda rd? (see <a href="#">page 940</a> )	<std> ::= {ISO   NISO}
:SBUS<n>:CAN:SAMPLEpo int <percent> (see <a href="#">page 941</a> )	:SBUS<n>:CAN:SAMPLEpo int? (see <a href="#">page 941</a> )	<percent> ::= 30.0 to 90.0 in NR3 format
:SBUS<n>:CAN:SIGNAl:B AUDrate <baudrate> (see <a href="#">page 942</a> )	:SBUS<n>:CAN:SIGNAl:B AUDrate? (see <a href="#">page 942</a> )	<baudrate> ::= integer from 10000 to 4000000 in 100 b/s increments, or 5000000
:SBUS<n>:CAN:SIGNAl:D EFinition <value> (see <a href="#">page 943</a> )	:SBUS<n>:CAN:SIGNAl:D EFinition? (see <a href="#">page 943</a> )	<value> ::= {CANH   CANL   RX   TX   DIFFerential   DIFL   DIFH}
:SBUS<n>:CAN:SIGNAl:F DBaudrate <baudrate> (see <a href="#">page 944</a> )	:SBUS<n>:CAN:SIGNAl:F DBaudrate? (see <a href="#">page 944</a> )	<baudrate> ::= integer from 10000 to 10000000 in 100 b/s increments.

**Table 124** :SBUS<n>:CAN Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:CAN:SOURCE <source> (see page 945)	:SBUS<n>:CAN:SOURce? (see <a href="#">page 945</a> )	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   EXTernal} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   } for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p>
:SBUS<n>:CAN:TRIGger <condition> (see page 946)	:SBUS<n>:CAN:TRIGger? (see <a href="#">page 947</a> )	<p>&lt;condition&gt; ::= {SOF   EOF   IDData   DATA   FDData   IDRemeTe   IDEither   ERRor   ACKerror   FORMerror   STUFFerror   CRCerror   SPECerror   ALLerrors   BRsBit   CRCDBit   EBActive   EBPassive   OVERload   MESSage   MSIGnal   FDMSignal}</p>
:SBUS<n>:CAN:TRIGger: IDFilter { {0   OFF}   {1   ON}} (see page 949)	:SBUS<n>:CAN:TRIGger: IDFilter? (see <a href="#">page 949</a> )	{0   1}
:SBUS<n>:CAN:TRIGger: PATtern:DATA <string> (see <a href="#">page 950</a> )	:SBUS<n>:CAN:TRIGger: PATtern:DATA? (see <a href="#">page 950</a> )	<p>&lt;string&gt; ::= "nn...n" where n ::= {0   1   X   \$}</p> <p>&lt;string&gt; ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$}</p>
:SBUS<n>:CAN:TRIGger: PATtern:DATA:DLC <dLC> (see <a href="#">page 951</a> )	:SBUS<n>:CAN:TRIGger: PATtern:DATA:DLC? (see <a href="#">page 951</a> )	<p>&lt;dLC&gt; ::= integer between -1 (don't care) and 64, in NR1 format.</p>
:SBUS<n>:CAN:TRIGger: PATtern:DATA:LENGTH <length> (see <a href="#">page 952</a> )	:SBUS<n>:CAN:TRIGger: PATtern:DATA:LENGTH? (see <a href="#">page 952</a> )	<p>&lt;length&gt; ::= integer from 1 to 8 in NR1 format</p>
:SBUS<n>:CAN:TRIGger: PATtern:DATA:START <start> (see <a href="#">page 953</a> )	:SBUS<n>:CAN:TRIGger: PATtern:DATA:START? (see <a href="#">page 953</a> )	<p>&lt;start&gt; ::= integer between 0 and 63, in NR1 format.</p>
:SBUS<n>:CAN:TRIGger: PATtern:ID <string> (see <a href="#">page 954</a> )	:SBUS<n>:CAN:TRIGger: PATtern:ID? (see <a href="#">page 954</a> )	<p>&lt;string&gt; ::= "nn...n" where n ::= {0   1   X   \$}</p> <p>&lt;string&gt; ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$}</p>
:SBUS<n>:CAN:TRIGger: PATtern:ID:MODE <value> (see <a href="#">page 955</a> )	:SBUS<n>:CAN:TRIGger: PATtern:ID:MODE? (see <a href="#">page 955</a> )	<p>&lt;value&gt; ::= {STANDARD   EXTENDED}</p>

**Table 124** :SBUS<n>:CAN Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:CAN:TRIGger: SYMBolic:MESSage <name> (see page 956)	:SBUS<n>:CAN:TRIGger: SYMBolic:MESSage? (see page 956)	<name> ::= quoted ASCII string
:SBUS<n>:CAN:TRIGGER: SYMBolic:SIGNAl <name> (see page 957)	:SBUS<n>:CAN:TRIGGER: SYMBolic:SIGNAl? (see page 957)	<name> ::= quoted ASCII string
:SBUS<n>:CAN:TRIGger: SYMBolic:VALue <data> (see page 958)	:SBUS<n>:CAN:TRIGger: SYMBolic:VALue? (see page 958)	<data> ::= value in NR3 format

## :SBUS<n>:CAN:COUNT:ERRor

**N** (see [page 1666](#))

**Query Syntax**    `:SBUS<n>:CAN:COUNT:ERRor?`

Returns the error frame count.

**Return Format**    `<frame_count><NL>`

`<frame_count> ::= integer in NR1 format`

**Errors**    • ["-241, Hardware missing" on page 1607](#)

**See Also**    • [":SBUS<n>:CAN:COUNt:RESet" on page 934](#)  
          • ["Introduction to :SBUS<n> Commands" on page 905](#)  
          • [":SBUS<n>:MODE" on page 909](#)  
          • [":SBUS<n>:CAN Commands" on page 929](#)

## :SBUS<n>:CAN:COUNT:OVERload

**N** (see [page 1666](#))

**Query Syntax** :SBUS<n>:CAN:COUNT:OVERload?

Returns the overload frame count.

**Return Format** <frame\_count><NL>

<frame\_count> ::= 0 in NR1 format

**Errors** • ["-241, Hardware missing"](#) on page 1607

**See Also** • [":SBUS<n>:CAN:COUNt:RESet"](#) on page 934  
• ["Introduction to :SBUS<n> Commands"](#) on page 905  
• [":SBUS<n>:MODE"](#) on page 909  
• [":SBUS<n>:CAN Commands"](#) on page 929

## :SBUS<n>:CAN:COUNT:RESet

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:CAN:COUNT:RESet

Resets the frame counters.

**Errors** • ["-241, Hardware missing" on page 1607](#)

**See Also** • [":SBUS<n>:CAN:COUNT:ERRor" on page 932](#)  
• [":SBUS<n>:CAN:COUNT:OVERload" on page 933](#)  
• [":SBUS<n>:CAN:COUNT:TOTal" on page 936](#)  
• [":SBUS<n>:CAN:COUNT:UTILization" on page 937](#)  
• ["Introduction to :SBUS<n> Commands" on page 905](#)  
• [":SBUS<n>:MODE" on page 909](#)  
• [":SBUS<n>:CAN Commands" on page 929](#)

## :SBUS<n>:CAN:COUNT:SPEC

**N** (see [page 1666](#))

**Query Syntax** :SBUS<n>:CAN:COUNT:SPEC?

Returns the Spec error (Ack + Form + Stuff + CRC errors) count.

**Return Format** <spec\_error\_count><NL>

<spec\_error\_count> ::= integer in NR1 format

**Errors** • ["-241, Hardware missing" on page 1607](#)

**See Also** • [":SBUS<n>:CAN:COUNt:RESet" on page 934](#)  
• ["Introduction to :SBUS<n> Commands" on page 905](#)  
• [":SBUS<n>:MODE" on page 909](#)  
• [":SBUS<n>:CAN Commands" on page 929](#)

**:SBUS<n>:CAN:COUNT:TOTal****N** (see [page 1666](#))**Query Syntax**    `:SBUS<n>:CAN:COUNT:TOTal?`

Returns the total frame count.

**Return Format**    `<frame_count><NL>``<frame_count> ::= integer in NR1 format`**Errors**    • ["-241, Hardware missing"](#) on page 1607**See Also**    • [":SBUS<n>:CAN:COUNt:RESet"](#) on page 934  
• ["Introduction to :SBUS<n> Commands"](#) on page 905  
• [":SBUS<n>:MODE"](#) on page 909  
• [":SBUS<n>:CAN Commands"](#) on page 929

## :SBUS<n>:CAN:COUNT:UTILization

**N** (see [page 1666](#))

**Query Syntax** :SBUS<n>:CAN:COUNT:UTILization?

Returns the percent utilization.

**Return Format** <percent><NL>

<percent> ::= floating-point in NR3 format

**Errors** • ["-241, Hardware missing"](#) on page 1607

**See Also** • [":SBUS<n>:CAN:COUNt:RESet"](#) on page 934  
• ["Introduction to :SBUS<n> Commands"](#) on page 905  
• [":SBUS<n>:MODE"](#) on page 909  
• [":SBUS<n>:CAN Commands"](#) on page 929

## :SBUS<n>:CAN:DISPlay

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:CAN:DISPlay <type>`  
`<type> ::= {HEXadecimAl | SYMBolic}`

The :SBUS<n>:CAN:DISPlay command specifies, when CAN symbolic data is loaded into the oscilloscope, whether symbolic values (from the DBC file) or hexadecimal values are displayed in the decode waveform and the Lister window.

**Query Syntax**    `:SBUS<n>:CAN:DISPlay?`

The :SBUS<n>:CAN:DISPlay? query returns the CAN decode display type.

**Return Format**    `<type><NL>`  
`<type> ::= {HEX | SYMB}`

**See Also**    · [":RECall:DBC\[:STARt\]" on page 865](#)

## :SBUS<n>:CAN:FDSPoint

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:CAN:FDSPoint <value>`  
`<value> ::= even numbered percentages from 30 to 90 in NR3 format.`

The :SBUS<n>:CAN:FDSPoint command sets the point during the bit time where the bit level is sampled to determine whether the bit is dominant or recessive. The sample point represents the percentage of time between the beginning of the bit time to the end of the bit time.

**Query Syntax**    `:SBUS<n>:CAN:FDSPoint?`

The :SBUS<n>:CAN:FDSPoint? query returns the current CAN FD sample point setting.

**Return Format**    `<value><NL>`  
`<value> ::= even numbered percentages from 30 to 90 in NR3 format.`

**See Also**

- [":SBUS<n>:CAN:SIGNAl:FDBaudrate"](#) on page 944

## :SBUS<n>:CAN:FDSTandard

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:CAN:FDSTandard <std>`  
`<std> ::= {ISO | NISO}`

The :SBUS<n>:CAN:FDSTandard command lets you pick the standard that will be used when decoding or triggering on FD frames, ISO, or non-ISO.

This setting has no effect on the processing of non-FD (classical) frames.

**Query Syntax**    `:SBUS<n>:CAN:FDSTandard?`

The :SBUS<n>:CAN:FDSTandard? query returns the selected CAN FD frame decode standard.

**Return Format**    `<std>`  
`<std> ::= {ISO | NISO}`

**See Also**    • [":SBUS<n>:CAN:FDSPoint"](#) on page 939

## :SBUS<n>:CAN:SAMPLEpoint

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:CAN:SAMPLEpoint <percent>

<percent><NL>

<percent> ::= 30.0 to 90.0 in NR3 format

The :SBUS<n>:CAN:SAMPLEpoint command sets the point during the bit time where the bit level is sampled to determine whether the bit is dominant or recessive. The sample point represents the percentage of time between the beginning of the bit time to the end of the bit time.

**Query Syntax** :SBUS<n>:CAN:SAMPLEpoint?

The :SBUS<n>:CAN:SAMPLEpoint? query returns the current CAN sample point setting.

**Return Format** <percent><NL>

<percent> ::= 30.0 to 90.0 in NR3 format

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":SBUS<n>:MODE](#)" on page 909
- "[":SBUS<n>:CAN:TRIGger](#)" on page 946

## :SBUS<n>:CAN:SIGNAl:BAUDrate

**N** (see [page 1666](#))

**Command Syntax**

```
:SBUS<n>:CAN:SIGNAl:BAUDrate <baudrate>
<baudrate> ::= integer from 10000 to 4000000 in 100 b/s increments,
               or 5000000
```

The :SBUS<n>:CAN:SIGNAl:BAUDrate command sets the standard baud rate of the CAN signal from 10 kb/s to 4 Mb/s in 100 b/s increments. If you enter a baud rate that is not divisible by 100 b/s, the baud rate is set to the nearest baud rate divisible by 100 b/s.

You can also set the baud rate of the CAN signal to 5 Mb/s. Fractional baud rates between 4 Mb/s and 5 Mb/s are not allowed.

If the baud rate you select does not match the system baud rate, false triggers may occur.

**Query Syntax**

```
:SBUS<n>:CAN:SIGNAl:BAUDrate?
```

The :SBUS<n>:CAN:SIGNAl:BAUDrate? query returns the current CAN baud rate setting.

**Return Format**

```
<baudrate><NL>
<baudrate> ::= integer from 10000 to 4000000 in 100 b/s increments,
               or 5000000
```

**See Also**

- ["Introduction to :TRIGger Commands" on page 1349](#)
- [":SBUS<n>:MODE" on page 909](#)
- [":SBUS<n>:CAN:TRIGger" on page 946](#)
- [":SBUS<n>:CAN:SIGNAl:DEFinition" on page 943](#)
- [":SBUS<n>:CAN:SOURce" on page 945](#)

## :SBUS<n>:CAN:SIGNAl:DEFinition

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:CAN:SIGNAl:DEFinition &lt;value&gt;</code> <code>&lt;value&gt; ::= {CANH   CANL   RX   TX   DIFFerential   DIFL   DIFH}</code>
	The :SBUS<n>:CAN:SIGNAl:DEFinition command sets the CAN signal type when :SBUS<n>:CAN:TRIGger is set to SOF (start of frame). These signals can be set to:
	Dominant high signals:
	<ul style="list-style-type: none"> <li>• CANH – the actual CAN_H differential bus signal.</li> <li>• DIFH – the CAN differential (H-L) bus signal connected to an analog source channel using a differential probe.</li> </ul>
	Dominant low signals:
	<ul style="list-style-type: none"> <li>• CANL – the actual CAN_L differential bus signal.</li> <li>• RX – the Receive signal from the CAN bus transceiver.</li> <li>• TX – the Transmit signal to the CAN bus transceiver.</li> <li>• DIFL – the CAN differential (L-H) bus signal connected to an analog source channel using a differential probe.</li> <li>• DIFFerential – the CAN differential bus signal connected to an analog source channel using a differential probe. This is the same as DIFL.</li> </ul>
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:CAN:SIGNAl:DEFinition?</code>
	The :SBUS<n>:CAN:SIGNAl:DEFinition? query returns the current CAN signal type.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code> <code>&lt;value&gt; ::= {CANH   CANL   RX   TX   DIFL   DIFH}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">:SBUS&lt;n&gt;:MODE</a>" on page 909</li> <li>• "<a href="#">:SBUS&lt;n&gt;:CAN:SIGNAl:BAUDrate</a>" on page 942</li> <li>• "<a href="#">:SBUS&lt;n&gt;:CAN:SOURce</a>" on page 945</li> <li>• "<a href="#">:SBUS&lt;n&gt;:CAN:TRIGger</a>" on page 946</li> </ul>

## :SBUS<n>:CAN:SIGNAl:FDBaudrate

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:CAN:SIGNAl:FDBaudrate <baudrate>`  
`<baudrate> ::= integer from 10000 to 10000000 in 100 b/s increments.`

The :SBUS<n>:CAN:SIGNAl:FDBaudrate command sets the CAN FD baud rate from 10 kb/s to 10 Mb/s in 100 b/s increments. If you enter a baud rate that is not divisible by 100 b/s, the baud rate is set to the nearest baud rate divisible by 100 b/s.

For CAN FD, both the standard rate settings (see :SBUS<n>:CAN:SIGNAl:BAUDrate) and the FD rate settings must be set correctly; otherwise, false triggers may occur.

**Query Syntax**    `:SBUS<n>:CAN:SIGNAl:FDBaudrate?`

The :SBUS<n>:CAN:SIGNAl:FDBaudrate? query returns the current CAN FD baud rate setting.

**Return Format**    `<baudrate><NL>`  
`<baudrate> ::= integer from 10000 to 10000000 in 100 b/s increments.`

**See Also**

- [":SBUS<n>:CAN:FDSPoint"](#) on page 939
- [":SBUS<n>:CAN:SIGNAl:BAUDrate"](#) on page 942

## :SBUS<n>:CAN:SOURce

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:CAN:SOURce &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   EXTERNAL} for the DSO models</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;} for the MSO models</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	The :SBUS<n>:CAN:SOURce command sets the source for the CAN signal.

<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:CAN:SOURce?</code>
	The :SBUS<n>:CAN:SOURce? query returns the current source for the CAN signal.

<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
----------------------	---------------------------------------

<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">:SBUS&lt;n&gt;:MODE</a>" on page 909</li> <li>• "<a href="#">:SBUS&lt;n&gt;:CAN:TRIGger</a>" on page 946</li> <li>• "<a href="#">:SBUS&lt;n&gt;:CAN:SIGNal:DEFinition</a>" on page 943</li> </ul>
-----------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

## :SBUS<n>:CAN:TRIGger

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:CAN:TRIGger <condition>

```
<condition> ::= {SOF | EOF | IDData | DATA | FDData | IDRemote
    | IDEEither | ERRor | ACKerror | FORMrror | STUFFerror | CRCerror
    | SPECerror | ALLerrors | BRSBit | CRCDbit | EBActive | EBPassive
    | OVERload | MESSage | MSIGnal | FDMSignal}
```

The :SBUS<n>:CAN:TRIGger command sets the CAN trigger on condition:

Condition	Front-panel name	Description	Filter by ID*
SOF	SOF - Start of Frame	Triggers at the start bit for both data and overload frames.	
EOF	EOF - End of Frame	Triggers at the end of any frame.	X
IDEEither	Frame ID	Triggers on any standard CAN (data or remote) or CAN FD frame at the end of the 11- or 29-bit ID field.	
IDData	Data Frame ID (non-FD)	Triggers on standard CAN data frames at the end of the 11- or 29-bit ID field.	
DATA	Data Frame ID and Data (non-FD)	Triggers on any standard CAN data frame at the end of the last data byte defined in the trigger. The DLC of the packet must match the number of bytes specified.	
FDData	Data Frame ID and Data (FD)	triggers on CAN FD frames at the end of the last data byte defined in the trigger. You can trigger on up to 8 bytes of data anywhere within the CAN FD data, which can be up to 64 bytes long.	
IDRemote	Remote Frame ID	Triggers on standard CAN remote frames at the end of the 11- or 29-bit ID field.	
ERRor	Error Frame	Triggers after 6 consecutive 0s while in a data frame, at the EOF.	X
ACKerror	Acknowledge Error	Triggers on the acknowledge bit if the polarity is incorrect.	X
FORMrror	Form Error	Triggers on reserved bit errors.	X
STUFFerror	Stuff Error	Triggers on 6 consecutive 1s or 6 consecutive 0s, while in a non-error or non overload frame.	X

Condition	Front-panel name	Description	Filter by ID*
CRCerror	CRC Field Error	Triggers when the calculated CRC does not match the transmitted CRC. In addition, for FD frames, will also trigger if the Stuff Count is in error.	X
SPECerror	Spec Error (Ack or Form or Stuff or CRC)	Triggers on Ack, Form, Stuff, or CRC errors.	X
ALLerrors	All Errors	Triggers on all Spec errors and error frames.	X
BRSBIt	BRS Bit (FD)	Triggers on the BRS bit of CAN FD frames.	X
CRCDbit	CRC Delimiter Bit (FD)	Triggers on the CRC delimiter bit in CAN FD frames.	X
EBAActive	ESI Bit Active (FD)	Triggers on the ESI bit if set active.	X
EBPassive	ESI Bit Passive (FD)	Triggers on the ESI bit if set passive.	X
OVERload	Overload Frame	Triggers on an overload frame.	
MESSage	Message	Triggers on a symbolic message.	
MSIGnal	Message and Signal (non-FD)	Triggers on a symbolic message and a signal value.	
FDMSignal	Message and Signal (FD, first 8 bytes only)	Triggers on a symbolic message and a signal value, limited to the first 8 bytes of FD data.	

\* Filtering by CAN IDs is available for these trigger conditions (see :SBUS<n>:CAN:TRIGger:IDFilter).

CAN Id specification is set by the :SBUS<n>:CAN:TRIGger:PATTern:ID and :SBUS<n>:CAN:TRIGger:PATTern:ID:MODE commands.

CAN Data specification is set by the :SBUS<n>:CAN:TRIGger:PATTern:DATA command.

CAN Data Length Code is set by the :SBUS<n>:CAN:TRIGger:PATTern:DATA:LENGth command.

**Query Syntax** :SBUS<n>:CAN:TRIGger?

The :SBUS<n>:CAN:TRIGger? query returns the current CAN trigger on condition.

**Return Format** <condition><NL>

```
<condition> ::= { SOF | EOF | IDD | DATA | FDD | IDR | IDE | ERR | ACK
    | FORM | STUF | CRC | SPEC | ALL | BRSB | CRCD | EBA | EBP | OVER
    | MESS | MSIG | FDMS }
```

**Errors** • "-241, Hardware missing" on page 1607

**See Also** • "Introduction to :SBUS<n> Commands" on page 905

- "[:SBUS<n>:MODE](#)" on page 909
- "[:SBUS<n>:CAN:TRIGger:PATTERn:DATA](#)" on page 950
- "[:SBUS<n>:CAN:TRIGger:PATTERn:DATA:LENGth](#)" on page 952
- "[:SBUS<n>:CAN:TRIGger:PATTERn:ID](#)" on page 954
- "[:SBUS<n>:CAN:TRIGger:PATTERn:ID:MODE](#)" on page 955
- "[:SBUS<n>:CAN:TRIGger:IDFilter](#)" on page 949
- "[:SBUS<n>:CAN:SIGNAL:DEFinition](#)" on page 943
- "[:SBUS<n>:CAN:SOURce](#)" on page 945
- "[:RECall:DBC\[:STARt\]](#)" on page 865
- "[:SBUS<n>:CAN:TRIGger:SYMBOLic:MESSAge](#)" on page 956
- "[:SBUS<n>:CAN:TRIGger:SYMBOLic:SIGNAl](#)" on page 957
- "[:SBUS<n>:CAN:TRIGger:SYMBOLic:VALue](#)" on page 958

## :SBUS<n>:CAN:TRIGger:IDFilter

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:CAN:TRIGger:IDFilter {{0 | OFF} | {1 | ON}}

The :SBUS<n>:CAN:TRIGger:IDFilter command specifies, in certain error and bit trigger modes, whether triggers are filtered by CAN IDs.

**Query Syntax** :SBUS<n>:CAN:TRIGger:IDFilter?

The :SBUS<n>:CAN:TRIGger:IDFilter? query returns the CAN trigger ID filter setting.

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

**See Also** • "[:SBUS<n>:CAN:TRIGger](#)" on page 946

## :SBUS<n>:CAN:TRIGger:PATTern:DATA

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:CAN:TRIGger:PATTern:DATA <string>`

`<string> ::= "nn...n" where n ::= {0 | 1 | X | $}`

`<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | X | $}`

The :SBUS<n>:CAN:TRIGger:PATTern:DATA command defines the CAN data pattern resource according to the string parameter. This pattern, along with the data length (set by the :SBUS<n>:CAN:TRIGger:PATTern:DATA:LENGth command), control the data pattern searched for in each CAN message.

If the string parameter starts with "0x", it is a hexadecimal string made up of hexadecimal and X (don't care) characters; otherwise, it is a binary string made up of 0, 1, and X (don't care) characters.

### NOTE

If more bits are sent for `<string>` than specified by the :SBUS<n>:CAN:TRIGger:PATTern:DATA:LENGth command, the most significant bits will be truncated. If the data length is changed after the `<string>` is programmed, the added or deleted bits will be added to or deleted from the least significant bits.

**Query Syntax**    `:SBUS<n>:CAN:TRIGger:PATTern:DATA?`

The :SBUS<n>:CAN:TRIGger:PATTern:DATA? query returns the current settings of the specified CAN data pattern resource in the binary string format.

**Return Format**    `<string><NL>` in nondecimal format

**Errors**    · ["-241, Hardware missing" on page 1607](#)

**See Also**    · ["Introduction to :TRIGger Commands" on page 1349](#)  
               · [":SBUS<n>:CAN:TRIGger:PATTern:DATA:LENGth" on page 952](#)  
               · [":SBUS<n>:CAN:TRIGger:PATTern:ID" on page 954](#)

## :SBUS<n>:CAN:TRIGger:PATTERn:DATA:DLC

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:CAN:TRIGger:PATTERn:DATA:DLC &lt;dLC&gt;</code>
	<code>&lt;dLC&gt; ::= integer between -1 (don't care) and 64, in NR1 format.</code>
	The :SBUS<n>:CAN:TRIGger:PATTERn:DATA:DLC command specifies the DLC value to be used in the CAN FD data trigger mode. A specific valid FD value can be specified, or -1 can be specified to indicate "don't care".
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:CAN:TRIGger:PATTERn:DATA:START?</code>
	The :SBUS<n>:CAN:TRIGger:PATTERn:DATA:DLC? query returns the currently set DLC value.
<b>Return Format</b>	<code>&lt;dLC&gt;&lt;NL&gt;</code> <code>&lt;dLC&gt; ::= integer between -1 (don't care) and 64, in NR1 format.</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":SBUS&lt;n&gt;:CAN:TRIGger:PATTERn:DATA"</a> on page 950</li></ul>

## :SBUS<n>:CAN:TRIGger:PATTern:DATA:LENGth

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:CAN:TRIGger:PATTern:DATA:LENGth &lt;length&gt;</code> <code>&lt;length&gt; ::= integer from 1 to 8 in NR1 format</code>
	The :SBUS<n>:CAN:TRIGger:PATTern:DATA:LENGth command sets the number of 8-bit bytes in the CAN data string. The number of bytes in the string can be anywhere from 1 bytes to 8 bytes (64 bits). The value for these bytes is set by the :SBUS<n>:CAN:TRIGger:PATTern:DATA command.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:CAN:TRIGger:PATTern:DATA:LENGth?</code>
	The :SBUS<n>:CAN:TRIGger:PATTern:DATA:LENGth? query returns the current CAN data pattern length setting.
<b>Return Format</b>	<code>&lt;count&gt;&lt;NL&gt;</code> <code>&lt;count&gt; ::= integer from 1 to 8 in NR1 format</code>
<b>Errors</b>	<ul style="list-style-type: none"><li><a href="#">"-241, Hardware missing"</a> on page 1607</li></ul>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">"Introduction to :TRIGger Commands"</a> on page 1349</li><li><a href="#">":SBUS&lt;n&gt;:CAN:TRIGger:PATTern:DATA"</a> on page 950</li><li><a href="#">":SBUS&lt;n&gt;:CAN:SOURce"</a> on page 945</li></ul>

## :SBUS<n>:CAN:TRIGger:PATTERn:DATA:STARt

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:CAN:TRIGger:PATTERn:DATA:STARt <start>

<start> ::= integer between 0 and 63, in NR1 format.

The :SBUS<n>:CAN:TRIGger:PATTERn:DATA:STARt command specifies the starting byte position for CAN FD data triggers.

CAN FD frames can have up to 64 bytes of data. You can trigger on up to 8 bytes of data. The starting byte position setting lets you trigger on data anywhere within the frame.

**Query Syntax** :SBUS<n>:CAN:TRIGger:PATTERn:DATA:STARt?

The :SBUS<n>:CAN:TRIGger:PATTERn:DATA:STARt? query returns the starting byte position setting.

**Return Format** <start><NL>

<start> ::= integer between 0 and 63, in NR1 format.

**See Also**

- "[:SBUS<n>:CAN:TRIGger:PATTERn:DATA](#)" on page 950
- "[:SBUS<n>:CAN:TRIGger:PATTERn:DATA:LENGth](#)" on page 952

## :SBUS<n>:CAN:TRIGger:PATTern:ID

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:CAN:TRIGger:PATTern:ID <string>`

`<string> ::= "nn...n" where n ::= {0 | 1 | X | $}`

`<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | X | $}`

The :SBUS<n>:CAN:TRIGger:PATTern:ID command defines the CAN identifier pattern resource according to the string parameter. This pattern, along with the identifier mode (set by the :SBUS<n>:CAN:TRIGger:PATTern:ID:MODE command), control the identifier pattern searched for in each CAN message.

If the string parameter starts with "0x", it is a hexadecimal string made up of hexadecimal and X (don't care) characters; otherwise, it is a binary string made up of 0, 1, and X (don't care) characters.

### NOTE

The ID pattern resource string is always 29 bits. Only 11 of these bits are used when the :SBUS<n>:CAN:TRIGger:PATTern:ID:MODE is STANdard.

A string longer than 29 bits is truncated to 29 bits when setting the ID pattern resource.

**Query Syntax**    `:SBUS<n>:CAN:TRIGger:PATTern:ID?`

The :SBUS<n>:CAN:TRIGger:PATTern:ID? query returns the current settings of the specified CAN identifier pattern resource in the 29-bit binary string format.

**Return Format**    `<string><NL>` in 29-bit binary string format

**Errors**

- ["-241, Hardware missing" on page 1607](#)

**See Also**

- ["Introduction to :TRIGger Commands" on page 1349](#)
- [":SBUS<n>:CAN:TRIGger:PATTern:ID:MODE" on page 955](#)
- [":SBUS<n>:CAN:TRIGger:PATTern:DATA" on page 950](#)

## :SBUS<n>:CAN:TRIGger:PATTern:ID:MODE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:CAN:TRIGger:PATTern:ID:MODE <value>`  
`<value> ::= {STANDARD | EXTENDED}`

The :SBUS<n>:CAN:TRIGger:PATTern:ID:MODE command sets the CAN identifier mode. STANDARD selects the standard 11-bit identifier. EXTENDED selects the extended 29-bit identifier. The CAN identifier is set by the :SBUS<n>:CAN:TRIGger:PATTern:ID command.

**Query Syntax**    `:SBUS<n>:CAN:TRIGger:PATTern:ID:MODE?`

The :SBUS<n>:CAN:TRIGger:PATTern:ID:MODE? query returns the current setting of the CAN identifier mode.

**Return Format**    `<value><NL>`  
`<value> ::= {STAN | EXT}`

**Errors**    • ["-241, Hardware missing" on page 1607](#)

**See Also**    • ["Introduction to :TRIGger Commands" on page 1349](#)  
• [":SBUS<n>:MODE" on page 909](#)  
• [":SBUS<n>:CAN:TRIGger:PATTern:DATA" on page 950](#)  
• [":SBUS<n>:CAN:TRIGger:PATTern:DATA:LENGTH" on page 952](#)  
• [":SBUS<n>:CAN:TRIGger:PATTern:ID" on page 954](#)

## :SBUS<n>:CAN:TRIGger:SYMBolic:MESSAge

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:CAN:TRIGger:SYMBolic:MESSAge <name>`  
`<name> ::= quoted ASCII string`

The :SBUS<n>:CAN:TRIGger:SYMBolic:MESSAge command specifies the message to trigger on when CAN symbolic data has been loaded (recalled) into the oscilloscope and the CAN trigger mode is set to MESSage or MSIGnal.

**Query Syntax**    `:SBUS<n>:CAN:TRIGger:SYMBolic:MESSAge?`

The :SBUS<n>:CAN:TRIGger:SYMBolic:MESSAge? query returns the specified message.

**Return Format**    `<name><NL>`  
`<name> ::= quoted ASCII string`

**See Also**

- "[:RECall:DBC\[:STARt\]](#)" on page 865
- "[:SBUS<n>:CAN:TRIGger](#)" on page 946
- "[:SBUS<n>:CAN:TRIGger:SYMBolic:SIGNAl](#)" on page 957
- "[:SBUS<n>:CAN:TRIGger:SYMBolic:VALue](#)" on page 958

## :SBUS<n>:CAN:TRIGger:SYMBolic:SIGNAl

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:CAN:TRIGger:SYMBolic:SIGNAl <name>

<name> ::= quoted ASCII string

The :SBUS<n>:CAN:TRIGger:SYMBolic:SIGNAl command specifies the signal to trigger on when CAN symbolic data has been loaded (recalled) into the oscilloscope and the CAN trigger mode is set to MSIGnAl.

**Query Syntax** :SBUS<n>:CAN:TRIGger:SYMBolic:SIGNAl?

The :SBUS<n>:CAN:TRIGger:SYMBolic:SIGNAl? query returns the specified signal.

**Return Format** <name><NL>

<name> ::= quoted ASCII string

**See Also**

- "[:RECall:DBC\[:STARt\]](#)" on page 865
- "[:SBUS<n>:CAN:TRIGger](#)" on page 946
- "[:SBUS<n>:CAN:TRIGger:SYMBolic:MESSAge](#)" on page 956
- "[:SBUS<n>:CAN:TRIGger:SYMBolic:VALue](#)" on page 958

## :SBUS<n>:CAN:TRIGger:SYMBolic:VALue

**N** (see [page 1666](#))

**Command Syntax**

```
:SBUS<n>:CAN:TRIGger:SYMBolic:VALue <data>
<data> ::= value in NR3 format
```

The :SBUS<n>:CAN:TRIGger:SYMBolic:VALue command specifies the signal value to trigger on when CAN symbolic data has been loaded (recalled) into the oscilloscope and the CAN trigger mode is set to MSIGnal.

**NOTE**

Encoded signal values are not supported in the remote interface (even though they can be used in the front panel graphical interface).

**Query Syntax**

```
:SBUS<n>:CAN:TRIGger:SYMBolic:VALue?
```

The :SBUS<n>:CAN:TRIGger:SYMBolic:VALue? query returns the specified signal value.

**Return Format**

```
<data><NL>
<data> ::= value in NR3 format
```

**See Also**

- "[:RECall:DBC\[:START\]](#)" on page 865
- "[:SBUS<n>:CAN:TRIGger](#)" on page 946
- "[:SBUS<n>:CAN:TRIGger:SYMBolic:MESSAge](#)" on page 956
- "[:SBUS<n>:CAN:TRIGger:SYMBolic:SIGNAl](#)" on page 957

## :SBUS<n>:CXPI Commands

**NOTE**

These commands are valid when the CXPI (Clock Extension Peripheral Interface) serial decode and triggering option has been licensed.

**Table 125** :SBUS<n>:CXPI Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:CXPI:BAUDrate <baudrate> (see <a href="#">page 961</a> )	:SBUS<n>:CXPI:BAUDrate? (see <a href="#">page 961</a> )	<baudrate> ::= integer from 9600 to 40000 in 100 b/s increments.
:SBUS<n>:CXPI:PARity {{0   OFF}   {1   ON}} (see <a href="#">page 962</a> )	:SBUS<n>:CXPI:PARity? (see <a href="#">page 962</a> )	{0   1}
:SBUS<n>:CXPI:SOURce <source> (see <a href="#">page 963</a> )	:SBUS<n>:CXPI:SOURce? (see <a href="#">page 963</a> )	<source> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format
:SBUS<n>:CXPI:TOLERance <percent> (see <a href="#">page 964</a> )	:SBUS<n>:CXPI:TOLERance? (see <a href="#">page 964</a> )	<percent> ::= from 1-30, in NR1 format.
:SBUS<n>:CXPI:TRIGger <mode> (see <a href="#">page 965</a> )	:SBUS<n>:CXPI:TRIGger? (see <a href="#">page 966</a> )	<mode> ::= {SOF   EOF   PTYPe   ID   DATA   LDATA   CRCerror   PARityerror   IBSerror   IFSerror   FRAMingerror   DLENGtherror   SAMPleerror   ALLerrors   SLEEPframe   WAKEuppulse}
:SBUS<n>:CXPI:TRIGger :IDFilter {{0   OFF}   {1   ON}} (see <a href="#">page 967</a> )	:SBUS<n>:CXPI:TRIGger :IDFilter? (see <a href="#">page 967</a> )	{0   1}
:SBUS<n>:CXPI:TRIGger :PTYPe {{0   OFF}   {1   ON}} (see <a href="#">page 968</a> )	:SBUS<n>:CXPI:TRIGger :PTYPe? (see <a href="#">page 968</a> )	{0   1}
:SBUS<n>:CXPI:TRIGger :PATtern:DATA <string> (see <a href="#">page 969</a> )	:SBUS<n>:CXPI:TRIGger :PATtern:DATA? (see <a href="#">page 969</a> )	<string> ::= "nn...n" where n ::= {0   1   X} <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X}
:SBUS<n>:CXPI:TRIGger :PATtern:DATA:LENGTH <length> (see <a href="#">page 970</a> )	:SBUS<n>:CXPI:TRIGger :PATtern:DATA:LENGTH? (see <a href="#">page 970</a> )	<start> ::= integer between 0 and 12, in NR1 format.

**Table 125** :SBUS<n>:CXPI Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:CXPI:TRIGger :PATTern:DATA:START <start> (see page 971)	:SBUS<n>:CXPI:TRIGger :PATTern:DATA:START? (see page 971)	<start> ::= integer between 0 and 124, in NR1 format.
:SBUS<n>:CXPI:TRIGger :PATTern:ID <string> (see page 972)	:SBUS<n>:CXPI:TRIGger :PATTern:ID? (see page 972)	<string> ::= "nn...n" where n ::= {0   1   X}  <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X}
:SBUS<n>:CXPI:TRIGger :PATTern:INFO:CT <string> (see page 973)	:SBUS<n>:CXPI:TRIGger :PATTern:INFO:CT? (see page 973)	<string> ::= "nn" where n ::= {0   1   X}
:SBUS<n>:CXPI:TRIGger :PATTern:INFO:DLC <dLC> (see page 974)	:SBUS<n>:CXPI:TRIGger :PATTern:INFO:DLC? (see page 974)	<dLC> ::= integer between -1 (don't care) and 15, in NR1 format, when trigger is in DATA mode.  <dLC> ::= integer between -1 (don't care) and 255, in NR1 format, when trigger is in LDATa mode.
:SBUS<n>:CXPI:TRIGger :PATTern:INFO:NM <string> (see page 975)	:SBUS<n>:CXPI:TRIGger :PATTern:INFO:NM? (see page 975)	<string> ::= "nn" where n ::= {0   1   X}

## :SBUS<n>:CXPI:BAUDrate

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:CXPI:BAUDrate &lt;baudrate&gt;</code> <code>&lt;baudrate&gt; ::= integer from 9600 to 40000 in 100 b/s increments.</code>
	The :SBUS<n>:CXPI:BAUDrate command specifies the baud rate of the CXPI signal from your device under test.
	The CXPI baud rate can be set from 9600 b/s to 40000 b/s in 100 b/s increments.
	You must set the baud rate to match your device under test.
	The default baud rate is 20 kb/s.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:CXPI:BAUDrate?</code>
	The :SBUS<n>:CXPI:BAUDrate? query returns the baud rate setting.
<b>Return Format</b>	<code>&lt;baudrate&gt;&lt;NL&gt;</code> <code>&lt;baudrate&gt; ::= integer from 9600 to 40000 in 100 b/s increments.</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:PARity"</a> on page 962</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:SOURce"</a> on page 963</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TOLerance"</a> on page 964</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger"</a> on page 965</li> </ul>

## :SBUS<n>:CXPI:PARity

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:CXPI:PARity {{0 | OFF} | {1 | ON}}

The :SBUS<n>:CXPI:PARity command specifies whether the parity bit should be displayed in the identifier field.

When OFF, the upper bit is masked. The parity is still checked, but it is not displayed unless a parity error occurs.

**Query Syntax** :SBUS<n>:CXPI:PARity?

The :SBUS<n>:CXPI:PARity? query returns the parity display setting.

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

**See Also**

- "[:SBUS<n>:CXPI:BAUDrate](#)" on page 961
- "[:SBUS<n>:CXPI:SOURce](#)" on page 963
- "[:SBUS<n>:CXPI:TOLerance](#)" on page 964
- "[:SBUS<n>:CXPI:TRIGger](#)" on page 965

## :SBUS<n>:CXPI:SOURce

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:CXPI:SOURce <source>`

```
<source> ::= {CHANnel<n>}
<n> ::= 1 to (# analog channels) in NR1 format
```

The :SBUS<n>:CXPI:SOURce command selects the oscilloscope channel connected to the CXPI signal line.

**Query Syntax**    `:SBUS<n>:CXPI:SOURce?`

The :SBUS<n>:CXPI:SOURce? query returns the selected oscilloscope channel source.

**Return Format**    `<source><NL>`

```
<source> ::= {CHAN<n>}
```

**See Also**

- "[:SBUS<n>:CXPI:BAUDrate](#)" on page 961
- "[:SBUS<n>:CXPI:PARity](#)" on page 962
- "[:SBUS<n>:CXPI:TOLerance](#)" on page 964
- "[:SBUS<n>:CXPI:TRIGger](#)" on page 965

## :SBUS<n>:CXPI:TOLerance

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:CXPI:TOLerance <percent>`  
`<percent> ::= from 1-30, in NR1 format.`

The :SBUS<n>:CXPI:TOLerance command specifies the tolerance as a percentage of the Tbit width.

**Query Syntax**    `:SBUS<n>:CXPI:TOLerance?`

The :SBUS<n>:CXPI:TOLerance? query returns the tolerance setting.

**Return Format**    `<percent><NL>`  
`<percent> ::= from 1-30, in NR1 format.`

**See Also**

- [":SBUS<n>:CXPI:BAUDrate"](#) on page 961
- [":SBUS<n>:CXPI:PARity"](#) on page 962
- [":SBUS<n>:CXPI:SOURce"](#) on page 963
- [":SBUS<n>:CXPI:TRIGger"](#) on page 965

## :SBUS<n>:CXPI:TRIGger

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:CXPI:TRIGger <mode>

```
<mode> ::= {SOF | EOF | PTYPe | ID | DATA | LDATA | CRCerror
            | PARityerror | IBSerror | IFSerror | FRAMingerror | DLENgtherror
            | SAMPleerror | ALLerrors | SLEepframe | WAKEuppulse}
```

The :SBUS<n>:CXPI:TRIGger command selects the CXPI trigger type:

- SOF – (Start of Frame) triggers at the start bit of any frame.
- EOF – (End of Frame) triggers at the end of any frame.
- PTYPe – triggers on any frame that starts with the special PTYPE byte.  
PTYPE frames begins with an extra PID byte with a Frame ID of 0000000b (reserved for only PTYPE frames). The PTYPE PID byte is then followed by a regular PID byte and the rest of the normal frame. The extra PTYPE byte is never included in the CRC calculation.
- ID – (Frame ID) triggers on a user-defined Frame ID at the end of the PID byte. The Frame ID value is user-defined, 7 bits, and has bitwise don't-cares. You can specify whether to trigger on PTYPE present or no PTYPE present.
- DATA – (Frame ID, Info and Data) triggers on CXPI frames at the end of the last data byte defined in the trigger. In addition to the PID value, you can specify the contents of the Frame Info byte with bitwise don't-cares. You can specify up to 12 data bytes on which to trigger with bitwise don't-cares.
- LDATA – (Frame ID, Info and Data (Long Frame)) triggers on CXPI frames at the end of the last data byte defined in the trigger. The standard DLC field will be locked to 1111b. You can specify up to 12 bytes of data on which to trigger and specify the start byte number as an offset. The offset can be up to 255.
- CRCerror – (CRC Field Error) triggers when the calculated CRC does not match the transmitted CRC. You can optionally filter by Frame ID and PTYPE as in the Frame ID trigger.
- PARityerror – triggers when the parity bit in the PID or PTYPE field is not correct.
- IBSerror – (Inter-Byte Space Error) triggers when there are more than 9 bits between consecutive bytes in a frame. You can optionally filter by Frame ID and PTYPE as in the Frame ID trigger.
- IFSerror – (Inter-Frame Space Error) triggers when there are fewer than 10 idle bits before a new frame begins.
- FRAMingerror – triggers when the stop bit of a byte is not logical 1. You can optionally filter by Frame ID and PTYPE as in the Frame ID trigger.

- DLENgtherror – (Data Length Error) triggers when there are more data bytes in a frame than is indicated by the DLC or Extended DLC field. You can optionally filter by Frame ID and PTYPE as in the Frame ID trigger.
- SAMPleerror – triggers when 10 consecutive logical Os are detected.
- ALLerrors – triggers on all CRC, Parity, IBS, Stop Bit, Data Length, and Sample errors.
- SLEEPframe – triggers when a normal frame is transmitted matching the definition of a sleep frame in the CXPI specification.
- WAKEuppulse – triggers when a wakeup pulse is detected.

**Query Syntax** :SBUS<n>:CXPI:TRIGger?

The :SBUS<n>:CXPI:TRIGger? query returns the CXPI trigger type setting.

**Return Format** <mode><NL>

```
<mode> ::= {SOF | EOF | PTYP | ID | DATA | LDAT | CRC | PAR | IBS
| IFS | FRAM | DLEN | SAMP | ALL | SLE | WAK}
```

**See Also**

- "[:SBUS<n>:CXPI:BAUDrate](#)" on page 961
- "[:SBUS<n>:CXPI:PARity](#)" on page 962
- "[:SBUS<n>:CXPI:SOURce](#)" on page 963
- "[:SBUS<n>:CXPI:TOLerance](#)" on page 964
- "[:SBUS<n>:CXPI:TRIGger:IDFilter](#)" on page 967
- "[:SBUS<n>:CXPI:TRIGger:PTYPe](#)" on page 968
- "[:SBUS<n>:CXPI:TRIGger:PATTERn:DATA](#)" on page 969
- "[:SBUS<n>:CXPI:TRIGger:PATTERn:DATA:LENGTH](#)" on page 970
- "[:SBUS<n>:CXPI:TRIGger:PATTERn:DATA:START](#)" on page 971
- "[:SBUS<n>:CXPI:TRIGger:PATTERn:ID](#)" on page 972
- "[:SBUS<n>:CXPI:TRIGger:PATTERn:INFO:CT](#)" on page 973
- "[:SBUS<n>:CXPI:TRIGger:PATTERn:INFO:DLC](#)" on page 974
- "[:SBUS<n>:CXPI:TRIGger:PATTERn:INFO:NM](#)" on page 975

## :SBUS<n>:CXPI:TRIGger:IDFilter

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:CXPI:TRIGger:IDFilter {{0 | OFF} | {1 | ON}}

When triggering on CRC Field Errors, Inter-Byte Space Errors, Framing Errors, or Data Length Errors, the :SBUS<n>:CXPI:TRIGger:IDFilter command lets you enable/disable modification of the trigger so that it occurs only for a specified ID.

**Query Syntax** :SBUS<n>:CXPI:TRIGger:IDFilter?

The :SBUS<n>:CXPI:TRIGger:IDFilter? query returns the ID filter setting.

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

- See Also**
- "[:SBUS<n>:CXPI:TRIGger](#)" on page 965
  - "[:SBUS<n>:CXPI:TRIGger:PTYPe](#)" on page 968
  - "[:SBUS<n>:CXPI:TRIGger:PATTERn:DATA](#)" on page 969
  - "[:SBUS<n>:CXPI:TRIGger:PATTERn:DATA:LENGth](#)" on page 970
  - "[:SBUS<n>:CXPI:TRIGger:PATTERn:DATA:START](#)" on page 971
  - "[:SBUS<n>:CXPI:TRIGger:PATTERn:ID](#)" on page 972
  - "[:SBUS<n>:CXPI:TRIGger:PATTERn:INFO:CT](#)" on page 973
  - "[:SBUS<n>:CXPI:TRIGger:PATTERn:INFO:DLC](#)" on page 974
  - "[:SBUS<n>:CXPI:TRIGger:PATTERn:INFO:NM](#)" on page 975

## :SBUS<n>:CXPI:TRIGger:PTYPe

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:CXPI:TRIGger:PTYPe { {0 | OFF} | {1 | ON} }`

For the trigger types that let you trigger on data, the `:SBUS<n>:CXPI:TRIGger:PTYPe` command specifies whether you want to trigger when the special PTYPE byte is present (ON) or not present (OFF).

**Query Syntax**    `:SBUS<n>:CXPI:TRIGger:PTYPe?`

The `:SBUS<n>:CXPI:TRIGger:PTYPe?` query returns the PTYPE trigger setting.

**Return Format**    `<setting><NL>`

`<setting> ::= {0 | 1}`

- See Also**
- "[:SBUS<n>:CXPI:TRIGger](#)" on page 965
  - "[:SBUS<n>:CXPI:TRIGger:IDFilter](#)" on page 967
  - "[:SBUS<n>:CXPI:TRIGger:PATTERn:DATA](#)" on page 969
  - "[:SBUS<n>:CXPI:TRIGger:PATTERn:DATA:LENGth](#)" on page 970
  - "[:SBUS<n>:CXPI:TRIGger:PATTERn:DATA:START](#)" on page 971
  - "[:SBUS<n>:CXPI:TRIGger:PATTERn:ID](#)" on page 972
  - "[:SBUS<n>:CXPI:TRIGger:PATTERn:INFO:CT](#)" on page 973
  - "[:SBUS<n>:CXPI:TRIGger:PATTERn:INFO:DLC](#)" on page 974
  - "[:SBUS<n>:CXPI:TRIGger:PATTERn:INFO:NM](#)" on page 975

## :SBUS<n>:CXPI:TRIGger:PATTern:DATA

**N** (see [page 1666](#))

<b>Command Syntax</b>	<pre>:SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:DATA &lt;string&gt; &lt;string&gt; ::= "nn...n" where n ::= {0   1   x} &lt;string&gt; ::= "0xnn...n" where n ::= {0,...,9   A,...,F   x}</pre>
	For the trigger types that let you trigger on data, the :SBUS<n>:CXPI:TRIGger:PATTern:DATA command lets you specify the data value.
	The :SBUS<n>:CXPI:TRIGger:PATTern:DATA:LENGth command specifies the length of the data to trigger on, from 0 to 12 bytes, limited by the data length code (DLC) setting of the :SBUS<n>:CXPI:TRIGger:PATTern:INFO:DLC command.
	When triggering on long frames (with the LDATa trigger type) that can have up to 255 data bytes, the maximum number of data bytes you can include in the trigger specification is still only 12 bytes. In this case, you can use the :SBUS<n>:CXPI:TRIGger:PATTern:DATA:START command to specify the starting byte location where the data value should be found.
<b>Query Syntax</b>	<pre>:SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:DATA?</pre>
	The :SBUS<n>:CXPI:TRIGger:PATTern:DATA? query returns the specified data value.
	Returned data values are always quoted binary format strings.
<b>Return Format</b>	<pre>&lt;string&gt;&lt;NL&gt; &lt;string&gt; ::= "nn...n" where n ::= {0   1   x}</pre>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger" on page 965</a></li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:IDFilter" on page 967</a></li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PTYPe" on page 968</a></li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:DATA:LENGth" on page 970</a></li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:DATA:START" on page 971</a></li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:ID" on page 972</a></li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:INFO:CT" on page 973</a></li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:INFO:DLC" on page 974</a></li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:INFO:NM" on page 975</a></li> </ul>

## :SBUS<n>:CXPI:TRIGger:PATTern:DATA:LENGth

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:DATA:LENGth &lt;length&gt;</code>
	<code>&lt;length&gt;</code> ::= integer between 0 and 12, in NR1 format.
	For the trigger types that let you trigger on data, the :SBUS<n>:CXPI:TRIGger:PATTern:DATA:LENGth command specifies the length of the data to trigger on, from 0 to 12 bytes, limited by the data length code (DLC) setting of the :SBUS<n>:CXPI:TRIGger:PATTern:INFO:DLC command.
	The :SBUS<n>:CXPI:TRIGger:PATTern:DATA command lets you specify the data value to trigger on.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:DATA:LENGth?</code>
	The :SBUS<n>:CXPI:TRIGger:PATTern:DATA:LENGth? query returns the data length setting.
<b>Return Format</b>	<code>&lt;length&gt;&lt;NL&gt;</code>
	<code>&lt;length&gt;</code> ::= integer between 0 and 12, in NR1 format.
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:SBUS&lt;n&gt;:CXPI:TRIGger</a>" on page 965</li> <li>· "<a href="#">:SBUS&lt;n&gt;:CXPI:TRIGger:IDFilter</a>" on page 967</li> <li>· "<a href="#">:SBUS&lt;n&gt;:CXPI:TRIGger:PTYPe</a>" on page 968</li> <li>· "<a href="#">:SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:DATA</a>" on page 969</li> <li>· "<a href="#">:SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:DATA:STARt</a>" on page 971</li> <li>· "<a href="#">:SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:ID</a>" on page 972</li> <li>· "<a href="#">:SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:INFO:CT</a>" on page 973</li> <li>· "<a href="#">:SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:INFO:DLC</a>" on page 974</li> <li>· "<a href="#">:SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:INFO:NM</a>" on page 975</li> </ul>

## :SBUS<n>:CXPI:TRIGger:PATTern:DATA:STARt

**N** (see [page 1666](#))

### Command Syntax

```
:SBUS<n>:CXPI:TRIGger:PATTern:DATA:STARt <start>
<start> ::= integer between 0 and 124, in NR1 format.
```

When triggering on long frames (with the LDATA trigger type) that can have up to 255 data bytes, the maximum number of data bytes you can include in the trigger specification is still only 12 bytes. In this case, you can use the :SBUS<n>:CXPI:TRIGger:PATTern:DATA:STARt command to specify the starting byte location where the data value should be found.

The starting byte location must be within the first 123 bytes when PTYPE is present or 124 bytes when PTYPE is not present.

The :SBUS<n>:CXPI:TRIGger:PATTern:DATA:LENGth command lets you specify the length of the data value to trigger on.

The :SBUS<n>:CXPI:TRIGger:PATTern:DATA command lets you specify the data value to trigger on.

### Query Syntax

```
:SBUS<n>:CXPI:TRIGger:PATTern:DATA:STARt?
```

The :SBUS<n>:CXPI:TRIGger:PATTern:DATA:STARt? query returns the start byte setting.

### Return Format

```
<start><NL>
<start> ::= integer between 0 and 124, in NR1 format.
```

### See Also

- "[:SBUS<n>:CXPI:TRIGger](#)" on page 965
- "[:SBUS<n>:CXPI:TRIGger:IDFilter](#)" on page 967
- "[:SBUS<n>:CXPI:TRIGger:PTYPe](#)" on page 968
- "[:SBUS<n>:CXPI:TRIGger:PATTern:DATA](#)" on page 969
- "[:SBUS<n>:CXPI:TRIGger:PATTern:DATA:LENGth](#)" on page 970
- "[:SBUS<n>:CXPI:TRIGger:PATTern:ID](#)" on page 972
- "[:SBUS<n>:CXPI:TRIGger:PATTern:INFO:CT](#)" on page 973
- "[:SBUS<n>:CXPI:TRIGger:PATTern:INFO:DLC](#)" on page 974
- "[:SBUS<n>:CXPI:TRIGger:PATTern:INFO:NM](#)" on page 975

## :SBUS<n>:CXPI:TRIGger:PATTern:ID

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:ID &lt;string&gt;</code> <code>&lt;string&gt; ::= "nn...n" where n ::= {0   1   x}</code> <code>&lt;string&gt; ::= "0xnn...n" where n ::= {0,...,9   A,...,F   x}</code>
	For the trigger types that let you specify frame ID values in the trigger or allow filtering by the frame ID, the :SBUS<n>:CXPI:TRIGger:PATTern:ID command lets you specify the frame ID value.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:ID?</code>
	The :SBUS<n>:CXPI:TRIGger:PATTern:ID? query returns the specified frame ID value.
	Returned frame ID values are always quoted binary format strings.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code> <code>&lt;string&gt; ::= "nn...n" where n ::= {0   1   x}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger"</a> on page 965</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:IDFilter"</a> on page 967</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PTYPe"</a> on page 968</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:DATA"</a> on page 969</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:DATA:LENGth"</a> on page 970</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:DATA:STARt"</a> on page 971</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:INFO:CT"</a> on page 973</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:INFO:DLC"</a> on page 974</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:INFO:NM"</a> on page 975</li> </ul>

## :SBUS<n>:CXPI:TRIGger:PATTern:INFO:CT

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:CXPI:TRIGger:PATTern:INFO:CT <string>

<string> ::= "nn" where n ::= {0 | 1 | x}

The command ...

For the trigger types that let you trigger on data, as well as frame ID and frame information bits, the :SBUS<n>:CXPI:TRIGger:PATTern:INFO:CT command lets you specify the Count (CT) value of the CXPI frame you wish to trigger on. This is a two-bit binary value.

**Query Syntax** :SBUS<n>:CXPI:TRIGger:PATTern:INFO:CT?

The :SBUS<n>:CXPI:TRIGger:PATTern:INFO:CT? query returns the specified CT bits included in the trigger.

**Return Format** <string><NL>

<string> ::= "nn" where n ::= {0 | 1 | x}

**See Also**

- "[:SBUS<n>:CXPI:TRIGger](#)" on page 965
- "[:SBUS<n>:CXPI:TRIGger:IDFilter](#)" on page 967
- "[:SBUS<n>:CXPI:TRIGger:PTYPe](#)" on page 968
- "[:SBUS<n>:CXPI:TRIGger:PATTern:DATA](#)" on page 969
- "[:SBUS<n>:CXPI:TRIGger:PATTern:DATA:LENGth](#)" on page 970
- "[:SBUS<n>:CXPI:TRIGger:PATTern:DATA:START](#)" on page 971
- "[:SBUS<n>:CXPI:TRIGger:PATTern:ID](#)" on page 972
- "[:SBUS<n>:CXPI:TRIGger:PATTern:INFO:DLC](#)" on page 974
- "[:SBUS<n>:CXPI:TRIGger:PATTern:INFO:NM](#)" on page 975

## :SBUS<n>:CXPI:TRIGger:PATTern:INFO:DLC

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:INFO:DLC &lt;dLC&gt;</code>
	<code>&lt;dLC&gt; ::= integer between -1 (don't care) and 15, in NR1 format, when trigger is in DATA mode.</code>
	<code>&lt;dLC&gt; ::= integer between -1 (don't care) and 255, in NR1 format, when trigger is in LDATA mode.</code>
	For the trigger types that let you trigger on data, the :SBUS<n>:CXPI:TRIGger:PATTern:INFO:DLC command specifies the data length code of the CXPI frame you wish to trigger on.
	This will also affect the number of data bytes you can specify in the trigger.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:INFO:DLC?</code>
	The :SBUS<n>:CXPI:TRIGger:PATTern:INFO:DLC? query returns the DLC trigger value setting.
<b>Return Format</b>	<code>&lt;dLC&gt;&lt;NL&gt;</code>
	<code>&lt;dLC&gt; ::= integer between -1 (don't care) and 15, in NR1 format, when trigger is in DATA mode.</code>
	<code>&lt;dLC&gt; ::= integer between -1 (don't care) and 255, in NR1 format, when trigger is in LDATA mode.</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger"</a> on page 965</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:IDFilter"</a> on page 967</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PTYPe"</a> on page 968</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:DATA"</a> on page 969</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:DATA:LENGth"</a> on page 970</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:DATA:STARt"</a> on page 971</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:ID"</a> on page 972</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:INFO:CT"</a> on page 973</li> <li>· <a href="#">":SBUS&lt;n&gt;:CXPI:TRIGger:PATTern:INFO:NM"</a> on page 975</li> </ul>

## :SBUS<n>:CXPI:TRIGger:PATTern:INFO:NM

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:CXPI:TRIGger:PATTern:INFO:NM <string>`  
`<string> ::= "nn" where n ::= {0 | 1 | x}`

For the trigger types that let you trigger on data, as well as frame ID and frame information bits, the :SBUS<n>:CXPI:TRIGger:PATTern:INFO:NM command lets you specify the Network Management (NM) value of the CXPI frame you wish to trigger on. This is a two-bit binary value.

**Query Syntax**    `:SBUS<n>:CXPI:TRIGger:PATTern:INFO:NM?`

The :SBUS<n>:CXPI:TRIGger:PATTern:INFO:NM? query returns the specified NM bits included in the trigger.

**Return Format**    `<string><NL>`  
`<string> ::= "nn" where n ::= {0 | 1 | x}`

**See Also**

- "[:SBUS<n>:CXPI:TRIGger](#)" on page 965
- "[:SBUS<n>:CXPI:TRIGger:IDFilter](#)" on page 967
- "[:SBUS<n>:CXPI:TRIGger:PTYPe](#)" on page 968
- "[:SBUS<n>:CXPI:TRIGger:PATTern:DATA](#)" on page 969
- "[:SBUS<n>:CXPI:TRIGger:PATTern:DATA:LENGTH](#)" on page 970
- "[:SBUS<n>:CXPI:TRIGger:PATTern:DATA:START](#)" on page 971
- "[:SBUS<n>:CXPI:TRIGger:PATTern:ID](#)" on page 972
- "[:SBUS<n>:CXPI:TRIGger:PATTern:INFO:CT](#)" on page 973
- "[:SBUS<n>:CXPI:TRIGger:PATTern:INFO:DLC](#)" on page 974

## :SBUS<n>:FLEXray Commands

**NOTE**

These commands are only valid when the FLEXray triggering and serial decode option has been licensed.

**Table 126** :SBUS<n>:FLEXray Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:FLEXray:AUTOsetup (see <a href="#">page 978</a> )	n/a	n/a
:SBUS<n>:FLEXray:BAUDrate <baudrate> (see <a href="#">page 979</a> )	:SBUS<n>:FLEXray:BAUDrate? (see <a href="#">page 979</a> )	<baudrate> ::= {2500000   5000000   10000000}
:SBUS<n>:FLEXray:CHANNEL <channel> (see <a href="#">page 980</a> )	:SBUS<n>:FLEXray:CHANNEL? (see <a href="#">page 980</a> )	<channel> ::= {A   B}
n/a	:SBUS<n>:FLEXray:COUNT:NULL? (see <a href="#">page 981</a> )	<frame_count> ::= integer in NR1 format
:SBUS<n>:FLEXray:COUNT:RESET (see <a href="#">page 982</a> )	n/a	n/a
n/a	:SBUS<n>:FLEXray:COUNT:SYNC? (see <a href="#">page 983</a> )	<frame_count> ::= integer in NR1 format
n/a	:SBUS<n>:FLEXray:COUNT:TOTAL? (see <a href="#">page 984</a> )	<frame_count> ::= integer in NR1 format
:SBUS<n>:FLEXray:SOURCE <source> (see <a href="#">page 985</a> )	:SBUS<n>:FLEXray:SOURCE? (see <a href="#">page 985</a> )	<source> ::= {CHANNEL<n>} <n> ::= 1-2 or 1-4 in NR1 format
:SBUS<n>:FLEXray:TRIGGER <condition> (see <a href="#">page 986</a> )	:SBUS<n>:FLEXray:TRIGGER? (see <a href="#">page 986</a> )	<condition> ::= {FRAME   ERROR   EVENT}
:SBUS<n>:FLEXray:TRIGGER:ERRORTYPE <error_type> (see <a href="#">page 987</a> )	:SBUS<n>:FLEXray:TRIGGER:ERRORTYPE? (see <a href="#">page 987</a> )	<error_type> ::= {ALL   HCRC   FCRC}
:SBUS<n>:FLEXray:TRIGGER:EVENT:AUTOSET (see <a href="#">page 988</a> )	n/a	n/a
:SBUS<n>:FLEXray:TRIGGER:EVENT:BSS:ID <frame_id> (see <a href="#">page 989</a> )	:SBUS<n>:FLEXray:TRIGGER:EVENT:BSS:ID? (see <a href="#">page 989</a> )	<frame_id> ::= {ALL   <frame #>} <frame #> ::= integer from 1-2047

**Table 126** :SBUS<n>:FLEXray Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:FLEXray:TRIG ger:EVENT:TYPE <event> (see page 990)	:SBUS<n>:FLEXray:TRIG ger:EVENT:TYPE? (see page 990)	<event> ::= {WAKEup   TSS   {FES   DTS}   BSS}
:SBUS<n>:FLEXray:TRIG ger:FRAMe:CCBase <cycle_count_base> (see page 991)	:SBUS<n>:FLEXray:TRIG ger:FRAMe:CCBase? (see page 991)	<cycle_count_base> ::= integer from 0-63
:SBUS<n>:FLEXray:TRIG ger:FRAMe:CCRepetitio n <cycle_count_repetiti on> (see page 992)	:SBUS<n>:FLEXray:TRIG ger:FRAMe:CCRepetitio n? (see page 992)	<cycle_count_repetition> ::= {ALL   <rep #>} <rep #> ::= integer values 2, 4, 8, 16, 32, or 64
:SBUS<n>:FLEXray:TRIG ger:FRAMe:ID <frame_id> (see page 993)	:SBUS<n>:FLEXray:TRIG ger:FRAMe:ID? (see page 993)	<frame_id> ::= {ALL   <frame #>} <frame #> ::= integer from 1-2047
:SBUS<n>:FLEXray:TRIG ger:FRAMe:TYPE <frame_type> (see page 994)	:SBUS<n>:FLEXray:TRIG ger:FRAMe:TYPE? (see page 994)	<frame_type> ::= {NORMAl   STARtup   NULL   SYNC   NSTArtup   NNULL   NSYNC   ALL}

## :SBUS<n>:FLEXray:AUTosetup

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:FLEXray:AUTosetup`

The `:SBUS<n>:FLEXray:AUTosetup` command automatically configures oscilloscope settings to facilitate FlexRay triggering and serial decode.

- Sets the selected source channel's impedance to 50 Ohms.
- Sets the selected source channel's probe attenuation to 10:1.
- Sets the trigger level (on the selected source channel) to -300 mV.
- Turns on trigger Noise Reject.
- Turns on Serial Decode.
- Sets the trigger to the specified serial bus (n of SBUS<n>).

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":SBUS<n>:FLEXray:TRIGger](#)" on page 986
- "[":SBUS<n>:FLEXray:BAUDrate](#)" on page 979
- "[":TRIGger\[:EDGE\]:LEVEL](#)" on page 1380
- "[":SBUS<n>:FLEXray:SOURce](#)" on page 985

## :SBUS<n>:FLEXray:BAUDrate

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:FLEXray:BAUDrate <baudrate>

<baudrate> ::= {2500000 | 5000000 | 10000000}

The :SBUS<n>:FLEXray:BAUDrate command specifies the baud rate as 2.5 Mb/s, 5 Mb/s, or 10 Mb/s.

**Query Syntax** :SBUS<n>:FLEXray:BAUDrate?

The :SBUS<n>:FLEXray:BAUDrate? query returns the current baud rate setting.

**Return Format** <baudrate><NL>

<baudrate> ::= {2500000 | 5000000 | 10000000}

**See Also** • ["Introduction to :TRIGger Commands" on page 1349](#)

• [":SBUS<n>:FLEXray Commands" on page 976](#)

## :SBUS<n>:FLEXray:CHANnel

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:FLEXray:CHANnel <channel>`  
`<channel> ::= {A | B}`

The :SBUS<n>:FLEXray:CHANnel command specifies the bus channel, A or B, of the FlexRay signal.

**Query Syntax**    `:SBUS<n>:FLEXray:CHANnel?`

The :SBUS<n>:FLEXray:CHANnel? query returns the current bus channel setting.

**Return Format**    `<channel><NL>`  
`<channel> ::= {A | B}`

**See Also**

- ["Introduction to :TRIGger Commands" on page 1349](#)
- [":SBUS<n>:FLEXray Commands" on page 976](#)

## :SBUS<n>:FLEXray:COUNT:NULL

**N** (see [page 1666](#))

**Query Syntax** :SBUS<n>:FLEXray:COUNT:NULL?

Returns the FlexRay null frame count.

**Return Format** <frame\_count><NL>

<frame\_count> ::= integer in NR1 format

**Errors** • ["-241, Hardware missing" on page 1607](#)

**See Also** • [":SBUS<n>:FLEXray:COUNT:RESet" on page 982](#)

• [":SBUS<n>:FLEXray:COUNT:TOTal" on page 984](#)

• [":SBUS<n>:FLEXray:COUNT:SYNC" on page 983](#)

• ["Introduction to :SBUS<n> Commands" on page 905](#)

• [":SBUS<n>:MODE" on page 909](#)

• [":SBUS<n>:FLEXray Commands" on page 976](#)

## :SBUS<n>:FLEXray:COUNt:RESet

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:FLEXray:COUNt:RESet

Resets the FlexRay frame counters.

**Errors** • ["-241, Hardware missing" on page 1607](#)

**See Also** • [":SBUS<n>:FLEXray:COUNt:NULL" on page 981](#)  
• [":SBUS<n>:FLEXray:COUNt:TOTal" on page 984](#)  
• [":SBUS<n>:FLEXray:COUNt:SYNC" on page 983](#)  
• ["Introduction to :SBUS<n> Commands" on page 905](#)  
• [":SBUS<n>:MODE" on page 909](#)  
• [":SBUS<n>:FLEXray Commands" on page 976](#)

## :SBUS<n>:FLEXray:COUNT:SYNC

**N** (see [page 1666](#))

**Query Syntax** :SBUS<n>:FLEXray:COUNT:SYNC?

Returns the FlexRay sync frame count.

**Return Format** <frame\_count><NL>

<frame\_count> ::= integer in NR1 format

**Errors** • ["-241, Hardware missing" on page 1607](#)

**See Also** • [":SBUS<n>:FLEXray:COUNT:RESet" on page 982](#)

• [":SBUS<n>:FLEXray:COUNT:TOTal" on page 984](#)

• [":SBUS<n>:FLEXray:COUNT:NULL" on page 981](#)

• ["Introduction to :SBUS<n> Commands" on page 905](#)

• [":SBUS<n>:MODE" on page 909](#)

• [":SBUS<n>:FLEXray Commands" on page 976](#)

## :SBUS<n>:FLEXray:COUNT:TOTal

**N** (see [page 1666](#))

**Query Syntax** :SBUS<n>:FLEXray:COUNT:TOTal?

Returns the FlexRay total frame count.

**Return Format** <frame\_count><NL>

<frame\_count> ::= integer in NR1 format

**Errors** • "-241, Hardware missing" on page 1607

**See Also** • "[:SBUS<n>:FLEXray:COUNT:RESet](#)" on page 982  
• "[:SBUS<n>:FLEXray:COUNT:TOTal](#)" on page 984  
• "[:SBUS<n>:FLEXray:COUNT:NULL](#)" on page 981  
• "[:SBUS<n>:FLEXray:COUNT:SYNC](#)" on page 983  
• "[Introduction to :SBUS<n> Commands](#)" on page 905  
• "[:SBUS<n>:MODE](#)" on page 909  
• "[:SBUS<n>:FLEXray Commands](#)" on page 976

## :SBUS<n>:FLEXray:SOURce

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:FLEXray:SOURce <source>`  
`<source> ::= {CHANnel<n>}`  
`<n> ::= {1 | 2 | 3 | 4}`

The :SBUS<n>:FLEXray:SOURce command specifies the input source for the FlexRay signal.

**Query Syntax**    `:SBUS<n>:FLEXray:SOURce?`

The :SBUS<n>:FLEXray:SOURce? query returns the current source for the FlexRay signal.

**Return Format**    `<source><NL>`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":SBUS<n>:FLEXray:TRIGger](#)" on page 986
- "[":SBUS<n>:FLEXray:TRIGger:EVENT:TYPE](#)" on page 990
- "[":SBUS<n>:FLEXray:AUTosetup](#)" on page 978

## :SBUS<n>:FLEXray:TRIGger

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:FLEXray:TRIGger &lt;condition&gt;</code> <code>&lt;condition&gt; ::= {FRAMe   ERRor   EVENT}</code>
	The :SBUS<n>:FLEXray:TRIGger command sets the FLEXray trigger on condition: <ul style="list-style-type: none"> <li>• FRAMe – triggers on specified frames (without errors).</li> <li>• ERRor – triggers on selected active error frames and unknown bus conditions.</li> <li>• EVENT – triggers on specified FlexRay event/symbol.</li> </ul>
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:FLEXray:TRIGger?</code>
	The :SBUS<n>:FLEXray:TRIGger? query returns the current FLEXray trigger on condition.
<b>Return Format</b>	<code>&lt;condition&gt;&lt;NL&gt;</code> <code>&lt;condition&gt; ::= {FRAM   ERR   EVEN}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">:TRIGger:MODE</a>" on page 1362</li> <li>• "<a href="#">:SBUS&lt;n&gt;:FLEXray:TRIGger:ERRor:TYPE</a>" on page 987</li> <li>• "<a href="#">:SBUS&lt;n&gt;:FLEXray:TRIGger:EVENT:AUToset</a>" on page 988</li> <li>• "<a href="#">:SBUS&lt;n&gt;:FLEXray:TRIGger:EVENT:BSS:ID</a>" on page 989</li> <li>• "<a href="#">:SBUS&lt;n&gt;:FLEXray:TRIGger:EVENT:TYPE</a>" on page 990</li> <li>• "<a href="#">:SBUS&lt;n&gt;:FLEXray:TRIGger:FRAMe:CCBase</a>" on page 991</li> <li>• "<a href="#">:SBUS&lt;n&gt;:FLEXray:TRIGger:FRAMe:CCRepetition</a>" on page 992</li> <li>• "<a href="#">:SBUS&lt;n&gt;:FLEXray:TRIGger:FRAMe:ID</a>" on page 993</li> <li>• "<a href="#">:SBUS&lt;n&gt;:FLEXray:TRIGger:FRAMe:TYPE</a>" on page 994</li> </ul>

## :SBUS<n>:FLEXray:TRIGger:ERRor:TYPE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:FLEXray:TRIGger:ERRor:TYPE <error_type>`  
`<error_type> ::= {ALL | HCRC | FCRC}`

Selects the FlexRay error type to trigger on. The error type setting is only valid when the FlexRay trigger mode is set to ERRor.

- ALL – triggers on ALL errors.
- HCRC – triggers on only Header CRC errors.
- FCRC – triggers on only Frame CRC errors.

**Query Syntax**    `:SBUS<n>:FLEXray:TRIGger:ERRor:TYPE?`

The :SBUS<n>:FLEXray:TRIGger:ERRor:TYPE? query returns the currently selected FLEXray error type.

**Return Format**    `<error_type><NL>`  
`<error_type> ::= {ALL | HCRC | FCRC}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":SBUS<n>:FLEXray:TRIGger"](#) on page 986

## :SBUS<n>:FLEXray:TRIGger:EVENT:AUToSet

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:FLEXray:TRIGger:EVENT:AUToSet`

The `:SBUS<n>:FLEXray:TRIGger:EVENT:AUToSet` command automatically configures oscilloscope settings (as shown on the display) for the selected event trigger.

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:SBUS<n>:FLEXray:TRIGger:EVENT:TYPE](#)" on page 990
- "[:SBUS<n>:FLEXray:TRIGger:EVENT:BSS:ID](#)" on page 989
- "[:SBUS<n>:FLEXray:TRIGger](#)" on page 986
- "[:SBUS<n>:FLEXray:BAUDrate](#)" on page 979
- "[:TRIGger\[:EDGE\]:LEVel](#)" on page 1380
- "[:SBUS<n>:FLEXray:SOURce](#)" on page 985

## :SBUS<n>:FLEXray:TRIGger:EVENT:BSS:ID

**N** (see [page 1666](#))

**Command Syntax**

```
:SBUS<n>:FLEXray:TRIGger:EVENT:BSS:ID <frame_id>
<frame_id> ::= {ALL | <frame #>}
<frame #> ::= integer from 1-2047
```

The :SBUS<N>:FLEXray:TRIGger:EVENT:BSS:ID command sets the frame ID used by the Byte Start Sequence (BSS) event trigger. This setting is only valid if the trigger mode is EVENT and the EVENT:TYPE is BSS.

**Query Syntax**

```
:SBUS<n>:FLEXray:TRIGger:EVENT:BSS:ID?
```

The :SBUS<n>:FLEXray:TRIGger:EVENT:BSS:ID? query returns the current frame ID setting for the Byte Start Sequence (BSS) event trigger setup.

**Return Format**

```
<frame_id><NL>
<frame_id> ::= {ALL | <frame #>}
<frame #> ::= integer from 1-2047
```

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:SBUS<n>:FLEXray:TRIGger:EVENT:TYPE](#)" on page 990
- "[:SBUS<n>:FLEXray:TRIGger:EVENT:AUToset](#)" on page 988
- "[:TRIGger:MODE](#)" on page 1362
- "[:SBUS<n>:FLEXray:TRIGger](#)" on page 986

## :SBUS<n>:FLEXray:TRIGger:EVENT:TYPE

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:FLEXray:TRIGger:EVENT:TYPE &lt;event&gt;</code> <code>&lt;event&gt; ::= {WAKEup   TSS   {FES   DTS}   BSS}</code>
	Selects the FlexRay event to trigger on. The event setting is only valid when the FlexRay trigger mode is set to EVENT.
	<ul style="list-style-type: none"> <li>• WAKEup – triggers on Wake-Up event.</li> <li>• TSS – triggers on Transmission Start Sequence event.</li> <li>• FES – triggers on either Frame End or Dynamic Trailing Sequence event.</li> <li>• DTS – triggers on either Frame End or Dynamic Trailing Sequence event.</li> <li>• BSS – triggers on Byte Start Sequence event.</li> </ul>
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:FLEXray:TRIGger:EVENT:TYPE?</code>
	The :SBUS<n>:FLEXray:TRIGger:EVENT:TYPE? query returns the currently selected FLEXray event.
<b>Return Format</b>	<code>&lt;event&gt;&lt;NL&gt;</code> <code>&lt;event&gt; ::= {WAK   TSS   {FES   DTS}   BSS}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">":SBUS&lt;n&gt;:FLEXray:TRIGger:EVENT:AUToset</a>" on page 988</li> <li>• "<a href="#">":SBUS&lt;n&gt;:FLEXray:TRIGger:EVENT:BSS:ID</a>" on page 989</li> <li>• "<a href="#">":SBUS&lt;n&gt;:FLEXray:TRIGger</a>" on page 986</li> <li>• "<a href="#">":SBUS&lt;n&gt;:FLEXray:AUTosetup</a>" on page 978</li> <li>• "<a href="#">":SBUS&lt;n&gt;:FLEXray:SOURce</a>" on page 985</li> </ul>

## :SBUS<n>:FLEXray:TRIGger:FRAMe:CCBase

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:FLEXray:TRIGger:FRAMe:CCBase <cycle_count_base>`  
`<cycle_count_base> ::= integer from 0-63`

The :SBUS<n>:FLEXray:TRIGger:FRAMe:CCBase command sets the base of the FlexRay cycle count (in the frame header) to trigger on. The cycle count base setting is only valid when the FlexRay trigger mode is set to FRAME.

**Query Syntax**    `:SBUS<n>:FLEXray:TRIGger:FRAMe:CCBase?`

The :SBUS<n>:FLEXray:TRIGger:FRAMe:CCBase? query returns the current cycle count base setting for the FlexRay frame trigger setup.

**Return Format**    `<cycle_count_base><NL>`  
`<cycle_count_base> ::= integer from 0-63`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":SBUS<n>:FLEXray:TRIGger"](#) on page 986

## :SBUS<n>:FLEXray:TRIGger:FRAMe:CCRepetition

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:FLEXray:TRIGger:FRAMe:CCRepetition <cycle_count_repetition>`

`<cycle_count_repetition> ::= {ALL | <rep #>}`

`<rep #> ::= integer values 2, 4, 8, 16, 32, or 64`

The :SBUS<n>:FLEXray:TRIGger:FRAMe:CCRepetition command sets the repetition number of the FlexRay cycle count (in the frame header) to trigger on. The cycle count repetition setting is only valid when the FlexRay trigger mode is set to FRAME.

**Query Syntax**    `:SBUS<n>:FLEXray:TRIGger:FRAMe:CCRepetition?`

The :SBUS<n>:FLEXray:TRIGger:FRAMe:CCRepetition? query returns the current cycle count repetition setting for the FlexRay frame trigger setup.

**Return Format**    `<cycle_count_repetition><NL>`  
                  `<cycle_count_repetition> ::= {ALL | <rep #>}`  
                  `<rep #> ::= integer values 2, 4, 8, 16, 32, or 64`

**See Also**

- ["Introduction to :TRIGger Commands" on page 1349](#)
- [":SBUS<n>:FLEXray:TRIGger" on page 986](#)

## :SBUS<n>:FLEXray:TRIGger:FRAMe:ID

**N** (see [page 1666](#))

**Command Syntax**

```
:SBUS<n>:FLEXray:TRIGger:FRAMe:ID <frame_id>
<frame_id> ::= {ALL | <frame #>}
<frame #> ::= integer from 1-2047
```

The :SBUS<n>:FLEXray:TRIGger:FRAMe:ID command sets the FlexRay frame ID to trigger on. The frame ID setting is only valid when the FlexRay trigger mode is set to FRAMe.

**Query Syntax**

```
:SBUS<n>:FLEXray:TRIGger:FRAMe:ID?
```

The :SBUS<n>:FLEXray:TRIGger:FRAMe:ID? query returns the current frame ID setting for the FlexRay frame trigger setup.

**Return Format**

```
<frame_id><NL>
<frame_id> ::= {ALL | <frame #>}
<frame #> ::= integer from 1-2047
```

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:SBUS<n>:FLEXray:TRIGger](#)" on page 986

## :SBUS<n>:FLEXray:TRIGger:FRAMe:TYPE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:FLEXray:TRIGger:FRAMe:TYPE <frame_type>`

$$<\text{frame\_type}> ::= \{\text{NORMal} \mid \text{STARtup} \mid \text{NULL} \mid \text{SYNC} \mid \text{NSTArtup} \mid \text{NNULL} \mid \text{NSYNC} \mid \text{ALL}\}$$

The :SBUS<n>:FLEXray:TRIGger:FRAMe:TYPE command sets the FlexRay frame type to trigger on. The frame type setting is only valid when the FlexRay trigger mode is set to FRAME.

- NORMal – will trigger on only normal (NSTArtup & NNULl & NSYNC) frames.
- STARtup – will trigger on only startup frames.
- NULL – will trigger on only null frames.
- SYNC – will trigger on only sync frames.
- NSTArtup – will trigger on frames other than startup frames.
- NNULl – will trigger on frames other than null frames.
- NSYNC – will trigger on frames other than sync frames.
- ALL – will trigger on all FlexRay frame types.

**Query Syntax**    `:SBUS<n>:FLEXray:TRIGger:FRAMe:TYPE?`

The :SBUS<n>:FLEXray:TRIGger:FRAMe:TYPE? query returns the current frame type setting for the FlexRay frame trigger setup.

**Return Format**    `<frame_type><NL>`

$$<\text{frame\_type}> ::= \{\text{NORM} \mid \text{STAR} \mid \text{NULL} \mid \text{SYNC} \mid \text{NSTA} \mid \text{NNUL} \mid \text{NSYN} \mid \text{ALL}\}$$

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:SBUS<n>:FLEXray:TRIGger](#)" on page 986

## :SBUS<n>:I2S Commands

**NOTE**

These commands are only valid when the I2S serial decode option has been licensed.

**Table 127** :SBUS<n>:I2S Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:I2S:ALIGnmen t <setting> (see <a href="#">page 998</a> )	:SBUS<n>:I2S:ALIGnmen t? (see <a href="#">page 998</a> )	<setting> ::= {I2S   LJ   RJ}
:SBUS<n>:I2S:BASE <base> (see <a href="#">page 999</a> )	:SBUS<n>:I2S:BASE? (see <a href="#">page 999</a> )	<base> ::= {DECimal   HEX}
:SBUS<n>:I2S:CLOCK:SL OPe <slope> (see <a href="#">page 1000</a> )	:SBUS<n>:I2S:CLOCK:SL OPe? (see <a href="#">page 1000</a> )	<slope> ::= {NEGative   POSitive}
:SBUS<n>:I2S:RWIDth <receiver> (see <a href="#">page 1001</a> )	:SBUS<n>:I2S:RWIDth? (see <a href="#">page 1001</a> )	<receiver> ::= 4-32 in NR1 format
:SBUS<n>:I2S:SOURce:C LOCK <source> (see <a href="#">page 1002</a> )	:SBUS<n>:I2S:SOURce:C LOCK? (see <a href="#">page 1002</a> )	<source> ::= {CHANnel<n>   EXTernal} for DSO models <source> ::= {CHANnel<n>   DIGital<d>} for MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:I2S:SOURce:D ATA <source> (see <a href="#">page 1003</a> )	:SBUS<n>:I2S:SOURce:D ATA? (see <a href="#">page 1003</a> )	<source> ::= {CHANnel<n>   EXTernal} for DSO models <source> ::= {CHANnel<n>   DIGital<d>} for MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format

**Table 127** :SBUS<n>:I2S Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:I2S:SOURce:W SELECT <source> (see page 1004)	:SBUS<n>:I2S:SOURce:W SElect? (see page 1004)	<source> ::= {CHANnel<n>   EXTernal} for DSO models <source> ::= {CHANnel<n>   DIGital<d>} for MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:I2S:TRIGger <operator> (see page 1005)	:SBUS<n>:I2S:TRIGger? (see page 1005)	<operator> ::= {EQUAL   NOTequal   LESSthan   GREaterthan   INRange   OUTRange   INCReasing   DECReasing}
:SBUS<n>:I2S:TRIGger:AUDIO <audio_ch> (see page 1007)	:SBUS<n>:I2S:TRIGger:AUDIO? (see page 1007)	<audio_ch> ::= {RIGHT   LEFT   EITHer}
:SBUS<n>:I2S:TRIGger:PATTern:DATA <string> (see page 1008)	:SBUS<n>:I2S:TRIGger:PATTern:DATA? (see page 1009)	<string> ::= "n" where n ::= 32-bit integer in signed decimal when <base> = DECimal <string> ::= "nn...n" where n ::= {0   1   X   \$} when <base> = BINary <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$} when <base> = HEX
:SBUS<n>:I2S:TRIGger:PATTern:FORMAT <base> (see page 1010)	:SBUS<n>:I2S:TRIGger:PATTern:FORMAT? (see page 1010)	<base> ::= {BINary   HEX   DECimal}
:SBUS<n>:I2S:TRIGger:RANGE <lower>,<upper> (see page 1011)	:SBUS<n>:I2S:TRIGger:RANGE? (see page 1011)	<lower> ::= 32-bit integer in signed decimal, <nondecimal>, or <string> <upper> ::= 32-bit integer in signed decimal, <nondecimal>, or <string> <nondecimal> ::= #Hnn...n where n ::= {0,...,9   A,...,F} for hexadecimal <nondecimal> ::= #Bnn...n where n ::= {0   1} for binary <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F} for hexadecimal

**Table 127** :SBUS<n>:I2S Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:I2S:TWIDth <word_size> (see <a href="#">page 1012</a> )	:SBUS<n>:I2S:TWIDth? (see <a href="#">page 1012</a> )	<word_size> ::= 4-32 in NR1 format
:SBUS<n>:I2S:WSLow <low_def> (see <a href="#">page 1013</a> )	:SBUS<n>:I2S:WSLow? (see <a href="#">page 1013</a> )	<low_def> ::= {LEFT   RIGHT}

## :SBUS<n>:I2S:ALIGnment

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:I2S:ALIGnment <setting>`  
`<setting> ::= {I2S | LJ | RJ}`

The :SBUS<n>:I2S:ALIGnment command selects the data alignment of the I2S bus for the serial decoder and/or trigger when in I2S mode:

- I2S – standard.
- LJ – left justified.
- RJ – right justified.

Note that the word select (WS) polarity is specified separately with the :SBUS<n>:I2S:WSLow command.

**Query Syntax**    `:SBUS<n>:I2S:ALIGnment?`

The :SBUS<n>:I2S:ALIGnment? query returns the currently selected I2S data alignment.

**Return Format**    `<setting><NL>`  
`<setting> ::= {I2S | LJ | RJ}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:SBUS<n>:I2S:CLOCK:SLOPe](#)" on page 1000
- "[:SBUS<n>:I2S:RWIDth](#)" on page 1001
- "[:SBUS<n>:I2S:TWIDth](#)" on page 1012
- "[:SBUS<n>:I2S:WSLow](#)" on page 1013

## :SBUS<n>:I2S:BASE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:I2S:BASE <base>`

`<base> ::= {DECimal | HEX}`

The :SBUS<n>:I2S:BASE command determines the base to use for the I2S decode display.

**Query Syntax**    `:SBUS<n>:I2S:BASE?`

The :SBUS<n>:I2S:BASE? query returns the current I2S display decode base.

**Return Format**    `<base><NL>`

`<base> ::= {DECimal | HEX}`

**Errors**    • ["-241, Hardware missing" on page 1607](#)

**See Also**    • ["Introduction to :SBUS<n> Commands" on page 905](#)  
                • [":SBUS<n>:I2S Commands" on page 995](#)

## :SBUS<n>:I2S:CLOCK:SLOPe

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:I2S:CLOCK:SLOPe <slope>`  
`<slope> ::= {NEGative | POSitive}`

The :SBUS<n>:I2S:CLOCK:SLOPe command specifies which edge of the I2S serial clock signal clocks in data.

- NEGative – Falling edge.
- POSitive – Rising edge.

**Query Syntax**    `:SBUS<n>:I2S:CLOCK:SLOPe?`

The :SBUS<n>:I2S:CLOCK:SLOPe? query returns the current I2S clock slope setting.

**Return Format**    `<slope><NL>`  
`<slope> ::= {NEG | POS}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:SBUS<n>:I2S:ALIGNment](#)" on page 998
- "[:SBUS<n>:I2S:RWIDth](#)" on page 1001
- "[:SBUS<n>:I2S:TWIDth](#)" on page 1012
- "[:SBUS<n>:I2S:WSLow](#)" on page 1013

## :SBUS<n>:I2S:RWIDth

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:I2S:RWIDth <receiver>

<receiver> ::= 4-32 in NR1 format

The :SBUS<n>:I2S:RWIDth command sets the width of the receiver (decoded) data word in I2S anywhere from 4 bits to 32 bits.

**Query Syntax** :SBUS<n>:I2S:RWIDth?

The :SBUS<n>:I2S:RWIDth? query returns the currently set I2S receiver data word width.

**Return Format** <receiver><NL>

<receiver> ::= 4-32 in NR1 format

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:SBUS<n>:I2S:ALIGnment](#)" on page 998
- "[:SBUS<n>:I2S:CLOCK:SLOPe](#)" on page 1000
- "[:SBUS<n>:I2S:TWIDth](#)" on page 1012
- "[:SBUS<n>:I2S:WSLow](#)" on page 1013

## :SBUS<n>:I2S:SOURce:CLOCK

**N** (see [page 1666](#))

<b>Command Syntax</b>	<pre>:SBUS&lt;n&gt;:I2S:SOURce:CLOCK &lt;source&gt;</pre> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   EXTernal} for the DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;} for the MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p>
	The :SBUS<n>:I2S:SOURce:CLOCK controls which signal is used as the serial clock (SCLK) source by the serial decoder and/or trigger when in I2S mode.
<b>Query Syntax</b>	<pre>:SBUS&lt;n&gt;:I2S:SOURce:CLOCK?</pre>
	The :SBUS<n>:I2S:SOURce:CLOCK? query returns the current source for the I2S serial clock (SCLK).
<b>Return Format</b>	<source><NL>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">"Introduction to :TRIGger Commands" on page 1349</a></li><li><a href="#">":SBUS&lt;n&gt;:I2S:SOURce:DATA" on page 1003</a></li><li><a href="#">":SBUS&lt;n&gt;:I2S:SOURce:WSELect" on page 1004</a></li></ul>

## :SBUS<n>:I2S:SOURce:DATA

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:I2S:SOURce:DATA &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   EXTERNAL} for the DSO models</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;} for the MSO models</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	The :SBUS<n>:I2S:SOURce:DATA command controls which signal is used as the serial data (SDATA) source by the serial decoder and/or trigger when in I2S mode.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:I2S:SOURce:DATA?</code>
	The :SBUS<n>:I2S:SOURce:DATA? query returns the current source for the I2S serial data (SDATA).
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">:SBUS&lt;n&gt;:I2S:SOURce:CLOCK</a>" on page 1002</li> <li>• "<a href="#">:SBUS&lt;n&gt;:I2S:SOURce:WSELect</a>" on page 1004</li> </ul>

## :SBUS<n>:I2S:SOURce:WSElect

**N** (see [page 1666](#))

<b>Command Syntax</b>	<pre>:SBUS&lt;n&gt;:I2S:SOURce:WSElect &lt;source&gt;</pre> <pre>&lt;source&gt; ::= {CHANnel&lt;n&gt;   EXTernal} for the DSO models</pre> <pre>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;} for the MSO models</pre> <pre>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</pre> <pre>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</pre>
	The :SBUS<n>:I2S:SOURce:WSElect command controls which signal is used as the word select (WS) source by the serial decoder and/or trigger when in I2S mode.
<b>Query Syntax</b>	<pre>:SBUS&lt;n&gt;:I2S:SOURce:WSElect?</pre>
	The :SBUS<n>:I2S:SOURce:WSElect? query returns the current source for I2S word select (WS).
<b>Return Format</b>	<pre>&lt;source&gt;&lt;NL&gt;</pre>
<b>See Also</b>	<ul style="list-style-type: none"><li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li><li>• "<a href="#">:SBUS&lt;n&gt;:I2S:SOURce:CLOCK</a>" on page 1002</li><li>• "<a href="#">:SBUS&lt;n&gt;:I2S:SOURce:DATA</a>" on page 1003</li></ul>

## :SBUS<n>:I2S:TRIGger


**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:I2S:TRIGger <operator>

```
<operator> ::= {EQUAL | NOTEqual | LESSthan | GREaterthan | INRange
                 | OUTRange | INCReasing | DECReasing}
```

The :SBUS<n>:I2S:TRIGger command sets the I2S trigger operator:

- EQUAL – triggers on the specified audio channel's data word when it equals the specified word.
- NOTEqual – triggers on any word other than the specified word.
- LESSthan – triggers when the channel's data word is less than the specified value.
- GREaterthan – triggers when the channel's data word is greater than the specified value.
- INRange – enter upper and lower values to specify the range in which to trigger.
- OUTRange – enter upper and lower values to specify range in which trigger will not occur.
- INCReasing – triggers when the data value makes a certain increase over time and the specified value is met or exceeded. Use the :SBUS<n>:I2S:TRIGger:RANGe command to set "Trigger" and "Armed" values. The "Trigger" value is the value that must be met or exceeded to cause the trigger. The "Armed" value is the value the data must go below in order to re-arm the oscilloscope (ready it to trigger again).



- DECReasing – similar to INCReasing except the trigger occurs on a certain decrease over time and the "Trigger" data value is less than the "Armed" data value.

**Query Syntax** :SBUS<n>:I2S:TRIGger?

The :SBUS<n>:I2S:TRIGger? query returns the current I2S trigger operator.

**Return Format** <operator><NL>

<operator> ::= {EQU | NOT | LESS | GRE | INR | OUTR | INCR | DECR}

See Also · "[Introduction to :TRIGger Commands](#)" on page 1349

· "[":SBUS<n>:I2S:TRIGger:AUDio](#)" on page 1007

· "[":SBUS<n>:I2S:TRIGger:RANGE](#)" on page 1011

· "[":SBUS<n>:I2S:TRIGger:PATTERn:FORMat](#)" on page 1010

## :SBUS<n>:I2S:TRIGger:AUDio

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:I2S:TRIGger:AUDio <audio_ch>`  
`<audio_ch> ::= {RIGHT | LEFT | EITHer}`

The :SBUS<n>:I2S:TRIGger:AUDio command specifies the audio channel to trigger on:

- RIGHT – right channel.
- LEFT – left channel.
- EITHer – right or left channel.

**Query Syntax**    `:SBUS<n>:I2S:TRIGger:AUDio?`

The :SBUS<n>:I2S:TRIGger:AUDio? query returns the current audio channel for the I2S trigger.

**Return Format**    `<audio_ch><NL>`  
`<audio_ch> ::= {RIGH | LEFT | EITH}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":SBUS<n>:I2S:TRIGger"](#) on page 1005

## :SBUS<n>:I2S:TRIGger:PATTERn:DATA

**N** (see [page 1666](#))

### Command Syntax

```
:SBUS<n>:I2S:TRIGger:PATTERn:DATA <string>
<string> ::= "n" where n ::= 32-bit integer in signed decimal when
             <base> = DECimal
<string> ::= "nn...n" where n ::= {0 | 1 | X | $} when
             <base> = BINary
<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | X | $} when
             <base> = HEX
```

### NOTE

<base> is specified with the :SBUS<n>:I2S:TRIGger:PATTERn:FORMat command. The default <base> is DECimal.

The :SBUS<n>:I2S:TRIGger:PATTERn:DATA command specifies the I2S trigger data pattern searched for in each I2S message.

Set a <string> bit to "0" or "1" to set the corresponding bit in the data pattern to low or high, respectively.

Set a <string> bit to "X" to ignore (mask off) that bit in the data pattern.

Use the "\$" character to indicate that the value of the corresponding bit will not be changed (the existing bit value is used).

When <base> = DECimal, the "X" and "\$" characters cannot be entered. When queried, the "\$" character is returned when any bits in the pattern have the value of "X" and <base> = DECimal. When any bits in a given nibble have the value of "X" and <base> = HEX, the "\$" character is returned for the corresponding nibble.

### NOTE

The :SBUS<n>:I2S:TRIGger:PATTERn:DATA command specifies the I2S trigger data pattern used by the EQUal, NOTEqual, GREaterthan, and LESSthan trigger conditions. If the GREaterthan or LESSthan trigger condition is selected, the bits specified to be masked off ("X") will be interpreted as 0's.

### NOTE

The length of the trigger data value is determined by the :SBUS<n>:I2S:RWIDth and :SBUS<n>:I2S:TWIDth commands. When the receiver word size is less than the transmitter word size, the data length is equal to the receiver word size. When the receiver word size is greater than the transmitter word size, the data length is equal to the transmitter word size.

### NOTE

If more bits are sent for <string> than the specified trigger data length, the most significant bits will be truncated. If the word size is changed after the <string> is programmed, the added or deleted bits will be added to or deleted from the least significant bits.

**Query Syntax** :SBUS<n>:I2S:TRIGger:PATTERn:DATA?

The :SBUS<n>:I2S:TRIGger:PATTERn:DATA? query returns the currently specified I2S trigger data pattern.

**Return Format** <string><NL>

- See Also**
- "[Introduction to :TRIGger Commands](#)" on page 1349
  - "[:SBUS<n>:I2S:TRIGger:FORMAT](#)" on page 1010
  - "[:SBUS<n>:I2S:TRIGger](#)" on page 1005
  - "[:SBUS<n>:I2S:RWIDth](#)" on page 1001
  - "[:SBUS<n>:I2S:TWIDth](#)" on page 1012
  - "[:SBUS<n>:I2S:TRIGger:AUDio](#)" on page 1007

## :SBUS<n>:I2S:TRIGger:PATTERn:FORMAT

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:I2S:TRIGger:PATTERn:FORMAT <base>`  
                  `<base> ::= {BINary | HEX | DECimal}`

The :SBUS<n>:I2S:TRIGger:PATTERn:FORMAT command sets the entry (and query) number base used by the :SBUS<n>:I2S:TRIGger:PATTERn:DATA command. The default <base> is DECimal.

**Query Syntax**    `:SBUS<n>:I2S:TRIGger:PATTERn:FORMAT?`

The :SBUS<n>:I2S:TRIGger:PATTERn:FORMAT? query returns the currently set number base for I2S pattern data.

**Return Format**    `<base><NL>`  
                  `<base> ::= {BIN | HEX | DEC}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":SBUS<n>:I2S:TRIGger:AUDio](#)" on page 1007
- "[":SBUS<n>:I2S:TRIGger](#)" on page 1005

## :SBUS<n>:I2S:TRIGger:RANGE

**N** (see [page 1666](#))

**Command Syntax**

```
:SBUS<n>:I2S:TRIGger:RANGE <lower>,<upper>
<lower> ::= 32-bit integer in signed decimal, <nondecimal>
           or <string>
<upper> ::= 32-bit integer in signed decimal, <nondecimal>,
           or <string>
<nondecimal> ::= #Hnn...n where n ::= {0,...,9 | A,...,F}
                           for hexadecimal
<nondecimal> ::= #Bnn...n where n ::= {0 | 1} for binary
<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F} for hexadecimal
```

The :SBUS<n>:I2S:TRIGger:RANGE command sets the lower and upper range boundaries used by the INRange, OUTRange, INCReasing, and DECReasing trigger conditions. You can enter the parameters in any order – the smaller value becomes the <lower> and the larger value becomes the <upper>.

Note that for INCReasing and DECReasing, the <lower> and <upper> values correspond to the "Armed" and "Trigger" softkeys.

### NOTE

The length of the <lower> and <upper> values is determined by the :SBUS<n>:I2S:RWIDth and :SBUS<n>:I2S:TWIDth commands. When the receiver word size is less than the transmitter word size, the length is equal to the receiver word size. When the receiver word size is greater than the transmitter word size, the length is equal to the transmitter word size.

**Query Syntax**

```
:SBUS<n>:I2S:TRIGger:RANGE?
```

The :SBUS<n>:I2S:TRIGger:RANGE? query returns the currently set lower and upper range boundaries.

**Return Format**

```
<lower>,<upper><NL>
<lower> ::= 32-bit integer in signed decimal
<upper> ::= 32-bit integer in signed decimal
```

**See Also**

- ["Introduction to :TRIGger Commands"](#) on page 1349
- [":SBUS<n>:I2S:TRIGger"](#) on page 1005
- [":SBUS<n>:I2S:RWIDth"](#) on page 1001
- [":SBUS<n>:I2S:TWIDth"](#) on page 1012
- [":SBUS<n>:I2S:WSLow"](#) on page 1013

## :SBUS<n>:I2S:TWIDth

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:I2S:TWIDth <word_size>`

`<word_size> ::= 4-32 in NR1 format`

The :SBUS<n>:I2S:TWIDth command sets the width of the transmitted data word in I2S anywhere from 4 bits to 32 bits.

**Query Syntax**    `:SBUS<n>:I2S:TWIDth?`

The :SBUS<n>:I2S:TWIDth? query returns the currently set I2S transmitted data word width.

**Return Format**    `<word_size><NL>`

`<word_size> ::= 4-32 in NR1 format`

**See Also**

- "Introduction to :TRIGger Commands" on page 1349
- "[:SBUS<n>:I2S:ALIGNment](#)" on page 998
- "[:SBUS<n>:I2S:CLOCK:SLOPe](#)" on page 1000
- "[:SBUS<n>:I2S:RWIDth](#)" on page 1001
- "[:SBUS<n>:I2S:WSLow](#)" on page 1013

## :SBUS<n>:I2S:WSLow

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:I2S:WSLow <low_def>`  
`<low_def> ::= {LEFT | RIGHT}`

The :SBUS<n>:I2S:WSLow command selects the polarity of the word select (WS) signal:

- LEFT – a word select (WS) state of low indicates left channel data is active on the I2S bus, and a WS state of high indicates right channel data is active on the bus.
- RIGHT – a word select (WS) state of low indicates right channel data is active on the I2S bus, and a WS state of high indicates left channel data is active on the bus.

**Query Syntax**    `:SBUS<n>:I2S:WSLow?`

The :SBUS<n>:I2S:WSLow? query returns the currently selected I2S word select (WS) polarity.

**Return Format**    `<low_def><NL>`  
`<low_def> ::= {LEFT | RIGHT}`

**See Also**    ["Introduction to :TRIGger Commands"](#) on page 1349  
[":SBUS<n>:I2S:ALIGNment"](#) on page 998  
[":SBUS<n>:I2S:CLOCK:SLOPe"](#) on page 1000  
[":SBUS<n>:I2S:RWIDth"](#) on page 1001  
[":SBUS<n>:I2S:TWIDth"](#) on page 1012

## :SBUS<n>:IIC Commands

**NOTE**

These commands are valid when the low-speed IIC and SPI serial decode option has been licensed.

**Table 128** :SBUS<n>:IIC Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:IIC:ASIZE <size> (see page 1016)	:SBUS<n>:IIC:ASIZE? (see page 1016)	<size> ::= {BIT7   BIT8}
:SBUS<n>:IIC[:SOURce] :CLOCk <source> (see page 1017)	:SBUS<n>:IIC[:SOURce] :CLOCk? (see page 1017)	<source> ::= {CHANnel<n>   EXTERNAL} for DSO models <source> ::= {CHANnel<n>   DIGITAL<d>} for MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:IIC[:SOURce] :DATA <source> (see page 1018)	:SBUS<n>:IIC[:SOURce] :DATA? (see page 1018)	<source> ::= {CHANnel<n>   EXTERNAL} for DSO models <source> ::= {CHANnel<n>   DIGITAL<d>} for MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:IIC:TRIGger: PATtern:ADDRess <value> (see page 1019)	:SBUS<n>:IIC:TRIGger: PATtern:ADDRess? (see page 1019)	<value> ::= integer or <string> <string> ::= "0xnn" n ::= {0,...,9   A,...,F}
:SBUS<n>:IIC:TRIGger: PATtern:DATA <value> (see page 1020)	:SBUS<n>:IIC:TRIGger: PATtern:DATA? (see page 1020)	<value> ::= integer or <string> <string> ::= "0xnn" n ::= {0,...,9   A,...,F}
:SBUS<n>:IIC:TRIGger: PATtern:DATA2 <value> (see page 1021)	:SBUS<n>:IIC:TRIGger: PATtern:DATA2? (see page 1021)	<value> ::= integer or <string> <string> ::= "0xnn" n ::= {0,...,9   A,...,F}

**Table 128** :SBUS<n>:IIC Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:IIC:TRIGger: QUALifier <value> (see page 1022)	:SBUS<n>:IIC:TRIGger: QUALifier? (see page 1022)	<value> ::= {EQUAL   NOTEqual   LESSthan   GREaterthan}
:SBUS<n>:IIC:TRIGGER[ :TYPE] <type> (see page 1023)	:SBUS<n>:IIC:TRIGger[ :TYPE]? (see page 1023)	<type> ::= {STARt   STOP   RESTART   ADDRESS   ANACK   DNACK   NACKnowledge   READEprom   READ7   WRITE7   R7Data2   W7Data2   WRITE10}

## :SBUS<n>:IIC:ASIZE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:IIC:ASIZE <size>`  
                  `<size> ::= {BIT7 | BIT8}`

The :SBUS<n>:IIC:ASIZE command determines whether the Read/Write bit is included as the LSB in the display of the IIC address field of the decode bus.

**Query Syntax**    `:SBUS<n>:IIC:ASIZE?`

The :SBUS<n>:IIC:ASIZE? query returns the current IIC address width setting.

**Return Format**    `<mode><NL>`  
                  `<mode> ::= {BIT7 | BIT8}`

**Errors**    • ["-241, Hardware missing" on page 1607](#)

**See Also**    • ["Introduction to :SBUS<n> Commands" on page 905](#)  
                  • [":SBUS<n>:IIC Commands" on page 1014](#)

## :SBUS<n>:IIC[:SOURce]:CLOCK

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:IIC[:SOURce]:CLOCK <source>  
 <source> ::= {CHANnel<n> | EXTernal} for the DSO models  
 <source> ::= {CHANnel<n> | DIGital<d>} for the MSO models  
 <n> ::= 1 to (# analog channels) in NR1 format  
 <d> ::= 0 to (# digital channels - 1) in NR1 format  
 The :SBUS<n>:IIC[:SOURce]:CLOCK command sets the source for the IIC serial clock (SCL).

**Query Syntax** :SBUS<n>:IIC[:SOURce]:CLOCK?

The :SBUS<n>:IIC[:SOURce]:CLOCK? query returns the current source for the IIC serial clock.

**Return Format** <source><NL>

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":SBUS<n>:IIC\[:SOURce\]:DATA](#)" on page 1018

## :SBUS<n>:IIC[:SOURce]:DATA

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:IIC[:SOURce]:DATA <source>`

`<source> ::= {CHANnel<n> | EXTernal} for the DSO models`

`<source> ::= {CHANnel<n> | DIGital<d>} for the MSO models`

`<n> ::= 1 to (# analog channels) in NR1 format`

`<d> ::= 0 to (# digital channels - 1) in NR1 format`

The :SBUS<n>:IIC[:SOURce]:DATA command sets the source for IIC serial data (SDA).

**Query Syntax**    `:SBUS<n>:IIC[:SOURce]:DATA?`

The :SBUS<n>:IIC[:SOURce]:DATA? query returns the current source for IIC serial data.

**Return Format**    `<source><NL>`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":SBUS<n>:IIC\[:SOURce\]:CLOCK](#)" on page 1017

## :SBUS<n>:IIC:TRIGger:PATTERn:ADDResS

**N** (see [page 1666](#))

**Command Syntax**

```
:SBUS<n>:IIC:TRIGger:PATTERn:ADDResS <value>
<value> ::= integer or <string>
<string> ::= "0xnn" where n ::= {0,...,9 | A,...,F}
```

The :SBUS<n>:IIC:TRIGger:PATTERn:ADDResS command sets the address for IIC data. The address can range from 0x00 to 0x7F (7-bit) or 0x3FF (10-bit) hexadecimal. Use the don't care address (-1 or 0xFFFFFFFF) to ignore the address value.

**Query Syntax**

```
:SBUS<n>:IIC:TRIGger:PATTERn:ADDResS?
```

The :SBUS<n>:IIC:TRIGger:PATTERn:ADDResS? query returns the current address for IIC data.

**Return Format**

```
<value><NL>
<value> ::= integer
```

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:SBUS<n>:IIC:TRIGger:PATTERn:DATA](#)" on page 1020
- "[:SBUS<n>:IIC:TRIGger:PATTERn:DATA2](#)" on page 1021
- "[:SBUS<n>:IIC:TRIGger\[:TYPE\]](#)" on page 1023

## :SBUS<n>:IIC:TRIGger:PATTERn:DATA

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:IIC:TRIGger:PATTERn:DATA <value>`  
`<value> ::= integer or <string>`  
`<string> ::= "0xnn" where n ::= {0,...,9 | A,...,F}`

The :SBUS<n>:IIC:TRIGger:PATTERn:DATA command sets IIC data. The data value can range from 0x00 to 0xFF (hexadecimal). Use the don't care data pattern (-1 or 0xFFFFFFFF) to ignore the data value.

**Query Syntax**    `:SBUS<n>:IIC:TRIGger:PATTERn:DATA?`

The :SBUS<n>:IIC:TRIGger:PATTERn:DATA? query returns the current pattern for IIC data.

**Return Format**    `<value><NL>`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:SBUS<n>:IIC:TRIGger:PATTERn:ADDReSS](#)" on page 1019
- "[:SBUS<n>:IIC:TRIGger:PATTERn:DATa2](#)" on page 1021
- "[:SBUS<n>:IIC:TRIGger\[:TYPE\]](#)" on page 1023

## :SBUS<n>:IIC:TRIGger:PATTERn:DATA2

**N** (see [page 1666](#))

**Command Syntax**

```
:SBUS<n>:IIC:TRIGger:PATTERn:DATA2 <value>
<value> ::= integer or <string>
<string> ::= "0xnn" where n ::= {0,...,9 | A,...,F}
```

The :SBUS<n>:IIC:TRIGger:PATTERn:DATA2 command sets IIC data 2. The data value can range from 0x00 to 0xOFF (hexadecimal). Use the don't care data pattern (-1 or 0xFFFFFFFF) to ignore the data value.

**Query Syntax**

```
:SBUS<n>:IIC:TRIGger:PATTERn:DATA2?
```

The :SBUS<n>:IIC:TRIGger:PATTERn:DATA2? query returns the current pattern for IIC data 2.

**Return Format**

```
<value><NL>
```

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:SBUS<n>:IIC:TRIGger:PATTERn:ADDReSS](#)" on page 1019
- "[:SBUS<n>:IIC:TRIGger:PATTERn:DATA](#)" on page 1020
- "[:SBUS<n>:IIC:TRIGger\[:TYPE\]](#)" on page 1023

## :SBUS<n>:IIC:TRIGger:QUALifier

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:IIC:TRIGger:QUALifier &lt;value&gt;</code> <code>&lt;value&gt; ::= {EQUAL   NOTEQUAL   LESSthan   GREATERthan}</code>
	The :SBUS<n>:IIC:TRIGger:QUALifier command sets the IIC data qualifier when TRIGger:IIC:TRIGger[:TYPE] is set to READEprom.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:IIC:TRIGger:QUALifier?</code>
	The :SBUS<n>:IIC:TRIGger:QUALifier? query returns the current IIC data qualifier value.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code> <code>&lt;value&gt; ::= {EQUAL   NOTEQUAL   LESSthan   GREATERthan}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">"Introduction to :TRIGger Commands"</a> on page 1349</li><li><a href="#">":TRIGger:MODE"</a> on page 1362</li><li><a href="#">":SBUS&lt;n&gt;:IIC:TRIGger[:TYPE]"</a> on page 1023</li></ul>

## :SBUS<n>:IIC:TRIGger[:TYPE]

**N** (see [page 1666](#))

### Command Syntax

```
:SBUS<n>:IIC:TRIGger[:TYPE] <value>
<value> ::= {START | STOP | RESTart | ADDRess | ANACK | DNACK
| NACKnowledge | READEeprom | READ7 | WRITe7 | R7Data2 | W7Data2
| WRITe10}
```

The :SBUS<n>:IIC:TRIGger[:TYPE] command sets the IIC trigger type:

- STARt – Start condition.
- STOP – Stop condition.
- RESTart – Another start condition occurs before a stop condition.
- ADDRess – Triggers on the selected address. The R/W bit is ignored.
- ANACK – Address with no acknowledge.
- DNACK – Write data with no acknowledge.
- NACKnowledge – Missing acknowledge.
- READEeprom – EEPROM data read.
- READ7 – 7-bit address frame containing (Start:Address7:Read:Ack:Data). The value READ is also accepted for READ7.
- WRITe7 – 7-bit address frame containing (Start:Address7:Write:Ack:Data). The value WRITe is also accepted for WRITe7.
- R7Data2 – 7-bit address frame containing (Start:Address7:Read:Ack:Data:Ack:Data2).
- W7Data2 – 7-bit address frame containing (Start:Address7:Write:Ack:Data:Ack:Data2).
- WRITe10 – 10-bit address frame containing (Start:Address byte1:Write:Ack:Address byte 2:Data).

### NOTE

The short form of READ7 (READ7), READEeprom (READE), WRITe7 (WRIT7), and WRITe10 (WRIT10) do not follow the defined Long Form to Short Form Truncation Rules (see [page 1668](#)).

### Query Syntax

```
:SBUS<n>:IIC:TRIGger[:TYPE] ?
```

The :SBUS<n>:IIC:TRIGger[:TYPE]? query returns the current IIC trigger type value.

### Return Format

```
<value><NL>
```

```
<value> ::= {STAR | STOP | REST | ADDR | ANAC | DNAC | NACK | READE
| READ7 | WRIT7 | R7D2 | W7D2 | WRIT10}
```

### See Also

- "[Introduction to :TRIGger Commands](#)" on page 1349

- "[:TRIGger:MODE](#)" on page 1362
- "[:SBUS<n>:IIC:TRIGger:PATTERn:ADDReSS](#)" on page 1019
- "[:SBUS<n>:IIC:TRIGger:PATTERn:DATA](#)" on page 1020
- "[:SBUS<n>:IIC:TRIGger:PATTERn:DATA2](#)" on page 1021
- "[:SBUS<n>:IIC:TRIGger:QUALifier](#)" on page 1022
- "["Long Form to Short Form Truncation Rules"](#) on page 1668

## :SBUS<n>:LIN Commands

**NOTE**

These commands are valid when the CAN and LIN serial decode license has been enabled.

**Table 129** :SBUS<n>:LIN Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:LIN:DISPLAY <type> (see page 1027)	:SBUS<n>:LIN:DISPLAY? (see page 1027)	<type> ::= {HEXAdecimal   SYMBolic}
:SBUS<n>:LIN:PARity { {0   OFF}   {1   ON} } (see page 1028)	:SBUS<n>:LIN:PARity? (see page 1028)	{0   1}
:SBUS<n>:LIN:SAMPLEpo int <value> (see page 1029)	:SBUS<n>:LIN:SAMPLEpo int? (see page 1029)	<value> ::= {60   62.5   68   70   75   80   87.5} in NR3 format
:SBUS<n>:LIN:SIGNAl:B AUDrate <baudrate> (see page 1030)	:SBUS<n>:LIN:SIGNAl:B AUDrate? (see page 1030)	<baudrate> ::= integer from 2400 to 625000 in 100 b/s increments
:SBUS<n>:LIN:SOURce <source> (see page 1031)	:SBUS<n>:LIN:SOURce? (see page 1031)	<source> ::= {CHANnel<n>   EXTernal} for DSO models  <source> ::= {CHANnel<n>   DIGItal<d>} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:LIN:STANDARD <std> (see page 1032)	:SBUS<n>:LIN:STANDARD ? (see page 1032)	<std> ::= {LIN13   LIN13NLC   LIN20}
:SBUS<n>:LIN:SYNCbre ak <value> (see page 1033)	:SBUS<n>:LIN:SYNCbre ak? (see page 1033)	<value> ::= integer = {11   12   13}
:SBUS<n>:LIN:TRIGger <condition> (see page 1034)	:SBUS<n>:LIN:TRIGger? (see page 1034)	<condition> ::= {SYNCbreak   ID   DATA}

**Table 129** :SBUS<n>:LIN Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:LIN:TRIGger: ID <value> (see <a href="#">page 1036</a> )	:SBUS<n>:LIN:TRIGger: ID? (see <a href="#">page 1036</a> )	<value> ::= 7-bit integer in decimal, <nondecimal>, or <string> from 0-63 or 0x00-0x3f <nondecimal> ::= #Hnn where n ::= {0,...,9   A,...,F} for hexadecimal <nondecimal> ::= #Bnn...n where n ::= {0   1} for binary <string> ::= "0xnn" where n ::= {0,...,9   A,...,F} for hexadecimal
:SBUS<n>:LIN:TRIGger: PATTern:DATA <string> (see <a href="#">page 1037</a> )	:SBUS<n>:LIN:TRIGger: PATTern:DATA? (see <a href="#">page 1037</a> )	<string> ::= "n" where n ::= 32-bit integer in unsigned decimal when <base> = DECimal <string> ::= "nn...n" where n ::= {0   1   X   \$} when <base> = BINary <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$} when <base> = HEX
:SBUS<n>:LIN:TRIGGER: PATTern:DATA:LENGTH <length> (see <a href="#">page 1039</a> )	:SBUS<n>:LIN:TRIGger: PATTern:DATA:LENGTH? (see <a href="#">page 1039</a> )	<length> ::= integer from 1 to 8 in NR1 format
:SBUS<n>:LIN:TRIGger: PATTern:FORMAT <base> (see <a href="#">page 1040</a> )	:SBUS<n>:LIN:TRIGger: PATTern:FORMAT? (see <a href="#">page 1040</a> )	<base> ::= {BINary   HEX   DECimal}
:SBUS<n>:LIN:TRIGger: SYMBolic:FRAMe <name> (see <a href="#">page 1041</a> )	:SBUS<n>:LIN:TRIGger: SYMBolic:FRAMe? (see <a href="#">page 1041</a> )	<name> ::= quoted ASCII string
:SBUS<n>:LIN:TRIGger: SYMBolic:SIGNal <name> (see <a href="#">page 1042</a> )	:SBUS<n>:LIN:TRIGger: SYMBolic:SIGNal? (see <a href="#">page 1042</a> )	<name> ::= quoted ASCII string
:SBUS<n>:LIN:TRIGger: SYMBolic:VALue <data> (see <a href="#">page 1043</a> )	:SBUS<n>:LIN:TRIGger: SYMBolic:VALue? (see <a href="#">page 1043</a> )	<data> ::= value in NR3 format

## :SBUS<n>:LIN:DISPlay

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:LIN:DISPLAY <type>`  
                  `<type> ::= {HEXAdecimal | SYMBolic}`

The :SBUS<n>:LIN:DISPLAY command specifies, when LIN symbolic data is loaded into the oscilloscope, whether symbolic values (from the LDF file) or hexadecimal values are displayed in the decode waveform and the Lister window.

**Query Syntax**    `:SBUS<n>:LIN:DISPLAY?`  
The :SBUS<n>:LIN:DISPLAY? query returns the LIN decode display type.

**Return Format**    `<type><NL>`  
                  `<type> ::= {HEX | SYMB}`

**See Also**    · [":RECall:LDF\[:STARt\]" on page 867](#)

## :SBUS<n>:LIN:PARity

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:LIN:PARity <display>`  
`<display> ::= {{1 | ON} | {0 | OFF}}`

The :SBUS<n>:LIN:PARity command determines whether the parity bits are included as the most significant bits (MSB) in the display of the Frame Id field in the LIN decode bus.

**Query Syntax**    `:SBUS<n>:LIN:PARity?`

The :SBUS<n>:LIN:PARity? query returns the current LIN parity bits display setting of the serial decode bus.

**Return Format**    `<display><NL>`  
`<display> ::= {0 | 1}`

**Errors**    • ["-241, Hardware missing" on page 1607](#)

**See Also**    • ["Introduction to :SBUS<n> Commands" on page 905](#)  
• [":SBUS<n>:LIN Commands" on page 1025](#)

## :SBUS<n>:LIN:SAMPLEpoint

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:LIN:SAMPLEpoint &lt;value&gt;</code> <code>&lt;value&gt;&lt;NL&gt;</code> <code>&lt;value&gt; ::= { 60   62.5   68   70   75   80   87.5 } in NR3 format</code>
The :SBUS<n>:LIN:SAMPLEpoint command sets the point during the bit time where the bit level is sampled to determine whether the bit is dominant or recessive. The sample point represents the percentage of time between the beginning of the bit time to the end of the bit time.	

### NOTE

The sample point values are not limited by the baud rate.

<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:LIN:SAMPLEpoint?</code>
The :SBUS<n>:LIN:SAMPLEpoint? query returns the current LIN sample point setting.	
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code> <code>&lt;value&gt; ::= { 60   62.5   68   70   75   80   87.5 } in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">:TRIGger:MODE</a>" on page 1362</li> <li>• "<a href="#">:SBUS&lt;n&gt;:LIN:TRIGger</a>" on page 1034</li> </ul>

**:SBUS<n>:LIN:SIGNAl:BAUDrate****N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:LIN:SIGNAl:BAUDrate <baudrate>`  
`<baudrate> ::= integer from 2400 to 625000 in 100 b/s increments`

The :SBUS<n>:LIN:SIGNAl:BAUDrate command sets the standard baud rate of the LIN signal from 2400 b/s to 625 kb/s in 100 b/s increments. If you enter a baud rate that is not divisible by 100 b/s, the baud rate is set to the nearest baud rate divisible by 100 b/s.

**Query Syntax**    `:SBUS<n>:LIN:SIGNAl:BAUDrate?`

The :SBUS<n>:LIN:SIGNAl:BAUDrate? query returns the current LIN baud rate setting.

**Return Format**    `<baudrate><NL>`  
`<baudrate> ::= integer from 2400 to 625000 in 100 b/s increments`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:SBUS<n>:LIN:TRIGger](#)" on page 1034
- "[:SBUS<n>:LIN:SIGNAl:DEFinition](#)" on page 1599
- "[:SBUS<n>:LIN:SOURce](#)" on page 1031

## :SBUS<n>:LIN:SOURce

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:LIN:SOURce &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   EXTernal} for the DSO models</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;} for the MSO models</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	The :SBUS<n>:LIN:SOURce command sets the source for the LIN signal.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:LIN:SOURce?</code>
	The :SBUS<n>:LIN:SOURce? query returns the current source for the LIN signal.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">:TRIGger:MODE</a>" on page 1362</li> <li>• "<a href="#">:SBUS&lt;n&gt;:LIN:TRIGger</a>" on page 1034</li> <li>• "<a href="#">:SBUS&lt;n&gt;:LIN:SIGNal:DEFinition</a>" on page 1599</li> </ul>

## :SBUS<n>:LIN:STANDARD

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:LIN:STANDARD <std>`  
`<std> ::= {LIN13 | LIN13NLC | LIN20}`

The :SBUS<n>:LIN:STANDARD command sets the LIN standard in effect for triggering and decoding:

- LIN13 – LIN 1.3.
- LIN13NLC – LIN 1.3 (no length control). Select this for systems where length control is not used and all nodes have knowledge of the data packet size. In LIN 1.3, the ID may or may not be used to indicate the number of bytes. (In LIN 2.X, there is no length control.)
- LIN20 – LIN 2.X.

For LIN 1.2 signals, use the LIN 1.3 setting. The LIN 1.3 setting assumes the signal follows the "Table of Valid ID Values" as shown in section A.2 of the LIN Specification dated December 12, 2002. If your signal does not comply with the table, use the LIN 2.X setting.

**Query Syntax**    `:SBUS<n>:LIN:STANDARD?`

The :SBUS<n>:LIN:STANDARD? query returns the current LIN standard setting.

**Return Format**    `<std><NL>`  
`<std> ::= {LIN13 | LIN13NLC | LIN20}`

**See Also**

- "[Introduction to :TRIGGER Commands](#)" on page 1349
- "[:TRIGGER:MODE](#)" on page 1362
- "[:SBUS<n>:LIN:SIGNAl:DEFinition](#)" on page 1599
- "[:SBUS<n>:LIN:SOURce](#)" on page 1031

## :SBUS<n>:LIN:SYNCbreak

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:LIN:SYNCbreak <value>`

`<value> ::= integer = {11 | 12 | 13}`

The :SBUS<n>:LIN:SYNCbreak command sets the length of the LIN sync break to be greater than or equal to 11, 12, or 13 clock lengths. The sync break is the idle period in the bus activity at the beginning of each packet that distinguishes one information packet from the previous one.

**Query Syntax**    `:SBUS<n>:LIN:SYNCbreak?`

The :SBUS<n>:LIN:SYNCbreak? query returns the current LIN sync break setting.

**Return Format**    `<value><NL>`

`<value> ::= {11 | 12 | 13}`

**See Also**

- "Introduction to :TRIGger Commands" on page 1349
- ":TRIGger:MODE" on page 1362
- ":SBUS<n>:LIN:SIGNAl:DEFinition" on page 1599
- ":SBUS<n>:LIN:SOURce" on page 1031

## :SBUS<n>:LIN:TRIGger

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:LIN:TRIGger &lt;condition&gt;</code>
	<code>&lt;condition&gt; ::= {SYNCbreak   ID   DATA   PARityerror   CSUMerror   FRAMe   FSIGnal}</code>
	The :SBUS<n>:LIN:TRIGger command sets the LIN trigger condition to be:
	<ul style="list-style-type: none"> <li>• SYNCbreak – Sync Break.</li> <li>• ID – Frame ID.</li> </ul> <p>Use the :SBUS&lt;n&gt;:LIN:TRIGger:ID command to specify the frame ID.</p> <ul style="list-style-type: none"> <li>• DATA – Frame ID and Data.</li> </ul> <p>Use the :SBUS&lt;n&gt;:LIN:TRIGger:ID command to specify the frame ID.</p> <p>Use the :SBUS&lt;n&gt;:LIN:TRIGger:PATTERn:DATA:LENGth and :SBUS&lt;n&gt;:LIN:TRIGger:PATTERn:DATA commands to specify the data string length and value.</p> <ul style="list-style-type: none"> <li>• PARityerror – parity errors.</li> <li>• CSUMerror – checksum errors.</li> <li>• FRAMe – Triggers on a symbolic frame.</li> <li>• FSIGnal – Triggers on a symbolic frame and a signal value.</li> </ul>
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:LIN:TRIGger?</code>
	The :SBUS<n>:LIN:TRIGger? query returns the current LIN trigger value.
<b>Return Format</b>	<code>&lt;condition&gt;&lt;NL&gt;</code> <code>&lt;condition&gt; ::= {SYNC   ID   DATA   PAR   CSUM   FRAM   FSIG}</code>
<b>Errors</b>	<ul style="list-style-type: none"> <li>• <a href="#">"-241, Hardware missing"</a> on page 1607</li> </ul>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">"Introduction to :TRIGger Commands"</a> on page 1349</li> <li>• <a href="#">":TRIGger:MODE"</a> on page 1362</li> <li>• <a href="#">":SBUS&lt;n&gt;:LIN:TRIGger:ID"</a> on page 1036</li> <li>• <a href="#">":SBUS&lt;n&gt;:LIN:TRIGger:PATTERn:DATA:LENGth"</a> on page 1039</li> <li>• <a href="#">":SBUS&lt;n&gt;:LIN:TRIGger:PATTERn:DATA"</a> on page 1037</li> <li>• <a href="#">":SBUS&lt;n&gt;:LIN:SIGNal:DEFinition"</a> on page 1599</li> <li>• <a href="#">":SBUS&lt;n&gt;:LIN:SOURce"</a> on page 1031</li> <li>• <a href="#">":RECall:LDF[:START]"</a> on page 867</li> <li>• <a href="#">":SBUS&lt;n&gt;:LIN:TRIGger:SYMBOLic:FRAMe"</a> on page 1041</li> <li>• <a href="#">":SBUS&lt;n&gt;:LIN:TRIGger:SYMBOLic:SIGNal"</a> on page 1042</li> </ul>

- [":SBUS<n>:LIN:TRIGger:SYMBolic:VALue"](#) on page 1043

## :SBUS<n>:LIN:TRIGger:ID

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:LIN:TRIGger:ID &lt;value&gt;</code>
	<pre>&lt;value&gt; ::= 7-bit integer in decimal, &lt;nondecimal&gt;, or &lt;string&gt;            from 0-63 or 0x00-0x3f  &lt;nondecimal&gt; ::= #Hnn where n ::= {0,...,9   A,...,F} for hexadecimal &lt;nondecimal&gt; ::= #Bnn...n where n ::= {0   1} for binary &lt;string&gt; ::= "0xnn" where n ::= {0,...,9   A,...,F} for hexadecimal</pre>
	The :SBUS<n>:LIN:TRIGger:ID command defines the LIN identifier searched for in each CAN message when the LIN trigger mode is set to frame ID.
	Setting the ID to a value of "-1" results in "0xXX" which is equivalent to all IDs.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:LIN:TRIGger:ID?</code>
	The :SBUS<n>:LIN:TRIGger:ID? query returns the current LIN identifier setting.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code>
	<pre>&lt;value&gt; ::= integer in decimal</pre>
<b>Errors</b>	<ul style="list-style-type: none"> <li>• <a href="#">"-241, Hardware missing" on page 1607</a></li> </ul>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">"Introduction to :TRIGger Commands" on page 1349</a></li> <li>• <a href="#">":TRIGger:MODE" on page 1362</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:LIN:TRIGger" on page 1034</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:LIN:SIGNal:DEFinition" on page 1599</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:LIN:SOURce" on page 1031</a></li> </ul>

## :SBUS<n>:LIN:TRIGger:PATTERn:DATA

**N** (see [page 1666](#))

### Command Syntax

```
:SBUS<n>:LIN:TRIGger:PATTERn:DATA <string>
<string> ::= "n" where n ::= 32-bit integer in unsigned decimal when
             <base> = DECimal
<string> ::= "nn...n" where n ::= {0 | 1 | X | $} when
             <base> = BINary
<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | X | $} when
             <base> = HEX
```

### NOTE

<base> is specified with the :SBUS<n>:LIN:TRIGger:PATTERn:FORMat command. The default <base> is BINary.

The :SBUS<n>:LIN:TRIGger:PATTERn:DATA command specifies the LIN trigger data pattern searched for in each LIN data field.

Set a <string> bit to "0" or "1" to set the corresponding bit in the data pattern to low or high, respectively.

Set a <string> bit to "X" to ignore (mask off) that bit in the data pattern.

Use the "\$" character to indicate that the value of the corresponding bit will not be changed (the existing bit value is used).

When <base> = DECimal, the "X" and "\$" characters cannot be entered. When queried, the "\$" character is returned when any bits in the pattern have the value of "X" and <base> = DECimal. When any bits in a given nibble have the value of "X" and <base> = HEX, the "\$" character is returned for the corresponding nibble.

### NOTE

The length of the trigger data value is determined by the :SBUS<n>:LIN:TRIGger:PATTERn:DATA:LENGTH command.

### NOTE

If more bits are sent for <string> than the specified trigger pattern data length, the most significant bits will be truncated. If the data length size is changed after the <string> is programmed, the added or deleted bits will be added to or deleted from the least significant bits.

### Query Syntax

```
:SBUS<n>:LIN:TRIGger:PATTERn:DATA?
```

The :SBUS<n>:LIN:TRIGger:PATTERn:DATA? query returns the currently specified LIN trigger data pattern.

### Return Format

```
<string><NL>
```

See Also

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:SBUS<n>:LIN:TRIGger:PTT:FORMAT](#)" on page 1040
- "[:SBUS<n>:LIN:TRIGger](#)" on page 1034
- "[:SBUS<n>:LIN:TRIGger:PTT:DATA:LENGTH](#)" on page 1039

## :SBUS<n>:LIN:TRIGger:PATTERn:DATA:LENGth

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:LIN:TRIGger:PATTERn:DATA:LENGth &lt;length&gt;</code> <code>&lt;length&gt; ::= integer from 1 to 8 in NR1 format</code>
	The :SBUS<n>:LIN:TRIGger:PATTERn:DATA:LENGth command sets the number of 8-bit bytes in the LIN data string. The number of bytes in the string can be anywhere from 1 bytes to 8 bytes (64 bits). The value for these bytes is set by the :SBUS<n>:LIN:TRIGger:PATTERn:DATA command.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:LIN:TRIGger:PATTERn:DATA:LENGth?</code>
	The :SBUS<n>:LIN:TRIGger:PATTERn:DATA:LENGth? query returns the current LIN data pattern length setting.
<b>Return Format</b>	<code>&lt;count&gt;&lt;NL&gt;</code> <code>&lt;count&gt; ::= integer from 1 to 8 in NR1 format</code>
<b>Errors</b>	<ul style="list-style-type: none"> <li>· <a href="#">"-241, Hardware missing" on page 1607</a></li> </ul>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">"Introduction to :TRIGger Commands" on page 1349</a></li> <li>· <a href="#">":SBUS&lt;n&gt;:LIN:TRIGger:PATTERn:DATA" on page 1037</a></li> <li>· <a href="#">":SBUS&lt;n&gt;:LIN:SOURce" on page 1031</a></li> </ul>

## :SBUS<n>:LIN:TRIGger:PATTern:FORMAT

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:LIN:TRIGger:PATTern:FORMAT <base>`  
                  `<base> ::= {BINary | HEX | DECimal}`

The :SBUS<n>:LIN:TRIGger:PATTern:FORMAT command sets the entry (and query) number base used by the :SBUS<n>:LIN:TRIGger:PATTern:DATA command. The default <base> is BINary.

**Query Syntax**    `:SBUS<n>:LIN:TRIGger:PATTern:FORMAT?`

The :SBUS<n>:LIN:TRIGger:PATTern:FORMAT? query returns the currently set number base for LIN pattern data.

**Return Format**    `<base><NL>`  
                  `<base> ::= {BIN | HEX | DEC}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":SBUS<n>:LIN:TRIGger:PATTern:DATA](#)" on page 1037
- "[":SBUS<n>:LIN:TRIGger:PATTern:DATA:LENGth](#)" on page 1039

## :SBUS<n>:LIN:TRIGger:SYMBolic:FRAMe

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:LIN:TRIGger:SYMBolic:FRAMe <name>

<name> ::= quoted ASCII string

The :SBUS<n>:LIN:TRIGger:SYMBolic:FRAMe command specifies the message to trigger on when LIN symbolic data has been loaded (recalled) into the oscilloscope and the LIN trigger mode is set to FRAMe or FSIGnal.

**Query Syntax** :SBUS<n>:LIN:TRIGger:SYMBolic:FRAMe?

The :SBUS<n>:LIN:TRIGger:SYMBolic:FRAMe? query returns the specified message.

**Return Format** <name><NL>

<name> ::= quoted ASCII string

**See Also**

- "[:RECall:LDF\[:START\]](#)" on page 867
- "[:SBUS<n>:LIN:TRIGger](#)" on page 1034
- "[:SBUS<n>:LIN:TRIGger:SYMBolic:SIGNAl](#)" on page 1042
- "[:SBUS<n>:LIN:TRIGger:SYMBolic:VALue](#)" on page 1043

## :SBUS<n>:LIN:TRIGger:SYMBolic:SIGNal

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:LIN:TRIGger:SYMBolic:SIGNal <name>`

`<name> ::= quoted ASCII string`

The :SBUS<n>:LIN:TRIGger:SYMBolic:SIGNal command specifies the signal to trigger on when LIN symbolic data has been loaded (recalled) into the oscilloscope and the LIN trigger mode is set to FSIGnAl.

**Query Syntax**    `:SBUS<n>:LIN:TRIGger:SYMBolic:SIGNal?`

The :SBUS<n>:LIN:TRIGger:SYMBolic:SIGNal? query returns the specified signal.

**Return Format**    `<name><NL>`

`<name> ::= quoted ASCII string`

**See Also**

- "[:RECall:LDF\[:STARt\]](#)" on page 867
- "[:SBUS<n>:LIN:TRIGger](#)" on page 1034
- "[:SBUS<n>:LIN:TRIGger:SYMBolic:FRAMe](#)" on page 1041
- "[:SBUS<n>:LIN:TRIGger:SYMBolic:VALue](#)" on page 1043

## :SBUS<n>:LIN:TRIGger:SYMBolic:VALue

**N** (see [page 1666](#))

**Command Syntax**

```
:SBUS<n>:LIN:TRIGger:SYMBolic:VALue <data>
<data> ::= value in NR3 format
```

The :SBUS<n>:LIN:TRIGger:SYMBolic:VALue command specifies the signal value to trigger on when LIN symbolic data has been loaded (recalled) into the oscilloscope and the LIN trigger mode is set to FSIGnal.

**NOTE**

Encoded signal values are not supported in the remote interface (even though they can be used in the front panel graphical interface).

**Query Syntax**

```
:SBUS<n>:LIN:TRIGger:SYMBolic:VALue?
```

The :SBUS<n>:LIN:TRIGger:SYMBolic:VALue? query returns the specified signal value.

**Return Format**

```
<data><NL>
<data> ::= value in NR3 format
```

**See Also**

- "[:RECall:LDF\[:STARt\]](#)" on page 867
- "[:SBUS<n>:LIN:TRIGger](#)" on page 1034
- "[:SBUS<n>:LIN:TRIGger:SYMBolic:FRAMe](#)" on page 1041
- "[:SBUS<n>:LIN:TRIGger:SYMBolic:SIGNal](#)" on page 1042

## :SBUS<n>:M1553 Commands

**NOTE**

These commands are valid when the MIL-STD-1553 and ARINC 429 triggering and serial decode license has been enabled.

**Table 130** :SBUS<n>:M1553 Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:M1553:AUTose tup (see <a href="#">page 1045</a> )	n/a	n/a
:SBUS<n>:M1553:BASE <base> (see <a href="#">page 1046</a> )	:SBUS<n>:M1553:BASE? (see <a href="#">page 1046</a> )	<base> ::= {BINary   HEX}
:SBUS<n>:M1553:SOURce <source> (see <a href="#">page 1047</a> )	:SBUS<n>:M1553:SOURce? (see <a href="#">page 1047</a> )	<source> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format
:SBUS<n>:M1553:TRIGge r:PATTern:DATA <string> (see <a href="#">page 1048</a> )	:SBUS<n>:M1553:TRIGge r:PATTern:DATA? (see <a href="#">page 1048</a> )	<string> ::= "nn...n" where n ::= {0   1   X}
:SBUS<n>:M1553:TRIGge r:RTA <value> (see <a href="#">page 1049</a> )	:SBUS<n>:M1553:TRIGge r:RTA? (see <a href="#">page 1049</a> )	<value> ::= 5-bit integer in decimal, <nondecimal>, or <string> from 0-31 <nondecimal> ::= #Hnn where n ::= {0,...,9 A,...,F} <string> ::= "0xnn" where n ::= {0,...,9 A,...,F}
:SBUS<n>:M1553:TRIGge r:TYPE <type> (see <a href="#">page 1050</a> )	:SBUS<n>:M1553:TRIGge r:TYPE? (see <a href="#">page 1050</a> )	<type> ::= {DSTArt   DSTOp   CSTArt   CSTOp   RTA   PERRor   SERRor   MERRor   RTA11}

## :SBUS<n>:M1553:AUTosetup

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:M1553:TRIGger:AUTosetup

The :SBUS<n>:M1553:AUTosetup command automatically sets these options for decoding and triggering on MIL-STD-1553 signals:

- High/Low Trigger Thresholds: to a voltage value equal to  $\pm 1/3$  division based on the source channel's current V/div setting.
- Noise Reject: Off.
- Probe Attenuation: 10.0.
- Serial Decode: On.
- Trigger: the specified serial bus (n of SBUS<n>).

**See Also** ["Introduction to :TRIGger Commands"](#) on page 1349  
[":TRIGger:MODE"](#) on page 1362  
[":SBUS<n>:M1553:SOURce"](#) on page 1047

**:SBUS<n>:M1553:BASE**

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:M1553:BASE <base>`

`<base> ::= {BINary | HEX}`

The :SBUS<n>:M1553:BASE command determines the base to use for the MIL-STD-1553 decode display.

**Query Syntax**    `:SBUS<n>:M1553:BASE?`

The :SBUS<n>:M1553:BASE? query returns the current MIL-STD-1553 display decode base.

**Return Format**    `<base><NL>`

`<base> ::= {BIN | HEX}`

**Errors**    • ["-241, Hardware missing" on page 1607](#)

**See Also**    • ["Introduction to :SBUS<n> Commands" on page 905](#)  
                • [":SBUS<n>:M1553 Commands" on page 1044](#)

## :SBUS<n>:M1553:SOURce

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:M1553:SOURce &lt;source&gt;</code> <code>&lt;source&gt; ::= {CHANnel&lt;n&gt;}</code> <code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	The :SBUS<n>:M1553:SOURce command sets the source of the MIL-STD 1553 signal.
	Use the :TRIGger:LEVel:HIGH and :TRIGger:LEVel:LOW commands to set the threshold levels for the selected source.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:M1553:TRIGger:SOURce?</code>
	The :SBUS<n>:M1553:SOURce? query returns the currently set source of the MIL-STD 1553 signal.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code> <code>&lt;source&gt; ::= {CHAN&lt;n&gt;}</code> <code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":TRIGger:LEVel:HIGH"</a> on page 1360</li> <li>· <a href="#">":TRIGger:LEVel:LOW"</a> on page 1361</li> <li>· <a href="#">":TRIGger:MODE"</a> on page 1362</li> <li>· <a href="#">"Introduction to :TRIGger Commands"</a> on page 1349</li> </ul>

## :SBUS<n>:M1553:TRIGger:PATTERn:DATA

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:M1553:TRIGger:PATTERn:DATA <string>`  
`<string> ::= "nn...n" where n ::= {0 | 1 | x}`

The :SBUS<n>:M1553:TRIGger:PATTERn:DATA command sets the 11 bits to trigger on if the trigger type has been set to RTA11 (RTA + 11 Bits) using the :SBUS<n>:M1553:TRIGger:TYPE command.

**Query Syntax**    `:SBUS<n>:M1553:TRIGger:PATTERn:DATA?`

The :SBUS<n>:M1553:TRIGger:PATTERn:DATA? query returns the current 11-bit setting.

**Return Format**    `<string><NL>`  
`<string> ::= "nn...n" where n ::= {0 | 1 | x}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":SBUS<n>:M1553:TRIGger:TYPE](#)" on page 1050
- "[":SBUS<n>:M1553:TRIGger:RTA](#)" on page 1049

## :SBUS<n>:M1553:TRIGger:RTA

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:M1553:TRIGger:RTA <value>

```
<value> ::= 5-bit integer in decimal, <nondecimal>, or
           <string> from 0-31

<nondecimal> ::= #Hnn where n ::= {0,...,9|A,...,F}

<string> ::= "0xnn" where n::= {0,...,9|A,...,F}
```

The :SBUS<n>:M1553:TRIGger:RTA command sets the Remote Terminal Address (RTA) to trigger on when the trigger type has been set to RTA or RTA11 (using the :SBUS<n>:M1553:TRIGger:TYPE command).

To set the RTA value to don't cares (0xXX), set the value to -1.

**Query Syntax** :SBUS<n>:M1553:TRIGger:RTA?

The :SBUS<n>:M1553:TRIGger:RTA? query returns the RTA value.

**Return Format** <value><NL> in decimal format

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:SBUS<n>:M1553:TRIGger:TYPE](#)" on page 1050

## :SBUS<n>:M1553:TRIGger:TYPE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:M1553:TRIGger:TYPE <type>`

$$\begin{aligned} <\text{type}> ::= \{ &\text{DSTArt} \mid \text{DSTOp} \mid \text{CSTArt} \mid \text{CSTOP} \mid \text{RTA} \mid \text{PERRor} \mid \text{SERRor} \\ &\mid \text{MERRor} \mid \text{RTA11} \} \end{aligned}$$

The :SBUS<n>:M1553:TRIGger:TYPE command specifies the type of MIL-STD-1553 trigger to be used:

- DSTArt – (Data Word Start) triggers on the start of a Data word (at the end of a valid Data Sync pulse).
- DSTOp – (Data Word Stop) triggers on the end of a Data word.
- CSTArt – (Command/Status Word Start) triggers on the start of Command/Status word (at the end of a valid C/S Sync pulse).
- CSTOP – (Command/Status Word Stop) triggers on the end of a Command/Status word.
- RTA – (Remote Terminal Address) triggers if the RTA of the Command/Status word matches the specified value. The value is specified in hex.
- RTA11 – (RTA + 11 Bits) triggers if the RTA and the remaining 11 bits match the specified criteria. The RTA can be specified as a hex value, and the remaining 11 bits can be specified as a 1, 0, or X (don't care).
- PERRor – (Parity Error) triggers if the (odd) parity bit is incorrect for the data in the word.
- MERRor – (Manchester Error) triggers if a Manchester encoding error is detected.
- SERRor – (Sync Error) triggers if an invalid Sync pulse is found.

**Query Syntax**    `:SBUS<n>:M1553:TRIGger:TYPE?`

The :SBUS<n>:M1553:TRIGger:TYPE? query returns the currently set MIL-STD-1553 trigger type.

**Return Format**    `<type><NL>`

$$\begin{aligned} <\text{type}> ::= \{ &\text{DSTA} \mid \text{DSTO} \mid \text{CSTA} \mid \text{CSTO} \mid \text{RTA} \mid \text{PERR} \mid \text{SERR} \\ &\mid \text{MERR} \mid \text{RTA11} \} \end{aligned}$$

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":SBUS<n>:M1553:TRIGger:RTA](#)" on page 1049
- "[":SBUS<n>:M1553:TRIGger:PATTERn:DATA](#)" on page 1048
- "[":TRIGger:MODE](#)" on page 1362

## :SBUS<n>:MANChester Commands

**NOTE**

These commands are valid when the automotive MANChester serial decode and triggering option has been licensed.

**Table 131** :SBUS<n>:MANChester Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:MANChester:B ASE <base> (see page 1053)	:SBUS<n>:MANChester:B ASE? (see <a href="#">page 1053</a> )	<base> ::= {HEX   DECimal   ASCii}
:SBUS<n>:MANChester:B AUDrate <baudrate> (see page 1054)	:SBUS<n>:MANChester:B AUDrate? (see <a href="#">page 1054</a> )	<baudrate> ::= integer from 500 to 5000000 in 100 b/s increments
:SBUS<n>:MANChester:B ITorder <bitorder> (see page 1055)	:SBUS<n>:MANChester:B ITorder? (see <a href="#">page 1055</a> )	<bitorder> ::= {MSBFirst   LSBFirst}
:SBUS<n>:MANChester:D ISPlay <format> (see page 1056)	:SBUS<n>:MANChester:D ISPlay? (see <a href="#">page 1056</a> )	<format> ::= {BIT   WORD}
:SBUS<n>:MANChester:D SIZE {AUTO   <#words>} (see page 1057)	:SBUS<n>:MANChester:D SIZE? (see <a href="#">page 1057</a> )	<#words> ::= from 1-255, in NR1 format
:SBUS<n>:MANChester:H SIZE <#bits> (see page 1058)	:SBUS<n>:MANChester:H SIZE? (see <a href="#">page 1058</a> )	<#bits> ::= from 0-32, in NR1 format
:SBUS<n>:MANChester:I DLE:BITS <#bits> (see page 1059)	:SBUS<n>:MANChester:I DLE:BITS? (see <a href="#">page 1059</a> )	<#bits> ::= minimum idle time in terms of bit width, from 1.50 to 32.0, in NR3 format.
:SBUS<n>:MANChester:L OGic <logic> (see page 1060)	:SBUS<n>:MANChester:L OGic? (see <a href="#">page 1060</a> )	<logic> ::= {FALLing   RISing}
:SBUS<n>:MANChester:S OURce <source> (see page 1061)	:SBUS<n>:MANChester:S OURce? (see <a href="#">page 1061</a> )	<source> ::= {CHANnel<n>   DIGital<d>}
:SBUS<n>:MANChester:S IZE <#bits> (see page 1062)	:SBUS<n>:MANChester:S IZE? (see <a href="#">page 1062</a> )	<#bits> ::= from 0-255, in NR1 format
:SBUS<n>:MANChester:S TART <edge#> (see page 1063)	:SBUS<n>:MANChester:S TART? (see <a href="#">page 1063</a> )	<edge#> ::= from 1-256, in NR1 format

**Table 131** :SBUS<n>:MANChester Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:MANChester:TOLerance <percent> (see <a href="#">page 1064</a> )	:SBUS<n>:MANChester:TOLerance? (see <a href="#">page 1064</a> )	<percent> ::= from 1-30, in NR1 format
:SBUS<n>:MANChester:TRIGger <mode> (see <a href="#">page 1065</a> )	:SBUS<n>:MANChester:TRIGger? (see <a href="#">page 1065</a> )	<mode> ::= {SOF   VALue   MERRor}
:SBUS<n>:MANChester:TRIGger:PATTern:VALue:DATA <string> (see <a href="#">page 1066</a> )	:SBUS<n>:MANChester:TRIGger:PATTern:VALue:DATA? (see <a href="#">page 1066</a> )	<string> ::= "nn...n" where n ::= {0   1   X   \$} <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:MANChester:TRIGger:PATTern:VALue:WIDTh <width> (see <a href="#">page 1067</a> )	:SBUS<n>:MANChester:TRIGger:PATTern:VALue:WIDTh? (see <a href="#">page 1067</a> )	<width> ::= integer from 4 to 128 in NR1 format
:SBUS<n>:MANChester:TSIZE <#bits> (see <a href="#">page 1068</a> )	:SBUS<n>:MANChester:TSIZE? (see <a href="#">page 1068</a> )	<#bits> ::= from 0-32, in NR1 format
:SBUS<n>:MANChester:WSIZE <#bits> (see <a href="#">page 1069</a> )	:SBUS<n>:MANChester:WSIZE? (see <a href="#">page 1069</a> )	<#bits> ::= from 2-32, in NR1 format

## :SBUS<n>:MANChester:BASE

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:MANChester:BASE <base>

<base> ::= {HEX | DECimal | ASCii | BINary}

When the display format is WORD (see :SBUS<n>:MANChester:DISPlay), the :SBUS<n>:MANChester:BASE command specifies the base for the Manchester bus decode and Lister display.

- HEX – hexadecimal
- DECimal – unsigned decimal
- ASCii

When the display format is BIT, the only legal decode base value is BINary.

**Query Syntax** :SBUS<n>:MANChester:BASE?

The :SBUS<n>:MANChester:BASE? query returns the decode number base setting.

**Return Format** <base><NL>

<base> ::= {HEX | DEC | ASC | BIN}

**See Also**

- "[:SBUS<n>:MANChester:BITorder](#)" on page 1055
- "[:SBUS<n>:MANChester:IDLE:BITS](#)" on page 1059
- "[:SBUS<n>:MANChester:LOGic](#)" on page 1060
- "[:SBUS<n>:MANChester:START](#)" on page 1063

## :SBUS<n>:MANChester:BAUDrate

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:MANChester:BAUDrate &lt;baudrate&gt;</code> <code>&lt;baudrate&gt; ::= integer from 500 to 5000000 in 100 b/s increments</code>
	The :SBUS<n>:MANChester:BAUDrate command specifies the baud rate of the Manchester signal.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:MANChester:BAUDrate?</code>
	The :SBUS<n>:MANChester:BAUDrate? query returns the specified baud rate.
<b>Return Format</b>	<code>&lt;baudrate&gt;&lt;NL&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":SBUS&lt;n&gt;:MANChester:SOURce" on page 1061</a></li><li><a href="#">":SBUS&lt;n&gt;:MANChester:TOLerance" on page 1064</a></li></ul>

## :SBUS<n>:MANChester:BITorder

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:MANChester:BITorder <bitorder>`  
`<bitorder> ::= {MSBFirst | LSBFirst}`

When the display format is WORD (see :SBUS<n>:MANChester:DISPlay), the :SBUS<n>:MANChester:BITorder command specifies the order of transmission on the Manchester bus:

- MSBFirst – specifies the most significant bit is transmitted first.
- LSBFirst – specifies the least significant bit is transmitted first.

**Query Syntax**    `:SBUS<n>:MANChester:BITorder?`

The :SBUS<n>:MANChester:BITorder? query returns the bit order setting.

**Return Format**    `<bitorder><NL>`  
`<bitorder> ::= {MSBF | LSBF}`

**See Also**

- "[:SBUS<n>:MANChester:BASE](#)" on page 1053
- "[:SBUS<n>:MANChester:IDLE:BITS](#)" on page 1059
- "[:SBUS<n>:MANChester:LOGic](#)" on page 1060
- "[:SBUS<n>:MANChester:START](#)" on page 1063

## :SBUS<n>:MANChester:DISPlay

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:MANChester:DISPlay <format>`  
`<format> ::= {BIT | WORD}`

The :SBUS<n>:MANChester:DISPlay command specifies the format of the Manchester bus display.

**Query Syntax**    `:SBUS<n>:MANChester:DISPlay?`

The :SBUS<n>:MANChester:DISPlay? query returns the bus display format setting.

**Return Format**    `<format><NL>`  
`<format> ::= {BIT | WORD}`

**See Also**

- [":SBUS<n>:MANChester:DSIZE"](#) on page 1057
- [":SBUS<n>:MANChester:HSIZE"](#) on page 1058
- [":SBUS<n>:MANChester:SSIZE"](#) on page 1062
- [":SBUS<n>:MANChester:TSIZE"](#) on page 1068
- [":SBUS<n>:MANChester:WSIZE"](#) on page 1069

## :SBUS<n>:MANChester:DSIZE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:MANChester:DSIZE {AUTO | <#words>}`  
`<#words> ::= from 1-255, in NR1 format`

When the display format is WORD (see :SBUS<n>:MANChester:DISPlay), the :SBUS<n>:MANChester:DSIZE command specifies the number of words in the data field of your Manchester protocol definition.

AUTO is available as a selection only when the trailer field size is 0 (see :SBUS<n>:MANChester:TSIZE).

**Query Syntax**    `:SBUS<n>:MANChester:DSIZE?`

The :SBUS<n>:MANChester:DSIZE? query returns the number of data field words setting.

**Return Format**    `<#words><NL>`  
`<#words> ::= from 0-255, in NR1 format`

In AUTO mode, the query returns 0.

In BIT format the only legal value is 0 (for AUTO).

**See Also**

- "[:SBUS<n>:MANChester:DISPlay](#)" on page 1056
- "[:SBUS<n>:MANChester:HSIZE](#)" on page 1058
- "[:SBUS<n>:MANChester:SSIZE](#)" on page 1062
- "[:SBUS<n>:MANChester:TSIZE](#)" on page 1068
- "[:SBUS<n>:MANChester:WSIZE](#)" on page 1069

## :SBUS<n>:MANChester:HSIZE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:MANChester:HSIZE <#bits>`  
`<#bits> ::= from 0-32, in NR1 format`

When the display format is WORD (see :SBUS<n>:MANChester:DISPlay), the :SBUS<n>:MANChester:HSIZE command specifies the number of bits in the header field of your Manchester protocol definition.

**Query Syntax**    `:SBUS<n>:MANChester:HSIZE?`

The :SBUS<n>:MANChester:HSIZE? query returns the number of header field bits setting.

**Return Format**    `<#bits><NL>`

**See Also**

- "[:SBUS<n>:MANChester:DISPlay](#)" on page 1056
- "[:SBUS<n>:MANChester:DSIZE](#)" on page 1057
- "[:SBUS<n>:MANChester:SSIZE](#)" on page 1062
- "[:SBUS<n>:MANChester:TSIZE](#)" on page 1068
- "[:SBUS<n>:MANChester:WSIZE](#)" on page 1069

## :SBUS<n>:MANChester:IDLE:BITS

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:MANChester:IDLE:BITS <#bits>  
 <#bits> ::= minimum idle time, from 1.50 to 32.00 in 0.25 increments,  
 in NR3 format.

The :SBUS<n>:MANChester:IDLE:BITS command specifies the minimum idle time or inter-frame gap time in terms of the number of bits.

**Query Syntax** :SBUS<n>:MANChester:IDLE:BITS?

The :SBUS<n>:MANChester:IDLE:BITS? query returns the specified idle time in terms of the number of bits.

**Return Format** <#bits><NL>

**See Also**

- "[:SBUS<n>:MANChester:BASE](#)" on page 1053
- "[:SBUS<n>:MANChester:BITorder](#)" on page 1055
- "[:SBUS<n>:MANChester:LOGic](#)" on page 1060
- "[:SBUS<n>:MANChester:START](#)" on page 1063

## :SBUS<n>:MANChester:LOGic

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:MANChester:LOGic <logic>`  
`<logic> ::= {FALLing | RISing}`

The :SBUS<n>:MANChester:LOGic command specifies the polarity of the Manchester signal:

- FALLing – specifies that a falling edge is used to encode a bit value of logic 1 (and a rising edge encodes a bit value of logic 0).
- RISing – specifies that a rising edge is used to encode a bit value of logic 1.

**Query Syntax**    `:SBUS<n>:MANChester:LOGic?`

The :SBUS<n>:MANChester:LOGic? query returns the polarity setting.

**Return Format**    `<logic><NL>`  
`<logic> ::= {FALL | RIS}`

**See Also**

- "[:SBUS<n>:MANChester:BASE](#)" on page 1053
- "[:SBUS<n>:MANChester:BITorder](#)" on page 1055
- "[:SBUS<n>:MANChester:IDLE:BITS](#)" on page 1059
- "[:SBUS<n>:MANChester:START](#)" on page 1063

## :SBUS<n>:MANChester:SOURce

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:MANChester:SOURce &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;}</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	The :SBUS<n>:MANChester:SOURce command selects the oscilloscope channel connected to the Manchester signal line.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:MANChester:SOURce?</code>
	The :SBUS<n>:MANChester:SOURce? query returns the selected oscilloscope channel source.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
	<code>&lt;source&gt; ::= {CHAN&lt;n&gt;   DIG&lt;d&gt;}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">:SBUS&lt;n&gt;:MANChester:BAUDrate</a>" on page 1054</li> <li>• "<a href="#">:SBUS&lt;n&gt;:MANChester:TOLerance</a>" on page 1064</li> </ul>

## :SBUS<n>:MANChester:SSIZE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:MANChester:SSIZE <#bits>`  
`<#bits> ::= from 0-255, in NR1 format`

The :SBUS<n>:MANChester:SSIZE command specifies the number of sync bits for the Manchester signal.

**Query Syntax**    `:SBUS<n>:MANChester:SSIZE?`

The :SBUS<n>:MANChester:SSIZE? query returns the number of sync bits setting.

**Return Format**    `<#bits><NL>`

**See Also**

- "[:SBUS<n>:MANChester:DISPlay](#)" on page 1056
- "[:SBUS<n>:MANChester:DSIZE](#)" on page 1057
- "[:SBUS<n>:MANChester:HSIZE](#)" on page 1058
- "[:SBUS<n>:MANChester:TSIZE](#)" on page 1068
- "[:SBUS<n>:MANChester:WSIZE](#)" on page 1069

## :SBUS<n>:MANChester:STARt

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:MANChester:STARt <edge#>`  
`<edge#> ::= from 1-256, in NR1 format`

The :SBUS<n>:MANChester:STARt command specifies the starting edge of the Manchester signal.

**Query Syntax**    `:SBUS<n>:MANChester:STARt?`

The :SBUS<n>:MANChester:STARt? query returns the starting edge number setting.

**Return Format**    `<edge#><NL>`

**See Also**

- "[:SBUS<n>:MANChester:BASE](#)" on page 1053
- "[:SBUS<n>:MANChester:BITorder](#)" on page 1055
- "[:SBUS<n>:MANChester:IDLE:BITS](#)" on page 1059
- "[:SBUS<n>:MANChester:LOGic](#)" on page 1060

## :SBUS<n>:MANChester:TOLerance

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:MANChester:TOLerance <percent>`  
`<percent> ::= from 5-30, in NR1 format`

The :SBUS<n>:MANChester:TOLerance command specifies the tolerance for the Manchester signal in terms of the percentage of the bit period.

**Query Syntax**    `:SBUS<n>:MANChester:TOLerance?`

The :SBUS<n>:MANChester:TOLerance? query returns the tolerance setting.

**Return Format**    `<percent><NL>`  
`<percent> ::= from 5-30, in NR1 format`

**See Also**

- [":SBUS<n>:MANChester:BAUDrate" on page 1054](#)
- [":SBUS<n>:MANChester:SOURce" on page 1061](#)

## :SBUS<n>:MANChester:TRIGger

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:MANChester:TRIGger <mode>

<mode> ::= {SOF | VALue | MERRor}

The :SBUS<n>:MANChester:TRIGger command specifies the trigger mode:

- SOF (Start Of Frame) – triggers at the start of a Manchester frame, after the starting edge.
- VALue – triggers on the specified bit values.
- MERRor – triggers on a Manchester error.

**Query Syntax** :SBUS<n>:MANChester:TRIGger?

The :SBUS<n>:MANChester:TRIGger? query returns the trigger mode setting.

**Return Format** <mode><NL>

<mode> ::= {SOF | VAL | MERR}

**See Also** • "[:SBUS<n>:MANChester:TRIGger:PATTERn:VALue:DATA](#)" on page 1066  
• "[:SBUS<n>:MANChester:TRIGger:PATTERn:VALue:WIDTh](#)" on page 1067

## :SBUS<n>:MANChester:TRIGger:PATTern:VALue:DATA

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:MANChester:TRIGger:PATTern:VALue:DATA <string>`

`<string> ::= "nn...n" where n ::= {0 | 1 | x | $}`

`<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | x | $}`

When the VALue trigger mode is selected (:SBUS<n>:MANChester:TRIGger), the :SBUS<n>:MANChester:TRIGger:PATTern:VALue:DATA command specifies the value to trigger on.

Note that the trigger value bit order is always for bits as they arrive (that is, MSB first) regardless of the serial decode bit order setting (in :SBUS<n>:MANChester:BITorder).

The bit width (length) of the value is set with the :SBUS<n>:MANChester:TRIGger:PATTern:VALue:WIDTh command.

**Query Syntax**    `:SBUS<n>:MANChester:TRIGger:PATTern:VALue:DATA?`

The :SBUS<n>:MANChester:TRIGger:PATTern:VALue:DATA? query returns the specified trigger value as a string of binary digits.

**Return Format**    `<string><NL>`

`<string> ::= "nn...n" where n ::= {0 | 1 | x | $}`

**See Also**

- "[:SBUS<n>:MANChester:BITorder](#)" on page 1055
- "[:SBUS<n>:MANChester:TRIGger](#)" on page 1065
- "[:SBUS<n>:MANChester:TRIGger:PATTern:VALue:WIDTh](#)" on page 1067

## :SBUS<n>:MANChester:TRIGger:PATTERn:VALue:WIDTh

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:MANChester:TRIGger:PATTERn:VALue:WIDTh <width>

<width> ::= integer from 4 to 128 in NR1 format

When the VALue trigger mode is selected (:SBUS<n>:MANChester:TRIGger), the :SBUS<n>:MANChester:TRIGger:PATTERn:VALue:WIDTh command specifies the bit width (length) of the value to trigger on.

The actual value to trigger on is set with the :SBUS<n>:MANChester:TRIGger:PATTERn:VALue:DATA command.

**Query Syntax** :SBUS<n>:MANChester:TRIGger:PATTERn:VALue:WIDTh?

The :SBUS<n>:MANChester:TRIGger:PATTERn:VALue:WIDTh? query returns the specified trigger value bit width (length).

**Return Format** <width><NL>

**See Also**

- "[:SBUS<n>:MANChester:BITorder](#)" on page 1055
- "[:SBUS<n>:MANChester:TRIGger](#)" on page 1065
- "[:SBUS<n>:MANChester:TRIGger:PATTERn:VALue:DATA](#)" on page 1066

## :SBUS<n>:MANChester:TSIZE

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:MANChester:TSIZE &lt;#bits&gt;</code>  <code>&lt;#bits&gt; ::= from 0-32, in NR1 format</code>
	When the display format is WORD (see :SBUS<n>:MANChester:DISPlay), the :SBUS<n>:MANChester:TSIZE command specifies the number of bits in the trailer field of your Manchester protocol definition.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:MANChester:TSIZE?</code>
	The :SBUS<n>:MANChester:TSIZE? query returns the number of trailer field bits setting.
<b>Return Format</b>	<code>&lt;#bits&gt;&lt;NL&gt;</code>  <code>&lt;#bits&gt; ::= from 0-32, in NR1 format</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":SBUS&lt;n&gt;:MANChester:DISPlay" on page 1056</a></li><li><a href="#">":SBUS&lt;n&gt;:MANChester:DSIZE" on page 1057</a></li><li><a href="#">":SBUS&lt;n&gt;:MANChester:HSIZE" on page 1058</a></li><li><a href="#">":SBUS&lt;n&gt;:MANChester:SSIZE" on page 1062</a></li><li><a href="#">":SBUS&lt;n&gt;:MANChester:WSIZE" on page 1069</a></li></ul>

## :SBUS<n>:MANChester:WSIZE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:MANChester:WSIZE <#bits>`  
`<#bits> ::= from 2-32, in NR1 format`

When the display format is WORD (see :SBUS<n>:MANChester:DISPlay), the :SBUS<n>:MANChester:WSIZE command the number of bits per word in the data field of your Manchester protocol definition.

**Query Syntax**    `:SBUS<n>:MANChester:WSIZE?`

The :SBUS<n>:MANChester:WSIZE? query returns the number of bits per word setting.

**Return Format**    `<#bits><NL>`

**See Also**

- "[:SBUS<n>:MANChester:DISPlay](#)" on page 1056
- "[:SBUS<n>:MANChester:DSIZE](#)" on page 1057
- "[:SBUS<n>:MANChester:HSIZE](#)" on page 1058
- "[:SBUS<n>:MANChester:SSIZE](#)" on page 1062
- "[:SBUS<n>:MANChester:TSIZE](#)" on page 1068

## :SBUS<n>:NRZ Commands

**NOTE**

These commands are valid when the automotive NRZ serial decode and triggering option has been licensed.

**Table 132** :SBUS<n>:NRZ Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:NRZ:BASE <base> (see <a href="#">page 1072</a> )	:SBUS<n>:NRZ:BASE? (see <a href="#">page 1072</a> )	<base> ::= {HEX   DECimal   ASCii}
:SBUS<n>:NRZ:BAUDrate <baudrate> (see <a href="#">page 1073</a> )	:SBUS<n>:NRZ:BAUDrate? (see <a href="#">page 1073</a> )	<baudrate> ::= integer from 5000 to 5000000 in 100 b/s increments
:SBUS<n>:NRZ:BITorder <bitorder> (see <a href="#">page 1074</a> )	:SBUS<n>:NRZ:BITorder? (see <a href="#">page 1074</a> )	<bitorder> ::= {MSBFirst   LSBFirst}
:SBUS<n>:NRZ:DISPLAY <format> (see <a href="#">page 1075</a> )	:SBUS<n>:NRZ:DISPLAY? (see <a href="#">page 1075</a> )	<format> ::= {BIT   WORD}
:SBUS<n>:NRZ:DSIZE <#words> (see <a href="#">page 1076</a> )	:SBUS<n>:NRZ:DSIZE? (see <a href="#">page 1076</a> )	<#words> ::= from 1-255, in NR1 format
:SBUS<n>:NRZ:FSIZE <#bits> (see <a href="#">page 1077</a> )	:SBUS<n>:NRZ:FSIZE? (see <a href="#">page 1077</a> )	<#bits> ::= from 2-255, in NR1 format
:SBUS<n>:NRZ:HSIZE <#bits> (see <a href="#">page 1078</a> )	:SBUS<n>:NRZ:HSIZE? (see <a href="#">page 1078</a> )	<#bits> ::= from 0-32, in NR1 format
:SBUS<n>:NRZ:IDLE:BITS <#bits> (see <a href="#">page 1079</a> )	:SBUS<n>:NRZ:IDLE:BITS? (see <a href="#">page 1079</a> )	<#bits> ::= minimum idle time in terms of bit width, from 1.50 to 32.0, in NR3 format.
:SBUS<n>:NRZ:IDLE:STATE <state> (see <a href="#">page 1080</a> )	:SBUS<n>:NRZ:IDLE:STATE? (see <a href="#">page 1080</a> )	<state> ::= {LOW   HIGH}
:SBUS<n>:NRZ:LOGIC <logic> (see <a href="#">page 1081</a> )	:SBUS<n>:NRZ:LOGIC? (see <a href="#">page 1081</a> )	<logic> ::= {HIGH   LOW}
:SBUS<n>:NRZ:SOURCE <source> (see <a href="#">page 1082</a> )	:SBUS<n>:NRZ:SOURce? (see <a href="#">page 1082</a> )	<source> ::= {CHANnel<n>   DIGital<d>}

**Table 132** :SBUS<n>:NRZ Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:NRZ:START <#bits> (see page 1083)	:SBUS<n>:NRZ:STARt? (see page 1083)	<#bits> ::= from 0-255, in NR1 format
:SBUS<n>:NRZ:TRIGger <mode> (see page 1084)	:SBUS<n>:NRZ:TRIGger? (see page 1084)	<mode> ::= { SOF   VALue }
:SBUS<n>:NRZ:TRIGger: PATtern:VALue:DATA <string> (see page 1085)	:SBUS<n>:NRZ:TRIGger: PATtern:VALue:DATA? (see page 1085)	<string> ::= "nn...n" where n ::= { 0   1   X   \$ }  <string> ::= "0xnn...n" where n ::= { 0,...,9   A,...,F   X   \$ }
:SBUS<n>:NRZ:TRIGger: PATtern:VALue:WIDTh <width> (see page 1086)	:SBUS<n>:NRZ:TRIGger: PATtern:VALue:WIDTh? (see page 1086)	<width> ::= integer from 4 to 128 in NR1 format
:SBUS<n>:NRZ:TSIZE <#bits> (see page 1087)	:SBUS<n>:NRZ:TSIZe? (see page 1087)	<#bits> ::= from 0-32, in NR1 format
:SBUS<n>:NRZ:WSIZE <#bits> (see page 1088)	:SBUS<n>:NRZ:WSIZe? (see page 1088)	<#bits> ::= from 2-32, in NR1 format

## :SBUS<n>:NRZ:BASE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:NRZ:BASE <base>`

`<base> ::= {HEX | DECimal | ASCii | BINary}`

When the display format is WORD (see :SBUS<n>:NRZ:DISPlay), the :SBUS<n>:NRZ:BASE command specifies the base for the NRZ bus decode and Lister display.

- HEX – hexadecimal
- DECimal – unsigned decimal
- ASCii

When the display format is BIT, the only legal decode base value is BINary.

**Query Syntax**    `:SBUS<n>:NRZ:BASE?`

The :SBUS<n>:NRZ:BASE? query returns the decode number base setting.

**Return Format**    `<base><NL>`

`<base> ::= {HEX | DEC | ASC | BIN}`

**See Also**

- "[:SBUS<n>:NRZ:BITorder](#)" on page 1074
- "[:SBUS<n>:NRZ:IDLE:BITS](#)" on page 1079
- "[:SBUS<n>:NRZ:IDLE:STATe](#)" on page 1080
- "[:SBUS<n>:NRZ:LOGic](#)" on page 1081

## :SBUS<n>:NRZ:BAUDrate

**N** (see [page 1666](#))

**Command Syntax**    :SBUS<n>:NRZ:BAUDrate <baudrate>  
                          <baudrate> ::= integer from 5000 to 5000000 in 100 b/s increments

The :SBUS<n>:NRZ:BAUDrate command specifies the baud rate of the NRZ signal.

**Query Syntax**    :SBUS<n>:NRZ:BAUDrate?

The :SBUS<n>:NRZ:BAUDrate? query returns the specified baud rate.

**Return Format**    <baudrate><NL>

**See Also**    • [":SBUS<n>:NRZ:SOURce"](#) on page 1082

## :SBUS<n>:NRZ:BITorder

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:NRZ:BITorder <bitorder>`

`<bitorder> ::= {MSBFirst | LSBFirst}`

When the display format is WORD (see :SBUS<n>:NRZ:DISPlay), the :SBUS<n>:NRZ:BITorder command specifies the order of transmission on the NRZ bus:

- MSBFirst – specifies the most significant bit is transmitted first.
- LSBFirst – specifies the least significant bit is transmitted first.

**Query Syntax**    `:SBUS<n>:NRZ:BITorder?`

The :SBUS<n>:NRZ:BITorder? query returns the bit order setting.

**Return Format**    `<bitorder><NL>`

`<bitorder> ::= {MSBF | LSBF}`

**See Also**

- "[:SBUS<n>:NRZ:BASE](#)" on page 1072
- "[:SBUS<n>:NRZ:IDLE:BITS](#)" on page 1079
- "[:SBUS<n>:NRZ:IDLE:STATE](#)" on page 1080
- "[:SBUS<n>:NRZ:LOGic](#)" on page 1081

## :SBUS<n>:NRZ:DISPlay

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:NRZ:DISPlay <format>`  
                  `<format> ::= {BIT | WORD}`

The :SBUS<n>:NRZ:DISPlay command specifies the format of the NRZ bus display.

**Query Syntax**    `:SBUS<n>:NRZ:DISPlay?`

The :SBUS<n>:NRZ:DISPlay? query returns the bus display format setting.

**Return Format**    `<format><NL>`  
                  `<format> ::= {BIT | WORD}`

**See Also**

- "[:SBUS<n>:NRZ:DSIZE](#)" on page 1076
- "[:SBUS<n>:NRZ:FSIZE](#)" on page 1077
- "[:SBUS<n>:NRZ:HSIZE](#)" on page 1078
- "[:SBUS<n>:NRZ:START](#)" on page 1083
- "[:SBUS<n>:NRZ:TSIZE](#)" on page 1087
- "[:SBUS<n>:NRZ:WSIZE](#)" on page 1088

## :SBUS<n>:NRZ:DSIZE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:NRZ:DSIZE <#words>`  
`<#words> ::= from 1-255, in NR1 format`

The :SBUS<n>:NRZ:DSIZE command ...

When the display format is WORD (see :SBUS<n>:NRZ:DISPLAY), the :SBUS<n>:NRZ:DSIZE command specifies the number of words in the data field of your NRZ protocol definition.

AUTO is available as a selection only when the trailer field size is 0 (see :SBUS<n>:NRZ:TSIZE).

**Query Syntax**    `:SBUS<n>:NRZ:DSIZE?`

The :SBUS<n>:NRZ:DSIZE? query returns the number of data field words setting.

**Return Format**    `<#words><NL>`  
`<#words> ::= from 1-255, in NR1 format`

In AUTO mode, the query returns 0.

In BIT format the only legal value is 0 (for AUTO).

**See Also**

- "[:SBUS<n>:NRZ:DISPLAY](#)" on page 1075
- "[:SBUS<n>:NRZ:FSIZE](#)" on page 1077
- "[:SBUS<n>:NRZ:HSIZE](#)" on page 1078
- "[:SBUS<n>:NRZ:START](#)" on page 1083
- "[:SBUS<n>:NRZ:TSIZE](#)" on page 1087
- "[:SBUS<n>:NRZ:WSIZE](#)" on page 1088

## :SBUS<n>:NRZ:FSIZE

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:NRZ:FSIZE <#bits>

<#bits> ::= from 2-255, in NR1 format

When the NRZ bus display format (:SBUS<n>:NRZ:DISPlay) is BIT, the :SBUS<n>:NRZ:FSIZE command lets you specify the total frame size of the NRZ signal from 2 to 255 bits. This would be equivalent to the sum of the number of bits in the header, data, and trailer fields in WORD format.

**Query Syntax** :SBUS<n>:NRZ:FSIZE?

The :SBUS<n>:NRZ:FSIZE? query returns the specified total frame size.

**Return Format** <#bits><NL>

- See Also**
- "[:SBUS<n>:NRZ:DISPlay](#)" on page 1075
  - "[:SBUS<n>:NRZ:DSIZE](#)" on page 1076
  - "[:SBUS<n>:NRZ:HSize](#)" on page 1078
  - "[:SBUS<n>:NRZ:START](#)" on page 1083
  - "[:SBUS<n>:NRZ:TSIZE](#)" on page 1087
  - "[:SBUS<n>:NRZ:WSIZE](#)" on page 1088

## :SBUS<n>:NRZ:HSIZE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:NRZ:HSIZE <#bits>`

`<#bits> ::= from 0-32, in NR1 format`

When the display format is WORD (see [:SBUS<n>:NRZ:DISPLAY](#)), the `:SBUS<n>:NRZ:HSIZE` command specifies the number of bits in the header field of your NRZ protocol definition.

**Query Syntax**    `:SBUS<n>:NRZ:HSIZE?`

The `:SBUS<n>:NRZ:HSIZE?` query returns the number of header field bits setting.

**Return Format**    `<#bits><NL>`

**See Also**

- "[:SBUS<n>:NRZ:DISPLAY](#)" on page 1075
- "[:SBUS<n>:NRZ:DSIZE](#)" on page 1076
- "[:SBUS<n>:NRZ:FSIZE](#)" on page 1077
- "[:SBUS<n>:NRZ:START](#)" on page 1083
- "[:SBUS<n>:NRZ:TSIZE](#)" on page 1087
- "[:SBUS<n>:NRZ:WSIZE](#)" on page 1088

## :SBUS<n>:NRZ:IDLE:BITS

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:NRZ:IDLE:BITS <#bits>  
<#bits> ::= minimum idle time, from 1.50 to 32.00 in 0.25 increments,  
in NR3 format.

The :SBUS<n>:NRZ:IDLE:BITS command specifies the minimum idle time or  
inter-frame gap time in terms of the number of bits.

**Query Syntax** :SBUS<n>:NRZ:IDLE:BITS?

The :SBUS<n>:NRZ:IDLE:BITS? query returns the specified idle time in terms of the  
number of bits.

**Return Format** <#bits><NL>

**See Also**

- "[:SBUS<n>:NRZ:BASE](#)" on page 1072
- "[:SBUS<n>:NRZ:BITorder](#)" on page 1074
- "[:SBUS<n>:NRZ:IDLE:STATE](#)" on page 1080
- "[:SBUS<n>:NRZ:LOGic](#)" on page 1081

**:SBUS<n>:NRZ:IDLE:STATe****N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:NRZ:IDLE:STATe <state>`  
                  `<state> ::= {LOW | HIGH}`

The :SBUS<n>:NRZ:IDLE:STATe command specifies the idle state of the NRZ signal.

**Query Syntax**    `:SBUS<n>:NRZ:IDLE:STATe?`

The :SBUS<n>:NRZ:IDLE:STATe? query returns the idle state setting.

**Return Format**    `<state><NL>`  
                  `<state> ::= {LOW | HIGH}`

**See Also**

- "[:SBUS<n>:NRZ:BASE](#)" on page 1072
- "[:SBUS<n>:NRZ:BITorder](#)" on page 1074
- "[:SBUS<n>:NRZ:IDLE:BITS](#)" on page 1079
- "[:SBUS<n>:NRZ:LOGic](#)" on page 1081

## :SBUS<n>:NRZ:LOGic

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:NRZ:LOGic <logic>`

`<logic> ::= {HIGH | LOW}`

The :SBUS<n>:NRZ:LOGic command specifies the polarity of the NRZ signal:

- HIGH – specifies that a positive voltage is used to encode a bit value of logic 1 (and a negative voltage encodes a bit value of logic 0).
- LOW – specifies that a negative voltage is used to encode a bit value of logic 1.

**Query Syntax**    `:SBUS<n>:NRZ:LOGic?`

The :SBUS<n>:NRZ:LOGic? query returns the polarity setting.

**Return Format**    `<logic><NL>`

`<logic> ::= {HIGH | LOW}`

**See Also**    [":SBUS<n>:NRZ:BASE" on page 1072](#)

[":SBUS<n>:NRZ:BITorder" on page 1074](#)

[":SBUS<n>:NRZ:IDLE:BITS" on page 1079](#)

[":SBUS<n>:NRZ:IDLE:STATE" on page 1080](#)

## :SBUS<n>:NRZ:SOURce

**N** (see [page 1666](#))

- Command Syntax**    `:SBUS<n>:NRZ:SOURce <source>`
- ```
<source> ::= {CHANnel<n> | DIGital<d>}
```
- ```
<n> ::= 1 to (# analog channels) in NR1 format
```
- ```
<d> ::= 0 to (# digital channels - 1) in NR1 format
```
- The :SBUS<n>:NRZ:SOURce command selects the oscilloscope channel connected to the NRZ signal
- Query Syntax**    `:SBUS<n>:NRZ:SOURce?`
- The :SBUS<n>:NRZ:SOURce? query returns the selected oscilloscope channel source.
- Return Format**    `<source><NL>`
- ```
<source> ::= {CHAN<n> | DIG<d>}
```
- See Also**
  - [":SBUS<n>:NRZ:BAUDrate"](#) on page 1073

## :SBUS<n>:NRZ:STARt

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:NRZ:STARt <#bits>

<#bits> ::= from 0-255, in NR1 format

The :SBUS<n>:NRZ:STARt command specifies the number of start bits for the NRZ signal.

**Query Syntax** :SBUS<n>:NRZ:STARt?

The :SBUS<n>:NRZ:STARt? query returns the number of start bits setting.

**Return Format** <#bits><NL>

**See Also**

- "[:SBUS<n>:NRZ:DISPlay](#)" on page 1075
- "[:SBUS<n>:NRZ:DSIZE](#)" on page 1076
- "[:SBUS<n>:NRZ:FSIZE](#)" on page 1077
- "[:SBUS<n>:NRZ:HSIZE](#)" on page 1078
- "[:SBUS<n>:NRZ:TSIZE](#)" on page 1087
- "[:SBUS<n>:NRZ:WSIZE](#)" on page 1088

## :SBUS<n>:NRZ:TRIGger

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:NRZ:TRIGger <mode>`  
`<mode> ::= {SOF | VALue}`

The :SBUS<n>:NRZ:TRIGger command specifies the trigger mode:

- SOF (Start Of Frame) – triggers at the start of a NRZ frame, before the header field.
- VALue – triggers on the specified bit values (see :SBUS<n>:NRZ:TRIGger:PATTERn:VALue:WIDTh and :SBUS<n>:NRZ:TRIGger:PATTERn:VALue:DATA), up to 128 bits, after the specified number of starting bits.

Note that the trigger value is always for bits as they arrive (that is, MSB first).

When the decode bit order (see :SBUS<n>:NRZ:BITorder) is MSBFirst, the decoded value bit order matches the trigger value bit order.

When the serial decode bit order is LSBFirst, the decoded value bit order is opposite of the trigger value bit order.

**Query Syntax**    `:SBUS<n>:NRZ:TRIGger?`

The :SBUS<n>:NRZ:TRIGger? query returns the trigger mode setting.

**Return Format**    `<mode><NL>`

`<mode> ::= {SOF | VAL}`

**See Also**

- "[:SBUS<n>:NRZ:TRIGger:PATTERn:VALue:DATA](#)" on page 1085
- "[:SBUS<n>:NRZ:TRIGger:PATTERn:VALue:WIDTh](#)" on page 1086

## :SBUS<n>:NRZ:TRIGger:PATTern:VALue:DATA

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:NRZ:TRIGger:PATTern:VALue:DATA &lt;string&gt;</code>
	<code>&lt;string&gt; ::= "nn...n" where n ::= {0   1   X   \$}</code>
	<code>&lt;string&gt; ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$}</code>

When the VALue trigger mode is selected (:SBUS<n>:NRZ:TRIGger), the :SBUS<n>:NRZ:TRIGger:PATTern:VALue:DATA command specifies the value to trigger on.

Note that the trigger value bit order is always for bits as they arrive (that is, MSB first) regardless of the serial decode bit order setting (in :SBUS<n>:NRZ:BITorder).

The bit width (length) of the value is set with the :SBUS<n>:NRZ:TRIGger:PATTern:VALue:WIDTh command.

<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:NRZ:TRIGger:PATTern:VALue:DATA?</code>
---------------------	-------------------------------------------------------------

The :SBUS<n>:NRZ:TRIGger:PATTern:VALue:DATA? query returns the specified trigger value as a string of binary digits.

<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code>
	<code>&lt;string&gt; ::= "nn...n" where n ::= {0   1   X   \$}</code>

<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":SBUS&lt;n&gt;:NRZ:BITorder" on page 1074</a></li> <li>· <a href="#">":SBUS&lt;n&gt;:NRZ:TRIGger" on page 1084</a></li> <li>· <a href="#">":SBUS&lt;n&gt;:NRZ:TRIGger:PATTern:VALue:WIDTh" on page 1086</a></li> </ul>
-----------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

## :SBUS<n>:NRZ:TRIGger:PATTern:VALue:WIDTh

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:NRZ:TRIGger:PATTern:VALue:WIDTh &lt;width&gt;</code> <code>&lt;width&gt; ::= integer from 4 to 128 in NR1 format</code>
	When the VALue trigger mode is selected (:SBUS<n>:NRZ:TRIGger), the :SBUS<n>:NRZ:TRIGger:PATTern:VALue:WIDTh command specifies the bit width (length) of the value to trigger on.
	The actual value to trigger on is set with the :SBUS<n>:NRZ:TRIGger:PATTern:VALue:DATA command.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:NRZ:TRIGger:PATTern:VALue:WIDTh?</code>
	The :SBUS<n>:NRZ:TRIGger:PATTern:VALue:WIDTh? query returns the specified trigger value bit width (length).
<b>Return Format</b>	<code>&lt;width&gt;&lt;NL&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":SBUS&lt;n&gt;:NRZ:BITOrder"</a> on page 1074</li><li><a href="#">":SBUS&lt;n&gt;:NRZ:TRIGger"</a> on page 1084</li><li><a href="#">":SBUS&lt;n&gt;:NRZ:TRIGger:PATTern:VALue:DATA"</a> on page 1085</li></ul>

## :SBUS<n>:NRZ:TSIZE

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:NRZ:TSIZE <#bits>

<#bits> ::= from 0-32, in NR1 format

When the display format is WORD (see :SBUS<n>:NRZ:DISPLAY), the :SBUS<n>:NRZ:TSIZE command specifies the number of bits in the trailer field of your NRZ protocol definition.

**Query Syntax** :SBUS<n>:NRZ:TSIZE?

The :SBUS<n>:NRZ:TSIZE? query returns the number of trailer field bits setting.

**Return Format** <opt><NL>

<#bits> ::= from 0-32, in NR1 format

**See Also** [":SBUS<n>:NRZ:DISPLAY" on page 1075](#)

[":SBUS<n>:NRZ:DSIZE" on page 1076](#)

[":SBUS<n>:NRZ:FSIZE" on page 1077](#)

[":SBUS<n>:NRZ:HSIZE" on page 1078](#)

[":SBUS<n>:NRZ:START" on page 1083](#)

[":SBUS<n>:NRZ:WSIZE" on page 1088](#)

## :SBUS<n>:NRZ:WSIZE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:NRZ:WSIZE <#bits>`

`<#bits> ::= from 2-32, in NR1 format`

When the display format is WORD (see `:SBUS<n>:NRZ:DISPLAY`), the `:SBUS<n>:NRZ:WSIZE` command specifies the number of bits per word in the data field of your NRZ protocol definition.

**Query Syntax**    `:SBUS<n>:NRZ:WSIZE?`

The `:SBUS<n>:NRZ:WSIZE?` query returns the number of bits per word setting.

**Return Format**    `<#bits><NL>`

**See Also**

- "[:SBUS<n>:NRZ:DISPLAY](#)" on page 1075
- "[:SBUS<n>:NRZ:DSIZE](#)" on page 1076
- "[:SBUS<n>:NRZ:FSIZE](#)" on page 1077
- "[:SBUS<n>:NRZ:HSIZE](#)" on page 1078
- "[:SBUS<n>:NRZ:START](#)" on page 1083
- "[:SBUS<n>:NRZ:TSIZE](#)" on page 1087

## :SBUS<n>:SENT Commands

**NOTE**

These commands are valid when the automotive SENT serial decode and triggering option has been licensed.

**Table 133** :SBUS<n>:SENT Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:SENT:CLOCK <period> (see page 1092)	:SBUS<n>:SENT:CLOCK? (see <a href="#">page 1092</a> )	<period> ::= the nominal clock period (tick), from 500 ns to 300 us, in NR3 format.
:SBUS<n>:SENT:CRC <format> (see page 1093)	:SBUS<n>:SENT:CRC? (see <a href="#">page 1093</a> )	<format> ::= {LEGacy   RECommended}
:SBUS<n>:SENT:DISPlay <base> (see <a href="#">page 1094</a> )	:SBUS<n>:SENT:DISPlay? (see <a href="#">page 1094</a> )	<base> ::= {HEX   DECimal   SYMBolic}
:SBUS<n>:SENT:FORMAT <decode> (see page 1096)	:SBUS<n>:SENT:FORMAT? (see <a href="#">page 1096</a> )	<decode> ::= {NIBBles   FSIGnal   FSSerial   FESerial   SSERial   ESERial}
:SBUS<n>:SENT:IDLE <state> (see page 1098)	:SBUS<n>:SENT:IDLE? (see <a href="#">page 1098</a> )	<state> ::= {LOW   HIGH}
:SBUS<n>:SENT:LENGTH <#_nibbles> (see page 1099)	:SBUS<n>:SENT:LENGTH? (see <a href="#">page 1099</a> )	<#_nibbles> ::= from 1-6, in NR1 format.
:SBUS<n>:SENT:PPULse { {0   OFF}   {1   ON}   SPC } (see <a href="#">page 1100</a> )	:SBUS<n>:SENT:PPULse? (see <a href="#">page 1100</a> )	{0   1   SPC}
:SBUS<n>:SENT:SIGNAl<s>:DISPlay { {0   OFF}   {1   ON} } (see <a href="#">page 1102</a> )	:SBUS<n>:SENT:SIGNAl<s>:DISPlay? (see <a href="#">page 1102</a> )	<s> ::= 1-6, in NR1 format. {0   1}
:SBUS<n>:SENT:SIGNAl<s>:LENGTH <length> (see <a href="#">page 1103</a> )	:SBUS<n>:SENT:SIGNAl<s>:LENGTH? (see <a href="#">page 1103</a> )	<s> ::= 1-6, in NR1 format. <length> ::= from 1-24, in NR1 format.
:SBUS<n>:SENT:SIGNAl<s>:MULTiplier <multiplier> (see <a href="#">page 1105</a> )	:SBUS<n>:SENT:SIGNAl<s>:MULTiplier? (see <a href="#">page 1105</a> )	<s> ::= 1-6, in NR1 format. <multiplier> ::= from 1-24, in NR3 format.

**Table 133** :SBUS<n>:SENT Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:SENT:SIGNAl<s>:OFFSet <offset> (see page 1107)	:SBUS<n>:SENT:SIGNAl<s>:OFFSet? (see page 1107)	<s> ::= 1-6, in NR1 format. <offset> ::= from 1-24, in NR3 format.
:SBUS<n>:SENT:SIGNAl<s>:ORDer <order> (see page 1109)	:SBUS<n>:SENT:SIGNAl<s>:ORDer? (see page 1109)	<s> ::= 1-6, in NR1 format. <order> ::= {MSNFirst   LSNFirst}
:SBUS<n>:SENT:SIGNAl<s>:STARt <position> (see page 1111)	:SBUS<n>:SENT:SIGNAl<s>:STARt? (see page 1111)	<s> ::= 1-6, in NR1 format. <position> ::= from 0-23, in NR1 format.
:SBUS<n>:SENT:SOURce <source> (see page 1113)	:SBUS<n>:SENT:SOURce? (see page 1113)	<source> ::= {CHANnel<n>   DIGItal<d>} <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:SENT:TOLeran ce <percent> (see page 1115)	:SBUS<n>:SENT:TOLeran ce? (see page 1115)	<percent> ::= from 3-30, in NR1 format.
:SBUS<n>:SENT:TRIGger <mode> (see page 1116)	:SBUS<n>:SENT:TRIGger? (see page 1116)	<mode> ::= {SFMessage   SSCMessage   FCData   SCMid   SCData   FCCerror   SCCerror   CRCerror   TOLerror   PPERror   SSPerror}
:SBUS<n>:SENT:TRIGger :FAST:DATA <string> (see page 1118)	:SBUS<n>:SENT:TRIGger :FAST:DATA? (see page 1118)	<string> ::= "nnnn..." where n ::= {0   1   X} <string> ::= "0xn..." where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:SENT:TRIGger :SLOW:DATA <data> (see page 1119)	:SBUS<n>:SENT:TRIGger :SLOW:DATA? (see page 1119)	<data> ::= when ILength = SHORT, from -1 (don't care) to 65535, in NR1 format.  <data> ::= when ILength = LONG, from -1 (don't care) to 4095, in NR1 format.
:SBUS<n>:SENT:TRIGger :SLOW:ID <id> (see page 1121)	:SBUS<n>:SENT:TRIGger :SLOW:ID? (see page 1121)	<id> ::= when ILength = SHORT, from -1 (don't care) to 15, in NR1 format.  <id> ::= when ILength = LONG, from -1 (don't care) to 255, in NR1 format.

**Table 133** :SBUS<n>:SENT Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:SENT:TRIGger :SLOW:ILENgh <length> (see <a href="#">page 1123</a> )	:SBUS<n>:SENT:TRIGger :SLOW:ILENgh? (see <a href="#">page 1123</a> )	<length> ::= {SHORt   LONG}
:SBUS<n>:SENT:TRIGger :TOLerance <percent> (see <a href="#">page 1124</a> )	:SBUS<n>:SENT:TRIGger :TOLerance? (see <a href="#">page 1124</a> )	<percent> ::= from 1-18, in NR1 format.

## :SBUS<n>:SENT:CLOCK

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:SENT:CLOCK &lt;period&gt;</code> <code>&lt;period&gt; ::= the nominal clock period (tick), from 500 ns to 300 us,  in NR3 format.</code>
	The :SBUS<n>:SENT:CLOCK command specifies the nominal clock period (tick), from 500 ns to 300 μs.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:SENT:CLOCK?</code>
	The :SBUS<n>:SENT:CLOCK? query returns the clock period setting.
<b>Return Format</b>	<code>&lt;period&gt;&lt;NL&gt;</code> <code>&lt;period&gt; ::= the nominal clock period (tick), from 500 ns to 300 us,  in NR3 format.</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:CRC"</a> on page 1093</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:DISPlay"</a> on page 1094</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:FORMAT"</a> on page 1096</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:IDLE"</a> on page 1098</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:LENGTH"</a> on page 1099</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:PPULse"</a> on page 1100</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:DISPlay"</a> on page 1102</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:LENGTH"</a> on page 1103</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:MULTiplier"</a> on page 1105</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:OFFSet"</a> on page 1107</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:ORDer"</a> on page 1109</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:START"</a> on page 1111</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SOURce"</a> on page 1113</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TOLerance"</a> on page 1115</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger"</a> on page 1116</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger:FAST:DATA"</a> on page 1118</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger:SLOW:DATA"</a> on page 1119</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger:SLOW:ID"</a> on page 1121</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger:SLOW:ILENghth"</a> on page 1123</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger:TOLerance"</a> on page 1124</li> </ul>

## :SBUS<n>:SENT:CRC

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SENT:CRC <format>`  
`<format> ::= {LEGacy | RECommended}`

The :SBUS<n>:SENT:CRC command specifies the format of the CRC. Either Legacy (2008) or Recommended (2010).

Enhanced Serial Message CRCs are always calculated using the 2010 format, but for the Fast Channel Messages, and for Short Serial Message CRCs, this setting is used.

**Query Syntax**    `:SBUS<n>:SENT:CRC?`  
The :SBUS<n>:SENT:CRC? query returns the CRC format setting.

**Return Format**    `<format><NL>`  
`<format> ::= {LEG | REC}`

**See Also**

- "[:SBUS<n>:SENT:CLOCK](#)" on page 1092
- "[:SBUS<n>:SENT:DISPlay](#)" on page 1094
- "[:SBUS<n>:SENT:FORMat](#)" on page 1096
- "[:SBUS<n>:SENT:IDLE](#)" on page 1098
- "[:SBUS<n>:SENT:LENGth](#)" on page 1099
- "[:SBUS<n>:SENT:PPULse](#)" on page 1100
- "[:SBUS<n>:SENT:SIGNAl<s>:DISPlay](#)" on page 1102
- "[:SBUS<n>:SENT:SIGNAl<s>:LENGth](#)" on page 1103
- "[:SBUS<n>:SENT:SIGNAl<s>:MULTiplier](#)" on page 1105
- "[:SBUS<n>:SENT:SIGNAl<s>:OFFSet](#)" on page 1107
- "[:SBUS<n>:SENT:SIGNAl<s>:ORDer](#)" on page 1109
- "[:SBUS<n>:SENT:SIGNAl<s>:STARt](#)" on page 1111
- "[:SBUS<n>:SENT:SOURce](#)" on page 1113
- "[:SBUS<n>:SENT:TOLerance](#)" on page 1115
- "[:SBUS<n>:SENT:TRIGger](#)" on page 1116
- "[:SBUS<n>:SENT:TRIGger:FAST:DATA](#)" on page 1118
- "[:SBUS<n>:SENT:TRIGger:SLOW:DATA](#)" on page 1119
- "[:SBUS<n>:SENT:TRIGger:SLOW:ID](#)" on page 1121
- "[:SBUS<n>:SENT:TRIGger:SLOW:IENGth](#)" on page 1123
- "[:SBUS<n>:SENT:TRIGger:TOLerance](#)" on page 1124

## :SBUS<n>:SENT:DISPlay

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SENT:DISPlay <base>`  
`<base> ::= {HEX | DECimal | SYMBolic}`

The :SBUS<n>:SENT:DISPlay command specifies the number base used by the decoder. The chosen base is used for the data nibbles in Raw decode format, the defined Signals in the other formats, and for the data field of the Serial Messages.

This selection is used for both the Lister and the decode line displays.

When SYMBolic is selected, Fast Channel Signals display a calculated physical value based on the specified multiplier and offset:

- $\text{PhysicalValue} = (\text{Multiplier} * \text{SignalValueAsUnsignedInteger}) + \text{Offset}$

When SYMBolic is selected, the CRC and Slow Channel information is displayed in hex.

**Query Syntax**    `:SBUS<n>:SENT:DISPLAY?`

The :SBUS<n>:SENT:DISPLAY? query returns the SENT decode number base setting.

**Return Format**    `<base><NL>`  
`<base> ::= {HEX | DEC | SYMB}`

- See Also**
- "[:SBUS<n>:SENT:CLOCK](#)" on page 1092
  - "[:SBUS<n>:SENT:CRC](#)" on page 1093
  - "[:SBUS<n>:SENT:FORMAT](#)" on page 1096
  - "[:SBUS<n>:SENT:IDLE](#)" on page 1098
  - "[:SBUS<n>:SENT:LENGTH](#)" on page 1099
  - "[:SBUS<n>:SENT:PPULSE](#)" on page 1100
  - "[:SBUS<n>:SENT:SIGNAl<s>:DISPLAY](#)" on page 1102
  - "[:SBUS<n>:SENT:SIGNAl<s>:LENGTH](#)" on page 1103
  - "[:SBUS<n>:SENT:SIGNAl<s>:MULTiplier](#)" on page 1105
  - "[:SBUS<n>:SENT:SIGNAl<s>:OFFSet](#)" on page 1107
  - "[:SBUS<n>:SENT:SIGNAl<s>:ORDer](#)" on page 1109
  - "[:SBUS<n>:SENT:SIGNAl<s>:START](#)" on page 1111
  - "[:SBUS<n>:SENT:SOURce](#)" on page 1113
  - "[:SBUS<n>:SENT:TOLERance](#)" on page 1115
  - "[:SBUS<n>:SENT:TRIGger](#)" on page 1116
  - "[:SBUS<n>:SENT:TRIGger:FAST:DATA](#)" on page 1118

- "[:SBUS<n>:SENT:TRIGger:SLOW:DATA](#)" on page 1119
- "[:SBUS<n>:SENT:TRIGger:SLOW:ID](#)" on page 1121
- "[:SBUS<n>:SENT:TRIGger:SLOW:ILENgth](#)" on page 1123
- "[:SBUS<n>:SENT:TRIGger:TOLerance](#)" on page 1124

## :SBUS<n>:SENT:FORMAT

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:SENT:FORMAT &lt;decode&gt;</code>
	<code>&lt;decode&gt; ::= {NIBBles   FSIGnal   FSSerial   FESerial   SSERial   ESERial}</code>

The :SBUS<n>:SENT:FORMAT command specifies the message decode/triggering format:

- NIBBles – displays the raw transmitted nibble values.
- FSIGnal – displays Fast Channel Message Signals.
- FSSerial – displays both Fast and Slow Messages (Short format) simultaneously.
- FESerial – displays both Fast and Slow Messages (Enhanced format) simultaneously.
- SSERial – displays Slow Channel Messages in Short format.
- ESERial – displays Slow Channel Messages in Enhanced format.

This selection affects both decoding and triggering. The decode is affected both in how the system interprets the data, and what will be displayed. The trigger is affected in that the trigger hardware needs to be configured to trigger on serial messages correctly.

You can specify the nibble display order for Fast Channel Message Signals (see :SBUS<n>:SENT:SIGNAl<s>:ORDer). Raw transmitted nibble values are displayed in the order received.

Note that for the Slow Channel, the proper format, Short or Enhanced, must be chosen for proper decoding and triggering to occur.

Slow Channel Serial Messages are always displayed as defined by the SENT specification.

<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:SENT:FORMAT?</code>
---------------------	------------------------------------------

The :SBUS<n>:SENT:FORMAT? query returns the message decode/triggering format setting.

<b>Return Format</b>	<code>&lt;decode&gt;&lt;NL&gt;</code>
	<code>&lt;decode&gt; ::= {NIBB   FSIG   FSS   FES   SSER   ESER}</code>

<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:CLOCK</a>" on page 1092</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:CRC</a>" on page 1093</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:DISPLAY</a>" on page 1094</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:IDLE</a>" on page 1098</li> </ul>
-----------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

- "[:SBUS<n>:SENT:LENGTH](#)" on page 1099
- "[:SBUS<n>:SENT:PPULse](#)" on page 1100
- "[:SBUS<n>:SENT:SIGNAl<s>:DISPLAY](#)" on page 1102
- "[:SBUS<n>:SENT:SIGNAl<s>:LENGTH](#)" on page 1103
- "[:SBUS<n>:SENT:SIGNAl<s>:MULTIplier](#)" on page 1105
- "[:SBUS<n>:SENT:SIGNAl<s>:OFFSet](#)" on page 1107
- "[:SBUS<n>:SENT:SIGNAl<s>:ORDer](#)" on page 1109
- "[:SBUS<n>:SENT:SIGNAl<s>:START](#)" on page 1111
- "[:SBUS<n>:SENT:SOURce](#)" on page 1113
- "[:SBUS<n>:SENT:TOLerance](#)" on page 1115
- "[:SBUS<n>:SENT:TRIGger](#)" on page 1116
- "[:SBUS<n>:SENT:TRIGger:FAST:DATA](#)" on page 1118
- "[:SBUS<n>:SENT:TRIGger:SLOW:DATA](#)" on page 1119
- "[:SBUS<n>:SENT:TRIGger:SLOW:ID](#)" on page 1121
- "[:SBUS<n>:SENT:TRIGger:SLOW:ILENgth](#)" on page 1123
- "[:SBUS<n>:SENT:TRIGger:TOLerance](#)" on page 1124

## :SBUS<n>:SENT:IDLE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SENT:IDLE <state>`  
`<state> ::= {LOW | HIGH}`

The :SBUS<n>:SENT:IDLE command specifies the idle state of the SENT bus.

**Query Syntax**    `:SBUS<n>:SENT:IDLE?`

The :SBUS<n>:SENT:IDLE? query returns the idle state setting.

**Return Format**    `<state><NL>`  
`<state> ::= {LOW | HIGH}`

- See Also**
- "[:SBUS<n>:SENT:CLOCK](#)" on page 1092
  - "[:SBUS<n>:SENT:CRC](#)" on page 1093
  - "[:SBUS<n>:SENT:DISPlay](#)" on page 1094
  - "[:SBUS<n>:SENT:FORMAT](#)" on page 1096
  - "[:SBUS<n>:SENT:LENGTH](#)" on page 1099
  - "[:SBUS<n>:SENT:PPULse](#)" on page 1100
  - "[:SBUS<n>:SENT:SIGNAl<s>:DISPLAY](#)" on page 1102
  - "[:SBUS<n>:SENT:SIGNAl<s>:LENGTH](#)" on page 1103
  - "[:SBUS<n>:SENT:SIGNAl<s>:MULTiplier](#)" on page 1105
  - "[:SBUS<n>:SENT:SIGNAl<s>:OFFSet](#)" on page 1107
  - "[:SBUS<n>:SENT:SIGNAl<s>:ORDer](#)" on page 1109
  - "[:SBUS<n>:SENT:SIGNAl<s>:START](#)" on page 1111
  - "[:SBUS<n>:SENT:SOURce](#)" on page 1113
  - "[:SBUS<n>:SENT:TOLerance](#)" on page 1115
  - "[:SBUS<n>:SENT:TRIGger](#)" on page 1116
  - "[:SBUS<n>:SENT:TRIGger:FAST:DATA](#)" on page 1118
  - "[:SBUS<n>:SENT:TRIGger:SLOW:DATA](#)" on page 1119
  - "[:SBUS<n>:SENT:TRIGger:SLOW:ID](#)" on page 1121
  - "[:SBUS<n>:SENT:TRIGger:SLOW:ILENghth](#)" on page 1123
  - "[:SBUS<n>:SENT:TRIGger:TOLerance](#)" on page 1124

## :SBUS<n>:SENT:LENGTH

**N** (see [page 1666](#))

Command Syntax	<code>:SBUS&lt;n&gt;:SENT:LENGTH &lt;#_nibbles&gt;</code> <code>&lt;#_nibbles&gt; ::= from 1-6, in NR1 format.</code>
	The :SBUS<n>:SENT:LENGTH command specifies the number of nibbles in a SENT message, from 1 to 6.
Query Syntax	<code>:SBUS&lt;n&gt;:SENT:LENGTH?</code>
	The :SBUS<n>:SENT:LENGTH? query returns the number of nibbles setting.
Return Format	<code>&lt;#_nibbles&gt;&lt;NL&gt;</code> <code>&lt;#_nibbles&gt; ::= from 1-6, in NR1 format.</code>
See Also	<ul style="list-style-type: none"> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:CLOCK</a>" on page 1092</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:CRC</a>" on page 1093</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:DISPLAY</a>" on page 1094</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:FORMAT</a>" on page 1096</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:IDLE</a>" on page 1098</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:PPULSE</a>" on page 1100</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:DISPLAY</a>" on page 1102</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:LENGTH</a>" on page 1103</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:MULTiplier</a>" on page 1105</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:OFFSet</a>" on page 1107</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:ORDer</a>" on page 1109</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:START</a>" on page 1111</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:SOURce</a>" on page 1113</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:TOLERance</a>" on page 1115</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGGER</a>" on page 1116</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:FAST:DATA</a>" on page 1118</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:SLOW:DATA</a>" on page 1119</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:SLOW:ID</a>" on page 1121</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:SLOW:IENGth</a>" on page 1123</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:TOLERance</a>" on page 1124</li> </ul>

## :SBUS<n>:SENT:PPULse

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:SENT:PPULse {{0 | OFF} | {1 | ON} | SPC}

The :SBUS<n>:SENT:PPULse command specifies whether there is a pause pulse between Fast Channel Messages:

- OFF – There is no pause pulse between Fast Channel Messages.  
Note that a SENT serial bus with no pause pulse is never idle. This means, during normal operation, the fast channel decode line will show a continuous stream of packets, with a new packet opening as soon as the previous one has closed.
- ON – Pause pulses are added between Fast Channel Messages so that frames come at a regular interval.

If there is a pause pulse (and **Pause Pulse** is on), idle time is shown between messages.

- SPC (Short PWM Code) – In SENT SPC, there are no pause pulses. Instead, the message event is triggered by the master when it wants to receive data. SENT SPC ends the transmission after the CRC so it almost appears as if there is a pause pulse from the end until the next master trigger.

**Query Syntax** :SBUS<n>:SENT:PPULse?

The :SBUS<n>:SENT:PPULse? query returns the pause mode setting.

**Return Format** <setting><NL>

<setting> ::= {0 | 1 | SPC}

**See Also** [":SBUS<n>:SENT:CLOCK"](#) on page 1092

- [":SBUS<n>:SENT:CRC"](#) on page 1093
- [":SBUS<n>:SENT:DISPlay"](#) on page 1094
- [":SBUS<n>:SENT:FORMAT"](#) on page 1096
- [":SBUS<n>:SENT:IDLE"](#) on page 1098
- [":SBUS<n>:SENT:LENGTH"](#) on page 1099
- [":SBUS<n>:SENT:SIGNAl<s>:DISPlay"](#) on page 1102
- [":SBUS<n>:SENT:SIGNAl<s>:LENGTH"](#) on page 1103
- [":SBUS<n>:SENT:SIGNAl<s>:MULTiplier"](#) on page 1105
- [":SBUS<n>:SENT:SIGNAl<s>:OFFSet"](#) on page 1107
- [":SBUS<n>:SENT:SIGNAl<s>:ORDer"](#) on page 1109
- [":SBUS<n>:SENT:SIGNAl<s>:START"](#) on page 1111
- [":SBUS<n>:SENT:SOURce"](#) on page 1113

- "[:SBUS<n>:SENT:TOLerance](#)" on page 1115
- "[:SBUS<n>:SENT:TRIGger](#)" on page 1116
- "[:SBUS<n>:SENT:TRIGger:FAST:DATA](#)" on page 1118
- "[:SBUS<n>:SENT:TRIGger:SLOW:DATA](#)" on page 1119
- "[:SBUS<n>:SENT:TRIGger:SLOW:ID](#)" on page 1121
- "[:SBUS<n>:SENT:TRIGger:SLOW:ILENGTH](#)" on page 1123
- "[:SBUS<n>:SENT:TRIGger:TOLerance](#)" on page 1124

## :SBUS<n>:SENT:SIGNAl<s>:DISPlay

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SENT:SIGNAl<s>:DISPlay {{0 | OFF} | {1 | ON}}`  
`<s> ::= 1-6, in NR1 format.`

The :SBUS<n>:SENT:SIGNAl<s>:DISPlay command specifies whether the given signal is on or off.

**Query Syntax**    `:SBUS<n>:SENT:SIGNAl<s>:DISPlay?`

The :SBUS<n>:SENT:SIGNAl<s>:DISPlay? query returns the signal on/off setting.

**Return Format**    `<setting><NL>`  
`<setting> ::= {0 | 1}`

- See Also**
- "[:SBUS<n>:SENT:CLOCK](#)" on page 1092
  - "[:SBUS<n>:SENT:CRC](#)" on page 1093
  - "[:SBUS<n>:SENT:DISPlay](#)" on page 1094
  - "[:SBUS<n>:SENT:FORMAT](#)" on page 1096
  - "[:SBUS<n>:SENT:IDLE](#)" on page 1098
  - "[:SBUS<n>:SENT:LENGTH](#)" on page 1099
  - "[:SBUS<n>:SENT:PPULse](#)" on page 1100
  - "[:SBUS<n>:SENT:SIGNAl<s>:LENGTH](#)" on page 1103
  - "[:SBUS<n>:SENT:SIGNAl<s>:MULTiplier](#)" on page 1105
  - "[:SBUS<n>:SENT:SIGNAl<s>:OFFSet](#)" on page 1107
  - "[:SBUS<n>:SENT:SIGNAl<s>:ORDer](#)" on page 1109
  - "[:SBUS<n>:SENT:SIGNAl<s>:START](#)" on page 1111
  - "[:SBUS<n>:SENT:SOURce](#)" on page 1113
  - "[:SBUS<n>:SENT:TOLERance](#)" on page 1115
  - "[:SBUS<n>:SENT:TRIGger](#)" on page 1116
  - "[:SBUS<n>:SENT:TRIGger:FAST:DATA](#)" on page 1118
  - "[:SBUS<n>:SENT:TRIGger:SLOW:DATA](#)" on page 1119
  - "[:SBUS<n>:SENT:TRIGger:SLOW:ID](#)" on page 1121
  - "[:SBUS<n>:SENT:TRIGger:SLOW:IENGth](#)" on page 1123
  - "[:SBUS<n>:SENT:TRIGger:TOLerance](#)" on page 1124

## :SBUS<n>:SENT:SIGNAl<s>:LENGTH

**N** (see [page 1666](#))

**Command Syntax**    :SBUS<n>:SENT:SIGNAl<s>:LENGTH <length>  
                           <s> ::= 1-6, in NR1 format.  
                           <length> ::= from 1-24, in NR1 format.


The :SBUS<n>:SENT:SIGNAl<s>:LENGTH command specifies the bit length of the signal being defined.

Fast Signal definition examples:

**Example 1: Start Bit # = 13, # of bits = 8, Nibble Order = LSN First**



**Example 2: Start Bit # = 10, # of bits = 5, Nibble Order = MSN First**



**Query Syntax**    :SBUS<n>:SENT:SIGNAl<s>:LENGTH?

The :SBUS<n>:SENT:SIGNAl<s>:LENGTH? query returns the signal bit length setting.

**Return Format**    <length><NL>  
                           <length> ::= from 1-24, in NR1 format.

**See Also**    [":SBUS<n>:SENT:CLOCK" on page 1092](#)  
                   [":SBUS<n>:SENT:CRC" on page 1093](#)  
                   [":SBUS<n>:SENT:DISPLAY" on page 1094](#)  
                   [":SBUS<n>:SENT:FORMAT" on page 1096](#)  
                   [":SBUS<n>:SENT:IDLE" on page 1098](#)  
                   [":SBUS<n>:SENT:LENGTH" on page 1099](#)  
                   [":SBUS<n>:SENT:PPULSE" on page 1100](#)  
                   [":SBUS<n>:SENT:SIGNAl<s>:DISPLAY" on page 1102](#)  
                   [":SBUS<n>:SENT:SIGNAl<s>:MULTIPLIER" on page 1105](#)  
                   [":SBUS<n>:SENT:SIGNAl<s>:OFFSET" on page 1107](#)

- "[:SBUS<n>:SENT:SIGNAl<s>:ORDer](#)" on page 1109
- "[:SBUS<n>:SENT:SIGNAl<s>:START](#)" on page 1111
- "[:SBUS<n>:SENT:SOURce](#)" on page 1113
- "[:SBUS<n>:SENT:TOLerance](#)" on page 1115
- "[:SBUS<n>:SENT:TRIGger](#)" on page 1116
- "[:SBUS<n>:SENT:TRIGger:FAST:DATA](#)" on page 1118
- "[:SBUS<n>:SENT:TRIGger:SLOW:DATA](#)" on page 1119
- "[:SBUS<n>:SENT:TRIGger:SLOW:ID](#)" on page 1121
- "[:SBUS<n>:SENT:TRIGger:SLOW:IENGth](#)" on page 1123
- "[:SBUS<n>:SENT:TRIGger:TOLerance](#)" on page 1124

## :SBUS<n>:SENT:SIGNAl<s>:MULTiplier

**N** (see [page 1666](#))

**Command Syntax**

```
:SBUS<n>:SENT:SIGNAl<s>:MULTiplier <multiplier>
<s> ::= 1-6, in NR1 format.
<multiplier> ::= from 1-24, in NR3 format.
```

When the display mode setting is SYMBolic (see :SBUS<n>:SENT:DISPLAY), the :SBUS<n>:SENT:SIGNAl<s>:MULTiplier command specifies the multiplier to be used in calculating a physical value displayed for a Fast Channel Signal.

- PhysicalValue = (Multiplier \* SignalValueAsUnsignedInteger) + Offset

**Query Syntax**

```
:SBUS<n>:SENT:SIGNAl<s>:MULTiplier?
```

The :SBUS<n>:SENT:SIGNAl<s>:MULTiplier? query returns the multiplier value for the Fast Channel Signal.

**Return Format**

```
<multiplier><NL>
<multiplier> ::= from 1-24, in NR3 format.
```

**See Also**

- [":SBUS<n>:SENT:CLOCK"](#) on page 1092
- [":SBUS<n>:SENT:CRC"](#) on page 1093
- [":SBUS<n>:SENT:DISPLAY"](#) on page 1094
- [":SBUS<n>:SENT:FORMAT"](#) on page 1096
- [":SBUS<n>:SENT:IDLE"](#) on page 1098
- [":SBUS<n>:SENT:LENGTH"](#) on page 1099
- [":SBUS<n>:SENT:PPULse"](#) on page 1100
- [":SBUS<n>:SENT:SIGNAl<s>:DISPLAY"](#) on page 1102
- [":SBUS<n>:SENT:SIGNAl<s>:LENGTH"](#) on page 1103
- [":SBUS<n>:SENT:SIGNAl<s>:OFFSet"](#) on page 1107
- [":SBUS<n>:SENT:SIGNAl<s>:ORDer"](#) on page 1109
- [":SBUS<n>:SENT:SIGNAl<s>:START"](#) on page 1111
- [":SBUS<n>:SENT:SOURce"](#) on page 1113
- [":SBUS<n>:SENT:TOLERance"](#) on page 1115
- [":SBUS<n>:SENT:TRIGger"](#) on page 1116
- [":SBUS<n>:SENT:TRIGger:FAST:DATA"](#) on page 1118
- [":SBUS<n>:SENT:TRIGger:SLOW:DATA"](#) on page 1119
- [":SBUS<n>:SENT:TRIGger:SLOW:ID"](#) on page 1121
- [":SBUS<n>:SENT:TRIGger:SLOW:ILENghth"](#) on page 1123

### 33 :SBUS<n> Commands

- [":SBUS<n>:SENT:TRIGger:TOLerance" on page 1124](#)

## :SBUS<n>:SENT:SIGNAl<s>:OFFSet

**N** (see [page 1666](#))

**Command Syntax**

```
:SBUS<n>:SENT:SIGNAl<s>:OFFSet <offset>
<s> ::= 1-6, in NR1 format.
<offset> ::= from 1-24, in NR3 format.
```

When the display mode setting is SYMBolic (see :SBUS<n>:SENT:DISPlay), the :SBUS<n>:SENT:SIGNAl<s>:OFFSet command is used in calculating a physical value displayed for the Fast Channel Signal:

- PhysicalValue = (Multiplier \* SignalValueAsUnsignedInteger) + Offset

**Query Syntax**

```
:SBUS<n>:SENT:SIGNAl<s>:OFFSet?
```

The :SBUS<n>:SENT:SIGNAl<s>:OFFSet? query returns the offset value for the Fast Channel Signal.

**Return Format**

```
<offset><NL>
<offset> ::= from 1-24, in NR3 format.
```

**See Also**

- [":SBUS<n>:SENT:CLOCK"](#) on page 1092
- [":SBUS<n>:SENT:CRC"](#) on page 1093
- [":SBUS<n>:SENT:DISPlay"](#) on page 1094
- [":SBUS<n>:SENT:FORMAT"](#) on page 1096
- [":SBUS<n>:SENT:IDLE"](#) on page 1098
- [":SBUS<n>:SENT:LENGTH"](#) on page 1099
- [":SBUS<n>:SENT:PPULse"](#) on page 1100
- [":SBUS<n>:SENT:SIGNAl<s>:DISPLAY"](#) on page 1102
- [":SBUS<n>:SENT:SIGNAl<s>:LENGTH"](#) on page 1103
- [":SBUS<n>:SENT:SIGNAl<s>:MULTiplier"](#) on page 1105
- [":SBUS<n>:SENT:SIGNAl<s>:ORDer"](#) on page 1109
- [":SBUS<n>:SENT:SIGNAl<s>:START"](#) on page 1111
- [":SBUS<n>:SENT:SOURce"](#) on page 1113
- [":SBUS<n>:SENT:TOLERance"](#) on page 1115
- [":SBUS<n>:SENT:TRIGger"](#) on page 1116
- [":SBUS<n>:SENT:TRIGger:FAST:DATA"](#) on page 1118
- [":SBUS<n>:SENT:TRIGger:SLOW:DATA"](#) on page 1119
- [":SBUS<n>:SENT:TRIGger:SLOW:ID"](#) on page 1121
- [":SBUS<n>:SENT:TRIGger:SLOW:ILENghth"](#) on page 1123

### 33 :SBUS<n> Commands

- [":SBUS<n>:SENT:TRIGger:TOlerance" on page 1124](#)

:SBUS<n>:SENT:SIGNAl<s>:ORDer

**N** (see page 1666)


The :SBUS<n>:SENT:SIGNAl<s>:ORDer command specifies the nibble order of the signal being defined, either Most Significant Nibble first, or Least Significant Nibble first.

## Fast Signal definition examples:

Example 1: Start Bit # = 13, # of bits = 8, Nibble Order = LSN First



Example 2: Start Bit # = 10, # of bits = 5, Nibble Order = MSN First



Query Syntax :SBUS<n>:SENT:SIGNAl<s>:ORDer?

The :SBUS<n>:SENT:SIGNAl<s>:ORDer? query returns the nibble order setting.

## Return Format <order><NL>

`<order>` ::= { MSNF | LSNF }

See Also

- "[":SBUS<n>:SENT:CLOCK](#)" on page 1092
- "[":SBUS<n>:SENT:CRC](#)" on page 1093
- "[":SBUS<n>:SENT:DISPlay](#)" on page 1094
- "[":SBUS<n>:SENT:FORMat](#)" on page 1096
- "[":SBUS<n>:SENT:IDLE](#)" on page 1098
- "[":SBUS<n>:SENT:LENGTH](#)" on page 1099
- "[":SBUS<n>:SENT:PPULse](#)" on page 1100
- "[":SBUS<n>:SENT:SIGNAl<s>:DISPlay](#)" on page 1102
- "[":SBUS<n>:SENT:SIGNAl<s>:LENGTH](#)" on page 1103
- "[":SBUS<n>:SENT:SIGNAl<s>:MULTiplier](#)" on page 1105

- "[:SBUS<n>:SENT:SIGNAl<s>:OFFSet](#)" on page 1107
- "[:SBUS<n>:SENT:SIGNAl<s>:START](#)" on page 1111
- "[:SBUS<n>:SENT:SOURce](#)" on page 1113
- "[:SBUS<n>:SENT:TOLerance](#)" on page 1115
- "[:SBUS<n>:SENT:TRIGger](#)" on page 1116
- "[:SBUS<n>:SENT:TRIGger:FAST:DATA](#)" on page 1118
- "[:SBUS<n>:SENT:TRIGger:SLOW:DATA](#)" on page 1119
- "[:SBUS<n>:SENT:TRIGger:SLOW:ID](#)" on page 1121
- "[:SBUS<n>:SENT:TRIGger:SLOW:ILENGTH](#)" on page 1123
- "[:SBUS<n>:SENT:TRIGger:TOLerance](#)" on page 1124

## :SBUS<n>:SENT:SIGNAl<s>:STARt

**N** (see [page 1666](#))

**Command Syntax**

```
:SBUS<n>:SENT:SIGNAl<s>:STARt <position>
<s> ::= 1-6, in NR1 format.
<position> ::= from 0-23, in NR1 format.
```


The :SBUS<n>:SENT:SIGNAl<s>:STARt command specifies the starting bit of the Fast Signal being defined.

Fast Signal definition examples:

**Example 1: Start Bit # = 13, # of bits = 8, Nibble Order = LSN First**



**Example 2: Start Bit # = 10, # of bits = 5, Nibble Order = MSN First**



**Query Syntax**

The :SBUS<n>:SENT:SIGNAl<s>:STARt? query returns the Fast Signal starting bit setting.

**Return Format**

```
<position><NL>
<position> ::= from 0-23, in NR1 format.
```

**See Also**

- "[:SBUS<n>:SENT:CLOCK](#)" on page 1092
- "[:SBUS<n>:SENT:CRC](#)" on page 1093
- "[:SBUS<n>:SENT:DISPlay](#)" on page 1094
- "[:SBUS<n>:SENT:FORMAT](#)" on page 1096
- "[:SBUS<n>:SENT:IDLE](#)" on page 1098
- "[:SBUS<n>:SENT:LENGTH](#)" on page 1099
- "[:SBUS<n>:SENT:PPULse](#)" on page 1100
- "[:SBUS<n>:SENT:SIGNAl<s>:DISPLAY](#)" on page 1102
- "[:SBUS<n>:SENT:SIGNAl<s>:LENGTH](#)" on page 1103
- "[:SBUS<n>:SENT:SIGNAl<s>:MULTiplier](#)" on page 1105

- "[:SBUS<n>:SENT:SIGNAl<s>:OFFSet](#)" on page 1107
- "[:SBUS<n>:SENT:SIGNAl<s>:ORDer](#)" on page 1109
- "[:SBUS<n>:SENT:SOURce](#)" on page 1113
- "[:SBUS<n>:SENT:TOLerance](#)" on page 1115
- "[:SBUS<n>:SENT:TRIGger](#)" on page 1116
- "[:SBUS<n>:SENT:TRIGger:FAST:DATA](#)" on page 1118
- "[:SBUS<n>:SENT:TRIGger:SLOW:DATA](#)" on page 1119
- "[:SBUS<n>:SENT:TRIGger:SLOW:ID](#)" on page 1121
- "[:SBUS<n>:SENT:TRIGger:SLOW:ILENGTH](#)" on page 1123
- "[:SBUS<n>:SENT:TRIGger:TOLerance](#)" on page 1124

## :SBUS<n>:SENT:SOURce

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:SENT:SOURce &lt;source&gt;</code>
	<pre>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;}</pre>
	<pre>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</pre>
	<pre>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</pre>
	The :SBUS<n>:SENT:SOURce command specifies the input channel for SENT decode and triggering.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:SENT:SOURce?</code>
	The :SBUS<n>:SENT:SOURce? query returns the specified SENT input source.
<b>Return Format</b>	<pre>&lt;source&gt;&lt;NL&gt;</pre>
	<pre>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;}</pre>
	<pre>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</pre>
	<pre>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</pre>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:CLOCK"</a> on page 1092</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:CRC"</a> on page 1093</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:DISPlay"</a> on page 1094</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:FORMAT"</a> on page 1096</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:IDLE"</a> on page 1098</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:LENGTH"</a> on page 1099</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:PPULse"</a> on page 1100</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:DISPlay"</a> on page 1102</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:LENGTH"</a> on page 1103</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:MULTiplier"</a> on page 1105</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:OFFSet"</a> on page 1107</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:ORDer"</a> on page 1109</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:START"</a> on page 1111</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TOLerance"</a> on page 1115</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger"</a> on page 1116</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger:FAST:DATA"</a> on page 1118</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger:SLOW:DATA"</a> on page 1119</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger:SLOW:ID"</a> on page 1121</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger:SLOW:ILENghth"</a> on page 1123</li> </ul>

- [":SBUS<n>:SENT:TRIGger:TOlerance" on page 1124](#)

## :SBUS<n>:SENT:TOLerance

**N** (see [page 1666](#))

Command Syntax	<code>:SBUS&lt;n&gt;:SENT:TOLerance &lt;percent&gt;</code> <code>&lt;percent&gt; ::= from 3-30, in NR1 format.</code>
	The :SBUS<n>:SENT:TOLerance command specifies the tolerance for determining whether the sync pulse is valid. Valid values range from 3% to 30%.
Query Syntax	<code>:SBUS&lt;n&gt;:SENT:TOLerance?</code>
	The :SBUS<n>:SENT:TOLerance? query returns the tolerance setting.
Return Format	<code>&lt;percent&gt;&lt;NL&gt;</code> <code>&lt;percent&gt; ::= from 3-30, in NR1 format.</code>
See Also	<ul style="list-style-type: none"> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:CLOCK</a>" on page 1092</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:CRC</a>" on page 1093</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:DISPlay</a>" on page 1094</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:FORMAT</a>" on page 1096</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:IDLE</a>" on page 1098</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:LENGTH</a>" on page 1099</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:PPULse</a>" on page 1100</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:DISPlay</a>" on page 1102</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:LENGTH</a>" on page 1103</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:MULTiplier</a>" on page 1105</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:OFFSet</a>" on page 1107</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:ORDer</a>" on page 1109</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:START</a>" on page 1111</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:SOURce</a>" on page 1113</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger</a>" on page 1116</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:FAST:DATA</a>" on page 1118</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:SLOW:DATA</a>" on page 1119</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:SLOW:ID</a>" on page 1121</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:SLOW:IENGth</a>" on page 1123</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:TOLerance</a>" on page 1124</li> </ul>

## :SBUS<n>:SENT:TRIGger

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SENT:TRIGger <mode>`

```
<mode> ::= {SFCMessage | SSCMessage | FCData | SCMid | SCData
             | TOLerror | FCCerror | SCCerror | CRCerror | PPERror | SSPerror}
```

The :SBUS<n>:SENT:TRIGger command specifies the SENT trigger mode:

- SFCMessage – triggers on the start of any Fast Channel Message (after 56 Synchronization/Calibration ticks).
- SSCMessage – trigger on the start of any Slow Channel Message.
- FCData – triggers on a Fast Channel Message when the Status & Communication nibble and the data nibbles match the values entered using additional softkeys.
- SCMid – triggers when a Slow Channel Message ID matches the value entered using additional softkeys.
- SCData – triggers when a Slow Channel Message ID and Data field both match the values entered using additional softkeys.
- TOLerror – triggers when the sync pulse width varies from the nominal value by greater than the entered percentage.
- FCCerror – triggers on any Fast Channel Message CRC error.
- SCCerror – triggers on any Slow Channel Message CRC error.
- CRCerror – triggers on any CRC error, Fast or Slow.
- PPERror – triggers if a nibble is either too wide or too narrow (for example, data nibble < 12 (11.5) or > 27 (27.5) ticks wide). Sync, S&C, data, or checksum pulse periods are checked.
- SSPerror – triggers on a sync pulse whose width varies from the previous sync pulse's width by greater than 1/64 (1.5625%, as defined in the SENT specification).

**Query Syntax**    `:SBUS<n>:SENT:TRIGger?`

The :SBUS<n>:SENT:TRIGger? query returns the trigger mode setting.

**Return Format**    `<mode><NL>`

```
<mode> ::= {SFCM | SSCM | FCD | SCM | SCD | TOL | FCC | SCC | CRC
             | PPER | SSP}
```

**See Also**

- "[:SBUS<n>:SENT:CLOCK](#)" on page 1092
- "[:SBUS<n>:SENT:CRC](#)" on page 1093
- "[:SBUS<n>:SENT:DISPLAY](#)" on page 1094
- "[:SBUS<n>:SENT:FORMAT](#)" on page 1096

- "[:SBUS<n>:SENT:IDLE](#)" on page 1098
- "[:SBUS<n>:SENT:LENGTH](#)" on page 1099
- "[:SBUS<n>:SENT:PPULse](#)" on page 1100
- "[:SBUS<n>:SENT:SIGNAl<s>:DISPLAY](#)" on page 1102
- "[:SBUS<n>:SENT:SIGNAl<s>:LENGTH](#)" on page 1103
- "[:SBUS<n>:SENT:SIGNAl<s>:MULTiplier](#)" on page 1105
- "[:SBUS<n>:SENT:SIGNAl<s>:OFFSet](#)" on page 1107
- "[:SBUS<n>:SENT:SIGNAl<s>:ORDer](#)" on page 1109
- "[:SBUS<n>:SENT:SIGNAl<s>:START](#)" on page 1111
- "[:SBUS<n>:SENT:SOURce](#)" on page 1113
- "[:SBUS<n>:SENT:TOLerance](#)" on page 1115
- "[:SBUS<n>:SENT:TRIGger:FAST:DATA](#)" on page 1118
- "[:SBUS<n>:SENT:TRIGger:SLOW:DATA](#)" on page 1119
- "[:SBUS<n>:SENT:TRIGger:SLOW:ID](#)" on page 1121
- "[:SBUS<n>:SENT:TRIGger:SLOW:ILENgth](#)" on page 1123
- "[:SBUS<n>:SENT:TRIGger:TOLerance](#)" on page 1124

## :SBUS<n>:SENT:TRIGger:FAST:DATA

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:SENT:TRIGger:FAST:DATA &lt;string&gt;</code> <code>&lt;string&gt; ::= "nnnn..." where n ::= {0   1   X}</code> <code>&lt;string&gt; ::= "0xn..." where n ::= {0,...,9   A,...,F   X   \$}</code>
	The :SBUS<n>:SENT:TRIGger:FAST:DATA command specifies the status and data nibbles that will be triggered on when the FCData trigger mode is chosen.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:SENT:TRIGger:FAST:DATA?</code>
	The :SBUS<n>:SENT:TRIGger:FAST:DATA? query returns the fast channel data trigger setting.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code> <code>&lt;string&gt; ::= "nnnn..." where n ::= {0   1   X}</code> <code>&lt;string&gt; ::= "0xn..." where n ::= {0,...,9   A,...,F   X   \$}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:CLOCK"</a> on page 1092</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:CRC"</a> on page 1093</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:DISPlay"</a> on page 1094</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:FORMAT"</a> on page 1096</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:IDLE"</a> on page 1098</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:LENGTH"</a> on page 1099</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:PPULse"</a> on page 1100</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNaL&lt;s&gt;:DISPlay"</a> on page 1102</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNaL&lt;s&gt;:LENGTH"</a> on page 1103</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNaL&lt;s&gt;:MULTiplier"</a> on page 1105</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNaL&lt;s&gt;:OFFSet"</a> on page 1107</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNaL&lt;s&gt;:ORDer"</a> on page 1109</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SIGNaL&lt;s&gt;:START"</a> on page 1111</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:SOURce"</a> on page 1113</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TOLerance"</a> on page 1115</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger"</a> on page 1116</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger:SLoW:DATA"</a> on page 1119</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger:SLoW:ID"</a> on page 1121</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger:SLoW:ILENghT"</a> on page 1123</li> <li>· <a href="#">":SBUS&lt;n&gt;:SENT:TRIGger:TOLerance"</a> on page 1124</li> </ul>

## :SBUS<n>:SENT:TRIGger:SLOW:DATA

**N** (see [page 1666](#))

Command Syntax	<pre>:SBUS&lt;n&gt;:SENT:TRIGger:SLOW:DATA &lt;data&gt;</pre> <p>&lt;data&gt; ::= when ILENgth = SHORt, from -1 (don't care) to 65535, in NR1 f ormat.</p> <p>&lt;data&gt; ::= when ILENgth = LONG, from -1 (don't care) to 4095, in NR1 for mat.</p>
	The :SBUS<n>:SENT:TRIGger:SLOW:DATA command specifies the data to trigger on for the Slow Channel Message ID and Data trigger mode.
Query Syntax	<pre>:SBUS&lt;n&gt;:SENT:TRIGger:SLOW:DATA?</pre>
	The :SBUS<n>:SENT:TRIGger:SLOW:DATA? query returns the data value setting for the slow channel ID and data trigger.
Return Format	<pre>&lt;data&gt;&lt;NL&gt;</pre> <p>&lt;data&gt; ::= when ILENgth = SHORt, from -1 (don't care) to 65535, in NR1 f ormat.</p> <p>&lt;data&gt; ::= when ILENgth = LONG, from -1 (don't care) to 4095, in NR1 for mat.</p>
See Also	<ul style="list-style-type: none"> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:CLOCK</a>" on page 1092</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:CRC</a>" on page 1093</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:DISPlay</a>" on page 1094</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:FORMAT</a>" on page 1096</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:IDLE</a>" on page 1098</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:LENGTH</a>" on page 1099</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:PPULse</a>" on page 1100</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:DISPLAY</a>" on page 1102</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:LENGTH</a>" on page 1103</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:MULTiplier</a>" on page 1105</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:OFFSet</a>" on page 1107</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:ORDer</a>" on page 1109</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:START</a>" on page 1111</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:SOURce</a>" on page 1113</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:TOLerance</a>" on page 1115</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger</a>" on page 1116</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:FAST:DATA</a>" on page 1118</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:SLOW:ID</a>" on page 1121</li> </ul>

- [":SBUS<n>:SENT:TRIGger:SLOW:ILENgth"](#) on page 1123
- [":SBUS<n>:SENT:TRIGger:TOLerance"](#) on page 1124

## :SBUS<n>:SENT:TRIGger:SLOW:ID

**N** (see [page 1666](#))

**Command Syntax**

```
:SBUS<n>:SENT:TRIGger:SLOW:ID <id>
<id> ::= when ILENgth = SHOrt, from -1 (don't care) to 15, in NR1 format
.
<id> ::= when ILENgth = LONG, from -1 (don't care) to 255, in NR1 format
.
```

The :SBUS<n>:SENT:TRIGger:SLOW:ID command specifies the ID to trigger on for the "Slow Channel Message ID" and "Slow Channel Message ID & Data" trigger modes. The ID can be from -1 (don't care) to 255 (depending on the message length).

**Query Syntax**

```
:SBUS<n>:SENT:TRIGger:SLOW:ID?
```

The :SBUS<n>:SENT:TRIGger:SLOW:ID? query returns the slow channel ID setting.

**Return Format**

```
<id><NL>
<id> ::= when ILENgth = SHOrt, from -1 (don't care) to 15, in NR1 format
.
<id> ::= when ILENgth = LONG, from -1 (don't care) to 255, in NR1 format
.
```

**See Also**

- "[:SBUS<n>:SENT:CLOCK](#)" on page 1092
- "[:SBUS<n>:SENT:CRC](#)" on page 1093
- "[:SBUS<n>:SENT:DISPlay](#)" on page 1094
- "[:SBUS<n>:SENT:FORMAT](#)" on page 1096
- "[:SBUS<n>:SENT:IDLE](#)" on page 1098
- "[:SBUS<n>:SENT:LENGTH](#)" on page 1099
- "[:SBUS<n>:SENT:PPULse](#)" on page 1100
- "[:SBUS<n>:SENT:SIGNAl<s>:DISPLAY](#)" on page 1102
- "[:SBUS<n>:SENT:SIGNAl<s>:LENGTH](#)" on page 1103
- "[:SBUS<n>:SENT:SIGNAl<s>:MULTiplier](#)" on page 1105
- "[:SBUS<n>:SENT:SIGNAl<s>:OFFSet](#)" on page 1107
- "[:SBUS<n>:SENT:SIGNAl<s>:ORDer](#)" on page 1109
- "[:SBUS<n>:SENT:SIGNAl<s>:START](#)" on page 1111
- "[:SBUS<n>:SENT:SOURce](#)" on page 1113
- "[:SBUS<n>:SENT:TOLERance](#)" on page 1115
- "[:SBUS<n>:SENT:TRIGger](#)" on page 1116
- "[:SBUS<n>:SENT:TRIGger:FAST:DATA](#)" on page 1118

- "[:SBUS<n>:SENT:TRIGger:SLOW:DATA](#)" on page 1119
- "[:SBUS<n>:SENT:TRIGger:SLOW:ILENGTH](#)" on page 1123
- "[:SBUS<n>:SENT:TRIGger:TOlerance](#)" on page 1124

## :SBUS<n>:SENT:TRIGger:SLOW:ILENGTH

**N** (see [page 1666](#))

**Command Syntax**

```
:SBUS<n>:SENT:TRIGger:SLOW:ILENGTH <length>
<length> ::= {SHORT | LONG}
```

The :SBUS<n>:SENT:TRIGger:SLOW:ILENGTH command specifies the ID and data lengths for the Slow Message Enhanced messages. Either "SHORt" for the 4-bit ID, 16-bit data format, or "LONG" for the 8-bit ID, 12-bit data format.

**Query Syntax**

```
:SBUS<n>:SENT:TRIGger:SLOW:ILENGTH?
```

The :SBUS<n>:SENT:TRIGger:SLOW:ILENGTH? query returns the ID and data length setting.

**Return Format**

```
<length><NL>
<length> ::= {SHOR | LONG}
```

**See Also**

- "[:SBUS<n>:SENT:CLOCK](#)" on page 1092
- "[:SBUS<n>:SENT:CRC](#)" on page 1093
- "[:SBUS<n>:SENT:DISPlay](#)" on page 1094
- "[:SBUS<n>:SENT:FORMAT](#)" on page 1096
- "[:SBUS<n>:SENT:IDLE](#)" on page 1098
- "[:SBUS<n>:SENT:LENGTH](#)" on page 1099
- "[:SBUS<n>:SENT:PPULse](#)" on page 1100
- "[:SBUS<n>:SENT:SIGNAl<s>:DISPLAY](#)" on page 1102
- "[:SBUS<n>:SENT:SIGNAl<s>:LENGTH](#)" on page 1103
- "[:SBUS<n>:SENT:SIGNAl<s>:MULTiplier](#)" on page 1105
- "[:SBUS<n>:SENT:SIGNAl<s>:OFFSet](#)" on page 1107
- "[:SBUS<n>:SENT:SIGNAl<s>:ORDer](#)" on page 1109
- "[:SBUS<n>:SENT:SIGNAl<s>:START](#)" on page 1111
- "[:SBUS<n>:SENT:SOURce](#)" on page 1113
- "[:SBUS<n>:SENT:TOLerance](#)" on page 1115
- "[:SBUS<n>:SENT:TRIGger](#)" on page 1116
- "[:SBUS<n>:SENT:TRIGger:FAST:DATA](#)" on page 1118
- "[:SBUS<n>:SENT:TRIGger:SLOW:DATA](#)" on page 1119
- "[:SBUS<n>:SENT:TRIGger:SLOW:ID](#)" on page 1121
- "[:SBUS<n>:SENT:TRIGger:TOLerance](#)" on page 1124

## :SBUS<n>:SENT:TRIGger:TOLerance

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:SENT:TRIGger:TOLerance &lt;percent&gt;</code> <code>&lt;percent&gt; ::= from 1-28, in NR1 format.</code>
	The :SBUS<n>:SENT:TRIGger:TOLerance command specifies the tolerance variation that is considered a violation.
	The trigger tolerance can be up to the :SBUS<n>:SENT:TOLerance setting minus two percent. For example, after sending ":SBUS1:SENT:TOLerance 20", the :SBUS1:SENT:TRIGger:TOLerance setting can be from 1 to 18.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:SENT:TRIGger:TOLerance?</code>
	The :SBUS<n>:SENT:TRIGger:TOLerance? query returns tolerance variation percent setting.
<b>Return Format</b>	<code>&lt;percent&gt;&lt;NL&gt;</code> <code>&lt;percent&gt; ::= from 1-28, in NR1 format.</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:CLOCK</a>" on page 1092</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:CRC</a>" on page 1093</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:DISPlay</a>" on page 1094</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:FORMAT</a>" on page 1096</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:IDLE</a>" on page 1098</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:LENGTH</a>" on page 1099</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:PPULse</a>" on page 1100</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:DISPLAY</a>" on page 1102</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:LENGTH</a>" on page 1103</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:MULTiplier</a>" on page 1105</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:OFFSet</a>" on page 1107</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:ORDer</a>" on page 1109</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:SIGNAl&lt;s&gt;:START</a>" on page 1111</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:SOURce</a>" on page 1113</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:TOLerance</a>" on page 1115</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger</a>" on page 1116</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:FAST:DATA</a>" on page 1118</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:SLOW:DATA</a>" on page 1119</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:SLOW:ID</a>" on page 1121</li> <li>· "<a href="#">:SBUS&lt;n&gt;:SENT:TRIGger:SLOW:ILENghth</a>" on page 1123</li> </ul>

## :SBUS<n>:SPI Commands

**NOTE**

These commands are only valid when the low-speed IIC and SPI serial decode option has been licensed.

**Table 134** :SBUS<n>:SPI Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:SPI:BITorder <order> (see page 1127)	:SBUS<n>:SPI:BITorder? (see <a href="#">page 1127</a> )	<order> ::= {LSBFFirst   MSBFFirst}
:SBUS<n>:SPI:CLOCK:SLOPe <slope> (see page 1128)	:SBUS<n>:SPI:CLOCK:SLOPe? (see <a href="#">page 1128</a> )	<slope> ::= {NEGative   POSitive}
:SBUS<n>:SPI:CLOCK:TI Meout <time_value> (see page 1129)	:SBUS<n>:SPI:CLOCK:TI Meout? (see <a href="#">page 1129</a> )	<time_value> ::= time in seconds in NR3 format
:SBUS<n>:SPI:DELay <value> (see page 1130)	:SBUS<n>:SPI:DELay? (see <a href="#">page 1130</a> )	<value> ::= {OFF   2-63}
:SBUS<n>:SPI:FRAMing <value> (see page 1131)	:SBUS<n>:SPI:FRAMing? (see <a href="#">page 1131</a> )	<value> ::= {CHIPselect   {NCHipselect   NOTC}   TIMeout}
:SBUS<n>:SPI:SOURce:LOCK <source> (see page 1132)	:SBUS<n>:SPI:SOURce:LOCK? (see <a href="#">page 1132</a> )	<value> ::= {CHANnel<n>   EXTERNAL} for the DSO models <value> ::= {CHANnel<n>   DIGital<d>} for the MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:SPI:SOURce:FRAMe <source> (see page 1133)	:SBUS<n>:SPI:SOURce:FRAMe? (see <a href="#">page 1133</a> )	<value> ::= {CHANnel<n>   EXTERNAL} for the DSO models <value> ::= {CHANnel<n>   DIGital<d>} for the MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format

**Table 134** :SBUS<n>:SPI Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:SPI:SOURce:MISO <source> (see page 1134)	:SBUS<n>:SPI:SOURce:MISO? (see page 1134)	<value> ::= {CHANnel<n>   EXTernal} for the DSO models <value> ::= {CHANnel<n>   DIGital<d>} for the MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:SPI:SOURce:MO SI <source> (see page 1135)	:SBUS<n>:SPI:SOURce:MO SI? (see page 1135)	<value> ::= {CHANnel<n>   EXTernal} for the DSO models <value> ::= {CHANnel<n>   DIGital<d>} for the MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:SPI:TRIGger:PATTern:MISO:DATA <string> (see page 1136)	:SBUS<n>:SPI:TRIGger:PATTern:MISO:DATA? (see page 1136)	<string> ::= "nn...n" where n ::= {0   1   X   \$} <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:SPI:TRIGger:PATTern:MISO:WIDTh <width> (see page 1137)	:SBUS<n>:SPI:TRIGger:PATTern:MISO:WIDTh? (see page 1137)	<width> ::= integer from 4 to 64 in NR1 format
:SBUS<n>:SPI:TRIGger:PATTern:MO SI:DATA <string> (see page 1138)	:SBUS<n>:SPI:TRIGger:PATTern:MO SI:DATA? (see page 1138)	<string> ::= "nn...n" where n ::= {0   1   X   \$} <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:SPI:TRIGger:PATTern:MO SI:WIDTh <width> (see page 1139)	:SBUS<n>:SPI:TRIGger:PATTern:MO SI:WIDTh? (see page 1139)	<width> ::= integer from 4 to 64 in NR1 format
:SBUS<n>:SPI:TRIGger:TYPE <value> (see page 1140)	:SBUS<n>:SPI:TRIGger:TYPE? (see page 1140)	<value> ::= {MO SI   MISO}
:SBUS<n>:SPI:WIDTh <word_width> (see page 1141)	:SBUS<n>:SPI:WIDTh? (see page 1141)	<word_width> ::= integer 4-16 in NR1 format

## :SBUS<n>:SPI:BITorder

**N** (see [page 1666](#))

**Command Syntax** `:SBUS<n>:SPI:BITorder <order>`

`<order> ::= {LSBFFirst | MSBFFirst}`

The :SBUS<n>:SPI:BITorder command selects the bit order, most significant bit first (MSB) or least significant bit first (LSB), used when displaying data in the serial decode waveform and in the Lister.

**Query Syntax** `:SBUS<n>:SPI:BITorder?`

The :SBUS<n>:SPI:BITorder? query returns the current SPI decode bit order.

**Return Format** `<order><NL>`

`<order> ::= {LSBF | MSBF}`

**Errors** • ["-241, Hardware missing" on page 1607](#)

**See Also** • ["Introduction to :SBUS<n> Commands" on page 905](#)

• [":SBUS<n>:MODE" on page 909](#)

• [":SBUS<n>:SPI Commands" on page 1125](#)

## :SBUS<n>:SPI:CLOCK:SLOPe

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SPI:CLOCK:SLOPe <slope>`  
`<slope> ::= {NEGative | POSitive}`

The :SBUS<n>:SPI:CLOCK:SLOPe command specifies the rising edge (POSitive) or falling edge (NEGative) of the SPI clock source that will clock in the data.

**Query Syntax**    `:SBUS<n>:SPI:CLOCK:SLOPe?`

The :SBUS<n>:SPI:CLOCK:SLOPe? query returns the current SPI clock source slope.

**Return Format**    `<slope><NL>`  
`<slope> ::= {NEG | POS}`

**See Also**

- "Introduction to :TRIGger Commands" on page 1349
- "[:SBUS<n>:SPI:CLOCK:TIMEout](#)" on page 1129
- "[:SBUS<n>:SPI:SOURce:CLOCK](#)" on page 1132

## :SBUS<n>:SPI:CLOCK:TIMEout

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:SPI:CLOCK:TIMEout &lt;time_value&gt;</code> <code>&lt;time_value&gt; ::= time in seconds in NR3 format</code>
	The :SBUS<n>:SPI:CLOCK:TIMEout command sets the SPI signal clock timeout resource in seconds from 100 ns to 10 s when the :SBUS<n>:SPI:FRAMing command is set to TIMEout. The timer is used to frame a signal by a clock timeout.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:SPI:CLOCK:TIMEout?</code>
	The :SBUS<n>:SPI:CLOCK:TIMEout? query returns current SPI clock timeout setting.
<b>Return Format</b>	<code>&lt;time value&gt;&lt;NL&gt;</code> <code>&lt;time_value&gt; ::= time in seconds in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SPI:CLOCK:SLOPe</a>" on page 1128</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SPI:SOURce:CLOCK</a>" on page 1132</li> <li>• "<a href="#">:SBUS&lt;n&gt;:SPI:FRAMing</a>" on page 1131</li> </ul>

## :SBUS<n>:SPI:DElay

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SPI:DElay <value>`

`<value> ::= {OFF | 2-63}`

The :SBUS<n>:SPI:DElay command specifies the number of bits to ignore (delay) before decoding the MISO stream.

**Query Syntax**    `:SBUS<n>:SPI:DElay?`

The :SBUS<n>:SPI:DElay? query returns the specified number of delay bits or "OFF" if there are none.

**Return Format**    `<value><NL>`

`<value> ::= {OFF | 2-63}`

**See Also**    · [":SBUS<n>:SPI:SOURce:MISO"](#) on page 1134

## :SBUS<n>:SPI:FRAMing

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:SPI:FRAMing <value>

<value> ::= {CHIPselect | {NCHipselect | NOTC} | TIMEout}

The :SBUS<n>:SPI:FRAMing command sets the SPI trigger framing value. If TIMEout is selected, the timeout value is set by the :SBUS<n>:SPI:CLOCK:TIMEout command.

### NOTE

The NOTC value is deprecated. It is the same as NCHipselect.

**Query Syntax** :SBUS<n>:SPI:FRAMing?

The :SBUS<n>:SPI:FRAMing? query returns the current SPI framing value.

**Return Format** <value><NL>

<value> ::= {CHIP | NCH | TIM}

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:SBUS<n>:SPI:CLOCK:TIMEout](#)" on page 1129
- "[:SBUS<n>:SPI:SOURce:FRAMe](#)" on page 1133

## :SBUS<n>:SPI:SOURce:CLOCK

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SPI:SOURce:CLOCK <source>`

`<source> ::= {CHANnel<n> | EXTernal} for the DSO models`

`<source> ::= {CHANnel<n> | DIGital<d>} for the MSO models`

`<n> ::= 1 to (# analog channels) in NR1 format`

`<d> ::= 0 to (# digital channels - 1) in NR1 format`

The :SBUS<n>:SPI:SOURce:CLOCK command sets the source for the SPI serial clock.

**Query Syntax**    `:SBUS<n>:SPI:SOURce:CLOCK?`

The :SBUS<n>:SPI:SOURce:CLOCK? query returns the current source for the SPI serial clock.

**Return Format**    `<source><NL>`

- See Also**
- "[Introduction to :TRIGger Commands](#)" on page 1349
  - "[:SBUS<n>:SPI:CLOCK:SLOPe](#)" on page 1128
  - "[:SBUS<n>:SPI:CLOCK:TIMEout](#)" on page 1129
  - "[:SBUS<n>:SPI:SOURce:FRAME](#)" on page 1133
  - "[:SBUS<n>:SPI:SOURce:MOSI](#)" on page 1135
  - "[:SBUS<n>:SPI:SOURce:MISO](#)" on page 1134

## :SBUS<n>:SPI:SOURce:FRAMe

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SPI:SOURce:FRAMe <source>`

```

<source> ::= {CHANnel<n> | EXTernal} for the DSO models
<source> ::= {CHANnel<n> | DIGital<d>} for the MSO models
<n> ::= 1 to (# analog channels) in NR1 format
<d> ::= 0 to (# digital channels - 1) in NR1 format

```

The :SBUS<n>:SPI:SOURce:FRAMe command sets the frame source when :SBUS<n>:SPI:FRAMing is set to CHIPselect or NOTchipselect.

**Query Syntax**    `:SBUS<n>:SPI:SOURce:FRAMe?`

The :SBUS<n>:SPI:SOURce:FRAMe? query returns the current frame source for the SPI serial frame.

**Return Format**    `<source><NL>`

- See Also**
- "[Introduction to :TRIGger Commands](#)" on page 1349
  - "[:SBUS<n>:SPI:SOURce:CLOCK](#)" on page 1132
  - "[:SBUS<n>:SPI:SOURce:MOSI](#)" on page 1135
  - "[:SBUS<n>:SPI:SOURce:MISO](#)" on page 1134
  - "[:SBUS<n>:SPI:FRAMing](#)" on page 1131

## :SBUS<n>:SPI:SOURce:MISO

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SPI:SOURce:MISO <source>`

```

<source> ::= {CHANnel<n> | EXTernal} for the DSO models
<source> ::= {CHANnel<n> | DIGital<d>} for the MSO models
<n> ::= 1 to (# analog channels) in NR1 format
<d> ::= 0 to (# digital channels - 1) in NR1 format

```

The :SBUS<n>:SPI:SOURce:MISO command sets the source for the SPI serial MISO data.

**Query Syntax**    `:SBUS<n>:SPI:SOURce:MISO?`

The :SBUS<n>:SPI:SOURce:MISO? query returns the current source for the SPI serial MISO data.

**Return Format**    `<source><NL>`

- See Also**
- "[:SBUS<n>:SPI:DELay](#)" on page 1130
  - "[Introduction to :TRIGger Commands](#)" on page 1349
  - "[:SBUS<n>:SPI:SOURce:MOSI](#)" on page 1135
  - "[:SBUS<n>:SPI:SOURce:CLOCK](#)" on page 1132
  - "[:SBUS<n>:SPI:SOURce:FRAMe](#)" on page 1133
  - "[:SBUS<n>:SPI:TRIGger:PATTERn:MISO:DATA](#)" on page 1136
  - "[:SBUS<n>:SPI:TRIGger:PATTERn:MOSI:DATA](#)" on page 1138
  - "[:SBUS<n>:SPI:TRIGger:PATTERn:MISO:WIDTh](#)" on page 1137
  - "[:SBUS<n>:SPI:TRIGger:PATTERn:MOSI:WIDTh](#)" on page 1139

## :SBUS<n>:SPI:SOURce:MOSI

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:SPI:SOURce:MOSI &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   EXTERNAL} for the DSO models</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;} for the MSO models</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	The :SBUS<n>:SPI:SOURce:MOSI command sets the source for the SPI serial MOSI data.

<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:SPI:SOURce:MOSI?</code>
	The :SBUS<n>:SPI:SOURce:MOSI? query returns the current source for the SPI serial MOSI data.

<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
----------------------	---------------------------------------

<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">"Introduction to :TRIGger Commands" on page 1349</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:SPI:SOURce:MISO" on page 1134</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:SPI:SOURce:CLOCK" on page 1132</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:SPI:SOURce:FRAMe" on page 1133</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:SPI:TRIGger:PATTern:MISO:DATA" on page 1136</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:SPI:TRIGger:PATTern:MOSI:DATA" on page 1138</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:SPI:TRIGger:PATTern:MISO:WIDTh" on page 1137</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:SPI:TRIGger:PATTern:MOSI:WIDTh" on page 1139</a></li> </ul>
-----------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

## :SBUS<n>:SPI:TRIGger:PATTERn:MISO:DATA

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SPI:TRIGger:PATTERn:MISO:DATA <string>`

`<string> ::= "nn...n" where n ::= {0 | 1 | X | $}`

`<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | X | $}`

The :SBUS<n>:SPI:TRIGger:PATTERn:MISO:DATA command defines the SPI data pattern resource according to the string parameter. This pattern, along with the data width, control the data pattern searched for in the data stream.

If the string parameter starts with "0x", it is a hexadecimal string made up of hexadecimal and X (don't care) characters; otherwise, it is a binary string made up of 0, 1, and X (don't care) characters.

### NOTE

The :SBUS<n>:SPI:TRIGger:PATTERn:MISO:WIDTh should be set before :SBUS<n>:SPI:TRIGger:PATTERn:MISO:DATA.

**Query Syntax**    `:SBUS<n>:SPI:TRIGger:PATTERn:MISO:DATA?`

The :SBUS<n>:SPI:TRIGger:PATTERn:MISO:DATA? query returns the current settings of the specified SPI data pattern resource in the binary string format.

**Return Format**    `<string><NL>`

- See Also**
- ["Introduction to :TRIGger Commands" on page 1349](#)
  - [":SBUS<n>:SPI:TRIGger:PATTERn:MISO:WIDTh" on page 1137](#)
  - [":SBUS<n>:SPI:SOURce:MISO" on page 1134](#)

## :SBUS<n>:SPI:TRIGger:PATTern:MISO:WIDTh

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SPI:TRIGger:PATTern:MISO:WIDTh <width>`  
`<width> ::= integer from 4 to 64 in NR1 format`

The :SBUS<n>:SPI:TRIGger:PATTern:MISO:WIDTh command sets the width of the SPI data pattern anywhere from 4 bits to 64 bits.

### NOTE

The :SBUS<n>:SPI:TRIGger:PATTern:MISO:WIDTh should be set before :SBUS<n>:SPI:TRIGger:PATTern:MISO:DATA.

**Query Syntax**    `:SBUS<n>:SPI:TRIGger:PATTern:MISO:WIDTh?`

The :SBUS<n>:SPI:TRIGger:PATTern:MISO:WIDTh? query returns the current SPI data pattern width setting.

**Return Format**    `<width><NL>`  
`<width> ::= integer from 4 to 64 in NR1 format`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":SBUS<n>:SPI:TRIGger:PATTern:MISO:DATA](#)" on page 1136
- "[":SBUS<n>:SPI:SOURce:MISO](#)" on page 1134

## :SBUS<n>:SPI:TRIGger:PATTERn:MOSI:DATA

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SPI:TRIGger:PATTERn:MOSI:DATA <string>`

`<string> ::= "nn...n" where n ::= {0 | 1 | X | $}`

`<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | X | $}`

The :SBUS<n>:SPI:TRIGger:PATTERn:MOSI:DATA command defines the SPI data pattern resource according to the string parameter. This pattern, along with the data width, control the data pattern searched for in the data stream.

If the string parameter starts with "0x", it is a hexadecimal string made up of hexadecimal and X (don't care) characters; otherwise, it is a binary string made up of 0, 1, and X (don't care) characters.

### NOTE

The :SBUS<n>:SPI:TRIGger:PATTERn:MOSI:WIDTh should be set before :SBUS<n>:SPI:TRIGger:PATTERn:MOSI:DATA.

**Query Syntax**    `:SBUS<n>:SPI:TRIGger:PATTERn:MOSI:DATA?`

The :SBUS<n>:SPI:TRIGger:PATTERn:MOSI:DATA? query returns the current settings of the specified SPI data pattern resource in the binary string format.

**Return Format**    `<string><NL>`

**See Also**

- ["Introduction to :TRIGger Commands" on page 1349](#)
- [":SBUS<n>:SPI:TRIGger:PATTERn:MOSI:WIDTh" on page 1139](#)
- [":SBUS<n>:SPI:SOURce:MOSI" on page 1135](#)

## :SBUS<n>:SPI:TRIGger:PATTERn:MOSI:WIDTh

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SPI:TRIGger:PATTERn:MOSI:WIDTh <width>`  
`<width> ::= integer from 4 to 64 in NR1 format`

The :SBUS<n>:SPI:TRIGger:PATTERn:MOSI:WIDTh command sets the width of the SPI data pattern anywhere from 4 bits to 64 bits.

### NOTE

The :SBUS<n>:SPI:TRIGger:PATTERn:MOSI:WIDTh should be set before :SBUS<n>:SPI:TRIGger:PATTERn:MOSI:DATA.

**Query Syntax**    `:SBUS<n>:SPI:TRIGger:PATTERn:MOSI:WIDTh?`

The :SBUS<n>:SPI:TRIGger:PATTERn:MOSI:WIDTh? query returns the current SPI data pattern width setting.

**Return Format**    `<width><NL>`  
`<width> ::= integer from 4 to 64 in NR1 format`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":SBUS<n>:SPI:TRIGger:PATTERn:MOSI:DATA](#)" on page 1138
- "[":SBUS<n>:SPI:SOURce:MOSI](#)" on page 1135

## :SBUS<n>:SPI:TRIGger:TYPE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SPI:TRIGger:TYPE <value>`  
`<value> ::= {MOSI | MISO}`

The :SBUS<n>:SPI:TRIGger:TYPE command specifies whether the SPI trigger will be on the MOSI data or the MISO data.

When triggering on MOSI data, the data value is specified by the :SBUS<n>:SPI:TRIGger:PATTern:MOSI:DATA and :SBUS<n>:SPI:TRIGger:PATTern:MOSI:WIDTh commands.

When triggering on MISO data, the data value is specified by the :SBUS<n>:SPI:TRIGger:PATTern:MISO:DATA and :SBUS<n>:SPI:TRIGger:PATTern:MISO:WIDTh commands.

**Query Syntax**    `:SBUS<n>:SPI:TRIGger:TYPE?`

The :SBUS<n>:SPI:TRIGger:TYPE? query returns the current SPI trigger type setting.

**Return Format**    `<value><NL>`  
`<value> ::= {MOSI | MISO}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":SBUS<n>:SPI:SOURce:MOSI"](#) on page 1135
- "[":SBUS<n>:SPI:SOURce:MISO"](#) on page 1134
- "[":SBUS<n>:SPI:TRIGger:PATTern:MISO:DATA"](#) on page 1136
- "[":SBUS<n>:SPI:TRIGger:PATTern:MOSI:DATA"](#) on page 1138
- "[":SBUS<n>:SPI:TRIGger:PATTern:MISO:WIDTh"](#) on page 1137
- "[":SBUS<n>:SPI:TRIGger:PATTern:MOSI:WIDTh"](#) on page 1139
- "[":TRIGger:MODE"](#) on page 1362

## :SBUS<n>:SPI:WIDTH

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:SPI:WIDTH <word\_width>

<word\_width> ::= integer 4-16 in NR1 format

The :SBUS<n>:SPI:WIDTH command determines the number of bits in a word of data for SPI.

**Query Syntax** :SBUS<n>:SPI:WIDTH?

The :SBUS<n>:SPI:WIDTH? query returns the current SPI decode word width.

**Return Format** <word\_width><NL>

<word\_width> ::= integer 4-16 in NR1 format

**Errors** • ["-241, Hardware missing"](#) on page 1607

**See Also** • ["Introduction to :SBUS<n> Commands"](#) on page 905

• [":SBUS<n>:MODE"](#) on page 909

• [":SBUS<n>:SPI Commands"](#) on page 1125

## :SBUS<n>:UART Commands

**NOTE**

These commands are only valid when the UART/RS-232 triggering and serial decode option has been licensed.

**Table 135** :SBUS<n>:UART Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:UART:BASE <base> (see <a href="#">page 1145</a> )	:SBUS<n>:UART:BASE? (see <a href="#">page 1145</a> )	<base> ::= {ASCII   BINARY   HEX}
:SBUS<n>:UART:BAUDrate e <baudrate> (see <a href="#">page 1146</a> )	:SBUS<n>:UART:BAUDrate e? (see <a href="#">page 1146</a> )	<baudrate> ::= integer from 100 to 8000000, 10000000, or 12000000
:SBUS<n>:UART:BITorde r <bitorder> (see <a href="#">page 1147</a> )	:SBUS<n>:UART:BITorde r? (see <a href="#">page 1147</a> )	<bitorder> ::= {LSBFIRST   MSBFIRST}
n/a	:SBUS<n>:UART:COUNT:E RRor? (see <a href="#">page 1148</a> )	<frame_count> ::= integer in NR1 format
:SBUS<n>:UART:COUNT:R ESet (see <a href="#">page 1149</a> )	n/a	n/a
n/a	:SBUS<n>:UART:COUNT:R XFRAMES? (see <a href="#">page 1150</a> )	<frame_count> ::= integer in NR1 format
n/a	:SBUS<n>:UART:COUNT:T XFRAMES? (see <a href="#">page 1151</a> )	<frame_count> ::= integer in NR1 format
:SBUS<n>:UART:FRAMing <value> (see <a href="#">page 1152</a> )	:SBUS<n>:UART:FRAMing ? (see <a href="#">page 1152</a> )	<value> ::= {OFF   <decimal>   <nondecimal>} <decimal> ::= 8-bit integer from 0-255 (0x00-0xff) <nondecimal> ::= #Hnn where n ::= {0,...,9   A,...,F} for hexadecimal <nondecimal> ::= #Bnn...n where n ::= {0   1} for binary
:SBUS<n>:UART:PARity <parity> (see <a href="#">page 1153</a> )	:SBUS<n>:UART:PARity? (see <a href="#">page 1153</a> )	<parity> ::= {EVEN   ODD   NONE}
:SBUS<n>:UART:POLarit y <polarity> (see <a href="#">page 1154</a> )	:SBUS<n>:UART:POLarit y? (see <a href="#">page 1154</a> )	<polarity> ::= {HIGH   LOW}

**Table 135** :SBUS<n>:UART Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:UART:SOURce: RX <source> (see <a href="#">page 1155</a> )	:SBUS<n>:UART:SOURce: RX? (see <a href="#">page 1155</a> )	<source> ::= {CHANnel<n>   EXTernal} for DSO models  <source> ::= {CHANnel<n>   DIGital<d>} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:UART:SOURce: TX <source> (see <a href="#">page 1156</a> )	:SBUS<n>:UART:SOURce: TX? (see <a href="#">page 1156</a> )	<source> ::= {CHANnel<n>   EXTernal} for DSO models  <source> ::= {CHANnel<n>   DIGital<d>} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:UART:TRIGger :BASE <base> (see <a href="#">page 1157</a> )	:SBUS<n>:UART:TRIGger :BASE? (see <a href="#">page 1157</a> )	<base> ::= {ASCII   HEX}
:SBUS<n>:UART:TRIGger :BURSt <value> (see <a href="#">page 1158</a> )	:SBUS<n>:UART:TRIGger :BURSt? (see <a href="#">page 1158</a> )	<value> ::= {OFF   1 to 4096 in NR1 format}
:SBUS<n>:UART:TRIGger :DATA <value> (see <a href="#">page 1159</a> )	:SBUS<n>:UART:TRIGger :DATA? (see <a href="#">page 1159</a> )	<value> ::= 8-bit integer from 0-255 (0x00-0xff) in decimal, <hexadecimal>, <binary>, or <quoted_string> format  <hexadecimal> ::= #Hnn where n ::= {0,...,9   A,...,F} for hexadecimal  <binary> ::= #Bnn...n where n ::= {0   1} for binary  <quoted_string> ::= any of the 128 valid 7-bit ASCII characters (or standard abbreviations)
:SBUS<n>:UART:TRIGger :IDLE <time_value> (see <a href="#">page 1160</a> )	:SBUS<n>:UART:TRIGger :IDLE? (see <a href="#">page 1160</a> )	<time_value> ::= time from 1 us to 10 s in NR3 format
:SBUS<n>:UART:TRIGger :QUALifier <value> (see <a href="#">page 1161</a> )	:SBUS<n>:UART:TRIGger :QUALifier? (see <a href="#">page 1161</a> )	<value> ::= {EQUAL   NOTEQUAL   GREATERthan   LESSthan}

**Table 135** :SBUS<n>:UART Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:UART:TRIGger :TYPE <value> (see <a href="#">page 1162</a> )	:SBUS<n>:UART:TRIGger :TYPE? (see <a href="#">page 1162</a> )	<value> ::= {RSTArt   RSTOP   RDATA   RD1   RD0   RDX   PARityerror   TSTAArt   TSTOP   TDATA   TD1   TD0   TDX}
:SBUS<n>:UART:WIDTH <width> (see <a href="#">page 1163</a> )	:SBUS<n>:UART:WIDTH? (see <a href="#">page 1163</a> )	<width> ::= {5   6   7   8   9}

## :SBUS<n>:UART:BASE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:UART:BASE <base>`  
                  `<base> ::= {ASCii | BINary | HEX}`

The :SBUS<n>:UART:BASE command determines the base to use for the UART decode and Lister display.

**Query Syntax**    `:SBUS<n>:UART:BASE?`

The :SBUS<n>:UART:BASE? query returns the current UART decode and Lister base setting.

**Return Format**    `<base><NL>`  
                  `<base> ::= {ASCii | BINary | HEX}`

**Errors**    · "–241, Hardware missing" on page 1607

**See Also**    · "[Introduction to :SBUS<n> Commands](#)" on page 905  
                  · "[:SBUS<n>:UART Commands](#)" on page 1142

## :SBUS<n>:UART:BAUDrate

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:UART:BAUDrate <baudrate>`  
`<baudrate> ::= integer from 100 to 8000000, 10000000, or 12000000`

The :SBUS<n>:UART:BAUDrate command selects the bit rate (in bps) for the serial decoder and/or trigger when in UART mode. The baud rate can be set in the range from 100 b/s to 8 Mb/s or to the specific values of 10 Mb/s or 12 Mb/s.

If the baud rate you select does not match the system baud rate, false triggers may occur.

**Query Syntax**    `:SBUS<n>:UART:BAUDrate?`

The :SBUS<n>:UART:BAUDrate? query returns the current UART baud rate setting.

**Return Format**    `<baudrate><NL>`  
`<baudrate> ::= integer from 100 to 8000000, 10000000, or 12000000`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:SBUS<n>:UART:TRIGger:TYPE](#)" on page 1162

## :SBUS<n>:UART:BITorder

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:UART:BITorder <bitorder>`  
`<bitorder> ::= {LSBFFirst | MSBFFirst}`

The :SBUS<n>:UART:BITorder command specifies the order of transmission used by the physical Tx and Rx input signals for the serial decoder and/or trigger when in UART mode. LSBFirst sets the least significant bit of each message "byte" as transmitted first. MSBFirst sets the most significant bit as transmitted first.

**Query Syntax**    `:SBUS<n>:UART:BITorder?`

The :SBUS<n>:UART:BITorder? query returns the current UART bit order setting.

**Return Format**    `<bitorder><NL>`  
`<bitorder> ::= {LSBF | MSBF}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:SBUS<n>:UART:TRIGger:TYPE](#)" on page 1162
- "[:SBUS<n>:UART:SOURce:RX](#)" on page 1155
- "[:SBUS<n>:UART:SOURce:TX](#)" on page 1156

**:SBUS<n>:UART:COUNt:ERRor**

**N** (see [page 1666](#))

**Query Syntax**    `:SBUS<n>:UART:COUNt:ERRor?`

Returns the UART error frame count.

**Return Format**    `<frame_count><NL>`

`<frame_count>` ::= integer in NR1 format

**Errors**    • ["-241, Hardware missing" on page 1607](#)

**See Also**    • [":SBUS<n>:UART:COUNt:RESet" on page 1149](#)  
          • ["Introduction to :SBUS<n> Commands" on page 905](#)  
          • [":SBUS<n>:MODE" on page 909](#)  
          • [":SBUS<n>:UART Commands" on page 1142](#)

## :SBUS<n>:UART:COUNT:RESet

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:UART:COUNT:RESet

Resets the UART frame counters.

**Errors** • ["-241, Hardware missing"](#) on page 1607

**See Also** • [":SBUS<n>:UART:COUNT:ERRor"](#) on page 1148  
• [":SBUS<n>:UART:COUNT:RXFRAMES"](#) on page 1150  
• [":SBUS<n>:UART:COUNT:TXFRAMES"](#) on page 1151  
• ["Introduction to :SBUS<n> Commands"](#) on page 905  
• [":SBUS<n>:MODE"](#) on page 909  
• [":SBUS<n>:UART Commands"](#) on page 1142

## :SBUS<n>:UART:COUNt:RXFRAMES

**N** (see [page 1666](#))

**Query Syntax** :SBUS<n>:UART:COUNt:RXFRAMES?

Returns the UART Rx frame count.

**Return Format** <frame\_count><NL>

<frame\_count> ::= integer in NR1 format

**Errors** • ["-241, Hardware missing"](#) on page 1607

**See Also** • [":SBUS<n>:UART:COUNt:RESet"](#) on page 1149  
• ["Introduction to :SBUS<n> Commands"](#) on page 905  
• [":SBUS<n>:MODE"](#) on page 909  
• [":SBUS<n>:UART Commands"](#) on page 1142

## :SBUS<n>:UART:COUNt:TXFRAMES

**N** (see [page 1666](#))

**Query Syntax** :SBUS<n>:UART:COUNt:TXFRAMES?

Returns the UART Tx frame count.

**Return Format** <frame\_count><NL>

<frame\_count> ::= integer in NR1 format

**Errors** • ["-241, Hardware missing"](#) on page 1607

**See Also** • [":SBUS<n>:UART:COUNt:RESet"](#) on page 1149  
• ["Introduction to :SBUS<n> Commands"](#) on page 905  
• [":SBUS<n>:MODE"](#) on page 909  
• [":SBUS<n>:UART Commands"](#) on page 1142

## :SBUS<n>:UART:FRAMing

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:UART:FRAMing &lt;value&gt;</code>
	<code>&lt;value&gt; ::= {OFF   &lt;decimal&gt;   &lt;nondecimal&gt;}</code>
	<code>&lt;decimal&gt; ::= 8-bit integer in decimal from 0-255 (0x00-0xff)</code>
	<code>&lt;nondecimal&gt; ::= #Hnn where n ::= {0,...,9   A,...,F} for hexadecimal</code>
	<code>&lt;nondecimal&gt; ::= #Bnn...n where n ::= {0   1} for binary</code>
	The :SBUS<n>:UART:FRAMing command determines the byte value to use for framing (end of packet) or to turn off framing for UART decode.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:UART:FRAMing?</code>
	The :SBUS<n>:UART:FRAMing? query returns the current UART decode base setting.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code>
	<code>&lt;value&gt; ::= {OFF   &lt;decimal&gt;}</code>
	<code>&lt;decimal&gt; ::= 8-bit integer in decimal from 0-255</code>
<b>Errors</b>	<ul style="list-style-type: none"> <li>• <a href="#">"-241, Hardware missing" on page 1607</a></li> </ul>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">"Introduction to :SBUS&lt;n&gt; Commands" on page 905</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:UART Commands" on page 1142</a></li> </ul>

## :SBUS<n>:UART:PARity

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:UART:PARity <parity>`  
                  `<parity> ::= {EVEN | ODD | NONE}`

The :SBUS<n>:UART:PARity command selects the parity to be used with each message "byte" for the serial decoder and/or trigger when in UART mode.

**Query Syntax**    `:SBUS<n>:UART:PARity?`

The :SBUS<n>:UART:PARity? query returns the current UART parity setting.

**Return Format**    `<parity><NL>`  
                  `<parity> ::= {EVEN | ODD | NONE}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:SBUS<n>:UART:TRIGger:TYPE](#)" on page 1162

## :SBUS<n>:UART:POLarity

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:UART:POLarity <polarity>`  
                  `<polarity> ::= {HIGH | LOW}`

The :SBUS<n>:UART:POLarity command selects the polarity as idle low or idle high for the serial decoder and/or trigger when in UART mode.

**Query Syntax**    `:SBUS<n>:UART:POLarity?`

The :SBUS<n>:UART:POLarity? query returns the current UART polarity setting.

**Return Format**    `<polarity><NL>`  
                  `<polarity> ::= {HIGH | LOW}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:SBUS<n>:UART:TRIGger:TYPE](#)" on page 1162

## :SBUS<n>:UART:SOURce:RX

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:UART:SOURce:RX &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   EXTERNAL} for the DSO models</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;} for the MSO models</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	The :SBUS<n>:UART:SOURce:RX command controls which signal is used as the Rx source by the serial decoder and/or trigger when in UART mode.

<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:UART:SOURce:RX?</code>
	The :SBUS<n>:UART:SOURce:RX? query returns the current source for the UART Rx signal.

<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
----------------------	---------------------------------------

<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">"Introduction to :TRIGger Commands" on page 1349</a></li> <li>· <a href="#">":TRIGger:MODE" on page 1362</a></li> <li>· <a href="#">":SBUS&lt;n&gt;:UART:TRIGger:TYPE" on page 1162</a></li> <li>· <a href="#">":SBUS&lt;n&gt;:UART:BITorder" on page 1147</a></li> </ul>
-----------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

## :SBUS<n>:UART:SOURce:TX

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:UART:SOURce:TX &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   EXTernal} for the DSO models</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;} for the MSO models</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	The :SBUS<n>:UART:SOURce:TX command controls which signal is used as the Tx source by the serial decoder and/or trigger when in UART mode.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:UART:SOURce:TX?</code>
	The :SBUS<n>:UART:SOURce:TX? query returns the current source for the UART Tx signal.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>· "<a href="#">:TRIGger:MODE</a>" on page 1362</li> <li>· "<a href="#">:SBUS&lt;n&gt;:UART:TRIGger:TYPE</a>" on page 1162</li> <li>· "<a href="#">:SBUS&lt;n&gt;:UART:BITorder</a>" on page 1147</li> </ul>

## :SBUS<n>:UART:TRIGger:BASE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:UART:TRIGger:BASE <base>`  
`<base> ::= {ASCII | HEX}`

The :SBUS<n>:UART:TRIGger:BASE command sets the front panel UART/RS232 trigger setup data selection option:

- ASCII – front panel data selection is from ASCII values.
- HEX – front panel data selection is from hexadecimal values.

The :SBUS<n>:UART:TRIGger:BASE setting does not affect the :SBUS<n>:UART:TRIGger:DATA command which can always set data values using ASCII or hexadecimal values.

### NOTE

The :SBUS<n>:UART:TRIGger:BASE command is independent of the :SBUS<n>:UART:BASE command which affects decode and Lister only.

**Query Syntax**    `:SBUS<n>:UART:TRIGger:BASE?`

The :SBUS<n>:UART:TRIGger:BASE? query returns the current UART base setting.

**Return Format**    `<base><NL>`  
`<base> ::= {ASC | HEX}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:SBUS<n>:UART:TRIGger:DATA](#)" on page 1159

## :SBUS<n>:UART:TRIGger:BURSt

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:UART:TRIGger:BURSt <value>`

`<value> ::= {OFF | 1 to 4096 in NR1 format}`

The :SBUS<n>:UART:TRIGger:BURSt command selects the burst value (Nth frame after idle period) in the range 1 to 4096 or OFF, for the trigger when in UART mode.

**Query Syntax**    `:SBUS<n>:UART:TRIGger:BURSt?`

The :SBUS<n>:UART:TRIGger:BURSt? query returns the current UART trigger burst value.

**Return Format**    `<value><NL>`

`<value> ::= {OFF | 1 to 4096 in NR1 format}`

**See Also**

- "Introduction to [:TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:SBUS<n>:UART:TRIGger:IDLE](#)" on page 1160
- "[:SBUS<n>:UART:TRIGger:TYPE](#)" on page 1162

## :SBUS<n>:UART:TRIGger:DATA

**N** (see [page 1666](#))

**Command Syntax**

```
:SBUS<n>:UART:TRIGger:DATA <value>
<value> ::= 8-bit integer from 0-255 (0x00-0xff) in decimal,
           <hexadecimal>, <binary>, or <quoted_string> format
<hexadecimal> ::= #Hnn where n ::= {0,...,9 | A,...,F} for hexadecimal
<binary> ::= #Bnn...n where n ::= {0 | 1} for binary
<quoted_string> ::= any of the 128 valid 7-bit ASCII characters
                     (or standard abbreviations)
```

The :SBUS<n>:UART:TRIGger:DATA command selects the data byte value (0x00 to 0xFF) for the trigger QUALifier when in UART mode. The data value is used when one of the RD or TD trigger types is selected.

When entering an ASCII character via the quoted string, it must be one of the 128 valid characters (case-sensitive): "NUL", "SOH", "STX", "ETX", "EOT", "ENQ", "ACK", "BEL", "BS", "HT", "LF", "VT", "FF", "CR", "SO", "SI", "DLE", "DC1", "DC2", "DC3", "DC4", "NAK", "SYN", "ETB", "CAN", "EM", "SUB", "ESC", "FS", "GS", "RS", "US", "SP", "!", "\\", "#", "\$", "%", "&", "\\", "(", ")", "\*", "+", ",", "-", ".", "/", "O", "1", "2", "3", "4", "5", "6", "7", "8", "9", ":", ";", "<", "=", ">", "?", "@", "A", "B", "C", "D", "E", "F", "G", "H", "I", "J", "K", "L", "M", "N", "O", "P", "Q", "R", "S", "T", "U", "V", "W", "X", "Y", "Z", "[", "\\", "]", "^", "\_", "a", "b", "c", "d", "e", "f", "g", "h", "i", "j", "k", "l", "m", "n", "o", "p", "q", "r", "s", "t", "u", "v", "w", "x", "y", "{", "|", "}", "~", or "DEL".

**Query Syntax**

```
:SBUS<n>:UART:TRIGger:DATA?
```

The :SBUS<n>:UART:TRIGger:DATA? query returns the current UART trigger data value.

**Return Format**

```
<value><NL>
<value> ::= 8-bit integer in decimal from 0-255
```

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:SBUS<n>:UART:TRIGger:BASE](#)" on page 1157
- "[:SBUS<n>:UART:TRIGger:TYPE](#)" on page 1162

## :SBUS<n>:UART:TRIGger:IDLE

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:UART:TRIGger:IDLE &lt;time_value&gt;</code> <code>&lt;time_value&gt; ::= time from 1 us to 10 s in NR3 format</code>
	The :SBUS<n>:UART:TRIGger:IDLE command selects the value of the idle period for burst trigger in the range from 1 us to 10 s when in UART mode.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:UART:TRIGger:IDLE?</code>
	The :SBUS<n>:UART:TRIGger:IDLE? query returns the current UART trigger idle period time.
<b>Return Format</b>	<code>&lt;time_value&gt;&lt;NL&gt;</code> <code>&lt;time_value&gt; ::= time from 1 us to 10 s in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">"Introduction to :TRIGger Commands"</a> on page 1349</li><li><a href="#">":TRIGger:MODE"</a> on page 1362</li><li><a href="#">":SBUS&lt;n&gt;:UART:TRIGger:BURSt"</a> on page 1158</li><li><a href="#">":SBUS&lt;n&gt;:UART:TRIGger:TYPE"</a> on page 1162</li></ul>

## :SBUS<n>:UART:TRIGger:QUALifier

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:UART:TRIGger:QUALifier &lt;value&gt;</code> <code>&lt;value&gt; ::= {EQUal   NOTequal   GREaterthan   LESSthan}</code>
	The :SBUS<n>:UART:TRIGger:QUALifier command selects the data qualifier when :TYPE is set to RDATa, RD1, RD0, RDX, TDATa, TD1, TD0, or TDX for the trigger when in UART mode.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:UART:TRIGger:QUALifier?</code>
	The :SBUS<n>:UART:TRIGger:QUALifier? query returns the current UART trigger qualifier.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code> <code>&lt;value&gt; ::= {EQU   NOT   GRE   LESS}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">:TRIGger:MODE</a>" on page 1362</li> <li>• "<a href="#">:SBUS&lt;n&gt;:UART:TRIGger:TYPE</a>" on page 1162</li> </ul>

## :SBUS<n>:UART:TRIGger:TYPE

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:UART:TRIGger:TYPE <value>`

```
<value> ::= {RSTA | RSTO | RDAT | RD1 | RD0 | RDX | PARityerror
             | TSTA | TSTO | TDAT | TD1 | TD0 | TDX}
```

The :SBUS<n>:UART:TRIGger:TYPE command selects the UART trigger type.

When one of the RD or TD types is selected, the :SBUS<n>:UART:TRIGger:DATA and :SBUS<n>:UART:TRIGger:QUALifier commands are used to specify the data value and comparison operator.

The RD1, RD0, RDX, TD1, TD0, and TDX types (for triggering on data and alert bit values) are only valid when a 9-bit width has been selected.

**Query Syntax**    `:SBUS<n>:UART:TRIGger:TYPE?`

The :SBUS<n>:UART:TRIGger:TYPE? query returns the current UART trigger data value.

**Return Format**    `<value><NL>`

```
<value> ::= {RSTA | RSTO | RDAT | RD1 | RD0 | RDX | PAR | TSTA |
             TSTO | TDAT | TD1 | TD0 | TDX}
```

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:SBUS<n>:UART:TRIGger:DATA](#)" on page 1159
- "[:SBUS<n>:UART:TRIGger:QUALifier](#)" on page 1161
- "[:SBUS<n>:UART:WIDTh](#)" on page 1163

## :SBUS<n>:UART:WIDTh

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:UART:WIDTh <width>`

`<width> ::= {5 | 6 | 7 | 8 | 9}`

The :SBUS<n>:UART:WIDTh command determines the number of bits (5-9) for each message "byte" for the serial decoder and/or trigger when in UART mode.

**Query Syntax**    `:SBUS<n>:UART:WIDTh?`

The :SBUS<n>:UART:WIDTh? query returns the current UART width setting.

**Return Format**    `<width><NL>`

`<width> ::= {5 | 6 | 7 | 8 | 9}`

**See Also**

- ["Introduction to :TRIGger Commands" on page 1349](#)
- [":TRIGger:MODE" on page 1362](#)
- [":SBUS<n>:UART:TRIGger:TYPE" on page 1162](#)

## :SBUS<n>:USB Commands

**NOTE**

These commands are only valid when a USB 2.0 triggering and serial decode option has been licensed.

**Table 136** :SBUS<n>:USB Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:USB:BASE <base> (see <a href="#">page 1167</a> )	:SBUS<n>:USB:BASE? (see <a href="#">page 1167</a> )	<base> ::= {ASCII   BINARY   DECIMAL   HEX}
:SBUS<n>:USB:SOURce:D MINus <source> (see <a href="#">page 1168</a> )	:SBUS<n>:USB:SOURce:D MINus? (see <a href="#">page 1168</a> )	<source> ::= {CHANNEL<n>} for DSO models  <source> ::= {CHANNEL<n>   DIGITAL<d>} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:USB:SOURce:D PLus <source> (see <a href="#">page 1169</a> )	:SBUS<n>:USB:SOURce:D PLus? (see <a href="#">page 1169</a> )	<source> ::= {CHANNEL<n>} for DSO models  <source> ::= {CHANNEL<n>   DIGITAL<d>} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:SBUS<n>:USB:SOURce:D IFFerential <source> (see <a href="#">page 1170</a> )	:SBUS<n>:USB:SOURce:D IFFerential? (see <a href="#">page 1170</a> )	<source> ::= {CHANNEL<n>}  <n> ::= 1 to (# analog channels) in NR1 format
:SBUS<n>:USB:SPEed <speed> (see <a href="#">page 1171</a> )	:SBUS<n>:USB:SPEed? (see <a href="#">page 1171</a> )	<speed> ::= {LOW   FULL   HIGH}
:SBUS<n>:USB:TRIGger <condition> (see <a href="#">page 1172</a> )	:SBUS<n>:USB:TRIGger? (see <a href="#">page 1172</a> )	<condition> ::= {SOP   EOP   ENTersuspend   EXITsuspend   RESet   TOKen   DATA   HANDshake   SPECIAL   ALLerrors   PIDerror   CRC5error   CRC16error   GLITcherror   STUFFerror   SE1rror}

**Table 136** :SBUS<n>:USB Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:USB:TRIGger: ADDReSS <string> (see <a href="#">page 1173</a> )	:SBUS<n>:USB:TRIGger: ADDReSS? (see <a href="#">page 1173</a> )	<string> ::= "nnnnnnnn" where n ::= {0   1   X}  <string> ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:USB:TRIGger: CRC <string> (see <a href="#">page 1174</a> )	:SBUS<n>:USB:TRIGger: CRC? (see <a href="#">page 1174</a> )	<string> ::= "nnnnn" where n ::= {0   1   X}  <string> ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:USB:TRIGger: DATA <string> (see <a href="#">page 1175</a> )	:SBUS<n>:USB:TRIGger: DATA? (see <a href="#">page 1175</a> )	<string> ::= "nnnn..." where n ::= {0   1   X}  <string> ::= "0xn..." where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:USB:TRIGger: DATA:LENGth <value> (see <a href="#">page 1176</a> )	:SBUS<n>:USB:TRIGger: DATA:LENGth? (see <a href="#">page 1176</a> )	<length> ::= data length between 1-20
:SBUS<n>:USB:TRIGger: ENDPoint <string> (see <a href="#">page 1177</a> )	:SBUS<n>:USB:TRIGger: ENDPoint? (see <a href="#">page 1177</a> )	<string> ::= "nnnn" where n ::= {0   1   X}  <string> ::= "0xn" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:USB:TRIGger: ET <string> (see <a href="#">page 1178</a> )	:SBUS<n>:USB:TRIGger: ET? (see <a href="#">page 1178</a> )	<string> ::= "nn" where n ::= {0   1   X}  <string> ::= "0xn" where n ::= {0   1   2   3   X   \$}
:SBUS<n>:USB:TRIGger: FRAMe <string> (see <a href="#">page 1179</a> )	:SBUS<n>:USB:TRIGger: FRAMe? (see <a href="#">page 1179</a> )	<string> ::= "nnnnnnnnnnnn" where n ::= {0   1   X}  <string> ::= "0xnnn" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:USB:TRIGger: HADDress <string> (see <a href="#">page 1180</a> )	:SBUS<n>:USB:TRIGger: HADDress? (see <a href="#">page 1180</a> )	<string> ::= "nnnnnn" where n ::= {0   1   X}  <string> ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:USB:TRIGger: PCHeck <string> (see <a href="#">page 1181</a> )	:SBUS<n>:USB:TRIGger: PCHeck? (see <a href="#">page 1181</a> )	<string> ::= "nnnn" where n ::= {0   1   X}  <string> ::= "0xn" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:USB:TRIGger: PID:DATA <pid> (see <a href="#">page 1182</a> )	:SBUS<n>:USB:TRIGger: PID:DATA? (see <a href="#">page 1182</a> )	<pid> ::= {DATA0   DATA1   DATA2   MDATA}

**Table 136** :SBUS<n>:USB Commands Summary (continued)

Command	Query	Options and Query Returns
:SBUS<n>:USB:TRIGger: PID:HAndshake <pid> (see <a href="#">page 1183</a> )	:SBUS<n>:USB:TRIGger: PID:HAndshake? (see <a href="#">page 1183</a> )	<pid> ::= {ACK   NAK   STALL   NYET}
:SBUS<n>:USB:TRIGger: PID:SPECial <pid> (see <a href="#">page 1184</a> )	:SBUS<n>:USB:TRIGger: PID:SPECIAL? (see <a href="#">page 1184</a> )	<pid> ::= {PING   PRE   ERR   SPLIt}
:SBUS<n>:USB:TRIGger: PID:TOKen <pid> (see <a href="#">page 1185</a> )	:SBUS<n>:USB:TRIGger: PID:TOKen? (see <a href="#">page 1185</a> )	<pid> ::= {OUT   IN   SETup   SOF}
:SBUS<n>:USB:TRIGger: PORT <string> (see <a href="#">page 1186</a> )	:SBUS<n>:USB:TRIGger: PORT? (see <a href="#">page 1186</a> )	<string> ::= "nnnnnnn" where n ::= {0   1   X}  <string> ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}
:SBUS<n>:USB:TRIGger: SC <string> (see <a href="#">page 1187</a> )	:SBUS<n>:USB:TRIGger: SC? (see <a href="#">page 1187</a> )	<string> ::= "n" where n ::= {0   1   X}  <string> ::= "0xn" where n ::= {0   1   X   \$}
:SBUS<n>:USB:TRIGger: SEU <string> (see <a href="#">page 1188</a> )	:SBUS<n>:USB:TRIGger: SEU? (see <a href="#">page 1188</a> )	<string> ::= "nn" where n ::= {0   1   X}  <string> ::= "0xn" where n ::= {0   1   2   3   X   \$}

## :SBUS<n>:USB:BASE

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:USB:BASE <base>

<base> ::= {ASCii | BINary | DECimal | HEX}

The :SBUS<n>:USB:BASE command determines the base to use for the USB decode and Lister display, controlling how the data or payload field is displayed.

All other fields are displayed in hex

**Query Syntax** :SBUS<n>:USB:BASE?

The :SBUS<n>:USB:BASE? query returns the currently specified base.

**Return Format** <base><NL>

<base> ::= {ASC | BIN | DEC | HEX}

## :SBUS<n>:USB:SOURce:DMINus

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:USB:SOURce:DMINus &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;} for DSO models</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;} for MSO models</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	The :SBUS<n>:USB:SOURce:DMINus command specifies which signal is used as the USB D- source for the selected bus.
	The D- source is only used for Low and Full Speed USB.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:USB:SOURce:DMINus?</code>
	The :SBUS<n>:USB:SOURce:DMINus? query returns the specified D- source.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
	<code>&lt;source&gt; ::= {CHAN&lt;n&gt;   DIG&lt;d&gt;}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":SBUS&lt;n&gt;:USB:SOURce:DPLus" on page 1169</a></li> <li>· <a href="#">":SBUS&lt;n&gt;:USB:SPEed" on page 1171</a></li> </ul>

## :SBUS<n>:USB:SOURce:DPLus

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:USB:SOURce:DPLus &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;} for DSO models</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;} for MSO models</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	The :SBUS<n>:USB:SOURce:DPLus command specifies which signal is used as the USB D+ source for the selected bus.
	The D+ source is only used for Low and Full Speed USB.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:USB:SOURce:DPLus?</code>
	The :SBUS<n>:USB:SOURce:DPLus? query returns the specified D+ source.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
	<code>&lt;source&gt; ::= {CHAN&lt;n&gt;   DIG&lt;d&gt;}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">:SBUS&lt;n&gt;:USB:SOURce:DMINus</a>" on page 1168</li> <li>• "<a href="#">:SBUS&lt;n&gt;:USB:SPEed</a>" on page 1171</li> </ul>

## :SBUS<n>:USB:SOURce:DIFFerential

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:USB:SOURce:DIFFerential <source>`  
`<source> ::= {CHANnel<n>}`  
`<n> ::= 1 to (# analog channels) in NR1 format`

The :SBUS<n>:USB:SOURce:DIFFerential command specifies which signal is used as the differential source for the selected bus.

Differential sources are only used for High Speed USB.

**Query Syntax**    `:SBUS<n>:USB:SOURce:DIFFerential?`

The :SBUS<n>:USB:SOURce:DIFFerential? query returns the specified differential source.

**Return Format**    `<source><NL>`  
`<source> ::= {CHAN<n>}`

**See Also**    • [":SBUS<n>:USB:SPEEd"](#) on page 1171

## :SBUS<n>:USB:SPEed

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:USB:SPEed <speed>`

`<speed> ::= {LOW | FULL | HIGH}`

The :SBUS<n>:USB:SPEed command specifies the speed of the USB interface for the selected bus.

**Query Syntax**    `:SBUS<n>:USB:SPEed?`

The :SBUS<n>:USB:SPEed? query returns the speed setting.

**Return Format**    `<speed><NL>`

`<speed> ::= {LOW | FULL | HIGH}`

**See Also**

- "[:SBUS<n>:USB:SOURce:DPLus](#)" on page 1169
- "[:SBUS<n>:USB:SOURce:DMINus](#)" on page 1168
- "[:SBUS<n>:USB:SOURce:DIFFerential](#)" on page 1170

## :SBUS<n>:USB:TRIGger

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:USB:TRIGger <condition>`

```
<condition> ::= {SOP | EOP | ENTersuspend | EXITsuspend | RESet
                  | TOKen | DATA | HANDshake | SPECIAL | ALLerrors
                  | PIDerror | CRC5error | CRC16error | GLITcherror
                  | STUFFerror | SE1error}
```

The :SBUS<n>:USB:TRIGger command specifies the USB trigger mode for the selected bus.

**Query Syntax**    `:SBUS<n>:USB:TRIGger?`

The :SBUS<n>:USB:TRIGger? query returns the specified USB trigger mode.

**Return Format**    `<condition><NL>`

```
<condition> ::= {SOP | EOP | ENT | EXIT | RES | TOK | DATA | HAND
                  | SPEC | ALL | PID | CRC5 | CRC16 | GLIT | STUFF
                  | SE1}
```

**See Also**

- "[":SBUS<n>:USB:TRIGger:PID:DATA](#)" on page 1182
- "[":SBUS<n>:USB:TRIGger:PID:HANDshake](#)" on page 1183
- "[":SBUS<n>:USB:TRIGger:PID:SPECIAL](#)" on page 1184
- "[":SBUS<n>:USB:TRIGger:PID:TOKen](#)" on page 1185

## :SBUS<n>:USB:TRIGger:ADDRess

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:USB:TRIGger:ADDRess &lt;string&gt;</code>
	<code>&lt;string&gt; ::= "nnnnnnn" where n ::= {0   1   x}</code>
	<code>&lt;string&gt; ::= "0xnn" where n ::= {0,...,9   A,...,F   x   \$}</code>
	The :SBUS<n>:USB:TRIGger:ADDRess command specifies the 7-bit Address portion of the trigger for the selected bus, in binary or hex.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:USB:TRIGger:ADDRess?</code>
	The :SBUS<n>:USB:TRIGger:ADDRess? query returns the specified Address portion of the trigger.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code>
	<code>&lt;string&gt; ::= "nnnnnnn" where n ::= {0   1   x}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">:SBUS&lt;n&gt;:USB:TRIGger:PID:SPECial</a>" on page 1184</li> <li>• "<a href="#">:SBUS&lt;n&gt;:USB:TRIGger:PID:TOken</a>" on page 1185</li> </ul>

## :SBUS<n>:USB:TRIGger:CRC

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:USB:TRIGger:CRC <string>`  
`<string> ::= "nnnnn" where n ::= {0 | 1 | x}`  
`<string> ::= "0xnn" where n ::= {0,...,9 | A,...,F | x | $}`  
The :SBUS<n>:USB:TRIGger:CRC command specifies the CRC portion of the trigger for the selected bus, in binary or hex.

**Query Syntax**    `:SBUS<n>:USB:TRIGger:CRC?`

The :SBUS<n>:USB:TRIGger:CRC? query returns the specified CRC portion of the trigger.

**Return Format**    `<string><NL>`  
`<string> ::= "nnnnn" where n ::= {0 | 1 | x}`

**See Also**

- [":SBUS<n>:USB:TRIGger:PID:SPECial" on page 1184](#)
- [":SBUS<n>:USB:TRIGger:PID:TOKen" on page 1185](#)

## :SBUS<n>:USB:TRIGger:DATA

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:USB:TRIGger:DATA &lt;string&gt;</code>
	<code>&lt;string&gt; ::= "nnnn..." where n ::= {0   1   X}</code>
	<code>&lt;string&gt; ::= "0xn..." where n ::= {0,...,9   A,...,F   X   \$}</code>
	The :SBUS<n>:USB:TRIGger:DATA command specifies the Data portion of the trigger for the selected bus, in binary or hex.
	See the :SBUS<n>:USB:TRIGger:DATA:LENGth command for setting the length of the data value.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:USB:TRIGger:DATA?</code>
	The :SBUS<n>:USB:TRIGger:DATA? query returns the specified Data portion of the trigger.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code>
	<code>&lt;string&gt; ::= "nnnn..." where n ::= {0   1   X}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":SBUS&lt;n&gt;:USB:TRIGger:DATA:LENGth" on page 1176</a></li> </ul>

## :SBUS<n>:USB:TRIGger:DATA:LENGth

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:USB:TRIGger:DATA:LENGth <length>`  
                  `<length> ::= data length between 1-20`

The :SBUS<n>:USB:TRIGger:DATA:LENGth command specifies the data length in bytes.

**Query Syntax**    `:SBUS<n>:USB:TRIGger:DATA:LENGth?`

The :SBUS<n>:USB:TRIGger:DATA:LENGth? query returns the specified data length.

**Return Format**    `<length><NL>`  
                  `<length> ::= data length between 1-20`

**See Also**    · [":SBUS<n>:USB:TRIGger:DATA"](#) on page 1175

## :SBUS<n>:USB:TRIGger:ENDPoint

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:USB:TRIGger:ENDPoint &lt;string&gt;</code>
	<code>&lt;string&gt; ::= "nnnn" where n ::= {0   1   x}</code>
	<code>&lt;string&gt; ::= "0xn" where n ::= {0,...,9   A,...,F   x   \$}</code>
	The :SBUS<n>:USB:TRIGger:ENDPoint command specifies the 4-bit Endpoint portion of the trigger for the selected bus, in binary or hex.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:USB:TRIGger:ENDPoint?</code>
	The :SBUS<n>:USB:TRIGger:ENDPoint? query returns the specified Endpoint portion of the trigger.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code>
	<code>&lt;string&gt; ::= "nnnn" where n ::= {0   1   x}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">:SBUS&lt;n&gt;:USB:TRIGger:PID:SPECial</a>" on page 1184</li> <li>• "<a href="#">:SBUS&lt;n&gt;:USB:TRIGger:PID:TOKen</a>" on page 1185</li> </ul>

## :SBUS<n>:USB:TRIGger:ET

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:USB:TRIGger:ET <string>`

`<string> ::= "nn" where n ::= {0 | 1 | x}`

`<string> ::= "0xn" where n ::= {0 | 1 | 2 | 3 | x | $}`

The :SBUS<n>:USB:TRIGger:ET command specifies the 2-bit ET portion of the trigger for the selected bus, in binary or hex.

**Query Syntax**    `:SBUS<n>:USB:TRIGger:ET?`

The :SBUS<n>:USB:TRIGger:ET? query returns the specified ET portion of the trigger.

**Return Format**    `<string><NL>`

`<string> ::= "nn" where n ::= {0 | 1 | x}`

**See Also**    • [":SBUS<n>:USB:TRIGger:PID:SPECial"](#) on page 1184

## :SBUS<n>:USB:TRIGger:FRAMe

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:USB:TRIGger:FRAMe &lt;string&gt;</code>
	<code>&lt;string&gt; ::= "nnnnnnnnnnn" where n ::= {0   1   X}</code>
	<code>&lt;string&gt; ::= "0xnnn" where n ::= {0,...,9   A,...,F   x   \$}</code>
	The :SBUS<n>:USB:TRIGger:FRAMe command specifies the 11-bit Frame portion of the trigger for the selected bus, in binary or hex.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:USB:TRIGger:FRAMe?</code>
	The :SBUS<n>:USB:TRIGger:FRAMe? query returns the specified Frame portion of the trigger.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code>
	<code>&lt;string&gt; ::= "nnnnnnnnnnn" where n ::= {0   1   X}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":SBUS&lt;n&gt;:USB:TRIGger:PID:TOKen"</a> on page 1185</li> </ul>

## :SBUS<n>:USB:TRIGger:HADDress

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:USB:TRIGger:HADDress &lt;string&gt;</code>
	<code>&lt;string&gt; ::= "nnnnnnn" where n ::= {0   1   x}</code>
	<code>&lt;string&gt; ::= "0xnn" where n ::= {0,...,9   A,...,F   x   \$}</code>
	The :SBUS<n>:USB:TRIGger:HADDress command specifies the 7-bit Hub Address portion of the trigger for the selected bus, in binary or hex.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:USB:TRIGger:HADDress?</code>
	The :SBUS<n>:USB:TRIGger:HADDress? query returns the specified Hub Address portion of the trigger.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code>
	<code>&lt;string&gt; ::= "nnnnnnn" where n ::= {0   1   x}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":SBUS&lt;n&gt;:USB:TRIGger:PID:SPECial" on page 1184</a></li></ul>

## :SBUS<n>:USB:TRIGger:PCheck

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:USB:TRIGger:PCheck &lt;string&gt;</code>
	<code>&lt;string&gt; ::= "nnnn" where n ::= {0   1   X}</code>
	<code>&lt;string&gt; ::= "0xn" where n ::= {0,...,9   A,...,F   x   \$}</code>
	The :SBUS<n>:USB:TRIGger:PCheck command specifies the 4-bit PID check portion of the trigger for the selected bus, in binary or hex.
	See the :SBUS<n>:USB:TRIGger:PID commands for setting the PID.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:USB:TRIGger:PCheck?</code>
	The :SBUS<n>:USB:TRIGger:PCheck? query returns the specified PID check portion of the trigger.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code>
	<code>&lt;string&gt; ::= "nnnn" where n ::= {0   1   X}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">:SBUS&lt;n&gt;:USB:TRIGger:PID:DATA</a>" on page 1182</li> <li>• "<a href="#">:SBUS&lt;n&gt;:USB:TRIGger:PID:HANDshake</a>" on page 1183</li> <li>• "<a href="#">:SBUS&lt;n&gt;:USB:TRIGger:PID:SPECial</a>" on page 1184</li> <li>• "<a href="#">:SBUS&lt;n&gt;:USB:TRIGger:PID:TOken</a>" on page 1185</li> </ul>

## :SBUS<n>:USB:TRIGger:PID:DATA

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:USB:TRIGger:PID:DATA <pid>`

`<pid> ::= {DATA0 | DATA1 | DATA2 | MDATA}`

The :SBUS<n>:USB:TRIGger:PID:DATA command specifies the USB data PID to trigger on for the selected bus.

The specified PID does not include the PID check value, which is specified using the :SBUS<n>:USB:TRIGger:PIDCheck command.

The DATA USB trigger mode can be selected using the :SBUS<n>:USB:TRIGger command.

**Query Syntax**    `:SBUS<n>:USB:TRIGger:PID:DATA?`

The :SBUS<n>:USB:TRIGger:PID:DATA? query returns the specified data PID.

**Return Format**    `<pid><NL>`

`<pid> ::= {DATA0 | DATA1 | DATA2 | MDAT}`

**See Also**

- "[":SBUS<n>:USB:TRIGger:PCheck](#)" on page 1181
- "[":SBUS<n>:USB:TRIGger](#)" on page 1172

## :SBUS<n>:USB:TRIGger:PID:HANDshake

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:USB:TRIGger:PID:HANDshake <pid>`  
`<pid> ::= {ACK | NAK | STALL | NYET}`

The :SBUS<n>:USB:TRIGger:PID:HANDshake command specifies the USB handshake PID to trigger on for the selected bus.

The specified PID does not include the PID check value, which is specified using the :SBUS<n>:USB:TRIGger:PIDCheck command.

The HANDshake USB trigger mode can be selected using the :SBUS<n>:USB:TRIGger command.

**Query Syntax**    `:SBUS<n>:USB:TRIGger:PID:HANDshake?`

The :SBUS<n>:USB:TRIGger:PID:HANDshake? query returns the specified handshake PID.

**Return Format**    `<pid><NL>`  
`<pid> ::= {ACK | NAK | STAL | NYET}`

**See Also**

- "[:SBUS<n>:USB:TRIGger:PCheck](#)" on page 1181
- "[:SBUS<n>:USB:TRIGger](#)" on page 1172

## :SBUS<n>:USB:TRIGger:PID:SPECial

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:USB:TRIGger:PID:SPECial <pid>`

`<pid> ::= {PING | PRE | ERR | SPL}`

The :SBUS<n>:USB:TRIGger:PID:SPECial command specifies the USB special PID to trigger on for the selected bus.

The specified PID does not include the PID check value, which is specified using the :SBUS<n>:USB:TRIGger:PIDCheck command.

The SPECial USB trigger mode can be selected using the :SBUS<n>:USB:TRIGger command.

**Query Syntax**    `:SBUS<n>:USB:TRIGger:PID:SPECial?`

The :SBUS<n>:USB:TRIGger:PID:SPECial? query returns the specified special PID.

**Return Format**    `<pid><NL>`

`<pid> ::= {PING | PRE | ERR | SPL}`

**See Also**

- "[":SBUS<n>:USB:TRIGger:PCheck](#)" on page 1181
- "[":SBUS<n>:USB:TRIGger](#)" on page 1172

## :SBUS<n>:USB:TRIGger:PID:TOKen

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:USB:TRIGger:PID:TOKen <pid>

<pid> ::= {OUT | IN | SETup | SOF}

The :SBUS<n>:USB:TRIGger:PID:TOKen command specifies the USB token PID to trigger on for the selected bus.

The specified PID does not include the PID check value, which is specified using the :SBUS<n>:USB:TRIGger:PIDCheck command.

The TOKen USB trigger mode can be selected using the :SBUS<n>:USB:TRIGger command.

**Query Syntax** :SBUS<n>:USB:TRIGger:PID:TOKen?

The :SBUS<n>:USB:TRIGger:PID:TOKen? query returns the specified token PID.

**Return Format** <pid><NL>

<pid> ::= {OUT | IN | SETup | SOF}

**See Also**

- "[:SBUS<n>:USB:TRIGger:PCheck](#)" on page 1181
- "[:SBUS<n>:USB:TRIGger](#)" on page 1172

## :SBUS<n>:USB:TRIGger:PORT

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:USB:TRIGger:PORT <string>`

`<string> ::= "nnnnnnn" where n ::= {0 | 1 | x}`

`<string> ::= "0xnn" where n ::= {0,...,9 | A,...,F | x | $}`

The :SBUS<n>:USB:TRIGger:PORT command specifies the 7-bit Port portion of the trigger for the selected bus, in binary or hex.

**Query Syntax**    `:SBUS<n>:USB:TRIGger:PORT?`

The :SBUS<n>:USB:TRIGger:PORT? query returns the specified Port portion of the trigger.

**Return Format**    `<string><NL>`

`<string> ::= "nnnnnnn" where n ::= {0 | 1 | x}`

**See Also**    • [":SBUS<n>:USB:TRIGger:PID:SPECial"](#) on page 1184

## :SBUS<n>:USB:TRIGger:SC

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:USB:TRIGger:SC &lt;string&gt;</code>
	<code>&lt;string&gt; ::= "n" where n ::= {0   1   x}</code>
	<code>&lt;string&gt; ::= "0xn" where n ::= {0   1   x   \$}</code>
	The :SBUS<n>:USB:TRIGger:SC command specifies the 1-bit SC portion of the trigger for the selected bus, in binary or hex.
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:USB:TRIGger:SC?</code>
	The :SBUS<n>:USB:TRIGger:SC? query returns the specified SC portion of the trigger.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code>
	<code>&lt;string&gt; ::= "nnnn" where n ::= {0   1   x}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">":SBUS&lt;n&gt;:USB:TRIGger:PID:SPECial" on page 1184</a></li> </ul>

## :SBUS<n>:USB:TRIGger:SEU

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:USB:TRIGger:SEU <string>`

`<string> ::= "nn" where n ::= {0 | 1 | x}`

`<string> ::= "0xn" where n ::= {0 | 1 | 2 | 3 | x | $}`

The :SBUS<n>:USB:TRIGger:SEU command specifies the 2-bit S and E or U portion of the trigger for the selected bus, in binary or hex.

**Query Syntax**    `:SBUS<n>:USB:TRIGger:SEU?`

The :SBUS<n>:USB:TRIGger:SEU? query returns the specified S and E or U portion of the trigger.

**Return Format**    `<string><NL>`

`<string> ::= "nn" where n ::= {0 | 1 | x}`

**See Also**    • [":SBUS<n>:USB:TRIGger:PID:SPECial"](#) on page 1184

## :SBUS<n>:USBPd Commands

**NOTE**

These commands are valid when the USB PD (Power Delivery) serial decode and triggering option has been licensed.

**Table 137** :SBUS<n>:USBPd Commands Summary

Command	Query	Options and Query Returns
:SBUS<n>:USBPd:SOURce <source> (see page 1190)	:SBUS<n>:USBPd:SOURce ? (see <a href="#">page 1190</a> )	<source> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format
:SBUS<n>:USBPd:TRIGger <mode> (see page 1191)	:SBUS<n>:USBPd:TRIGger? (see <a href="#">page 1191</a> )	<mode> ::= {PSTart   EOP   SOP   SPRime   SDPRime   SPDebug   SDPDebug   HRST   CRST   CRCerror   PERRor   HEADer}
:SBUS<n>:USBPd:TRIGger:HEADer <type> (see page 1192)	:SBUS<n>:USBPd:TRIGger:HEADer? (see <a href="#">page 1192</a> )	<type> ::= {CMESsage   DMEssage   EMESsage   VALue}
:SBUS<n>:USBPd:TRIGger:HEADer:CMESsage <type> (see page 1194)	:SBUS<n>:USBPd:TRIGger:HEADer:CMESsage? (see <a href="#">page 1194</a> )	<type> ::= {GOODcrc   GOTomin   ACCEpt   REJECT   PING   PSRDy   GSRCap   GSNCap   DRSSwap   PRSSwap   VCSswap   WAIT   SRST   GSCX   GSTatus   FRSswap   GPSTatus   GCCodes}
:SBUS<n>:USBPd:TRIGger:HEADer:DMEssage <type> (see page 1196)	:SBUS<n>:USBPd:TRIGger:HEADer:DMEssage? (see <a href="#">page 1196</a> )	<type> ::= {SRCap   REQuest   BIST   SNCap   BSTatus   ALERt   GCInfo   VDEFINED}
:SBUS<n>:USBPd:TRIGger:HEADer:EMESsage <type> (see page 1197)	:SBUS<n>:USBPd:TRIGger:HEADer:EMESsage? (see <a href="#">page 1197</a> )	<type> ::= {SCX   STATus   GBCap   GBStatus   BCAP   GMInfo   MINfo   SREQuest   SRESPonse   FREQuest   FREResponse   PSTatus   CINFO   CCODEs}
:SBUS<n>:USBPd:TRIGger:HEADer:VALue <string> (see page 1199)	:SBUS<n>:USBPd:TRIGger:HEADer:VALue? (see <a href="#">page 1199</a> )	<string> ::= "nn...n" where n ::= {0   1   X} <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X}
:SBUS<n>:USBPd:TRIGger:HEADer:QUALifier <type> (see page 1200)	:SBUS<n>:USBPd:TRIGger:HEADer:QUALifier? (see <a href="#">page 1200</a> )	<type> ::= {NONE   SOP   SPRime   SDPRime}

## :SBUS<n>:USBPd:SOURce

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:USBPd:SOURce <source>`

```
<source> ::= {CHANnel<n>}
<n> ::= 1 to (# analog channels) in NR1 format
```

The :SBUS<n>:USBPd:SOURce command selects the USB PD waveform source. You can use analog channels.

**Query Syntax**    `:SBUS<n>:USBPd:SOURce?`

The :SBUS<n>:USBPd:SOURce? query returns the selected analog input channel.

**Return Format**    `<source><NL>`

```
<source> ::= {CHAN<n>}
```

**See Also**

- "[":SBUS<n>:USBPd:TRIGger](#)" on page 1191
- "[":SBUS<n>:USBPd:TRIGger:HEADER](#)" on page 1192
- "[":SBUS<n>:USBPd:TRIGger:HEADER:CMESSAGE](#)" on page 1194
- "[":SBUS<n>:USBPd:TRIGger:HEADER:DMESSAGE](#)" on page 1196
- "[":SBUS<n>:USBPd:TRIGger:HEADER:EMESSAGE](#)" on page 1197
- "[":SBUS<n>:USBPd:TRIGger:HEADER:VALUe](#)" on page 1199
- "[":SBUS<n>:USBPd:TRIGger:HEADER:QUALifier](#)" on page 1200

## :SBUS<n>:USBPd:TRIGger

**N** (see [page 1666](#))

**Command Syntax** :SBUS<n>:USBPd:TRIGger <mode>  
 <mode> ::= {PSTArt | EOP | SOP | SPRime | SDPRime | SPDebug | SDPDebug  
 | HRST | CRST | CRCerror | PERRor | HEADer}

The :SBUS<n>:USBPd:TRIGger command selects the USB PD trigger mode:

- PSTArt – **Preamble Start**, triggers at the start of a preamble, which starts with 0.
- EOP – **EOP**, triggers at the end of packet.
- SOP – **SOP**, triggers on ordered set Sync-1, Sync-1, Sync-1, Sync-2.
- SPRime – **SOP<sup>1</sup>**, triggers on ordered set Sync-1, Sync-1, Sync-3, Sync-3.
- SDPRime – **SOP<sup>2</sup>**, triggers on ordered set Sync-1, Sync-3, Sync-1, Sync-3.
- SPDebug – **SOP<sup>1</sup> Debug**, triggers on ordered set Sync-1, RST-2, RST-2, Sync-3.
- SDPDebug – **SOP<sup>2</sup> Debug**, triggers on ordered set Sync-1, RST-2, Sync-3, Sync-2.
- HRST – **Hard Reset**, triggers on ordered set RST-1, RST-1, RST-1, RST-2.
- CRST – **Cable Reset**, triggers on ordered set RST-1, Sync-1, RST-1, Sync-3.
- CRCerror – **CRC Error**, triggers when an error is detected on a 32-bit CRC.
- PERRor – **Preamble Error**, triggers when an error is detected on a 64-bit sequence of alternating 0 and 1.
- HEADer – **Header Content**, triggers on a user-defined 16-bit value.

In this mode, use the :SBUS<n>:USBPd:TRIGger:HEADer command to select the header type.

**Query Syntax** :SBUS<n>:USBPd:TRIGger?

The :SBUS<n>:USBPd:TRIGger? query returns the selected USB PD trigger mode.

**Return Format** <mode><NL>  
 <mode> ::= {PST | EOP | SOP | SPR | SDPR | SPD | SDPD | HRST | CRST  
 | CRC | PERR | HEAD}

**See Also**

- "[:SBUS<n>:USBPd:SOURce](#)" on page 1190
- "[:SBUS<n>:USBPd:TRIGger:HEADer](#)" on page 1192
- "[:SBUS<n>:USBPd:TRIGger:HEADer:CMESSage](#)" on page 1194
- "[:SBUS<n>:USBPd:TRIGger:HEADer:DMESSage](#)" on page 1196
- "[:SBUS<n>:USBPd:TRIGger:HEADer:EMESSage](#)" on page 1197
- "[:SBUS<n>:USBPd:TRIGger:HEADer:VALue](#)" on page 1199
- "[:SBUS<n>:USBPd:TRIGger:HEADer:QUALifier](#)" on page 1200

## :SBUS<n>:USBPd:TRIGger:HEADer

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer &lt;type&gt;</code> <code>&lt;type&gt; ::= {CMESsage   DMESsage   EMESsage   VALue}</code>
	When the <b>Header Content</b> trigger mode is selected (with the " <code>:SBUS&lt;n&gt;:USBPd:TRIGger HEADer</code> " command), the <code>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer</code> command selects the header type:
	<ul style="list-style-type: none"> <li>• CMESsage – <b>Control Message</b>, triggers on control message types (0 data object).            When the CMESsage header type is selected, use the <code>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:CMESsage</code> command to select the control message type.</li> <li>• DMESsage – <b>Data Message</b>, triggers on data message types (1 or more data objects).            When the DMESsage header type is selected, use the <code>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:DMESsage</code> command to select the data message type.</li> <li>• EMESsage – <b>Extended Message</b>, triggers on extended message types (bit 15 is set).            When the EMESsage header type is selected, use the <code>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:EMESsage</code> command to select the extended message type.</li> <li>• VALue – <b>Value</b>, triggers on a user-defined header value.            When the CMESsage header type is selected, use the <code>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:VALue</code> command to specify the user-defined header value.</li> </ul>
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer?</code>
	The <code>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer?</code> query returns the selected header type.
<b>Return Format</b>	<code>&lt;type&gt;&lt;NL&gt;</code> <code>&lt;type&gt; ::= {CMES   DMES   EMES   VAL}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">:SBUS&lt;n&gt;:USBPd:SOURce</a>" on page 1190</li> <li>• "<a href="#">:SBUS&lt;n&gt;:USBPd:TRIGger</a>" on page 1191</li> <li>• "<a href="#">:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:CMESsage</a>" on page 1194</li> <li>• "<a href="#">:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:DMESsage</a>" on page 1196</li> <li>• "<a href="#">:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:EMESsage</a>" on page 1197</li> <li>• "<a href="#">:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:VALue</a>" on page 1199</li> </ul>

- "[:SBUS<n>:USBPd:TRIGger:HEADer:QUALifier](#)" on page 1200

## :SBUS<n>:USBPd:TRIGger:HEADER:CMESSage

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADER:CMESSage &lt;type&gt;</code>
	<pre>&lt;type&gt; ::= {GOODcrc   GOT0min   ACCept   REJect   PING   PSRDy               GSRCap   GSNCap   DRSSwap   PRSWap   VCSswap   WAIT   SRST   GSCX               GSTatus   FRSwap   GPSTatus   GCCodes}</pre>
	<p>When the <b>Header Content</b> trigger mode is selected (with the ":SBUS&lt;n&gt;:USBPd:TRIGger HEADER" command) and the <b>Control Message</b> header type is selected (with the ":SBUS&lt;n&gt;:USBPd:TRIGger:HEADER CMESSage" command), the :SBUS&lt;n&gt;:USBPd:TRIGger:HEADER:CMESSage command selects the control message type:</p> <ul style="list-style-type: none"> <li>· GOODcrc – GoodCRC</li> <li>· GOT0min – GotoMin</li> <li>· ACCept – Accept</li> <li>· REJect – Reject</li> <li>· PING – Ping</li> <li>· PSRDy – PS_RDY</li> <li>· GSRCap – Get_Source_Cap</li> <li>· GSNCap – Get_Sink_Cap</li> <li>· DRSSwap – DR_Swap</li> <li>· PRSWap – PR_Swap</li> <li>· VCSswap – VCONN_Swap</li> <li>· WAIT – Wait</li> <li>· SRST – Soft_Reset</li> <li>· GSCX – Get_Source_Cap_Extended</li> <li>· GSTatus – Get_Status</li> <li>· FRSwap – FR_Swap</li> <li>· GPSTatus – Get_PPS_Status</li> <li>· GCCodes – Get_Country_Codes</li> </ul>
<b>Query Syntax</b>	<code>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADER:CMESSage?</code>
	<p>The :SBUS&lt;n&gt;:USBPd:TRIGger:HEADER:CMESSage? query returns the selected control message type.</p>
<b>Return Format</b>	<code>&lt;type&gt;&lt;NL&gt;</code> <pre>&lt;type&gt; ::= {GOOD   GOTO   ACC   REJ   PING   PSRD   GSRC   GSNC   DRSSW               PRSW   VCSW   WAIT   SRST   GSCX   GST   FRSW   GPST   GCC}</pre>

**See Also**

- "[:SBUS<n>:USBPd:SOURce](#)" on page 1190
- "[:SBUS<n>:USBPd:TRIGger](#)" on page 1191
- "[:SBUS<n>:USBPd:TRIGger:HEADer](#)" on page 1192
- "[:SBUS<n>:USBPd:TRIGger:HEADer:DMESsage](#)" on page 1196
- "[:SBUS<n>:USBPd:TRIGger:HEADer:EMESsage](#)" on page 1197
- "[:SBUS<n>:USBPd:TRIGger:HEADer:VALue](#)" on page 1199
- "[:SBUS<n>:USBPd:TRIGger:HEADer:QUALifier](#)" on page 1200

## :SBUS<n>:USBPd:TRIGger:HEADer:DMESSage

**N** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:USBPd:TRIGger:HEADer:DMESSage <type>`  
`<type> ::= {SRCap | REQuest | BIST | SNCap | BSTatus | ALERt | GCInfo  
| VDEFined}`

When the **Header Content** trigger mode is selected (with the "`:SBUS<n>:USBPd:TRIGger HEADer`" command) and the **Data Message** header type is selected (with the "`:SBUS<n>:USBPd:TRIGger:HEADer DMESSage`" command), the `:SBUS<n>:USBPd:TRIGger:HEADer:DMESSage` command selects the data message type:

- SRCap – Source\_Capabilities
- REQuest – Request
- BIST – BIST
- SNCap – Sink\_Capabilities
- BSTatus – Battery\_Status
- ALERt – Alert
- GCInfo – Get\_Country\_Info
- VDEFined – Vendor Defined

**Query Syntax**    `:SBUS<n>:USBPd:TRIGger:HEADer:DMESSage?`

The `:SBUS<n>:USBPd:TRIGger:HEADer:DMESSage?` query returns the selected data message type.

**Return Format**    `<type><NL>`  
`<type> ::= {SRC | REQ | BIST | SNC | BST | ALER | GCIN | VDEF}`

**See Also**    [":SBUS<n>:USBPd:SOURce"](#) on page 1190  
[":SBUS<n>:USBPd:TRIGger"](#) on page 1191  
[":SBUS<n>:USBPd:TRIGger:HEADer"](#) on page 1192  
[":SBUS<n>:USBPd:TRIGger:HEADer:CMESsage"](#) on page 1194  
[":SBUS<n>:USBPd:TRIGger:HEADer:EMESsage"](#) on page 1197  
[":SBUS<n>:USBPd:TRIGger:HEADer:VALue"](#) on page 1199  
[":SBUS<n>:USBPd:TRIGger:HEADer:QUALifier"](#) on page 1200

## :SBUS<n>:USBPd:TRIGger:HEADER:EMESsage

**N** (see [page 1666](#))

### Command Syntax

```
:SBUS<n>:USBPd:TRIGger:HEADER:EMESsage <type>
<type> ::= {SCX | STATus | GBCap | GBSTatus | BCAP | GMINfo | MINFo
             | SREQuest | SRESponse | FREQuest | FRESponse | PSTatus | CINFO
             | CCODEs}
```

When the **Header Content** trigger mode is selected (with the ":SBUS<n>:USBPd:TRIGger HEADER" command) and the **Extended Message** header type is selected (with the ":SBUS<n>:USBPd:TRIGger:HEADER EMESsage" command), the :SBUS<n>:USBPd:TRIGger:HEADER:EMESsage command selects the extended message type:

- SCX – Source\_Capabilities\_Extended
- STATus – Status
- GBCap – Get\_Battery\_Cap
- GBSTatus – Get\_Battery\_Status
- BCAP – Battery\_Capabilities
- GMINfo – Get\_Manufacturer\_Info
- MINFo – Manufacturer\_Info
- SREQuest – Security\_Request
- SRESponse – Security\_Response
- FREQuest – Firmware\_Update\_Request
- FRESponse – Firmware\_Update\_Response
- PSTatus – PPS\_Status
- CINFO – Country\_Info
- CCODEs – Country\_Codes

### Query Syntax

```
:SBUS<n>:USBPd:TRIGger:HEADER:EMESsage?
```

The :SBUS<n>:USBPd:TRIGger:HEADER:EMESsage? query returns the selected extended message type

### Return Format

```
<type><NL>
<type> ::= {SCX | STATus | GBC | GBST | BCAP | GMIN | MINF | SREQ
             | SRES | FREQ | FRES | PSTatus | CINF | CCOD}
```

### See Also

- "[":SBUS<n>:USBPd:SOURce](#)" on page 1190
- "[":SBUS<n>:USBPd:TRIGger](#)" on page 1191
- "[":SBUS<n>:USBPd:TRIGger:HEADER](#)" on page 1192
- "[":SBUS<n>:USBPd:TRIGger:HEADER:CMESsage](#)" on page 1194

- "[:SBUS<n>:USBPd:TRIGger:HEADer:DMESsage](#)" on page 1196
- "[:SBUS<n>:USBPd:TRIGger:HEADer:VALue](#)" on page 1199
- "[:SBUS<n>:USBPd:TRIGger:HEADer:QUALifier](#)" on page 1200

## :SBUS<n>:USBPd:TRIGger:HEADer:VALue

**N** (see [page 1666](#))

Command Syntax	<pre>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:VALue &lt;string&gt; &lt;string&gt; ::= "nn...n" where n ::= {0   1   x} &lt;string&gt; ::= "0xnn...n" where n ::= {0,...,9   A,...,F   x}</pre>
	When the <b>Header Content</b> trigger mode is selected (with the " <code>:SBUS&lt;n&gt;:USBPd:TRIGger HEADer</code> " command) and the user-defined <b>Value</b> type is selected (with the " <code>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer VALue</code> " command), the <code>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:VALue</code> command specifies the user-defined header value.
Query Syntax	<pre>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:VALue?</pre>
	The <code>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:VALue?</code> query returns the specified user-defined header value.
	Returned data values are always quoted binary format strings.
Return Format	<pre>&lt;string&gt;&lt;NL&gt; &lt;string&gt; ::= "nn...n" where n ::= {0   1   x}</pre>
See Also	<ul style="list-style-type: none"> <li>• <a href="#">":SBUS&lt;n&gt;:USBPd:SOURce"</a> on page 1190</li> <li>• <a href="#">":SBUS&lt;n&gt;:USBPd:TRIGger"</a> on page 1191</li> <li>• <a href="#">":SBUS&lt;n&gt;:USBPd:TRIGger:HEADer"</a> on page 1192</li> <li>• <a href="#">":SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:CMESsage"</a> on page 1194</li> <li>• <a href="#">":SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:DMESsage"</a> on page 1196</li> <li>• <a href="#">":SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:EMESsage"</a> on page 1197</li> <li>• <a href="#">":SBUS&lt;n&gt;:USBPd:TRIGger:HEADer:QUALifier"</a> on page 1200</li> </ul>

## :SBUS<n>:USBPd:TRIGger:HEADER:QUALifier

**N** (see [page 1666](#))

Command Syntax	<code>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADER:QUALifier &lt;type&gt;</code>
	<code>&lt;type&gt; ::= {NONE   SOP   SPRime   SDPRime}</code>
	When the <b>Header Content</b> trigger mode is selected (with the ".:SBUS<n>:USBPd:TRIGger HEADER" command), the :SBUS<n>:USBPd:TRIGger:HEADER:QUALifier command selects an additional qualifier for the Header Content trigger:
	<ul style="list-style-type: none"> <li>• NONE – <b>None</b>. There is no additional qualifier for the trigger.</li> <li>• SOP – <b>SOP</b>. The trigger occurs on Sync-1, Sync-1, Sync-1, Sync-2 ordered sets only.</li> <li>• SPRime – <b>SOP'</b>. The trigger occurs on Sync-1, Sync-1, Sync-3, Sync-3 ordered sets only.</li> <li>• SDPRime – <b>SOP''</b>. The trigger occurs on Sync-1, Sync-3, Sync-1, Sync-3 ordered sets only.</li> </ul>
Query Syntax	<code>:SBUS&lt;n&gt;:USBPd:TRIGger:HEADER:QUALifier?</code>
	The :SBUS<n>:USBPd:TRIGger:HEADER:QUALifier? query returns the selected header content trigger qualifier.
Return Format	<code>&lt;type&gt;&lt;NL&gt;</code> <code>&lt;type&gt; ::= {NONE   SOP   SPRime   SDPRime}</code>
See Also	<ul style="list-style-type: none"> <li>• "<a href="#">":SBUS&lt;n&gt;:USBPd:SOURce</a>" on page 1190</li> <li>• "<a href="#">":SBUS&lt;n&gt;:USBPd:TRIGger</a>" on page 1191</li> <li>• "<a href="#">":SBUS&lt;n&gt;:USBPd:TRIGger:HEADER</a>" on page 1192</li> <li>• "<a href="#">":SBUS&lt;n&gt;:USBPd:TRIGger:HEADER:CMESsage</a>" on page 1194</li> <li>• "<a href="#">":SBUS&lt;n&gt;:USBPd:TRIGger:HEADER:DMESsage</a>" on page 1196</li> <li>• "<a href="#">":SBUS&lt;n&gt;:USBPd:TRIGger:HEADER:EMESsage</a>" on page 1197</li> <li>• "<a href="#">":SBUS&lt;n&gt;:USBPd:TRIGger:HEADER:VALue</a>" on page 1199</li> </ul>

## 34 :SEARch Commands

Control the event search modes and parameters for each search type. See:

- "[General :SEARch Commands](#)" on page 1202
- "[:SEARch:EDGE Commands](#)" on page 1207
- "[:SEARch:GLITch Commands](#)" on page 1210 (Pulse Width search)
- "[:SEARch:PEAK Commands](#)" on page 1217
- "[:SEARch:RUNT Commands](#)" on page 1222
- "[:SEARch:TRANSition Commands](#)" on page 1227
- "[:SEARch:SERial:A429 Commands](#)" on page 1232
- "[:SEARch:SERial:CAN Commands](#)" on page 1238
- "[:SEARch:SERial:FLEXray Commands](#)" on page 1248
- "[:SEARch:SERial:I2S Commands](#)" on page 1254
- "[:SEARch:SERial:IIC Commands](#)" on page 1260
- "[:SEARch:SERial:LIN Commands](#)" on page 1267
- "[:SEARch:SERial:M1553 Commands](#)" on page 1276
- "[:SEARch:SERial:SENT Commands](#)" on page 1280
- "[:SEARch:SERial:SPI Commands](#)" on page 1285
- "[:SEARch:SERial:UART Commands](#)" on page 1289
- "[:SEARch:SERial:USB Commands](#)" on page 1293

## General :SEARch Commands

**Table 138** General :SEARch Commands Summary

Command	Query	Options and Query Returns
n/a	:SEARch:COUNT? (see page 1203)	<count> ::= an integer count value
:SEARch:EVENT <event_number> (see page 1204)	:SEARch:EVENT? (see page 1204)	<event_number> ::= the integer number of a found search event
:SEARch:MODE <value> (see page 1205)	:SEARch:MODE? (see page 1205)	<value> ::= {EDGE   GLITch   RUNT   TRANSition   SERial{1   2}   PEAK}
:SEARch:STATE <value> (see page 1206)	:SEARch:STATE? (see page 1206)	<value> ::= {{0   OFF}   {1   ON}}

## :SEARch:COUNT

**N** (see [page 1666](#))

**Query Syntax** `:SEARch:COUNT?`

The `:SEARch:COUNT?` query returns the number of search events found.

**Return Format** `<count><NL>`

`<count>` ::= an integer count value

- See Also**
- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
  - [":SEARch:EVENT"](#) on page 1204
  - [":SEARch:STATe"](#) on page 1206
  - [":SEARch:MODE"](#) on page 1205

## :SEARch:EVENT

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:EVENT &lt;event_number&gt;</code>  <code>&lt;event_number&gt; ::= the integer number of a found search event</code>
The :SEARch:EVENT command navigates to a found search event.	
	If the :SEARch:STATe is ON, the horizontal position is changed so that the specified event is located at the time reference.
<b>Query Syntax</b>	<code>:SEARch:EVENT?</code>
	The :SEARch:EVENT? query returns the currently selected event number.
<b>Return Format</b>	<code>&lt;event_number&gt;&lt;NL&gt;</code>  <code>&lt;event_number&gt; ::= the integer number of a found search event</code>
<b>See Also</b>	<ul style="list-style-type: none"><li>• <a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li><li>• <a href="#">":SEARch:COUNt"</a> on page 1203</li><li>• <a href="#">":SEARch:STATe"</a> on page 1206</li><li>• <a href="#">":SEARch:MODE"</a> on page 1205</li></ul>

## :SEARch:MODE

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:MODE &lt;value&gt;</code> <code>&lt;value&gt; ::= {EDGE   GLITch   RUNT   TRANSition   SERial{1   2}   PEAK}</code>
	The :SEARch:MODE command selects the search mode.
	The command is only valid when the :SEARch:STATe is ON.
<b>Query Syntax</b>	<code>:SEARch:MODE?</code>
	The :SEARch:MODE? query returns the currently selected mode or OFF if the :SEARch:STATe is OFF.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code> <code>&lt;value&gt; ::= {EDGE   GLIT   RUNT   TRAN   SER{1   2}   PEAK   OFF}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li> <li>• <a href="#">":SEARch:STATe"</a> on page 1206</li> <li>• <a href="#">":SEARch:COUNt"</a> on page 1203</li> <li>• <a href="#">":SEARch:EVENT"</a> on page 1204</li> </ul>

## :SEARch:STATe

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:STATe <value>`

`<value> ::= {{0 | OFF} | {1 | ON}}`

The :SEARch:STATe command enables or disables the search feature.

**Query Syntax**    `:SEARch:STATe?`

The :SEARch:STATe? query returns the current setting.

**Return Format**    `<value><NL>`

`<value> ::= {0 | 1}`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201

- [":SEARch:MODE"](#) on page 1205

- [":SEARch:COUNt"](#) on page 1203

- [":SEARch:EVENT"](#) on page 1204

## :SEARch:EDGE Commands

**Table 139** :SEARch:EDGE Commands Summary

Command	Query	Options and Query Returns
:SEARch:EDGE:SLOPe <slope> (see <a href="#">page 1208</a> )	:SEARch:EDGE:SLOPe? (see <a href="#">page 1208</a> )	<slope> ::= {POSitive   NEGative   EITHer}
:SEARch:EDGE:SOURce <source> (see <a href="#">page 1209</a> )	:SEARch:EDGE:SOURce? (see <a href="#">page 1209</a> )	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format

## :SEARch:EDGE:SLOPe

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:EDGE:SLOPe <slope>`

`<slope> ::= {NEGative | POSitive | EITHer}`

The :SEARch:EDGE:SLOPe command specifies the slope of the edge for the search.

**Query Syntax**    `:SEARch:EDGE:SLOPe?`

The :SEARch:EDGE:SLOPe? query returns the current slope setting.

**Return Format**    `<slope><NL>`

`<slope> ::= {NEG | POS | EITH}`

**See Also**    • [Chapter 34](#), “:SEARch Commands,” starting on page 1201

## :SEARch:EDGE:SOURce

**N** (see [page 1666](#))

- Command Syntax**    `:SEARch:EDGE:SOURce <source>`  
`<source> ::= CHANnel<n>`  
`<n> ::= 1 to (# analog channels) in NR1 format`
- The :SEARch:EDGE:SOURce command selects the channel on which to search for edges.
- Query Syntax**    `:SEARch:EDGE:SOURce?`
- The :SEARch:EDGE:SOURce? query returns the current source.
- Return Format**    `<source><NL>`  
`<source> ::= CHAN<n>`
- See Also**    · [Chapter 34](#), “:SEARch Commands,” starting on page 1201

## :SEARch:GLITch Commands

**Table 140** :SEARch:GLITch Commands Summary

Command	Query	Options and Query Returns
:SEARch:GLITch:GREaterthan <greater_than_time>[suffix] (see <a href="#">page 1211</a> )	:SEARch:GLITch:GREaterthan? (see <a href="#">page 1211</a> )	<greater_than_time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}
:SEARch:GLITch:LESSthan <less_than_time>[suffix] (see <a href="#">page 1212</a> )	:SEARch:GLITch:LESSthan? (see <a href="#">page 1212</a> )	<less_than_time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}
:SEARch:GLITch:POLarity <polarity> (see <a href="#">page 1213</a> )	:SEARch:GLITch:POLarity? (see <a href="#">page 1213</a> )	<polarity> ::= {POSitive   NEGative}
:SEARch:GLITch:QUALifier <qualifier> (see <a href="#">page 1214</a> )	:SEARch:GLITch:QUALifier? (see <a href="#">page 1214</a> )	<qualifier> ::= {GREaterthan   LESSthan   RANGE}
:SEARch:GLITch:RANGE <less_than_time>[suffix], <greater_than_time>[suffix] (see <a href="#">page 1215</a> )	:SEARch:GLITch:RANGE? (see <a href="#">page 1215</a> )	<less_than_time> ::= 15 ns to 10 seconds in NR3 format <greater_than_time> ::= 10 ns to 9.99 seconds in NR3 format [suffix] ::= {s   ms   us   ns   ps}
:SEARch:GLITch:SOURce <source> (see <a href="#">page 1216</a> )	:SEARch:GLITch:SOURce? (see <a href="#">page 1216</a> )	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format

## :SEARch:GLITch:GREaterthan

**N** (see [page 1666](#))

**Command Syntax** :SEARch:GLITch:GREaterthan <greater\_than\_time>[<suffix>]

<greater\_than\_time> ::= floating-point number in NR3 format

<suffix> ::= {s | ms | us | ns | ps}

The :SEARch:GLITch:GREaterthan command sets the minimum pulse width duration for the selected :SEARch:GLITch:SOURce.

**Query Syntax** :SEARch:GLITch:GREaterthan?

The :SEARch:GLITch:GREaterthan? query returns the minimum pulse width duration time for :SEARch:GLITch:SOURce.

**Return Format** <greater\_than\_time><NL>

<greater\_than\_time> ::= floating-point number in NR3 format.

- See Also**
- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
  - [":SEARch:GLITch:SOURce"](#) on page 1216
  - [":SEARch:GLITch:QUALifier"](#) on page 1214
  - [":SEARch:MODE"](#) on page 1205

## :SEARch:GLITch:LESSthan

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:GLITch:LESSthan &lt;less_than_time&gt;[&lt;suffix&gt;]</code>
	<code>&lt;less_than_time&gt;</code> ::= floating-point number in NR3 format
	<code>&lt;suffix&gt;</code> ::= {s   ms   us   ns   ps}
	The :SEARch:GLITch:LESSthan command sets the maximum pulse width duration for the selected :SEARch:GLITch:SOURce.
<b>Query Syntax</b>	<code>:SEARch:GLITch:LESSthan?</code>
	The :SEARch:GLITch:LESSthan? query returns the pulse width duration time for :SEARch:GLITch:SOURce.
<b>Return Format</b>	<code>&lt;less_than_time&gt;&lt;NL&gt;</code> <code>&lt;less_than_time&gt;</code> ::= floating-point number in NR3 format.
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li><li><a href="#">":SEARch:GLITch:SOURce"</a> on page 1216</li><li><a href="#">":SEARch:GLITch:QUALifier"</a> on page 1214</li><li><a href="#">":SEARch:MODE"</a> on page 1205</li></ul>

## :SEARch:GLITch:POLarity

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:GLITch:POLarity <polarity>`  
`<polarity> ::= {POSitive | NEGative}`

The :SEARch:GLITch:POLarity command sets the polarity for the glitch (pulse width) search.

**Query Syntax**    `:SEARch:GLITch:POLarity?`

The :SEARch:GLITch:POLarity? query returns the current polarity setting for the glitch (pulse width) search.

**Return Format**    `<polarity><NL>`  
`<polarity> ::= {POS | NEG}`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [“:SEARch:MODE”](#) on page 1205
- [“:SEARch:GLITch:SOURce”](#) on page 1216

## :SEARch:GLITch:QUALifier

**N** (see [page 1666](#))

**Command Syntax** `:SEARch:GLITch:QUALifier <operator>`

`<operator> ::= {GREaterthan | LESSthan | RANGE}`

This command sets the mode of operation of the glitch (pulse width) search. The oscilloscope can search for a pulse width that is greater than a time value, less than a time value, or within a range of time values.

**Query Syntax** `:SEARch:GLITch:QUALifier?`

The `:SEARch:GLITch:QUALifier?` query returns the glitch (pulse width) qualifier.

**Return Format** `<operator><NL>`

`<operator> ::= {GRE | LESS | RANG}`

**See Also** • [Chapter 34](#), “:SEARch Commands,” starting on page 1201

• [":SEARch:GLITch:SOURce"](#) on page 1216

• [":SEARch:MODE"](#) on page 1205

## :SEARch:GLITch:RANGE

**N** (see [page 1666](#))

**Command Syntax**

```
:SEARch:GLITch:RANGE <less_than_time>[suffix],  
                      <greater_than_time>[suffix]  
  
<less_than_time> ::= (15 ns - 10 seconds) in NR3 format  
  
<greater_than_time> ::= (10 ns - 9.99 seconds) in NR3 format  
  
[suffix] ::= {s | ms | us | ns | ps}
```

The :SEARch:GLITch:RANGE command sets the pulse width duration for the selected :SEARch:GLITch:SOURce. You can enter the parameters in any order – the smaller value becomes the <greater\_than\_time> and the larger value becomes the <less\_than\_time>.

**Query Syntax**

```
:SEARch:GLITch:RANGE?
```

The :SEARch:GLITch:RANGE? query returns the pulse width duration time for :SEARch:GLITch:SOURce.

**Return Format**

```
<less_than_time>,<greater_than_time><NL>
```

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:GLITch:SOURce"](#) on page 1216
- [":SEARch:GLITch:QUALifier"](#) on page 1214
- [":SEARch:MODE"](#) on page 1205

## :SEARch:GLITch:SOURce

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:GLITch:SOURce <source>`

`<source> ::= CHANnel<n>`

`<n> ::= 1 to (# analog channels) in NR1 format`

The :SEARch:GLITch:SOURce command selects the channel on which to search for glitches (pulse widths).

**Query Syntax**    `:SEARch:GLITch:SOURce?`

The :SEARch:GLITch:SOURce? query returns the current pulse width source.

If all channels are off, the query returns "NONE."

**Return Format**    `<source><NL>`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201

- [":SEARch:MODE"](#) on page 1205

- [":SEARch:GLITch:POLarity"](#) on page 1213

- [":SEARch:GLITch:QUALifier"](#) on page 1214

- [":SEARch:GLITch:RANGE"](#) on page 1215

## :SEARch:PEAK Commands

**Table 141** :SEARch:PEAK Commands Summary

Command	Query	Options and Query Returns
:SEARch:PEAK:EXCursion <delta_level> (see page 1218)	:SEARch:PEAK:EXCursion? (see page 1218)	<delta_level> ::= required change in level to be recognized as a peak, in NR3 format.
:SEARch:PEAK:NPEaks <number> (see page 1219)	:SEARch:PEAK:NPEaks? (see page 1219)	<number> ::= max number of peaks to find, 1-11 in NR1 format.
:SEARch:PEAK:SOURCE <source> (see page 1220)	:SEARch:PEAK:SOURce? (see page 1220)	<source> ::= {FUNCTION<m>   MATH<m>   FFT} (must be an FFT waveform) <m> ::= 1 to (# math functions) in NR1 format
:SEARch:PEAK:THResholt <level> (see page 1221)	:SEARch:PEAK:THResholt? (see page 1221)	<level> ::= necessary level to be considered a peak, in NR3 format.

## :SEARch:PEAK:EXCursion

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:PEAK:EXCursion <delta_level>`  
`<delta_level> ::= required change in level to be recognized as a peak,  
                   in NR3 format.`

The :SEARch:PEAK:EXCursion command specifies the change in level that must occur (in other words, hysteresis) to be recognized as a peak.

The threshold level units are specified by the :FFT:VTYPe or :FUNCtion<m>[:FFT]:VTYPe command.

**Query Syntax**    `:SEARch:PEAK:EXCursion?`

The :SEARch:PEAK:EXCursion? query returns the specified excursion delta level value.

**Return Format**    `<delta_level><NL>`  
`<delta_level> ::= in NR3 format.`

**See Also**

- "[:FFT:VTYPe](#)" on page 466
- "[:FUNCtion<m>\[:FFT\]:VTYPe](#)" on page 512
- "[:SEARch:PEAK:NPEaks](#)" on page 1219
- "[:SEARch:PEAK:SOURce](#)" on page 1220
- "[:SEARch:PEAK:THreshold](#)" on page 1221

## :SEARch:PEAK:NPEaks

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:PEAK:NPEaks &lt;number&gt;</code>  <code>&lt;number&gt; ::= max number of peaks to find, 1-11 in NR1 format.</code>
	The :SEARch:PEAK:NPEaks command specifies the maximum number of FFT peaks to find. This number can be from 1 to 11.
<b>Query Syntax</b>	<code>:SEARch:PEAK:NPEaks?</code>  The :SEARch:PEAK:NPEaks? query returns the specified maximum number of FFT peaks to find.
<b>Return Format</b>	<code>&lt;number&gt;&lt;NL&gt;</code>  <code>&lt;number&gt; ::= in NR1 format.</code>

- See Also**
- [":SEARch:PEAK:EXCursion"](#) on page 1218
  - [":SEARch:PEAK:SOURce"](#) on page 1220
  - [":SEARch:PEAK:THreshold"](#) on page 1221

## :SEARch:PEAK:SOURce

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:PEAK:SOURce &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {FUNCTION&lt;m&gt;   MATH&lt;m&gt;   FFT} (source must be an FFT waveform)</code>
	<code>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</code>
	The :SEARch:PEAK:SOURce command selects the FFT math function waveform to search.
<b>Query Syntax</b>	<code>:SEARch:PEAK:SOURce?</code>
	The :SEARch:PEAK:SOURce? query returns the FFT math function waveform that is being searched.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code> <code>&lt;source&gt; ::= {FUNC&lt;m&gt;   FFT} (must be FFT)</code> <code>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">":SEARch:PEAK:EXCursion</a>" on page 1218</li> <li>· "<a href="#">":SEARch:PEAK:NPEaks</a>" on page 1219</li> <li>· "<a href="#">":SEARch:PEAK:THreshold</a>" on page 1221</li> </ul>

## :SEARch:PEAK:THReShold

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:PEAK:THReShold <level>`  
`<level> ::= necessary level to be considered a peak, in NR3 format.`

The :SEARch:PEAK:THReShold command specifies the threshold level necessary to be considered a peak.

The threshold level units are specified by the :FFT:VTYPe or :FUNCTION<m>[:FFT]:VTYPe command.

**Query Syntax**    `:SEARch:PEAK:THReShold?`

The :SEARch:PEAK:THReShold? query returns the specified threshold level for FFT peak search.

**Return Format**    `<level><NL>`  
`<level> ::= in NR3 format.`

**See Also**

- [":FFT:VTYPe" on page 466](#)
- [":FUNCTION<m>\[:FFT\]:VTYPe" on page 512](#)
- [":SEARch:PEAK:EXCursion" on page 1218](#)
- [":SEARch:PEAK:NPEaks" on page 1219](#)
- [":SEARch:PEAK:SOURce" on page 1220](#)

## :SEARch:RUNT Commands

**Table 142** :SEARch:RUNT Commands Summary

Command	Query	Options and Query Returns
:SEARch:RUNT:POLarity <polarity> (see <a href="#">page 1223</a> )	:SEARch:RUNT:POLarity? ? (see <a href="#">page 1223</a> )	<polarity> ::= {POSitive   NEGative   EITHer}
:SEARch:RUNT:QUALifie r <qualifier> (see <a href="#">page 1224</a> )	:SEARch:RUNT:QUALifie r? ? (see <a href="#">page 1224</a> )	<qualifier> ::= {GREaterthan   LESSthan   NONE}
:SEARch:RUNT:SOURCE <source> (see <a href="#">page 1225</a> )	:SEARch:RUNT:SOURce? (see <a href="#">page 1225</a> )	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:SEARch:RUNT:TIME <time>[suffix] (see <a href="#">page 1226</a> )	:SEARch:RUNT:TIME? (see <a href="#">page 1226</a> )	<time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}

## :SEARch:RUNT:POLarity

**N** (see [page 1666](#))

**Command Syntax** :SEARch:RUNT:POLarity <slope>

<polarity> ::= {POSitive | NEGative | EITHer}

The :SEARch:RUNT:POLarity command sets the polarity for the runt search.

**Query Syntax** :SEARch:RUNT:POLarity?

The :SEARch:RUNT:POLarity? query returns the currently set runt polarity.

**Return Format** <slope><NL>

<polarity> ::= {POS | NEG | EITH}

- See Also**
- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
  - [“:SEARch:MODE”](#) on page 1205
  - [“:SEARch:RUNT:SOURce”](#) on page 1225

## :SEARch:RUNT:QUALifier

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:RUNT:QUALifier <qualifier>`

`<qualifier> ::= {GREaterthan | LESSthan | NONE}`

The :SEARch:RUNT:QUALifier command specifies whether to search for a runt that is greater than a time value, less than a time value, or any time value.

**Query Syntax**    `:SEARch:RUNT:QUALifier?`

The :SEARch:RUNT:QUALifier? query returns the current runt search qualifier.

**Return Format**    `<qualifier><NL>`

`<qualifier> ::= {GRE | LESS | NONE}`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201

- [":SEARch:MODE"](#) on page 1205

## :SEARch:RUNT:SOURce

**N** (see [page 1666](#))

<b>Command Syntax</b>	<pre>:SEARch:RUNT:SOURce &lt;source&gt; &lt;source&gt; ::= CHANnel&lt;n&gt; &lt;n&gt; ::= 1 to (# analog channels) in NR1 format</pre>
	The :SEARch:RUNT:SOURce command selects the channel on which to search for the runt pulse.
<b>Query Syntax</b>	<pre>:SEARch:RUNT:SOURce?</pre>
	The :SEARch:RUNT:SOURce? query returns the current runt search source.
<b>Return Format</b>	<pre>&lt;source&gt;&lt;NL&gt; &lt;source&gt; ::= CHAN&lt;n&gt;</pre>
<b>See Also</b>	<ul style="list-style-type: none"><li>• <a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li><li>• <a href="#">":SEARch:RUNT:POLarity"</a> on page 1223</li></ul>

## :SEARch:RUNT:TIME

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:RUNT:TIME <time>[suffix]`

`<time>` ::= floating-point number in NR3 format

`[suffix]` ::= {s | ms | us | ns | ps}

When searching for runt pulses whose widths are greater than or less than a time (see :SEARch:RUNT:QUALifier), the :SEARch:RUNT:TIME command specifies the time value.

**Query Syntax**    `:SEARch:RUNT:TIME?`

The :SEARch:RUNT:TIME? query returns the currently specified runt time value.

**Return Format**    `<time><NL>`

`<time>` ::= floating-point number in NR3 format

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201

- [":SEARch:RUNT:QUALifier"](#) on page 1224

## :SEARch:TRANSition Commands

**Table 143** :SEARch:TRANSition Commands Summary

Command	Query	Options and Query Returns
:SEARch:TRANSition:QUALifier <qualifier> (see <a href="#">page 1228</a> )	:SEARch:TRANSition:QUALifier? (see <a href="#">page 1228</a> )	<qualifier> ::= {GREaterthan   LESSthan}
:SEARch:TRANSition:SLOPe <slope> (see <a href="#">page 1229</a> )	:SEARch:TRANSition:SLOPe? (see <a href="#">page 1229</a> )	<slope> ::= {NEGative   POSitive}
:SEARch:TRANSition:SOURce <source> (see <a href="#">page 1230</a> )	:SEARch:TRANSition:SOURce? (see <a href="#">page 1230</a> )	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:SEARch:TRANSition:TIME <time>[suffix] (see <a href="#">page 1231</a> )	:SEARch:TRANSition:TIME? (see <a href="#">page 1231</a> )	<time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}

## :SEARch:TRANSition:QUALifier

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:TRANSition:QUALifier &lt;qualifier&gt;</code> <code>&lt;qualifier&gt; ::= {GREaterthan   LESSthan}</code>
	The :SEARch:TRANSition:QUALifier command specifies whether to search for edge transitions greater than or less than a time.
<b>Query Syntax</b>	<code>:SEARch:TRANSition:QUALifier?</code>
	The :SEARch:TRANSition:QUALifier? query returns the current transition search qualifier.
<b>Return Format</b>	<code>&lt;qualifier&gt;&lt;NL&gt;</code> <code>&lt;qualifier&gt; ::= {GRE   LESS}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li><li><a href="#">":SEARch:MODE"</a> on page 1205</li><li><a href="#">":SEARch:TRANSition:TIME"</a> on page 1231</li></ul>

## :SEARch:TRANSition:SLOPe

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:TRANSition:SLOPe <slope>`  
`<slope> ::= {NEGative | POSitive}`  
The :SEARch:TRANSition:SLOPe command selects whether to search for rising edge (POSitive slope) transitions or falling edge (NEGative slope) transitions.

**Query Syntax**    `:SEARch:TRANSition:SLOPe?`  
The :SEARch:TRANSition:SLOPe? query returns the current transition search slope setting.

**Return Format**    `<slope><NL>`  
`<slope> ::= {NEG | POS}`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [“:SEARch:MODE”](#) on page 1205
- [“:SEARch:TRANSition:SOURce”](#) on page 1230
- [“:SEARch:TRANSition:TIME”](#) on page 1231

## :SEARch:TRANSition:SOURce

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:TRANSition:SOURce <source>`

`<source> ::= CHANnel<n>`

`<n> ::= 1 to (# analog channels) in NR1 format`

The :SEARch:TRANSition:SOURce command selects the channel on which to search for edge transitions.

**Query Syntax**    `:SEARch:TRANSition:SOURce?`

The :SEARch:TRANSition:SOURce? query returns the current transition search source.

**Return Format**    `<source><NL>`

`<source> ::= CHAN<n>`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:MODE"](#) on page 1205
- [":SEARch:TRANSition:SLOPe"](#) on page 1229

## :SEARch:TRANSition:TIME

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:TRANSition:TIME &lt;time&gt;[suffix]</code>
	<code>&lt;time&gt; ::= floating-point number in NR3 format</code>
	<code>[suffix] ::= {s   ms   us   ns   ps}</code>
	The :SEARch:TRANSition:TIME command sets the time of the transition to search for. You can search for transitions greater than or less than this time.
<b>Query Syntax</b>	<code>:SEARch:TRANSition:TIME?</code>
	The :SEARch:TRANSition:TIME? query returns the current transition time value.
<b>Return Format</b>	<code>&lt;time&gt;&lt;NL&gt;</code>
	<code>&lt;time&gt; ::= floating-point number in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"><li>• <a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li><li>• <a href="#">":SEARch:TRANSition:QUALifier"</a> on page 1228</li></ul>

## :SEARch:SERial:A429 Commands

**Table 144** :SEARch:SERial:A429 Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:A429:L ABel <value> (see <a href="#">page 1233</a> )	:SEARch:SERial:A429:L ABel? (see <a href="#">page 1233</a> )	<value> ::= 8-bit integer in decimal, <hex>, <octal>, or <string> from 0-255 <hex> ::= #Hnn where n ::= {0,...,9   A,...,F} <octal> ::= #Qnnn where n ::= {0,...,7} <string> ::= "0xnn" where n ::= {0,...,9   A,...,F}
:SEARch:SERial:A429:M ODE <condition> (see <a href="#">page 1234</a> )	:SEARch:SERial:A429:M ODE? (see <a href="#">page 1234</a> )	<condition> ::= {LABEL   LBITS   PERRor   WERRor   GERRor   WGERRors   ALLerrors}
:SEARch:SERial:A429:P ATTern:DATA <string> (see <a href="#">page 1235</a> )	:SEARch:SERial:A429:P ATTern:DATA? (see <a href="#">page 1235</a> )	<string> ::= "nn...n" where n ::= {0   1}, length depends on FORMat
:SEARch:SERial:A429:P ATTern:SDI <string> (see <a href="#">page 1236</a> )	:SEARch:SERial:A429:P ATTern:SDI? (see <a href="#">page 1236</a> )	<string> ::= "nn" where n ::= {0   1}, length always 2 bits
:SEARch:SERial:A429:P ATTern:SSM <string> (see <a href="#">page 1237</a> )	:SEARch:SERial:A429:P ATTern:SSM? (see <a href="#">page 1237</a> )	<string> ::= "nn" where n ::= {0   1}, length always 2 bits

## :SEARch:SERial:A429:LABel

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:A429:LABel <value>`

`<value> ::= 8-bit integer in decimal, <hex>, <octal>, or <string>`  
                   from 0-255

`<hex> ::= #Hnn where n ::= {0,...,9 | A,...,F}`

`<octal> ::= #Qnnn where n ::= {0,...,7}`

`<string> ::= "0xnn" where n ::= {0,...,9 | A,...,F}`

The :SEARch:SERial:A429:LABel command defines the ARINC 429 label value when labels are used in the selected search mode.

**Query Syntax**    `:SEARch:SERial:A429:LABel?`

The :SEARch:SERial:A429:LABel? query returns the current label value in decimal format.

**Return Format**    `<value><NL>` in decimal format

**Errors**    • ["-241, Hardware missing" on page 1607](#)

**See Also**    • ["Introduction to :TRIGger Commands" on page 1349](#)  
                   • [":SEARch:SERial:A429:MODE" on page 1234](#)

## :SEARch:SERial:A429:MODE

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:A429:MODE &lt;condition&gt;</code>
	<code>&lt;condition&gt; ::= {LABel   LBITS   PERRor   WERRor   GERRor   WGERRors   ALLerrors}</code>

The :SEARch:SERial:A429:MODE command selects the type of ARINC 429 information to find in the Lister display:

- LABel – finds the specified label value.
- LBITS – finds the label and the other word fields as specified.
- PERRor – finds words with a parity error.
- WERRor – finds an intra-word coding error.
- GERRor – finds an inter-word gap error.
- WGERRors – finds either a Word or Gap Error.
- ALLerrors – finds any of the above errors.

<b>Query Syntax</b>	<code>:SEARch:SERial:A429:MODE?</code>
---------------------	----------------------------------------

The :SEARch:SERial:A429:MODE? query returns the current ARINC 429 search mode condition.

<b>Return Format</b>	<code>&lt;condition&gt;&lt;NL&gt;</code>
	<code>&lt;condition&gt; ::= {LAB   LBIT   PERR   WERR   GERR   WGERR   ALL}</code>

- Errors** • ["-241, Hardware missing" on page 1607](#)

<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">"Introduction to :SBUS&lt;n&gt; Commands" on page 905</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:MODE" on page 909</a></li> <li>• <a href="#">":SEARch:SERial:A429:LABEL" on page 1233</a></li> <li>• <a href="#">":SEARch:SERial:A429:PATTERn:DATA" on page 1235</a></li> <li>• <a href="#">":SEARch:SERial:A429:PATTERn:SDI" on page 1236</a></li> <li>• <a href="#">":SEARch:SERial:A429:PATTERn:SSM" on page 1237</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:A429:SOURce" on page 920</a></li> </ul>
-----------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

## :SEARch:SERial:A429:PATTERn:DATA

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:A429:PATTERn:DATA <string>`

`<string> ::= "nn...n" where n ::= {0 | 1}, length depends on FORMat`

The :SEARch:SERial:A429:PATTERn:DATA command defines the ARINC 429 data pattern resource according to the string parameter. This pattern controls the data pattern searched for in each ARINC 429 word.

### NOTE

If more bits are sent for `<string>` than specified by the :SBUS<n>:A429:FORMat command, the most significant bits will be truncated.

**Query Syntax**    `:SEARch:SERial:A429:PATTERn:DATA?`

The :SEARch:SERial:A429:PATTERn:DATA? query returns the current settings of the specified ARINC 429 data pattern resource in the binary string format.

**Return Format**    `<string><NL>`

**Errors**    -241, Hardware missing on page 1607

**See Also**

- ["Introduction to :TRIGger Commands" on page 1349](#)
- [":SEARch:SERial:A429:MODE" on page 1234](#)
- [":SEARch:SERial:A429:PATTERn:SDI" on page 1236](#)
- [":SEARch:SERial:A429:PATTERn:SSM" on page 1237](#)

## :SEARch:SERial:A429:PATTern:SDI

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:A429:PATTern:SDI &lt;string&gt;</code> <code>&lt;string&gt; ::= "nn" where n ::= {0   1}, length always 2 bits</code>
	The :SEARch:SERial:A429:PATTern:SDI command defines the ARINC 429 two-bit SDI pattern resource according to the string parameter. This pattern controls the SDI pattern searched for in each ARINC 429 word.
	The specified SDI is only used if the :SBUS<n>:A429:FORMat includes the SDI field.
<b>Query Syntax</b>	<code>:SEARch:SERial:A429:PATTern:SDI?</code>
	The :SEARch:SERial:A429:PATTern:SDI? query returns the current settings of the specified ARINC 429 two-bit SDI pattern resource in the binary string format.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code>
<b>Errors</b>	<ul style="list-style-type: none"> <li>• <a href="#">"-241, Hardware missing" on page 1607</a></li> </ul>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">"Introduction to :TRIGger Commands" on page 1349</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:A429:FORMat" on page 918</a></li> <li>• <a href="#">":SEARch:SERial:A429:MODE" on page 1234</a></li> <li>• <a href="#">":SEARch:SERial:A429:PATTern:DATA" on page 1235</a></li> <li>• <a href="#">":SEARch:SERial:A429:PATTern:SSM" on page 1237</a></li> </ul>

## :SEARch:SERial:A429:PATTern:SSM

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:A429:PATTern:SSM &lt;string&gt;</code> <code>&lt;string&gt; ::= "nn" where n ::= {0   1}, length always 2 bits</code>
	The :SEARch:SERial:A429:PATTern:SSM command defines the ARINC 429 two-bit SSM pattern resource according to the string parameter. This pattern controls the SSM pattern searched for in each ARINC 429 word.
	The specified SSM is only used if the :SBUS<n>:A429:FORMat includes the SSM field.
<b>Query Syntax</b>	<code>:SEARch:SERial:A429:PATTern:SSM?</code>
	The :SEARch:SERial:A429:PATTern:SSM? query returns the current settings of the specified ARINC 429 two-bit SSM pattern resource in the binary string format.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code>
<b>Errors</b>	<ul style="list-style-type: none"> <li>• <a href="#">"-241, Hardware missing" on page 1607</a></li> </ul>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">"Introduction to :TRIGger Commands" on page 1349</a></li> <li>• <a href="#">":SBUS&lt;n&gt;:A429:FORMat" on page 918</a></li> <li>• <a href="#">":SEARch:SERial:A429:MODE" on page 1234</a></li> <li>• <a href="#">":SEARch:SERial:A429:PATTern:DATA" on page 1235</a></li> <li>• <a href="#">":SEARch:SERial:A429:PATTern:SDI" on page 1236</a></li> </ul>

## :SEARch:SERial:CAN Commands

**Table 145** :SEARch:SERial:CAN Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:CAN:MODE <value> (see page 1239)	:SEARch:SERial:CAN:MODE? (see page 1239)	<value> ::= {IDEither   IDData   DATA   IDRmote   ERRor   ACKrror   FORMrror   STUFFrror   CRCrror   ALLerrors   OVERload   MESSAGE   MSIGnal}
:SEARch:SERial:CAN:ATTern:DATA <string> (see page 1241)	:SEARch:SERial:CAN:ATTern:DATA? (see page 1241)	<string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X} for hexadecimal
:SEARch:SERial:CAN:ATTern:DATA:LENGTH <length> (see page 1242)	:SEARch:SERial:CAN:ATTern:DATA:LENGTH? (see page 1242)	<length> ::= integer from 1 to 8 in NR1 format
:SEARch:SERial:CAN:ATTern:ID <string> (see page 1243)	:SEARch:SERial:CAN:ATTern:ID? (see page 1243)	<string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X} for hexadecimal
:SEARch:SERial:CAN:ATTern:ID:MODE <value> (see page 1244)	:SEARch:SERial:CAN:ATTern:ID:MODE? (see page 1244)	<value> ::= {STANDARD   EXTENDED}
:SEARch:SERial:CAN:SYMBolic:MESSAge <name> (see page 1245)	:SEARch:SERial:CAN:SYMBolic:MESSAge? (see page 1245)	<name> ::= quoted ASCII string
:SEARch:SERial:CAN:SYMBolic:SIGNAl <name> (see page 1246)	:SEARch:SERial:CAN:SYMBolic:SIGNAl? (see page 1246)	<name> ::= quoted ASCII string
:SEARch:SERial:CAN:SYMBolic:VALue <data> (see page 1247)	:SEARch:SERial:CAN:SYMBolic:VALue? (see page 1247)	<data> ::= value in NR3 format

## :SEARch:SERial:CAN:MODE

**N** (see [page 1666](#))

**Command Syntax** :SEARch:SERial:CAN:MODE <value>

```
<value> ::= { IDEither | IDData | DATA | IDR | ERR | ACK | FORM | STUF | CRC
    | ALL | OVER | MESS | MSIG}
```

The :SEARch:SERial:CAN:MODE command selects the type of CAN information to find in the Lister display:

Condition	Front-panel name	Description
IDEither	Frame ID	Finds remote or data frames matching the specified ID.
IDData	Data Frame ID	Finds data frames matching the specified ID.
DATA	Data Frame ID and Data	Finds data frames matching the specified ID and data.
IDR	Remote Frame ID	Finds remote frames with the specified ID.
ERR	Error Frame	Finds CAN active error frames.
ACK	Acknowledge Error	Finds the acknowledge bit if the polarity is incorrect.
FORM	Form Error	Finds reserved bit errors.
STUF	Stuff Error	Finds 6 consecutive 1s or 6 consecutive 0s, while in a non-error or non overload frame.
CRC	CRC Field Error	Finds when the calculated CRC does not match the transmitted CRC.
ALL	All Errors	Finds any form error or active error.
OVER	Overload Frame	Finds CAN overload frames.
MESS	Message	Finds a symbolic message.
MSIG	Message and Signal (non-FD)	Finds a symbolic message and a signal value.

**Query Syntax** :SEARch:SERial:CAN:MODE?

The :SEARch:SERial:CAN:MODE? query returns the currently selected mode.

**Return Format** <value><NL>

```
<value> ::= { IDE | IDD | DATA | IDR | ERR | ACK | FORM | STUF | CRC
    | ALL | OVER | MESS | MSIG}
```

- See Also**
- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
  - [":SEARch:SERial:CAN:PATTERn:DATA"](#) on page 1241
  - [":SEARch:SERial:CAN:PATTERn:ID"](#) on page 1243

- "[:RECall:DBC\[:STARt\]](#)" on page 865
- "[:SEARch:SERial:CAN:SYMBolic:MESSage](#)" on page 1245
- "[:SEARch:SERial:CAN:SYMBolic:SIGNal](#)" on page 1246
- "[:SEARch:SERial:CAN:SYMBolic:VALUe](#)" on page 1247

## :SEARch:SERial:CAN:PATTERn:DATA

**N** (see [page 1666](#))

**Command Syntax** :SEARch:SERial:CAN:PATTERn:DATA <string>

```
<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | X}
for hexadecimal
```

The :SEARch:SERial:CAN:PATTERn:DATA command specifies the data value when searching for Data Frame ID and Data.

The length of the data value is specified using the :SEARch:SERial:CAN:PATTERn:DATA:LENGth command.

**Query Syntax** :SEARch:SERial:CAN:PATTERn:DATA?

The :SEARch:SERial:CAN:PATTERn:DATA? query returns the current data value setting.

**Return Format** <string><NL>

```
<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | X}
for hexadecimal
```

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:SERial:CAN:MODE"](#) on page 1239
- [":SEARch:SERial:CAN:PATTERn:DATA:LENGth"](#) on page 1242

## :SEARch:SERial:CAN:PATTern:DATA:LENGth

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:CAN:PATTern:DATA:LENGth <length>`  
`<length> ::= integer from 1 to 8 in NR1 format`

The :SEARch:SERial:CAN:PATTern:DATA:LENGth command specifies the length of the data value when searching for Data Frame ID and Data.

The data value is specified using the :SEARch:SERial:CAN:PATTern:DATA command.

**Query Syntax**    `:SEARch:SERial:CAN:PATTern:DATA:LENGth?`

The :SEARch:SERial:CAN:PATTern:DATA:LENGth? query returns the current data length setting.

**Return Format**    `<length><NL>`  
`<length> ::= integer from 1 to 8 in NR1 format`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:SERial:CAN:MODE"](#) on page 1239
- [":SEARch:SERial:CAN:PATTern:DATA"](#) on page 1241

## :SEARch:SERial:CAN:PATTern:ID

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:CAN:PATTern:ID <string>`  
`<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | X}`  
                   for hexadecimal

The :SEARch:SERial:CAN:PATTern:ID command specifies the ID value when searching for a CAN event.

The value can be a standard ID or an extended ID, depending on the :SEARch:SERial:CAN:PATTern:ID:MODE command's setting.

**Query Syntax**    `:SEARch:SERial:CAN:PATTern:ID?`

The :SEARch:SERial:CAN:PATTern:ID? query returns the current ID value setting.

**Return Format**    `<string><NL>`  
`<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | X}`  
                   for hexadecimal

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:SERial:CAN:MODE"](#) on page 1239
- [":SEARch:SERial:CAN:PATTern:ID:MODE"](#) on page 1244

## :SEARch:SERial:CAN:PATTern:ID:MODE

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:CAN:PATTern:ID:MODE <value>`  
                  `<value> ::= {STANDARD | EXTENDED}`

The :SEARch:SERial:CAN:PATTern:ID:MODE command specifies whether a standard ID value or an extended ID value is used when searching for a CAN event.

The ID value is specified using the :SEARch:SERial:CAN:PATTern:ID command.

**Query Syntax**    `:SEARch:SERial:CAN:PATTern:ID:MODE?`

The :SEARch:SERial:CAN:PATTern:ID:MODE? query returns the current setting.

**Return Format**    `<value><NL>`  
                  `<value> ::= {STAN | EXT}`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:SERial:CAN:MODE"](#) on page 1239
- [":SEARch:SERial:CAN:PATTern:ID"](#) on page 1243

## :SEARch:SERial:CAN:SYMBolic:MESSAge

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:CAN:SYMBolic:MESSAge <name>`  
`<name> ::= quoted ASCII string`

The :SEARch:SERial:CAN:SYMBolic:MESSAge command specifies the message to search for when CAN symbolic data has been loaded (recalled) into the oscilloscope and the CAN serial search mode is set to MESSAge or MSIGnAl.

**Query Syntax**    `:SEARch:SERial:CAN:SYMBolic:MESSAge?`

The :SEARch:SERial:CAN:SYMBolic:MESSAge? query returns the specified message.

**Return Format**    `<name><NL>`  
`<name> ::= quotes ASCII string`

**See Also**

- [":RECall:DBC\[:STARt\]" on page 865](#)
- [":SEARch:SERial:CAN:MODE" on page 1239](#)
- [":SEARch:SERial:CAN:SYMBolic:SIGNAl" on page 1246](#)
- [":SEARch:SERial:CAN:SYMBolic:VALue" on page 1247](#)

## :SEARch:SERial:CAN:SYMBolic:SIGNal

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:CAN:SYMBolic:SIGNal <name>`  
                  `<name> ::= quoted ASCII string`

The :SEARch:SERial:CAN:SYMBolic:SIGNal command specifies the signal to search for when CAN symbolic data has been loaded (recalled) into the oscilloscope and the CAN serial search mode is set to MSIGnal.

**Query Syntax**    `:SEARch:SERial:CAN:SYMBolic:SIGNal?`  
The :SEARch:SERial:CAN:SYMBolic:SIGNal? query returns the specified signal.

**Return Format**    `<name><NL>`  
                  `<name> ::= quoted ASCII string`

**See Also**

- [":RECall:DBC\[:STARt\]" on page 865](#)
- [":SEARch:SERial:CAN:MODE" on page 1239](#)
- [":SEARch:SERial:CAN:SYMBolic:MESSage" on page 1245](#)
- [":SEARch:SERial:CAN:SYMBolic:VALue" on page 1247](#)

## :SEARch:SERial:CAN:SYMBolic:VALue

**N** (see [page 1666](#))

**Command Syntax**

```
:SEARch:SERial:CAN:SYMBolic:VALue <data>
<data> ::= value in NR3 format
```

The :SEARch:SERial:CAN:SYMBolic:VALue command specifies the signal value to search for when CAN symbolic data has been loaded (recalled) into the oscilloscope and the CAN serial search mode is set to MSIGnal.

**NOTE**

Encoded signal values are not supported in the remote interface (even though they can be used in the front panel graphical interface).

**Query Syntax**

```
:SEARch:SERial:CAN:SYMBolic:VALue?
```

The :SEARch:SERial:CAN:SYMBolic:VALue? query returns the specified signal value.

**Return Format**

```
<data><NL>
<data> ::= value in NR3 format
```

**See Also**

- "[:RECall:DBC\[:START\]](#)" on page 865
- "[:SEARch:SERial:CAN:MODE](#)" on page 1239
- "[:SEARch:SERial:CAN:SYMBolic:MESSAge](#)" on page 1245
- "[:SEARch:SERial:CAN:SYMBolic:SIGNal](#)" on page 1246

## :SEARch:SERial:FLEXray Commands

**Table 146** :SEARch:SERial:FLEXray Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:FLEXra y:CYCLE <cycle> (see <a href="#">page 1249</a> )	:SEARch:SERial:FLEXra y:CYCLE? (see <a href="#">page 1249</a> )	<cycle> ::= {ALL   <cycle #>} <cycle #> ::= integer from 0-63
:SEARch:SERial:FLEXra y:DATA <string> (see <a href="#">page 1250</a> )	:SEARch:SERial:FLEXra y:DATA? (see <a href="#">page 1250</a> )	<string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X }
:SEARch:SERial:FLEXra y:DATA:LENGth <length> (see <a href="#">page 1251</a> )	:SEARch:SERial:FLEXra y:DATA:LENGth? (see <a href="#">page 1251</a> )	<length> ::= integer from 1 to 12 in NR1 format
:SEARch:SERial:FLEXra y:FRAMe <frame id> (see <a href="#">page 1252</a> )	:SEARch:SERial:FLEXra y:FRAMe? (see <a href="#">page 1252</a> )	<frame_id> ::= {ALL   <frame #>} <frame #> ::= integer from 1-2047
:SEARch:SERial:FLEXra y:MODE <value> (see <a href="#">page 1253</a> )	:SEARch:SERial:FLEXra y:MODE? (see <a href="#">page 1253</a> )	<value> ::= {FRAMe   CYCLE   DATA   HERRor   FERRor   AERRor}

## :SEARch:SERial:FLEXray:CYCLE

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:FLEXray:CYCLE <cycle>`  
`<cycle> ::= {ALL | <cycle #>}`  
`<cycle #> ::= integer from 0-63`

The :SEARch:SERial:FLEXray:CYCLE command specifies the cycle value to find when searching for FlexRay frames.

A cycle value of -1 is the same as ALL.

**Query Syntax**    `:SEARch:SERial:FLEXray:CYCLE?`

The :SEARch:SERial:FLEXray:CYCLE? query returns the current cycle value setting.

**Return Format**    `<cycle><NL>`  
`<cycle> ::= {ALL | <cycle #>}`  
`<cycle #> ::= integer from 0-63`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:SERial:FLEXray:MODE"](#) on page 1253

## :SEARch:SERial:FLEXray:DATA

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:FLEXray:DATA &lt;string&gt;</code> <code>&lt;string&gt; ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X}</code>
The :SEARch:SERial:FLEXray:DATA command specifies the data value to find when searching for FlexRay frames.	
	The length of the data value is specified by the :SEARch:SERial:FLEXray:DATA:LENGth command.
<b>Query Syntax</b>	<code>:SEARch:SERial:FLEXray:DATA?</code>
The :SEARch:SERial:FLEXray:DATA? query returns the current data value setting.	
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code> <code>&lt;string&gt; ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li><li><a href="#">":SEARch:SERial:FLEXray:MODE"</a> on page 1253</li><li><a href="#">":SEARch:SERial:FLEXray:DATA:LENGth"</a> on page 1251</li></ul>

## :SEARch:SERial:FLEXray:DATA:LENGth

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:FLEXray:DATA:LENGth &lt;length&gt;</code> <code>&lt;length&gt; ::= integer from 1 to 12 in NR1 format</code>
	The :SEARch:SERial:FLEXray:DATA:LENGth command specifies the length of data values when searching for FlexRay frames.
	The data value is specified using the :SEARch:SERial:FLEXray:DATA command.
<b>Query Syntax</b>	<code>:SEARch:SERial:FLEXray:DATA:LENGth?</code>
	The :SEARch:SERial:FLEXray:DATA:LENGth? query returns the current data length setting.
<b>Return Format</b>	<code>&lt;length&gt;&lt;NL&gt;</code> <code>&lt;length&gt; ::= integer from 1 to 12 in NR1 format</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li><li><a href="#">":SEARch:SERial:FLEXray:MODE"</a> on page 1253</li><li><a href="#">":SEARch:SERial:FLEXray:DATA"</a> on page 1250</li></ul>

## :SEARch:SERial:FLEXray:FRAMe

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:FLEXray:FRAMe &lt;frame_id&gt;</code> <code>&lt;frame_id&gt; ::= {ALL   &lt;frame #&gt;}</code> <code>&lt;frame #&gt; ::= integer from 1-2047</code>
	The :SEARch:SERial:FLEXray:FRAMe command specifies the frame ID value to find when searching for FlexRay frames.
<b>Query Syntax</b>	<code>:SEARch:SERial:FLEXray:FRAMe?</code>
	The :SEARch:SERial:FLEXray:FRAMe? query returns the current frame ID setting.
<b>Return Format</b>	<code>&lt;frame_id&gt;&lt;NL&gt;</code> <code>&lt;frame_id&gt; ::= {ALL   &lt;frame #&gt;}</code> <code>&lt;frame #&gt; ::= integer from 1-2047</code>
<b>See Also</b>	<ul style="list-style-type: none"><li>• <a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li><li>• <a href="#">":SEARch:SERial:FLEXray:MODE"</a> on page 1253</li></ul>

## :SEARch:SERial:FLEXray:MODE

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:FLEXray:MODE &lt;value&gt;</code> <code>&lt;value&gt; := {FRAMe   CYCLe   DATA   HERRor   FERRor   AERRor}</code>
The :SEARch:SERial:FLEXray:MODE command selects the type of FlexRay information to find in the Lister display:	
	<ul style="list-style-type: none"> <li>• FRAMe – searches for FlexRay frames with the specified frame ID.</li> <li>• CYCLe – searches for FlexRay frames with the specified cycle number and frame ID.</li> <li>• DATA – searches for FlexRay frames with the specified data, cycle number, and frame ID.</li> <li>• HERRor – searches for header CRC errors.</li> <li>• FERRor – searches for frame CRC errors.</li> <li>• AERRor – searches for all errors.</li> </ul>
<b>Query Syntax</b>	<code>:SEARch:SERial:FLEXray:MODE?</code>
The :SEARch:SERial:FLEXray:MODE? query returns the currently selected mode.	
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code> <code>&lt;value&gt; := {FRAM   CYCL   DATA   HERR   FERR   AERR}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li> <li>• <a href="#">":SEARch:SERial:FLEXray:FRAMe"</a> on page 1252</li> <li>• <a href="#">":SEARch:SERial:FLEXray:CYCLE"</a> on page 1249</li> <li>• <a href="#">":SEARch:SERial:FLEXray:DATA"</a> on page 1250</li> </ul>

## :SEARch:SERial:I2S Commands

**Table 147** :SEARch:SERial:I2S Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:I2S:AU Dio <audio_ch> (see page 1255)	:SEARch:SERial:I2S:AU Dio? (see <a href="#">page 1255</a> )	<audio_ch> ::= {RIGHT   LEFT   EITHer}
:SEARch:SERial:I2S:MO DE <value> (see page 1256)	:SEARch:SERial:I2S:MO DE? (see <a href="#">page 1256</a> )	<value> ::= {EQUAL   NOTequal   LESSthan   GREaterthan   INRange   OUTRange}
:SEARch:SERial:I2S:PA TTern:DATA <string> (see <a href="#">page 1257</a> )	:SEARch:SERial:I2S:PA TTern:DATA? (see <a href="#">page 1257</a> )	<string> ::= "n" where n ::= 32-bit integer in signed decimal when <base> = DECimal  <string> ::= "nn...n" where n ::= {0   1   X} when <base> = BINary  <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X} when <base> = HEX
:SEARch:SERial:I2S:PA TTern:FORMAT <base> (see <a href="#">page 1258</a> )	:SEARch:SERial:I2S:PA TTern:FORMAT? (see <a href="#">page 1258</a> )	<base> ::= {BINary   HEX   DECimal}
:SEARch:SERial:I2S:RA NGe <lower>, <upper> (see <a href="#">page 1259</a> )	:SEARch:SERial:I2S:RA NGe? (see <a href="#">page 1259</a> )	<lower> ::= 32-bit integer in signed decimal, <nondecimal>, or <string>  <upper> ::= 32-bit integer in signed decimal, <nondecimal>, or <string>  <nondecimal> ::= #Hnn...n where n ::= {0,...,9   A,...,F} for hexadecimal  <nondecimal> ::= #Bnn...n where n ::= {0   1} for binary  <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F} for hexadecimal

## :SEARch:SERial:I2S:AUDio

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:I2S:AUDio <audio_ch>`  
`<audio_ch> ::= {RIGHT | LEFT | EITHer}`

The :SEARch:SERial:I2S:AUDIO command specifies the channel on which to search for I2S events: right, left, or either channel.

**Query Syntax**    `:SEARch:SERial:I2S:AUDio?`

The :SEARch:SERial:I2S:AUDIO? query returns the current channel setting.

**Return Format**    `<audio_ch><NL>`  
`<audio_ch> ::= {RIGH | LEFT | EITH}`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:SERial:I2S:MODE"](#) on page 1256

## :SEARch:SERial:I2S:MODE

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:I2S:MODE <value>`

```
<value> ::= {EQUal | NOTequal | LESSthan | GREaterthan | INRange
              | OUTRange}
```

The :SEARch:SERial:I2S:MODE command selects the type of I2S information to find in the Lister display:

- EQUal – searches for the specified audio channel's data word when it equals the specified word.
- NOTequal – searches for any word other than the specified word.
- LESSthan – searches for channel data words less than the specified value.
- GREaterthan – searches for channel data words greater than the specified value.
- INRange – searches for channel data words in the range.
- OUTRange – searches for channel data words outside the range.

Data word values are specified using the :SEARch:SERial:I2S:PATTERn:DATA command.

Value ranges are specified using the :SEARch:SERial:I2S:RANGE command.

**Query Syntax**    `:SEARch:SERial:I2S:MODE?`

The :SEARch:SERial:I2S:MODE? query returns the currently selected mode.

**Return Format**    `<value><NL>`

```
<value> ::= {EQU | NOT | LESS | GRE | INR | OUTR}
```

- See Also**
- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
  - “[:SEARch:SERial:I2S:PATTERn:DATA](#)” on page 1257
  - “[:SEARch:SERial:I2S:RANGE](#)” on page 1259
  - “[:SEARch:SERial:I2S:AUDIO](#)” on page 1255

## :SEARch:SERial:I2S:PATTern:DATA

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:I2S:PATTern:DATA <string>`

```

<string> ::= "n" where n ::= 32-bit integer in signed decimal
           when <base> = DECimal

<string> ::= "nn...n" where n ::= {0 | 1 | X} when <base> = BINary

<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | X}
           when <base> = HEX

```

The :SEARch:SERial:I2S:PATTern:DATA command specifies the data word value when searching for I2S events.

The base of the value entered with this command is specified using the :SEARch:SERial:I2S:PATTern:FORMAT command.

**Query Syntax**    `:SEARch:SERial:I2S:PATTern:DATA?`

The :SEARch:SERial:I2S:PATTern:DATA? query returns the current data word value setting.

**Return Format**    `<string><NL>`

```

<string> ::= "n" where n ::= 32-bit integer in signed decimal
           when <base> = DECimal

<string> ::= "nn...n" where n ::= {0 | 1 | X} when <base> = BINary

<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | X}
           when <base> = HEX

```

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:SERial:I2S:MODE"](#) on page 1256
- [":SEARch:SERial:I2S:PATTern:FORMAT"](#) on page 1258

## :SEARch:SERial:I2S:PATTERn:FORMAT

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:I2S:PATTERn:FORMAT &lt;base&gt;</code>
	<code>&lt;base&gt; ::= {BINary   HEX   DECimal}</code>
	The :SEARch:SERial:I2S:PATTERn:FORMAT command specifies the number base used with the :SEARch:SERial:I2S:PATTERn:DATA command.
<b>Query Syntax</b>	<code>:SEARch:SERial:I2S:PATTERn:FORMAT?</code>
	The :SEARch:SERial:I2S:PATTERn:FORMAT? query returns the current number base setting.
<b>Return Format</b>	<code>&lt;base&gt;&lt;NL&gt;</code>
	<code>&lt;base&gt; ::= {BIN   HEX   DEC}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li><li><a href="#">":SEARch:SERial:I2S:PATTERn:DATA"</a> on page 1257</li></ul>

## :SEARch:SERial:I2S:RANGE

**N** (see [page 1666](#))

### Command Syntax

```
:SEARch:SERial:I2S:RANGE <lower>, <upper>
<lower> ::= 32-bit integer in signed decimal, <nondecimal>, or <string>
<upper> ::= 32-bit integer in signed decimal, <nondecimal>, or <string>
<nondecimal> ::= #Hnn...n where n ::= {0,...,9 | A,...,F} for hexadecimal
<nondecimal> ::= #Bnn...n where n ::= {0 | 1} for binary
<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F} for hexadecimal
```

The :SEARch:SERial:I2S:RANGE command specifies the data value range when searching for I2S events in the INRange and OUTRange search modes (set by the :SEARch:SERial:I2S:MODE command).

You can enter the parameters in any order – the smaller value becomes the <lower> and the larger value becomes the <upper>.

### Query Syntax

```
:SEARch:SERial:I2S:RANGE?
```

The :SEARch:SERial:I2S:RANGE? query returns the current data value range setting.

### Return Format

```
<lower>, <upper><NL>
<lower> ::= 32-bit integer in signed decimal
<upper> ::= 32-bit integer in signed decimal
```

### See Also

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:SERial:I2S:MODE"](#) on page 1256

## :SEARch:SERial:IIC Commands

**Table 148** :SEARch:SERial:IIC Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:IIC:MODE <value> (see page 1261)	:SEARch:SERial:IIC:MODE? (see page 1261)	<value> ::= {REStart   ADDRess   ANACK   NACKnowledge   READEprom   READ7   WRITE7   R7Data2   W7Data2}
:SEARch:SERial:IIC:ATTern:ADDRESS <value> (see page 1263)	:SEARch:SERial:IIC:ATTern:ADDRess? (see page 1263)	<value> ::= integer or <string> <string> ::= "0xnn" n ::= {0,...,9   A,...,F}
:SEARch:SERial:IIC:ATTern:DATA <value> (see page 1264)	:SEARch:SERial:IIC:ATTern:DATA? (see page 1264)	<value> ::= integer or <string> <string> ::= "0xnn" n ::= {0,...,9   A,...,F}
:SEARch:SERial:IIC:ATTern:DATA2 <value> (see page 1265)	:SEARch:SERial:IIC:ATTern:DATA2? (see page 1265)	<value> ::= integer or <string> <string> ::= "0xnn" n ::= {0,...,9   A,...,F}
:SEARch:SERial:IIC:QUALifier <value> (see page 1266)	:SEARch:SERial:IIC:QUALifier? (see page 1266)	<value> ::= {EQUAL   NOTEqual   LESSthan   GREaterthan}

## :SEARCh:SERial:IIC:MODE

**N** (see [page 1666](#))

**Command Syntax** :SEARCh:SERial:IIC:MODE <value>

```
<value> ::= {REStart | ADDRess | ANACK | NACKnowledge | READEprom
             | READ7 | WRITE7 | R7Data2 | W7Data2}
```

The :SEARCh:SERial:IIC:MODE command selects the type of IIC information to find in the Lister display:

- REStart – searches for another start condition occurring before a stop condition.
- ADDRess – searches for a packet with the specified address, ignoring the R/W bit.
- ANACK – searches for address with no acknowledge events.
- NACKnowledge – searches for missing acknowledge events.
- READEprom – searches for EEPROM data reads.
- READ7 – searches for 7-bit address frames containing Start:Address7:Read:Ack:Data. The value READ is also accepted for READ7.
- WRITE7 – searches for 7-bit address frames containing Start:Address7:Write:Ack:Data. The value WRITE is also accepted for WRITE7.
- R7Data2 – searches for 7-bit address frames containing Start:Address7:Read:Ack:Data:Ack:Data2.
- W7Data2 – searches for 7-bit address frames containing Start:Address7:Write:Ack:Data:Ack:Data2.

### NOTE

The short form of READ7 (READ7), READEprom (READE), and WRITE7 (WRITE7) do not follow the defined Long Form to Short Form Truncation Rules (see [page 1668](#)).

When searching for events containing addresses, address values are specified using the :SEARCh:SERial:IIC:PATTERn:ADDRess command.

When searching for events containing data, data values are specified using the :SEARCh:SERial:IIC:PATTERn:DATA and :SEARCh:SERial:IIC:PATTERn:DATA2 commands.

**Query Syntax** :SEARCh:SERial:IIC:MODE?

The :SEARCh:SERial:IIC:MODE? query returns the currently selected mode.

**Return Format** <value><NL>

```
<value> ::= {REST | ADDR | ANAC | NACK | READE | READ7 | WRITE7
             | R7D2 | W7D2}
```

- See Also**
- [Chapter 34, “:SEARch Commands,” starting on page 1201](#)
  - [":SEARch:SERial:IIC:PATTern:ADDReSS" on page 1263](#)
  - [":SEARch:SERial:IIC:PATTern:DATA" on page 1264](#)
  - [":SEARch:SERial:IIC:PATTern:DATA2" on page 1265](#)
  - [":SEARch:SERial:IIC:QUALifier" on page 1266](#)

## :SEARch:SERial:IIC:PATTern:ADDResS

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:IIC:PATTern:ADDResS <value>`  
`<value> ::= integer or <string>`  
`<string> ::= "0xnn" n ::= {0,...,9 | A,...,F}`

The :SEARch:SERial:IIC:PATTern:ADDResS command specifies address values when searching for IIC events.

To set don't care values, use the integer -1.

**Query Syntax**    `:SEARch:SERial:IIC:PATTern:ADDResS?`

The :SEARch:SERial:IIC:PATTern:ADDResS? query returns the current address value setting.

**Return Format**    `<value><NL>`  
`<value> ::= integer`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:SERial:IIC:MODE"](#) on page 1261

## :SEARch:SERial:IIC:PATTern:DATA

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:IIC:PATTern:DATA &lt;value&gt;</code> <code>&lt;value&gt; ::= integer or &lt;string&gt;</code> <code>&lt;string&gt; ::= "0xnn" n ::= {0,...,9   A,...,F}</code>
	The :SEARch:SERial:IIC:PATTern:DATA command specifies data values when searching for IIC events.
	To set don't care values, use the integer -1.
	When searching for IIC EEPROM data read events, you specify the data value qualifier using the :SEARch:SERial:IIC:QUALifier command.
<b>Query Syntax</b>	<code>:SEARch:SERial:IIC:PATTern:DATA?</code>
	The :SEARch:SERial:IIC:PATTern:DATA? query returns the current data value setting.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code> <code>&lt;value&gt; ::= integer</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li><li><a href="#">":SEARch:SERial:IIC:MODE"</a> on page 1261</li><li><a href="#">":SEARch:SERial:IIC:QUALifier"</a> on page 1266</li><li><a href="#">":SEARch:SERial:IIC:PATTern:DATA2"</a> on page 1265</li></ul>

## :SEARch:SERial:IIC:PATTern:DATA2

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:IIC:PATTern:DATA2 &lt;value&gt;</code>
	<code>&lt;value&gt; ::= integer or &lt;string&gt;</code>
	<code>&lt;string&gt; ::= "0xnn" n ::= {0,...,9   A,...,F}</code>
	The :SEARch:SERial:IIC:PATTern:DATA2 command specifies the second data value when searching for IIC events with two data values.
	To set don't care values, use the integer -1.
<b>Query Syntax</b>	<code>:SEARch:SERial:IIC:PATTern:DATA2?</code>
	The :SEARch:SERial:IIC:PATTern:DATA2? query returns the current second data value setting.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code>
	<code>&lt;value&gt; ::= integer</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li> <li>• <a href="#">":SEARch:SERial:IIC:MODE"</a> on page 1261</li> <li>• <a href="#">":SEARch:SERial:IIC:PATTern:DATA"</a> on page 1264</li> </ul>

## :SEARch:SERial:IIC:QUALifier

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:IIC:QUALifier &lt;value&gt;</code> <code>&lt;value&gt; ::= {EQUal   NOTequal   LESSthan   GREaterthan}</code>
	The :SEARch:SERial:IIC:QUALifier command specifies the data value qualifier used when searching for IIC EEPROM data read events.
<b>Query Syntax</b>	<code>:SEARch:SERial:IIC:QUALifier?</code>
	The :SEARch:SERial:IIC:QUALifier? query returns the current data value qualifier setting.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code> <code>&lt;value&gt; ::= {EQU   NOT   LESS   GRE}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li><li><a href="#">":SEARch:SERial:IIC:MODE"</a> on page 1261</li><li><a href="#">":SEARch:SERial:IIC:PATTern:DATA"</a> on page 1264</li></ul>

## :SEARch:SERial:LIN Commands

**Table 149** :SEARch:SERial:LIN Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:LIN:ID <value> (see <a href="#">page 1268</a> )	:SEARch:SERial:LIN:ID ? (see <a href="#">page 1268</a> )	<value> ::= 7-bit integer in decimal, <nondecimal>, or <string> from 0-63 or 0x00-0x3f <nondecimal> ::= #Hnn where n ::= {0,...,9   A,...,F} for hexadecimal <nondecimal> ::= #Bnn...n where n ::= {0   1} for binary <string> ::= "0xnn" where n ::= {0,...,9   A,...,F} for hexadecimal
:SEARch:SERial:LIN:MO DE <value> (see <a href="#">page 1269</a> )	:SEARch:SERial:LIN:MO DE? (see <a href="#">page 1269</a> )	<value> ::= {ID   DATA   ERRor}
:SEARch:SERial:LIN:PA TTern:DATA <string> (see <a href="#">page 1270</a> )	:SEARch:SERial:LIN:PA TTern:DATA? (see <a href="#">page 1270</a> )	When :SEARch:SERial:LIN:PATTern:FORMat DECimal, <string> ::= "n" where n ::= 32-bit integer in unsigned decimal, returns "\$" if data has any don't cares When :SEARch:SERial:LIN:PATTern:FORMat HEX, <string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X }
:SEARch:SERial:LIN:PA TTern:DATA:LENGTH <length> (see <a href="#">page 1271</a> )	:SEARch:SERial:LIN:PA TTern:DATA:LENGTH? (see <a href="#">page 1271</a> )	<length> ::= integer from 1 to 8 in NR1 format
:SEARch:SERial:LIN:PA TTern:FORMAT <base> (see <a href="#">page 1272</a> )	:SEARch:SERial:LIN:PA TTern:FORMAT? (see <a href="#">page 1272</a> )	<base> ::= {HEX   DECimal}
:SEARch:SERial:LIN:SY MBolic:FRAMe <name> (see <a href="#">page 1273</a> )	:SEARch:SERial:LIN:SY MBolic:FRAMe? (see <a href="#">page 1273</a> )	<name> ::= quoted ASCII string
:SEARch:SERial:LIN:SY MBolic:SIGNal <name> (see <a href="#">page 1274</a> )	:SEARch:SERial:LIN:SY MBolic:SIGNal? (see <a href="#">page 1274</a> )	<name> ::= quoted ASCII string
:SEARch:SERial:LIN:SY MBolic:VALue <data> (see <a href="#">page 1275</a> )	:SEARch:SERial:LIN:SY MBolic:VALue? (see <a href="#">page 1275</a> )	<data> ::= value in NR3 format

## :SEARch:SERial:LIN:ID

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:LIN:ID &lt;value&gt;</code>
	<code>&lt;value&gt; ::= 7-bit integer in decimal, &lt;nondecimal&gt;, or &lt;string&gt;</code> <code>                  from 0-63 or 0x00-0x3f</code>
	<code>&lt;nondecimal&gt; ::= #Hnn where n ::= {0,...,9   A,...,F} for hexadecimal</code>
	<code>&lt;nondecimal&gt; ::= #Bnn...n where n ::= {0   1} for binary</code>
	<code>&lt;string&gt; ::= "0xnn" where n ::= {0,...,9   A,...,F} for hexadecimal</code>
	The :SEARch:SERial:LIN:ID command specifies the frame ID value when searching for LIN events.
<b>Query Syntax</b>	<code>:SEARch:SERial:LIN:ID?</code>
	The :SEARch:SERial:LIN:ID? query returns the current frame ID setting.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code>
	<code>&lt;value&gt; ::= 7-bit integer in decimal</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li><li><a href="#">":SEARch:SERial:LIN:MODE"</a> on page 1269</li></ul>

## :SEARch:SERial:LIN:MODE

**N** (see [page 1666](#))

**Command Syntax** :SEARch:SERial:LIN:MODE <value>

<value> ::= { ID | DATA | ERRor | FRAMe | FSIGnal }

The :SEARch:SERial:LIN:MODE command selects the type of LIN information to find in the Lister display:

- ID – searches for a frame ID.
- DATA – searches for a frame ID and data.
- ERRor – searches for errors.
- FRAMe – searches for symbolic frames.
- FSIGnal – searched for symbolic frames and a signal values.

Frame IDs are specified using the :SEARch:SERial:LIN:ID command.

Data values are specified using the :SEARch:SERial:LIN:PATTern:DATA command.

Frames, signals, and signal values are specified using the :SEARch:SERial:LIN:SYMBolic:FRAMe, :SEARch:SERial:LIN:SYMBolic:SIGNal, and :SEARch:SERial:LIN:SYMBolic:VALue commands. LIN symbolic data files are loaded (recalled) using the :RECall:LDF[:STARt] command.

**Query Syntax** :SEARch:SERial:LIN:MODE?

The :SEARch:SERial:LIN:MODE? query returns the currently selected mode.

**Return Format** <value><NL>

<value> ::= { ID | DATA | ERR | FRAM | FSIG }

**See Also** • [Chapter 34](#), “:SEARch Commands,” starting on page 1201

- “[:SEARch:SERial:LIN:ID](#)” on page 1268
- “[:SEARch:SERial:LIN:PATTern:DATA](#)” on page 1270
- “[:RECall:LDF\[:STARt\]](#)” on page 867
- “[:SEARch:SERial:LIN:SYMBolic:FRAMe](#)” on page 1273
- “[:SEARch:SERial:LIN:SYMBolic:SIGNal](#)” on page 1274
- “[:SEARch:SERial:LIN:SYMBolic:VALue](#)” on page 1275

## :SEARCh:SERial:LIN:PATTERn:DATA

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARCh:SERial:LIN:PATTERn:DATA &lt;string&gt;</code>
	When :SEARCh:SERial:LIN:PATTERn:FORMAT DECimal, <code>&lt;string&gt; ::= "n"</code> where n ::= 32-bit integer in unsigned decimal
	When :SEARCh:SERial:LIN:PATTERn:FORMAT HEX, <code>&lt;string&gt; ::= "0xnn...n"</code> where n ::= {0,...,9   A,...,F   X}
	The :SEARCh:SERial:LIN:PATTERn:DATA command specifies the data value when searching for LIN events.
	The number base of the value entered with this command is specified using the :SEARCh:SERial:LIN:PATTERn:FORMAT command. To set don't care values with the DATA command, the FORMAT must be HEX.
	The length of the data value entered is specified using the :SEARCh:SERial:LIN:PATTERn:DATA:LENGTH command.
<b>Query Syntax</b>	<code>:SEARCh:SERial:LIN:PATTERn:DATA?</code>
	The :SEARCh:SERial:LIN:PATTERn:DATA? query returns the current data value setting.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code>
	When :SEARCh:SERial:LIN:PATTERn:FORMAT DECimal, <code>&lt;string&gt; ::= "n"</code> where n ::= 32-bit integer in unsigned decimal or "\$" if data has any don't cares
	When :SEARCh:SERial:LIN:PATTERn:FORMAT HEX, <code>&lt;string&gt; ::= "0xnn...n"</code> where n ::= {0,...,9   A,...,F   X}
<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">Chapter 34</a>, “:SEARCh Commands,” starting on page 1201</li> <li>• <a href="#">":SEARCh:SERial:LIN:MODE"</a> on page 1269</li> <li>• <a href="#">":SEARCh:SERial:LIN:PATTERn:FORMAT"</a> on page 1272</li> <li>• <a href="#">":SEARCh:SERial:LIN:PATTERn:DATA:LENGTH"</a> on page 1271</li> </ul>

## :SEARch:SERial:LIN:PATTern:DATA:LENGth

**N** (see [page 1666](#))

**Command Syntax** :SEARch:SERial:LIN:PATTern:DATA:LENGth <length>  
<length> ::= integer from 1 to 8 in NR1 format

The :SEARch:SERial:LIN:PATTern:DATA:LENGth command specifies the the length of the data value when searching for LIN events.

The data value is specified using the :SEARch:SERial:LIN:PATTern:DATA command.

**Query Syntax** :SEARch:SERial:LIN:PATTern:DATA:LENGth?

The :SEARch:SERial:LIN:PATTern:DATA:LENGth? query returns the current data value length setting.

**Return Format** <length><NL>  
<length> ::= integer from 1 to 8 in NR1 format

**See Also** • [Chapter 34](#), “:SEARch Commands,” starting on page 1201  
• [“:SEARch:SERial:LIN:PATTern:DATA”](#) on page 1270

## :SEARch:SERial:LIN:PATTern:FORMAT

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:LIN:PATTern:FORMAT <base>`  
                  `<base> ::= {HEX | DECimal}`

The :SEARch:SERial:LIN:PATTern:FORMAT command specifies the number base used with the :SEARch:SERial:LIN:PATTern:DATA command.

**Query Syntax**    `:SEARch:SERial:LIN:PATTern:FORMAT?`

The :SEARch:SERial:LIN:PATTern:FORMAT? query returns the current number base setting.

**Return Format**    `<base><NL>`  
                  `<base> ::= {HEX | DEC}`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:SERial:LIN:PATTern:DATA"](#) on page 1270

## :SEARch:SERial:LIN:SYMBolic:FRAMe

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:LIN:SYMBolic:FRAMe <name>`  
`<name> ::= quoted ASCII string`

The :SEARch:SERial:LIN:SYMBolic:FRAMe command specifies the message to search for when LIN symbolic data has been loaded (recalled) into the oscilloscope and the LIN serial search mode is set to FRAMe or FSIGnAl.

**Query Syntax**    `:SEARch:SERial:LIN:SYMBolic:FRAMe?`

The :SEARch:SERial:LIN:SYMBolic:FRAMe? query returns the specified message.

**Return Format**    `<name><NL>`  
`<name> ::= quotes ASCII string`

**See Also**

- [":RECall:LDF\[:STARt\]" on page 867](#)
- [":SEARch:SERial:LIN:MODE" on page 1269](#)
- [":SEARch:SERial:LIN:SYMBolic:SIGNAl" on page 1274](#)
- [":SEARch:SERial:LIN:SYMBolic:VALue" on page 1275](#)

## :SEARch:SERial:LIN:SYMBolic:SIGNal

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:LIN:SYMBolic:SIGNal <name>`  
                  `<name> ::= quoted ASCII string`

The :SEARch:SERial:LIN:SYMBolic:SIGNal command specifies the signal to search for when LIN symbolic data has been loaded (recalled) into the oscilloscope and the LIN serial search mode is set to FSIGnal.

**Query Syntax**    `:SEARch:SERial:LIN:SYMBolic:SIGNal?`

The :SEARch:SERial:LIN:SYMBolic:SIGNal? query returns the specified signal.

**Return Format**    `<name><NL>`  
                  `<name> ::= quoted ASCII string`

**See Also**

- "[:RECall:LDF\[:STARt\]](#)" on page 867
- "[:SEARch:SERial:LIN:MODE](#)" on page 1269
- "[:SEARch:SERial:LIN:SYMBolic:FRAMe](#)" on page 1273
- "[:SEARch:SERial:LIN:SYMBolic:VALue](#)" on page 1275

## :SEARch:SERial:LIN:SYMBolic:VALue

**N** (see [page 1666](#))

**Command Syntax**

```
:SEARch:SERial:LIN:SYMBolic:VALue <data>
<data> ::= value in NR3 format
```

The :SEARch:SERial:LIN:SYMBolic:VALue command specifies the signal value to search for when LIN symbolic data has been loaded (recalled) into the oscilloscope and the LIN serial search mode is set to FSIGnal.

### NOTE

Encoded signal values are not supported in the remote interface (even though they can be used in the front panel graphical interface).

**Query Syntax**

```
:SEARch:SERial:LIN:SYMBolic:VALue?
```

The :SEARch:SERial:LIN:SYMBolic:VALue? query returns the specified signal value.

**Return Format**

```
<data><NL>
```

```
<data> ::= value in NR3 format
```

**See Also**

- "[:RECall:LDF\[:STARt\]](#)" on page 867
- "[:SEARch:SERial:LIN:MODE](#)" on page 1269
- "[:SEARch:SERial:LIN:SYMBolic:FRAME](#)" on page 1273
- "[:SEARch:SERial:LIN:SYMBolic:SIGNal](#)" on page 1274

## :SEARch:SERial:M1553 Commands

**Table 150** :SEARch:SERial:M1553 Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:M1553:MODE <value> (see page 1277)	:SEARch:SERial:M1553:MODE? (see page 1277)	<value> ::= {DSTARt   CSTArt   RTA   RTA11   PERRor   SERRor   MERRor}
:SEARch:SERial:M1553:PATTERn:DATA <string> (see page 1278)	:SEARch:SERial:M1553:PATTERn:DATA? (see page 1278)	<string> ::= "nn...n" where n ::= {0   1}
:SEARch:SERial:M1553:RTA <value> (see page 1279)	:SEARch:SERial:M1553:RTA? (see page 1279)	<value> ::= 5-bit integer in decimal, <hexadecimal>, <binary>, or <string> from 0-31 <hexadecimal> ::= #Hnn where n ::= {0,...,9 A,...,F} <binary> ::= #Bnn...n where n ::= {0   1} for binary <string> ::= "0xnn" where n ::= {0,...,9 A,...,F}

## :SEARch:SERial:M1553:MODE

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:M1553:MODE <value>`  
`<value> ::= {DSTArt | CSTArt | RTA | RTA11 | PERRor | SERRor | MERRor}`

The :SEARch:SERial:M1553:MODE command selects the type of MIL-STD-1553 information to find in the Lister display:

- DSTArt – searches for the start of a Data word (at the end of a valid Data Sync pulse).
- CSTArt – searches for the start of a Command/Status word (at the end of a valid C/S Sync pulse).
- RTA – searches for the Remote Terminal Address (RTA) of a Command/Status word.
- RTA11 – searches for the Remote Terminal Address (RTA) and the additional 11 bits of a Command/Status word.
- PERRor – searches for (odd) parity errors for the data in the word.
- SERRor – searches for invalid Sync pulses.
- MERRor – searches for Manchester encoding errors.

In the RTA or RTA11 modes, the Remote Terminal Address is specified using the :SEARch:SERial:M1553:RTA command.

In the RTA11 mode, the additional 11 bits are specified using the :SEARch:SERial:M1553:PATTERn:DATA command.

**Query Syntax**    `:SEARch:SERial:M1553:MODE?`

The :SEARch:SERial:M1553:MODE? query returns the currently selected mode.

**Return Format**    `<value><NL>`  
`<value> ::= {DSTA | CSTA | RTA | RTA11 | PERR | SERR | MERR}`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:SERial:M1553:RTA"](#) on page 1279
- [":SEARch:SERial:M1553:PATTERn:DATA"](#) on page 1278

**:SEARch:SERial:M1553:PATTern:DATA**

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:M1553:PATTern:DATA <string>`  
`<string> ::= "nn...n" where n ::= {0 | 1}`

The :SEARch:SERial:M1553:PATTern:DATA command specifies the additional 11 bits when searching for the MIL-STD-1553 Remote Terminal Address + 11 Bits.

**Query Syntax**    `:SEARch:SERial:M1553:PATTern:DATA?`

The :SEARch:SERial:M1553:PATTern:DATA? query returns the current value setting for the additional 11 bits.

**Return Format**    `<string><NL>`  
`<string> ::= "nn...n" where n ::= {0 | 1}`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:SERial:M1553:MODE"](#) on page 1277

## :SEARch:SERial:M1553:RTA

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:M1553:RTA &lt;value&gt;</code>
	<pre>&lt;value&gt; ::= 5-bit integer in decimal, &lt;hexadecimal&gt;, &lt;binary&gt;,            or &lt;string&gt; from 0-31</pre>
	<pre>&lt;hexadecimal&gt; ::= #Hnn where n ::= {0,...,9 A,...,F}</pre>
	<pre>&lt;binary&gt; ::= #Bnn...n where n ::= {0   1} for binary</pre>
	<pre>&lt;string&gt; ::= "0xnn" where n ::= {0,...,9 A,...,F}</pre>
	The :SEARch:SERial:M1553:RTA command specifies the Remote Terminal Address (RTA) value when searching for MIL-STD-1553 events.
<b>Query Syntax</b>	<code>:SEARch:SERial:M1553:RTA?</code>
	The :SEARch:SERial:M1553:RTA? query returns the current Remote Terminal Address value setting.
<b>Return Format</b>	<pre>&lt;value&gt;&lt;NL&gt;</pre>
	<pre>&lt;value&gt; ::= 5-bit integer in decimal from 0-31</pre>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li> </ul>

## :SEARch:SERial:SENT Commands

**Table 151** :SEARch:SERial:SENT Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:SENT:F AST:DATA <string> (see <a href="#">page 1281</a> )	:SEARch:SERial:SENT:F AST:DATA? (see <a href="#">page 1281</a> )	<string> ::= "0xn..." where n ::= {0,...,9   A,...,F   X   \$}
:SEARch:SERial:SENT:M ODE <mode> (see <a href="#">page 1282</a> )	:SEARch:SERial:SENT:M ODE? (see <a href="#">page 1282</a> )	<mode> ::= {FCData   SCMid   SCData   CRCerror PPERror}
:SEARch:SERial:SENT:S LOW:DATA <data> (see <a href="#">page 1283</a> )	:SEARch:SERial:SENT:S LOW:DATA? (see <a href="#">page 1283</a> )	<data> ::= from -1 (don't care) to 65535, in NR1 format.
:SEARch:SERial:SENT:S LOW:ID <id> (see <a href="#">page 1284</a> )	:SEARch:SERial:SENT:S LOW:ID? (see <a href="#">page 1284</a> )	<id> ::= from -1 (don't care) to 255, in NR1 format.

## :SEARch:SERial:SENT:FAST:DATA

**N** (see [page 1666](#))

<b>Command Syntax</b>	<pre>:SEARch:SERial:SENT:FAST:DATA &lt;string&gt; &lt;string&gt; ::= "0xn..." where n ::= {0,...,9   A,...,F   X   \$}</pre>
	The :SEARch:SERial:SENT:FAST:DATA command specifies the status and data nibbles that will be searched for when the FCData search mode is chosen.
<b>Query Syntax</b>	<pre>:SEARch:SERial:SENT:FAST:DATA?</pre>
	The :SEARch:SERial:SENT:FAST:DATA? query returns the fast channel data search value setting.
<b>Return Format</b>	<pre>&lt;string&gt;&lt;NL&gt; &lt;string&gt; ::= "0xn..." where n ::= {0,...,9   A,...,F   X   \$}</pre>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":SEARch:SERial:SENT:MODE" on page 1282</a></li><li><a href="#">":SEARch:SERial:SENT:SLOW:DATA" on page 1283</a></li><li><a href="#">":SEARch:SERial:SENT:SLOW:ID" on page 1284</a></li></ul>

## :SEARch:SERial:SENT:MODE

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:SENT:MODE <mode>`

`<mode> ::= {FCData | SCMid | SCData | CRCerror | PPERror}`

When SENT serial decode is turned on and displayed in the Lister, the :SEARch:SERial:SENT:MODE command specifies what to search for in the decoded data:

- FCData – finds Fast Channel data nibbles that match the values entered using additional softkeys.
- SCMid – finds Slow Channel Message IDs that match the value entered using additional softkeys.
- SCData – finds Slow Channel Message IDs and Data that match the values entered using additional softkeys.
- CRCerror – finds any CRC error, Fast or Slow.
- PPERror – finds where a nibble is either too wide or too narrow (for example, data nibble < 12 (11.5) or > 27 (27.5) ticks wide). Sync, S&C, data, or checksum pulse periods are checked.

**Query Syntax**    `:SEARch:SERial:SENT:MODE?`

The :SEARch:SERial:SENT:MODE? query returns the search mode setting.

**Return Format**    `<mode><NL>`

`<mode> ::= {FCD | SCM | SCD | CRC | PPER}`

**See Also**

- "[:SEARch:SERial:SENT:FAST:DATA](#)" on page 1281
- "[:SEARch:SERial:SENT:SLOW:DATA](#)" on page 1283
- "[:SEARch:SERial:SENT:SLOW:ID](#)" on page 1284

## :SEARch:SERial:SENT:SLOW:DATA

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:SENT:SLOW:DATA &lt;data&gt;</code> <code>&lt;data&gt; ::= from -1 (don't care) to 65535, in NR1 format.</code>
	The :SEARch:SERial:SENT:SLOW:DATA command specifies the data to search for in the Slow Channel Message ID and Data search mode.
<b>Query Syntax</b>	<code>:SEARch:SERial:SENT:SLOW:DATA?</code>
	The :SEARch:SERial:SENT:SLOW:DATA? query returns the slow channel data search value setting.
<b>Return Format</b>	<code>&lt;data&gt;&lt;NL&gt;</code> <code>&lt;data&gt; ::= from -1 (don't care) to 65535, in NR1 format.</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":SEARch:SERial:SENT:FAST:DATA"</a> on page 1281</li><li><a href="#">":SEARch:SERial:SENT:MODE"</a> on page 1282</li><li><a href="#">":SEARch:SERial:SENT:SLOW:ID"</a> on page 1284</li></ul>

## :SEARch:SERial:SENT:SLOW:ID

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:SENT:SLOW:ID <id>`

`<id> ::= from -1 (don't care) to 255, in NR1 format.`

The :SEARch:SERial:SENT:SLOW:ID command specifies the ID to search for in the "Slow Channel Message ID" and "Slow Channel Message ID & Data" trigger modes. The ID can be from -1 (don't care) to 255 (depending on the message length).

**Query Syntax**    `:SEARch:SERial:SENT:SLOW:ID?`

The :SEARch:SERial:SENT:SLOW:ID? query returns the slow channel ID search value setting.

**Return Format**    `<id><NL>`

`<id> ::= from -1 (don't care) to 255, in NR1 format.`

**See Also**

- [":SEARch:SERial:SENT:FAST:DATA" on page 1281](#)
- [":SEARch:SERial:SENT:MODE" on page 1282](#)
- [":SEARch:SERial:SENT:SLOW:DATA" on page 1283](#)

## :SEARch:SERial:SPI Commands

**Table 152** :SEARch:SERial:SPI Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:SPI:MODE <value> (see page 1286)	:SEARch:SERial:SPI:MODE? (see page 1286)	<value> ::= {MOSI   MISO}
:SEARch:SERial:SPI:PTtern:DATA <string> (see page 1287)	:SEARch:SERial:SPI:PTtern:DATA? (see page 1287)	<string> ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X}
:SEARch:SERial:SPI:PTtern:WIDTH <width> (see page 1288)	:SEARch:SERial:SPI:PTtern:WIDTH? (see page 1288)	<width> ::= integer from 1 to 10

## :SEARch:SERial:SPI:MODE

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:SPI:MODE <value>`  
                  `<value> ::= {MOSI | MISO}`

The :SEARch:SERial:SPI:MODE command specifies whether the SPI search will be on the MOSI data or the MISO data.

Data values are specified using the :SEARch:SERial:SPI:PATTERn:DATA command.

**Query Syntax**    `:SEARch:SERial:SPI:MODE?`

The :SEARch:SERial:SPI:MODE? query returns the current SPI search mode setting.

**Return Format**    `<value><NL>`  
                  `<value> ::= {MOSI | MISO}`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:SERial:SPI:PATTERn:DATA"](#) on page 1287

## :SEARch:SERial:SPI:PATTern:DATA

**N** (see [page 1666](#))

**Command Syntax** :SEARch:SERial:SPI:PATTern:DATA <string>

<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | X}

The :SEARch:SERial:SPI:PATTern:DATA command specifies the data value when searching for SPI events.

The width of the data value is specified using the :SEARch:SERial:SPI:PATTern:WIDTh command.

**Query Syntax** :SEARch:SERial:SPI:PATTern:DATA?

The :SEARch:SERial:SPI:PATTern:DATA? query returns the current data value setting.

**Return Format** <string><NL>

<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | X}

**See Also** • [Chapter 34](#), “:SEARch Commands,” starting on page 1201

• [“:SEARch:SERial:SPI:PATTern:WIDTh”](#) on page 1288

## :SEARch:SERial:SPI:PATTERn:WIDTh

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:SPI:PATTERn:WIDTh <width>`  
                  `<width> ::= integer from 1 to 10`

The :SEARch:SERial:SPI:PATTERn:WIDTh command specifies the width of the data value (in bytes) when searching for SPI events.

The data value is specified using the :SEARch:SERial:SPI:PATTERn:DATA command.

**Query Syntax**    `:SEARch:SERial:SPI:PATTERn:WIDTh?`

The :SEARch:SERial:SPI:PATTERn:WIDTh? query returns the current data width setting.

**Return Format**    `<width><NL>`  
                  `<width> ::= integer from 1 to 10`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:SERial:SPI:PATTERn:DATA"](#) on page 1287

## :SEARch:SERial:UART Commands

**Table 153** :SEARch:SERial:UART Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:UART:D ATA <value> (see <a href="#">page 1290</a> )	:SEARch:SERial:UART:D ATA? (see <a href="#">page 1290</a> )	<p>&lt;value&gt; ::= 8-bit integer from 0-255 (0x00-0xff) in decimal, &lt;hexadecimal&gt;, &lt;binary&gt;, or &lt;quoted_string&gt; format</p> <p>&lt;hexadecimal&gt; ::= #Hnn where n ::= {0,...,9  A,...,F} for hexadecimal</p> <p>&lt;binary&gt; ::= #Bnn...n where n ::= {0   1} for binary</p> <p>&lt;quoted_string&gt; ::= any of the 128 valid 7-bit ASCII characters (or standard abbreviations)</p>
:SEARch:SERial:UART:M ODE <value> (see <a href="#">page 1291</a> )	:SEARch:SERial:UART:M ODE? (see <a href="#">page 1291</a> )	<p>&lt;value&gt; ::= {RDATa   RD1   RD0   RDX   TDATa   TD1   TD0   TDX   PARityerror   AERRor}</p>
:SEARch:SERial:UART:Q UALifier <value> (see <a href="#">page 1292</a> )	:SEARch:SERial:UART:Q UALifier? (see <a href="#">page 1292</a> )	<p>&lt;value&gt; ::= {EQUal   NOTequal   GREaterthan   LESSthan}</p>

## :SEARch:SERial:UART:DATA

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:UART:DATA <value>`

`<value> ::= 8-bit integer from 0-255 (0x00-0xff) in decimal,  
                     <hexadecimal>, <binary>, or <quoted_string> format`

`<hexadecimal> ::= #Hnn where n ::= {0,...,9| A,...,F} for hexadecimal`

`<binary> ::= #Bnn...n where n ::= {0 | 1} for binary`

`<quoted_string> ::= any of the 128 valid 7-bit ASCII characters (or  
                     standard abbreviations)`

The :SEARch:SERial:UART:DATA command specifies a data value when searching for UART/RS232 events.

The data value qualifier is specified using the :SEARch:SERial:UART:QUALifier command.

**Query Syntax**    `:SEARch:SERial:UART:DATA?`

The :SEARch:SERial:UART:DATA? query returns the current data value setting.

**Return Format**    `<value><NL>`

`<value> ::= 8-bit integer from 0-255 (0x00-0xff) in decimal format`

**See Also**

- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
- [":SEARch:SERial:UART:MODE"](#) on page 1291
- [":SEARch:SERial:UART:QUALifier"](#) on page 1292

## :SEARch:SERial:UART:MODE

**N** (see [page 1666](#))

**Command Syntax** :SEARch:SERial:UART:MODE <value>

```
<value> ::= {RDATA | RD1 | RD0 | RDX | TDATA | TD1 | TD0 | TDX
             | PARityerror | AERRor}
```

The :SEARch:SERial:UART:MODE command selects the type of UART/RS232 information to find in the Lister display:

- RDATA – searches for a receive data value when data words are from 5 to 8 bits long.
- RD1 – searches for a receive data value when data words are 9 bits long and the 9th (alert) bit is 1.
- RD0 – searches for a receive data value when data words are 9 bits long and the 9th (alert) bit is 0.
- RDX – searches for a receive data value when data words are 9 bits long and the 9th (alert) bit is a don't care (X).
- TDATA – searches for a transmit data value when data words are from 5 to 8 bits long.
- TD1 – searches for a transmit data value when data words are 9 bits long and the 9th (alert) bit is 1.
- TD0 – searches for a transmit data value when data words are 9 bits long and the 9th (alert) bit is 0.
- TDX – searches for a transmit data value when data words are 9 bits long and the 9th (alert) bit is a don't care (X).
- PARityerror – searches for parity errors.
- AERRor – searches for any error.

Data values are specified using the :SEARch:SERial:UART:DATA command.

Data value qualifiers are specified using the :SEARch:SERial:UART:QUALifier command.

**Query Syntax** :SEARch:SERial:UART:MODE?

The :SEARch:SERial:UART:MODE? query returns ...

**Return Format** <value><NL>

```
<value> ::= {RDAT | RD1 | RD0 | RDX | TDAT | TD1 | TD0 | TDX | PAR
             | AERR}
```

- See Also**
- [Chapter 34](#), “:SEARch Commands,” starting on page 1201
  - “[:SEARch:SERial:UART:DATA](#)” on page 1290
  - “[:SEARch:SERial:UART:QUALifier](#)” on page 1292

## :SEARch:SERial:UART:QUALifier

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:UART:QUALifier &lt;value&gt;</code> <code>&lt;value&gt; ::= {EQUal   NOTequal   GREaterthan   LESSthan}</code>
	The :SEARch:SERial:UART:QUALifier command specifies the data value qualifier when searching for UART/RS232 events.
<b>Query Syntax</b>	<code>:SEARch:SERial:UART:QUALifier?</code>
	The :SEARch:SERial:UART:QUALifier? query returns the current data value qualifier setting.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code> <code>&lt;value&gt; ::= {EQU   NOT   GRE   LESS}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">Chapter 34</a>, “:SEARch Commands,” starting on page 1201</li><li><a href="#">":SEARch:SERial:UART:DATA"</a> on page 1290</li></ul>

## :SEARch:SERial:USB Commands

**Table 154** :SEARch:SERial:USB Commands Summary

Command	Query	Options and Query Returns
:SEARch:SERial:USB:MO DE <condition> (see <a href="#">page 1295</a> )	:SEARch:SERial:USB:MO DE? (see <a href="#">page 1295</a> )	<event> ::= {TOKen   DATA   HANDshake   SPECial   ALLerrors   PIDerror   CRC5error   CRC16error   GLITCHerror   STUFFerror   SE1error}
:SEARch:SERial:USB:AD DResS <string> (see <a href="#">page 1296</a> )	:SEARch:SERial:USB:AD DResS? (see <a href="#">page 1296</a> )	<string> ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}
:SEARch:SERial:USB:CR C <string> (see <a href="#">page 1297</a> )	:SEARch:SERial:USB:CR C? (see <a href="#">page 1297</a> )	<string> ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}
:SEARch:SERial:USB:DA TA <string> (see <a href="#">page 1298</a> )	:SEARch:SERial:USB:DA TA? (see <a href="#">page 1298</a> )	<string> ::= "0xn..." where n ::= {0,...,9   A,...,F   X   \$}
:SEARch:SERial:USB:DA TA:LENGTH <value> (see <a href="#">page 1299</a> )	:SEARch:SERial:USB:DA TA:LENGTH? (see <a href="#">page 1299</a> )	<length> ::= data length between 1-20
:SEARch:SERial:USB:EN DPoint <string> (see <a href="#">page 1300</a> )	:SEARch:SERial:USB:EN DPoint? (see <a href="#">page 1300</a> )	<string> ::= "0xn" where n ::= {0,...,9   A,...,F   X   \$}
:SEARch:SERial:USB:ET <string> (see <a href="#">page 1301</a> )	:SEARch:SERial:USB:ET ? (see <a href="#">page 1301</a> )	<string> ::= "0xn" where n ::= {0   1   2   3   X   \$}
:SEARch:SERial:USB:FR AMe <string> (see <a href="#">page 1302</a> )	:SEARch:SERial:USB:FR AMe? (see <a href="#">page 1302</a> )	<string> ::= "0xnnn" where n ::= {0,...,9   A,...,F   X   \$}
:SEARch:SERial:USB:HA DDress <string> (see <a href="#">page 1303</a> )	:SEARch:SERial:USB:HA DDress? (see <a href="#">page 1303</a> )	<string> ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}
:SEARch:SERial:USB:PI D:DATA <pid> (see <a href="#">page 1304</a> )	:SEARch:SERial:USB:PI D:DATA? (see <a href="#">page 1304</a> )	<pid> ::= {DATA0   DATA1   DATA2   MDATA}
:SEARch:SERial:USB:PI D:HANDshake <pid> (see <a href="#">page 1305</a> )	:SEARch:SERial:USB:PI D:HANDshake? (see <a href="#">page 1305</a> )	<pid> ::= {ACK   NAK   STALL   NYET}
:SEARch:SERial:USB:PI D:SPECial <pid> (see <a href="#">page 1306</a> )	:SEARch:SERial:USB:PI D:SPECial? (see <a href="#">page 1306</a> )	<pid> ::= {PING   PRE   ERR   SPLIt}

**Table 154** :SEARch:SERial:USB Commands Summary (continued)

Command	Query	Options and Query Returns
:SEARch:SERial:USB:PI D:TOKen <pid> (see <a href="#">page 1307</a> )	:SEARch:SERial:USB:PI D:TOKen? (see <a href="#">page 1307</a> )	<pid> ::= {OUT   IN   SETup   SOF}
:SEARch:SERial:USB:PO RT <string> (see <a href="#">page 1308</a> )	:SEARch:SERial:USB:PO RT? (see <a href="#">page 1308</a> )	<string> ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}
:SEARch:SERial:USB:SC <string> (see <a href="#">page 1309</a> )	:SEARch:SERial:USB:SC ? (see <a href="#">page 1309</a> )	<string> ::= "0xn" where n ::= {0   1   X   \$}
:SEARch:SERial:USB:SE U <string> (see <a href="#">page 1310</a> )	:SEARch:SERial:USB:SE U? (see <a href="#">page 1310</a> )	<string> ::= "0xn" where n ::= {0   1   2   3   X   \$}

## :SEARch:SERial:USB:MODE

**N** (see [page 1666](#))

**Command Syntax** :SEARch:SERial:USB:MODE <mode>

```
<mode> ::= {TOKen | DATA | HANDshake | SPECial | ALLerrors
             | PIDerror | CRC5error | CRC16error | GLITcherror
             | STUFFerror | SE1error}
```

The :SEARch:SERial:USB:MODE command specifies the USB search mode.

**Query Syntax** :SEARch:SERial:USB:MODE?

The :SEARch:SERial:USB:MODE? query returns the specified USB search mode.

**Return Format** <mode><NL>

```
<mode> ::= {TOK | DATA | HAND | SPEC | ALL | PID | CRC5
             | CRC16 | GLIT | STUFF | SE1}
```

- See Also**
- "[:SEARch:SERial:USB:PID:DATA](#)" on page 1304
  - "[:SEARch:SERial:USB:PID:HANDshake](#)" on page 1305
  - "[:SEARch:SERial:USB:PID:SPECial](#)" on page 1306
  - "[:SEARch:SERial:USB:PID:TOKen](#)" on page 1307

## :SEARch:SERial:USB:ADDRess

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:USB:ADDRess &lt;string&gt;</code> <code>&lt;string&gt; ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}</code>
	The :SEARch:SERial:USB:ADDRess command specifies the 7-bit Address portion of the search value, in hex.
<b>Query Syntax</b>	<code>:SEARch:SERial:USB:ADDRess?</code>
	The :SEARch:SERial:USB:ADDRess? query returns the specified Address portion of the search value.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code> <code>&lt;string&gt; ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":SEARch:SERial:USB:PID:SPEcial"</a> on page 1306</li><li><a href="#">":SEARch:SERial:USB:PID:TOKen"</a> on page 1307</li></ul>

## :SEARch:SERial:USB:CRC

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:USB:CRC &lt;string&gt;</code> <code>&lt;string&gt; ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}</code>
	The :SEARch:SERial:USB:CRC command specifies the CRC portion of the search value, in hex.
<b>Query Syntax</b>	<code>:SEARch:SERial:USB:CRC?</code>
	The :SEARch:SERial:USB:CRC? query returns the specified CRC portion of the search value.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code> <code>&lt;string&gt; ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":SEARch:SERial:USB:PID:SPECial"</a> on page 1306</li><li><a href="#">":SEARch:SERial:USB:PID:TOKen"</a> on page 1307</li></ul>

## :SEARch:SERial:USB:DATA

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:USB:DATA <string>`

`<string> ::= "0xn..." where n ::= {0,...,9 | A,...,F | X | $}`

The :SEARch:SERial:USB:DATA command specifies the Data portion of the search value, in hex.

See the :SEARch:SERial:USB:DATA:LENGth command for setting the length of the data value.

**Query Syntax**    `:SEARch:SERial:USB:DATA?`

The :SEARch:SERial:USB:DATA? query returns the specified Data portion of the search value.

**Return Format**    `<string><NL>`

`<string> ::= "0xn..." where n ::= {0,...,9 | A,...,F | X | $}`

**See Also**    • [":SEARch:SERial:USB:DATA:LENGth" on page 1299](#)

## :SEARch:SERial:USB:DATA:LENGth

**N** (see [page 1666](#))

- Command Syntax**    `:SEARch:SERial:USB:DATA:LENGth <length>`  
`<length> ::= data length between 1-20`
- The :SEARch:SERial:USB:DATA:LENGth command specifies the data length in bytes.
- Query Syntax**    `:SEARch:SERial:USB:DATA:LENGth?`
- The :SEARch:SERial:USB:DATA:LENGth? query returns the specified data length.
- Return Format**    `<length><NL>`  
`<length> ::= data length between 1-20`
- See Also**    • [":SEARch:SERial:USB:DATA"](#) on page 1298

## :SEARch:SERial:USB:ENDPoint

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:USB:ENDPoint &lt;string&gt;</code> <code>&lt;string&gt; ::= "0xn" where n ::= {0,...,9   A,...,F   x   \$}</code>
	The :SEARch:SERial:USB:ENDPoint command specifies the 4-bit Endpoint portion of the search value, in hex.
<b>Query Syntax</b>	<code>:SEARch:SERial:USB:ENDPoint?</code>
	The :SEARch:SERial:USB:ENDPoint? query returns the specified Endpoint portion of the search value.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code> <code>&lt;string&gt; ::= "0xn" where n ::= {0,...,9   A,...,F   x   \$}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":SEARch:SERial:USB:PID:SPEcial"</a> on page 1306</li><li><a href="#">":SEARch:SERial:USB:PID:TOKen"</a> on page 1307</li></ul>

## :SEARch:SERial:USB:ET

**N** (see [page 1666](#))

**Command Syntax** :SEARch:SERial:USB:ET <string>

```
<string> ::= "0xn" where n ::= {0 | 1 | 2 | 3 | X | $}
```

The :SEARch:SERial:USB:ET command specifies the 2-bit ET portion of the search value, in hex.

**Query Syntax** :SEARch:SERial:USB:ET?

The :SEARch:SERial:USB:ET? query returns the specified ET portion of the search value.

**Return Format** <string><NL>

```
<string> ::= "0xn" where n ::= {0 | 1 | 2 | 3 | X | $}
```

**See Also** • [":SEARch:SERial:USB:PID:SPECial"](#) on page 1306

## :SEARch:SERial:USB:FRAMe

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:USB:FRAMe &lt;string&gt;</code> <code>&lt;string&gt; ::= "0xnnn" where n ::= {0,...,9   A,...,F   X   \$}</code>
	The :SEARch:SERial:USB:FRAMe command specifies the 11-bit Frame portion of the search value, in hex.
<b>Query Syntax</b>	<code>:SEARch:SERial:USB:FRAMe?</code>
	The :SEARch:SERial:USB:FRAMe? query returns the specified Frame portion of the search value.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code> <code>&lt;string&gt; ::= "0xnnn" where n ::= {0,...,9   A,...,F   X   \$}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":SEARch:SERial:USB:PID:TOKen" on page 1307</a></li></ul>

## :SEARch:SERial:USB:HADDress

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:USB:HADDress &lt;string&gt;</code> <code>&lt;string&gt; ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}</code>
	The :SEARch:SERial:USB:HADDress command specifies the 7-bit Hub Address portion of the search value, in hex.
<b>Query Syntax</b>	<code>:SEARch:SERial:USB:HADDress?</code>
	The :SEARch:SERial:USB:HADDress? query returns the specified Hub Address portion of the search value.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code> <code>&lt;string&gt; ::= "0xnn" where n ::= {0,...,9   A,...,F   X   \$}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":SEARch:SERial:USB:PID:SPECial"</a> on page 1306</li></ul>

## :SEARch:SERial:USB:PID:DATA

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:USB:PID:DATA <pid>`  
`<pid> ::= {DATA0 | DATA1 | DATA2 | MDATA}`

The :SEARch:SERial:USB:PID:DATA command specifies the USB data PID to find.

The DATA USB search mode can be selected using the :SEARch:SERial:USB:MODE command.

**Query Syntax**    `:SEARch:SERial:USB:PID:DATA?`

The :SEARch:SERial:USB:PID:DATA? query returns the specified data PID.

**Return Format**    `<pid><NL>`  
`<pid> ::= {DATA0 | DATA1 | DATA2 | MDAT}`

**See Also**    - [":SEARch:SERial:USB:MODE" on page 1295](#)

## :SEARch:SERial:USB:PID:HANDshake

**N** (see [page 1666](#))

**Command Syntax** :SEARch:SERial:USB:PID:HANDshake <pid>

<pid> ::= {ACK | NAK | STALL | NYET}

The :SEARch:SERial:USB:PID:HANDshake command specifies the USB handshake PID to find.

The HANDshake USB search mode can be selected using the :SEARch:SERial:USB:MODE command.

**Query Syntax** :SEARch:SERial:USB:PID:HANDshake?

The :SEARch:SERial:USB:PID:HANDshake? query returns the specified handshake PID.

**Return Format** <pid><NL>

<pid> ::= {ACK | NAK | STAL | NYET}

**See Also** • "[:SEARch:SERial:USB:MODE](#)" on page 1295

## :SEARch:SERial:USB:PID:SPECial

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:USB:PID:SPECial <pid>`  
`<pid> ::= {PING | PRE | ERR | SPL}`

The :SEARch:SERial:USB:PID:SPECial command specifies the USB special PID to find.

The SPECial USB search mode can be selected using the :SEARch:SERial:USB:MODE command.

**Query Syntax**    `:SEARch:SERial:USB:PID:SPECial?`

The :SEARch:SERial:USB:PID:SPECial? query returns the specified special PID.

**Return Format**    `<pid><NL>`  
`<pid> ::= {PING | PRE | ERR | SPL}`

**See Also**    • [":SEARch:SERial:USB:MODE" on page 1295](#)

## :SEARch:SERial:USB:PID:TOKen

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:USB:PID:TOKen <pid>`

`<pid> ::= {OUT | IN | SETup | SOF}`

The :SEARch:SERial:USB:PID:TOKen command specifies the USB token PID to find.

The TOKen USB search mode can be selected using the :SEARch:SERial:USB:MODE command.

**Query Syntax**    `:SEARch:SERial:USB:PID:TOKen?`

The :SEARch:SERial:USB:PID:TOKen? query returns the specified token PID.

**Return Format**    `<pid><NL>`

`<pid> ::= {OUT | IN | SETup | SOF}`

**See Also**    · " [":SEARch:SERial:USB:MODE](#)" on page 1295

## :SEARch:SERial:USB:PORT

**N** (see [page 1666](#))

- Command Syntax**    `:SEARch:SERial:USB:PORT <string>`  
`<string> ::= "0xnn" where n ::= {0,...,9 | A,...,F | X | $}`
- The :SEARch:SERial:USB:PORT command specifies the 7-bit Port portion of the search value, in hex.
- Query Syntax**    `:SEARch:SERial:USB:PORT?`
- The :SEARch:SERial:USB:PORT? query returns the specified Port portion of the search value.
- Return Format**    `<string><NL>`  
`<string> ::= "0xnn" where n ::= {0,...,9 | A,...,F | X | $}`
- See Also**    · [":SEARch:SERial:USB:PID:SPECial"](#) on page 1306

## :SEARch:SERial:USB:SC

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SEARch:SERial:USB:SC &lt;string&gt;</code> <code>&lt;string&gt; ::= "0xn" where n ::= {0   1   X   \$}</code>
	The :SEARch:SERial:USB:SC command specifies the 1-bit SC portion of the search value, in hex.
<b>Query Syntax</b>	<code>:SEARch:SERial:USB:SC?</code>
	The :SEARch:SERial:USB:SC? query returns the specified SC portion of the search value.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code> <code>&lt;string&gt; ::= "0xn" where n ::= {0   1   X   \$}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":SEARch:SERial:USB:PID:SPECial"</a> on page 1306</li></ul>

## :SEARch:SERial:USB:SEU

**N** (see [page 1666](#))

**Command Syntax**    `:SEARch:SERial:USB:SEU <string>`

`<string> ::= "0xn" where n ::= {0 | 1 | 2 | 3 | X | $}`

The :SEARch:SERial:USB:SEU command specifies the 2-bit S and E or U portion of the search value, in hex.

**Query Syntax**    `:SEARch:SERial:USB:SEU?`

The :SEARch:SERial:USB:SEU? query returns the specified S and E or U portion of the search value.

**Return Format**    `<string><NL>`

`<string> ::= "0xn" where n ::= {0 | 1 | 2 | 3 | X | $}`

**See Also**    · [":SEARch:SERial:USB:PID:SPECial"](#) on page 1306

## 35 :SYSTem Commands

Control basic system functions of the oscilloscope. See "[Introduction to :SYSTem Commands](#)" on page 1313.

**Table 155** :SYSTem Commands Summary

Command	Query	Options and Query Returns
:SYSTem:DATE <date> (see <a href="#">page 1314</a> )	:SYSTem:DATE? (see <a href="#">page 1314</a> )	<date> ::= <year>,<month>,<day> <year> ::= 4-digit year in NR1 format  <month> ::= {1,...,12   JANuary   FEBruary   MARch   APRil   MAY   JUNe   JULy   AUGust   SEPtember   OCTober   NOVember   DECember}  <day> ::= {1,...31}
n/a	:SYSTem:DIDentifier? (see <a href="#">page 1315</a> )	n/a
:SYSTem:DSP <string> (see <a href="#">page 1316</a> )	n/a	<string> ::= up to 75 characters as a quoted ASCII string
n/a	:SYSTem:ERRor? (see <a href="#">page 1317</a> )	<error> ::= an integer error code  <error string> ::= quoted ASCII string.  See Error Messages (see <a href="#">page 1605</a> ).
:SYSTem:LOCK <value> (see <a href="#">page 1318</a> )	:SYSTem:LOCK? (see <a href="#">page 1318</a> )	<value> ::= {{1   ON}   {0   OFF}}
:SYSTem:PERSONa [:MANufacturer] <manufacturer_string> (see <a href="#">page 1319</a> )	:SYSTem:PERSONa [:MANufacturer]? (see <a href="#">page 1319</a> )	<manufacturer_string> ::= quoted ASCII string, up to 63 characters
:SYSTem:PERSONa [:MANufacturer] :DEFault (see <a href="#">page 1320</a> )	n/a	Sets manufacturer string to "KEYSIGHT TECHNOLOGIES"

**Table 155** :SYSTem Commands Summary (continued)

Command	Query	Options and Query Returns
:SYSTem:PRESet (see page 1321)	n/a	See :SYSTem:PRESet (see page 1321)
:SYSTem:PROTection:LOCK <value> (see page 1324)	:SYSTem:PROTection:LOCK? (see page 1324)	<value> ::= {{1   ON}   {0   OFF}}
:SYSTem:RLOGger <setting>[,<file_name>[,<write_mode>]] (see page 1325)	n/a	<setting> ::= {0   OFF}   {1   ON} <file_name> ::= quoted ASCII string <write_mode> ::= {CREATE   APPend}
:SYSTem:RLOGger:DESTination <dest> (see page 1326)	:SYSTem:RLOGger:DESTination? (see page 1326)	<dest> ::= {FILE   SCReen   BOTH}
:SYSTem:RLOGger:DISPLAY {{0   OFF}   {1   ON}} (see page 1327)	:SYSTem:RLOGger:DISPLAY? (see page 1327)	<setting> ::= {0   1}
:SYSTem:RLOGger:FNAMe <file_name> (see page 1328)	:SYSTem:RLOGger:FNAMe? (see page 1328)	<file_name> ::= quoted ASCII string
:SYSTem:RLOGger:STATE {{0   OFF}   {1   ON}} (see page 1329)	:SYSTem:RLOGger:STATE? (see page 1329)	<setting> ::= {0   1}
:SYSTem:RLOGger:TRANsport {{0   OFF}   {1   ON}} (see page 1330)	:SYSTem:RLOGger:TRANsport? (see page 1330)	<setting> ::= {0   1}
:SYSTem:RLOGger:WMODE <write_mode> (see page 1331)	:SYSTem:RLOGger:WMODE? (see page 1331)	<write_mode> ::= {CREATE   APPend}
:SYSTem:SETup <setup_data> (see page 1332)	:SYSTem:SETup? (see page 1332)	<setup_data> ::= data in IEEE 488.2 # format.
:SYSTem:TIME <time> (see page 1334)	:SYSTem:TIME? (see page 1334)	<time> ::= hours,minutes,seconds in NR1 format
:SYSTem:TOUCH {{1   ON}   {0   OFF}} (see page 1335)	:SYSTem:TOUCH? (see page 1335)	{1   0}

**Introduction to :SYSTem Commands** SYSTem subsystem commands enable writing messages to the display, setting and reading both the time and the date, querying for errors, and saving and recalling setups.

## :SYSTem:DATE

**N** (see [page 1666](#))

**Command Syntax**    `:SYSTem:DATE <date>`

`<date> ::= <year>,<month>,<day>`

`<year> ::= 4-digit year in NR1 format`

`<month> ::= {1,...,12 | JANuary | FEBruary | MARch | APRil | MAY | JUNe  
                  | JULy | AUGust | SEPtember | OCTober | NOVember | DECember}`

`<day> ::= {1,...,31}`

The :SYSTem:DATE command sets the date. Validity checking is performed to ensure that the date is valid.

**Query Syntax**    `:SYSTem:DATE?`

The SYSTem:DATE? query returns the date.

**Return Format**    `<year>,<month>,<day><NL>`

**See Also**

- "[Introduction to :SYSTem Commands](#)" on page 1313
- "[":SYSTem:TIME"](#) on page 1334

## :SYSTem:DIDentifier

**N** (see [page 1666](#))

**Query Syntax** `:SYSTem:DIDentifier?`

The `:SYSTem:DIDentifier?` query returns the oscilloscope's Host ID as (part of) a quoted string.

The oscilloscope's Host ID is needed when redeeming licenses for oscilloscope upgrades or other licensed features.

The exact format of returned string are product-specific. This example returns the model number, serial number, and host ID in a comma-separated format:

`"X12345A,US12345678,G1EFDNLPAF2YPLRN"`

Portable programs should not attempt to parse the contents of the returned string. Use the `*IDN?` query instead to get the model number and/or serial number in a defined portable format.

**Return Format** `<host_id><NL>`

`<host_id>` ::= quoted ASCII string

**See Also** • ["\\*IDN \(Identification Number\)" on page 238](#)

## :SYSTem:DSP

**N** (see [page 1666](#))

**Command Syntax**    `:SYSTem:DSP <string>`

`<string>` ::= quoted ASCII string (up to 75 characters)

The :SYSTem:DSP command writes the quoted string (excluding quotation marks) to a text box on-screen.

Use :SYSTem:DSP "" to remotely remove the message from the display. (Two sets of quote marks without a space between them creates a NULL string.)

Press any menu key to manually remove the message from the display.

**See Also**    · ["Introduction to :SYSTem Commands"](#) on page 1313

## :SYSTem:ERRor

**C** (see [page 1666](#))

### Query Syntax :SYSTem:ERRor?

The :SYSTem:ERRor? query outputs the next error number and text from the error queue. The instrument has an error queue that is 30 errors deep and operates on a first-in, first-out basis. Repeatedly sending the :SYSTem:ERRor? query returns the errors in the order that they occurred until the queue is empty. Any further queries then return zero until another error occurs.

When remote logging is enabled (using the oscilloscope's front panel), additional debug information can be included in the returned error string. If the error is detected by the SCPI command parser, such as a header error or other syntax error, the extra debug information is generated and included. But if the error is detected by the oscilloscope system, such as when an out-of-range value is sent, then no extra debug information is included.

**Return Format**

```
<error number>,<error string><NL>
<error number> ::= an integer error code in NR1 format
<error string> ::= quoted ASCII string containing the error message
```

Error messages are listed in [Chapter 42](#), “Error Messages,” starting on page 1605.

**See Also**

- ["Introduction to :SYSTem Commands"](#) on page 1313
- ["\\*ESR \(Standard Event Status Register\)"](#) on page 236
- ["\\*CLS \(Clear Status\)"](#) on page 233

## :SYSTem:LOCK

**N** (see [page 1666](#))

**Command Syntax**    `:SYSTem:LOCK <on_off>`

`<on_off> ::= {{1 | ON} | {0 | OFF}}`

The :SYSTem:LOCK command disables the front panel. LOCK ON is the equivalent of sending a local lockout message over the programming interface.

**Query Syntax**    `:SYSTem:LOCK?`

The :SYSTem:LOCK? query returns the lock status of the front panel.

**Return Format**    `<on_off><NL>`

`<on_off> ::= {1 | 0}`

**See Also**    • "Introduction to :SYSTem Commands" on page 1313

## :SYSTem:PERSONa[:MANufacturer]

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SYSTem:PERSONa [:MANufacturer] &lt;manufacturer_string&gt;</code> <code>&lt;manufacturer_string&gt; ::= ::= quoted ASCII string, up to 63 characters</code>
	The :SYSTem:PERSONa[:MANufacturer] command lets you change the manufacturer string portion of the identification string returned by the *IDN? query.
	The default manufacturer string is "KEYSIGHT TECHNOLOGIES".
	If your remote programs depend on a legacy manufacturer string, for example, you could use this command to set the manufacturer string to "AGILENT TECHNOLOGIES".
<b>Query Syntax</b>	<code>:SYSTem:PERSONa [:MANufacturer] ?</code>
	The :SYSTem:PERSONa[:MANufacturer]? query returns the currently set manufacturer string.
<b>Return Format</b>	<code>&lt;manufacturer_string&gt;&lt;NL&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">"*IDN (Identification Number)" on page 238</a></li> <li>· <a href="#">":SYSTem:PERSONa[:MANufacturer]:DEFault" on page 1320</a></li> <li>· <a href="#">"Introduction to :SYSTem Commands" on page 1313</a></li> </ul>

## :SYSTem:PERSONa[:MANufacturer]:DEFault

**N** (see [page 1666](#))

**Command Syntax** :SYSTem:PERSONa [:MANufacturer] :DEFault

The :SYSTem:PERSONa[:MANufacturer]:DEFault command sets the manufacturer string to "KEYSIGHT TECHNOLOGIES".

- See Also**
- ["\\*IDN \(Identification Number\)" on page 238](#)
  - [":SYSTem:PERSONa\[:MANufacturer\]" on page 1319](#)
  - ["Introduction to :SYSTem Commands" on page 1313](#)

## :SYSTem:PRESet

**C** (see [page 1666](#))

Command Syntax :SYSTem:PRESet

The :SYSTem:PRESet command places the instrument in a known state. This is the same as pressing the **[Default Setup]** key or **[Save/Recall] > Default/Erase > Default Setup** on the front panel.

When you perform a default setup, some user settings (like preferences) remain unchanged. To reset all user settings to their factory defaults, use the \*RST command.

Reset conditions are:

Acquire Menu	
Mode	Normal
Averaging	Off
# Averages	8

Analog Channel Menu	
Channel 1	On
Channel 2	Off
Volts/division	5.00 V
Offset	0.00
Coupling	DC
Probe attenuation	10:1
Vernier	Off
Invert	Off
BW limit	Off
Impedance	1 M Ohm (cannot be changed)
Units	Volts
Skew	0

Cursor Menu	
Source	Channel 1

<b>Digital Channel Menu (MSO models only)</b>	
Channel 0 - 7	Off
Labels	Off
Threshold	TTL (1.4 V)

<b>Display Menu</b>	
Persistence	Off
Grid	20%

<b>Quick Meas Menu</b>	
Source	Channel 1

<b>Run Control</b>	
	Scope is running

<b>Time Base Menu</b>	
Main time/division	100 us
Main time base delay	0.00 s
Delay time/division	500 ns
Delay time base delay	0.00 s
Reference	center
Mode	main
Vernier	Off

<b>Trigger Menu</b>	
Type	Edge
Mode	Auto
Coupling	dc
Source	Channel 1
Level	0.0 V
Slope	Positive

Trigger Menu	
HF Reject and noise reject	Off
Holdoff	40 ns
External probe attenuation	10:1
External Units	Volts
External Impedance	1 M Ohm (cannot be changed)

- See Also
- ["Introduction to Common \(\\*\) Commands"](#) on page 231
  - ["\\*RST \(Reset\)"](#) on page 244

## :SYSTem:PROTection:LOCK

**N** (see [page 1666](#))

**Command Syntax**    `:SYSTem:PROTection:LOCK <on_off>`  
`<on_off> ::= {{1 | ON} | {0 | OFF}}`

The :SYSTem:PROTection:LOCK command disables the fifty ohm impedance setting for all analog channels.

### NOTE

Be careful when turning ON the :SYSTem:PROTection:LOCK because there is no visual indication of this setting in the front-panel user interface (other than a disabled 50 Ω channel input impedance selection), and a user could think the oscilloscope is not working properly.

**Query Syntax**    `:SYSTem:PROTection:LOCK?`

The :SYSTem:PROTection:LOCK? query returns the analog channel protection lock status.

**Return Format**    `<on_off><NL>`  
`<on_off> ::= {1 | 0}`

**See Also**

- ["Introduction to :SYSTem Commands"](#) on page 1313

## :SYSTem:RLOGger

**N** (see [page 1666](#))

**Command Syntax**    `:SYSTem:RLOGger <setting>[,<file_name>[,<write_mode>]]`

`<setting> ::= {{0 | OFF} | {1 | ON}}`

`<file_name> ::= quoted ASCII string`

`<write_mode> ::= {CREATE | APPEND}`

The :SYSTem:RLOGger command enables or disables remote command logging, optionally specifying the log file name and write mode.

- See Also**
- [":SYSTem:RLOGger:DESTination" on page 1326](#)
  - [":SYSTem:RLOGger:DISPLAY" on page 1327](#)
  - [":SYSTem:RLOGger:FNAME" on page 1328](#)
  - [":SYSTem:RLOGger:STATE" on page 1329](#)
  - [":SYSTem:RLOGger:TRANSPARENT" on page 1330](#)
  - [":SYSTem:RLOGger:WMODE" on page 1331](#)

## :SYSTem:RLOGger:DESTination

**N** (see [page 1666](#))

**Command Syntax**    `:SYSTem:RLOGger:DESTination <dest>`  
`<dest> ::= {FILE | SCReen | BOTH}`

The :SYSTem:RLOGger:DESTination command specifies whether remote commands are logged to a text file (on a connected USB storage device), logged to the screen, or both.

**NOTE** If the destination is changed while remote command logging is running, remote command logging is turned off.

**Query Syntax**    `:SYSTem:RLOGger:DESTination?`

The :SYSTem:RLOGger:DESTination? query returns the remote command logging destination.

**Return Format**    `<dest><NL>`  
`<dest> ::= {FILE | SCR | BOTH}`

**See Also**

- "[:SYSTem:RLOGger](#)" on page 1325
- "[:SYSTem:RLOGger:DISPlay](#)" on page 1327
- "[:SYSTem:RLOGger:FNAME](#)" on page 1328
- "[:SYSTem:RLOGger:STATE](#)" on page 1329
- "[:SYSTem:RLOGger:TRANsparent](#)" on page 1330
- "[:SYSTem:RLOGger:WMODE](#)" on page 1331

## :SYSTem:RLOGger:DISPlay

**N** (see [page 1666](#))

**Command Syntax** :SYSTem:RLOGger:DISPlay {0 | OFF} | {1 | ON}

The :SYSTem:RLOGger:DISPlay command enables or disables the screen display of logged remote commands and their return values (if applicable).

**Query Syntax** :SYSTem:RLOGger:DISPlay?

The :SYSTem:RLOGger:DISPlay? query returns whether the screen display for remote command logging is enabled or disabled.

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

- See Also**
- "[:SYSTem:RLOGger](#)" on page 1325
  - "[:SYSTem:RLOGger:DESTination](#)" on page 1326
  - "[:SYSTem:RLOGger:FNAME](#)" on page 1328
  - "[:SYSTem:RLOGger:STATE](#)" on page 1329
  - "[:SYSTem:RLOGger:TRANsparent](#)" on page 1330
  - "[:SYSTem:RLOGger:WMODE](#)" on page 1331

## :SYSTem:RLOGger:FNAME

**N** (see [page 1666](#))

**Command Syntax**    `:SYSTem:RLOGger:FNAME <file_name>`  
`<file_name> ::= quoted ASCII string`

The :SYSTem:RLOGger:FNAME command specifies the remote command log file name.

Because log files are ASCII text files, the ".txt" extension is automatically added to the name specified.

**Query Syntax**    `:SYSTem:RLOGger:FNAME?`

The :SYSTem:RLOGger:FNAME? query returns the remote command log file name.

**Return Format**    `<file_name><NL>`

**See Also**

- "[":SYSTem:RLOGger](#)" on page 1325
- "[":SYSTem:RLOGger:DESTination](#)" on page 1326
- "[":SYSTem:RLOGger:DISPLAY](#)" on page 1327
- "[":SYSTem:RLOGger:STATE](#)" on page 1329
- "[":SYSTem:RLOGger:TRANSPARENT](#)" on page 1330
- "[":SYSTem:RLOGger:WMODE](#)" on page 1331

## :SYSTem:RLOGger:STATe

**N** (see [page 1666](#))

**Command Syntax** :SYSTem:RLOGger:STATe {{0 | OFF} | {1 | ON}}

The :SYSTem:RLOGger:STATe command enables or disables remote command logging.

**Query Syntax** :SYSTem:RLOGger:STATe?

The :SYSTem:RLOGger:STATe? query returns the remote command logging state.

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

- See Also**
- "[:SYSTem:RLOGger](#)" on page 1325
  - "[:SYSTem:RLOGger:DESTination](#)" on page 1326
  - "[:SYSTem:RLOGger:DISPLAY](#)" on page 1327
  - "[:SYSTem:RLOGger:FNAME](#)" on page 1328
  - "[:SYSTem:RLOGger:TRANsparent](#)" on page 1330
  - "[:SYSTem:RLOGger:WMODe](#)" on page 1331

## :SYSTem:RLOGger:TRANsparent

**N** (see [page 1666](#))

**Command Syntax**    `:SYSTem:RLOGger:TRANsparent {{0 | OFF} | {1 | ON}}`

The :SYSTem:RLOGger:TRANsparent command specifies whether the screen display background for remote command logging is transparent or solid.

**Query Syntax**    `:SYSTem:RLOGger:TRANsparent?`

The :SYSTem:RLOGger:TRANsparent? query returns the setting for transparent screen display background.

**Return Format**    `<setting><NL>`

`<setting> ::= {0 | 1}`

- See Also**
- "[":SYSTem:RLOGger](#)" on page 1325
  - "[":SYSTem:RLOGger:DESTination](#)" on page 1326
  - "[":SYSTem:RLOGger:DISPlay](#)" on page 1327
  - "[":SYSTem:RLOGger:FNAME](#)" on page 1328
  - "[":SYSTem:RLOGger:STATe](#)" on page 1329
  - "[":SYSTem:RLOGger:WMODE](#)" on page 1331

## :SYSTem:RLOGger:WMODE

**N** (see [page 1666](#))

**Command Syntax**    `:SYSTem:RLOGger:WMODE <write_mode>`  
`<write_mode> ::= {CREate | APPend}`

The :SYSTem:RLOGger:WMODE command specifies the remote command logging write mode.

**Query Syntax**    `:SYSTem:RLOGger:WMODE?`

The :SYSTem:RLOGger:WMODE? query returns the remote command logging write mode.

**Return Format**    `<write_mode><NL>`  
`<write_mode> ::= {CRE | APP}`

**See Also**

- [":SYSTem:RLOGger"](#) on page 1325
- [":SYSTem:RLOGger:DESTination"](#) on page 1326
- [":SYSTem:RLOGger:DISPLAY"](#) on page 1327
- [":SYSTem:RLOGger:FNAME"](#) on page 1328
- [":SYSTem:RLOGger:STATE"](#) on page 1329
- [":SYSTem:RLOGger:TRANSparent"](#) on page 1330

## :SYSTem:SETUp

**C** (see [page 1666](#))

<b>Command Syntax</b>	<code>:SYSTem:SETUp &lt;setup_data&gt;</code> <code>&lt;setup_data&gt; ::= binary block data in IEEE 488.2 # format.</code>
	The :SYSTem:SETUp command sets the oscilloscope as defined by the data in the setup (learn) string sent from the controller. The setup string does not change the interface mode or interface address.
<b>Query Syntax</b>	<code>:SYSTem:SETUp?</code>
	The :SYSTem:SETUp? query operates the same as the *LRN? query. It outputs the current oscilloscope setup in the form of a learn string to the controller. The setup (learn) string is sent and received as a binary block of data. The format for the data transmission is the # format defined in the IEEE 488.2 specification.
<b>Return Format</b>	<code>&lt;setup_data&gt;&lt;NL&gt;</code> <code>&lt;setup_data&gt; ::= binary block data in IEEE 488.2 # format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :SYSTem Commands</a>" on page 1313</li> <li>• "<a href="#">"*LRN (Learn Device Setup)</a>" on page 239</li> </ul>
<b>Example Code</b>	<pre> ' SAVE_SYSTEM_SETUP - The :SYSTEM:SETUP? query returns a program ' message that contains the current state of the instrument. Its ' format is a definite-length binary block, for example, ' #800075595&lt;setup string&gt;&lt;NL&gt; ' where the setup string is 75595 bytes in length. myScope.WriteString ":SYSTEM:SETUP?" varQueryResult = myScope.ReadIEEEBlock(BinaryType_UI1) CheckForInstrumentErrors      ' After reading query results.  ' Output setup string to a file: Dim strPath As String strPath = "c:\scope\config\setup.dat"  ' Open file for output. Close #1      ' If #1 is open, close it. Open strPath For Binary Access Write Lock Write As #1 Put #1, , varQueryResult      ' Write data. Close #1      ' Close file.  ' RESTORE_SYSTEM_SETUP - Read the setup string from a file and ' write it back to the oscilloscope. Dim varSetupString As Variant strPath = "c:\scope\config\setup.dat"  ' Open file for input. Open strPath For Binary Access Read As #1 Get #1, , varSetupString      ' Read data. Close #1      ' Close file. </pre>

```
' Write setup string back to oscilloscope using ":SYSTEM:SETUP"
' command:
myScope.WriteIEEEBlock ":SYSTEM:SETUP ", varSetupString
CheckForInstrumentErrors
```

See complete example programs at: [Chapter 46](#), “Programming Examples,” starting on page 1675

## :SYSTem:TIME

**N** (see [page 1666](#))

**Command Syntax**    `:SYSTem:TIME <time>`

`<time> ::= hours,minutes,seconds in NR1 format`

The :SYSTem:TIME command sets the system time, using a 24-hour format. Commas are used as separators. Validity checking is performed to ensure that the time is valid.

**Query Syntax**    `:SYSTem:TIME? <time>`

The :SYSTem:TIME? query returns the current system time.

**Return Format**    `<time><NL>`

`<time> ::= hours,minutes,seconds in NR1 format`

**See Also**

- "[Introduction to :SYSTem Commands](#)" on page 1313
- "[":SYSTem:DATE"](#) on page 1314

## :SYSTem:TOUCH

**N** (see [page 1666](#))

**Command Syntax** :SYSTem:TOUCH <on\_off>

<on\_off> ::= {{1 | ON} | {0 | OFF}}

The :SYSTem:TOUCH command disables or enables the touchscreen.

**Query Syntax** :SYSTem:TOUCH?

The :SYSTem:TOUCH? query returns the touchscreen's on/off status.

**Return Format** <on\_off><NL>

<on\_off> ::= {1 | 0}

**See Also** • "Introduction to :SYSTem Commands" on page 1313



# 36 :TIMEbase Commands

Control all horizontal sweep functions. See "[Introduction to :TIMEbase Commands](#)" on page 1338.

**Table 156** :TIMEbase Commands Summary

Command	Query	Options and Query Returns
:TIMEbase:MODE <value> (see <a href="#">page 1339</a> )	:TIMEbase:MODE? (see <a href="#">page 1339</a> )	<value> ::= {MAIN   WINDOW   XY   ROLL}
:TIMEbase:POSITION <pos> (see <a href="#">page 1340</a> )	:TIMEbase:POSITION? (see <a href="#">page 1340</a> )	<pos> ::= time from the trigger event to the display reference point in NR3 format
:TIMEbase:RANGE <range_value> (see <a href="#">page 1341</a> )	:TIMEbase:RANGE? (see <a href="#">page 1341</a> )	<range_value> ::= time for 10 div in seconds in NR3 format
:TIMEbase:REFERENCE {LEFT   CENTER   RIGHT   CUSTOM} (see <a href="#">page 1342</a> )	:TIMEbase:REFERENCE? (see <a href="#">page 1342</a> )	<return_value> ::= {LEFT   CENTER   RIGHT   CUSTOM}
:TIMEbase:REFERENCE:LOCation <loc> (see <a href="#">page 1343</a> )	:TIMEbase:REFERENCE:LOCATION? (see <a href="#">page 1343</a> )	<loc> ::= 0.0 to 1.0 in NR3 format
:TIMEbase:SCALE <scale_value> (see <a href="#">page 1344</a> )	:TIMEbase:SCALE? (see <a href="#">page 1344</a> )	<scale_value> ::= time/div in seconds in NR3 format
:TIMEbase:VERNier {{0   OFF}   {1   ON}} (see <a href="#">page 1345</a> )	:TIMEbase:VERNier? (see <a href="#">page 1345</a> )	{0   1}
:TIMEbase:WINDOW:POSITION <pos> (see <a href="#">page 1346</a> )	:TIMEbase:WINDOW:POSITION? (see <a href="#">page 1346</a> )	<pos> ::= time from the trigger event to the zoomed view reference point in NR3 format

**Table 156** :TIMEbase Commands Summary (continued)

Command	Query	Options and Query Returns
:TIMEbase:WINDOW:RANGE <range_value> (see page 1347)	:TIMEbase:WINDOW:RANGE? (see page 1347)	<range_value> ::= range value in seconds in NR3 format for the zoomed window
:TIMEbase:WINDOW:SCALE <scale_value> (see page 1348)	:TIMEbase:WINDOW:SCALE? (see page 1348)	<scale_value> ::= scale value in seconds in NR3 format for the zoomed window

**Introduction to :TIMEbase Commands** The TIMEbase subsystem commands control the horizontal (X-axis) functions and set the oscilloscope to X-Y mode (where channel 1 becomes the X input and channel 2 becomes the Y input). The time per division, delay, vernier control, and reference can be controlled for the main and window (zoomed) time bases.

### Reporting the Setup

Use :TIMEbase? to query setup information for the TIMEbase subsystem.

### Return Format

The following is a sample response from the :TIMEbase? query. In this case, the query was issued following a \*RST command.

```
:TIM:MODE MAIN;REF CENT;MAIN:RANG +1.00E-03;POS +0.0E+00
```

## :TIMEbase:MODE

**C** (see [page 1666](#))

**Command Syntax** :TIMEbase:MODE <value>

<value> ::= {MAIN | WINDOW | XY | ROLL}

The :TIMEbase:MODE command sets the current time base. There are four time base modes:

- MAIN – The normal time base mode is the main time base. It is the default time base mode after the \*RST (Reset) command.
- WINDOW – In the WINDOW (zoomed or delayed) time base mode, measurements are made in the zoomed time base if possible; otherwise, the measurements are made in the main time base.
- XY – In the XY mode, the :TIMEbase:RANGE, :TIMEbase:POSITION, and :TIMEbase:REFERENCE commands are not available. No measurements are available in this mode.
- ROLL – In the ROLL mode, data moves continuously across the display from left to right. The oscilloscope runs continuously and is untriggered. The :TIMEbase:REFERENCE selection changes to RIGHT.

**Query Syntax** :TIMEbase:MODE?

The :TIMEbase:MODE query returns the current time base mode.

**Return Format** <value><NL>

<value> ::= {MAIN | WIND | XY | ROLL}

**See Also**

- ["Introduction to :TIMEbase Commands"](#) on page 1338
- ["\\*RST \(Reset\)"](#) on page 244
- [":TIMEbase:RANGE"](#) on page 1341
- [":TIMEbase:POSITION"](#) on page 1340
- [":TIMEbase:REFERENCE"](#) on page 1342

**Example Code**

```
' TIMEBASE_MODE - (not executed in this example)
' Set the time base mode to MAIN, DELAYED, XY, or ROLL.

' Set time base mode to main.
myScope.WriteString ":TIMEBASE:MODE MAIN"
```

See complete example programs at: [Chapter 46, "Programming Examples,"](#) starting on page 1675

## :TIMEbase:POSIon

**C** (see [page 1666](#))

**Command Syntax**    `:TIMEbase:POSITION <pos>`

`<pos> ::= time in seconds from the trigger to the display reference  
in NR3 format`

The :TIMEbase:POSIon command sets the time interval between the trigger event and the display reference point on the screen. The display reference point is either left, right, or center and is set with the :TIMEbase:REFerence command. The maximum position value depends on the time/division settings.

### NOTE

This command is an alias for the :TIMEbase:DELay command.

**Query Syntax**    `:TIMEbase:POSITION?`

The :TIMEbase:POSIon? query returns the current time from the trigger to the display reference in seconds.

**Return Format**    `<pos><NL>`

`<pos> ::= time in seconds from the trigger to the display reference  
in NR3 format`

**See Also**

- "[Introduction to :TIMEbase Commands](#)" on page 1338
- "[:TIMEbase:REFerence](#)" on page 1342
- "[:TIMEbase:RANGE](#)" on page 1341
- "[:TIMEbase:SCALe](#)" on page 1344
- "[:TIMEbase:WINDOW:POSIon](#)" on page 1346
- "[:TIMEbase:DELay](#)" on page 1602

## :TIMEbase:RANGE

 (see [page 1666](#))

<b>Command Syntax</b>	<code>:TIMEbase:RANGE &lt;range_value&gt;</code> <code>&lt;range_value&gt; ::= time for 10 div in seconds in NR3 format</code>
	The :TIMEbase:RANGE command sets the full-scale horizontal time in seconds for the main window. The range is 10 times the current time-per-division setting.
<b>Query Syntax</b>	<code>:TIMEbase:RANGE?</code>
	The :TIMEbase:RANGE query returns the current full-scale range value for the main window.
<b>Return Format</b>	<code>&lt;range_value&gt;&lt;NL&gt;</code> <code>&lt;range_value&gt; ::= time for 10 div in seconds in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">Introduction to :TIMEbase Commands</a>" on page 1338</li> <li>· "<a href="#">:TIMEbase:MODE</a>" on page 1339</li> <li>· "<a href="#">:TIMEbase:SCALe</a>" on page 1344</li> <li>· "<a href="#">:TIMEbase:WINDow:RANGE</a>" on page 1347</li> </ul>
<b>Example Code</b>	<pre>' TIME_RANGE - Sets the full scale horizontal time in seconds. The ' range value is 10 times the time per division. myScope.WriteString ":TIM:RANG 2e-3"      ' Set the time range to 0.002 seconds.</pre> <p>See complete example programs at: <a href="#">Chapter 46</a>, “Programming Examples,” starting on page 1675</p>

## :TImebase:REFerence

**C** (see [page 1666](#))

**Command Syntax**    `:TImebase:REFerence <reference>`

`<reference> ::= {LEFT | CENTER | RIGHT | CUSTOM}`

The :TImebase:REFerence command sets the time reference to:

- LEFT – one division from the left side of the screen.
- CENTER – the center of the screen.
- RIGHT – one division from the right side of the screen.
- CUSTOM – lets you use the :TImebase:REFerence:LOCation command to place the time reference location at a percent of the graticule width (where 0.0 is the left edge and 1.0 is the right edge).

The time reference is the point on the display where the trigger point is referenced.

**Query Syntax**    `:TImebase:REFerence?`

The :TImebase:REFerence? query returns the current display reference for the main window.

**Return Format**    `<reference><NL>`

`<reference> ::= {LEFT | CENT | RIGH | CUST}`

- See Also**
- "[Introduction to :TImebase Commands](#)" on page 1338
  - "[:TImebase:REFerence:LOCation](#)" on page 1343
  - "[:TImebase:MODE](#)" on page 1339

**Example Code**

```
myScope.WriteString ":TImebase:REFerence CENTER" ' Set reference to center.
```

See complete example programs at: [Chapter 46](#), "Programming Examples," starting on page 1675

## :TIMEbase:REFerence:LOCation

**N** (see [page 1666](#))

**Command Syntax** :TIMEbase:REFerence:LOCation <loc>  
<loc> ::= 0.0 to 1.0 in NR3 format

When the :TIMEbase:REFerence is set to CUSTom, the :TIMEbase:REFerence:LOCation command lets you place the time reference location at a percent of the graticule width (where 0.0 is the left edge and 1.0 is the right edge).

**Query Syntax** :TIMEbase:REFerence:LOCation?

The :TIMEbase:REFerence:LOCATION? query returns the time base reference custom location setting.

**Return Format** <loc><NL>  
<loc> ::= 0.0 to 1.0 in NR3 format

**See Also** • [":TIMEbase:REFerence"](#) on page 1342

## :TIMEbase:SCALe

**N** (see [page 1666](#))

**Command Syntax**    `:TIMEbase:SCALe <scale_value>`

`<scale_value> ::= time/div in seconds in NR3 format`

The :TIMEbase:SCALe command sets the horizontal scale or units per division for the main window.

**Query Syntax**    `:TIMEbase:SCALe?`

The :TIMEbase:SCALe? query returns the current horizontal scale setting in seconds per division for the main window.

**Return Format**    `<scale_value><NL>`

`<scale_value> ::= time/div in seconds in NR3 format`

**See Also**

- "Introduction to :TIMEbase Commands" on page 1338
- ":TIMEbase:RANGE" on page 1341
- ":TIMEbase:WINDOW:SCALe" on page 1348
- ":TIMEbase:WINDOW:RANGE" on page 1347

## :TIMEbase:VERNier

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TIMEbase:VERNier &lt;vernier value&gt;</code>
	<code>&lt;vernier value&gt; ::= {{1   ON}   {0   OFF}}</code>
	The :TIMEbase:VERNier command specifies whether the time base control's vernier (fine horizontal adjustment) setting is ON (1) or OFF (0).
<b>Query Syntax</b>	<code>:TIMEbase:VERNier?</code>
	The :TIMEbase:VERNier? query returns the current state of the time base control's vernier setting.
<b>Return Format</b>	<code>&lt;vernier value&gt;&lt;NL&gt;</code> <code>&lt;vernier value&gt; ::= {0   1}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li>· "Introduction to :TIMEbase Commands" on page 1338</li></ul>

## :TIMEbase:WINDOW:POSITION

**C** (see [page 1666](#))

**Command Syntax**    `:TIMEbase:WINDOW:POSITION <pos value>`  
`<pos value> ::= time from the trigger event to the zoomed (delayed) view reference point in NR3 format`

The :TIMEbase:WINDOW:POSITION command sets the horizontal position in the zoomed (delayed) view of the main sweep. The main sweep range and the main sweep horizontal position determine the range for this command. The value for this command must keep the zoomed view window within the main sweep range.

**Query Syntax**    `:TIMEbase:WINDOW:POSITION?`

The :TIMEbase:WINDOW:POSITION? query returns the current horizontal window position setting in the zoomed view.

**Return Format**    `<value><NL>`  
`<value> ::= position value in seconds`

**See Also**

- "[Introduction to :TIMEbase Commands](#)" on page 1338
- "[:TIMEbase:MODE](#)" on page 1339
- "[:TIMEbase:POSITION](#)" on page 1340
- "[:TIMEbase:RANGE](#)" on page 1341
- "[:TIMEbase:SCALe](#)" on page 1344
- "[:TIMEbase:WINDOW:RANGE](#)" on page 1347
- "[:TIMEbase:WINDOW:SCALe](#)" on page 1348

## :TIMEbase:WINDOW:RANGE

**C** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TIMEbase:WINDOW:RANGE &lt;range value&gt;</code> <code>&lt;range value&gt; ::= range value in seconds in NR3 format</code>
	The :TIMEbase:WINDOW:RANGE command sets the full-scale horizontal time in seconds for the zoomed (delayed) window. The range is 10 times the current zoomed view window seconds per division setting. The main sweep range determines the range for this command. The maximum value is one half of the :TIMEbase:RANGE value.
<b>Query Syntax</b>	<code>:TIMEbase:WINDOW:RANGE?</code>
	The :TIMEbase:WINDOW:RANGE? query returns the current window timebase range setting.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code> <code>&lt;value&gt; ::= range value in seconds</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TIMEbase Commands</a>" on page 1338</li> <li>• "<a href="#">:TIMEbase:RANGE</a>" on page 1341</li> <li>• "<a href="#">:TIMEbase:POStion</a>" on page 1340</li> <li>• "<a href="#">:TIMEbase:SCALe</a>" on page 1344</li> </ul>

## :TIMEbase:WINDOW:SCALe

**N** (see [page 1666](#))

<b>Command Syntax</b>	<pre>:TIMEbase:WINDOW:SCALe &lt;scale_value&gt;</pre> <p>&lt;scale_value&gt; ::= scale value in seconds in NR3 format</p>
	The :TIMEbase:WINDOW:SCALe command sets the zoomed (delayed) window horizontal scale (seconds/division). The main sweep scale determines the range for this command. The maximum value is one half of the :TIMEbase:SCALe value.
<b>Query Syntax</b>	<pre>:TIMEbase:WINDOW:SCALe?</pre>
	The :TIMEbase:WINDOW:SCALe? query returns the current zoomed window scale setting.
<b>Return Format</b>	<pre>&lt;scale_value&gt;&lt;NL&gt;</pre> <p>&lt;scale_value&gt; ::= current seconds per division for the zoomed window</p>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">"Introduction to :TIMEbase Commands"</a> on page 1338</li><li><a href="#">":TIMEbase:RANGE"</a> on page 1341</li><li><a href="#">":TIMEbase:POSIon"</a> on page 1340</li><li><a href="#">":TIMEbase:SCALe"</a> on page 1344</li><li><a href="#">":TIMEbase:WINDOW:RANGE"</a> on page 1347</li></ul>

# 37 :TRIGger Commands

Control the trigger modes and parameters for each trigger type. See:

- ["Introduction to :TRIGger Commands" on page 1349](#)
- ["General :TRIGger Commands" on page 1351](#)
- [":TRIGger:DELay Commands" on page 1365](#)
- [":TRIGger:EBURst Commands" on page 1372](#)
- [":TRIGger\[:EDGE\] Commands" on page 1377](#)
- [":TRIGger:GLITch Commands" on page 1384 \(Pulse Width trigger\)](#)
- [":TRIGger:NFC Commands" on page 1393](#)
- [":TRIGger:OR Commands" on page 1404](#)
- [":TRIGger:PATTern Commands" on page 1406](#)
- [":TRIGger:RUNT Commands" on page 1414](#)
- [":TRIGger:SHOLD Commands" on page 1419](#)
- [":TRIGger:TRANsition Commands" on page 1425](#)
- [":TRIGger:TV Commands" on page 1430](#)
- [":TRIGger:USB Commands" on page 1440](#)
- [":TRIGger:ZONE Commands" on page 1445](#)

## Introduction to :TRIGger Commands

The commands in the TRIGger subsystem define the conditions for an internal trigger. Many of these commands are valid in multiple trigger modes.

The default trigger mode is :EDGE.

The trigger subsystem controls the trigger sweep mode and the trigger specification. The trigger sweep (see [":TRIGger:SWEep" on page 1364](#)) can be AUTO or NORMAl.

- **NORMAl** mode – displays a waveform only if a trigger signal is present and the trigger conditions are met. Otherwise the oscilloscope does not trigger and the display is not updated. This mode is useful for low-repetitive-rate signals.
- **AUTO** trigger mode – generates an artificial trigger event if the trigger specification is not satisfied within a preset time, acquires unsynchronized data and displays it.

AUTO mode is useful for signals other than low-repetitive-rate signals. You must use this mode to display a DC signal because there are no edges on which to trigger.

The following trigger types are available (see "[:TRIGger:MODE](#)" on page 1362).

- **Edge triggering**— identifies a trigger by looking for a specified slope and voltage level on a waveform.
- **Nth Edge Burst triggering**— lets you trigger on the Nth edge of a burst that occurs after an idle time.
- **Pulse width triggering**— (:TRIGger:GLITch commands) sets the oscilloscope to trigger on a positive pulse or on a negative pulse of a specified width.
- **Pattern triggering**— identifies a trigger condition by looking for a specified pattern. This pattern is a logical AND combination of the channels. You can also trigger on a specified time duration of a pattern.
- **TV triggering**— is used to capture the complicated waveforms of television equipment. The trigger circuitry detects the vertical and horizontal interval of the waveform and produces triggers based on the TV trigger settings you selected. TV triggering requires greater than  $\frac{1}{4}$  division of sync amplitude with any analog channel as the trigger source.
- **USB (Universal Serial Bus) triggering**— will trigger on a Start of Packet (SOP), End of Packet (EOP), Reset Complete, Enter Suspend, or Exit Suspend signal on the differential USB data lines. USB Low Speed and Full Speed are supported by this trigger.

### Reporting the Setup

Use :TRIGger? to query setup information for the TRIGger subsystem.

### Return Format

The return format for the TRIGger? query varies depending on the current mode. The following is a sample response from the :TRIGger? query. In this case, the query was issued following a \*RST command.

```
:TRIG:MODE EDGE;SWE AUTO;NREJ 0;HFR 0;HOLD +60.000000000000E-09;
:TRIG:EDGE:SOUR CHAN1;LEV +0.00000E+00;SLOP POS;REJ OFF;COUP DC;
:TRIG:ZONE:STAT 0
```

## General :TRIGger Commands

**Table 157** General :TRIGger Commands Summary

Command	Query	Options and Query Returns
:TRIGger:FORCe (see page 1353)	n/a	n/a
:TRIGger:HFReject {{0   OFF}   {1   ON}} (see page 1354)	:TRIGger:HFReject? (see page 1354)	{0   1}
:TRIGger:HOLDoff <holdoff_time> (see page 1355)	:TRIGger:HOLDoff? (see page 1355)	<holdoff_time> ::= 60 ns to 10 s in NR3 format
:TRIGger:HOLDoff:MAXimum <max_holdoff> (see page 1356)	:TRIGger:HOLDoff:MAXimum? (see page 1356)	<max_holdoff> ::= maximum holdoff time in seconds in NR3 format
:TRIGger:HOLDoff:MINimum <min_holdoff> (see page 1357)	:TRIGger:HOLDoff:MINimum? (see page 1357)	<min_holdoff> ::= minimum holdoff time in seconds in NR3 format
:TRIGger:HOLDoff:RANDom {{0   OFF}   {1   ON}} (see page 1358)	:TRIGger:HOLDoff:RANDOM? (see page 1358)	<setting> ::= {0   1}
:TRIGger:LEVel:ASETup (see page 1359)	n/a	n/a
:TRIGger:LEVel:HIGH <level>, <source> (see page 1360)	:TRIGger:LEVel:HIGH? <source> (see page 1360)	<level> ::= .75 x full-scale voltage from center screen in NR3 format. <source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:TRIGger:LEVel:LOW <level>, <source> (see page 1361)	:TRIGger:LEVel:LOW? <source> (see page 1361)	<level> ::= .75 x full-scale voltage from center screen in NR3 format. <source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format

**Table 157** General :TRIGger Commands Summary (continued)

Command	Query	Options and Query Returns
:TRIGger:MODE <mode> (see <a href="#">page 1362</a> )	:TRIGger:MODE? (see <a href="#">page 1362</a> )	<mode> ::= {EDGE   GLITCH   PATTern   TV   DELay   EBURst   OR   RUNT   SHOLD   TRANSition   SBUS{1   2}} <return_value> ::= {<mode>   <none>} <none> ::= query returns "NONE" if the :TIMEbase:MODE is ROLL or XY
:TRIGger:NREJect {{0   OFF}   {1   ON}} (see <a href="#">page 1363</a> )	:TRIGger:NREJect? (see <a href="#">page 1363</a> )	{0   1}
:TRIGger:SWEep <sweep> (see <a href="#">page 1364</a> )	:TRIGger:SWEep? (see <a href="#">page 1364</a> )	<sweep> ::= {AUTO   NORMAL}

## :TRIGger:FORCe

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:FORCe

The :TRIGger:FORCe command causes an acquisition to be captured even though the trigger condition has not been met. This command is equivalent to the front panel **[Force Trigger]** key.

**See Also** • ["Introduction to :TRIGger Commands"](#) on page 1349

## :TRIGger:HFReject

 (see [page 1666](#))

**Command Syntax**    `:TRIGger:HFReject <value>`

`<value> ::= {{0 | OFF} | {1 | ON}}`

The :TRIGger:HFReject command turns the high frequency reject filter off and on. The high frequency reject filter adds a 50 kHz low-pass filter in the trigger path to remove high frequency components from the trigger waveform. Use this filter to remove high-frequency noise, such as AM or FM broadcast stations, from the trigger path.

**Query Syntax**    `:TRIGger:HFReject?`

The :TRIGger:HFReject? query returns the current high frequency reject filter mode.

**Return Format**    `<value><NL>`

`<value> ::= {0 | 1}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":TRIGger\[:EDGE\]:REject](#)" on page 1381

## :TRIGger:HOLDoff

**C** (see [page 1666](#))

**Command Syntax** :TRIGger:HOLDoff <holdoff\_time>

<holdoff\_time> ::= 40 ns to 10 s in NR3 format

The :TRIGger:HOLDoff command defines the holdoff time value in seconds. Holdoff keeps a trigger from occurring until after a certain amount of time has passed since the last trigger. This feature is valuable when a waveform crosses the trigger level multiple times during one period of the waveform. Without holdoff, the oscilloscope could trigger on each of the crossings, producing a confusing waveform. With holdoff set correctly, the oscilloscope always triggers on the same crossing. The correct holdoff setting is typically slightly less than one period.

**Query Syntax** :TRIGger:HOLDoff?

The :TRIGger:HOLDoff? query returns the holdoff time value for the current trigger mode.

**Return Format** <holdoff\_time><NL>

<holdoff\_time> ::= the holdoff time value in seconds in NR3 format.

**See Also** • ["Introduction to :TRIGger Commands"](#) on page 1349

## :TRIGger:HOLDoff:MAXimum

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:HOLDoff:MAXimum &lt;max_holdoff&gt;</code>  <code>&lt;max_holdoff&gt; ::= maximum holdoff time in seconds in NR3 format</code>
	When the random trigger holdoff mode is enabled (see :TRIGger:HOLDoff:RANDOM), the :TRIGger:HOLDoff:MAXimum command specifies the maximum trigger holdoff time.
<b>Query Syntax</b>	<code>:TRIGger:HOLDoff:MAXimum?</code>
	The :TRIGger:HOLDoff:MAXimum? query returns the maximum random trigger holdoff time setting.

**Return Format** `<max_holdoff><NL>`

**See Also**

- [":TRIGger:HOLDoff:MINimum" on page 1357](#)
- [":TRIGger:HOLDoff:RANDOM" on page 1358](#)

## :TRIGger:HOLDoff:MINimum

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:HOLDoff:MINimum &lt;min_holdoff&gt;</code>  <code>&lt;min_holdoff&gt; ::= minimum holdoff time in seconds in NR3 format</code>
	When the random trigger holdoff mode is enabled (see :TRIGger:HOLDoff:RANDOM), the :TRIGger:HOLDoff:MINimum command specifies the minimum trigger holdoff time.
<b>Query Syntax</b>	<code>:TRIGger:HOLDoff:MINimum?</code>
	The :TRIGger:HOLDoff:MINimum? query returns the minimum random trigger holdoff time setting.

**Return Format** `<min_holdoff><NL>`

- See Also**
- [":TRIGger:HOLDoff:MAXimum" on page 1356](#)
  - [":TRIGger:HOLDoff:RANDOM" on page 1358](#)

## :TRIGger:HOLDoff:RANDOM

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:HOLDoff:RANDOM { {0 | OFF} | {1 | ON} }

The :TRIGger:HOLDoff:RANDOM command enables or disables the random trigger holdoff mode. This mode randomizes the holdoff time from one acquisition to the next. The randomized holdoff time values will be between the values specified by the :TRIGger:HOLDoff:MINimum and :TRIGger:HOLDoff:MAXimum commands.

The random trigger holdoff mode ensures that the oscilloscope re-arms after each acquisition in a manner that minimizes or eliminates the likelihood of triggering at the beginning of a DDR burst. Randomizing the holdoff time increases the likelihood that the oscilloscope will trigger on different data phases of a multi-phase (8 data transfer) burst. This mode mixes up the traffic pattern the oscilloscope triggers on and is very effective when used on repeating patterns.

**Query Syntax** :TRIGger:HOLDoff:RANDOM?

The :TRIGger:HOLDoff:RANDOM? query returns random trigger holdoff mode setting.

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

**See Also**

- "[":TRIGger:HOLDoff:MAXimum](#)" on page 1356
- "[":TRIGger:HOLDoff:MINimum](#)" on page 1357

## :TRIGger:LEVel:ASETUp

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:LEVel:ASETUp

The :TRIGger:LEVel:ASETUp command automatically sets the trigger levels of all displayed analog channels to their waveforms' 50% values.

If AC coupling is used, the trigger levels are set to 0 V.

When High and Low (dual) trigger levels are used (as with Rise/Fall Time and Runt triggers, for example), this command has no effect.

**See Also** • [":TRIGger\[:EDGE\]:LEVel"](#) on page 1380

## :TRIGger:LEVel:HIGH

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:LEVel:HIGH <level>, <source>`

`<level> ::= 0.75 x full-scale voltage from center screen in NR3 format  
for internal triggers`

`<source> ::= CHANnel<n>`  
`<n> ::= 1 to (# analog channels) in NR1 format`

The :TRIGger:LEVel:HIGH command sets the high trigger voltage level voltage for the specified source.

High and low trigger levels are used with runt triggers and rise/fall time (transition) triggers.

**Query Syntax**    `:TRIGger:LEVel:HIGH? <source>`

The :TRIGger:LEVel:HIGH? query returns the high trigger voltage level for the specified source.

**Return Format**    `<level><NL>`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":TRIGger:LEVel:LOW](#)" on page 1361
- "[":TRIGger:RUNT Commands](#)" on page 1414
- "[":TRIGger:TRANSition Commands](#)" on page 1425
- "[":TRIGger\[:EDGE\]:SOURce](#)" on page 1383

## :TRIGger:LEVel:LOW

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:LEVel:LOW <level>, <source>  
 <level> ::= 0.75 x full-scale voltage from center screen in NR3 format  
 for internal triggers  
 <source> ::= CHANnel<n>  
 <n> ::= 1 to (# analog channels) in NR1 format

The :TRIGger:LEVel:LOW command sets the low trigger voltage level voltage for the specified source.

High and low trigger levels are used with runt triggers and rise/fall time (transition) triggers.

**Query Syntax** :TRIGger:LEVel:LOW? <source>

The :TRIGger:LEVel:LOW? query returns the low trigger voltage level for the specified source.

**Return Format** <level><NL>

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":TRIGger:LEVel:HIGH](#)" on page 1360
- "[":TRIGger:RUNT Commands](#)" on page 1414
- "[":TRIGger:TRANSition Commands](#)" on page 1425
- "[":TRIGger\[:EDGE\]:SOURce](#)" on page 1383

## :TRIGger:MODE

 (see [page 1666](#))

**Command Syntax**    `:TRIGger:MODE <mode>`

`<mode> ::= {EDGE | GLITch | PATtern | TV | DELay | EBURst | OR | RUNT  
| SHOLD | TRANsition | SBUS{1 | 2} | NFC | USB}`

The :TRIGger:MODE command selects the trigger mode (trigger type).

**Query Syntax**    `:TRIGger:MODE?`

The :TRIGger:MODE? query returns the current trigger mode. If the :TIMEbase:MODE is ROLL or XY, the query returns "NONE".

**Return Format**    `<mode><NL>`

`<mode> ::= {EDGE | GLIT | PATT | TV | DEL | EBUR | OR | RUNT | SHOL  
| TRAN | SBUS{1 | 2} | NFC | USB}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":TRIGger:SWEep](#)" on page 1364
- "[":TIMEbase:MODE](#)" on page 1339

**Example Code**

```
' TRIGGER_MODE - Set the trigger mode to EDGE.
myScope.WriteString ":TRIGger:MODE EDGE"
```

See complete example programs at: [Chapter 46](#), “Programming Examples,” starting on page 1675

## :TRIGger:NREject

**C** (see [page 1666](#))

**Command Syntax** :TRIGger:NREject <value>

<value> ::= {{0 | OFF} | {1 | ON}}

The :TRIGger:NREject command turns the noise reject filter off and on. When the noise reject filter is on, the trigger circuitry is less sensitive to noise but may require a greater amplitude waveform to trigger the oscilloscope. This command is not valid in TV trigger mode.

**Query Syntax** :TRIGger:NREject?

The :TRIGger:NREject? query returns the current noise reject filter mode.

**Return Format** <value><NL>

<value> ::= {0 | 1}

**See Also** • ["Introduction to :TRIGger Commands"](#) on page 1349

## :TRIGger:SWEep

**C** (see [page 1666](#))

**Command Syntax**    `:TRIGger:SWEep <sweep>`

`<sweep> ::= {AUTO | NORMAl}`

The :TRIGger:SWEep command selects the trigger sweep mode.

When AUTO sweep mode is selected, a baseline is displayed in the absence of a signal. If a signal is present but the oscilloscope is not triggered, the unsynchronized signal is displayed instead of a baseline.

When NORMAl sweep mode is selected and no trigger is present, the instrument does not sweep, and the data acquired on the previous trigger remains on the screen.

### NOTE

This feature is called "Mode" on the instrument's front panel.

**Query Syntax**    `:TRIGger:SWEep?`

The :TRIGger:SWEep? query returns the current trigger sweep mode.

**Return Format**    `<sweep><NL>`

`<sweep> ::= current trigger sweep mode`

**See Also**    · ["Introduction to :TRIGger Commands" on page 1349](#)

## :TRIGger:DELay Commands

**Table 158** :TRIGger:DELay Commands Summary

Command	Query	Options and Query Returns
:TRIGger:DELay:ARM:SL OPe <slope> (see <a href="#">page 1366</a> )	:TRIGger:DELay:ARM:SL OPe? (see <a href="#">page 1366</a> )	<slope> ::= {NEGative   POSitive}
:TRIGger:DELay:ARM:SOURce <source> (see <a href="#">page 1367</a> )	:TRIGger:DELay:ARM:SOURce? (see <a href="#">page 1367</a> )	<source> ::= {CHANnel<n>   DIGital<d>} <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:TRIGger:DELay:TDELay :TIME <time_value> (see <a href="#">page 1368</a> )	:TRIGger:DELay:TDELay :TIME? (see <a href="#">page 1368</a> )	<time_value> ::= time in seconds in NR3 format
:TRIGger:DELay:TRIGger:COUNT <count> (see <a href="#">page 1369</a> )	:TRIGger:DELay:TRIGger:COUNT? (see <a href="#">page 1369</a> )	<count> ::= integer in NR1 format
:TRIGger:DELay:TRIGger:SLOPe <slope> (see <a href="#">page 1370</a> )	:TRIGger:DELay:TRIGger:SLOPe? (see <a href="#">page 1370</a> )	<slope> ::= {NEGative   POSitive}
:TRIGger:DELay:TRIGger:SOURce <source> (see <a href="#">page 1371</a> )	:TRIGger:DELay:TRIGger:SOURce? (see <a href="#">page 1371</a> )	<source> ::= {CHANnel<n>   DIGital<d>} <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format

The :TRIGger:DELay:ARM:SOURce and :TRIGger:DELay:TRIGger:SOURce commands are used to specify the source channel for the arming edge and the trigger edge in the Edge Then Edge trigger.

If an analog channel is selected as a source, the :TRIGger:EDGE:LEVel command is used to set the trigger level.

If a digital channel is selected as the source, the :DIGital<n>:THreshold or :POD<n>:THreshold command is used to set the trigger level.

## :TRIGger:DELay:ARM:SLOPe

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:DELay:ARM:SLOPe <slope>`  
                  `<slope> ::= {NEGative | POSitive}`

The :TRIGger:DELay:ARM:SLOPe command specifies rising (POSitive) or falling (NEGative) for the arming edge in the Edge Then Edge trigger.

**Query Syntax**    `:TRIGger:DELay:ARM:SLOPe?`

The :TRIGger:DELay:ARM:SLOPe? query returns the current arming edge slope setting.

**Return Format**    `<slope><NL>`  
                  `<slope> ::= {NEG | POS}`

**See Also**

- "Introduction to :TRIGger Commands" on page 1349
- ":TRIGger:DELay:ARM:SOURce" on page 1367
- ":TRIGger:DELay:TDELay:TIME" on page 1368

## :TRIGger:DElay:ARM:SOURce

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:DElay:ARM:SOURce &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;}</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	The :TRIGger:DElay:ARM:SOURce command selects the input used for the arming edge in the Edge Then Edge trigger.
<b>Query Syntax</b>	<code>:TRIGger:DElay:ARM:SOURce?</code>
	The :TRIGger:DElay:ARM:SOURce? query returns the current arming edge source.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
	<code>&lt;source&gt; ::= {CHAN&lt;n&gt;   DIG&lt;d&gt;}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">"Introduction to :TRIGger Commands"</a> on page 1349</li> <li>· <a href="#">":TRIGger:DElay:ARM:SLOPe"</a> on page 1366</li> <li>· <a href="#">":TRIGger:DElay:TDElay:TIME"</a> on page 1368</li> <li>· <a href="#">":TRIGger:MODE"</a> on page 1362</li> </ul>

## :TRIGger:DELay:TDElay:TIME

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:DELay:TDElay:TIME <time_value>`  
`<time_value> ::= time in seconds in NR3 format`

The :TRIGger:DELay:TDElay:TIME command sets the delay time between the arming edge and the trigger edge in the Edge Then Edge trigger. The time is in seconds and must be from 4 ns to 10 s.

**Query Syntax**    `:TRIGger:DELay:TDElay:TIME?`  
The :TRIGger:DELay:TDElay:TIME? query returns current delay time setting.

**Return Format**    `<time value><NL>`  
`<time_value> ::= time in seconds in NR3 format`

**See Also**

- "Introduction to :TRIGger Commands" on page 1349
- ":TRIGger:DELay:TRIGger:SLOPe" on page 1370
- ":TRIGger:DELay:TRIGger:COUNt" on page 1369

## :TRIGger:DElay:TRIGger:COUNt

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:DElay:TRIGger:COUNt &lt;count&gt;</code> <code>&lt;count&gt; ::= integer in NR1 format</code>
	The :TRIGger:DElay:TRIGger:COUNt command sets the Nth edge of the trigger source to trigger on.
<b>Query Syntax</b>	<code>:TRIGger:DElay:TRIGger:COUNt?</code>
	The :TRIGger:DElay:TRIGger:COUNt? query returns the current Nth trigger edge setting.
<b>Return Format</b>	<code>&lt;count&gt;&lt;NL&gt;</code> <code>&lt;count&gt; ::= integer in NR1 format</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">"Introduction to :TRIGger Commands"</a> on page 1349</li><li><a href="#">":TRIGger:DElay:TRIGger:SLOPe"</a> on page 1370</li><li><a href="#">":TRIGger:DElay:TRIGger:SOURce"</a> on page 1371</li><li><a href="#">":TRIGger:DElay:TDElay:TIME"</a> on page 1368</li></ul>

## :TRIGger:DELay:TRIGger:SLOPe

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:DELay:TRIGger:SLOPe <slope>`  
`<slope> ::= {NEGative | POSitive}`

The :TRIGger:DELay:TRIGger:SLOPe command specifies rising (POSitive) or falling (NEGative) for the trigger edge in the Edge Then Edge trigger.

**Query Syntax**    `:TRIGger:DELay:TRIGger:SLOPe?`

The :TRIGger:DELay:TRIGger:SLOPe? query returns the current trigger edge slope setting.

**Return Format**    `<slope><NL>`  
`<slope> ::= {NEG | POS}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:DELay:TRIGger:SOURce](#)" on page 1371
- "[:TRIGger:DELay:TDELay:TIME](#)" on page 1368
- "[:TRIGger:DELay:TRIGger:COUNT](#)" on page 1369

## :TRIGger:DElay:TRIGger:SOURce

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:DElay:TRIGger:SOURce &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;}</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	The :TRIGger:DElay:TRIGger:SOURce command selects the input used for the trigger edge in the Edge Then Edge trigger.
<b>Query Syntax</b>	<code>:TRIGger:DElay:TRIGger:SOURce?</code>
	The :TRIGger:DElay:TRIGger:SOURce? query returns the current trigger edge source.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
	<code>&lt;source&gt; ::= {CHAN&lt;n&gt;   DIG&lt;d&gt;}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">:TRIGger:DElay:TRIGger:SLOPe</a>" on page 1370</li> <li>• "<a href="#">:TRIGger:DElay:TDElay:TIME</a>" on page 1368</li> <li>• "<a href="#">:TRIGger:DElay:TRIGger:COUNT</a>" on page 1369</li> <li>• "<a href="#">:TRIGger:MODE</a>" on page 1362</li> </ul>

## :TRIGger:EBURst Commands

**Table 159** :TRIGger:EBURst Commands Summary

Command	Query	Options and Query Returns
:TRIGger:EBURst:COUNT <count> (see <a href="#">page 1373</a> )	:TRIGger:EBURst:COUNT? ? (see <a href="#">page 1373</a> )	<count> ::= integer in NR1 format
:TRIGger:EBURst:IDLE <time_value> (see <a href="#">page 1374</a> )	:TRIGger:EBURst:IDLE? ? (see <a href="#">page 1374</a> )	<time_value> ::= time in seconds in NR3 format
:TRIGger:EBURst:SLOPe <slope> (see <a href="#">page 1375</a> )	:TRIGger:EBURst:SLOPe? ? (see <a href="#">page 1375</a> )	<slope> ::= {NEGative   POSitive}
:TRIGger:EBURst:SOURce <source> (see <a href="#">page 1376</a> )	:TRIGger:EBURst:SOURce? ? (see <a href="#">page 1376</a> )	<source> ::= {CHANnel<n>   DIGital<d>} <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format

The :TRIGger:EBURst:SOURce command is used to specify the source channel for the Nth Edge Burst trigger. If an analog channel is selected as the source, the :TRIGger:EDGE:LEVel command is used to set the Nth Edge Burst trigger level. If a digital channel is selected as the source, the :DIGital<n>:THreshold or :POD<n>:THreshold command is used to set the Nth Edge Burst trigger level.

## :TRIGger:EBURst:COUNt

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:EBURst:COUNt <count>  
<count> ::= integer in NR1 format

The :TRIGger:EBURst:COUNt command sets the Nth edge at burst counter resource. The edge counter is used in the trigger stage to determine which edge in a burst will generate a trigger.

**Query Syntax** :TRIGger:EBURst:COUNt?

The :TRIGger:EBURst:COUNt? query returns the current Nth edge of burst edge counter setting.

**Return Format** <count><NL>  
<count> ::= integer in NR1 format

**See Also** • ["Introduction to :TRIGger Commands"](#) on page 1349  
• [":TRIGger:EBURst:SLOPe"](#) on page 1375  
• [":TRIGger:EBURst:IDLE"](#) on page 1374

## :TRIGger:EBURst:IDLE

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:EBURst:IDLE <time_value>`

`<time_value> ::= time in seconds in NR3 format`

The :TRIGger:EBURst:IDLE command sets the Nth edge in a burst idle resource in seconds from 10 ns to 10 s. The timer is used to set the minimum time before the next burst.

**Query Syntax**    `:TRIGger:EBURst:IDLE?`

The :TRIGger:EBURst:IDLE? query returns current Nth edge in a burst idle setting.

**Return Format**    `<time_value><NL>`

`<time_value> ::= time in seconds in NR3 format`

**See Also**

- ["Introduction to :TRIGger Commands" on page 1349](#)

- [":TRIGger:EBURst:SLOPe" on page 1375](#)

- [":TRIGger:EBURst:COUNT" on page 1373](#)

## :TRIGger:EBURst:SLOPe

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:EBURst:SLOPe <slope>`  
`<slope> ::= {NEGative | POSitive}`

The :TRIGger:EBURst:SLOPe command specifies whether the rising edge (POSitive) or falling edge (NEGative) of the Nth edge in a burst will generate a trigger.

**Query Syntax**    `:TRIGger:EBURst:SLOPe?`

The :TRIGger:EBURst:SLOPe? query returns the current Nth edge in a burst slope.

**Return Format**    `<slope><NL>`  
`<slope> ::= {NEG | POS}`

**See Also**

- "Introduction to :TRIGger Commands" on page 1349
- ":TRIGger:EBURst:IDLE" on page 1374
- ":TRIGger:EBURst:COUNT" on page 1373

## :TRIGger:EBURst:SOURce

**C** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:EBURst:SOURce &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;}</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	The :TRIGger:EBURst:SOURce command selects the input that produces the Nth edge burst trigger.
<b>Query Syntax</b>	<code>:TRIGger:EBURst:SOURce?</code>
	The :TRIGger:EBURst:SOURce? query returns the current Nth edge burst trigger source. If all channels are off, the query returns "NONE."
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
	<code>&lt;source&gt; ::= {CHAN&lt;n&gt;   DIG&lt;d&gt;}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">":TRIGger:MODE"</a> on page 1362</li> </ul>

## :TRIGger[:EDGE] Commands

**Table 160** :TRIGger[:EDGE] Commands Summary

Command	Query	Options and Query Returns
:TRIGger[:EDGE] :COUPling {AC   DC   LFReject} (see page 1379)	:TRIGger[:EDGE] :COUPling? (see page 1379)	{AC   DC   LFReject}
:TRIGger[:EDGE] :LEVel <level> [,<source>] (see page 1380)	:TRIGger[:EDGE] :LEVel? [<source>] (see page 1380)	<p>For internal triggers, &lt;level&gt; ::= .75 x full-scale voltage from center screen in NR3 format.</p> <p>For external triggers, &lt;level&gt; ::= ±(external range setting) in NR3 format.</p> <p>For digital channels (MSO models), &lt;level&gt; ::= ±8 V.</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   EXTERNAL} for DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   EXTERNAL } for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p>
:TRIGger[:EDGE] :REJect {OFF   LFReject   HFReject} (see page 1381)	:TRIGger[:EDGE] :REJect? (see page 1381)	{OFF   LFReject   HFReject}

**Table 160** :TRIGger[:EDGE] Commands Summary (continued)

Command	Query	Options and Query Returns
:TRIGger[:EDGE]:SLOPe <polarity> (see page 1382)	:TRIGger[:EDGE]:SLOPe ? (see <a href="#">page 1382</a> )	<polarity> ::= {POSitive   NEGative   EITHer   ALTernate}
:TRIGger[:EDGE]:SOURce <source> (see page 1383)	:TRIGger[:EDGE]:SOURce? (see <a href="#">page 1383</a> )	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   EXTernal   LINE   WGEN   WGEN1   WMOD} for the DSO models</p> <p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;   EXTernal   LINE   WGEN   WGEN1   WMOD} for the MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>Note: WGEN and WGEN1 are equivalent.</p>

## :TRIGger[:EDGE]:COUPLing

**C** (see [page 1666](#))

**Command Syntax**    `:TRIGger[:EDGE]:COUPLing <coupling>`  
`<coupling> ::= {AC | DC | LFReject}`

The :TRIGger[:EDGE]:COUPLing command sets the input coupling for the selected trigger sources. The coupling can be set to AC, DC, or LFReject.

- AC coupling places a high-pass filter (10 Hz for analog channels, and 3.5 Hz for all External trigger inputs) in the trigger path, removing dc offset voltage from the trigger waveform. Use AC coupling to get a stable edge trigger when your waveform has a large dc offset.
- LFReject coupling places a 50 KHz high-pass filter in the trigger path.
- DC coupling allows dc and ac signals into the trigger path.

### NOTE

The :TRIGger[:EDGE]:COUPLing and the :TRIGger[:EDGE]:REJect selections are coupled. Changing the setting of the :TRIGger[:EDGE]:REJect can change the COUPLing setting.

**Query Syntax**    `:TRIGger[:EDGE]:COUPLing?`

The :TRIGger[:EDGE]:COUPLing? query returns the current coupling selection.

**Return Format**    `<coupling><NL>`  
`<coupling> ::= {AC | DC | LFR}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:TRIGger\[:EDGE\]:REJect](#)" on page 1381

## :TRIGger[:EDGE]:LEVel

**C** (see [page 1666](#))

**Command Syntax**

```
:TRIGger[:EDGE]:LEVel <level>
<level> ::= <level>[,<source>]
<level> ::= 0.75 x full-scale voltage from center screen in NR3 format
            for internal triggers
<level> ::= ±(external range setting) in NR3 format
            for external triggers
<level> ::= ±8 V for digital channels (MSO models)
<source> ::= {CHANnel<n> | EXTERNAL} for the DSO models
<source> ::= {CHANnel<n> | DIGital<d> | EXTERNAL}
            for the MSO models
<n> ::= 1 to (# analog channels) in NR1 format
<d> ::= 0 to (# digital channels - 1) in NR1 format
```

The :TRIGger[:EDGE]:LEVel command sets the trigger level voltage for the active trigger source.

### NOTE

If the optional source is specified and is not the active source, the level on the active source is not affected and the active source is not changed.

**Query Syntax**

:TRIGger[:EDGE]:LEVel? [<source>]

The :TRIGger[:EDGE]:LEVel? query returns the trigger level of the current trigger source.

**Return Format**

<level><NL>

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":TRIGger\[:EDGE\]:SOURce](#)" on page 1383
- "[":EXTERNAL:RANGE](#)" on page 446
- "[":POD<n>:THRESHOLD](#)" on page 755
- "[":DIGITAL<d>:THRESHOLD](#)" on page 409

## :TRIGger[:EDGE]:REJect

**C** (see [page 1666](#))

**Command Syntax** :TRIGger[:EDGE]:REJect <reject>

<reject> ::= {OFF | LFRReject | HFRReject}

The :TRIGger[:EDGE]:REJect command turns the low-frequency or high-frequency reject filter on or off. You can turn on one of these filters at a time.

- The high frequency reject filter adds a 50 kHz low-pass filter in the trigger path to remove high frequency components from the trigger waveform. Use the high frequency reject filter to remove high-frequency noise, such as AM or FM broadcast stations, from the trigger path.
- The low frequency reject filter adds a 50 kHz high-pass filter in series with the trigger waveform to remove any unwanted low frequency components from a trigger waveform, such as power line frequencies, that can interfere with proper triggering.

### NOTE

The :TRIGger[:EDGE]:REJect and the :TRIGger[:EDGE]:COUPLing selections are coupled. Changing the setting of the :TRIGger[:EDGE]:COUPLing can change the COUPLing setting.

**Query Syntax** :TRIGger[:EDGE]:REJect?

The :TRIGger[:EDGE]:REJect? query returns the current status of the reject filter.

**Return Format** <reject><NL>

<reject> ::= {OFF | LFR | HFR}

**See Also** • ["Introduction to :TRIGger Commands"](#) on page 1349

• [":TRIGger:HFRReject"](#) on page 1354

• [":TRIGger\[:EDGE\]:COUPLing"](#) on page 1379

## :TRIGger[:EDGE]:SLOPe

**C** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger[:EDGE]:SLOPe &lt;slope&gt;</code> <code>&lt;slope&gt; ::= {NEGative   POSitive   EITHer   ALTernate}</code>
The :TRIGger[:EDGE]:SLOPe command specifies the slope of the edge for the trigger. The SLOPe command is not valid in TV trigger mode. Instead, use :TRIGger:TV:POLarity to set the polarity in TV trigger mode.	
<b>Query Syntax</b>	<code>:TRIGger[:EDGE]:SLOPe?</code>
	The :TRIGger[:EDGE]:SLOPe? query returns the current trigger slope.
<b>Return Format</b>	<code>&lt;slope&gt;&lt;NL&gt;</code> <code>&lt;slope&gt; ::= {NEG   POS   EITH   ALT}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>· "<a href="#">":TRIGger:MODE"</a> on page 1362</li> <li>· "<a href="#">":TRIGger:TV:POLarity"</a> on page 1433</li> </ul>
<b>Example Code</b>	<pre>' TRIGGER_EDGE_SLOPE - Sets the slope of the edge for the trigger.  ' Set the slope to positive. myScope.WriteString ":TRIGGER:EDGE:SLOPE POSITIVE"</pre>
	See complete example programs at: <a href="#">Chapter 46</a> , “Programming Examples,” starting on page 1675

## :TRIGger[:EDGE]:SOURce

**C** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger[:EDGE]:SOURce &lt;source&gt;</code>
	<pre>&lt;source&gt; ::= {CHANnel&lt;n&gt;   EXTERNAL   LINE   WGEN   WGEN1                 WMOD} for the DSO models</pre>
	<pre>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGITAL&lt;d&gt;   EXTERNAL   LINE   WGEN   WGEN1                 WMOD} for the MSO models</pre>
	<pre>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</pre>
	<pre>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</pre>
	<p>Note: WAVE and WGEN1 are equivalent.</p>
	<p>The :TRIGger[:EDGE]:SOURce command selects the input that produces the trigger.</p> <ul style="list-style-type: none"> <li>• EXTERNAL – triggers on the rear panel EXT TRIG IN signal.</li> <li>• LINE – triggers at the 50% level of the rising or falling edge of the AC power source signal.</li> <li>• WGEN, WGEN1 – triggers at the 50% level of the rising edge of the waveform generator output signal. This option is not available when the DC, NOISE, or CARDiac waveforms are selected.</li> <li>• WMOD – when waveform generator FSK or FM modulation is used, triggers at the 50% level of the rising edge of the modulating signal.</li> </ul>
<b>Query Syntax</b>	<code>:TRIGger[:EDGE]:SOURce?</code>
	<p>The :TRIGger[:EDGE]:SOURce? query returns the current source. If all channels are off, the query returns "NONE."</p>
<b>Return Format</b>	<pre>&lt;source&gt;&lt;NL&gt;</pre>
	<pre>&lt;source&gt; ::= {CHAN&lt;n&gt;   EXT   LINE   WGEN   WGEN1   WMOD                 NONE} for the DSO models</pre>
	<pre>&lt;source&gt; ::= {CHAN&lt;n&gt;   DIG&lt;d&gt;   EXTERNAL   LINE   WGEN   WGEN1                 WMOD   NONE} for the MSO models</pre>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">:TRIGger:MODE</a>" on page 1362</li> </ul>
<b>Example Code</b>	<pre>' TRIGGER_EDGE_SOURCE - Selects the channel that actually produces the ' edge trigger. Any channel can be selected. myScope.WriteString ":TRIGger:EDGE:SOURce CHANnel1"</pre>
	<p>See complete example programs at: <a href="#">Chapter 46</a>, "Programming Examples," starting on page 1675</p>

## :TRIGger:GLITch Commands

**Table 161** :TRIGger:GLITch Commands Summary

Command	Query	Options and Query Returns
:TRIGger:GLITch:GREaterthan <greater_than_time>[suffix] (see <a href="#">page 1386</a> )	:TRIGger:GLITch:GREaterthan? (see <a href="#">page 1386</a> )	<greater_than_time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}
:TRIGger:GLITch:LESSthan <less_than_time>[suffix] (see <a href="#">page 1387</a> )	:TRIGger:GLITch:LESSthan? (see <a href="#">page 1387</a> )	<less_than_time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}
:TRIGger:GLITch:LEVel <level> [<source>] (see <a href="#">page 1388</a> )	:TRIGger:GLITch:LEVel? (see <a href="#">page 1388</a> )	For internal triggers, <level> ::= .75 x full-scale voltage from center screen in NR3 format. For external triggers (DSO models), <level> ::= ±(external range setting) in NR3 format. For digital channels (MSO models), <level> ::= ±8 V. <source> ::= {CHANnel<n>   EXTERNAL} for DSO models <source> ::= {CHANnel<n>   DIGital<d>} for MSO models <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:TRIGger:GLITch:POLarity <polarity> (see <a href="#">page 1389</a> )	:TRIGger:GLITch:POLarity? (see <a href="#">page 1389</a> )	<polarity> ::= {POSitive   NEGative}
:TRIGger:GLITch:QUALifier <qualifier> (see <a href="#">page 1390</a> )	:TRIGger:GLITch:QUALifier? (see <a href="#">page 1390</a> )	<qualifier> ::= {GREaterthan   LESSthan   RANGE}

**Table 161** :TRIGger:GLITch Commands Summary (continued)

Command	Query	Options and Query Returns
:TRIGger:GLITch:RANGE <less_than_time>[suffix], <greater_than_time>[suffix] (see <a href="#">page 1391</a> )	:TRIGger:GLITch:RANGE ? (see <a href="#">page 1391</a> )	<less_than_time> ::= 15 ns to 10 seconds in NR3 format  <greater_than_time> ::= 10 ns to 9.99 seconds in NR3 format  [suffix] ::= {s   ms   us   ns   ps}
:TRIGger:GLITch:SOURce <source> (see <a href="#">page 1392</a> )	:TRIGger:GLITch:SOURce? (see <a href="#">page 1392</a> )	<source> ::= {CHANnel<n>   DIGital<d>}  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format

## :TRIGger:GLITch:GREaterthan

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:GLITch:GREaterthan <greater_than_time>[<suffix>]`  
`<greater_than_time> ::= floating-point number in NR3 format`  
`<suffix> ::= {s | ms | us | ns | ps}`

The :TRIGger:GLITch:GREaterthan command sets the minimum pulse width duration for the selected :TRIGger:GLITch:SOURce.

**Query Syntax**    `:TRIGger:GLITch:GREaterthan?`

The :TRIGger:GLITch:GREaterthan? query returns the minimum pulse width duration time for :TRIGger:GLITch:SOURce.

**Return Format**    `<greater_than_time><NL>`  
`<greater_than_time> ::= floating-point number in NR3 format.`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":TRIGger:GLITch:SOURce](#)" on page 1392
- "[":TRIGger:GLITch:QUALifier](#)" on page 1390
- "[":TRIGger:MODE](#)" on page 1362

## :TRIGger:GLITch:LESSthan

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:GLITch:LESSthan &lt;less_than_time&gt;[&lt;suffix&gt;]</code>
	<code>&lt;less_than_time&gt;</code> ::= floating-point number in NR3 format
	<code>&lt;suffix&gt;</code> ::= {s   ms   us   ns   ps}
	The :TRIGger:GLITch:LESSthan command sets the maximum pulse width duration for the selected :TRIGger:GLITch:SOURce.
<b>Query Syntax</b>	<code>:TRIGger:GLITch:LESSthan?</code>
	The :TRIGger:GLITch:LESSthan? query returns the pulse width duration time for :TRIGger:GLITch:SOURce.
<b>Return Format</b>	<code>&lt;less_than_time&gt;&lt;NL&gt;</code> <code>&lt;less_than_time&gt;</code> ::= floating-point number in NR3 format.
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">":TRIGger:GLITch:SOURce"</a> on page 1392</li> <li>• "<a href="#">":TRIGger:GLITch:QUALifier"</a> on page 1390</li> <li>• "<a href="#">":TRIGger:MODE"</a> on page 1362</li> </ul>

## :TRIGger:GLITch:LEVel

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:GLITch:LEVel &lt;level&gt;[,&lt;source&gt;]</code>
	<pre>&lt;level&gt; ::= .75 x full-scale voltage from center screen in NR3 format           for internal triggers</pre>
	<pre>&lt;level&gt; ::= ±(external range setting) in NR3 format           for external triggers (DSO models)</pre>
	<pre>&lt;level&gt; ::= ±8 V for digital channels (MSO models)</pre>
	<pre>&lt;source&gt; ::= {CHANnel&lt;n&gt;   EXTERNAL} for DSO models</pre>
	<pre>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;} for MSO models</pre>
	<pre>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</pre>
	<pre>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</pre>
	The :TRIGger:GLITch:LEVel command sets the trigger level voltage for the active pulse width trigger.
<b>Query Syntax</b>	<code>:TRIGger:GLITch:LEVel?</code>
	The :TRIGger:GLITch:LEVel? query returns the trigger level of the current pulse width trigger mode. If all channels are off, the query returns "NONE."
<b>Return Format</b>	<code>&lt;level&gt;&lt;NL&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">":TRIGger:MODE"</a> on page 1362</li> <li>• "<a href="#">":TRIGger:GLITch:SOURce"</a> on page 1392</li> <li>• "<a href="#">":EXTERNAL:RANGE"</a> on page 446</li> </ul>

## :TRIGger:GLITch:POLarity

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:GLITch:POLarity &lt;polarity&gt;</code> <code>&lt;polarity&gt; ::= {POSitive   NEGative}</code>
	The :TRIGger:GLITch:POLarity command sets the polarity for the glitch pulse width trigger.
<b>Query Syntax</b>	<code>:TRIGger:GLITch:POLarity?</code>
	The :TRIGger:GLITch:POLarity? query returns the glitch pulse width trigger polarity.
<b>Return Format</b>	<code>&lt;polarity&gt;&lt;NL&gt;</code> <code>&lt;polarity&gt; ::= {POS   NEG}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">"Introduction to :TRIGger Commands"</a> on page 1349</li><li><a href="#">":TRIGger:MODE"</a> on page 1362</li><li><a href="#">":TRIGger:GLITch:SOURce"</a> on page 1392</li></ul>

## :TRIGger:GLITch:QUALifier

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:GLITch:QUALifier <operator>

<operator> ::= {GREaterthan | LESSthan | RANGE}

This command sets the mode of operation of the glitch pulse width trigger. The oscilloscope can trigger on a pulse width that is greater than a time value, less than a time value, or within a range of time values.

**Query Syntax** :TRIGger:GLITch:QUALifier?

The :TRIGger:GLITch:QUALifier? query returns the glitch pulse width qualifier.

**Return Format** <operator><NL>

<operator> ::= {GRE | LESS | RANG}

**See Also** · ["Introduction to :TRIGger Commands"](#) on page 1349

· [":TRIGger:GLITch:SOURce"](#) on page 1392

· [":TRIGger:MODE"](#) on page 1362

:TRIGger:GLITch:RANGE

**N** (see page 1666)

Command Syntax	<pre>:TRIGger:GLITch:RANGE &lt;less_than_time&gt;[suffix],                           &lt;greater_than_time&gt;[suffix]   &lt;less_than_time&gt; ::= (15 ns - 10 seconds) in NR3 format   &lt;greater_than_time&gt; ::= (10 ns - 9.99 seconds) in NR3 format   [suffix] ::= {s   ms   us   ns   ps}</pre>
	The :TRIGger:GLITch:RANGE command sets the pulse width duration for the selected :TRIGger:GLITch:SOURce. You can enter the parameters in any order – the smaller value becomes the <greater_than_time> and the larger value becomes the <less_than_time>.
Query Syntax	:TRIGger:GLITch:RANGE?
	The :TRIGger:GLITch:RANGE? query returns the pulse width duration time for :TRIGger:GLITch:SOURce.
Return Format	<less_than_time>,<greater_than_time><NL>
See Also	<ul style="list-style-type: none"> <li>· <a href="#">"Introduction to :TRIGger Commands" on page 1349</a></li> <li>· <a href="#">":TRIGger:GLITch:SOURce" on page 1392</a></li> <li>· <a href="#">":TRIGger:GLITch:QUALifier" on page 1390</a></li> <li>· <a href="#">":TRIGger:MODE" on page 1362</a></li> </ul>

## :TRIGger:GLITch:SOURce

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:GLITch:SOURce <source>`

```
<source> ::= {DIGItal<d> | CHANnel<n>}
```

```
<n> ::= 1 to (# analog channels) in NR1 format
```

```
<d> ::= 0 to (# digital channels - 1) in NR1 format
```

The :TRIGger:GLITch:SOURce command selects the channel that produces the pulse width trigger.

**Query Syntax**    `:TRIGger:GLITch:SOURce?`

The :TRIGger:GLITch:SOURce? query returns the current pulse width source. If all channels are off, the query returns "NONE".

**Return Format**    `<source><NL>`

**See Also**

- ["Introduction to :TRIGger Commands"](#) on page 1349

- [":TRIGger:MODE"](#) on page 1362

- [":TRIGger:GLITch:LEVel"](#) on page 1388

- [":TRIGger:GLITch:POLarity"](#) on page 1389

- [":TRIGger:GLITch:QUALifier"](#) on page 1390

- [":TRIGger:GLITch:RANGE"](#) on page 1391

**Example Code**

- ["Example Code"](#) on page 1383

## :TRIGger:NFC Commands

NFC (Near Field Communication) triggering is used to capture waveforms used in NFC testing. The NFC trigger mode is license-enabled.

**Table 162** :TRIGger:NFC Commands Summary

Command	Query	Options and Query Returns
:TRIGger:NFC:AEVENT <arm_event> (see <a href="#">page 1394</a> )	:TRIGger:NFC:AEVENT? (see <a href="#">page 1394</a> )	<arm_event> ::= {NONE   ASReq   AALLreq   AEITher   BSReq   BALLreq   BEITher   FSReq}
n/a	:TRIGger:NFC:ATTIME? (see <a href="#">page 1395</a> )	<time> ::= seconds in NR3 format
:TRIGger:NFC:RPOLarit y {{0   OFF}   {1   ON}} (see <a href="#">page 1396</a> )	:TRIGger:NFC:RPOLarit y? (see <a href="#">page 1396</a> )	{0   1}
:TRIGger:NFC:SOURce <source> (see <a href="#">page 1397</a> )	:TRIGger:NFC:SOURce? (see <a href="#">page 1397</a> )	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:TRIGger:NFC:STANDARD <standard> (see <a href="#">page 1398</a> )	:TRIGger:NFC:STANDARD ? (see <a href="#">page 1398</a> )	<standard> ::= {{A   A106}   {B   B106}   F212   F424}
:TRIGger:NFC:TEVENT <trigger_event> (see <a href="#">page 1399</a> )	:TRIGger:NFC:TEVENT? (see <a href="#">page 1399</a> )	<trigger_event> ::= {ATRigger   ASReq   AALLreq   AEITher   ASDDreq   BSReq   BALLreq   BEITher   BATTrib   FSReq   FAReq   FPReqamble}
n/a	:TRIGger:NFC:TIMEout? (see <a href="#">page 1401</a> )	{0   1}
:TRIGger:NFC:TIMEout: ENABLE {{0   OFF}   {1   ON}} (see <a href="#">page 1402</a> )	:TRIGger:NFC:TIMEout: ENABLE? (see <a href="#">page 1402</a> )	{0   1}
:TRIGger:NFC:TIMEout: TIME <time> (see <a href="#">page 1403</a> )	:TRIGger:NFC:TIMEout: TIME? (see <a href="#">page 1403</a> )	<time> ::= seconds in NR3 format

## :TRIGger:NFC:AEVENT

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:NFC:AEVENT <arm_event>`

`<arm_event> ::= {NONE | ASReq | AALLreq | AEITher | BSReq | BALLreq | BEITher | FSReq}`

When the ATRigger (Arm & Trigger) trigger event is selected (by :TRIGger:NFC:TEVENT), the :TRIGger:NFC:AEVENT command specifies the arm event. Valid arm event settings depend on the signaling technology selected (by :TRIGger:NFC:STANDARD):

Signaling Technology	Arm Event	Description
NFC-A	ASReq	SENS_REQ
	AALLreq	ALL_REQ
	AEITher	Either the SENS_REQ or ALL_REQ events will arm.
NFC-B	BSReq	SENSB_REQ
	BALLreq	ALLB_REQ
	BEITher	Either the SENSB_REQ or ALLB_REQ events will arm.
NFC-F	FSReq	SENSF_REQ

When a trigger event other than ATRigger (Arm & Trigger) is selected, the arm event is NONE.

**Query Syntax**    `:TRIGger:NFC:AEVENT?`

The :TRIGger:NFC:AEVENT? query returns the specified arm event.

**Return Format**    `<arm_event><NL>`

`<arm_event> ::= {NONE | ASR | AALL | AEIT | BSR | BALL | BEIT | FSR}`

- See Also**
- [":TRIGger:NFC:ATTIME"](#) on page 1395
  - [":TRIGger:NFC:RPOLarity"](#) on page 1396
  - [":TRIGger:NFC:SOURce"](#) on page 1397
  - [":TRIGger:NFC:STANDARD"](#) on page 1398
  - [":TRIGger:NFC:TEVENT"](#) on page 1399
  - [":TRIGger:NFC:TIMEOUT"](#) on page 1401
  - [":TRIGger:NFC:TIMEOUT:ENABLE"](#) on page 1402
  - [":TRIGger:NFC:TIMEOUT:TIME"](#) on page 1403

## :TRIGger:NFC:ATTime

**N** (see [page 1666](#))

**Query Syntax** :TRIGger:NFC:ATTime?

The :TRIGger:NFC:ATTime? query returns the time between the arm and the trigger when the ATRigger (Arm & Trigger) trigger event is selected.

**Return Format** <time><NL>

<time> ::= seconds in NR3 format

**See Also**

- "[:TRIGger:NFC:AEvent](#)" on page 1394
- "[:TRIGger:NFC:SOURce](#)" on page 1397
- "[:TRIGger:NFC:RPOLarity](#)" on page 1396
- "[:TRIGger:NFC:STANDARD](#)" on page 1398
- "[:TRIGger:NFC:TEVENT](#)" on page 1399
- "[:TRIGger:NFC:TIMEOUT](#)" on page 1401
- "[:TRIGger:NFC:TIMEOUT:ENABLE](#)" on page 1402
- "[:TRIGger:NFC:TIMEOUT:TIME](#)" on page 1403

## :TRIGger:NFC:RPOLarity

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:NFC:RPOLarity {{0 | OFF} | {1 | ON}}

The :TRIGger:NFC:RPOLarity ON command enables the oscilloscope to trigger on signals with "reverse" polarity.

When OFF, the oscilloscope will trigger on signals with "obverse" polarity.

**Query Syntax** :TRIGger:NFC:RPOLarity?

The :TRIGger:NFC:RPOLarity? query returns the "reverse" polarity setting.

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

- See Also**
- "[:TRIGger:NFC:AEvent](#)" on page 1394
  - "[:TRIGger:NFC:ATTime](#)" on page 1395
  - "[:TRIGger:NFC:SOURce](#)" on page 1397
  - "[:TRIGger:NFC:STANDARD](#)" on page 1398
  - "[:TRIGger:NFC:TEVENT](#)" on page 1399
  - "[:TRIGger:NFC:TIMeout](#)" on page 1401
  - "[:TRIGger:NFC:TIMeout:ENABLE](#)" on page 1402
  - "[:TRIGger:NFC:TIMeout:TIME](#)" on page 1403

## :TRIGger:NFC:SOURce

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:NFC:SOURce <source>

<source> ::= CHANnel<n>

<n> ::= 1 to (# analog channels) in NR1 format

The :TRIGger:NFC:SOURce command selects the input waveform source for the NFC trigger. You can choose an analog input channel.

**Query Syntax** :TRIGger:NFC:SOURce?

The :TRIGger:NFC:SOURce? query returns the input waveform source setting.

**Return Format** <source><NL>

<source> ::= CHAN<n>

- See Also**
- [":TRIGger:NFC:AEvent" on page 1394](#)
  - [":TRIGger:NFC:ATTime" on page 1395](#)
  - [":TRIGger:NFC:RPOLarity" on page 1396](#)
  - [":TRIGger:NFC:STANDARD" on page 1398](#)
  - [":TRIGger:NFC:TEVENT" on page 1399](#)
  - [":TRIGger:NFC:TIMEOUT" on page 1401](#)
  - [":TRIGger:NFC:TIMEOUT:ENABLE" on page 1402](#)
  - [":TRIGger:NFC:TIMEOUT:TIME" on page 1403](#)

## :TRIGger:NFC:STANDARD

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:NFC:STANDARD <standard>`

```
<standard> ::= {{A | A106} | {B | B106} | F212 | F424}
```

The :TRIGger:NFC:STANDARD command selects the signaling technology used by the input signal:

- A or A106 – NFC-A standard, 106 kbits/s.
- B or B106 – NFC-A standard, 106 kbits/s.
- F212 – NFC-F standard, 212 kbits/s.
- F424 – NFC-F standard, 424 kbits/s.

**Query Syntax**    `:TRIGger:NFC:STANDARD?`

The :TRIGger:NFC:STANDARD? query returns the signaling technology setting.

**Return Format**    `<standard><NL>`

```
<standard> ::= {{A | A106} | {B | B106} | F212 | F424}
```

**See Also**

- "[:TRIGger:NFC:AEvent](#)" on page 1394
- "[:TRIGger:NFC:ATTime](#)" on page 1395
- "[:TRIGger:NFC:RPOLarity](#)" on page 1396
- "[:TRIGger:NFC:SOURce](#)" on page 1397
- "[:TRIGger:NFC:TEEvent](#)" on page 1399
- "[:TRIGger:NFC:TIMEout](#)" on page 1401
- "[:TRIGger:NFC:TIMEout:ENABLE](#)" on page 1402
- "[:TRIGger:NFC:TIMEout:TIME](#)" on page 1403

## :TRIGger:NFC:TEvent

**N** (see [page 1666](#))

**Command Syntax**

```
:TRIGger:NFC:TEvent <trigger_event>
<trigger_event> ::= {ATRigger | ASReq | AALLreq | AEITher | ASDDreq
                     | BSReq | BALLreq | BEITher | BATTrib | FSReq | FAReq | FPRreamble}
```

The :TRIGger:NFC:TEvent command specifies the trigger event. Valid trigger event settings depend on the signaling technology selected (by :TRIGger:NFC:STANDARD):

Signaling Technology	Trigger Event	Description
NFC-A	ATRigger	The arm event is specified by :TRIGger:NFC:AEvent, and the trigger event is SDD_REQ.
	ASReq	SENS_REQ
	AALLreq	ALL_REQ
	AEITher	Either the SENS_REQ or ALL_REQ events will cause a trigger.
	ASDDreq	SDD_REQ
NFC-B	ATRigger	The arm event is specified by :TRIGger:NFC:AEvent, and the trigger event is ATTRIB.
	BSReq	SENSB_REQ
	BALLreq	ALLB_REQ
	BEITher	Either the SENSB_REQ or ALLB_REQ events will cause a trigger.
	BATTrib	ATTRIB
NFC-F	ATRigger	The arm event is specified by :TRIGger:NFC:AEvent, and the trigger event is ATR_REQ.
	FSReq	SENSF_REQ
	FAReq	ATR_REQ
	FPRreamble	The preamble sequence that begins a data frame will cause a trigger.

**Query Syntax**

```
:TRIGger:NFC:TEvent?
```

The :TRIGger:NFC:TEvent? query returns the specified trigger event.

**Return Format**

```
<trigger_event><NL>
<trigger_event> ::= {ATR | ASR | AALL | AEIT | ASDD | BSR | BALL
                     | BEIT | BATT | FSR | FAR | FPR}
```

See Also

- "[:TRIGger:NFC:AEVENT](#)" on page 1394
- "[:TRIGger:NFC:ATTIME](#)" on page 1395
- "[:TRIGger:NFC:RPOLarity](#)" on page 1396
- "[:TRIGger:NFC:SOURce](#)" on page 1397
- "[:TRIGger:NFC:STANDARD](#)" on page 1398
- "[:TRIGger:NFC:TIMEOUT](#)" on page 1401
- "[:TRIGger:NFC:TIMEOUT:ENABLE](#)" on page 1402
- "[:TRIGger:NFC:TIMEOUT:TIME](#)" on page 1403

## :TRIGger:NFC:TIMeout

**N** (see [page 1666](#))

**Query Syntax** :TRIGger:NFC:TIMeout?

The :TRIGger:NFC:TIMeout? query returns whether the timeout occurred.

With the ATRigger (Arm & Trigger) trigger event, if the second event does not occur within the timeout period, the oscilloscope triggers when the timeout period expires.

A return value of 1 says the desired trigger event did not occur within the specified time after the arm event.

A return value of 0 says the desired trigger event occurred before the timeout.

**Return Format** <timeout\_occurred><NL>  
 {0 | 1}

- See Also**
- [":TRIGger:NFC:AEvent"](#) on page 1394
  - [":TRIGger:NFC:ATTime"](#) on page 1395
  - [":TRIGger:NFC:RPOLarity"](#) on page 1396
  - [":TRIGger:NFC:SOURce"](#) on page 1397
  - [":TRIGger:NFC:STANDARD"](#) on page 1398
  - [":TRIGger:NFC:TEVENT"](#) on page 1399
  - [":TRIGger:NFC:TIMeout:ENABLE"](#) on page 1402
  - [":TRIGger:NFC:TIMeout:TIME"](#) on page 1403

## :TRIGger:NFC:TIMEout:ENABLE

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:NFC:TIMEout:ENABLE {1 | ON}

The :TRIGger:NFC:TIMEout:ENABLE command enables the timeout period. Currently, ON is the only valid setting.

With the ATRigger (Arm & Trigger) trigger event, if the second event does not occur within the timeout period, the oscilloscope triggers when the timeout period expires.

**Query Syntax** :TRIGger:NFC:TIMEout:ENABLE?

The :TRIGger:NFC:TIMEout:ENABLE? query returns the timeout period enable setting.

**Return Format** <setting><NL>  
{1}

**See Also**

- [":TRIGger:NFC:AEvent"](#) on page 1394
- [":TRIGger:NFC:ATTime"](#) on page 1395
- [":TRIGger:NFC:RPOLarity"](#) on page 1396
- [":TRIGger:NFC:SOURce"](#) on page 1397
- [":TRIGger:NFC:STANDARD"](#) on page 1398
- [":TRIGger:NFC:TEVENT"](#) on page 1399
- [":TRIGger:NFC:TIMEOUT"](#) on page 1401
- [":TRIGger:NFC:TIMEOUT:TIME"](#) on page 1403

## :TRIGger:NFC:TIMeout:TIME

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:NFC:TIMeout:TIME &lt;time&gt;</code> <code>&lt;time&gt; ::= seconds in NR3 format</code>
	The :TRIGger:NFC:TIMeout:TIME command specifies the timeout period. With the ATTrigger (Arm & Trigger) trigger event, if the second event does not occur within the timeout period, the oscilloscope triggers when the timeout period expires.
<b>Query Syntax</b>	<code>:TRIGger:NFC:TIMeout:TIME?</code>
	The :TRIGger:NFC:TIMeout:TIME? query returns the specified timeout period.
<b>Return Format</b>	<code>&lt;time&gt;&lt;NL&gt;</code> <code>&lt;time&gt; ::= seconds in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":TRIGger:NFC:AEvent"</a> on page 1394</li> <li>· <a href="#">":TRIGger:NFC:ATTime"</a> on page 1395</li> <li>· <a href="#">":TRIGger:NFC:RPOLarity"</a> on page 1396</li> <li>· <a href="#">":TRIGger:NFC:SOURce"</a> on page 1397</li> <li>· <a href="#">":TRIGger:NFC:STANDARD"</a> on page 1398</li> <li>· <a href="#">":TRIGger:NFC:TEVENT"</a> on page 1399</li> <li>· <a href="#">":TRIGger:NFC:TIMeout"</a> on page 1401</li> <li>· <a href="#">":TRIGger:NFC:TIMeout:ENABLE"</a> on page 1402</li> </ul>

## :TRIGger:OR Commands

**Table 163** :TRIGger:OR Commands Summary

Command	Query	Options and Query Returns
:TRIGger:OR <string> (see <a href="#">page 1405</a> )	:TRIGger:OR? (see <a href="#">page 1405</a> )	<p>&lt;string&gt; ::= "nn...n" where n ::= {R   F   E   X}</p> <p>R = rising edge, F = falling edge, E = either edge, X = don't care.</p> <p>Each character in the string is for an analog or digital channel as shown on the front panel display.</p>

## :TRIGger:OR

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:OR &lt;string&gt;</code>
	<code>&lt;string&gt; ::= "nn...n" where n ::= {R   F   E   X}</code>
	R = rising edge, F = falling edge, E = either edge, X = don't care.
	The :TRIGger:OR command specifies the edges to include in the OR'ed edge trigger.
	In the <string> parameter, each bit corresponds to a channel as described in the following table:

Oscilloscope Models	Value and Mask Bit Assignments
<b>4 analog + 16 digital channels (mixed-signal)</b>	Bits 0 through 15 - digital channels 0 through 15. Bits 16 through 19 - analog channels 4 through 1.
<b>2 analog + 16 digital channels (mixed-signal)</b>	Bits 0 through 15 - digital channels 0 through 15. Bits 16 and 17 - analog channels 2 and 1.
<b>4 analog channels only</b>	Bits 0 through 3 - analog channels 4 through 1.
<b>2 analog channels only</b>	Bits 0 and 1 - analog channels 2 and 1.

<b>Query Syntax</b>	<code>:TRIGger:OR?</code>
	The :TRIGger:OR? query returns the current OR'ed edge trigger string.
<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">"Introduction to :TRIGger Commands"</a> on page 1349</li> <li>· <a href="#">":TRIGger:MODE"</a> on page 1362</li> </ul>

## :TRIGger:PATTERn Commands

**Table 164** :TRIGger:PATTERn Commands Summary

Command	Query	Options and Query Returns
:TRIGger:PATTERn <string>[,<edge_source>,<edge>] (see page 1407)	:TRIGger:PATTERn? (see <a href="#">page 1408</a> )	<p>&lt;string&gt; ::= "nn...n" where n ::= {0   1   X   R   F} when &lt;base&gt; = ASCII          &lt;string&gt; ::= "0xnn...n" where n ::= {0,...,9   A,...,F   X   \$} when &lt;base&gt; = HEX</p> <p>&lt;edge_source&gt; ::= {CHANnel&lt;n&gt;   NONE} for DSO models</p> <p>&lt;edge_source&gt; ::= {CHANnel&lt;n&gt;   DIGItal&lt;d&gt;   NONE} for MSO models</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</p> <p>&lt;edge&gt; ::= {POsitive   NEGative}</p>
:TRIGger:PATTERn:FORM at <base> (see page 1409)	:TRIGger:PATTERn:FORM at? (see <a href="#">page 1409</a> )	<base> ::= {ASCII   HEX}
:TRIGger:PATTERn:GREaterthan <greater_than_time>[suffix] (see <a href="#">page 1410</a> )	:TRIGger:PATTERn:GREaterthan? (see <a href="#">page 1410</a> )	<p>&lt;greater_than_time&gt; ::= floating-point number in NR3 format</p> <p>[suffix] ::= {s   ms   us   ns   ps}</p>
:TRIGger:PATTERn:LESS than <less_than_time>[suffix] (see <a href="#">page 1411</a> )	:TRIGger:PATTERn:LESS than? (see <a href="#">page 1411</a> )	<p>&lt;less_than_time&gt; ::= floating-point number in NR3 format</p> <p>[suffix] ::= {s   ms   us   ns   ps}</p>
:TRIGger:PATTERn:QUALifier <qualifier> (see <a href="#">page 1412</a> )	:TRIGger:PATTERn:QUALifier? (see <a href="#">page 1412</a> )	<qualifier> ::= {ENTERed   GREaterthan   LESSthan   INRange   OUTRange   TIMeout}
:TRIGger:PATTERn:RANGE <less_than_time>[suffix], <greater_than_time>[suffix] (see <a href="#">page 1413</a> )	:TRIGger:PATTERn:RANGE? (see <a href="#">page 1413</a> )	<p>&lt;less_than_time&gt; ::= 15 ns to 10 seconds in NR3 format</p> <p>&lt;greater_than_time&gt; ::= 10 ns to 9.99 seconds in NR3 format</p> <p>[suffix] ::= {s   ms   us   ns   ps}</p>

## :TRIGger:PATTERn

**C** (see [page 1666](#))

**Command Syntax**

```
:TRIGger:PATTERn <pattern>

<pattern> ::= <string>[,<edge_source>,<edge>]

<string> ::= "nn...n" where n ::= {0 | 1 | X | R | F} when
            <base> = ASCII

<string> ::= "0xnn...n" where n ::= {0,...,9 | A,...,F | X | $} when
            <base> = HEX

<edge_source> ::= {CHANnel<n> | NONE} for DSO models

<edge_source> ::= {CHANnel<n> | DIGital<d>
                  | NONE} for MSO models

<n> ::= 1 to (# of analog channels) in NR1 format

<d> ::= 0 to (# digital channels - 1) in NR1 format

<edge> ::= {POSitive | NEGative}
```

The :TRIGger:PATTERn command specifies the channel values to be used in the pattern trigger.

In the <string> parameter, each bit corresponds to a channel as described in the following table:

Oscilloscope Models	Value and Mask Bit Assignments
<b>4 analog + 16 digital channels (mixed-signal)</b>	Bits 0 through 15 - digital channels 0 through 15. Bits 16 through 19 - analog channels 4 through 1.
<b>2 analog + 16 digital channels (mixed-signal)</b>	Bits 0 through 15 - digital channels 0 through 15. Bits 16 and 17 - analog channels 2 and 1.
<b>4 analog channels only</b>	Bits 0 through 3 - analog channels 4 through 1.
<b>2 analog channels only</b>	Bits 0 and 1 - analog channels 2 and 1.

The format of the <string> parameter depends on the :TRIGger:PATTERn:FORMAT command setting:

- When the format is ASCII, the string looks just like the string you see on the oscilloscope's front panel, made up of 0, 1, X (don't care), R (rising edge), and F (falling edge) characters.
- When the format is HEX, the string begins with "0x" and contains hex digit characters or X (don't care for all four bits in the nibble).

With the hex format string, you can use the <edge\_source> and <edge> parameters to specify an edge on one of the channels.

**NOTE**

The optional <edge\_source> and <edge> parameters should be sent together or not at all. The edge can be specified in the ASCII <string> parameter. If the edge source and edge parameters are used, they take precedence.

---

You can only specify an edge on one channel. When an edge is specified, the :TRIGger:PATTERn:QUALifier does not apply.

**Query Syntax** :TRIGger:PATTERn?

The :TRIGger:PATTERn? query returns the pattern string, edge source, and edge.

**Return Format** <string>,<edge\_source>,<edge><NL>

- See Also**
- "[Introduction to :TRIGger Commands](#)" on page 1349
  - "[":TRIGger:PATTERn:FORMAT](#)" on page 1409
  - "[":TRIGger:PATTERn:QUALifier](#)" on page 1412
  - "[":TRIGger:MODE](#)" on page 1362

## :TRIGger:PATTERn:FORMAT

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:PATTERn:FORMAT <base>  
<base> ::= {ASCii | HEX}

The :TRIGger:PATTERn:FORMAT command sets the entry (and query) number base used by the :TRIGger:PATTERn command. The default <base> is ASCii.

**Query Syntax** :TRIGger:PATTERn:FORMAT?

The :TRIGger:PATTERn:FORMAT? query returns the currently set number base for pattern trigger patterns.

**Return Format** <base><NL>  
<base> ::= {ASC | HEX}

**See Also** · ["Introduction to :TRIGger Commands"](#) on page 1349  
· [":TRIGger:PATTERn"](#) on page 1407

## :TRIGger:PATTERn:GREaterthan

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:PATTERn:GREaterthan <greater_than_time>[<suffix>]`

`<greater_than_time>` ::= minimum trigger duration in seconds  
in NR3 format

`<suffix>` ::= {s | ms | us | ns | ps}

The :TRIGger:PATTERn:GREaterthan command sets the minimum duration for the defined pattern when :TRIGger:PATTERn:QUALifier is set to GREaterthan. The command also sets the timeout value when the :TRIGger:PATTERn:QUALifier is set to TImeout.

**Query Syntax**    `:TRIGger:PATTERn:GREaterthan?`

The :TRIGger:PATTERn:GREaterthan? query returns the minimum duration time for the defined pattern.

**Return Format**    `<greater_than_time><NL>`

**See Also**

- ["Introduction to :TRIGger Commands"](#) on page 1349
- [":TRIGger:PATTERn"](#) on page 1407
- [":TRIGger:PATTERn:QUALifier"](#) on page 1412
- [":TRIGger:MODE"](#) on page 1362

## :TRIGger:PATTERn:LESSthan

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:PATTERn:LESSthan <less_than_time>[<suffix>]`

`<less_than_time>` ::= maximum trigger duration in seconds  
in NR3 format

`<suffix>` ::= {s | ms | us | ns | ps}

The :TRIGger:PATTERn:LESSthan command sets the maximum duration for the defined pattern when :TRIGger:PATTERn:QUALifier is set to LESSthan.

**Query Syntax**    `:TRIGger:PATTERn:LESSthan?`

The :TRIGger:PATTERn:LESSthan? query returns the duration time for the defined pattern.

**Return Format**    `<less_than_time><NL>`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":TRIGger:PATTERn](#)" on page 1407
- "[":TRIGger:PATTERn:QUALifier](#)" on page 1412
- "[":TRIGger:MODE](#)" on page 1362

## :TRIGger:PATTERn:QUALifier

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:PATTERn:QUALifier <qualifier>`

```
<qualifier> ::= {ENTer | GREaterthan | LESSthan | INRange | OUTRange
                  | TIMEout}
```

The :TRIGger:PATTERn:QUALifier command qualifies when the trigger occurs:

- ENTer – when the pattern is entered.
- LESSthan – when the pattern is present for less than a time value.
- GREaterthan – when the pattern is present for greater than a time value. The trigger occurs when the pattern exits (not when the GREaterthan time value is exceeded).
- INRange – when the pattern is present for a time within a range of values.
- OUTRange – when the pattern is present for a time outside of range of values.

Pattern durations are evaluated using a timer. The timer starts on the last edge that makes the pattern (logical AND) true. Except when the TIMEout qualifier is selected, the trigger occurs on the first edge that makes the pattern false, provided the time qualifier criteria has been met.

Set the GREaterthan qualifier value with the :TRIGger:PATTERn:GREaterthan command.

Set the LESSthan qualifier value with the :TRIGger:PATTERn:LESSthan command.

Set the INRange and OUTRange qualifier values with the :TRIGger:PATTERn:RANGE command.

Set the TIMEout qualifier value with the :TRIGger:PATTERn:GREaterthan command.

**Query Syntax**    `:TRIGger:PATTERn:QUALifier?`

The :TRIGger:PATTERn:QUALifier? query returns the trigger duration qualifier.

**Return Format**    `<qualifier><NL>`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":TRIGger:PATTERn:GREaterthan](#)" on page 1410
- "[":TRIGger:PATTERn:LESSthan](#)" on page 1411
- "[":TRIGger:PATTERn:RANGE](#)" on page 1413

## :TRIGger:PATTERn:RANGE

**N** (see [page 1666](#))

### Command Syntax

```
:TRIGger:PATTERn:RANGE <less_than_time>[<suffix>],  
                      <greater_than_time>[<suffix>]  
  
<greater_than_time> ::= 10 ns to 9.99 seconds in NR3 format  
  
<less_than_time> ::= 15 ns to 10 seconds in NR3 format  
  
<suffix> ::= {s | ms | us | ns | ps}
```

The :TRIGger:PATTERn:RANGE command sets the duration for the defined pattern when the :TRIGger:PATTERn:QUALifier command is set to INRange or OUTRange. You can enter the parameters in any order – the smaller value becomes the <greater\_than\_time> and the larger value becomes the <less\_than\_time>.

### Query Syntax

```
:TRIGger:PATTERn:RANGE?
```

The :TRIGger:PATTERn:RANGE? query returns the duration time for the defined pattern.

### Return Format

```
<less_than_time>, <greater_than_time><NL>
```

### See Also

- ["Introduction to :TRIGger Commands"](#) on page 1349
- [":TRIGger:PATTERn"](#) on page 1407
- [":TRIGger:PATTERn:QUALifier"](#) on page 1412
- [":TRIGger:MODE"](#) on page 1362

## :TRIGger:RUNT Commands

**Table 165** :TRIGger:RUNT Commands Summary

Command	Query	Options and Query Returns
:TRIGger:RUNT:POLarit y <polarity> (see <a href="#">page 1415</a> )	:TRIGger:RUNT:POLarit y? (see <a href="#">page 1415</a> )	<polarity> ::= {POSitive   NEGative   EITHer}
:TRIGger:RUNT:QUALifi er <qualifier> (see <a href="#">page 1416</a> )	:TRIGger:RUNT:QUALifi er? (see <a href="#">page 1416</a> )	<qualifier> ::= {GREaterthan   LESSthan   NONE}
:TRIGger:RUNT:SOURce <source> (see <a href="#">page 1417</a> )	:TRIGger:RUNT:SOURce? (see <a href="#">page 1417</a> )	<source> ::= CHANnel<n> <n> ::= 1 to (# analog channels) in NR1 format
:TRIGger:RUNT:TIME <time>[suffix] (see <a href="#">page 1418</a> )	:TRIGger:RUNT:TIME? (see <a href="#">page 1418</a> )	<time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}

## :TRIGger:RUNT:POLarity

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:RUNT:POLarity <polarity>

<polarity> ::= {POSitive | NEGative | EITHer}

The :TRIGger:RUNT:POLarity command sets the polarity for the runt trigger:

- POSitive – positive runt pulses.
- NEGative – negative runt pulses.
- EITHer – either positive or negative runt pulses.

**Query Syntax** :TRIGger:RUNT:POLarity?

The :TRIGger:RUNT:POLarity? query returns the runt trigger polarity.

**Return Format** <polarity><NL>

<polarity> ::= {POS | NEG | EITH}

**See Also** ["Introduction to :TRIGger Commands" on page 1349](#)

- [":TRIGger:MODE" on page 1362](#)
- [":TRIGger:LEVel:HIGH" on page 1360](#)
- [":TRIGger:LEVel:LOW" on page 1361](#)
- [":TRIGger:RUNT:SOURce" on page 1417](#)

## :TRIGger:RUNT:QUALifier

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:RUNT:QUALifier <qualifier>`

`<qualifier> ::= {GREaterthan | LESSthan | NONE}`

The :TRIGger:RUNT:QUALifier command selects the qualifier used for specifying runt pulse widths:

- GREaterthan – triggers on runt pulses whose width is greater than the :TRIGger:RUNT:TIME.
- LESSthan – triggers on runt pulses whose width is less than the :TRIGger:RUNT:TIME.
- NONE – triggers on runt pulses of any width.

**Query Syntax**    `:TRIGger:RUNT:QUALifier?`

The :TRIGger:RUNT:QUALifier? query returns the runt trigger qualifier setting.

**Return Format**    `<qualifier><NL>`

`<qualifier> ::= {GRE | LESS NONE}`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[":TRIGger:MODE"](#) on page 1362
- "[":TRIGger:RUNT:TIME"](#) on page 1418

## :TRIGger:RUNT:SOURce

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:RUNT:SOURce <source>

<source> ::= CHANnel<n>

<n> ::= 1 to (# analog channels) in NR1 format

The :TRIGger:RUNT:SOURce command selects the channel used to produce the trigger.

**Query Syntax** :TRIGger:RUNT:SOURce?

The :TRIGger:RUNT:SOURce? query returns the current runt trigger source.

**Return Format** <source><NL>

<source> ::= CHAN<n>

**See Also** · "Introduction to :TRIGger Commands" on page 1349  
· ":TRIGger:RUNT:POLarity" on page 1415

## :TRIGger:RUNT:TIME

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:RUNT:TIME <time>[suffix]`

`<time>` ::= floating-point number in NR3 format

`[suffix]` ::= {s | ms | us | ns | ps}

When triggering on runt pulses whose width is greater than or less than a certain value (see :TRIGger:RUNT:QUALifier), the :TRIGger:RUNT:TIME command specifies the time used with the qualifier.

**Query Syntax**    `:TRIGger:RUNT:TIME?`

The :TRIGger:RUNT:TIME? query returns the current runt pulse qualifier time setting.

**Return Format**    `<time><NL>`

`<time>` ::= floating-point number in NR3 format

**See Also**

- "Introduction to :TRIGger Commands" on page 1349

- ":TRIGger:RUNT:QUALifier" on page 1416

## :TRIGger:SHOLD Commands

**Table 166** :TRIGger:SHOLD Commands Summary

Command	Query	Options and Query Returns
:TRIGger:SHOLD:SLOPe <slope> (see page 1420)	:TRIGger:SHOLD:SLOPe? (see <a href="#">page 1420</a> )	<slope> ::= {NEGative   POSitive}
:TRIGger:SHOLD:SOURce :CLOCk <source> (see page 1421)	:TRIGger:SHOLD:SOURce :CLOCk? (see <a href="#">page 1421</a> )	<source> ::= {CHANnel<n>   DIGital<d>} <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:TRIGger:SHOLD:SOURce :DATA <source> (see page 1422)	:TRIGger:SHOLD:SOURce :DATA? (see <a href="#">page 1422</a> )	<source> ::= {CHANnel<n>   DIGital<d>} <n> ::= 1 to (# analog channels) in NR1 format <d> ::= 0 to (# digital channels - 1) in NR1 format
:TRIGger:SHOLD:TIME:H OLD <time>[suffix] (see <a href="#">page 1423</a> )	:TRIGger:SHOLD:TIME:H OLD? (see <a href="#">page 1423</a> )	<time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}
:TRIGger:SHOLD:TIME:S ETup <time>[suffix] (see <a href="#">page 1424</a> )	:TRIGger:SHOLD:TIME:S ETup? (see <a href="#">page 1424</a> )	<time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}

## :TRIGger:SHOLD:SLOPe

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:SHOLD:SLOPe <slope>`  
                  `<slope> ::= {NEGative | POSitive}`

The :TRIGger:SHOLD:SLOPe command specifies whether the rising edge or the falling edge of the clock signal is used.

**Query Syntax**    `:TRIGger:SHOLD:SLOPe?`

The :TRIGger:SHOLD:SLOPe? query returns the current rising or falling edge setting.

**Return Format**    `<slope><NL>`  
                  `<slope> ::= {NEG | POS}`

**See Also**

- "Introduction to :TRIGger Commands" on page 1349
- ":TRIGger:MODE" on page 1362
- ":TRIGger:SHOLD:SOURce:CLOCK" on page 1421
- ":TRIGger:SHOLD:SOURce:DATA" on page 1422

## :TRIGger:SHOLd:SOURce:CLOCK

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:SHOLd:SOURce:CLOCK &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;}</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	The :TRIGger:SHOLd:SOURce:CLOCK command selects the input channel probing the clock signal.
<b>Query Syntax</b>	<code>:TRIGger:SHOLd:SOURce:CLOCK?</code>
	The :TRIGger:SHOLd:SOURce:CLOCK? query returns the currently set clock signal source.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
	<code>&lt;source&gt; ::= {CHAN&lt;n&gt;   DIG&lt;d&gt;}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">:TRIGger:MODE</a>" on page 1362</li> <li>• "<a href="#">:TRIGger:SHOLd:SLOPe</a>" on page 1420</li> </ul>

## :TRIGger:SHOLd:SOURce:DATA

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:SHOLd:SOURce:DATA &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;   DIGital&lt;d&gt;}</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	The :TRIGger:SHOLd:SOURce:DATA command selects the input channel probing the data signal.
<b>Query Syntax</b>	<code>:TRIGger:SHOLd:SOURce:DATA?</code>
	The :TRIGger:SHOLd:SOURce:DATA? query returns the currently set data signal source.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
	<code>&lt;source&gt; ::= {CHAN&lt;n&gt;   DIG&lt;d&gt;}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :TRIGger Commands</a>" on page 1349</li> <li>• "<a href="#">:TRIGger:MODE</a>" on page 1362</li> <li>• "<a href="#">:TRIGger:SHOLd:SLOPe</a>" on page 1420</li> </ul>

## :TRIGger:SHOLD:TIME:HOLD

**N** (see [page 1666](#))

- Command Syntax**    :TRIGger:SHOLD:TIME:HOLD <time>[suffix]  
                  <time> ::= floating-point number in NR3 format  
                  [suffix] ::= {s | ms | us | ns | ps}  
The :TRIGger:SHOLD:TIME:HOLD command sets the hold time.
- Query Syntax**    :TRIGger:SHOLD:TIME:HOLD?  
The :TRIGger:SHOLD:TIME:HOLD? query returns the currently specified hold time.
- Return Format**    <time><NL>  
                  <time> ::= floating-point number in NR3 format
- See Also**    · "Introduction to :TRIGger Commands" on page 1349

## :TRIGger:SHOLD:TIME:SETup

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:SHOLD:TIME:SETup &lt;time&gt;[suffix]</code>
	<code>&lt;time&gt;</code> ::= floating-point number in NR3 format
	<code>[suffix]</code> ::= {s   ms   us   ns   ps}
	The :TRIGger:SHOLD:TIME:SETup command sets the setup time.
<b>Query Syntax</b>	<code>:TRIGger:SHOLD:TIME:SETup?</code>
	The :TRIGger:SHOLD:TIME:SETup? query returns the currently specified setup time.
<b>Return Format</b>	<code>&lt;time&gt;&lt;NL&gt;</code>
	<code>&lt;time&gt;</code> ::= floating-point number in NR3 format
<b>See Also</b>	<ul style="list-style-type: none"><li>· "Introduction to :TRIGger Commands" on page 1349</li></ul>

## :TRIGger:TRANSition Commands

The :TRIGger:TRANSition commands set the rise/fall time trigger options.

**Table 167** :TRIGger:TRANSition Commands Summary

Command	Query	Options and Query Returns
:TRIGger:TRANSition:QUALifier <qualifier> (see page 1426)	:TRIGger:TRANSition:QUALifier? (see page 1426)	<qualifier> ::= {GREaterthan   LESSthan}
:TRIGger:TRANSition:SLOPe <slope> (see page 1427)	:TRIGger:TRANSition:SLOPe? (see page 1427)	<slope> ::= {NEGative   POSitive}
:TRIGger:TRANSition:SOURce <source> (see page 1428)	:TRIGger:TRANSition:SOURce? (see page 1428)	<source> ::= CHANNEL<n> <n> ::= 1 to (# analog channels) in NR1 format
:TRIGger:TRANSition:TIME <time>[suffix] (see page 1429)	:TRIGger:TRANSition:TIME? (see page 1429)	<time> ::= floating-point number in NR3 format [suffix] ::= {s   ms   us   ns   ps}

## :TRIGger:TRANSition:QUALifier

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:TRANSition:QUALifier <qualifier>`  
`<qualifier> ::= {GREaterthan | LESSthan}`

The :TRIGger:TRANSition:QUALifier command specifies whether you are looking for rise/fall times greater than or less than a certain time value. The time value is set using the :TRIGger:TRANSition:TIME command.

**Query Syntax**    `:TRIGger:TRANSition:QUALifier?`

The :TRIGger:TRANSition:QUALifier? query returns the current rise/fall time trigger qualifier setting.

**Return Format**    `<qualifier><NL>`  
`<qualifier> ::= {GRE | LESS}`

**See Also**

- ["Introduction to :TRIGger Commands" on page 1349](#)
- [":TRIGger:TRANSition:TIME" on page 1429](#)
- [":TRIGger:MODE" on page 1362](#)

## :TRIGger:TRANSition:SLOPe

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:TRANSition:SLOPe <slope>  
<slope> ::= {NEGative | POSitive}

The :TRIGger:TRANSition:SLOPe command specifies a POSitive rising edge or a NEGative falling edge.

**Query Syntax** :TRIGger:TRANSition:SLOPe?

The :TRIGger:TRANSition:SLOPe? query returns the current rise/fall time trigger slope setting.

**Return Format** <slope><NL>  
<slope> ::= {NEG | POS}

**See Also** · "Introduction to :TRIGger Commands" on page 1349  
· ":TRIGger:MODE" on page 1362  
· ":TRIGger:TRANSition:SOURce" on page 1428

## :TRIGger:TRANSition:SOURce

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:TRANSition:SOURce &lt;source&gt;</code>
	<code>&lt;source&gt; ::= CHANnel&lt;n&gt;</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	The :TRIGger:TRANSition:SOURce command selects the channel used to produce the trigger.
<b>Query Syntax</b>	<code>:TRIGger:TRANSition:SOURce?</code>
	The :TRIGger:TRANSition:SOURce? query returns the current transition trigger source.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
	<code>&lt;source&gt; ::= CHAN&lt;n&gt;</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">"Introduction to :TRIGger Commands"</a> on page 1349</li><li><a href="#">":TRIGger:MODE"</a> on page 1362</li><li><a href="#">":TRIGger:TRANSition:SLOPe"</a> on page 1427</li></ul>

## :TRIGger:TRANSition:TIME

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:TRANSition:TIME &lt;time&gt;[suffix]</code> <code>&lt;time&gt; ::= floating-point number in NR3 format</code> <code>[suffix] ::= {s   ms   us   ns   ps}</code>
	The :TRIGger:TRANSition:TIME command sets the time value for rise/fall time triggers. You also use the :TRIGger:TRANSition:QUALifier command to specify whether you are triggering on times greater than or less than this time value.
<b>Query Syntax</b>	<code>:TRIGger:TRANSition:TIME?</code>
	The :TRIGger:TRANSition:TIME? query returns the current rise/fall time trigger time value.
<b>Return Format</b>	<code>&lt;time&gt;&lt;NL&gt;</code> <code>&lt;time&gt; ::= floating-point number in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">"Introduction to :TRIGger Commands"</a> on page 1349</li><li><a href="#">":TRIGger:TRANSition:QUALifier"</a> on page 1426</li></ul>

## :TRIGger:TV Commands

**Table 168** :TRIGger:TV Commands Summary

Command	Query	Options and Query Returns
:TRIGger:TV:LINE <line number> (see <a href="#">page 1431</a> )	:TRIGger:TV:LINE? (see <a href="#">page 1431</a> )	<line number> ::= integer in NR1 format
:TRIGger:TV:MODE <tv mode> (see <a href="#">page 1432</a> )	:TRIGger:TV:MODE? (see <a href="#">page 1432</a> )	<tv mode> ::= {FIELD1   FIELD2   AFields   ALINes   LINE   LFIELD1   LFIELD2   LATernate}
:TRIGger:TV:POLarity <polarity> (see <a href="#">page 1433</a> )	:TRIGger:TV:POLarity? (see <a href="#">page 1433</a> )	<polarity> ::= {POSitive   NEGative}
:TRIGger:TV:SOURce <source> (see <a href="#">page 1434</a> )	:TRIGger:TV:SOURce? (see <a href="#">page 1434</a> )	<source> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format
:TRIGger:TV:STANDARD <standard> (see <a href="#">page 1435</a> )	:TRIGger:TV:STANDARD? (see <a href="#">page 1435</a> )	<standard> ::= {NTSC   PAL   PALM   SECam}  <standard> ::= {GENeric   {P480L60HZ   P480}   {P720L60HZ   P720}   {P1080L24HZ   P1080}   P1080L25HZ   P1080L50HZ   P1080L60HZ   {I1080L50HZ   I1080}   I1080L60HZ} with extended video triggering license
:TRIGger:TV:UDTV:ENUM ber <count> (see <a href="#">page 1436</a> )	:TRIGger:TV:UDTV:ENUM ber? (see <a href="#">page 1436</a> )	<count> ::= edge number in NR1 format
:TRIGger:TV:UDTV:HSYN C {{0   OFF}   {1   ON}} (see <a href="#">page 1437</a> )	:TRIGger:TV:UDTV:HSYN C? (see <a href="#">page 1437</a> )	{0   1}
:TRIGger:TV:UDTV:HTIM e <time> (see <a href="#">page 1438</a> )	:TRIGger:TV:UDTV:HTIM e? (see <a href="#">page 1438</a> )	<time> ::= seconds in NR3 format
:TRIGger:TV:UDTV:PGTH an <min_time> (see <a href="#">page 1439</a> )	:TRIGger:TV:UDTV:PGTH an? (see <a href="#">page 1439</a> )	<min_time> ::= seconds in NR3 format

## :TRIGger:TV:LINE

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:TV:LINE <line\_number>

<line\_number> ::= integer in NR1 format

The :TRIGger:TV:LINE command allows triggering on a specific line of video. The line number limits vary with the standard and mode, as shown in the following table.

**Table 169** TV Trigger Line Number Limits

TV Standard	Mode				
	LINE	LField1	LField2	LALternate	VERTical
NTSC		1 to 263	1 to 262	1 to 262	
PAL		1 to 313	314 to 625	1 to 312	
PAL-M		1 to 263	264 to 525	1 to 262	
SECAM		1 to 313	314 to 625	1 to 312	
GENERIC		1 to 1024	1 to 1024		1 to 1024
P480L60HZ	1 to 525				
P720L60HZ	1 to 750				
P1080L24HZ	1 to 1125				
P1080L25HZ	1 to 1125				
P1080L50HZ	1 to 1125				
P1080L60HZ	1 to 1125				
I1080L50HZ	1 to 1125				
I1080L60HZ	1 to 1125				

**Query Syntax** :TRIGger:TV:LINE?

The :TRIGger:TV:LINE? query returns the current TV trigger line number setting.

**Return Format** <line\_number><NL>

<line\_number> ::= integer in NR1 format

- See Also**
- "[Introduction to :TRIGger Commands](#)" on page 1349
  - "[:TRIGger:TV:STANDARD](#)" on page 1435
  - "[:TRIGger:TV:MODE](#)" on page 1432

## :TRIGger:TV:MODE

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:TV:MODE <mode>

```
<mode> ::= {FIEld1 | FIEld2 | AFIELDS | ALINes | LINE | LFIeld1
             | LFIeld2 | LALTernate}
```

The :TRIGger:TV:MODE command selects the TV trigger mode and field. The LALTernate parameter is not available when :TRIGger:TV:STANDARD is GENeric.

Old forms for <mode> are accepted:

<mode>	Old Forms Accepted
FIEld1	F1
FIEld2	F2
AFIELDS	ALLFields, ALLFLDS
ALINes	ALLLines
LFIeld1	LINEF1, LINEFIELD1
LFIeld2	LINEF2, LINEFIELD2
LALTernate	LINEAlt

**Query Syntax** :TRIGger:TV:MODE?

The :TRIGger:TV:MODE? query returns the TV trigger mode.

**Return Format** <value><NL>

```
<value> ::= {FIE1 | FIE2 | AFI | ALIN | LINE | LFI1 | LFI2 | LALT}
```

- See Also**
- “[Introduction to :TRIGger Commands](#)” on page 1349
  - “[:TRIGger:TV:STANDARD](#)” on page 1435
  - “[:TRIGger:MODE](#)” on page 1362

## :TRIGger:TV:POLarity

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:TV:POLarity <polarity>

<polarity> ::= {POSitive | NEGative}

The :TRIGger:TV:POLarity command sets the polarity for the TV trigger.

**Query Syntax** :TRIGger:TV:POLarity?

The :TRIGger:TV:POLarity? query returns the TV trigger polarity.

**Return Format** <polarity><NL>

<polarity> ::= {POS | NEG}

**See Also** • ["Introduction to :TRIGger Commands" on page 1349](#)

• [":TRIGger:MODE" on page 1362](#)

• [":TRIGger:TV:SOURce" on page 1434](#)

## :TRIGger:TV:SOURce

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:TRIGger:TV:SOURce &lt;source&gt;</code>
	<code>&lt;source&gt; ::= {CHANnel&lt;n&gt;}</code>
	<code>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</code>
	The :TRIGger:TV:SOURce command selects the channel used to produce the trigger.
<b>Query Syntax</b>	<code>:TRIGger:TV:SOURce?</code>
	The :TRIGger:TV:SOURce? query returns the current TV trigger source.
<b>Return Format</b>	<code>&lt;source&gt;&lt;NL&gt;</code>
	<code>&lt;source&gt; ::= {CHAN&lt;n&gt;}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">"Introduction to :TRIGger Commands"</a> on page 1349</li><li><a href="#">":TRIGger:MODE"</a> on page 1362</li><li><a href="#">":TRIGger:TV:POLarity"</a> on page 1433</li></ul>
<b>Example Code</b>	<ul style="list-style-type: none"><li><a href="#">"Example Code"</a> on page 1383</li></ul>

## :TRIGger:TV:STANDARD

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:TV:STANDARD <standard>

```
<standard> ::= {GENeric | NTSC | PALM | PAL | SECam
                 | {P480L60HZ | P480} | {P720L60HZ | P720}
                 | {P1080L24HZ | P1080} | P1080L25HZ
                 | P1080L50HZ | P1080L60HZ
                 | {I1080L50HZ | I1080} | I1080L60HZ}
```

The :TRIGger:TV:STANDARD command selects the video standard:

- NTSC
- PAL
- PAL-M
- SECAM

With an extended Video triggering license, the oscilloscope additionally supports these standards:

- Generic – GENeric mode is non-interlaced.
- EDTV 480p/60
- HDTV 720p/60
- HDTV 1080p/24
- HDTV 1080p/25
- HDTV 1080i/50
- HDTV 1080i/60

**Query Syntax** :TRIGger:TV:STANDARD?

The :TRIGger:TV:STANDARD? query returns the current TV trigger standard setting.

**Return Format** <standard><NL>

```
<standard> ::= {GEN | NTSC | PALM | PAL | SEC | P480L60HZ | P760L60HZ
                 | P1080L24HZ | P1080L25HZ | P1080L50HZ | P1080L60HZ
                 | I1080L50HZ | I1080L60HZ}
```

## :TRIGger:TV:UDTV:ENUMber

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:TV:UDTV:ENUMber <count>`  
                  `<count> ::= edge number in NR1 format`

The :TRIGger:TV:UDTV:ENUMber command specifies the Generic video trigger's Nth edge to trigger on after synchronizing with the vertical sync.

**Query Syntax**    `:TRIGger:TV:UDTV:ENUMber?`

The :TRIGger:TV:UDTV:ENUMber query returns the edge count setting.

**Return Format**    `<count><NL>`  
                  `<count> ::= edge number in NR1 format`

**See Also**

- [":TRIGger:TV:STANDARD"](#) on page 1435
- [":TRIGger:TV:UDTV:PGTHan"](#) on page 1439
- [":TRIGger:TV:UDTV:HSYNC"](#) on page 1437

## :TRIGger:TV:UDTV:HSync

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:TV:UDTV:HSync {{0 | OFF} | {1 | ON}}

The :TRIGger:TV:UDTV:HSync command enables or disables the horizontal sync control in the Generic video trigger.

For interleaved video, enabling the HSync control and setting the HTIME adjustment to the sync time of the probed video signal allows the ENUMber function to count only lines and not double count during equalization.

Additionally, the Field Holdoff can be adjusted so that the oscilloscope triggers once per frame.

Similarly, for progressive video with a tri-level sync, enabling the HSync control and setting the HTIME adjustment to the sync time of the probed video signal allows the ENUMber function to count only lines and not double count during vertical sync.

**Query Syntax** :TRIGger:TV:UDTV:HSync?

The :TRIGger:TV:UDTV:HSync query returns the horizontal sync control setting.

**Return Format** {0 | 1}

- See Also**
- "[:TRIGger:TV:STANDARD](#)" on page 1435
  - "[:TRIGger:TV:UDTV:HTIME](#)" on page 1438
  - "[:TRIGger:TV:UDTV:ENUMber](#)" on page 1436
  - "[:TRIGger:TV:UDTV:PGTHan](#)" on page 1439

## :TRIGger:TV:UDTV:HTIMe

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:TV:UDTV:HTIMe <time>`  
                  `<time> ::= seconds in NR3 format`

When the Generic video trigger's horizontal sync control is enabled, the :TRIGger:TV:UDTV:HTIMe command sets the minimum time the horizontal sync pulse must be present to be considered valid.

**Query Syntax**    `:TRIGger:TV:UDTV:HTIMe?`

The :TRIGger:TV:UDTV:HTIMe query returns the horizontal sync time setting.

**Return Format**    `<time><NL>`  
                  `<time> ::= seconds in NR3 format`

**See Also**

- [":TRIGger:TV:STANDARD"](#) on page 1435
- [":TRIGger:TV:UDTV:HSYNC"](#) on page 1437

## :TRIGger:TV:UDTV:PGTHan

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:TV:UDTV:PGTHan <min\_time>  
<min\_time> ::= seconds in NR3 format

The :TRIGger:TV:UDTV:PGTHan command specifies the "greater than the sync pulse width" time in the Generic video trigger. This setting allows oscilloscope synchronization to the vertical sync.

**Query Syntax** :TRIGger:TV:UDTV:PGTHan?

The :TRIGger:TV:UDTV:PGTHan query returns the "greater than the sync pulse width" time setting.

**Return Format** <min\_time><NL>  
<min\_time> ::= seconds in NR3 format

**See Also** • [":TRIGger:TV:STANDARD"](#) on page 1435  
• [":TRIGger:TV:UDTV:ENUMber"](#) on page 1436  
• [":TRIGger:TV:UDTV:HSYNC"](#) on page 1437

## :TRIGger:USB Commands

**Table 170** :TRIGger:USB Commands Summary

Command	Query	Options and Query Returns
:TRIGger:USB:SOURce:D MINus <source> (see <a href="#">page 1441</a> )	:TRIGger:USB:SOURce:D MINus? (see <a href="#">page 1441</a> )	<source> ::= {CHANnel<n>   EXternal} for the DSO models  <source> ::= {CHANnel<n>   DIGital<d>} for the MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:TRIGger:USB:SOURce:D PLus <source> (see <a href="#">page 1442</a> )	:TRIGger:USB:SOURce:D PLus? (see <a href="#">page 1442</a> )	<source> ::= {CHANnel<n>   EXternal} for the DSO models  <source> ::= {CHANnel<n>   DIGital<d>} for the MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <d> ::= 0 to (# digital channels - 1) in NR1 format
:TRIGger:USB:SPEed <value> (see <a href="#">page 1443</a> )	:TRIGger:USB:SPEed? (see <a href="#">page 1443</a> )	<value> ::= {LOW   FULL}
:TRIGger:USB:TRIGger <value> (see <a href="#">page 1444</a> )	:TRIGger:USB:TRIGger? (see <a href="#">page 1444</a> )	<value> ::= {SOP   EOP   ENTersuspend   EXITsuspend   RESet}

## :TRIGger:USB:SOURce:DMINus

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:USB:SOURce:DMINus <source>`

```
<source> ::= {CHANnel<n> | EXTernal} for the DSO models
<source> ::= {CHANnel<n> | DIGital<d>} for the MSO models
<n> ::= 1 to (# analog channels) in NR1 format
<d> ::= 0 to (# digital channels - 1) in NR1 format
```

The :TRIGger:USB:SOURce:DMINus command sets the source for the USB D- signal.

**Query Syntax**    `:TRIGger:USB:SOURce:DMINus?`

The :TRIGger:USB:SOURce:DMINus? query returns the current source for the USB D- signal.

**Return Format**    `<source><NL>`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:TRIGger:USB:SOURce:DPLus](#)" on page 1442
- "[:TRIGger:USB:TRIGger](#)" on page 1444

## :TRIGger:USB:SOURce:DPLus

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:USB:SOURce:DPLus <source>`

```
<source> ::= {CHANnel<n> | EXTernal} for the DSO models
<source> ::= {CHANnel<n> | DIGital<d>} for the MSO models
<n> ::= 1 to (# analog channels) in NR1 format
<d> ::= 0 to (# digital channels - 1) in NR1 format
```

The :TRIGger:USB:SOURce:DPLus command sets the source for the USB D+ signal.

**Query Syntax**    `:TRIGger:USB:SOURce:DPLus?`

The :TRIGger:USB:SOURce:DPLus? query returns the current source for the USB D+ signal.

**Return Format**    `<source><NL>`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:TRIGger:USB:SOURce:DMINus](#)" on page 1441
- "[:TRIGger:USB:TRIGger](#)" on page 1444

## :TRIGger:USB:SPEed

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:USB:SPEed <value>

<value> ::= {LOW | FULL}

The :TRIGger:USB:SPEed command sets the expected USB signal speed to be Low Speed (1.5 Mb/s) or Full Speed (12 Mb/s).

**Query Syntax** :TRIGger:USB:SPEed?

The :TRIGger:USB:SPEed? query returns the current speed value for the USB signal.

**Return Format** <value><NL>

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:TRIGger:USB:SOURce:DMINus](#)" on page 1441
- "[:TRIGger:USB:SOURce:DPLus](#)" on page 1442
- "[:TRIGger:USB:TRIGger](#)" on page 1444

## :TRIGger:USB:TRIGger

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:USB:TRIGger <value>`

`<value> ::= {SOP | EOP | ENTersuspend | EXITsuspend | RESet}`

The :TRIGger:USB:TRIGger command sets where the USB trigger will occur:

- SOP – Start of packet.
- EOP – End of packet.
- ENTersuspend – Enter suspend state.
- EXITsuspend – Exit suspend state.
- RESet – Reset complete.

**Query Syntax**    `:TRIGger:USB:TRIGger?`

The :TRIGger:USB:TRIGger? query returns the current USB trigger value.

**Return Format**    `<value><NL>`

`<value> ::= {SOP | EOP | ENTersuspend | EXITsuspend | RESet}`

**See Also**    ["Introduction to :TRIGger Commands" on page 1349](#)

[":TRIGger:MODE" on page 1362](#)

[":TRIGger:USB:SPEEd" on page 1443](#)

## :TRIGger:ZONE Commands

**Table 171** :TRIGger:ZONE Commands Summary

Command	Query	Options and Query Returns
:TRIGger:ZONE:SOURce <source> (see page 1446)	:TRIGger:ZONE:SOURce? (see page 1446)	<source> ::= {CHANnel<n>} <n> ::= 1 to (# analog channels) in NR1 format
:TRIGger:ZONE:STATE { {0   OFF}   {1   ON} } (see page 1447)	:TRIGger:ZONE:STATE? (see page 1447)	{0   1}
:TRIGger:ZONE<n>:MODE <mode> (see page 1448)	:TRIGger:ZONE<n>:MODE? (see page 1448)	<mode> ::= {INTERsect   NOTintersect}  <n> ::= 1-2 in NR1 format
:TRIGger:ZONE<n>:PLACEMENT <width>, <height>, <x_center>, <y_center> (see page 1449)	:TRIGger:ZONE<n>:PLACEMENT? (see page 1449)	<width> ::= width of zone in seconds  <height> ::= height of zone in volts  <x_center> ::= center of zone in seconds  <y_center> ::= center of zone in volts  <n> ::= 1-2 in NR1 format
n/a	:TRIGger:ZONE<n>:VALIDity? (see page 1450)	<value> ::= {VALID   INVALID   OSCreen}  <n> ::= 1-2 in NR1 format
:TRIGger:ZONE<n>:STATE { {0   OFF}   {1   ON} } (see page 1451)	:TRIGger:ZONE<n>:STATE? (see page 1451)	{0   1}  <n> ::= 1-2 in NR1 format

## :TRIGger:ZONE:SOURce

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:ZONE:SOURce <source>`

`<source> ::= {CHANnel<n>}`

`<n> ::= 1 to (# analog channels) in NR1 format`

The :TRIGger:ZONE:SOURce command sets the analog source channel shared by all zones.

**Query Syntax**    `:TRIGger:ZONE:SOURce?`

The :TRIGger:ZONE:SOURce? query returns the analog source channel specified for zone qualified triggers.

**Return Format**    `<source><NL>`

`<source> ::= {CHAN<n>}`

**See Also**    • [":TRIGger:ZONE:STATE"](#) on page 1447

## :TRIGger:ZONE:STATe

**N** (see [page 1666](#))

**Command Syntax** :TRIGger:ZONE:STATe <on\_off>  
 <on\_off> ::= {{0 | OFF} | {1 | ON}}

The :TRIGger:ZONE:STATe command enables or disables the zone qualified trigger feature.

When the zone qualified trigger is on, the zone(s) are actively being used to qualify the trigger.

Note that the :TRIGger:ZONE<n>:STATe setting must also be ON for a zone to be active.

Note that :TRIGger:ZONE:STATe mimics the behavior of the **[Zone]** key on the front panel, and :TRIGger:ZONE<n>:STATe mimics the behavior of the **Zone 1 On** and **Zone 2 On** softkeys. At least one zone's state must be on for the Zone Trigger feature (:TRIGger:ZONE:STATE) to be on. When the states of both individual zones are turned off, Zone Trigger is automatically turned off. In this case, when Zone Trigger is turned back on Zone 1 is forced to on. Otherwise, if at least one zone was on when Zone Trigger was turned off, the same configuration of individual zone on/off states will be restored when Zone Trigger is turned back on.

**Query Syntax** :TRIGger:ZONE:STATe?

The :TRIGger:ZONE:STATe? query returns whether the zone qualified trigger feature is enabled or disabled.

**Return Format** <on\_off><NL>  
 <on\_off> ::= {0 | 1}

**See Also**

- "[:TRIGger:ZONE<n>:STATe](#)" on page 1451
- "[:TRIGger:ZONE:SOURce](#)" on page 1446

**:TRIGger:ZONE<n>:MODE****N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:ZONE<n>:MODE <mode>`  
`<mode> ::= {INTersect | NOTintersect}`  
`<n> ::= 1-2 in NR1 format`

The :TRIGger:ZONE<n>:MODE command sets the zone qualifying condition for Zone 1 or Zone 2 as either "Must Intersect" or "Must Not Intersect".

**Query Syntax**    `:TRIGger:ZONE<n>:MODE?`

The :TRIGger:ZONE<n>:MODE? query returns the zone qualifying condition for Zone 1 or Zone 2.

**Return Format**    `<mode><NL>`  
`<mode> ::= {INT | NOT}`

**See Also**

- "[":TRIGger:ZONE<n>:STATe](#)" on page 1451
- "[":TRIGger:ZONE<n>:PLACement](#)" on page 1449
- "[":TRIGger:ZONE<n>:VALidity](#)" on page 1450

## :TRIGger:ZONE<n>:PLACement

**N** (see [page 1666](#))

**Command Syntax**

```
:TRIGger:ZONE<n>:PLACement <width>, <height>, <x_center>, <y_center>
<width> ::= width of zone in seconds
<height> ::= height of zone in volts
<x_center> ::= center of zone in seconds
<y_center> ::= center of zone in volts
<n> ::= 1-2 in NR1 format
```

The :TRIGger:ZONE<n>:PLACement command sets the size and location of Zone 1 or Zone 2.

No error is returned if the zone is placed off-screen, or if the zones overlap such that Zone 2 becomes invalid. The :TRIGger:ZONE<n>:VALidity? query is used to retrieve this information.

**Query Syntax**

```
:TRIGger:ZONE<n>:PLACement?
```

The :TRIGger:ZONE<n>:PLACement? query returns the size and location of Zone 1 or Zone 2.

**Return Format**

```
<opt><NL>
<opt> ::= <width>, <height>, <x_center>, <y_center>
```

**See Also**

- [":TRIGger:ZONE<n>:STATe"](#) on page 1451
- [":TRIGger:ZONE<n>:MODE"](#) on page 1448
- [":TRIGger:ZONE<n>:VALidity"](#) on page 1450

## :TRIGger:ZONE<n>:VALidity

**N** (see [page 1666](#))

**Query Syntax**    `:TRIGger:ZONE<n>:VALidity?`

`<n>` ::= 1-2 in NR1 format

The `:TRIGger:ZONE<n>:VALidity?` query returns the validity of Zone 1 or Zone 2.

- INValid is returned (for Zone 2 only) when Zone 1 and Zone 2 overlap and have opposing qualifying conditions (modes). Zone 1 can never be invalid.
- OSCReen (off-screen) is returned when the associated zone is off-screen, and thus not being used to qualify the trigger.
- A zone is valid when it is neither invalid nor off-screen.

The validity of a zone is not affected by the zone's state. For example, a zone can be valid and off. You cannot directly set the validity of a zone.

**Return Format**    `<validity><NL>`  
`<validity>` ::= {VALid | INValid | OSCReen}

**See Also**

- "[:TRIGger:ZONE<n>:STATe](#)" on page 1451
- "[:TRIGger:ZONE<n>:MODE](#)" on page 1448
- "[:TRIGger:ZONE<n>:PLACement](#)" on page 1449

## :TRIGger:ZONE<n>:STATe

**N** (see [page 1666](#))

**Command Syntax**    `:TRIGger:ZONE<n>:STATe <on_off>`

`<n> ::= {1 | 2}`

`<on_off> ::= {{0 | OFF} | {1 | ON}}`

`<n> ::= 1-2 in NR1 format`

The :TRIGger:ZONE<n>:STATe command sets the state for Zone 1 or Zone 2.

- When a zone's state is on, and the Zone Trigger feature is on (see "[:TRIGger:ZONE:STATe](#)" on page 1447), that zone is actively being used to qualify the trigger if it is not invalid or off-screen (see "[:TRIGger:ZONE<n>:VALidity](#)" on page 1450).
- When the Zone Trigger feature is off, no zones are being used to qualify the trigger, regardless of their individual states.

Note that :TRIGger:ZONE:STATe mimics the behavior of the **[Zone]** key on the front panel, and :TRIGger:ZONE<n>:STATe mimics the behavior of the **Zone 1 On** and **Zone 2 On** softkeys. At least one zone's state must be on for the Zone Trigger feature (:TRIGger:ZONE:STATe) to be on. When the states of both individual zones are turned off, Zone Trigger is automatically turned off. In this case, when Zone Trigger is turned back on Zone 1 is forced to on. Otherwise, if at least one zone was on when Zone Trigger was turned off, the same configuration of individual zone on/off states will be restored when Zone Trigger is turned back on.

**Query Syntax**    `:TRIGger:ZONE<n>:STATe?`

The :TRIGger:ZONE<n>:STATe? query returns the state of Zone 1 or Zone 2.

**Return Format**    `<on_off><NL>`

`<on_off> ::= {0 | 1}`

**See Also**

- "[:TRIGger:ZONE:STATe](#)" on page 1447
- "[:TRIGger:ZONE<n>:VALidity](#)" on page 1450



## 38 :WAVeform Commands

Provide access to waveform data. See "[Introduction to :WAVeform Commands](#)" on page 1456.

**Table 172** :WAVeform Commands Summary

Command	Query	Options and Query Returns
:WAVeform:BYTeorder <value> (see <a href="#">page 1461</a> )	:WAVeform:BYTeorder? (see <a href="#">page 1461</a> )	<value> ::= {LSBFFirst   MSBFFirst}
n/a	:WAVeform:COUNT? (see <a href="#">page 1462</a> )	<count> ::= an integer from 1 to 65536 in NR1 format
n/a	:WAVeform:DATA? (see <a href="#">page 1463</a> )	<binary block length bytes>, <binary data>  For example, to transmit 1000 bytes of data, the syntax would be: #800001000<1000 bytes of data><NL>  8 is the number of digits that follow  00001000 is the number of bytes to be transmitted  <1000 bytes of data> is the actual data
:WAVeform:FORMAT <value> (see <a href="#">page 1465</a> )	:WAVeform:FORMAT? (see <a href="#">page 1465</a> )	<value> ::= {WORD   BYTE   ASCII}

**Table 172** :WAVEform Commands Summary (continued)

Command	Query	Options and Query Returns
:WAVEform:POINTs <# points> (see <a href="#">page 1466</a> )	:WAVEform:POINTs? (see <a href="#">page 1466</a> )	<# points> ::= {100   250   500   1000   <points_mode>} if waveform points mode is NORMAl  <# points> ::= {100   250   500   1000   2000 ... 8000000 in 1-2-5 sequence   <points_mode>} if waveform points mode is MAXimum or RAW  <points_mode> ::= {NORMAl   MAXimum   RAW}
:WAVEform:POINTs:MODE <points_mode> (see <a href="#">page 1468</a> )	:WAVEform:POINTs:MODE? (see <a href="#">page 1468</a> )	<points_mode> ::= {NORMAl   MAXimum   RAW}
n/a	:WAVEform:PREamble? (see <a href="#">page 1470</a> )	<preamble_block> ::= <format NR1>, <type NR1>, <points NR1>, <count NR1>, <xincrement NR3>, <xorigin NR3>, <xreference NR1>, <yincrement NR3>, <yorigin NR3>, <yreference NR1>  <format> ::= an integer in NR1 format: <ul style="list-style-type: none"><li>• 0 for BYTE format</li><li>• 1 for WORD format</li><li>• 2 for ASCii format</li></ul> <type> ::= an integer in NR1 format: <ul style="list-style-type: none"><li>• 0 for NORMAl type</li><li>• 1 for PEAK detect type</li><li>• 3 for AVERage type</li><li>• 4 for HRESolution type</li></ul> <count> ::= Average count, or 1 if PEAK detect type or NORMAl; an integer in NR1 format
:WAVEform:SEGmented:A LL {{0   OFF}   {1   ON}} (see <a href="#">page 1473</a> )	:WAVEform:SEGmented:A LL? (see <a href="#">page 1473</a> )	<setting> ::= {0   1}
n/a	:WAVEform:SEGmented:C OUNT? (see <a href="#">page 1474</a> )	<count> ::= an integer from 2 to 1000 in NR1 format
n/a	:WAVEform:SEGmented:T TAG? (see <a href="#">page 1475</a> )	<time_tag> ::= in NR3 format

**Table 172** :WAVeform Commands Summary (continued)

Command	Query	Options and Query Returns
n/a	:WAVeform:SEGmented:XLIST? <xlist_type> (see <a href="#">page 1476</a> )	<xlist_type> ::= {RELXorigin   ABSXorigin   TTAG} <return_value> ::= X-info for all segments
:WAVeform:SOURce <source> (see <a href="#">page 1477</a> )	:WAVeform:SOURce? (see <a href="#">page 1477</a> )	<source> ::= {CHANnel<n>   FUNCtion<m>   MATH<m>   FFT   SBUS} for DSO models  <source> ::= {CHANnel<n>   POD{1   2}   BUS{1   2}   FUNCtion<m>   MATH<m>   FFT   SBUS} for MSO models  <n> ::= 1 to (# analog channels) in NR1 format  <m> ::= 1 to (# math functions) in NR1 format
:WAVeform:SOURce:SUBS ource <subsource> (see <a href="#">page 1481</a> )	:WAVeform:SOURce:SUBS ource? (see <a href="#">page 1481</a> )	<subsource> ::= {{SUB0   RX   MOSI}   {SUB1   TX   MISO}}
n/a	:WAVeform:TYPE? (see <a href="#">page 1482</a> )	<return_mode> ::= {NORM   PEAK   AVER   HRES}
:WAVeform:UNSIGNED { {0   OFF}   {1   ON} } (see <a href="#">page 1483</a> )	:WAVeform:UNSIGNED? (see <a href="#">page 1483</a> )	{0   1}
:WAVeform:VIEW <view> (see <a href="#">page 1484</a> )	:WAVeform:VIEW? (see <a href="#">page 1484</a> )	<view> ::= {MAIN   ALL}
n/a	:WAVeform:XINCREMENT? (see <a href="#">page 1485</a> )	<return_value> ::= x-increment in the current preamble in NR3 format
n/a	:WAVeform:XORIGIN? (see <a href="#">page 1486</a> )	<return_value> ::= x-origin value in the current preamble in NR3 format
n/a	:WAVeform:XREFERENCE? (see <a href="#">page 1487</a> )	<return_value> ::= 0 (x-reference value in the current preamble in NR1 format)
n/a	:WAVeform:YINCREMENT? (see <a href="#">page 1488</a> )	<return_value> ::= y-increment value in the current preamble in NR3 format

**Table 172** :WAVEform Commands Summary (continued)

Command	Query	Options and Query Returns
n/a	:WAVEform:YORigin? (see <a href="#">page 1489</a> )	<return_value> ::= y-origin in the current preamble in NR3 format
n/a	:WAVEform:YREFerence? (see <a href="#">page 1490</a> )	<return_value> ::= y-reference value in the current preamble in NR1 format

**Introduction to :WAVEform Commands** The WAVEform subsystem is used to transfer data to a controller from the oscilloscope waveform memories. The queries in this subsystem will only operate when the channel selected by :WAVEform:SOURce is on.

#### Waveform Data and Preamble

The waveform record is actually contained in two portions: the preamble and waveform data. The waveform record must be read from the oscilloscope by the controller using two separate commands, :WAVEform:DATA (see [page 1463](#)) and :WAVEform:PREamble (see [page 1470](#)). The waveform data is the actual data acquired for each point in the specified source. The preamble contains the information for interpreting the waveform data, which includes the number of points acquired, the format of acquired data, and the type of acquired data. The preamble also contains the X and Y increments, origins, and references for the acquired data, so that word and byte data can be translated to time and voltage values.

#### Data Acquisition Types

There are four types of waveform acquisitions that can be selected for analog channels with the :ACQuire:TYPE command (see [page 317](#)): NORMal, AVERage, PEAK, and HRESolution. Digital channels are always acquired using NORMal. When the data is acquired using the :DIGItize command (see [page 268](#)) or :RUN command (see [page 292](#)), the data is placed in the channel buffer of the specified source.

Once you have acquired data with the :DIGItize command, the instrument is stopped. If the instrument is restarted (via the programming interface or the front panel), or if any instrument setting is changed, the data acquired with the :DIGItize command may be overwritten. You should first acquire the data with the :DIGItize command, then immediately read the data with the :WAVEform:DATA? query (see [page 1463](#)) before changing any instrument setup.

A waveform record consists of either all of the acquired points or a subset of the acquired points. The number of points acquired may be queried using :ACQuire:POINts[:ANALog]? (see [page 308](#)).

#### Helpful Hints:

The number of points transferred to the computer is controlled using the :WAVeform:POINts command (see [page 1466](#)). If :WAVeform:POINts MAXimum is specified and the instrument is not running (stopped), all of the points that are displayed are transferred. This can be as many as 4,000,000 in some operating modes or as many as 8,000,000 for a digital channel on the mixed signal oscilloscope. Fewer points may be specified to speed data transfers and minimize controller analysis time. The :WAVeform:POINts may be varied even after data on a channel is acquired. However, this decimation may result in lost pulses and transitions. The number of points selected for transfer using :WAVeform:POINts must be an even divisor of 1,000 or be set to MAXimum. :WAVeform:POINTS determines the increment between time buckets that will be transferred. If POINTs = MAXimum, the data cannot be decimated. For example:

- `:WAVeform:POINTS 1000` – returns time buckets 0, 1, 2, 3, 4 ..., 999.
- `:WAVeform:POINTS 500` – returns time buckets 0, 2, 4, 6, 8 ..., 998.
- `:WAVeform:POINTS 250` – returns time buckets 0, 4, 8, 12, 16 ..., 996.
- `:WAVeform:POINTS 100` – returns time buckets 0, 10, 20, 30, 40 ..., 990.

### Analog Channel Data

#### **NORMal Data**

Normal data consists of the last data point (hit) in each time bucket. This data is transmitted over the programming interface in a linear fashion starting with time bucket 0 and going through time bucket n - 1, where n is the number returned by the :WAVeform:POINts? query (see [page 1466](#)). Only the magnitude values of each data point are transmitted. The first voltage value corresponds to the first time bucket on the left side of the screen and the last value corresponds to the next-to-last time bucket on the right side of the screen. Time buckets without data return 0. The time values for each data point correspond to the position of the data point in the data array. These time values are not transmitted.

#### **AVERage Data**

AVERage data consists of the average of the first n hits in a time bucket, where n is the value returned by the :ACQuire:COUNt query (see [page 304](#)). Time buckets that have fewer than n hits return the average of the data they do have. If a time bucket does not have any data in it, it returns 0.

This data is transmitted over the interface linearly, starting with time bucket 0 and proceeding through time bucket n-1, where n is the number returned by the :WAVeform:POINts? query (see [page 1466](#)). The first value corresponds to a point at the left side of the screen and the last value corresponds to one point away from the right side of the screen. The maximum number of points that can be returned in average mode is 1000 unless ACQuire:COUNt has been set to 1.

#### **PEAK Data**

Peak detect display mode is used to detect glitches for time base settings of 500 us/div and slower. In this mode, the oscilloscope can sample more data than it can store and display. So, when peak detect is turned on, the oscilloscope scans through the extra data, picks up the minimum and maximum for each time bucket, then stores the data in an array. Each time bucket contains two data sample.

The array is transmitted over the interface bus linearly, starting with time bucket 0 proceeding through time bucket n-1, where n is the number returned by the :WAVeform:POINts? query (see [page 1466](#)). In each time bucket, two values are transmitted, first the minimum, followed by the maximum. The first pair of values corresponds to the time bucket at the leftmost side of the screen. The last pair of values corresponds to the time bucket at the far right side of the screen. In :ACQuire:TYPE PEAK mode (see [page 317](#)), the value returned by the :WAVeform:XINCrement query (see [page 1485](#)) should be doubled to find the time difference between the min-max pairs.

### **HRESolution Data**

The high resolution (*smoothing*) mode is used to reduce noise at slower sweep speeds where the digitizer samples faster than needed to fill memory for the displayed time range.

### **Data Conversion**

Word or byte data sent from the oscilloscope must be scaled for useful interpretation. The values used to interpret the data are the X and Y references, X and Y origins, and X and Y increments. These values are read from the waveform preamble. Each channel has its own waveform preamble.

In converting a data value to a voltage value, the following formula is used:

$$\text{voltage} = [(\text{data value} - \text{yreference}) * \text{yincrement}] + \text{yorigin}$$

If the :WAVeform:FORMat data format is ASCII (see [page 1465](#)), the data values are converted internally and sent as floating point values separated by commas.

In converting a data value to time, the time value of a data point can be determined by the position of the data point. For example, the fourth data point sent with :WAVeform:XORigin = 16 ns, :WAVeform:XREFerence = 0, and :WAVeform:XINCrement = 2 ns, can be calculated using the following formula:

$$\text{time} = [(\text{data point number} - \text{xreference}) * \text{xincrement}] + \text{xorigin}$$

This would result in the following calculation for time bucket 3:

$$\text{time} = [(3 - 0) * 2 \text{ ns}] + 16 \text{ ns} = 22 \text{ ns}$$

In :ACQuire:TYPE PEAK mode (see [page 317](#)), because data is acquired in max-min pairs, modify the previous time formula to the following:

$$\text{time} = [(\text{data pair number} - \text{xreference}) * \text{xincrement} * 2] + \text{xorigin}$$

### **Data Format for Transfer**

There are three formats for transferring waveform data over the interface: BYTE, WORD and ASCII (see "[:WAVeform:FORMAT](#)" on page 1465). BYTE, WORD and ASCII formatted waveform records are transmitted using the arbitrary block program data format specified in IEEE 488.2.

When you use the block data format, the ASCII character string "#8<DD...D>" is sent prior to sending the actual data. The 8 indicates how many Ds follow. The Ds are ASCII numbers that indicate how many data bytes follow.

For example, if 1000 points will be transferred, and the WORD format was specified, the block header "#800001000" would be sent. The 8 indicates that eight length bytes follow, and 00001000 indicates that 1000 binary data bytes follow.

Use the :WAVeform:UNSIGNED command (see [page 1483](#)) to control whether data values are sent as unsigned or signed integers. This command can be used to match the instrument's internal data type to the data type used by the programming language. This command has no effect if the data format is ASCII.

#### Data Format for Transfer - ASCII format

The ASCII format (see "[:WAVeform:FORMAT](#)" on page 1465) provides access to the waveform data as real Y-axis values without using Y origin, Y reference, and Y increment to convert the binary data. Values are transferred as ASCII digits in floating point format separated by commas. In ASCII format, holes are represented by the value 9.9e+37. The setting of :WAVeform:BYTeorder (see [page 1461](#)) and :WAVeform:UNSIGNED (see [page 1483](#)) have no effect when the format is ASCII.

#### Data Format for Transfer - WORD format

WORD format (see "[:WAVeform:FORMAT](#)" on page 1465) provides 16-bit access to the waveform data. In the WORD format, the number of data bytes is twice the number of data points. The number of data points is the value returned by the :WAVeform:POINTS? query (see [page 1466](#)). If the data intrinsically has less than 16 bits of resolution, the data is left-shifted to provide 16 bits of resolution and the least significant bits are set to 0. Currently, the greatest intrinsic resolution of any data is 12 bits, so at least the lowest 4 bits of data will be 0. If there is a hole in the data, the hole is represented by a 16 bit value equal to 0.

Use :WAVeform:BYTeorder (see [page 1461](#)) to determine if the least significant byte or most significant byte is to be transferred first. The :BYTeorder command can be used to alter the transmit sequence to match the storage sequence of an integer in the programming language being used.

#### Data Format for Transfer - BYTE format

The BYTE format (see "[:WAVeform:FORMAT](#)" on page 1465) allows 8-bit access to the waveform data. If the data intrinsically has more than 8 bits of resolution (averaged data), the data is right-shifted (truncated) to fit into 8 bits.

If there is a hole in the data, the hole is represented by a value of 0. The BYTE-formatted data transfers over the programming interface faster than ASCII or WORD-formatted data, because in ASCII format, as many as 13 bytes per point are transferred, in BYTE format one byte per point is transferred, and in WORD format two bytes per point are transferred.

The :WAVeform:BYTeorder command (see [page 1461](#)) has no effect when the data format is BYTE.

#### Digital Channel Data (MSO models only)

The waveform record for digital channels is similar to that of analog channels. The main difference is that the data points represent either DIGital0...7 (POD1), DIGital8...15 (POD2), or any grouping of digital channels (BUS1 or BUS2).

For digital channels, :WAVeform:UNSIGNED (see [page 1483](#)) must be set to ON.

#### Digital Channel POD Data Format

Data for digital channels is only available in groups of 8 bits (Pod1 = D0 - D7, Pod2 = D8 - D15). The bytes are organized as:

:WAVeform:SOURce	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0
POD1	D7	D6	D5	D4	D3	D2	D1	D0
POD2	D15	D14	D13	D12	D11	D10	D9	D8

If the :WAVeform:FORMAT is WORD (see [page 1465](#)) is WORD, every other data byte will be 0. The setting of :WAVeform:BYTeorder (see [page 1461](#)) controls which byte is 0.

If a digital channel is not displayed, its bit value in the pod data byte is not defined.

#### Digital Channel BUS Data Format

Digital channel BUS definitions can include any or all of the digital channels. Therefore, data is always returned as 16-bit values. :BUS commands (see [page 319](#)) are used to select the digital channels for a bus.

#### Reporting the Setup

The following is a sample response from the :WAVeform? query. In this case, the query was issued following a \*RST command.

```
:WAV:UNS 1;VIEW MAIN;BYT MSBF;FORM BYTE;POIN +1000;SOUR CHAN1;SOUR:SUBS NONE
```

## :WAVeform:BYTeorder

**C** (see [page 1666](#))

<b>Command Syntax</b>	<code>:WAVeform:BYTeorder &lt;value&gt;</code> <code>&lt;value&gt; ::= {LSBFFirst   MSBFFirst}</code>
	The :WAVeform:BYTeorder command sets the output sequence of the WORD data.
	<ul style="list-style-type: none"> <li>• MSBFFirst – sets the most significant byte to be transmitted first.</li> <li>• LSBFirst – sets the least significant byte to be transmitted first.</li> </ul>
	This command affects the transmitting sequence only when :WAVeform:FORMat WORD is selected.
	The default setting is MSBFFirst.
<b>Query Syntax</b>	<code>:WAVeform:BYTeorder?</code>
	The :WAVeform:BYTeorder query returns the current output sequence.
<b>Return Format</b>	<code>&lt;value&gt;&lt;NL&gt;</code> <code>&lt;value&gt; ::= {LSBF   MSBF}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">Introduction to :WAVeform Commands</a>" on page 1456</li> <li>• "<a href="#">":WAVeform:DATA</a>" on page 1463</li> <li>• "<a href="#">":WAVeform:FORMat</a>" on page 1465</li> <li>• "<a href="#">":WAVeform:PREamble</a>" on page 1470</li> </ul>
<b>Example Code</b>	<ul style="list-style-type: none"> <li>• "<a href="#">":Example Code</a>" on page 1478</li> <li>• "<a href="#">":Example Code</a>" on page 1471</li> </ul>

## :WAVeform:COUNT

 (see [page 1666](#))

**Query Syntax**    `:WAVeform:COUNT?`

The `:WAVeform:COUNT?` query returns the count used to acquire the current waveform. This may differ from current values if the unit has been stopped and its configuration modified. For all acquisition types except average, this value is 1.

**Return Format**    `<count_argument><NL>`

`<count_argument>` ::= an integer from 1 to 65536 in NR1 format

**See Also**

- ["Introduction to :WAVeform Commands"](#) on page 1456
- [":ACQuire:COUNT"](#) on page 304
- [":ACQuire:TYPE"](#) on page 317

## :WAVeform:DATA

**C** (see [page 1666](#))

**Query Syntax** :WAVeform:DATA?

The :WAVeform:DATA query returns the binary block of sampled data points transmitted using the IEEE 488.2 arbitrary block data format. The binary data is formatted according to the settings of the :WAVeform:UNSIGNED, :WAVeform:BYTeorder, :WAVeform:FORMat, and :WAVeform:SOURce commands. The number of points returned is controlled by the :WAVeform:POINTs command.

In BYTE or WORD waveform formats, these data values have special meaning:

- 0x00 or 0x0000 – Hole. Holes are locations where data has not yet been acquired.

Another situation where there can be zeros in the data, incorrectly, is when programming over telnet port 5024. Port 5024 provides a command prompt and is intended for ASCII transfers. Use telnet port 5025 instead.

- 0x01 or 0x0001 – Clipped low. These are locations where the waveform is clipped at the bottom of the oscilloscope display.
- 0xFF or 0xFFFF – Clipped high. These are locations where the waveform is clipped at the top of the oscilloscope display.

**Return Format** <binary block data><NL>

**See Also**

- For a more detailed description of the data returned for different acquisition types, see: ["Introduction to :WAVeform Commands" on page 1456](#)
- [":WAVeform:UNSIGNED" on page 1483](#)
- [":WAVeform:BYTeorder" on page 1461](#)
- [":WAVeform:FORMat" on page 1465](#)
- [":WAVeform:POINTs" on page 1466](#)
- [":WAVeform:PREamble" on page 1470](#)
- [":WAVeform:SOURce" on page 1477](#)
- [":WAVeform:TYPE" on page 1482](#)

**Example Code**

```

' QUERY_WAVE_DATA - Outputs waveform data that is stored in a buffer.

' Query the oscilloscope for the waveform data.
myScope.WriteString ":WAV:DATA?"

' READ_WAVE_DATA - The wave data consists of two parts: the header,
' and the actual waveform data followed by a new line (NL) character.
' The query data has the following format:
'
'     <header><waveform_data><NL>
'
' Where:

```

```

'      <header> = #800001000 (This is an example header)
' The "#8" may be stripped off of the header and the remaining
' numbers are the size, in bytes, of the waveform data block. The
' size can vary depending on the number of points acquired for the
' waveform. You can then read that number of bytes from the
' oscilloscope and the terminating NL character.
'

Dim lngI As Long
Dim lngDataValue As Long

varQueryResult = myScope.ReadIEEEBlock(BinaryType_UI1)
' Unsigned integer bytes.
For lngI = 0 To UBound(varQueryResult) -
    Step (UBound(varQueryResult) / 20) - ' 20 points.
    If intBytesPerData = 2 Then
        lngDataValue = varQueryResult(lngI) * 256 -
            + varQueryResult(lngI + 1) ' 16-bit value.
    Else
        lngDataValue = varQueryResult(lngI) ' 8-bit value.
    End If
    strOutput = strOutput + "Data point " + _
        CStr(lngI / intBytesPerData) + ", " + _
        FormatNumber((lngDataValue - lngYReference) -
            * sngYIncrement + sngYOrigin) + " V, " + _
        FormatNumber(((lngI / intBytesPerData - lngXReference) -
            * sngXIncrement + dblXOrigin) * 1000000) + " us" + vbCrLf
Next lngI
MsgBox "Waveform data:" + vbCrLf + strOutput

```

See complete example programs at: [Chapter 46](#), “Programming Examples,” starting on page 1675

## :WAVeform:FORMAT

**C** (see [page 1666](#))

**Command Syntax** :WAVeform:FORMAT <value>

<value> ::= {WORD | BYTE | ASCii}

The :WAVeform:FORMAT command sets the data transmission mode for waveform data points. This command controls how the data is formatted when sent from the oscilloscope.

- ASCii formatted data converts the internal integer data values to real Y-axis values. Values are transferred as ASCii digits in floating point notation, separated by commas.

ASCII formatted data is transferred ASCii text.

- WORD formatted data transfers 16-bit data as two bytes. The :WAVeform:BYTeorder command can be used to specify whether the upper or lower byte is transmitted first. The default (no command sent) is that the upper byte transmitted first.
- BYTE formatted data is transferred as 8-bit bytes.

When the :WAVeform:SOURce is the serial decode bus (SBUS1 or SBUS2), ASCii is the only waveform format allowed.

When the :WAVeform:SOURce is one of the digital channel buses (BUS1 or BUS2), ASCii and WORD are the only waveform formats allowed.

**Query Syntax** :WAVeform:FORMAT?

The :WAVeform:FORMAT query returns the current output format for the transfer of waveform data.

**Return Format** <value><NL>

<value> ::= {WORD | BYTE | ASC}

- See Also**
- "[Introduction to :WAVeform Commands](#)" on page 1456
  - "[":WAVeform:BYTeorder](#)" on page 1461
  - "[":WAVeform:SOURce](#)" on page 1477
  - "[":WAVeform:DATA](#)" on page 1463
  - "[":WAVeform:PREamble](#)" on page 1470

- Example Code**
- "[Example Code](#)" on page 1478

## :WAVEform:POINTS

**C** (see [page 1666](#))

**Command Syntax**

```
:WAVEform:POINTS <# points>
<# points> ::= {100 | 250 | 500 | 1000 | <points mode>}
               if waveform points mode is NORMAl
<# points> ::= {100 | 250 | 500 | 1000 | 2000 | 5000 | 10000 | 20000
               | 50000 | 100000 | 200000 | 500000 | 1000000 | 2000000
               | 4000000 | 8000000 | <points mode>}
               if waveform points mode is MAXimum or RAW
<points mode> ::= {NORMAl | MAXimum | RAW}
```

### NOTE

The <points\_mode> option is deprecated. Use the :WAVEform:POINTS:MODE command instead.

The :WAVEform:POINTS command sets the number of waveform points to be transferred with the :WAVEform:DATA? query. This value represents the points contained in the waveform selected with the :WAVEform:SOURce command.

For the analog or digital sources, the records that can be transferred depend on the waveform points mode. The maximum number of points returned for math (function) waveforms is determined by the NORMAl waveform points mode. See the :WAVEform:POINTS:MODE command ([see page 1468](#)) for more information.

Only data visible on the display will be returned.

When the :WAVEform:SOURce is the serial decode bus (SBUS1 or SBUS2), this command is ignored, and all available serial decode bus data is returned.

**Query Syntax**

:WAVEform:POINTS?

The :WAVEform:POINTS query returns the number of waveform points to be transferred when using the :WAVEform:DATA? query. Setting the points mode will affect what data is transferred (see the :WAVEform:POINTS:MODE command ([see page 1468](#)) for more information).

When the :WAVEform:SOURce is the serial decode bus (SBUS1 or SBUS2), this query returns the number of messages that were decoded.

**Return Format**

```
<# points><NL>
<# points> ::= {100 | 250 | 500 | 1000 | <maximum # points>}
               if waveform points mode is NORMAl
<# points> ::= {100 | 250 | 500 | 1000 | 2000 | 5000 | 10000 | 20000
               | 50000 | 100000 | 200000 | 500000 | 1000000 | 2000000
               | 4000000 | 8000000 | <maximum # points>}
               if waveform points mode is MAXimum or RAW
```

**NOTE**

If a full screen of data is not displayed, the number of points returned will not be 1000 or an even divisor of it.

---

**See Also**

- "[Introduction to :WAVeform Commands](#)" on page 1456
- "[:ACQuire:POINts\[:ANALog\]](#)" on page 308
- "[:WAVeform:DATA](#)" on page 1463
- "[:WAVeform:SOURce](#)" on page 1477
- "[:WAVeform:VIEW](#)" on page 1484
- "[:WAVeform:PREamble](#)" on page 1470
- "[:WAVeform:POINts:MODE](#)" on page 1468

**Example Code**

```
' WAVE_POINTS - Specifies the number of points to be transferred  
' using the ":WAVEFORM:DATA?" query.  
myScope.WriteString ":WAVEFORM:POINTS 1000"
```

See complete example programs at: [Chapter 46](#), "Programming Examples," starting on page 1675

## :WAVEform:POINTS:MODE

**N** (see [page 1666](#))

**Command Syntax** :WAVEform:POINTS:MODE <points\_mode>

<points\_mode> ::= {NORMAl | MAXimum | RAW}

The :WAVEform:POINTS:MODE command sets the data record to be transferred with the :WAVEform:DATA? query.

For the analog or digital sources, there are two different records that can be transferred:

- The first is the raw acquisition record. The maximum number of points available in this record is returned by the :ACQuire:POINTS? query. The raw acquisition record can only be retrieved from the analog or digital sources.
- The second is referred to as the *measurement record* and is a 62,500-point (maximum) representation of the raw acquisition record. The measurement record can be retrieved from any source.

If the <points\_mode> is NORMAl the measurement record is retrieved.

If the <points\_mode> is RAW, the raw acquisition record is used. Under some conditions, this data record is unavailable.

If the <points\_mode> is MAXimum, whichever record contains the maximum amount of points is used. Usually, this is the raw acquisition record. But, the measurement record may have more data. If data is being retrieved as the oscilloscope is stopped and as the data displayed is changing, the data being retrieved can switch between the measurement and raw acquisition records.

### NOTE

If the :WAVEform:SOURce is not an analog or digital source, the only valid parameters for WAVEform:POINTS:MODE is NORMAl or MAXimum.

### Considerations for MAXimum or RAW data retrieval

- The instrument must be stopped (see the :STOP command (see [page 296](#)) or the :DIGItize command (see [page 268](#)) in the root subsystem) in order to return more than the *measurement record*.
- :TIMEbase:MODE must be set to MAIN.
- :ACQuire:TYPE must be set to NORMAl, AVERage, or HRESolution.
- MAXimum or RAW will allow up to 4,000,000 points to be returned. The number of points returned will vary as the instrument's configuration is changed. Use the :WAVEform:POINTS? MAXimum query to determine the maximum number of points that can be retrieved at the current settings.

**Query Syntax** :WAVEform:POINTS:MODE?

The :WAVeform:POINts:MODE? query returns the current points mode. Setting the points mode will affect what data is transferred. See the discussion above.

**Return Format** <points\_mode><NL>  
<points\_mode> ::= {NORMal | MAXimum | RAW}

- See Also**
- "[Introduction to :WAVeform Commands](#)" on page 1456
  - "[:WAVeform:DATA](#)" on page 1463
  - "[:ACQuire:POINts\[:ANALog\]](#)" on page 308
  - "[:WAVeform:VIEW](#)" on page 1484
  - "[:WAVeform:PREamble](#)" on page 1470
  - "[:WAVeform:POINts](#)" on page 1466
  - "[:TIMEbase:MODE](#)" on page 1339
  - "[:ACQuire:TYPE](#)" on page 317
  - "[:ACQuire:COUNT](#)" on page 304

## :WAVeform:PREamble

**C** (see [page 1666](#))

**Query Syntax**    `:WAVeform:PREamble?`

The `:WAVeform:PREamble` query requests the preamble information for the selected waveform source. The preamble data contains information concerning the vertical and horizontal scaling of the data of the corresponding channel.

**Return Format**    `<preamble_block><NL>`

```


<preamble_block> ::= <format 16-bit NR1>,
                    <type 16-bit NR1>,
                    <points 32-bit NR1>,
                    <count 32-bit NR1>,
                    <xincrement 64-bit floating point NR3>,
                    <xorigin 64-bit floating point NR3>,
                    <xreference 32-bit NR1>,
                    <yincrement 32-bit floating point NR3>,
                    <yorigin 32-bit floating point NR3>,
                    <yreference 32-bit NR1>

<format> ::= 0 for BYTE format, 1 for WORD format, 4 for ASCII format;
            an integer in NR1 format (format set by :WAVeform:FORMAT).

<type> ::= 3 for HRESolution type, 2 for AVERage type, 0 for NORMAl
            type, 1 for PEAK detect type; an integer in NR1 format
            (type set by :ACQuire:TYPE).

<count> ::= Average count or 1 if PEAK or NORMAl; an integer in NR1
            format (count set by :ACQuire:COUNT).

```



**See Also**

- ["Introduction to :WAVeform Commands"](#) on page 1456
- [":ACQuire:COUNT"](#) on page 304
- [":ACQuire:POINTs\[:ANALog\]"](#) on page 308

- "[:ACQuire:TYPE](#)" on page 317
- "[:DIGitize](#)" on page 268
- "[:WAVeform:COUNT](#)" on page 1462
- "[:WAVeform:DATA](#)" on page 1463
- "[:WAVeform:FORMAT](#)" on page 1465
- "[:WAVeform:POINts](#)" on page 1466
- "[:WAVeform:TYPE](#)" on page 1482
- "[:WAVeform:XINCrement](#)" on page 1485
- "[:WAVeform:XORigin](#)" on page 1486
- "[:WAVeform:XREFerence](#)" on page 1487
- "[:WAVeform:YINCrement](#)" on page 1488
- "[:WAVeform:YORigin](#)" on page 1489
- "[:WAVeform:YREFerence](#)" on page 1490

**Example Code**

```

' GET_PREAMBLE - The preamble block contains all of the current
' WAVEFORM settings. It is returned in the form <preamble_block><NL>
' where <preamble_block> is:
'   FORMAT      : int16 - 0 = BYTE, 1 = WORD, 4 = ASCII.
'   TYPE        : int16 - 0 = NORM, 1 = PEAK, 2 = AVER, 3 = HRES
'   POINTS     : int32 - number of data points transferred.
'   COUNT       : int32 - 1 and is always 1.
'   XINCREMENT : float64 - time difference between data points.
'   XORIGIN    : float64 - always the first data point in memory.
'   XREFERENCE : int32 - specifies the data point associated with
'                      x-origin.
'   YINCREMENT : float32 - voltage diff between data points.
'   YORIGIN    : float32 - value is the voltage at center screen.
'   YREFERENCE : int32 - specifies the data point where y-origin
'                      occurs.

Dim Preamble()
Dim intFormat As Integer
Dim intType As Integer
Dim lngPoints As Long
Dim lngCount As Long
Dim dblXIncrement As Double
Dim dblXOrigin As Double
Dim lngXReference As Long
Dim sngYIncrement As Single
Dim sngYOrigin As Single
Dim lngYReference As Long
Dim strOutput As String

myScope.WriteString ":WAVEFORM:PREAMBLE?" ' Query for the preamble.
Preamble() = myScope.ReadList ' Read preamble information.
intFormat = Preamble(0)
intType = Preamble(1)
lngPoints = Preamble(2)
lngCount = Preamble(3)
dblXIncrement = Preamble(4)

```

```
dblXOrigin = Preamble(5)
lngXReference = Preamble(6)
sngYIncrement = Preamble(7)
sngYOrigin = Preamble(8)
lngYReference = Preamble(9)
```

See complete example programs at: [Chapter 46](#), “Programming Examples,” starting on page 1675

## :WAVeform:SEGmented:ALL

**N** (see [page 1666](#))

**Command Syntax** :WAVeform:SEGmented:ALL { {0 | OFF} | {1 | ON} }

The :WAVeform:SEGmented:ALL command enables or disables the "waveform data for all segments" setting:

- ON – The :WAVeform:DATA? query returns data for all segments.  
ON is available only when the :WAVeform:SOURce is an analog input channel.  
When ON, the :WAVeform:DATA? query returns data for the number of segments multiplied by the number of points in a segment (which is the points value returned by the :WAVeform:POINts? or :WAVeform:PREamble? queries).
- OFF – The :WAVeform:DATA? query returns data for the current segment.

The ability to get waveform data for all segments is faster and more convenient than iterating over multiple segments and retrieving each one separately.

The performance improvement comes primarily when raw acquisition record data is being retrieved (:WAVeform:POINts:MODE RAW) instead of the measurement record data (:WAVeform:POINts:MODE NORMAl).

One corner case where you may want to retrieve the measurement record data is when the acquired data for a segment is less than the screen resolution and the measurement record is interpolated.

Most often though, the acquired data for a segment is enough to fill the screen, and less than the maximum measurement record size, so the segmented raw acquisition data and the measurement record data are the same.

If the number of segments is small, the raw acquisition segment size is greater than the measurement record size.

**Query Syntax** :WAVeform:SEGmented:ALL?

The :WAVeform:SEGmented:ALL? query returns the "waveform data for all segments" setting.

**Return Format** <setting><NL>

<setting> ::= {0 | 1}

**See Also**

- "[:WAVeform:DATA](#)" on page 1463
- "[:WAVeform:SEGmented:XLIST](#)" on page 1476
- "[:WAVeform:POINts:MODE](#)" on page 1468
- "[:WAVeform:POINts](#)" on page 1466
- "[:WAVeform:PREamble](#)" on page 1470

## :WAVeform:SEGmented:COUNt

**N** (see [page 1666](#))

**Query Syntax** `:WAVeform:SEGmented:COUNt?`

The `:WAVeform:SEGmented:COUNt` query returns the number of memory segments in the acquired data. You can use the `:WAVeform:SEGmented:COUNt?` query while segments are being acquired (although `:DIGitize` blocks subsequent queries until the full segmented acquisition is complete).

The segmented memory acquisition mode is enabled with the `:ACQuire:MODE` command. The number of segments to acquire is set using the `:ACQuire:SEGmented:COUNt` command, and data is acquired using the `:DIGITIZE`, `:SINGle`, or `:RUN` commands.

**Return Format** `<count> ::= an integer from 2 to 1000 in NR1 format (count set by :ACQuire:SEGmented:COUNt).`

**See Also**

- [":ACQuire:MODE"](#) on page 307
- [":ACQuire:SEGmented:COUNt"](#) on page 311
- [":DIGITIZE"](#) on page 268
- [":SINGle"](#) on page 294
- [":RUN"](#) on page 292
- ["Introduction to :WAVeform Commands"](#) on page 1456

**Example Code** · ["Example Code"](#) on page 312

## :WAVeform:SEGMedted:TTAG

**N** (see [page 1666](#))

**Query Syntax** `:WAVeform:SEGMedted:TTAG?`

The `:WAVeform:SEGMedted:TTAG?` query returns the time tag of the currently selected segmented memory index. The index is selected using the `:ACQuire:SEGMedted:INDex` command.

**Return Format** `<time_tag> ::= in NR3 format`

- See Also**
- [":ACQuire:SEGMedted:INDex"](#) on page 312
  - ["Introduction to :WAVeform Commands"](#) on page 1456

**Example Code**

- ["Example Code"](#) on page 312

## :WAVeform:SEGMedted:XLIST

**N** (see [page 1666](#))

**Query Syntax**    `:WAVeform:SEGMedted:XLIST? <xlist_type>`  
`<xlist_type> ::= {RELXorigin | ABSXorigin | TTAG}`

The :WAVeform:SEGMedted:XLIST? query returns the X (time) information for all segments at once. The <xlist\_type> option specifies the type of information that is returned:

- RELXorigin – The relative X-origin for each segment (the value returned by the :WAVeform:XORigin? query) is returned.
- TTAG – The time tag for each segment (the value returned by the :WAVeform:SEGMedted:TTAG? query) will be returned.
- ABSXorigin – The sum of the values of the RELXorigin and TTAG types is returned for each segment.

This command is useful when getting the waveform data for all segments at once (see :WAVeform:SEGMedted:ALL).

**Return Format**    `<return_value><NL>`  
`<return_value> ::= binary block data in IEEE 488.2 # format, contains comma-separated string with X-info for all segments`

**See Also**

- "[:WAVeform:XORigin](#)" on page 1486
- "[:WAVeform:SEGMedted:TTAG](#)" on page 1475
- "[:WAVeform:SEGMedted:ALL](#)" on page 1473

## :WAVeform:SOURce

**C** (see [page 1666](#))

### Command Syntax

```
:WAVeform:SOURce <source>
<source> ::= {CHANnel<n> | FUNCtion<m> | MATH<m> | FFT | WMEMory<r>
              | SBUS{1 | 2}} for DSO models
<source> ::= {CHANnel<n> | POD{1 | 2} | BUS{1 | 2} | FUNCtion<m>
              | MATH<m> | FFT | WMEMory<r> | SBUS{1 | 2}} for MSO models
<n> ::= 1 to (# analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :WAVeform:SOURce command selects the analog channel, function, digital pod, digital bus, reference waveform, or serial decode bus to be used as the source for the :WAVeform commands.

Function capabilities include add, subtract, multiply, integrate, differentiate, and FFT (Fast Fourier Transform) operations.

When the :WAVeform:SOURce is the serial decode bus (SBUS1 or SBUS2), ASCII is the only waveform format allowed, and the :WAVeform:DATA? query returns a string with timestamps and associated bus decode information.

With MSO oscilloscope models, you can choose a POD or BUS as the waveform source. There are some differences between POD and BUS when formatting and getting data from the oscilloscope:

- When POD1 or POD2 is selected as the waveform source, you can choose the BYTE, WORD, or ASCII formats (see "[:WAVeform:FORMAT](#)" on page 1465).

When the WORD format is chosen, every other data byte will be 0. The setting of :WAVeform:BYTeorder controls which byte is 0.

When the ASCII format is chosen, the :WAVeform:DATA? query returns a string with unsigned decimal values separated by commas.

- When BUS1 or BUS2 is selected as the waveform source, you can choose the WORD or ASCII formats (but not BYTE because bus values are always returned as 16-bit values).

When the ASCII format is chosen, the :WAVeform:DATA? query returns a string with hexadecimal bus values, for example: 0x1938,0xff38,...

### Query Syntax

```
:WAVeform:SOURce?
```

The :WAVeform:SOURce? query returns the currently selected source for the WAVeform commands.

**NOTE**

MATH<m> is an alias for FUNCtion<m>. The :WAVeform:SOURce? query returns FUNC<m> if the source is FUNCtion<m> or MATH<m>.

Return Format	<pre>&lt;source&gt;&lt;NL&gt; &lt;source&gt; ::= {CHAN&lt;n&gt;   FUNC&lt;m&gt;   WMEM&lt;r&gt;   SBUS{1   2}} for DSO models &lt;source&gt; ::= {CHAN&lt;n&gt;   POD{1   2}   BUS{1   2}   FUNC&lt;m&gt;                  WMEM&lt;r&gt;   SBUS{1   2}} for MSO models &lt;n&gt; ::= 1 to (# analog channels) in NR1 format &lt;m&gt; ::= 1 to (# math functions) in NR1 format &lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</pre>
See Also	<ul style="list-style-type: none"> <li>· "<a href="#">Introduction to :WAVeform Commands</a>" on page 1456</li> <li>· "<a href="#">:DIGitize</a>" on page 268</li> <li>· "<a href="#">:WAVeform:FORMat</a>" on page 1465</li> <li>· "<a href="#">:WAVeform:BYTeorder</a>" on page 1461</li> <li>· "<a href="#">:WAVeform:DATA</a>" on page 1463</li> <li>· "<a href="#">:WAVeform:PREamble</a>" on page 1470</li> </ul>
Example Code	<pre>' WAVEFORM_DATA - To obtain waveform data, you must specify the ' WAVEFORM parameters for the waveform data prior to sending the ' ":WAVEFORM:DATA?" query. Once these parameters have been sent, ' the waveform data and the preamble can be read. ' ' WAVE_SOURCE - Selects the channel to be used as the source for ' the waveform commands. myScope.WriteString ":WAVEFORM:SOURCE CHAN1"  ' WAVE_POINTS - Specifies the number of points to be transferred ' using the ":WAVEFORM:DATA?" query. myScope.WriteString ":WAVEFORM:POINTS 1000"  ' WAVE_FORMAT - Sets the data transmission mode for the waveform ' data output. This command controls whether data is formatted in ' a word or byte format when sent from the oscilloscope. Dim lngVSteps As Long Dim intBytesPerData As Integer  ' Data in range 0 to 65535. myScope.WriteString ":WAVEFORM:FORMAT WORD" lngVSteps = 65536 intBytesPerData = 2  ' Data in range 0 to 255. 'myScope.WriteString ":WAVEFORM:FORMAT BYTE" 'lngVSteps = 256 'intBytesPerData = 1  ' GET_PREAMBLE - The preamble block contains all of the current</pre>

```

' WAVEFORM settings. It is returned in the form <preamble_block><NL>
' where <preamble_block> is:
'   FORMAT      : int16 - 0 = BYTE, 1 = WORD, 4 = ASCII.
'   TYPE        : int16 - 0 = NORMAL, 1 = PEAK DETECT, 2 = AVERAGE
'   POINTS     : int32 - number of data points transferred.
'   COUNT       : int32 - 1 and is always 1.
'   XINCREMENT  : float64 - time difference between data points.
'   XORIGIN     : float64 - always the first data point in memory.
'   XREFERENCE  : int32 - specifies the data point associated with
'                     x-origin.
'   YINCREMENT  : float32 - voltage diff between data points.
'   YORIGIN     : float32 - value is the voltage at center screen.
'   YREFERENCE  : int32 - specifies the data point where y-origin
'                     occurs.

Dim Preamble()
Dim intFormat As Integer
Dim intType As Integer
Dim lngPoints As Long
Dim lngCount As Long
Dim dblXIncrement As Double
Dim dblXOrigin As Double
Dim lngXReference As Long
Dim sngYIncrement As Single
Dim sngYOrigin As Single
Dim lngYReference As Long
Dim strOutput As String

myScope.WriteString ":WAVEFORM:PREAMBLE?"    ' Query for the preamble.
Preamble() = myScope.ReadList      ' Read preamble information.
intFormat = Preamble(0)
intType = Preamble(1)
lngPoints = Preamble(2)
lngCount = Preamble(3)
dblXIncrement = Preamble(4)
dblXOrigin = Preamble(5)
lngXReference = Preamble(6)
sngYIncrement = Preamble(7)
sngYOrigin = Preamble(8)
lngYReference = Preamble(9)
strOutput = ""
strOutput = strOutput + "Format = " + CStr(intFormat) + vbCrLf
strOutput = strOutput + "Type = " + CStr(intType) + vbCrLf
strOutput = strOutput + "Points = " + CStr(lngPoints) + vbCrLf
strOutput = strOutput + "Count = " + CStr(lngCount) + vbCrLf
strOutput = strOutput + "X increment = " +
'           FormatNumber(dblXIncrement * 1000000) + " us" + vbCrLf
strOutput = strOutput + "X origin = " +
'           FormatNumber(dblXOrigin * 1000000) + " us" + vbCrLf
strOutput = strOutput + "X reference = " +
'           CStr(lngXReference) + vbCrLf
strOutput = strOutput + "Y increment = " +
'           FormatNumber(sngYIncrement * 1000) + " mV" + vbCrLf
strOutput = strOutput + "Y origin = " +
'           FormatNumber(sngYOrigin) + " V" + vbCrLf
strOutput = strOutput + "Y reference = " +
'           CStr(lngYReference) + vbCrLf
strOutput = strOutput + "Volts/Div = " +
'
```

```

        FormatNumber(lngVSteps * sngYIncrement / 8) + _
        " V" + vbCrLf
strOutput = strOutput + "Offset = " + _
        FormatNumber((lngVSteps / 2 - lngYReference) * _
        sngYIncrement + sngYOrigin) + " V" + vbCrLf
strOutput = strOutput + "Sec/Div = " + _
        FormatNumber(lngPoints * dblXIncrement / 10 * _
        1000000) + " us" + vbCrLf
strOutput = strOutput + "Delay = " + _
        FormatNumber(((lngPoints / 2 - lngXReference) * _
        dblXIncrement + dblXOrigin) * 1000000) + " us" + vbCrLf

' QUERY_WAVE_DATA - Outputs waveform data that is stored in a buffer.

' Query the oscilloscope for the waveform data.
myScope.WriteString ":WAV:DATA?"

' READ_WAVE_DATA - The wave data consists of two parts: the header,
' and the actual waveform data followed by a new line (NL) character.
' The query data has the following format:
'
'     <header><waveform_data><NL>
'
' Where:
'     <header> = #800001000 (This is an example header)
' The "#8" may be stripped off of the header and the remaining
' numbers are the size, in bytes, of the waveform data block. The
' size can vary depending on the number of points acquired for the
' waveform. You can then read that number of bytes from the
' oscilloscope and the terminating NL character.
'
Dim lngI As Long
Dim lngDataValue As Long

' Unsigned integer bytes.
varQueryResult = myScope.ReadIEEEBlock(BinaryType_UI1)

For lngI = 0 To UBound(varQueryResult) -
    Step (UBound(varQueryResult) / 20)      ' 20 points.
    If intBytesPerData = 2 Then
        lngDataValue = varQueryResult(lngI) * 256 -
            + varQueryResult(lngI + 1)      ' 16-bit value.
    Else
        lngDataValue = varQueryResult(lngI)      ' 8-bit value.
    End If
    strOutput = strOutput + "Data point " + _
        CStr(lngI / intBytesPerData) + ", " + _
        FormatNumber((lngDataValue - lngYReference) -
        * sngYIncrement + sngYOrigin) + " V, " + _
        FormatNumber(((lngI / intBytesPerData - lngXReference) -
        * sngXIncrement + dblXOrigin) * 1000000) + " us" + vbCrLf
Next lngI
MsgBox "Waveform data:" + vbCrLf + strOutput

```

See complete example programs at: [Chapter 46](#), “Programming Examples,” starting on page 1675

## :WAVeform:SOURce:SUBSource

**C** (see [page 1666](#))

<b>Command Syntax</b>	<code>:WAVeform:SOURce:SUBSource &lt;subsource&gt;</code>
	<pre>&lt;subsource&gt; ::= {{SUB0   RX   MOSI   FAST}       {SUB1   TX   MISO   SLOW}}}</pre>
	If the :WAVeform:SOURce is SBUS<n> (serial decode), more than one data set may be available, and this command lets you choose from the available data sets.
	When using UART serial decode, this option lets you get "TX" data. (TX is an alias for SUB1.) The default, SUB0, specifies "RX" data. (RX is an alias for SUB0.)
	When using SPI serial decode, this option lets you get "MISO" data. (MISO is an alias for SUB1.) The default, SUB0, specifies "MOSI" data. (MOSI is an alias for SUB0.)
	When using SENT serial decode, this option lets you get "SLOW" data. (SLOW is an alias for SUB1.) The default, SUB0, specifies "FAST" data. (FAST is an alias for SUB0.)
	If the :WAVeform:SOURce is not SBUS, or the :SBUS<n>:MODE is not UART, SPI, or SENT, the only valid subsource is SUB0.
<b>Query Syntax</b>	<code>:WAVeform:SOURce:SUBSource?</code>
	The :WAVeform:SOURce:SUBSource? query returns the current waveform subsource setting.
<b>Return Format</b>	<pre>&lt;subsource&gt;&lt;NL&gt; &lt;subsource&gt; ::= {SUB0   SUB1}</pre>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">"Introduction to :WAVeform Commands"</a> on page 1456</li> <li>· <a href="#">":WAVeform:SOURce"</a> on page 1477</li> </ul>

## :WAVeform:TYPE

**C** (see [page 1666](#))

**Query Syntax**    `:WAVeform:TYPE?`

The `:WAVeform:TYPE?` query returns the acquisition mode associated with the currently selected waveform. The acquisition mode is set by the `:ACQuire:TYPE` command.

**Return Format**    `<mode><NL>`

`<mode> ::= {NORM | PEAK | AVER | HRES}`

**NOTE** If the `:WAVeform:SOURce` is POD1, POD2, or SBUS1, SBUS2, the type is always NORM.

- 
- See Also**
- "[Introduction to :WAVeform Commands](#)" on page 1456
  - "[":ACQuire:TYPE](#)" on page 317
  - "[":WAVeform:DATA](#)" on page 1463
  - "[":WAVeform:PREamble](#)" on page 1470
  - "[":WAVeform:SOURce](#)" on page 1477

## :WAVeform:UNSIGNED

**C** (see [page 1666](#))

**Command Syntax**    `:WAVeform:UNSIGNED <unsigned>`  
`<unsigned> ::= {{0 | OFF} | {1 | ON}}`

The :WAVeform:UNSIGNED command turns unsigned mode on or off for the currently selected waveform. Use the WAVeform:UNSIGNED command to control whether data values are sent as unsigned or signed integers. This command can be used to match the instrument's internal data type to the data type used by the programming language. This command has no effect if the data format is ASCII.

If :WAVeform:SOURce is set to POD1, POD2, BUS1, or BUS2, WAVeform:UNSIGNED must be set to ON.

**Query Syntax**    `:WAVeform:UNSIGNED?`

The :WAVeform:UNSIGNED? query returns the status of unsigned mode for the currently selected waveform.

**Return Format**    `<unsigned><NL>`  
`<unsigned> ::= {0 | 1}`

**See Also**

- "Introduction to :WAVeform Commands" on page 1456
- "[:WAVeform:SOURce](#)" on page 1477

## :WAVeform:VIEW

**C** (see [page 1666](#))

**Command Syntax**    `:WAVeform:VIEW <view>`  
`<view> ::= {MAIN | ALL}`

The :WAVeform:VIEW command sets the view setting associated with the currently selected waveform:

- MAIN – This view specifies the data you see in the oscilloscope's main waveform display area.
- ALL – Available only when Digitizer mode is on (see :ACQuire:DIGitizer), this view specifies all the captured data, which may extend beyond the edges of the oscilloscope's main waveform display area depending on the settings for sample rate, memory depth, and horizontal time/div.

**Query Syntax**    `:WAVeform:VIEW?`

The :WAVeform:VIEW? query returns the view setting associated with the currently selected waveform.

**Return Format**    `<view><NL>`  
`<view> ::= {MAIN | ALL}`

**See Also**

- "[Introduction to :WAVeform Commands](#)" on page 1456
- "[":WAVeform:POINts](#)" on page 1466
- "[":ACQuire:DIGitizer](#)" on page 306

## :WAVeform:XINCrement

 (see [page 1666](#))

**Query Syntax** `:WAVeform:XINCrement?`

The `:WAVeform:XINCrement?` query returns the x-increment value for the currently specified source. This value is the time difference between consecutive data points in seconds.

**Return Format** `<value><NL>`

`<value>` ::= x-increment in the current preamble in 64-bit floating point NR3 format

**See Also**

- ["Introduction to :WAVeform Commands"](#) on page 1456
- [":WAVeform:PREamble"](#) on page 1470

**Example Code**

- ["Example Code"](#) on page 1471

## :WAveform:XORigin

 (see [page 1666](#))

**Query Syntax** `:WAveform:XORigin?`

The `:WAveform:XORigin?` query returns the x-origin value for the currently specified source. XORigin is the X-axis value of the data point specified by the `:WAveform:XREFerence` value. In this product, that is always the X-axis value of the first data point (`XREFerence = 0`).

**Return Format** `<value><NL>`

`<value> ::= x-origin value in the current preamble in 64-bit floating point NR3 format`

**See Also**

- ["Introduction to :WAveform Commands"](#) on page 1456
- [":WAveform:PREamble"](#) on page 1470
- [":WAveform:XREFerence"](#) on page 1487

**Example Code**

- ["Example Code"](#) on page 1471

## :WAVeform:XREFerence

 (see [page 1666](#))

**Query Syntax** `:WAVeform:XREFerence?`

The `:WAVeform:XREFerence?` query returns the x-reference value for the currently specified source. This value specifies the index of the data point associated with the x-origin data value. In this product, the x-reference point is the first point displayed and XREFerence is always 0.

**Return Format** `<value><NL>`

`<value> ::= x-reference value = 0 in 32-bit NR1 format`

**See Also**

- ["Introduction to :WAVeform Commands"](#) on page 1456

- [":WAVeform:PREamble"](#) on page 1470

- [":WAVeform:XORigin"](#) on page 1486

**Example Code**

- ["Example Code"](#) on page 1471

## :WAveform:YINCrement

 (see [page 1666](#))

**Query Syntax** `:WAveform:YINCrement?`

The `:WAveform:YINCrement?` query returns the y-increment value in volts for the currently specified source. This value is the voltage difference between consecutive data values. The y-increment for digital waveforms is always "1".

**Return Format** `<value><NL>`

`<value>` ::= y-increment value in the current preamble in 32-bit floating point NR3 format

**See Also**

- ["Introduction to :WAveform Commands"](#) on page 1456
- [":WAveform:PREamble"](#) on page 1470

**Example Code**

- ["Example Code"](#) on page 1471

## :WAVeform:YORigin

 (see [page 1666](#))

**Query Syntax** :WAVeform:YORigin?

The :WAVeform:YORigin? query returns the y-origin value for the currently specified source. This value is the Y-axis value of the data value specified by the :WAVeform:YREFerence value. For this product, this is the Y-axis value of the center of the screen.

**Return Format** <value><NL>

<value> ::= y-origin in the current preamble in 32-bit floating point NR3 format

**See Also** · ["Introduction to :WAVeform Commands"](#) on page 1456  
· [":WAVeform:PREamble"](#) on page 1470  
· [":WAVeform:YREFerence"](#) on page 1490

**Example Code** · ["Example Code"](#) on page 1471

## :WAVeform:YREFerence

 (see [page 1666](#))

**Query Syntax** `:WAVeform:YREFerence?`

The `:WAVeform:YREFerence?` query returns the y-reference value for the currently specified source. This value specifies the data point value where the y-origin occurs. In this product, this is the data point value of the center of the screen. It is undefined if the format is ASCII.

**Return Format** `<value><NL>`

`<value>` ::= y-reference value in the current preamble in 32-bit  
NR1 format

**See Also**

- ["Introduction to :WAVeform Commands"](#) on page 1456
- [":WAVeform:PREamble"](#) on page 1470
- [":WAVeform:YORigin"](#) on page 1489

**Example Code**

- ["Example Code"](#) on page 1471

## 39 :WGEN<w> Commands

When the built-in waveform generator is licensed (WAVEGEN license), you can use it to output sine, square, ramp, pulse, DC, noise, sine cardinal, exponential rise, exponential fall, cardiac, and gaussian pulse waveforms. The :WGEN<w> commands are used to select the waveform function and parameters. See "[Introduction to :WGEN<w> Commands](#)" on page 1495.

**Table 173** :WGEN<w> Commands Summary

Command	Query	Options and Query Returns
:WGEN<w>:ARBitrary:BYTeorder <order> (see <a href="#">page 1496</a> )	:WGEN<w>:ARBitrary:BYTeorder? (see <a href="#">page 1496</a> )	<order> ::= {MSBFFirst   LSBFirst} <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:ARBitrary:DATA {<binary>   <value>, <value> ... } (see <a href="#">page 1497</a> )	n/a	<binary> ::= floating point values between -1.0 to +1.0 in IEEE 488.2 binary block format <value> ::= floating point values between -1.0 to +1.0 in comma-separated format <w> ::= 1 to (# WaveGen outputs) in NR1 format
n/a	:WGEN<w>:ARBitrary:DATATTRibute:POINTs? (see <a href="#">page 1500</a> )	<points> ::= number of points in NR1 format <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:ARBitrary:DATACLEAR (see <a href="#">page 1501</a> )	n/a	<w> ::= 1 to (# WaveGen outputs) in NR1 format

**Table 173** :WGEN<w> Commands Summary (continued)

Command	Query	Options and Query Returns
:WGEN<w>:ARBitrary:DA TA:DAC {<binary>   <value>, <value> ... } (see <a href="#">page 1502</a> )	n/a	<p>&lt;binary&gt; ::= decimal 16-bit integer values between -512 to +511 in IEEE 488.2 binary block format</p> <p>&lt;value&gt; ::= decimal integer values between -512 to +511 in comma-separated NR1 format</p> <p>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</p>
:WGEN<w>:ARBitrary:IN Terpolate {{0   OFF}   {1   ON}} (see <a href="#">page 1503</a> )	:WGEN<w>:ARBitrary:IN Terpolate? (see <a href="#">page 1503</a> )	<p>{0   1}</p> <p>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</p>
:WGEN<w>:ARBitrary:ST ORe <source> (see <a href="#">page 1504</a> )	n/a	<p>&lt;source&gt; ::= {CHANnel&lt;n&gt;   WMEMory&lt;r&gt;   FUNCTion&lt;m&gt;   FFT   MATH&lt;m&gt;}</p> <p>&lt;n&gt; ::= 1 to (# analog channels) in NR1 format</p> <p>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</p> <p>&lt;m&gt; ::= 1 to (# math functions) in NR1 format</p> <p>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</p>
:WGEN<w>:FREQuency <frequency> (see <a href="#">page 1505</a> )	:WGEN<w>:FREQuency? (see <a href="#">page 1505</a> )	<p>&lt;frequency&gt; ::= frequency in Hz in NR3 format</p> <p>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</p>
:WGEN<w>:FUNCTION <signal> (see <a href="#">page 1506</a> )	:WGEN<w>:FUNCTION? (see <a href="#">page 1509</a> )	<p>&lt;signal&gt; ::= {SINusoid   SQUARE   RAMP   PULSe   NOISE   DC   SINC   EXPRIse   EXPFall   CARDiac   GAUSSian   ARBitrary}</p> <p>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</p>
:WGEN<w>:FUNCTION:PUL Se:WIDTH <width> (see <a href="#">page 1510</a> )	:WGEN<w>:FUNCTION:PUL Se:WIDTH? (see <a href="#">page 1510</a> )	<p>&lt;width&gt; ::= pulse width in seconds in NR3 format</p> <p>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</p>

**Table 173** :WGEN<w> Commands Summary (continued)

Command	Query	Options and Query Returns
:WGEN<w>:FUNCTION:RAM P:SYMMetry <percent> (see <a href="#">page 1511</a> )	:WGEN<w>:FUNCTION:RAM P:SYMMetry? (see <a href="#">page 1511</a> )	<percent> ::= symmetry percentage from 0% to 100% in NR1 format <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:FUNCTION:SQU are:DCYCle <percent> (see <a href="#">page 1512</a> )	:WGEN<w>:FUNCTION:SQU are:DCYCle? (see <a href="#">page 1512</a> )	<percent> ::= duty cycle percentage from 20% to 80% in NR1 format <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:MODulation:A M:DEPTH <percent> (see <a href="#">page 1513</a> )	:WGEN<w>:MODulation:A M:DEPTH? (see <a href="#">page 1513</a> )	<percent> ::= AM depth percentage from 0% to 100% in NR1 format <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:A M:FREQuency <frequency> (see <a href="#">page 1514</a> )	:WGEN<w>:MODulation:A M:FREQuency? (see <a href="#">page 1514</a> )	<frequency> ::= modulating waveform frequency in Hz in NR3 format <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:F M:DEViation <frequency> (see <a href="#">page 1515</a> )	:WGEN<w>:MODulation:F M:DEViation? (see <a href="#">page 1515</a> )	<frequency> ::= frequency deviation in Hz in NR3 format <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:F M:FREQuency <frequency> (see <a href="#">page 1516</a> )	:WGEN<w>:MODulation:F M:FREQuency? (see <a href="#">page 1516</a> )	<frequency> ::= modulating waveform frequency in Hz in NR3 format <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:F SKey:FREQuency <percent> (see <a href="#">page 1517</a> )	:WGEN<w>:MODulation:F SKey:FREQuency? (see <a href="#">page 1517</a> )	<frequency> ::= hop frequency in Hz in NR3 format <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:F SKey:RATE <rate> (see <a href="#">page 1518</a> )	:WGEN<w>:MODulation:F SKey:RATE? (see <a href="#">page 1518</a> )	<rate> ::= FSK modulation rate in Hz in NR3 format <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:F UNCTION <shape> (see <a href="#">page 1519</a> )	:WGEN<w>:MODulation:F UNCTION? (see <a href="#">page 1519</a> )	<shape> ::= {SINusoid   SQUare  RAMP} <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:F UNCTION:RAMP:SYMMetry <percent> (see <a href="#">page 1520</a> )	:WGEN<w>:MODulation:F UNCTION:RAMP:SYMMetry? (see <a href="#">page 1520</a> )	<percent> ::= symmetry percentage from 0% to 100% in NR1 format <w> ::= 1 in NR1 format

**Table 173** :WGEN<w> Commands Summary (continued)

Command	Query	Options and Query Returns
:WGEN<w>:MODulation:N OISe <percent> (see <a href="#">page 1521</a> )	:WGEN<w>:MODulation:N OISe? (see <a href="#">page 1521</a> )	<percent> ::= 0 to 100 <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:S TATE {{0   OFF}   {1   ON}} (see <a href="#">page 1522</a> )	:WGEN<w>:MODulation:S TATE? (see <a href="#">page 1522</a> )	{0   1} <w> ::= 1 in NR1 format
:WGEN<w>:MODulation:T YPE <type> (see <a href="#">page 1523</a> )	:WGEN<w>:MODulation:T YPE? (see <a href="#">page 1523</a> )	<type> ::= {AM   FM   FSK} <w> ::= 1 in NR1 format
:WGEN<w>:OUTPut {{0   OFF}   {1   ON}} (see <a href="#">page 1525</a> )	:WGEN<w>:OUTPut? (see <a href="#">page 1525</a> )	{0   1} <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:OUTPut:LOAD <impedance> (see <a href="#">page 1526</a> )	:WGEN<w>:OUTPut:LOAD? (see <a href="#">page 1526</a> )	<impedance> ::= {ONEMeg   FIFTy} <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:OUTPut:MODE <mode> (see <a href="#">page 1527</a> )	:WGEN<w>:OUTPut:MODE? (see <a href="#">page 1527</a> )	<mode> ::= {NORMAL   SINGLE}
:WGEN<w>:OUTPut:POLar ity <polarity> (see <a href="#">page 1528</a> )	:WGEN<w>:OUTPut:POLar ity? (see <a href="#">page 1528</a> )	<polarity> ::= {NORMAL   INVerted} <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:OUTPut:SINGl e (see <a href="#">page 1529</a> )	n/a	n/a
:WGEN<w>:PERiod <period> (see <a href="#">page 1530</a> )	:WGEN<w>:PERiod? (see <a href="#">page 1530</a> )	<period> ::= period in seconds in NR3 format <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:RST (see <a href="#">page 1531</a> )	n/a	<w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:VOLTage <amplitude> (see <a href="#">page 1532</a> )	:WGEN<w>:VOLTage? (see <a href="#">page 1532</a> )	<amplitude> ::= amplitude in volts in NR3 format <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:VOLTage:HIGH <high> (see <a href="#">page 1533</a> )	:WGEN<w>:VOLTage:HIGH ? (see <a href="#">page 1533</a> )	<high> ::= high-level voltage in volts, in NR3 format <w> ::= 1 to (# WaveGen outputs) in NR1 format

**Table 173** :WGEN<w> Commands Summary (continued)

Command	Query	Options and Query Returns
:WGEN<w>:VOLTage:LOW <low> (see <a href="#">page 1534</a> )	:WGEN<w>:VOLTage:LOW? (see <a href="#">page 1534</a> )	<low> ::= low-level voltage in volts, in NR3 format <w> ::= 1 to (# WaveGen outputs) in NR1 format
:WGEN<w>:VOLTage:OFFS et <offset> (see <a href="#">page 1535</a> )	:WGEN<w>:VOLTage:OFFS et? (see <a href="#">page 1535</a> )	<offset> ::= offset in volts in NR3 format <w> ::= 1 to (# WaveGen outputs) in NR1 format

**Introduction to :WGEN<w> Commands** The :WGEN<w> subsystem provides commands to select the waveform generator function and parameters.  
In the :WGEN<w> commands, the <w> can be 1 or 2, and :WGEN is equivalent to :WGEN1

#### Reporting the Setup

Use :WGEN<w>? to query setup information for the WGEN<w> subsystem.

#### Return Format

The following is a sample response from the :WGEN? query. In this case, the query was issued following the \*RST command.

```
:WGEN1:FUNC SIN;OUTP 0;FREQ +1.0000E+03;VOLT +500.0E-03;VOLT:OFFS
+0.0E+00;:WGEN1:OUTP:LOAD ONEM
```

## :WGEN<w>:ARBitrary:BYTeorder

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:WGEN&lt;w&gt;:ARBitrary:BYTeorder &lt;order&gt;</code>
	<code>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</code>
	<code>&lt;order&gt; ::= {MSBFIRST   LSBFIRST}</code>
	The :WGEN<w>:ARBitrary:BYTeorder command selects the byte order for binary transfers.
<b>Query Syntax</b>	<code>:WGEN&lt;w&gt;:ARBitrary:BYTeorder?</code>
	The :WGEN<w>:ARBitrary:BYTeorder query returns the current byte order selection.
<b>Return Format</b>	<code>&lt;order&gt;&lt;NL&gt;</code>
	<code>&lt;order&gt; ::= {MSBFIRST   LSBFIRST}</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">":WGEN&lt;w&gt;:ARBitrary:DATA" on page 1497</a></li><li><a href="#">":WGEN&lt;w&gt;:ARBitrary:DATA:DAC" on page 1502</a></li></ul>

## :WGEN<w>:ARBitrary:DATA

**N** (see [page 1666](#))

**Command Syntax** :WGEN<w>:ARBitrary:DATA {<binary> | <value>, <value> ...}

<w> ::= 1 to (# WaveGen outputs) in NR1 format

<binary> ::= floating point values between -1.0 to +1.0  
in IEEE 488.2 binary block format

<value> ::= floating point values between -1.0 to +1.0  
in comma-separated format

The :WGEN<w>:ARBitrary:DATA command downloads an arbitrary waveform in floating-point values format.

- See Also**
- "[:WGEN<w>:ARBitrary:DATA:DAC](#)" on page 1502
  - "[:SAVE:ARBitrary\[:STARt\]](#)" on page 877
  - "[:RECall:ARBitrary\[:STARt\]](#)" on page 864

**Example Code**

```
' Waveform generator arbitrary data commands example.
' -----
```

Option Explicit

```
Public myMgr As VisaComLib.ResourceManager
Public myScope As VisaComLib.FormattedIO488
Public varQueryResult As Variant
Public strQueryResult As String

Private Declare Sub Sleep Lib "kernel32" (ByVal dwMilliseconds As Long)
Private Declare Sub CopyMemory Lib "kernel32" Alias "RtlMoveMemory" ( _
    dest As Any, _
    source As Any, _
    ByVal bytes As Long)

Sub Main()

    On Error GoTo VisaComError

    ' Create the VISA COM I/O resource.
    Set myMgr = New VisaComLib.ResourceManager
    Set myScope = New VisaComLib.FormattedIO488
    Set myScope.IO =
        myMgr.Open("TCPIPO::a-mx4154a-60014.cos.is.keysight.com::inst0::INSTR")
    myScope.IO.Clear      ' Clear the interface.

    ' Turn on arbitrary waveform generator function.
    myScope.WriteString ":WGEN1:OUTPut ON"
    myScope.WriteString ":WGEN1:FUNCTION ARBitrary"
    myScope.WriteString ":WGEN1:FUNCTION?"
    strQueryResult = myScope.ReadString
    Debug.Print "WaveGen1 function: " + strQueryResult

End Sub
```

```

DefaultArbitraryWaveform

' Download comma-separated floating-point values.
myScope.WriteString ":WGEN1:ARBITRARY:DATA 0.0, 0.5, 1.0, 0.5, 0.0, -0
.5, -1.0, -0.5"
Debug.Print "WaveGen1 CSV floating-point values downloaded."
Sleep 5000

DefaultArbitraryWaveform

' Download comma-separated 16-bit integer (DAC) values.
myScope.WriteString ":WGEN1:ARBITRARY:DATA:DAC 0, 255, 511, 255, 0, -2
56, -512, -256"
Debug.Print "WaveGen1 CSV 16-bit integer (DAC) values downloaded."
Sleep 5000

' Set the byte order for binary data.
myScope.WriteString ":WGEN1:ARBITRARY:BYTeorder LSBFirst"
myScope.WriteString ":WGEN1:ARBITRARY:BYTeorder?"
strQueryResult = myScope.ReadString
Debug.Print "WaveGen1 byte order for binary data: " + strQueryResult

DefaultArbitraryWaveform

' Download binary floating-point values.
Dim mySingleArray(8) As Single
mySingleArray(0) = 0!
mySingleArray(1) = 0.5!
mySingleArray(2) = 1!
mySingleArray(3) = 0.5!
mySingleArray(4) = 0!
mySingleArray(5) = -0.5!
mySingleArray(6) = -1!
mySingleArray(7) = -0.5!

Dim myByteArray(32) As Byte
CopyMemory myByteArray(0), mySingleArray(0), 32 * LenB(myByteArray(0))

myScope.WriteIEEEBlock ":WGEN1:ARBITRARY:DATA", myByteArray, True
Debug.Print "WaveGen1 binary floating-point values downloaded."
Sleep 5000

DefaultArbitraryWaveform

' Download binary 16-bit integer (DAC) values.
Dim myIntegerArray(8) As Integer
myIntegerArray(0) = 0
myIntegerArray(1) = 255
myIntegerArray(2) = 511
myIntegerArray(3) = 255
myIntegerArray(4) = 0
myIntegerArray(5) = -256
myIntegerArray(6) = -512
myIntegerArray(7) = -256

Dim myByteArray2(16) As Byte

```

```
CopyMemory myByteArray2(0), myIntegerArray(0), 16 * LenB(myByteArray2(0))

myScope.WriteLineEEBlock ":WGEN1:ARBITRARY:DATA:DAC", myByteArray2, True
Debug.Print "WaveGen1 binary 16-bit integer (DAC) values downloaded."
Sleep 5000

Exit Sub

VisaComError:
MsgBox "VISA COM Error:" + vbCrLf + Err.Description

End Sub

'

' Initialize WaveGen1 to a known state.
' -----
Private Sub DefaultArbitraryWaveform()

On Error GoTo VisaComError

' Load default arbitrary waveform.
myScope.WriteString ":WGEN1:ARBITRARY:DATA:CLEar"
Debug.Print "WaveGen1 default arbitrary waveform loaded."
Sleep 5000

Exit Sub

VisaComError:
MsgBox "VISA COM Error:" + vbCrLf + Err.Description
End

End Sub
```

## :WGEN<w>:ARBitrary:DATA:ATTRibute:POINts

**N** (see [page 1666](#))

**Query Syntax**    `:WGEN<w>:ARBitrary:DATA:ATTRibute:POINts?`

`<w> ::= 1 to (# WaveGen outputs) in NR1 format`

The `:WGEN<w>:ARBitrary:DATA:ATTRibute:POINts` query returns the number of points used by the current arbitrary waveform.

**Return Format**    `<points> ::= number of points in NR1 format`

**See Also**

- "[:WGEN<w>:ARBitrary:DATA](#)" on page 1497
- "[:WGEN<w>:ARBitrary:DATA:DAC](#)" on page 1502
- "[:SAVE:ARBitrary\[:STARt\]](#)" on page 877
- "[:RECall:ARBitrary\[:STARt\]](#)" on page 864

## :WGEN<w>:ARBitrary:DATA:CLEar

**N** (see [page 1666](#))

**Command Syntax** :WGEN<w>:ARBitrary:DATA:CLEar

<w> ::= 1 to (# WaveGen outputs) in NR1 format

The :WGEN<w>:ARBitrary:DATA:CLEar command clears the arbitrary waveform memory and loads it with the default waveform.

- See Also**
- "[:WGEN<w>:ARBitrary:DATA](#)" on page 1497
  - "[:WGEN<w>:ARBitrary:DATA:DAC](#)" on page 1502
  - "[:SAVE:ARBitrary\[:STARt\]](#)" on page 877
  - "[:RECall:ARBitrary\[:STARt\]](#)" on page 864

- Example Code**
- "["Example Code"](#) on page 1497

## :WGEN<w>:ARBitrary:DATA:DAC

**N** (see [page 1666](#))

**Command Syntax**    `:WGEN<w>:ARBitrary:DATA:DAC {<binary> | <value>, <value> ...}`

`<w> ::= 1 to (# WaveGen outputs) in NR1 format`

`<binary> ::= decimal 16-bit integer values between -512 to +511  
                  in IEEE 488.2 binary block format`

`<value> ::= decimal integer values between -512 to +511  
                  in comma-separated NR1 format`

The :WGEN<w>:ARBitrary:DATA:DAC command downloads an arbitrary waveform using 16-bit integer (DAC) values.

**See Also**

- [":WGEN<w>:ARBitrary:DATA"](#) on page 1497

- [":SAVE:ARBitrary\[:STARt\]"](#) on page 877

- [":RECall:ARBitrary\[:STARt\]"](#) on page 864

**Example Code**

- ["Example Code"](#) on page 1497

## :WGEN<w>:ARBitrary:INTerpolate

**N** (see [page 1666](#))

**Command Syntax**    `:WGEN<w>:ARBitrary:INTerpolate {{0 | OFF} | {1 | ON}}`  
`<w> ::= 1 to (# WaveGen outputs) in NR1 format`

The :WGEN<w>:ARBitrary:INTerpolate command enables or disables the Interpolation control.

Interpolation specifies how lines are drawn between arbitrary waveform points:

- When ON, lines are drawn between points in the arbitrary waveform. Voltage levels change linearly between one point and the next.
- When OFF, all line segments in the arbitrary waveform are horizontal. The voltage level of one point remains until the next point.

**Query Syntax**    `:WGEN<w>:ARBitrary:INTerpolate?`

The :WGEN<w>:ARBitrary:INTerpolate query returns the current interpolation setting.

**Return Format**    `{0 | 1}`

**See Also**

- "[:WGEN<w>:ARBitrary:DATA](#)" on page 1497
- "[:WGEN<w>:ARBitrary:DATA:DAC](#)" on page 1502
- "[:SAVE:ARBitrary\[:STARt\]](#)" on page 877
- "[:RECall:ARBitrary\[:STARt\]](#)" on page 864

## :WGEN<w>:ARBitrary:STORe

**N** (see [page 1666](#))

**Command Syntax**

```
:WGEN<w>:ARBitrary:STORe <source>
<w> ::= 1 to (# WaveGen outputs) in NR1 format
<source> ::= {CHANnel<n> | WMMemory<r> | FUNCtion<m> | MATH<m> | FFT}
<n> ::= 1 to (# analog channels) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
```

The :WGEN<w>:ARBitrary:STORe command stores the source's waveform into the arbitrary waveform memory.

**See Also**

- "[:WGEN<w>:ARBitrary:DATA](#)" on page 1497
- "[:WGEN<w>:ARBitrary:DATA:DAC](#)" on page 1502
- "[:SAVE:ARBitrary\[:STARt\]](#)" on page 877
- "[:RECall:ARBitrary\[:STARt\]](#)" on page 864

## :WGEN<w>:FREQuency

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:WGEN&lt;w&gt;:FREQuency &lt;frequency&gt;</code>
	<code>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</code>
	<code>&lt;frequency&gt; ::= frequency in Hz in NR3 format</code>
	For all waveforms except Noise and DC, the :WGEN<w>:FREQuency command specifies the frequency of the waveform.
	You can also specify the frequency indirectly using the :WGEN<w>:PERiod command.
<b>Query Syntax</b>	<code>:WGEN&lt;w&gt;:FREQuency?</code>
	The :WGEN<w>:FREQuency? query returns the currently set waveform generator frequency.
<b>Return Format</b>	<code>&lt;frequency&gt;&lt;NL&gt;</code> <code>&lt;frequency&gt; ::= frequency in Hz in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">Introduction to :WGEN&lt;w&gt; Commands</a>" on page 1495</li> <li>· "<a href="#">":WGEN&lt;w&gt;:FUNCTION</a>" on page 1506</li> <li>· "<a href="#">":WGEN&lt;w&gt;:PERiod</a>" on page 1530</li> </ul>

## :WGEN<w>:FUNCTION

**N** (see [page 1666](#))

**Command Syntax**

```
:WGEN<w>:FUNCTION <signal>
<w> ::= 1 to (# WaveGen outputs) in NR1 format
<signal> ::= {SINusoid | SQUare | RAMP | PULSe | DC | NOISE | SINC
               | EXPRIse | EXPFall | CARDiac | GAUSSian | ARBITrary}
```

The :WGEN<w>:FUNCTION command selects the type of waveform:

Waveform Type	Characteristics	Frequency Range	Max. Amplitude <sup>2</sup> (High-Z) <sup>1</sup>	Offset <sup>2</sup> (High-Z) <sup>1</sup>
SINusoid	<p>Use these commands to set the sine signal parameters:</p> <ul style="list-style-type: none"> <li>▪ "<a href="#">:WGEN&lt;w&gt;:FREQuency</a>" on page 1505</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:PERiod</a>" on page 1530</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:VOLTage</a>" on page 1532</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:VOLTage:OFFSet</a>" on page 1535</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:VOLTage:HIGH</a>" on page 1533</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:VOLTage:LOW</a>" on page 1534</li> </ul>	100 mHz to 20 MHz	20 mVpp to 10 Vpp	±4.00 V
SQUare	<p>Use these commands to set the square wave signal parameters:</p> <ul style="list-style-type: none"> <li>▪ "<a href="#">:WGEN&lt;w&gt;:FREQuency</a>" on page 1505</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:PERiod</a>" on page 1530</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:VOLTage</a>" on page 1532</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:VOLTage:OFFSet</a>" on page 1535</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:VOLTage:HIGH</a>" on page 1533</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:VOLTage:LOW</a>" on page 1534</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:FUNCTION:SQUare:DCYCLE</a>" on page 1512</li> </ul> <p>The duty cycle can be adjusted from 20% to 80%.</p>	100 mHz to 10 MHz	20 mVpp to 10 Vpp	±5.00 V

Waveform Type	Characteristics	Frequency Range	Max. Amplitude <sup>2</sup> (High-Z) <sup>1</sup>	Offset <sup>2</sup> (High-Z) <sup>1</sup>
RAMP	<p>Use these commands to set the ramp signal parameters:</p> <ul style="list-style-type: none"> <li>▪ <a href="#">":WGEN&lt;w&gt;:FREQuency"</a> on page 1505</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:PERiod"</a> on page 1530</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage"</a> on page 1532</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:OFFSet"</a> on page 1535</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:HIGH"</a> on page 1533</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:LOW"</a> on page 1534</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:FUNCTION:RAMP:SYMMetry"</a> on page 1511</li> </ul> <p>Symmetry represents the amount of time per cycle that the ramp waveform is rising and can be adjusted from 0% to 100%.</p>	100 mHz to 200 kHz	20 mVpp to 10 Vpp	±5.00 V
PULSe	<p>Use these commands to set the pulse signal parameters:</p> <ul style="list-style-type: none"> <li>▪ <a href="#">":WGEN&lt;w&gt;:FREQuency"</a> on page 1505</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:PERiod"</a> on page 1530</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage"</a> on page 1532</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:OFFSet"</a> on page 1535</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:HIGH"</a> on page 1533</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:LOW"</a> on page 1534</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:FUNCTION:PULSe:WIDTH"</a> on page 1510</li> </ul> <p>The pulse width can be adjusted from 20 ns to the period minus 20 ns.</p>	100 mHz to 10 MHz	20 mVpp to 10 Vpp	±5.00 V
DC	<p>Use this command to set the DC level:</p> <ul style="list-style-type: none"> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:OFFSet"</a> on page 1535</li> </ul>	n/a	n/a	±10.00 V
NOISE	<p>Use these commands to set the noise signal parameters:</p> <ul style="list-style-type: none"> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage"</a> on page 1532</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:OFFSet"</a> on page 1535</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:HIGH"</a> on page 1533</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:LOW"</a> on page 1534</li> </ul>	n/a	20 mVpp to 10 Vpp	±5.00 V

Waveform Type	Characteristics	Frequency Range	Max. Amplitude <sup>2</sup> (High-Z) <sup>1</sup>	Offset <sup>2</sup> (High-Z) <sup>1</sup>
SINC	<p>Use these commands to set the sine cardinal signal parameters:</p> <ul style="list-style-type: none"> <li>▪ <a href="#">":WGEN&lt;w&gt;:FREQuency"</a> on page 1505</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:PERiod"</a> on page 1530</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage"</a> on page 1532</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:OFFSet"</a> on page 1535</li> </ul>	100 mHz to 1 MHz	20 mVpp to 9 Vpp	±2.50 V
EXPRise	<p>Use these commands to set the exponential rise signal parameters:</p> <ul style="list-style-type: none"> <li>▪ <a href="#">":WGEN&lt;w&gt;:FREQuency"</a> on page 1505</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:PERiod"</a> on page 1530</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage"</a> on page 1532</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:OFFSet"</a> on page 1535</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:HIGH"</a> on page 1533</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:LOW"</a> on page 1534</li> </ul>	100 mHz to 5 MHz	20 mVpp to 10 Vpp	±5.00 V
EXPFall	<p>Use these commands to set the exponential fall signal parameters:</p> <ul style="list-style-type: none"> <li>▪ <a href="#">":WGEN&lt;w&gt;:FREQuency"</a> on page 1505</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:PERiod"</a> on page 1530</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage"</a> on page 1532</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:OFFSet"</a> on page 1535</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:HIGH"</a> on page 1533</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:LOW"</a> on page 1534</li> </ul>	100 mHz to 5 MHz	20 mVpp to 10 Vpp	±5.00 V
CARDiac	<p>Use these commands to set the cardiac signal parameters:</p> <ul style="list-style-type: none"> <li>▪ <a href="#">":WGEN&lt;w&gt;:FREQuency"</a> on page 1505</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:PERiod"</a> on page 1530</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage"</a> on page 1532</li> <li>▪ <a href="#">":WGEN&lt;w&gt;:VOLTage:OFFSet"</a> on page 1535</li> </ul>	100 mHz to 200 kHz	20 mVpp to 9 Vpp	±2.50 V

Waveform Type	Characteristics	Frequency Range	Max. Amplitude <sup>2</sup> (High-Z) <sup>1</sup>	Offset <sup>2</sup> (High-Z) <sup>1</sup>
GAUSSian	<p>Use these commands to set the gaussian pulse signal parameters:</p> <ul style="list-style-type: none"> <li>▪ "<a href="#">:WGEN&lt;w&gt;:FREQuency</a>" on page 1505</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:PERiod</a>" on page 1530</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:VOLTage</a>" on page 1532</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:VOLTage:OFFSet</a>" on page 1535</li> </ul>	100 mHz to 5 MHz	20 mVpp to 7.5 Vpp	±2.50 V
ARBitrary	<p>Use these commands to set the arbitrary signal parameters:</p> <ul style="list-style-type: none"> <li>▪ "<a href="#">:WGEN&lt;w&gt;:FREQuency</a>" on page 1505</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:PERiod</a>" on page 1530</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:VOLTage</a>" on page 1532</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:VOLTage:OFFSet</a>" on page 1535</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:VOLTage:HIGH</a>" on page 1533</li> <li>▪ "<a href="#">:WGEN&lt;w&gt;:VOLTage:LOW</a>" on page 1534</li> </ul>	100 mHz to 12 MHz	20 mVpp to 10 Vpp	±5.00 V

<sup>1</sup>When the output load is 50 Ω, these values are halved.

<sup>2</sup>The minimum amplitude is limited to 40 mVpp if the offset is greater than 500 mV or less than -500 mV. Likewise, the offset is limited to +/-500 mV if the amplitude is less than 40 mVpp.

**Query Syntax**    :WGEN<w>:FUNCTION?

The :WGEN<w>:FUNCTION? query returns the currently selected signal type.

**Return Format**    <signal><NL>

```
<signal> ::= {SIN | SQU | RAMP | PULS | DC | NOIS | SINC | EXPR | EXPF
               | CARD | GAUS | ARB}
```

**See Also**

- "[Introduction to :WGEN<w> Commands](#)" on page 1495
- "[:WGEN<w>:MODulation:NOISe](#)" on page 1521

## :WGEN<w>:FUNCTION:PULSe:WIDTH

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:WGEN&lt;w&gt;:FUNCTION:PULSe:WIDTH &lt;width&gt;</code>
	<code>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</code>
	<code>&lt;width&gt; ::= pulse width in seconds in NR3 format</code>
	For Pulse waveforms, the :WGEN<w>:FUNCTION:PULSe:WIDTH command specifies the width of the pulse.
	The pulse width can be adjusted from 20 ns to the period minus 20 ns.
<b>Query Syntax</b>	<code>:WGEN&lt;w&gt;:FUNCTION:PULSe:WIDTH?</code>
	The :WGEN<w>:FUNCTION:PULSe:WIDTH? query returns the currently set pulse width.
<b>Return Format</b>	<code>&lt;width&gt;&lt;NL&gt;</code>
	<code>&lt;width&gt; ::= pulse width in seconds in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">"Introduction to :WGEN&lt;w&gt; Commands" on page 1495</a></li><li><a href="#">":WGEN&lt;w&gt;:FUNCTION" on page 1506</a></li></ul>

## :WGEN<w>:FUNCTION:RAMP:SYMMetry

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:WGEN&lt;w&gt;:FUNCTION:RAMP:SYMMetry &lt;percent&gt;</code>
	<code>&lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format</code>
	<code>&lt;percent&gt; ::= symmetry percentage from 0% to 100% in NR1 format</code>
	For Ramp waveforms, the :WGEN<w>:FUNCTION:RAMP:SYMMetry command specifies the symmetry of the waveform.
	Symmetry represents the amount of time per cycle that the ramp waveform is rising.
<b>Query Syntax</b>	<code>:WGEN&lt;w&gt;:FUNCTION:RAMP:SYMMetry?</code>
	The :WGEN<w>:FUNCTION:RAMP:SYMMetry? query returns the currently set ramp symmetry.
<b>Return Format</b>	<code>&lt;percent&gt;&lt;NL&gt;</code>
	<code>&lt;percent&gt; ::= symmetry percentage from 0% to 100% in NR1 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">"Introduction to :WGEN&lt;w&gt; Commands" on page 1495</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:FUNCTION" on page 1506</a></li> </ul>

## :WGEN<w>:FUNCTION:SQUare:DCYCle

**N** (see [page 1666](#))

**Command Syntax**    `:WGEN<w>:FUNCTION:SQUare:DCYCle <percent>`  
`<w> ::= 1 to (# WaveGen outputs) in NR1 format`  
`<percent> ::= duty cycle percentage from 20% to 80% in NR1 format`  
For Square waveforms, the :WGEN<w>:FUNCTION:SQUare:DCYCle command specifies the square wave duty cycle.  
Duty cycle is the percentage of the period that the waveform is high.

**Query Syntax**    `:WGEN<w>:FUNCTION:SQUare:DCYCle?`

The :WGEN<w>:FUNCTION:SQUare:DCYCle? query returns the currently set square wave duty cycle.

**Return Format**    `<percent><NL>`  
`<percent> ::= duty cycle percentage from 20% to 80% in NR1 format`

**See Also**

- ["Introduction to :WGEN<w> Commands" on page 1495](#)
- [":WGEN<w>:FUNCTION" on page 1506](#)

## :WGEN<w>:MODulation:AM:DEPTH

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:WGEN&lt;w&gt;:MODulation:AM:DEPTH &lt;percent&gt;</code>
	<code>&lt;w&gt; ::= 1 in NR1 format</code>
	<code>&lt;percent&gt; ::= AM depth percentage from 0% to 100% in NR1 format</code>

The :WGEN<w>:MODulation:AM:DEPTH command specifies the amount of amplitude modulation.

AM Depth refers to the portion of the amplitude range that will be used by the modulation. For example, a depth setting of 80% causes the output amplitude to vary from 10% to 90% (90% – 10% = 80%) of the original amplitude as the modulating signal goes from its minimum to maximum amplitude.

<b>Query Syntax</b>	<code>:WGEN&lt;w&gt;:MODulation:AM:DEPTH?</code>
	The :WGEN<w>:MODulation:AM:DEPTH? query returns the AM depth percentage setting.

<b>Return Format</b>	<code>&lt;percent&gt;&lt;NL&gt;</code>
	<code>&lt;percent&gt; ::= AM depth percentage from 0% to 100% in NR1 format</code>

<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:AM:FREQuency</a>" on page 1514</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FM:DEViation</a>" on page 1515</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FM:FREQuency</a>" on page 1516</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FSKey:FREQuency</a>" on page 1517</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FSKey:RATE</a>" on page 1518</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FUNCTION</a>" on page 1519</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FUNCTION:RAMP:SYMMetry</a>" on page 1520</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:STATE</a>" on page 1522</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:TYPE</a>" on page 1523</li> </ul>
-----------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

## :WGEN<w>:MODulation:AM:FREQuency

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:WGEN&lt;w&gt;:MODulation:AM:FREQuency &lt;frequency&gt;</code>
	<code>&lt;w&gt; ::= 1 in NR1 format</code>
	<code>&lt;frequency&gt; ::= modulating waveform frequency in Hz in NR3 format</code>
	The :WGEN<w>:MODulation:AM:FREQuency command specifies the frequency of the modulating signal.
<b>Query Syntax</b>	<code>:WGEN&lt;w&gt;:MODulation:AM:FREQuency?</code>
	The :WGEN<w>:MODulation:AM:FREQuency? query returns the frequency of the modulating signal.
<b>Return Format</b>	<code>&lt;frequency&gt;&lt;NL&gt;</code>
	<code>&lt;frequency&gt; ::= modulating waveform frequency in Hz in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:AM:DEPTH</a>" on page 1513</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FM:DEViation</a>" on page 1515</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FM:FREQuency</a>" on page 1516</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FSKey:FREQuency</a>" on page 1517</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FSKey:RATE</a>" on page 1518</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FUNCTION</a>" on page 1519</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FUNCTION:RAMP:SYMMetry</a>" on page 1520</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:STATE</a>" on page 1522</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:TYPE</a>" on page 1523</li> </ul>

## :WGEN<w>:MODulation:FM:DEViation

**N** (see [page 1666](#))

**Command Syntax** :WGEN<w>:MODulation:FM:DEViation <frequency>

<w> ::= 1 in NR1 format

<frequency> ::= frequency deviation in Hz in NR3 format

The :WGEN<w>:MODulation:FM:DEViation command specifies the frequency deviation from the original carrier signal frequency.

When the modulating signal is at its maximum amplitude, the output frequency is the carrier signal frequency plus the deviation amount, and when the modulating signal is at its minimum amplitude, the output frequency is the carrier signal frequency minus the deviation amount.

The frequency deviation cannot be greater than the original carrier signal frequency.

Also, the sum of the original carrier signal frequency and the frequency deviation must be less than or equal to the maximum frequency for the selected waveform generator function plus 100 kHz.

**Query Syntax** :WGEN<w>:MODulation:FM:DEViation?

The :WGEN<w>:MODulation:FM:DEViation? query returns the frequency deviation setting.

**Return Format** <frequency><NL>

<frequency> ::= frequency deviation in Hz in NR3 format

**See Also** [":WGEN<w>:MODulation:AM:DEPTH"](#) on page 1513

[":WGEN<w>:MODulation:AM:FREQuency"](#) on page 1514

[":WGEN<w>:MODulation:FM:FREQuency"](#) on page 1516

[":WGEN<w>:MODulation:FSKey:FREQuency"](#) on page 1517

[":WGEN<w>:MODulation:FSKey:RATE"](#) on page 1518

[":WGEN<w>:MODulation:FUNCTION"](#) on page 1519

[":WGEN<w>:MODulation:FUNCTION:RAMP:SYMMetry"](#) on page 1520

[":WGEN<w>:MODulation:STATE"](#) on page 1522

[":WGEN<w>:MODulation:TYPE"](#) on page 1523

## :WGEN<w>:MODulation:FM:FREQuency

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:WGEN&lt;w&gt;:MODulation:FM:FREQuency &lt;frequency&gt;</code>
	<code>&lt;w&gt; ::= 1 in NR1 format</code>
	<code>&lt;frequency&gt; ::= modulating waveform frequency in Hz in NR3 format</code>
	The :WGEN<w>:MODulation:FM:FREQuency command specifies the frequency of the modulating signal.
<b>Query Syntax</b>	<code>:WGEN&lt;w&gt;:MODulation:FM:FREQuency?</code>
	The :WGEN<w>:MODulation:FM:FREQuency? query returns the frequency of the modulating signal.
<b>Return Format</b>	<code>&lt;frequency&gt;&lt;NL&gt;</code>
	<code>&lt;frequency&gt; ::= modulating waveform frequency in Hz in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:AM:DEPTh</a>" on page 1513</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:AM:FREQuency</a>" on page 1514</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FM:DEViation</a>" on page 1515</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FSKey:FREQuency</a>" on page 1517</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FSKey:RATE</a>" on page 1518</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FUNCTION</a>" on page 1519</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:FUNCTION:RAMP:SYMMetry</a>" on page 1520</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:STATE</a>" on page 1522</li> <li>· "<a href="#">:WGEN&lt;w&gt;:MODulation:TYPE</a>" on page 1523</li> </ul>

## :WGEN<w>:MODulation:FSKey:FREQuency

**N** (see [page 1666](#))

Command Syntax	<code>:WGEN&lt;w&gt;:MODulation:FSKey:FREQuency &lt;frequency&gt;</code>
	<code>&lt;w&gt; ::= 1 in NR1 format</code>
	<code>&lt;frequency&gt; ::= hop frequency in Hz in NR3 format</code>
	The :WGEN<w>:MODulation:FSKey:FREQuency command specifies the "hop frequency".
	The output frequency "shifts" between the original carrier frequency and this "hop frequency".
Query Syntax	<code>:WGEN&lt;w&gt;:MODulation:FSKey:FREQuency?</code>
	The :WGEN<w>:MODulation:FSKey:FREQuency? query returns the "hop frequency" setting.
Return Format	<code>&lt;frequency&gt;&lt;NL&gt;</code> <code>&lt;frequency&gt; ::= hop frequency in Hz in NR3 format</code>
See Also	<ul style="list-style-type: none"> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:AM:DEPTH" on page 1513</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:AM:FREQuency" on page 1514</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:FM:DEViation" on page 1515</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:FM:FREQuency" on page 1516</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:FSKey:RATE" on page 1518</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:FUNCTION" on page 1519</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:FUNCTION:RAMP:SYMMetry" on page 1520</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:STATE" on page 1522</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:TYPE" on page 1523</a></li> </ul>

## :WGEN<w>:MODulation:FSKey:RATE

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:WGEN&lt;w&gt;:MODulation:FSKey:RATE &lt;rate&gt;</code>
	<code>&lt;w&gt; ::= 1 in NR1 format</code>
	<code>&lt;rate&gt; ::= FSK modulation rate in Hz in NR3 format</code>
	The :WGEN<w>:MODulation:FSKey:RATE command specifies the rate at which the output frequency "shifts".
	The FSK rate specifies a digital square wave modulating signal.
<b>Query Syntax</b>	<code>:WGEN&lt;w&gt;:MODulation:FSKey:RATE?</code>
	The :WGEN<w>:MODulation:FSKey:RATE? query returns the FSK rate setting.
<b>Return Format</b>	<code>&lt;rate&gt;&lt;NL&gt;</code>
	<code>&lt;rate&gt; ::= FSK modulation rate in Hz in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· "<a href="#">":WGEN&lt;w&gt;:MODulation:AM:DEPTH</a>" on page 1513</li> <li>· "<a href="#">":WGEN&lt;w&gt;:MODulation:AM:FREQuency</a>" on page 1514</li> <li>· "<a href="#">":WGEN&lt;w&gt;:MODulation:FM:DEViation</a>" on page 1515</li> <li>· "<a href="#">":WGEN&lt;w&gt;:MODulation:FM:FREQuency</a>" on page 1516</li> <li>· "<a href="#">":WGEN&lt;w&gt;:MODulation:FSKey:FREQuency</a>" on page 1517</li> <li>· "<a href="#">":WGEN&lt;w&gt;:MODulation:FUNCTION</a>" on page 1519</li> <li>· "<a href="#">":WGEN&lt;w&gt;:MODulation:FUNCTION:RAMP:SYMMetry</a>" on page 1520</li> <li>· "<a href="#">":WGEN&lt;w&gt;:MODulation:STATE</a>" on page 1522</li> <li>· "<a href="#">":WGEN&lt;w&gt;:MODulation:TYPE</a>" on page 1523</li> </ul>

## :WGEN<w>:MODulation:FUNCTION

**N** (see [page 1666](#))

**Command Syntax**    `:WGEN<w>:MODulation:FUNCTION <shape>`

`<w> ::= 1 in NR1 format`

`<shape> ::= {SINusoid | SQUare| RAMP}`

The :WGEN<w>:MODulation:FUNCTION command specifies the shape of the modulating signal.

When the RAMP shape is selected, you can specify the amount of time per cycle that the ramp waveform is rising with the :WGEN<w>:MODulation:FUNCTION:RAMP:SYMMetry command.

This command applies to AM and FM modulation. (The FSK modulation signal is a square wave shape.)

**Query Syntax**    `:WGEN<w>:MODulation:FUNCTION?`

The :WGEN<w>:MODulation:FUNCTION? query returns the specified modulating signal shape.

**Return Format**    `<shape><NL>`

`<shape> ::= {SIN | SQU| RAMP}`

**See Also**

- "[:WGEN<w>:MODulation:AM:DEPTH](#)" on page 1513
- "[:WGEN<w>:MODulation:AM:FREQuency](#)" on page 1514
- "[:WGEN<w>:MODulation:FM:DEViation](#)" on page 1515
- "[:WGEN<w>:MODulation:FM:FREQuency](#)" on page 1516
- "[:WGEN<w>:MODulation:FSKey:FREQuency](#)" on page 1517
- "[:WGEN<w>:MODulation:FSKey:RATE](#)" on page 1518
- "[:WGEN<w>:MODulation:FUNCTION:RAMP:SYMMetry](#)" on page 1520
- "[:WGEN<w>:MODulation:STATe](#)" on page 1522
- "[:WGEN<w>:MODulation:TYPE](#)" on page 1523

## :WGEN<w>:MODulation:FUNCTION:RAMP:SYMMetry

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:WGEN&lt;w&gt;:MODulation:FUNCTION:RAMP:SYMMetry &lt;percent&gt;</code>
	<code>&lt;w&gt; ::= 1 in NR1 format</code>
	<code>&lt;percent&gt; ::= symmetry percentage from 0% to 100% in NR1 format</code>
	The :WGEN<w>:MODulation:FUNCTION:RAMP:SYMMetry command specifies the amount of time per cycle that the ramp waveform is rising. The ramp modulating waveform shape is specified with the :WGEN<w>:MODulation:FUNCTION command.
<b>Query Syntax</b>	<code>:WGEN&lt;w&gt;:MODulation:FUNCTION:RAMP:SYMMetry?</code>
	The :WGEN<w>:MODulation:FUNCTION:RAMP:SYMMetry? query returns ramp symmetry percentage setting.
<b>Return Format</b>	<code>&lt;percent&gt;&lt;NL&gt;</code> <code>&lt;percent&gt; ::= symmetry percentage from 0% to 100% in NR1 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• "<a href="#">:WGEN&lt;w&gt;:MODulation:AM:DEPTH</a>" on page 1513</li> <li>• "<a href="#">:WGEN&lt;w&gt;:MODulation:AM:FREQuency</a>" on page 1514</li> <li>• "<a href="#">:WGEN&lt;w&gt;:MODulation:FM:DEViation</a>" on page 1515</li> <li>• "<a href="#">:WGEN&lt;w&gt;:MODulation:FM:FREQuency</a>" on page 1516</li> <li>• "<a href="#">:WGEN&lt;w&gt;:MODulation:FSKey:FREQuency</a>" on page 1517</li> <li>• "<a href="#">:WGEN&lt;w&gt;:MODulation:FSKey:RATE</a>" on page 1518</li> <li>• "<a href="#">:WGEN&lt;w&gt;:MODulation:FUNCTION</a>" on page 1519</li> <li>• "<a href="#">:WGEN&lt;w&gt;:MODulation:STATe</a>" on page 1522</li> <li>• "<a href="#">:WGEN&lt;w&gt;:MODulation:TYPE</a>" on page 1523</li> </ul>

## :WGEN<w>:MODulation:NOISe

**N** (see [page 1666](#))

**Command Syntax**    `:WGEN<w>:MODulation:NOISe <percent>`

```
<w> ::= 1 in NR1 format
<percent> ::= 0 to 100
```

The :WGEN<w>:MODulation:NOISe command adds noise to the currently selected signal. The sum of the amplitude between the original signal and injected noise is limited to the regular amplitude limit (for example, 5 Vpp in 1 MΩ), so the range for <percent> varies according to current amplitude.

Note that adding noise affects edge triggering on the waveform generator source as well as the waveform generator sync pulse output signal (which can be sent to TRIG OUT). This is because the trigger comparator is located after the noise source.

**Query Syntax**    `:WGEN<w>:MODulation:NOISe?`

The :WGEN<w>:MODulation:NOISe query returns the percent of added noise.

**Return Format**    `<percent><NL>`

```
<percent> ::= 0 to 100
```

**See Also**    • [":WGEN<w>:FUNCTION"](#) on page 1506

## :WGEN<w>:MODulation:STATe

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:WGEN&lt;w&gt;:MODulation:STATe &lt;setting&gt;</code>
	<code>&lt;w&gt; ::= 1 in NR1 format</code>
	<code>&lt;setting&gt; ::= {{OFF   0}   {ON   1}}</code>
	The :WGEN<w>:MODulation:STATe command enables or disables modulated waveform generator output.
	You can enable modulation for all waveform generator function types except pulse, DC, and noise.
<b>Query Syntax</b>	<code>:WGEN&lt;w&gt;:MODulation:STATe?</code>
	The :WGEN<w>:MODulation:STATe? query returns whether the modulated waveform generator output is enabled or disabled.
<b>Return Format</b>	<code>&lt;setting&gt;&lt;NL&gt;</code> <code>&lt;setting&gt; ::= {0   1}</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:AM:DEPTH" on page 1513</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:AM:FREQuency" on page 1514</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:FM:DEViation" on page 1515</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:FM:FREQuency" on page 1516</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:FSKey:FREQuency" on page 1517</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:FSKey:RATE" on page 1518</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:FUNCTION" on page 1519</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:FUNCTION:RAMP:SYMMetry" on page 1520</a></li> <li>· <a href="#">":WGEN&lt;w&gt;:MODulation:TYPE" on page 1523</a></li> </ul>

## :WGEN<w>:MODulation:TYPE

**N** (see [page 1666](#))

### Command Syntax

```
:WGEN<w>:MODulation:TYPE <type>
<w> ::= 1 in NR1 format
<type> ::= {AM | FM | FSK}
```

The :WGEN<w>:MODulation:TYPE command selects the modulation type:

- AM (amplitude modulation) – the amplitude of the original carrier signal is modified according to the amplitude of the modulating signal.

Use the :WGEN<w>:MODulation:AM:FREQuency command to set the modulating signal frequency.

Use the :WGEN<w>:MODulation:AM:DEPTH command to specify the amount of amplitude modulation.

- FM (frequency modulation) – the frequency of the original carrier signal is modified according to the amplitude of the modulating signal.

Use the :WGEN<w>:MODulation:FM:FREQuency command to set the modulating signal frequency.

Use the :WGEN<w>:MODulation:FM:DEViation command to specify the frequency deviation from the original carrier signal frequency.

- FSK (frequency-shift keying modulation) – the output frequency "shifts" between the original carrier frequency and a "hop frequency" at the specified FSK rate.

The FSK rate specifies a digital square wave modulating signal.

Use the :WGEN<w>:MODulation:FSKey:FREQuency command to specify the "hop frequency".

Use the :WGEN<w>:MODulation:FSKey:RATE command to specify the rate at which the output frequency "shifts".

### Query Syntax

```
:WGEN<w>:MODulation:TYPE?
```

The :WGEN<w>:MODulation:TYPE? query returns the selected modulation type.

### Return Format

```
<type><NL>
<type> ::= {AM | FM | FSK}
```

### See Also

- "[:WGEN<w>:MODulation:AM:DEPTH](#)" on page 1513
- "[:WGEN<w>:MODulation:AM:FREQuency](#)" on page 1514
- "[:WGEN<w>:MODulation:FM:DEViation](#)" on page 1515
- "[:WGEN<w>:MODulation:FM:FREQuency](#)" on page 1516

- "[:WGEN<w>:MODulation:FSKey:FREQuency](#)" on page 1517
- "[:WGEN<w>:MODulation:FSKey:RATE](#)" on page 1518
- "[:WGEN<w>:MODulation:FUNCTION](#)" on page 1519
- "[:WGEN<w>:MODulation:FUNCTION:RAMP:SYMMetry](#)" on page 1520
- "[:WGEN<w>:MODulation:STATe](#)" on page 1522

## :WGEN<w>:OUTPut

**N** (see [page 1666](#))

**Command Syntax** :WGEN<w>:OUTPut <on\_off>

<w> ::= 1 to (# WaveGen outputs) in NR1 format

<on\_off> ::= {{1 | ON} | {0 | OFF}}

The :WGEN<w>:OUTPut command specifies whether the waveform generator signal output is ON (1) or OFF (0).

**Query Syntax** :WGEN<w>:OUTPut?

The :WGEN<w>:OUTPut? query returns the current state of the waveform generator output setting.

**Return Format** <on\_off><NL>

<on\_off> ::= {1 | 0}

**See Also** • ["Introduction to :WGEN<w> Commands"](#) on page 1495

## :WGEN<w>:OUTPut:LOAD

**N** (see [page 1666](#))

**Command Syntax**    `:WGEN<w>:OUTPut:LOAD <impedance>`

`<w> ::= 1 to (# WaveGen outputs) in NR1 format`

`<impedance> ::= {ONEMeg | FIFTy}`

The :WGEN<w>:OUTPut:LOAD command selects the expected output load impedance.

The output impedance of the Gen Out BNC is fixed at 50 ohms. However, the output load selection lets the waveform generator display the correct amplitude and offset levels for the expected output load.

If the actual load impedance is different than the selected value, the displayed amplitude and offset levels will be incorrect.

**Query Syntax**    `:WGEN<w>:OUTPut:LOAD?`

The :WGEN<w>:OUTPut:LOAD? query returns the current expected output load impedance.

**Return Format**    `<impedance><NL>`

`<impedance> ::= {ONEM | FIFT}`

**See Also**    • "Introduction to :WGEN<w> Commands" on page 1495

## :WGEN<w>:OUTPut:MODE

**N** (see [page 1666](#))

**Command Syntax**    `:WGEN<w>:OUTPut:MODE <mode>`  
`<mode> ::= {NORMAL | SINGLE}`

The :WGEN<w>:OUTPut:MODE command specifies whether the defined waveform is output continuously or as a single cycle (single-shot):

- NORMAL – the defined waveform is output continuously.
- SINGLE – one cycle of the defined waveform is output when you send the :WGEN<w>:OUTPut:SINGLE command.

Not all waveform types allow single-shot output.

**Query Syntax**    `:WGEN<w>:OUTPut:MODE?`

The :WGEN<w>:OUTPut:MODE? query returns the output mode setting.

**Return Format**    `<mode><NL>`  
`<mode> ::= {NORMAL | SINGLE}`

**See Also**    • "[":WGEN<w>:OUTPut:SINGLE](#)" on page 1529

## :WGEN<w>:OUTPut:POLarity

**N** (see [page 1666](#))

**Command Syntax**    `:WGEN<w>:OUTPut:POLarity <polarity>`

`<w> ::= 1 to (# WaveGen outputs) in NR1 format`

`<polarity> ::= {NORMAL | INVERTED}`

The :WGEN<w>:OUTPut:POLarity command specifies whether the waveform generator output is inverted..

**Query Syntax**    `:WGEN<w>:OUTPut:POLarity?`

The :WGEN<w>:OUTPut:POLarity? query returns the specified output polarity.

**Return Format**    `<polarity><NL>`

`<polarity> ::= {NORM | INV}`

**See Also**    · "Introduction to :WGEN<w> Commands" on page 1495

## :WGEN<w>:OUTPut:SINGle

**N** (see [page 1666](#))

**Command Syntax** :WGEN<w>:OUTPut:SINGle

When the single-shot output mode is selected (by the :WGEN<w>:OUTPut:MODE command), the :WGEN<w>:OUTPut:SINGle command causes a single cycle of the defined waveform to be output.

Sending this command multiple times will interrupt a slow signal output before the cycle is completed.

**See Also** • [":WGEN<w>:OUTPut:MODE"](#) on page 1527

## :WGEN<w>:PERiod

**N** (see [page 1666](#))

<b>Command Syntax</b>	<pre>:WGEN&lt;w&gt;:PERiod &lt;period&gt; &lt;w&gt; ::= 1 to (# WaveGen outputs) in NR1 format &lt;period&gt; ::= period in seconds in NR3 format</pre>
	For all waveforms except Noise and DC, the :WGEN<w>:PERiod command specifies the period of the waveform.
	You can also specify the period indirectly using the :WGEN<w>:FREQuency command.
<b>Query Syntax</b>	<pre>:WGEN&lt;w&gt;:PERiod?</pre>
	The :WGEN<w>:PERiod? query returns the currently set waveform generator period.
<b>Return Format</b>	<pre>&lt;period&gt;&lt;NL&gt; &lt;period&gt; ::= period in seconds in NR3 format</pre>
<b>See Also</b>	<ul style="list-style-type: none"><li><a href="#">"Introduction to :WGEN&lt;w&gt; Commands"</a> on page 1495</li><li><a href="#">":WGEN&lt;w&gt;:FUNCTION"</a> on page 1506</li><li><a href="#">":WGEN&lt;w&gt;:FREQuency"</a> on page 1505</li></ul>

## :WGEN<w>:RST

**N** (see [page 1666](#))

**Command Syntax** :WGEN<w>:RST

<w> ::= 1 to (# WaveGen outputs) in NR1 format

The :WGEN<w>:RST command restores the waveform generator factory default settings (1 kHz sine wave, 500 mVpp, 0 V offset).

**See Also**

- "[Introduction to :WGEN<w> Commands](#)" on page 1495
- "[":WGEN<w>:FUNCTION](#)" on page 1506
- "[":WGEN<w>:FREQuency](#)" on page 1505

## :WGEN<w>:VOLTage

**N** (see [page 1666](#))

**Command Syntax**    `:WGEN<w>:VOLTage <amplitude>`

`<w> ::= 1 to (# WaveGen outputs) in NR1 format`

`<amplitude> ::= amplitude in volts in NR3 format`

For all waveforms except DC, the :WGEN<w>:VOLTage command specifies the waveform's amplitude. Use the :WGEN<w>:VOLTage:OFFSet command to specify the offset voltage or DC level.

You can also specify the amplitude and offset indirectly using the :WGEN<w>:VOLTage:HIGH and :WGEN<w>:VOLTage:LOW commands. For example, an amplitude of 5 V and an offset of 1 V is the same as a high-level voltage of 4 V and a low-level voltage of -1 V.

### NOTE

When the amplitude is below 40 mV, the offset is limited to  $\pm 500$  mV.

**Query Syntax**    `:WGEN<w>:VOLTage?`

The :WGEN<w>:VOLTage? query returns the currently specified waveform amplitude.

**Return Format**    `<amplitude><NL>`

`<amplitude> ::= amplitude in volts in NR3 format`

**See Also**

- "[Introduction to :WGEN<w> Commands](#)" on page 1495
- "[":WGEN<w>:FUNCTION](#)" on page 1506
- "[":WGEN<w>:VOLTage:OFFSet](#)" on page 1535
- "[":WGEN<w>:VOLTage:HIGH](#)" on page 1533
- "[":WGEN<w>:VOLTage:LOW](#)" on page 1534

## :WGEN<w>:VOLTage:HIGH

**N** (see [page 1666](#))

**Command Syntax** :WGEN<w>:VOLTage:HIGH <high>

<w> ::= 1 to (# WaveGen outputs) in NR1 format

<high> ::= high-level voltage in volts, in NR3 format

For all waveforms except DC, the :WGEN<w>:VOLTage:HIGH command specifies the waveform's high-level voltage. Use the :WGEN<w>:VOLTage:LOW command to specify the low-level voltage.

You can also specify the high-level and low-level voltages indirectly using the :WGEN<w>:VOLTage and :WGEN<w>:VOLTage:OFFSET commands. For example, a high-level voltage of 4 V and a low-level voltage of -1 V is the same as an amplitude of 5 V and an offset of 1 V.

### NOTE

When the amplitude is below 40 mV, the offset is limited to  $\pm 500$  mV.

**Query Syntax** :WGEN<w>:VOLTage:HIGH?

The :WGEN<w>:VOLTage:HIGH? query returns the currently specified waveform high-level voltage.

**Return Format** <high><NL>

<high> ::= high-level voltage in volts, in NR3 format

**See Also**

- "[Introduction to :WGEN<w> Commands](#)" on page 1495
- "[":WGEN<w>:FUNCTION](#)" on page 1506
- "[":WGEN<w>:VOLTage:LOW](#)" on page 1534
- "[":WGEN<w>:VOLTage](#)" on page 1532
- "[":WGEN<w>:VOLTage:OFFSET](#)" on page 1535

## :WGEN<w>:VOLTage:LOW

**N** (see [page 1666](#))

**Command Syntax**    `:WGEN<w>:VOLTage:LOW <low>`

`<w> ::= 1 to (# WaveGen outputs) in NR1 format`

`<low> ::= low-level voltage in volts, in NR3 format`

For all waveforms except DC, the :WGEN<w>:VOLTage:LOW command specifies the waveform's low-level voltage. Use the :WGEN<w>:VOLTage:HIGH command to specify the high-level voltage.

You can also specify the high-level and low-level voltages indirectly using the :WGEN<w>:VOLTage and :WGEN<w>:VOLTage:OFFSet commands. For example, a high-level voltage of 4 V and a low-level voltage of -1 V is the same as an amplitude of 5 V and an offset of 1 V.

### NOTE

When the amplitude is below 40 mV, the offset is limited to  $\pm 500$  mV.

**Query Syntax**    `:WGEN<w>:VOLTage:LOW?`

The :WGEN<w>:VOLTage:LOW? query returns the currently specified waveform low-level voltage.

**Return Format**    `<low><NL>`

`<low> ::= low-level voltage in volts, in NR3 format`

**See Also**

- "[Introduction to :WGEN<w> Commands](#)" on page 1495
- "[":WGEN<w>:FUNCTION](#)" on page 1506
- "[":WGEN<w>:VOLTage:LOW](#)" on page 1534
- "[":WGEN<w>:VOLTage](#)" on page 1532
- "[":WGEN<w>:VOLTage:OFFSet](#)" on page 1535

## :WGEN<w>:VOLTage:OFFSet

**N** (see [page 1666](#))

**Command Syntax** :WGEN<w>:VOLTage:OFFSet <offset>

<w> ::= 1 to (# WaveGen outputs) in NR1 format

<offset> ::= offset in volts in NR3 format

The :WGEN<w>:VOLTage:OFFSet command specifies the waveform's offset voltage or the DC level. Use the :WGEN<w>:VOLTage command to specify the amplitude.

You can also specify the amplitude and offset indirectly using the :WGEN<w>:VOLTage:HIGH and :WGEN<w>:VOLTage:LOW commands. For example, an amplitude of 5 V and an offset of 1 V is the same as a high-level voltage of 4 V and a low-level voltage of -1 V.

### NOTE

When the amplitude is below 40 mV, the offset is limited to  $\pm 500$  mV.

### Query Syntax

:WGEN<w>:VOLTage:OFFSet?

The :WGEN<w>:VOLTage:OFFSet? query returns the currently specified waveform offset voltage.

### Return Format

<offset><NL>

<offset> ::= offset in volts in NR3 format

### See Also

- "[Introduction to :WGEN<w> Commands](#)" on page 1495
- "[":WGEN<w>:FUNCTION](#)" on page 1506
- "[":WGEN<w>:VOLTage](#)" on page 1532
- "[":WGEN<w>:VOLTage:HIGH](#)" on page 1533
- "[":WGEN<w>:VOLTage:LOW](#)" on page 1534



# 40 :WMEMory<r> Commands

Control reference waveforms.

**Table 174** :WMEMory<r> Commands Summary

Command	Query	Options and Query Returns
:WMEMory<r>:CLEar (see <a href="#">page 1539</a> )	n/a	<r> ::= 1 to (# ref waveforms) in NR1 format
:WMEMory<r>:DISPlay { {0   OFF}   {1   ON} } (see <a href="#">page 1540</a> )	:WMEMory<r>:DISPlay? (see <a href="#">page 1540</a> )	<r> ::= 1 to (# ref waveforms) in NR1 format {0   1}
:WMEMory<r>:LABEL <string> (see <a href="#">page 1541</a> )	:WMEMory<r>:LABEL? (see <a href="#">page 1541</a> )	<r> ::= 1 to (# ref waveforms) in NR1 format <string> ::= any series of 10 or less ASCII characters enclosed in quotation marks
:WMEMory<r>:SAVE <source> (see <a href="#">page 1542</a> )	n/a	<r> ::= 1 to (# ref waveforms) in NR1 format <source> ::= {CHANnel<n>   FUNCtion<m>   MATH<m>} <n> ::= 1 to (# analog channels) in NR1 format <m> ::= 1 to (# math functions) in NR1 format NOTE: Math functions whose x-axis is not frequency can be saved as reference waveforms.
:WMEMory<r>:SKEW <skew> (see <a href="#">page 1543</a> )	:WMEMory<r>:SKEW? (see <a href="#">page 1543</a> )	<r> ::= 1 to (# ref waveforms) in NR1 format <skew> ::= time in seconds in NR3 format

**Table 174** :WMEMory<r> Commands Summary (continued)

Command	Query	Options and Query Returns
:WMEMory<r>:YOFFset <offset>[suffix] (see <a href="#">page 1544</a> )	:WMEMory<r>:YOFFset? (see <a href="#">page 1544</a> )	<r> ::= 1 to (# ref waveforms) in NR1 format  <offset> ::= vertical offset value in NR3 format  [suffix] ::= {V   mV}
:WMEMory<r>:YRANGE <range>[suffix] (see <a href="#">page 1545</a> )	:WMEMory<r>:YRANGE? (see <a href="#">page 1545</a> )	<r> ::= 1 to (# ref waveforms) in NR1 format  <range> ::= vertical full-scale range value in NR3 format  [suffix] ::= {V   mV}
:WMEMory<r>:YScale <scale>[suffix] (see <a href="#">page 1546</a> )	:WMEMory<r>:YScale? (see <a href="#">page 1546</a> )	<r> ::= 1 to (# ref waveforms) in NR1 format  <scale> ::= vertical units per division value in NR3 format  [suffix] ::= {V   mV}

## :WMEMory<r>:CLEar

**N** (see [page 1666](#))

**Command Syntax** :WMEMory<r>:CLEar

<r> ::= 1 to (# ref waveforms) in NR1 format

The :WMEMory<r>:CLEar command clears the specified reference waveform location.

**See Also**

- [Chapter 40, “:WMEMory<r> Commands,” starting on page 1537](#)
- [":WMEMory<r>:SAVE" on page 1542](#)
- [":WMEMory<r>:DISPlay" on page 1540](#)

## :WMEMory<r>:DISPlay

**N** (see [page 1666](#))

**Command Syntax**    `:WMEMory<r>:DISPlay <on_off>`

`<r> ::= 1 to (# ref waveforms) in NR1 format`

`<on_off> ::= {{1 | ON} | {0 | OFF}}`

The :WMEMory<r>:DISPlay command turns the display of the specified reference waveform on or off.

There are two reference waveform locations, but only one reference waveform can be displayed at a time. That means, if :WMEMory1:DISPlay is ON, sending the :WMEMory2:DISPlay ON command will automatically set :WMEMory1:DISPlay OFF.

**Query Syntax**    `:WMEMory<r>:DISPlay?`

The :WMEMory<r>:DISPlay? query returns the current display setting for the reference waveform.

**Return Format**    `<on_off><NL>`

`<on_off> ::= {1 | 0}`

**See Also**

- [Chapter 40, “:WMEMory<r> Commands,” starting on page 1537](#)

- [“:WMEMory<r>:CLEar” on page 1539](#)

- [“:WMEMory<r>:LABEL” on page 1541](#)

## :WMEMory<r>:LABel

**N** (see [page 1666](#))

**Command Syntax** :WMEMory<r>:LABel <string>

<r> ::= 1 to (# ref waveforms) in NR1 format

<string> ::= quoted ASCII string

### NOTE

Label strings are 10 characters or less, and may contain any commonly used ASCII characters. Labels with more than 10 characters are truncated to 10 characters. Lower case characters are converted to upper case.

The :WMEMory<r>:LABel command sets the reference waveform label to the string that follows.

Setting a label for a reference waveform also adds the name to the label list in non-volatile memory (replacing the oldest label in the list).

**Query Syntax** :WMEMory<r>:LABel?

The :WMEMory<r>:LABel? query returns the label associated with a particular reference waveform.

**Return Format** <string><NL>

<string> ::= quoted ASCII string

**See Also** • [Chapter 40](#), “:WMEMory<r> Commands,” starting on page 1537

• [":WMEMory<r>:DISPlay"](#) on page 1540

## :WMEMory<r>:SAVE

**N** (see [page 1666](#))

### Command Syntax

```
:WMEMory<r>:SAVE <source>  
<r> ::= 1 to (# ref waveforms) in NR1 format  
<source> ::= {CHANnel<n> | FUNCTion<m> | MATH<m>}  
<n> ::= 1 to (# analog channels) in NR1 format  
<m> ::= 1 to (# math functions) in NR1 format
```

The :WMEMory<r>:SAVE command copies the analog channel or math function waveform to the specified reference waveform location.

### NOTE

Math functions whose x-axis is not frequency can be saved as reference waveforms.

### See Also

- [Chapter 40, “:WMEMory<r> Commands,” starting on page 1537](#)
- [":WMEMory<r>:DISPLAY" on page 1540](#)

## :WMEMory<r>:SKEW

**N** (see [page 1666](#))

**Command Syntax** :WMEMory<r>:SKEW <skew>

<r> ::= 1 to (# ref waveforms) in NR1 format

<skew> ::= time in seconds in NR3 format

The :WMEMory<r>:SKEW command sets the skew factor for the specified reference waveform.

**Query Syntax** :WMEMory<r>:SKEW?

The :WMEMory<r>:SKEW? query returns the current skew setting for the selected reference waveform.

**Return Format** <skew><NL>

<skew> ::= time in seconds in NR3 format

- See Also**
- [Chapter 40](#), “:WMEMory<r> Commands,” starting on page 1537
  - [":WMEMory<r>:DISPlay"](#) on page 1540
  - [":WMEMory<r>:YOFFset"](#) on page 1544
  - [":WMEMory<r>:YRANge"](#) on page 1545
  - [":WMEMory<r>:YScale"](#) on page 1546

## :WMEMory<r>:YOFFset

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:WMEMory&lt;r&gt;:YOFFset &lt;offset&gt; [&lt;suffix&gt;]</code>
	<code>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</code>
	<code>&lt;offset&gt; ::= vertical offset value in NR3 format</code>
	<code>&lt;suffix&gt; ::= {V   mV}</code>
	The :WMEMory<r>:YOFFset command sets the value that is represented at center screen for the selected reference waveform.
	The range of legal values varies with the value set by the :WMEMory<r>:YRANGE or :WMEMory<r>:YScale commands. If you set the offset to a value outside of the legal range, the offset value is automatically set to the nearest legal value. Legal values are affected by the probe attenuation setting.

<b>Query Syntax</b>	<code>:WMEMory&lt;r&gt;:YOFFset?</code>
	The :WMEMory<r>:YOFFset? query returns the current offset value for the selected reference waveform.
<b>Return Format</b>	<code>&lt;offset&gt;&lt;NL&gt;</code>  <code>&lt;offset&gt; ::= vertical offset value in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">Chapter 40, “:WMEMory&lt;r&gt; Commands,” starting on page 1537</a></li> <li>• <a href="#">":WMEMory&lt;r&gt;:DISPLAY" on page 1540</a></li> <li>• <a href="#">":WMEMory&lt;r&gt;:YRANGE" on page 1545</a></li> <li>• <a href="#">":WMEMory&lt;r&gt;:YScale" on page 1546</a></li> <li>• <a href="#">":WMEMory&lt;r&gt;:SKEW" on page 1543</a></li> </ul>

## :WMEMory<r>:YRANge

**N** (see [page 1666](#))

<b>Command Syntax</b>	<code>:WMEMory&lt;r&gt;:YRANge &lt;range&gt;[&lt;suffix&gt;]</code>
	<code>&lt;r&gt; ::= 1 to (# ref waveforms) in NR1 format</code>
	<code>&lt;range&gt; ::= vertical full-scale range value in NR3 format</code>
	<code>&lt;suffix&gt; ::= {V   mV}</code>
	The :WMEMory<r>:YRANge command defines the full-scale vertical axis of the selected reference waveform.
	Legal values for the range are copied from the original source waveform (that is, the analog channel or math function waveform that was originally saved as a reference waveform).
<b>Query Syntax</b>	<code>:WMEMory&lt;r&gt;:YRANge?</code>
	The :WMEMory<r>:YRANge? query returns the current full-scale range setting for the specified reference waveform.
<b>Return Format</b>	<code>&lt;range&gt;&lt;NL&gt;</code>
	<code>&lt;range&gt; ::= vertical full-scale range value in NR3 format</code>
<b>See Also</b>	<ul style="list-style-type: none"> <li>• <a href="#">Chapter 40, “:WMEMory&lt;r&gt; Commands,” starting on page 1537</a></li> <li>• <a href="#">":WMEMory&lt;r&gt;:DISPlay" on page 1540</a></li> <li>• <a href="#">":WMEMory&lt;r&gt;:YOFFset" on page 1544</a></li> <li>• <a href="#">":WMEMory&lt;r&gt;:SKEW" on page 1543</a></li> <li>• <a href="#">":WMEMory&lt;r&gt;:YScale" on page 1546</a></li> </ul>

## :WMEMory<r>:YSCale

**N** (see [page 1666](#))

**Command Syntax**    `:WMEMory<r>:YSCale <scale>[<suffix>]`

```
<r> ::= 1 to (# ref waveforms) in NR1 format
<scale> ::= vertical units per division in NR3 format
<suffix> ::= {V | mV}
```

The :WMEMory<r>:YSCale command sets the vertical scale, or units per division, of the selected reference waveform.

Legal values for the scale are copied from the original source waveform (that is, the analog channel or math function waveform that was originally saved as a reference waveform).

**Query Syntax**    `:WMEMory<r>:YSCale?`

The :WMEMory<r>:YSCale? query returns the current scale setting for the specified reference waveform.

**Return Format**    `<scale><NL>`

```
<scale> ::= vertical units per division in NR3 format
```

**See Also**

- [Chapter 40, “:WMEMory<r> Commands,” starting on page 1537](#)
- [":WMEMory<r>:DISPlay" on page 1540](#)
- [":WMEMory<r>:YOFFset" on page 1544](#)
- [":WMEMory<r>:YRANGE" on page 1545](#)
- [":WMEMory<r>:SKEW" on page 1543](#)

# 41 Obsolete and Discontinued Commands

Obsolete commands are older forms of commands that are provided to reduce customer rework for existing systems and programs (see "[Obsolete Commands](#)" on page 1666).

Obsolete Command	Current Command Equivalent	Behavior Differences
ANALog<n>:BWLimit	:CHANnel<n>:BWLimit (see <a href="#">page 345</a> )	
ANALog<n>:COUpling	:CHANnel<n>:COUpling (see <a href="#">page 346</a> )	
ANALog<n>:INVert	:CHANnel<n>:INVert (see <a href="#">page 349</a> )	
ANALog<n>:LABEL	:CHANnel<n>:LABEL (see <a href="#">page 350</a> )	
ANALog<n>:OFFSet	:CHANnel<n>:OFFSet (see <a href="#">page 351</a> )	
ANALog<n>:PROBe	:CHANnel<n>:PROBe (see <a href="#">page 352</a> )	
ANALog<n>:PMODe	none	
ANALog<n>:RANGE	:CHANnel<n>:RANGE (see <a href="#">page 367</a> )	
:CHANnel:ACTivity (see <a href="#">page 1554</a> )	:ACTivity (see <a href="#">page 259</a> )	
:CHANnel:LABEL (see <a href="#">page 1555</a> )	:CHANnel<n>:LABEL (see <a href="#">page 350</a> ) or :DIGital<n>:LABEL (see <a href="#">page 406</a> )	use CHANnel<n>:LABEL for analog channels and use DIGital<n>:LABEL for digital channels

Obsolete Command	Current Command Equivalent	Behavior Differences
:CHANnel:THReShold (see page 1556)	:POD<n>:THReShold (see page 755) or :DIGItal<d>:THReShold (see page 409)	
:CHANnel2:SKEW (see page 1557)	:CHANnel<n>:PROBe:SKEW (see page 363)	
:CHANnel<n>:INPut (see page 1558)	:CHANnel<n>:IMPedance (see page 348)	
:CHANnel<n>:PMODe (see page 1559)	none	
:DISPlay:CONNect (see page 1560)	:DISPlay:VECTors (see page 436)	
:DISPlay:ORDer (see page 1561)	none	
:ERASe (see page 1562)	:DISPlay:CLEar (see page 421)	
:EXternal:PMODe (see page 1563)	none	
FUNCTION1, FUNCTION2	:FUNCTION Commands (see page 485)	ADD not included
:FUNCTION Commands	:FUNCTION2 Commands (see page 485)	:FUNCTION commands (with no <m> number) map to :FUNCTION2. This allows legacy programs to work without change.
:FUNCTION:GOFT:OPERation (see page 1564)	:FUNCTION1:OPERation (see page 523)	GOFT maps to FUNCTION1.
:FUNCTION:GOFT:SOURce1 (see page 1565)	:FUNCTION1:SOURce1 (see page 537)	GOFT maps to FUNCTION1.
:FUNCTION:GOFT:SOURce2 (see page 1566)	:FUNCTION1:SOURce2 (see page 539)	GOFT maps to FUNCTION1.
:FUNCTION:SOURce (see page 1567)	:FUNCTION:SOURce1 (see page 537)	Obsolete command has ADD, SUBTract, and MULTiply parameters; current command has GOFT parameter.
:FUNCTION:VIEW (see page 1568)	:FUNCTION:DISPlay (see page 499)	
:HARDcopy:DESTination (see page 1569)	:HARDcopy:FILEname (see page 1570)	

Obsolete Command	Current Command Equivalent	Behavior Differences
:HARDcopy:FILEname (see page 1570)	:RECall:FILEname (see page 866) :SAVE:FILEname (see page 866)	
:HARDcopy:GRAYscale (see page 1571)	:HARDcopy:PALette (see page 556)	
:HARDcopy:IGColors (see page 1572)	:HARDcopy:INKSaver (see page 548)	
:HARDcopy:PDRiver (see page 1573)	:HARDcopy:APRinter (see page 545)	
:MEASure:LOWER (see page 1574)	:MEASure:DEFine:THResholds (see page 629)	MEASure:DEFine:THResholds can define absolute values or percentage
:MEASure:SCRatch (see page 1575)	:MEASure:CLEar (see page 626)	
:MEASure:TDELta (see page 1576)	:MARKer:XDELta (see page 590)	
:MEASure:THResholds (see page 1577)	:MEASure:DEFine:THResholds (see page 629)	MEASure:DEFine:THResholds can define absolute values or percentage
:MEASure:TMAX (see page 1578)	:MEASure:XMAX (see page 690)	
:MEASure:TMIN (see page 1579)	:MEASure:XMIN (see page 691)	
:MEASure:TSTArt (see page 1580)	:MARKer:X1Position (see page 585)	
:MEASure:TSTOP (see page 1581)	:MARKer:X2Position (see page 588)	
:MEASure:TVOLT (see page 1582)	:MEASure:TVALue (see page 678)	TVALue measures additional values such as db, Vs, etc.
:MEASure:UPPer (see page 1583)	:MEASure:DEFine:THResholds (see page 629)	MEASure:DEFine:THResholds can define absolute values or percentage
:MEASure:VDELta (see page 1584)	:MARKer:YDELta (see page 597)	
:MEASure:VSTArt (see page 1585)	:MARKer:Y1Position (see page 594)	
:MEASure:VSTOP (see page 1586)	:MARKer:Y2Position (see page 596)	

Obsolete Command	Current Command Equivalent	Behavior Differences
:MEASure:VTIMe (see page 1587)	:MEASure:YATX (see page 692)	With :MEASure:YATX, there is a command for installing the measurement on the oscilloscope's display. :MEASure:VTIMe had no command, only a query.
:MTEST:AMASK:{SAVE   STORe} (see page 1588)	:SAVE:MASK[:STARt] (see page 886)	
:MTEST:AVERage (see page 1589)	:ACQuire:TYPE AVERage (see page 317)	
:MTEST:AVERage:COUNt (see page 1590)	:ACQuire:COUNt (see page 304)	
:MTEST:LOAD (see page 1591)	:RECall:MASK[:STARt] (see page 868)	
:MTEST:RUMode (see page 1592)	:MTEST:RMODe (see page 736)	
:MTEST:RUMode:SOFailure (see page 1593)	:MTEST:RMODe:FACTion:STOP (see page 740)	
:MTEST:{STARt   STOP} (see page 1594)	:RUN (see page 292) or :STOP (see page 296)	
:MTEST:TRIGger:SOURce (see page 1595)	:TRIGger Commands (see page 1349)	There are various commands for setting the source with different types of triggers.
:PRINt? (see page 1596)	:DISPlay:DATA? (see page 422)	
:SAVE:IMAGe:AREA (see page 1598)	none	
:TIMEbase:DELay (see page 1602)	:TIMEbase:POSition (see page 1340) or :TIMEbase:WINDOW:POSition (see page 1346)	TIMEbase:POSition is position value of main time base; TIMEbase:WINDOW:POSition is position value of zoomed (delayed) time base window.
:SBUS<n>:LIN:SIGNal:DEFinition (see page 1599)	none	
:SBUS<n>:SPI:SOURce:DATA (see page 1600)	:SBUS<n>:SPI:SOURce:MOSt (see page 1135)	
:SYSTem:MENU (see page 1601)	:DISPlay:MENU (see page 430)	No change in behavior.

Obsolete Command	Current Command Equivalent	Behavior Differences
:TRIGger:THReShold (see page 1603)	:POD<n>:THReShold (see page 755) or :DIGItal<d>:THReShold (see page 409)	
:TRIGger:TV:TMoDe (see page 1604)	:TRIGger:TV:MODE (see page 1432)	

### Discontinued Commands

Discontinued commands are commands that were used by previous oscilloscopes, but are not supported by the InfiniiVision 3000T X-Series oscilloscopes. Listed below are the Discontinued commands and the nearest equivalent command available (if any).

Discontinued Command	Current Command Equivalent	Comments
ASTore	:DISPlay:PERSistence INFinite (see page 432)	
CHANnel:MATH	:FUNCtion:OPERation (see page 523)	ADD not included
CHANnel<n>:PROTection	:CHANnel<n>:PROTection (see page 366)	Previous form of this command was used to enable/disable 50Ω protection. The new command resets a tripped protect and the query returns the status of TRIPed or NORMAl.
DISPlay:INVerse	none	
DISPlay:COLumn	none	
DISPlay:FREeze	none	
DISPlay:GRID	none	
DISPlay:LINE	none	
DISPlay:PIXel	none	
DISPlay:POSITION	none	
DISPlay:ROW	none	
DISPlay:TEXT	none	
FUNCtion:MOVE	none	
FUNCtion:PEAKs	none	
HARDcopy:ADDRess	none	Only parallel printer port is supported. GPIB printing not supported

Discontinued Command	Current Command Equivalent	Comments
MASK	none	All commands discontinued, feature not available
:POWer:SIGNals:CYCLeS	:POWer:SIGNals:CYCLeS:HARMonics (see <a href="#">page 829</a> ) :POWer:SIGNals:CYCLeS:QUALity (see <a href="#">page 830</a> )	This command was separated into several other commands for specific types of power analysis.
:POWer:SIGNals:DURation	:POWer:SIGNals:DURation:EFFiciency (see <a href="#">page 831</a> ) :POWer:SIGNals:DURation:MODulation (see <a href="#">page 832</a> ) :POWer:SIGNals:DURation:ONOFF:OFF (see <a href="#">page 833</a> ) :POWer:SIGNals:DURation:ONOFF:ON (see <a href="#">page 834</a> ) :POWer:SIGNals:DURation:RIPPLE (see <a href="#">page 835</a> ) :POWer:SIGNals:DURation:TRANSIENT (see <a href="#">page 836</a> )	This command was separated into several other commands for specific types of power analysis.
:POWer:SIGNals:VMAXimum	:POWer:SIGNals:VMAXimum:INRush (see <a href="#">page 839</a> ) :POWer:SIGNals:VMAXimum:ONOFF:OFF (see <a href="#">page 840</a> ) :POWer:SIGNals:VMAXimum:ONOFF:ON (see <a href="#">page 841</a> )	This command was separated into several other commands for specific types of power analysis.
:POWer:SIGNals:VSTeady	:POWer:SIGNals:VSTeady:ONOFF:OFF (see <a href="#">page 842</a> ) :POWer:SIGNals:VSTeady:ONOFF:ON (see <a href="#">page 843</a> ) :POWer:SIGNals:VSTeady:TRANSIENT (see <a href="#">page 844</a> )	This command was separated into several other commands for specific types of power analysis.
:POWer:SLEW:VALue	none	Slew rate values are now displayed using max and min measurements of a differentiate math function signal.
:PWRenable	none	The Power Event Enable Register does not exist in the 3000T X-Series oscilloscopes.
:PWRRegister[:EVENT]	none	The Power Event Event Register does not exist in the 3000T X-Series oscilloscopes.

Discontinued Command	Current Command Equivalent	Comments
SYSTem:KEY	none	
TEST:ALL	*TST (Self Test) (see page 253)	
TRACE subsystem	none	All commands discontinued, feature not available
TRIGger:ADVanced subsystem		Use new GLITch, PATTern, or TV trigger modes
TRIGger:TV:FIELD	:TRIGger:TV:MODE (see page 1432)	
TRIGger:TV:VHFrej		
TRIGger:TV:VIR	none	
:TRIGger:USB:SOURce:DMINus	none	USB serial decode and triggering is not supported on the 3000T X-Series oscilloscopes.
:TRIGger:USB:SOURce:DPLus	none	
:TRIGger:USB:SPEed	none	
:TRIGger:USB:TRIGger	none	
VAUToscale	none	

**Discontinued Parameters** Some previous oscilloscope queries returned control setting values of OFF and ON. The InfiniiVision 3000T X-Series oscilloscopes only return the enumerated values 0 (for off) and 1 (for on).

**:CHANnel:ACTivity****O** (see [page 1666](#))**Command Syntax** `:CHANnel:ACTivity`

The :CHANnel:ACTivity command clears the cumulative edge variables for the next activity query.

**NOTE** The :CHANnel:ACTivity command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :ACTivity command (see [page 259](#)) instead.

---

**Query Syntax** `:CHANnel:ACTivity?`

The :CHANnel:ACTivity? query returns the active edges since the last clear, and returns the current logic levels.

**Return Format** `<edges>,<levels><NL>`

`<edges>` ::= presence of edges (32-bit integer in NR1 format).

`<levels>` ::= logical highs or lows (32-bit integer in NR1 format).

**NOTE** A bit equal to zero indicates that no edges were detected at the specified threshold since the last clear on that channel. Edges may have occurred that were not detected because of the threshold setting.

---

A bit equal to one indicates that edges have been detected at the specified threshold since the last clear on that channel.

## :CHANnel:LABel

**O** (see [page 1666](#))

<b>Command Syntax</b>	<code>:CHANnel:LABel &lt;source_text&gt;&lt;string&gt;</code>
	<code>&lt;source_text&gt; ::= {CHANnel1   CHANnel2   DIGital&lt;d&gt;}</code>
	<code>&lt;d&gt; ::= 0 to (# digital channels - 1) in NR1 format</code>
	<code>&lt;string&gt; ::= quoted ASCII string</code>
The :CHANnel:LABel command sets the source text to the string that follows. Setting a channel will also result in the name being added to the label list.	

### NOTE

The :CHANnel:LABel command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :CHANnel<n>:LABel command (see [page 350](#)) or :DIGital<n>:LABel command (see [page 406](#)).

<b>Query Syntax</b>	<code>:CHANnel:LABel?</code>
	The :CHANnel:LABel? query returns the label associated with a particular analog channel.

<b>Return Format</b>	<code>&lt;string&gt;&lt;NL&gt;</code>
	<code>&lt;string&gt; ::= quoted ASCII string</code>

## :CHANnel:THreshold

**O** (see [page 1666](#))

**Command Syntax**

```
:CHANnel:THreshold <channel group>, <threshold type> [, <value>]
<channel group> ::= {POD1 | POD2}
<threshold type> ::= {CMOS | ECL | TTL | USERdef}
<value> ::= voltage for USERdef in NR3 format [volt_type]
[volt_type] ::= {V | mV (-3) | uV (-6)}
```

The :CHANnel:THreshold command sets the threshold for a group of channels. The threshold is either set to a predefined value or to a user-defined value. For the predefined value, the voltage parameter is ignored.

### NOTE

The :CHANnel:THreshold command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :POD<n>:THreshold command (see [page 755](#)) or :DIGital<n>:THreshold command (see [page 409](#)).

### Query Syntax

```
:CHANnel:THreshold? <channel group>
```

The :CHANnel:THreshold? query returns the voltage and threshold text for a specific group of channels.

### Return Format

```
<threshold type> [, <value>]<NL>
<threshold type> ::= {CMOS | ECL | TTL | USERdef}
<value> ::= voltage for USERdef (float 32 NR3)
```

### NOTE

- CMOS = 2.5V
- TTL = 1.5V
- ECL = -1.3V
- USERdef := -6.0V to 6.0V

## :CHANnel2:SKEW

**O** (see [page 1666](#))

**Command Syntax** :CHANnel2:SKEW <skew value>

<skew value> ::= skew time in NR3 format

<skew value> ::= -100 ns to +100 ns

The :CHANnel2:SKEW command sets the skew between channels 1 and 2. The maximum skew is +/-100 ns. You can use the oscilloscope's analog probe skew control to remove cable delay errors between channel 1 and channel 2.

**NOTE**

The :CHANnel2:SKEW command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :CHANnel<n>:PROBe:SKEW command (see [page 363](#)) instead.

**NOTE**

This command is only valid for the two channel oscilloscope models.

**Query Syntax**

:CHANnel2:SKEW?

The :CHANnel2:SKEW? query returns the current probe skew setting for the selected channel.

**Return Format**

<skew value><NL>

<skew value> ::= skew value in NR3 format

**See Also**

- "Introduction to :CHANnel<n> Commands" on page 344

**:CHANnel<n>:INPut****O** (see [page 1666](#))**Command Syntax**    `:CHANnel<n>:INPut <impedance>``<impedance> ::= {ONEMeg | FIFTy}``<n> ::= 1 to (# analog channels) in NR1 format`

The :CHANnel<n>:INPut command selects the input impedance setting for the specified channel. The legal values for this command are ONEMeg ( $1\text{ M}\Omega$ ) and FIFTy ( $50\Omega$ ).

**NOTE**

The :CHANnel<n>:INPut command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :CHANnel<n>:IMPedance command (see [page 348](#)) instead.

**Query Syntax**    `:CHANnel<n>:INPut ?`

The :CHANnel<n>:INPut? query returns the current input impedance setting for the specified channel.

**Return Format**    `<impedance value><NL>``<impedance value> ::= {ONEM | FIFT}`

**:CHANnel<n>:PMODe****O** (see [page 1666](#))**Command Syntax** :CHANnel<n>:PMODe <pmode value>

&lt;pmode value&gt; ::= {AUTo | MANual}

&lt;n&gt; ::= 1 to (# analog channels) in NR1 format

The probe sense mode is controlled internally and cannot be set. If a probe with sense is connected to the specified channel, auto sensing is enabled; otherwise, the mode is manual.

If the PMODe sent matches the oscilloscope's setting, the command will be accepted. Otherwise, a setting conflict error is generated.

**NOTE**

The :CHANnel<n>:PMODe command is an obsolete command provided for compatibility to previous oscilloscopes.

**Query Syntax** :CHANnel<n>:PMODe?

The :CHANnel<n>:PMODe? query returns AUT if an autosense probe is attached and MAN otherwise.

**Return Format** <pmode value><NL>

&lt;pmode value&gt; ::= {AUT | MAN}

## :DISPlay:CONNect

**O** (see [page 1666](#))

**Command Syntax** :DISPLAY:CONNect <connect>

<connect> ::= {{ 1 | ON} | {0 | OFF}}

The :DISPlay:CONNect command turns vectors on and off. When vectors are turned on, the oscilloscope displays lines connecting sampled data points. When vectors are turned off, only the sampled data is displayed.

### NOTE

The :DISPlay:CONNect command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :DISPlay:VECTors command (see [page 436](#)) instead.

**Query Syntax** :DISPLAY:CONNect?

The :DISPlay:CONNect? query returns the current state of the vectors setting.

**Return Format** <connect><NL>

<connect> ::= {1 | 0}

**See Also** • "[:DISPLAY:VECTors](#)" on page 436

## :DISPlay:ORDer

**O** (see [page 1666](#))

**Query Syntax** :DISPLAY:ORDer?

The :DISPLAY:ORDer? query returns a list of digital channel numbers in screen order, from top to bottom, separated by commas. Busing is displayed as digital channels with no separator. For example, in the following list, the bus consists of digital channels 4 and 5: DIG1, DIG4 DIG5, DIG7.

**NOTE** The :DISPLAY:ORDer command is an obsolete command provided for compatibility to previous oscilloscopes. This command is only available on the MSO models.

**Return Format**

```
<order><NL>
<order> ::= Unquoted ASCII string
```

**NOTE** A return value is included for each digital channel. A return value of NONE indicates that a channel is turned off.

**See Also**

- [":DIGital<d>:POSIon"](#) on page 407

**Example Code**

```
' DISP_ORDER - Set the order the channels are displayed on the
' analyzer. You can enter between 1 and 32 channels at one time.
' If you leave out channels, they will not be displayed.

' Display ONLY channel 0 and channel 10 in that order.
myScope.WriteString ":DISPLAY:ORDER 0,10"
```

See complete example programs at: [Chapter 46, “Programming Examples,”](#) starting on page 1675

## :ERASe

 (see [page 1666](#))

**Command Syntax** :ERASe

The :ERASe command erases the screen.

### NOTE

The :ERASe command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :DISPLAY:CLEAR command (see [page 421](#)) instead.

---

## :EXTernal:PMODE

**O** (see [page 1666](#))

**Command Syntax** :EXTernal:PMODE <pmode value>  
<pmode value> ::= {AUTo | MANual}

The probe sense mode is controlled internally and cannot be set. If a probe with sense is connected to the specified channel, auto sensing is enabled; otherwise, the mode is manual.

If the pmode sent matches the oscilloscope's setting, the command will be accepted. Otherwise, a setting conflict error is generated.

### NOTE

The :EXTernal:PMODE command is an obsolete command provided for compatibility to previous oscilloscopes.

**Query Syntax** :EXTernal:PMODE?

The :EXTernal:PMODE? query returns AUT if an autosense probe is attached and MAN otherwise.

**Return Format** <pmode value><NL>  
<pmode value> ::= {AUT | MAN}

## :FUNCTION:GOFT:OPERation

**O** (see [page 1666](#))

**Command Syntax** :FUNCTION:GOFT:OPERation <operation>

<operation> ::= {ADD | SUBTract | MULTIply}

The :FUNCTION:GOFT:OPERation command sets the math operation for the g(t) source that can be used as the input to transform or filter functions (if available):

- ADD – Source1 + source2.
- SUBTract – Source1 - source2.
- MULTIply – Source1 \* source2.

The :FUNCTION:GOFT:SOURce1 and :FUNCTION:GOFT:SOURce2 commands are used to select source1 and source2.

## :FUNCTION:GOFT:SOURce1

**O** (see [page 1666](#))

**Command Syntax**

```
:FUNCTION:GOFT:SOURce1 <value>
<value> ::= CHANnel<n>
<n> ::= {1 | 2 | 3 | 4} for 4ch models
<n> ::= {1 | 2} for 2ch models
```

The :FUNCTION:GOFT:SOURce1 command selects the first input channel for the g(t) source that can be used as the input to transform or filter functions (if available).

**Query Syntax**

```
:FUNCTION:GOFT:SOURce1?
```

The :FUNCTION:GOFT:SOURce1? query returns the current selection for the first input channel for the g(t) source.

**Return Format**

```
<value><NL>
<value> ::= CHAN<n>
<n> ::= {1 | 2 | 3 | 4} for the 4ch models
<n> ::= {1 | 2} for the 2ch models
```

**See Also**

- "[Introduction to :FUNCTION<m> Commands](#)" on page 491
- "[":FUNCTION:GOFT:SOURce2](#)" on page 1566
- "[":FUNCTION:GOFT:OPERation](#)" on page 1564

## :FUNCTION:GOFT:SOURce2

**O** (see [page 1666](#))

**Command Syntax**    `:FUNCTION:GOFT:SOURce2 <value>`  
`<value> ::= CHANnel<n>`  
`<n> ::= {1 | 2 | 3 | 4} for 4ch models`  
`<n> ::= {1 | 2} for 2ch models`

The :FUNCTION:GOFT:SOURce2 command selects the second input channel for the g(t) source that can be used as the input to transform or filter functions (if available).

**Query Syntax**    `:FUNCTION:GOFT:SOURce2?`

The :FUNCTION:GOFT:SOURce2? query returns the current selection for the second input channel for the g(t) source.

**Return Format**    `<value><NL>`  
`<value> ::= CHAN<n>`  
`<n> ::= {1 | 2 | 3 | 4} for 4ch models`  
`<n> ::= {1 | 2} for 2ch models`

**See Also**

- "Introduction to :FUNCTION<m> Commands" on page 491
- "[":FUNCTION:GOFT:SOURce1](#)" on page 1565
- "[":FUNCTION:GOFT:OPERation](#)" on page 1564

## :FUNCTION:SOURce

**O** (see [page 1666](#))

**Command Syntax**    `:FUNCTION:SOURce <value>`

`<value> ::= {CHANnel<n> | ADD | SUBTract | MULTiply}`

`<n> ::= 1 to (# analog channels) in NR1 format`

The :FUNCTION:SOURce command is only used when an FFT (Fast Fourier Transform), DIFF, or INT operation is selected (see the :FUNCTION:OPERation command for more information about selecting an operation). The :FUNCTION:SOURce command selects the source for function operations. Choose CHANnel<n>, or ADD, SUBT, or MULT to specify the desired source for function DIFF (differentiate), INTegrate, and FFT operations specified by the :FUNCTION:OPERation command.

### NOTE

The :FUNCTION:SOURce command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :FUNCTION:SOURce1 command (see [page 537](#)) instead.

**Query Syntax**    `:FUNCTION:SOURce?`

The :FUNCTION:SOURce? query returns the current source for function operations.

**Return Format**    `<value><NL>`

`<value> ::= {CHAN<n> | ADD | SUBT | MULT}`

`<n> ::= 1 to (# analog channels) in NR1 format`

**See Also**

- "[Introduction to :FUNCTION<m> Commands](#)" on page 491
- "[:FUNCTION<m>:OPERation](#)" on page 523

## :FUNCTION:VIEW

**O** (see [page 1666](#))

**Command Syntax**    `:FUNCTION:VIEW <view>`  
`<view> ::= {{1 | ON} | (0 | OFF)}`

The :FUNCTION:VIEW command turns the selected function on or off. When ON is selected, the function performs as specified using the other FUNCTION commands. When OFF is selected, function is neither calculated nor displayed.

**NOTE**

The :FUNCTION:VIEW command is provided for backward compatibility to previous oscilloscopes. Use the :FUNCTION:DISPLAY command (see [page 499](#)) instead.

**Query Syntax**    `:FUNCTION:VIEW?`

The :FUNCTION:VIEW? query returns the current state of the selected function.

**Return Format**    `<view><NL>`  
`<view> ::= {1 | 0}`

## :HARDcopy:DESTination

**O** (see [page 1666](#))

**Command Syntax**    `:HARDcopy:DESTination <destination>`  
`<destination> ::= {CENTronics | FLOPpy}`

The :HARDcopy:DESTination command sets the hardcopy destination.

**NOTE**    The :HARDcopy:DESTination command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :HARDcopy:FILENAME command (see [page 1570](#)) instead.

**Query Syntax**    `:HARDcopy:DESTination?`

The :HARDcopy:DESTination? query returns the selected hardcopy destination.

**Return Format**    `<destination><NL>`  
`<destination> ::= {CENT | FLOP}`

**See Also**    • "Introduction to :HARDcopy Commands" on page 542

## :HARDcopy:FILEname

**O** (see [page 1666](#))

**Command Syntax**    `:HARDcopy:FILEname <string>`  
`<string> ::= quoted ASCII string`

The HARDcopy:FILEname command sets the output filename for those print formats whose output is a file.

**NOTE**    The :HARDcopy:FILEname command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :SAVE:FILEname command ([see page 879](#)) and :RECall:FILEname command ([see page 866](#)) instead.

---

**Query Syntax**    `:HARDcopy:FILEname?`

The :HARDcopy:FILEname? query returns the current hardcopy output filename.

**Return Format**    `<string><NL>`  
`<string> ::= quoted ASCII string`

**See Also**

- "Introduction to :HARDcopy Commands" on [page 542](#)

## :HARDcopy:GRAYscale

**O** (see [page 1666](#))

**Command Syntax** :HARDcopy:GRAYscale <gray>

<gray> ::= {{OFF | 0} | {ON | 1}}

The :HARDcopy:GRAYscale command controls whether grayscaling is performed in the hardcopy dump.

### NOTE

The :HARDcopy:GRAYscale command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :HARDcopy:PALETTE command (see [page 556](#)) instead. ("":HARDcopy:GRAYscale ON" is the same as "":HARDcopy:PALETTE GRAYscale" and "":HARDcopy:GRAYscale OFF" is the same as "":HARDcopy:PALETTE COLOR".)

**Query Syntax** :HARDcopy:GRAYscale?

The :HARDcopy:GRAYscale? query returns a flag indicating whether grayscaling is performed in the hardcopy dump.

**Return Format** <gray><NL>

<gray> ::= {0 | 1}

**See Also** · ["Introduction to :HARDcopy Commands"](#) on page 542

## :HARDcopy:IGColors

**O** (see [page 1666](#))

**Command Syntax** :HARDcopy:IGColors <value>

<value> ::= {{OFF | 0} | {ON | 1}}

The HARDcopy:IGColors command controls whether the graticule colors are inverted or not.

### NOTE

The :HARDcopy:IGColors command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :HARDcopy:INKSaver (see [page 548](#)) command instead.

**Query Syntax** :HARDcopy:IGColors?

The :HARDcopy:IGColors? query returns a flag indicating whether graticule colors are inverted or not.

**Return Format** <value><NL>

<value> ::= {0 | 1}

**See Also** • "Introduction to :HARDcopy Commands" on page 542

## :HARDcopy:PDRiver

**O** (see [page 1666](#))

**Command Syntax** :HARDcopy:PDRiver <driver>

```
<driver> ::= {AP2XXX | AP21XX | {AP2560 | AP25} | {DJ350 | DJ35} |
               DJ6XX | {DJ630 | DJ63} | DJ6Special | DJ6Photo |
               DJ8Special | DJ8XX | DJ9Vip | OJPRokx50 | DJ9XX | GVIP |
               DJ55XX | {PS470 | PS47} {PS100 | PS10} | CLASer |
               MLASer | LJFastraster | POSTscript}
```

The HARDcopy:PDRiver command sets the hardcopy printer driver used for the selected printer.

If the correct driver for the selected printer can be identified, it will be selected and cannot be changed.

### NOTE

The :HARDcopy:PDRiver command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :HARDcopy:APRinter (see [page 545](#)) command instead.

**Query Syntax** :HARDcopy:PDRiver?

The :HARDcopy:PDRiver? query returns the selected hardcopy printer driver.

**Return Format** <driver><NL>

```
<driver> ::= {AP2X | AP21 | AP25 | DJ35 | DJ6 | DJ63 | DJ6S | DJ6P |
               DJ8S | DJ8 | DJ9V | OJPR | DJ9 | GVIP | DJ55 | PS10 |
               PS47 | CLAS | MLAS | LJF | POST}
```

**See Also** • "Introduction to :HARDcopy Commands" on page 542

## :MEASure:LOWER

 (see [page 1666](#))

**Command Syntax**    `:MEASure:LOWER <voltage>`

The :MEASure:LOWER command sets the lower measurement threshold value. This value and the UPPer value represent absolute values when the thresholds are ABSolute and percentage when the thresholds are PERCent as defined by the :MEASure:DEFine THresholds command.

### NOTE

The :MEASure:LOWER command is obsolete and is provided for backward compatibility to previous oscilloscopes. Use the :MEASure:DEFine THresholds command (see [page 629](#)) instead.

**Query Syntax**    `:MEASure:LOWER?`

The :MEASure:LOWER? query returns the current lower threshold level.

**Return Format**    `<voltage><NL>`

`<voltage>` ::= the user-defined lower threshold in volts in NR3 format

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:THresholds](#)" on page 1577
- "[":MEASure:UPPer](#)" on page 1583

## :MEASure:SCRatch

 (see [page 1666](#))

**Command Syntax** :MEASure:SCRatch

The :MEASure:SCRatch command clears all selected measurements and markers from the screen.

### NOTE

The :MEASure:SCRatch command is obsolete and is provided for backward compatibility to previous oscilloscopes. Use the :MEASure:CLEar command ([see page 626](#)) instead.

---

## :MEASure:TDELta

 (see [page 1666](#))

**Query Syntax** `:MEASure:TDELta?`

The `:MEASure:TDELta?` query returns the time difference between the Tstop marker (X2 cursor) and the Tstart marker (X1 cursor).

$$\text{Tdelta} = \text{Tstop} - \text{Tstart}$$

Tstart is the time at the start marker (X1 cursor) and Tstop is the time at the stop marker (X2 cursor). No measurement is made when the `:MEASure:TDELta?` query is received by the oscilloscope. The delta time value that is output is the current value. This is the same value as the front-panel cursors delta X value.

### NOTE

The `:MEASure:TDELta` command is an obsolete command provided for compatibility to previous oscilloscopes. Use the `:MARKer:XDELta` command (see [page 590](#)) instead.

**Return Format** `<value><NL>`

`<value>` ::= time difference between start and stop markers in NR3 format

**See Also**

- ["Introduction to :MARKer Commands"](#) on page 581
- ["Introduction to :MEASure Commands"](#) on page 620
- [":MARKer:X1Position"](#) on page 585
- [":MARKer:X2Position"](#) on page 588
- [":MARKer:XDELta"](#) on page 590
- [":MEASure:TSTArt"](#) on page 1580
- [":MEASure:TSTOP"](#) on page 1581

## :MEASure:THResholds

**O** (see [page 1666](#))

**Command Syntax** :MEASure:THResholds {T1090 | T2080 | VOLTage}

The :MEASure:THResholds command selects the thresholds used when making time measurements.

### NOTE

The :MEASure:THResholds command is obsolete and is provided for backward compatibility to previous oscilloscopes. Use the :MEASure:DEFine THResholds command (see [page 629](#)) instead.

**Query Syntax** :MEASure:THResholds?

The :MEASure:THResholds? query returns the current thresholds selected when making time measurements.

**Return Format** {T1090 | T2080 | VOLTage}<NL>

{T1090} uses the 10% and 90% levels of the selected waveform.

{T2080} uses the 20% and 80% levels of the selected waveform.

{VOLTage} uses the upper and lower voltage thresholds set by the UPPer and LOWER commands on the selected waveform.

**See Also** • ["Introduction to :MEASure Commands" on page 620](#)

• [":MEASure:LOWER" on page 1574](#)

• [":MEASure:UPPer" on page 1583](#)

## :MEASure:TMAX

 (see [page 1666](#))

**Command Syntax**    `:MEASure:TMAX [<source>]`

```
<source> ::= {CHANnel<n> | FUNCtion | MATH}
<n> ::= 1 to (# analog channels) in NR1 format
```

The :MEASure:TMAX command installs a screen measurement and starts an X-at-Max-Y measurement on the selected waveform. If the optional source is specified, the current source is modified.

### NOTE

The :MEASure:TMAX command is obsolete and is provided for backward compatibility to previous oscilloscopes. Use the :MEASure:XMAX command (see [page 690](#)) instead.

**Query Syntax**    `:MEASure:TMAX? [<source>]`

The :MEASure:TMAX? query returns the horizontal axis value at which the maximum vertical value occurs on the current source. If the optional source is specified, the current source is modified.

**Return Format**    `<value><NL>`

```
<value> ::= time at maximum in NR3 format
```

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:TMIN"](#) on page 1579
- "[":MEASure:XMAX"](#) on page 690
- "[":MEASure:XMIN"](#) on page 691

## :MEASure:TMIN

**O** (see [page 1666](#))

**Command Syntax**    `:MEASure:TMIN [<source>]`

```
<source> ::= {CHANnel<n> | FUNCtion | MATH}
<n> ::= 1 to (# analog channels) in NR1 format
```

The :MEASure:TMIN command installs a screen measurement and starts an X-at-Min-Y measurement on the selected waveform. If the optional source is specified, the current source is modified.

### NOTE

The :MEASure:TMIN command is obsolete and is provided for backward compatibility to previous oscilloscopes. Use the :MEASure:XMIN command (see [page 691](#)) instead.

**Query Syntax**    `:MEASure:TMIN? [<source>]`

The :MEASure:TMIN? query returns the horizontal axis value at which the minimum vertical value occurs on the current source. If the optional source is specified, the current source is modified.

**Return Format**    `<value><NL>`

```
<value> ::= time at minimum in NR3 format
```

**See Also**

- "Introduction to :MEASure Commands" on page 620
- "[:MEASure:TMAX](#)" on page 1578
- "[:MEASure:XMAX](#)" on page 690
- "[:MEASure:XMIN](#)" on page 691

## :MEASure:TSTArt

**O** (see [page 1666](#))

**Command Syntax**    `:MEASure:TSTArt <value> [suffix]`

`<value>` ::= time at the start marker in seconds

`[suffix]` ::= {s | ms | us | ns | ps}

The :MEASure:TSTArt command moves the start marker (X1 cursor) to the specified time with respect to the trigger time.

### NOTE

The short form of this command, TSTA, does not follow the defined Long Form to Short Form Truncation Rules (see [page 1668](#)). The normal short form "TST" would be the same for both TSTArt and TSTOP, so sending TST for the TSTArt command produces an error.

### NOTE

The :MEASure:TSTArt command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :MARKer:X1Position command (see [page 585](#)) instead.

### Query Syntax

`:MEASure:TSTArt?`

The :MEASure:TSTArt? query returns the time at the start marker (X1 cursor).

### Return Format

`<value><NL>`

`<value>` ::= time at the start marker in NR3 format

### See Also

- ["Introduction to :MARKer Commands"](#) on page 581
- ["Introduction to :MEASure Commands"](#) on page 620
- [":MARKer:X1Position"](#) on page 585
- [":MARKer:X2Position"](#) on page 588
- [":MARKer:XDELta"](#) on page 590
- [":MEASure:TDELta"](#) on page 1576
- [":MEASure:TSTOP"](#) on page 1581

## :MEASure:TSTOp

**O** (see [page 1666](#))

**Command Syntax** :MEASure:TSTOp <value> [suffix]

<value> ::= time at the stop marker in seconds

[suffix] ::= {s | ms | us | ns | ps}

The :MEASure:TSTOp command moves the stop marker (X2 cursor) to the specified time with respect to the trigger time.

### NOTE

The short form of this command, TSTO, does not follow the defined Long Form to Short Form Truncation Rules (see [page 1668](#)). The normal short form "TST" would be the same for both TSTArt and TSTOp, so sending TST for the TSTOp command produces an error.

### NOTE

The :MEASure:TSTOp command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :MARKer:X2Position command (see [page 588](#)) instead.

### Query Syntax

:MEASure:TSTOp?

The :MEASure:TSTOp? query returns the time at the stop marker (X2 cursor).

### Return Format

<value><NL>

<value> ::= time at the stop marker in NR3 format

### See Also

- "[Introduction to :MARKer Commands](#)" on page 581
- "[Introduction to :MEASure Commands](#)" on page 620
- "[:MARKer:X1Position](#)" on page 585
- "[:MARKer:X2Position](#)" on page 588
- "[:MARKer:XDELta](#)" on page 590
- "[:MEASure:TDELta](#)" on page 1576
- "[:MEASure:TSTArt](#)" on page 1580

## :MEASure:TVOLt

**O** (see [page 1666](#))

**Query Syntax**

```
:MEASure:TVOLt? <value>, [<slope>]<occurrence>[,<source>]
<value> ::= the voltage level that the waveform must cross.
<slope> ::= direction of the waveform. A rising slope is indicated by
           a plus sign (+). A falling edge is indicated by a minus
           sign (-).
<occurrence> ::= the transition to be reported. If the occurrence
                  number is one, the first crossing is reported. If
                  the number is two, the second crossing is reported,
                  etc.
<source> ::= {<digital channels> | CHANnel<n> | FUNCtion | MATH}
<digital channels> ::= {DIGital<d>} for the MSO models
<n> ::= 1 to (# analog channels) in NR1 format
<d> ::= 0 to (# digital channels - 1) in NR1 format
```

When the :MEASure:TVOLt? query is sent, the displayed signal is searched for the specified voltage level and transition. The time interval between the trigger event and this defined occurrence is returned as the response to the query.

The specified voltage can be negative or positive. To specify a negative voltage, use a minus sign (-). The sign of the slope selects a rising (+) or falling (-) edge. If no sign is specified for the slope, it is assumed to be the rising edge.

The magnitude of the occurrence defines the occurrence to be reported. For example, +3 returns the time for the third time the waveform crosses the specified voltage level in the positive direction. Once this voltage crossing is found, the oscilloscope reports the time at that crossing in seconds, with the trigger point (time zero) as the reference.

If the specified crossing cannot be found, the oscilloscope reports +9.9E+37. This value is returned if the waveform does not cross the specified voltage, or if the waveform does not cross the specified voltage for the specified number of times in the direction specified.

If the optional source parameter is specified, the current source is modified.

### NOTE

The :MEASure:TVOLt command is obsolete and is provided for backward compatibility to previous oscilloscopes. Use the :MEASure:TVALue command (see [page 678](#)).

### Return Format

```
<value><NL>
<value> ::= time in seconds of the specified voltage crossing
           in NR3 format
```

## :MEASure:UPPer

**O** (see [page 1666](#))

**Command Syntax** :MEASure:UPPer <value>

The :MEASure:UPPer command sets the upper measurement threshold value. This value and the LOWER value represent absolute values when the thresholds are ABSolute and percentage when the thresholds are PERCent as defined by the :MEASure:DEFine THresholds command.

### NOTE

The :MEASure:UPPer command is obsolete and is provided for backward compatibility to previous oscilloscopes. Use the :MEASure:DEFine THresholds command (see [page 629](#)) instead.

**Query Syntax** :MEASure:UPPer?

The :MEASure:UPPer? query returns the current upper threshold level.

**Return Format** <value><NL>

<value> ::= the user-defined upper threshold in NR3 format

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MEASure:LOWER"](#) on page 1574
- "[":MEASure:THresholds"](#) on page 1577

**:MEASure:VDELta****O** (see [page 1666](#))**Query Syntax** `:MEASure:VDELta?`

The `:MEASure:VDELta?` query returns the voltage difference between vertical marker 1 (Y1 cursor) and vertical marker 2 (Y2 cursor). No measurement is made when the `:MEASure:VDELta?` query is received by the oscilloscope. The delta value that is returned is the current value. This is the same value as the front-panel cursors delta Y value.

$VDELta = \text{value at marker 2} - \text{value at marker 1}$

**NOTE**

The `:MEASure:VDELta` command is an obsolete command provided for compatibility to previous oscilloscopes. Use the `:MARKer:YDELta` command ([see page 597](#)) instead.

**Return Format** `<value><NL>`

`<value> ::= delta V value in NR1 format`

**See Also**

- "[Introduction to :MARKer Commands](#)" on page 581
- "[Introduction to :MEASure Commands](#)" on page 620
- "[:MARKer:Y1Position](#)" on page 594
- "[:MARKer:Y2Position](#)" on page 596
- "[:MARKer:YDELta](#)" on page 597
- "[:MEASure:TDELta](#)" on page 1576
- "[:MEASure:TSTArt](#)" on page 1580

## :MEASure:VSTArt

**O** (see [page 1666](#))

**Command Syntax** :MEASure:VSTArt <vstart\_argument>

<vstart\_argument> ::= value for vertical marker 1

The :MEASure:VSTArt command moves the vertical marker (Y1 cursor) to the specified value corresponding to the selected source. The source can be selected by the MARKer:X1Y1source command.

### NOTE

The short form of this command, VSTA, does not follow the defined Long Form to Short Form Truncation Rules (see [page 1668](#)). The normal short form, VST, would be the same for both VSTArt and VSTOp, so sending VST for the VSTArt command produces an error.

### NOTE

The :MEASure:VSTArt command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :MARKer:Y1Position command (see [page 594](#)) instead.

#### Query Syntax

:MEASure:VSTArt?

The :MEASure:VSTArt? query returns the current value of the Y1 cursor.

#### Return Format

<value><NL>

<value> ::= voltage at voltage marker 1 in NR3 format

#### See Also

- "[Introduction to :MARKer Commands](#)" on page 581
- "[Introduction to :MEASure Commands](#)" on page 620
- "[":MARKer:Y1Position](#)" on page 594
- "[":MARKer:Y2Position](#)" on page 596
- "[":MARKer:YDELta](#)" on page 597
- "[":MARKer:X1Y1source](#)" on page 586
- "[":MEASure:SOURce](#)" on page 667
- "[":MEASure:TDELta](#)" on page 1576
- "[":MEASure:TSTArt](#)" on page 1580

## :MEASure:VSTOp

**O** (see [page 1666](#))

**Command Syntax**    `:MEASure:VSTOp <vstop_argument>`

`<vstop_argument> ::= value for Y2 cursor`

The :MEASure:VSTOp command moves the vertical marker 2 (Y2 cursor) to the specified value corresponding to the selected source. The source can be selected by the MARKer:X2Y2source command.

### NOTE

The short form of this command, VSTO, does not follow the defined Long Form to Short Form Truncation Rules (see [page 1668](#)). The normal short form, VST, would be the same for both VSTArt and VSTOp, so sending VST for the VSTOp command produces an error.

### NOTE

The :MEASure:VSTOp command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :MARKer:Y2Position command (see [page 596](#)) instead.

#### Query Syntax

`:MEASure:VSTOp?`

The :MEASure:VSTOp? query returns the current value of the Y2 cursor.

#### Return Format

`<value><NL>`

`<value> ::= value of the Y2 cursor in NR3 format`

#### See Also

- ["Introduction to :MARKer Commands"](#) on page 581
- ["Introduction to :MEASure Commands"](#) on page 620
- [":MARKer:Y1Position"](#) on page 594
- [":MARKer:Y2Position"](#) on page 596
- [":MARKer:YDELta"](#) on page 597
- [":MARKer:X2Y2source"](#) on page 589
- [":MEASure:SOURce"](#) on page 667
- [":MEASure:TDELta"](#) on page 1576
- [":MEASure:TSTArt"](#) on page 1580

## :MEASure:VTIMe

**O** (see [page 1666](#))

**Query Syntax**

```
:MEASure:VTIMe? <vtimetime_argument>[,<source>]
<vtimetime_argument> ::= time from trigger in seconds
<source> ::= {<digital channels> | CHANnel<n> | FUNCtion<m> | MATH<m>
              | FFT | WMEMory<r>}
<digital channels> ::= DIGItal<d> for the MSO models
<d> ::= 0 to (# digital channels - 1) in NR1 format
<n> ::= 1 to (# of analog channels) in NR1 format
<m> ::= 1 to (# math functions) in NR1 format
<r> ::= 1 to (# ref waveforms) in NR1 format
```

The :MEASure:VTIMe? query returns the vertical value at a specified horizontal value on the source specified (see also :MEASure:SOURce). The specified horizontal value must be on the screen; when it is a time value, it is referenced to the trigger event. If the optional source parameter is specified, the measurement source is modified.

**NOTE**

When the source is an FFT (Fast Fourier Transform) waveform, the <vtimetime\_argument> is a frequency value instead of a time value.

**Return Format**

```
<value><NL>
<value> ::= vertical value at the specified horizontal location
           in NR3 format
```

**See Also**

- "[Introduction to :MEASure Commands](#)" on page 620
- "[:MEASure:SOURce](#)" on page 667
- "[:MEASure:TEDGE](#)" on page 675
- "[:MEASure:TVALUE](#)" on page 678

## :MTEST:AMASK:{SAVE | STORe}

 (see [page 1666](#))

**Command Syntax** :MTEST:AMASK:{SAVE | STORe} "<filename>"

The :MTEST:AMASK:SAVE command saves the automask generated mask to a file. If an automask has not been generated, an error occurs.

The <filename> parameter is an MS-DOS compatible name of the file, a maximum of 254 characters long (including the path name, if used). The filename assumes the present working directory if a path does not precede the file name.

### NOTE

The :MTEST:AMASK:{SAVE | STORe} command is obsolete and is provided for backward compatibility to previous oscilloscopes. Use the :SAVE:MASK[:STARt] command (see [page 886](#)) instead.

**See Also** • ["Introduction to :MTEST Commands"](#) on page 719

## :MTEST:AVERage

**O** (see [page 1666](#))

**Command Syntax** :MTEST:AVERage <on\_off>

<on\_off> ::= {{1 | ON} | {0 | OFF}}

The :MTEST:AVERage command enables or disables averaging. When ON, the oscilloscope acquires multiple data values for each time bucket, and averages them. When OFF, averaging is disabled. To set the number of averages, use the :MTEST:AVERage:COUNt command described next.

### NOTE

The :MTEST:AVERage command is obsolete and is provided for backward compatibility to previous oscilloscopes. Use the :ACQuire:TYPE AVERage command (see [page 317](#)) instead.

**Query Syntax** :MTEST:AVERage?

The :MTEST:AVERage? query returns the current setting for averaging.

**Return Format** <on\_off><NL>

<on\_off> ::= {1 | 0}

**See Also**

- "[Introduction to :MTEST Commands](#)" on page 719
- "[":MTEST:AVERage:COUNt](#)" on page 1590

## :MTEST:AVERage:COUNt

 (see [page 1666](#))

**Command Syntax** :MTEST:AVERage:COUNt <count>

<count> ::= an integer from 2 to 65536 in NR1 format

The :MTEST:AVERage:COUNt command sets the number of averages for the waveforms. With the AVERage acquisition type, the :MTEST:AVERage:COUNt command specifies the number of data values to be averaged for each time bucket before the acquisition is considered complete for that time bucket.

### NOTE

The :MTEST:AVERage:COUNt command is obsolete and is provided for backward compatibility to previous oscilloscopes. Use the :ACQuire:COUNt command (see [page 304](#)) instead.

**Query Syntax** :MTEST:AVERage:COUNt?

The :MTEST:AVERage:COUNt? query returns the currently selected count value.

**Return Format** <count><NL>

<count> ::= an integer from 2 to 65536 in NR1 format

**See Also**

- "[Introduction to :MTEST Commands](#)" on page 719
- "[":MTEST:AVERage"](#) on page 1589

## :MTEST:LOAD

 (see [page 1666](#))

**Command Syntax** :MTEST:LOAD "<filename>"

The :MTEST:LOAD command loads the specified mask file.

The <filename> parameter is an MS-DOS compatible name of the file, a maximum of 254 characters long (including the path name, if used).

### NOTE

The :MTEST:LOAD command is obsolete and is provided for backward compatibility to previous oscilloscopes. Use the :RECall:MASK[:START] command (see [page 868](#)) instead.

### See Also

- "[Introduction to :MTEST Commands](#)" on page 719
- "[":MTEST:AMASK:{SAVE | STORe}](#)" on page 1588

## :MTEST:RUMode

 (see [page 1666](#))

**Command Syntax**

```
:MTEST:RUMode {FORever | TIME,<seconds> | {WAVeforms,<wfm_count>}}

<seconds> ::= from 1 to 86400 in NR3 format

<wfm_count> ::= number of waveforms in NR1 format
                  from 1 to 1,000,000,000
```

The :MTEST:RUMode command determines the termination conditions for the mask test. The choices are FORever, TIME, or WAVeforms.

- FORever – runs the Mask Test until the test is turned off.
- TIME – sets the amount of time in seconds that a mask test will run before it terminates. The <seconds> parameter is a real number from 1 to 86400 seconds.
- WAVeforms – sets the maximum number of waveforms that are required before the mask test terminates. The <wfm\_count> parameter indicates the number of waveforms that are to be acquired; it is an integer from 1 to 1,000,000,000.

### NOTE

The :MTEST:RUMode command is obsolete and is provided for backward compatibility to previous oscilloscopes. Use the :MTEST:RMODe command (see [page 736](#)) instead.

**Query Syntax**

`:MTEST:RUMode?`

The :MTEST:RUMode? query returns the currently selected termination condition and value.

**Return Format**

```
{FOR | TIME,<seconds> | {WAV,<wfm_count>} }<NL>

<seconds> ::= from 1 to 86400 in NR3 format

<wfm_count> ::= number of waveforms in NR1 format
                  from 1 to 1,000,000,000
```

**See Also**

- "[Introduction to :MTEST Commands](#)" on page 719
- "[":MTEST:RUMode:SOFailure](#)" on page 1593

## :MTEST:RUMode:SOFailure

 (see [page 1666](#))

**Command Syntax**

```
:MTEST:RUMode:SOFailure <on_off>
<on_off> ::= {{1 | ON} | {0 | OFF}}
```

The :MTEST:RUMode:SOFailure command enables or disables the Stop On Failure run until criteria. When a mask test is run and a mask violation is detected, the mask test is stopped and the acquisition system is stopped.

### NOTE

The :MTEST:RUMode:SOFailure command is obsolete and is provided for backward compatibility to previous oscilloscopes. Use the :MTEST:RMODE:FACTION:STOP command (see [page 740](#)) instead.

**Query Syntax**

```
:MTEST:RUMode:SOFailure?
```

The :MTEST:RUMode:SOFailure? query returns the current state of the Stop on Failure control.

**Return Format**

```
<on_off><NL>
```

```
<on_off> ::= {1 | 0}
```

**See Also**

- "[Introduction to :MTEST Commands](#)" on page 719
- "[":MTEST:RUMode"](#) on page 1592

## :MTEST:{STARt | STOP}

 (see [page 1666](#))

**Command Syntax** :MTEST:{START | STOP}

The :MTEST:{STARt | STOP} command starts or stops the acquisition system.

### NOTE

The :MTEST:STARt and :MTEST:STOP commands are obsolete and are provided for backward compatibility to previous oscilloscopes. Use the :RUN command (see [page 292](#)) and :STOP command (see [page 296](#)) instead.

**See Also** · ["Introduction to :MTEST Commands"](#) on page 719

## :MTEST:TRIGger:SOURce

 (see [page 1666](#))

**Command Syntax** :MTEST:TRIGger:SOURce <source>

<source> ::= CHANnel<n>

<n> ::= 1 to (# analog channels) in NR1 format

The :MTEST:TRIGger:SOURce command sets the channel to use as the trigger.

### NOTE

The :MTEST:TRIGger:SOURce command is obsolete and is provided for backward compatibility to previous oscilloscopes. Use the trigger source commands (see [page 1349](#)) instead.

**Query Syntax** :MTEST:TRIGger:SOURce?

The :MTEST:TRIGger:SOURce? query returns the currently selected trigger source.

**Return Format** <source> ::= CHAN<n>

<n> ::= 1 to (# analog channels) in NR1 format

**See Also** • "Introduction to :MTEST Commands" on page 719

## :PRINt?

**O** (see [page 1666](#))

**Query Syntax**

```
:PRINt? [<options>]
<options> ::= [<print option>] [,...<print option>]
<print option> ::= {COLor | GRAYscale | BMP8bit | BMP}
```

The :PRINt? query pulls image data back over the bus for storage.

**NOTE**

The :PRINt command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :DISPLAY:DATA command (see [page 422](#)) instead.

Print Option	:PRINt command	:PRINt? query	Query Default
COLor	Sets palette=COLor		
GRAYscale	Sets palette=GRAYscale		palette=COLor
PRINter0,1	Causes the USB printer #0,1 to be selected as destination (if connected)	Not used	N/A
BMP8bit	Sets print format to 8-bit BMP	Selects 8-bit BMP formatting for query	N/A
BMP	Sets print format to BMP	Selects BMP formatting for query	N/A
FACTors	Selects outputting of additional settings information for :PRINT	Not used	N/A
NOFACTors	Deselects outputting of additional settings information for :PRINT	Not used	N/A

Old Print Option:	Is Now:
Hires	COLor
Lores	GRAYscale
PARallel	PRINter0
DISK	invalid
PCL	invalid

**NOTE**

The PRINt? query is not a core command.

---

**See Also**

- "[Introduction to Root \(:\)](#) Commands" on page 258
- "[Introduction to :HARDcopy Commands](#)" on page 542
- "[:HARDcopy:FACTors](#)" on page 546
- "[:HARDcopy:GRAYscale](#)" on page 1571
- "[:DISPlay:DATA](#)" on page 422

**:SAVE:IMAGe:AREA****O** (see [page 1666](#))**Query Syntax** `:SAVE:IMAGe:AREA?`

The `:SAVE:IMAGe:AREA?` query returns the selected image area.

When saving images, this query returns SCR (screen). When saving setups or waveform data, this query returns GRAT (graticule) even though graticule images are not saved.

**Return Format** `<area><NL>``<area> ::= {GRAT | SCR}`**See Also**

- ["Introduction to :SAVE Commands"](#) on page 876
- [":SAVE:IMAGe\[:STARt\]"](#) on page 880
- [":SAVE:IMAGe:FACTors"](#) on page 881
- [":SAVE:IMAGe:FORMAT"](#) on page 882
- [":SAVE:IMAGe:INKSaver"](#) on page 883
- [":SAVE:IMAGe:PALETTE"](#) on page 884

## :SBUS<n>:LIN:SIGNAl:DEFinition

**0** (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:LIN:SIGNAl:DEFinition <value>`  
`<value> ::= {LIN | RX | TX}`

The :SBUS<n>:LIN:SIGNAl:DEFinition command sets the LIN signal type. These signals can be set to:

Dominant low signals:

- LIN – the actual LIN single-end bus signal line.
- RX – the Receive signal from the LIN bus transceiver.
- TX – the Transmit signal to the LIN bus transceiver.

### NOTE

This command is available, but the only legal value is LIN.

**Query Syntax**    `:SBUS<n>:LIN:SIGNAl:DEFinition?`

The :SBUS<n>:LIN:SIGNAl:DEFinition? query returns the current LIN signal type.

**Return Format**    `<value><NL>`  
`<value> ::= LIN`

**See Also**

- "[Introduction to :TRIGger Commands](#)" on page 1349
- "[:TRIGger:MODE](#)" on page 1362
- "[:SBUS<n>:LIN:SIGNAl:BAUDrate](#)" on page 1030
- "[:SBUS<n>:LIN:SOURce](#)" on page 1031

## :SBUS<n>:SPI:SOURce:DATA

 (see [page 1666](#))

**Command Syntax**    `:SBUS<n>:SPI:SOURce:DATA <source>`

```

<source> ::= {CHANnel<n> | EXTernal} for the DSO models
<source> ::= {CHANnel<n> | DIGital<d>} for the MSO models
<n> ::= 1 to (# analog channels) in NR1 format
<d> ::= 0 to (# digital channels - 1) in NR1 format

```

The :SBUS<n>:SPI:SOURce:DATA command sets the source for the SPI serial MOSI data.

This command is the same as the :SBUS<n>:SPI:SOURce:MOSI command.

**Query Syntax**    `:SBUS<n>:SPI:SOURce:DATA?`

The :SBUS<n>:SPI:SOURce:DATA? query returns the current source for the SPI serial MOSI data.

**Return Format**    `<source><NL>`

- See Also**
- "[Introduction to :TRIGger Commands](#)" on page 1349
  - "[":SBUS<n>:SPI:SOURce:MOSI](#)" on page 1135
  - "[":SBUS<n>:SPI:SOURce:MISO](#)" on page 1134
  - "[":SBUS<n>:SPI:SOURce:CLOCK](#)" on page 1132
  - "[":SBUS<n>:SPI:SOURce:FRAMe](#)" on page 1133
  - "[":SBUS<n>:SPI:TRIGger:PATTERn:MISO:DATA](#)" on page 1136
  - "[":SBUS<n>:SPI:TRIGger:PATTERn:MOSI:DATA](#)" on page 1138
  - "[":SBUS<n>:SPI:TRIGger:PATTERn:MISO:WIDTh](#)" on page 1137
  - "[":SBUS<n>:SPI:TRIGger:PATTERn:MOSI:WIDTh](#)" on page 1139

## :SYSTem:MENU

 (see [page 1666](#))

**Command Syntax** :SYSTem:MENU <menu>

<menu> ::= {MASK | MEASure | SEGmented | LISTer | POWer}

The :SYSTem:MENU command changes the front panel softkey menu.

## :TIMEbase:DElay

**0** (see [page 1666](#))

**Command Syntax** :TIMEbase:DElay <delay\_value>  
 <delay\_value> ::= time in seconds from trigger to the delay reference point on the screen.

The valid range for delay settings depends on the time/division setting for the main time base.

The :TIMEbase:DElay command sets the main time base delay. This delay is the time between the trigger event and the delay reference point on the screen. The delay reference point is set with the :TIMEbase:REFerence command (see [page 1342](#)).

### NOTE

The :TIMEbase:DElay command is obsolete and is provided for backward compatibility to previous oscilloscopes. Use the :TIMEbase:POSition command (see [page 1340](#)) instead.

**Query Syntax** :TIMEbase:DElay?

The :TIMEbase:DElay query returns the current delay value.

**Return Format** <delay\_value><NL>

<delay\_value> ::= time from trigger to display reference in seconds in NR3 format.

### Example Code

```
' TIMEBASE_DELAY - Sets the time base delay. This delay
' is the internal time between the trigger event and the
' onscreen delay reference point.

' Set time base delay to 0.0.
myScope.WriteString ":TIMEBASE:DELAY 0.0"
```

See complete example programs at: [Chapter 46](#), “Programming Examples,” starting on page 1675

## :TRIGger:THreshold

**O** (see [page 1666](#))

**Command Syntax**

```
:TRIGger:THreshold <channel group>, <threshold type> [, <value>]
<channel group> ::= {POD1 | POD2}
<threshold type> ::= {CMOS | ECL | TTL | USERdef}
<value> ::= voltage for USERdef (floating-point number) [Volt type]
[Volt type] ::= {V | mV | uV}
```

The :TRIGger:THreshold command sets the threshold (trigger level) for a pod of 8 digital channels (either digital channels 0 through 7 or 8 through 15). The threshold can be set to a predefined value or to a user-defined value. For the predefined value, the voltage parameter is not required.

### NOTE

This command is only available on the MSO models.

### NOTE

The :TRIGger:THreshold command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :POD<n>:THreshold command (see [page 755](#)), :DIGital<d>:THreshold command (see [page 409](#)), or :TRIGger[:EDGE]:LEVel command (see [page 1380](#)).

### Query Syntax

```
:TRIGger:THreshold? <channel group>
```

The :TRIGger:THreshold? query returns the voltage and threshold text for analog channel 1 or 2, or POD1 or POD2.

### Return Format

```
<threshold type> [, <value>]<NL>
<threshold type> ::= {CMOS | ECL | TTL | USER}
CMOS ::= 2.5V
TTL ::= 1.5V
ECL ::= -1.3V
USERdef ::= range from -8.0V to +8.0V.
<value> ::= voltage for USERdef (a floating-point number in NR1.
```

## :TRIGger:TV:TMode

**0** (see [page 1666](#))

### Command Syntax

```
:TRIGger:TV:TMode <mode>
<mode> ::= {FIEld1 | FIEld2 | AFIElds | ALINes | LINE | VERTical
             | LFIeld1 | LFIeld2 | LALTernate | LVERtical}
```

The :TRIGger:TV:MODE command selects the TV trigger mode and field. The LVERtical parameter is only available when :TRIGger:TV:STANDARD is GENeric. The LALTernate parameter is not available when :TRIGger:TV:STANDARD is GENeric (see [page 1435](#)).

Old forms for <mode> are accepted:

<mode>	Old Forms Accepted
FIEld1	F1
FIEld2	F2
AFIEld	ALLFields, ALLFLDS
ALINes	ALLLines
LFIeld1	LINEF1, LINEFIELD1
LFIeld2	LINEF2, LINEFIELD2
LALTernate	LINEAlt
LVERtical	LINEVert

### NOTE

The :TRIGger:TV:TMODE command is an obsolete command provided for compatibility to previous oscilloscopes. Use the :TRIGger:TV:MODE command (see [page 1432](#)) instead.

### Query Syntax

```
:TRIGger:TV:TMODE?
```

The :TRIGger:TV:TMODE? query returns the TV trigger mode.

### Return Format

```
<value><NL>
```

```
<value> ::= {FIE1 | FIE2 | AFI | ALIN | LINE | VERT | LFI1 | LFI2
             | LALT | LVER}
```

## 42 Error Messages

-440, Query UNTERMINATED after indefinite response

-430, Query DEADLOCKED

-420, Query UNTERMINATED

-410, Query INTERRUPTED

-400, Query error

-340, Calibration failed

-330, Self-test failed

-321, Out of memory

-320, Storage fault

-315, Configuration memory lost

-314, Save/recall memory lost

-313, Calibration memory lost

-311, Memory error

-310, System error

-300, Device specific error

-278, Macro header not found

-277, Macro redefinition not allowed

-276, Macro recursion error

-273, Illegal macro label

-272, Macro execution error

-258, Media protected

-257, File name error

-256, File name not found

-255, Directory full

-254, Media full

-253, Corrupt media

-252, Missing media

-251, Missing mass storage

-250, Mass storage error

-241, Hardware missing

This message can occur when a feature is unavailable or unlicensed.

-240, Hardware error

-231, Data questionable

-230, Data corrupt or stale

-224, Illegal parameter value

-223, Too much data

-222, Data out of range

-221, Settings conflict

-220, Parameter error

-200, Execution error

-183, Invalid inside macro definition

-181, Invalid outside macro definition

-178, Expression data not allowed

-171, Invalid expression

-170, Expression error

-168, Block data not allowed

-161, Invalid block data

-158, String data not allowed

-151, Invalid string data

-150, String data error

-148, Character data not allowed

-138, Suffix not allowed

-134, Suffix too long

-131, Invalid suffix

-128, Numeric data not allowed

-124, Too many digits

-123, Exponent too large

-121, Invalid character in number

-120, Numeric data error

-114, Header suffix out of range

-113, Undefined header

-112, Program mnemonic too long

-109, Missing parameter

-108, Parameter not allowed

-105, GET not allowed

-104, Data type error

-103, Invalid separator

-102, Syntax error

-101, Invalid character

-100, Command error

+10, Software Fault Occurred

+100, File Exists

+101, End-Of-File Found

+102, Read Error

+103, Write Error

**+104, Illegal Operation**

**+105, Print Canceled**

**+106, Print Initialization Failed**

**+107, Invalid Trace File**

**+108, Compression Error**

**+109, No Data For Operation**

A remote operation wants some information, but there is no information available. For example, you may request a stored TIFF image using the :DISPLAY:DATA? query, but there may be no image stored.

**+112, Unknown File Type**

**+113, Directory Not Supported**




# 43 Status Reporting

- Status Reporting Data Structures / 1615
- Status Byte Register (STB) / 1618
- Service Request Enable Register (SRE) / 1620
- Trigger Event Register (TER) / 1621
- Output Queue / 1622
- Message Queue / 1623
- (Standard) Event Status Register (ESR) / 1624
- (Standard) Event Status Enable Register (ESE) / 1625
- Error Queue / 1626
- Operation Status Event Register (:OPERegister[:EVENT]) / 1627
- Operation Status Condition Register (:OPERegister:CONDition) / 1629
- Arm Event Register (AER) / 1630
- Overload Event Register (:OVLRegister) / 1631
- Hardware Event Event Register (:HWERegister[:EVENT]) / 1632
- Hardware Event Condition Register (:HWERegister:CONDition) / 1633
- Mask Test Event Event Register (:MTERegister[:EVENT]) / 1634
- Clearing Registers and Queues / 1635
- Status Reporting Decision Chart / 1636
- Example: Checking for Armed Status / 1637

IEEE 488.2 defines data structures, commands, and common bit definitions for status reporting (for example, the Status Byte Register and the Standard Event Status Register). There are also instrument-defined structures and bits (for example, the Operation Status Event Register and the Overload Event Register).

An overview of the oscilloscope's status reporting structure is shown in the following block diagram. The status reporting structure allows monitoring specified events in the oscilloscope. The ability to monitor and report these events allows determination of such things as the status of an operation, the availability and reliability of the measured data, and more.




- To monitor an event, first clear the event; then, enable the event. All of the events are cleared when you initialize the instrument.
- To allow a service request (SRQ) interrupt to an external controller, enable at least one bit in the Status Byte Register (by setting, or unmasking, the bit in the Service Request Enable register).


The Status Byte Register, the Standard Event Status Register group, and the Output Queue are defined as the Standard Status Data Structure Model in IEEE 488.2-1987.

The bits in the status byte act as summary bits for the data structures residing behind them. In the case of queues, the summary bit is set if the queue is not empty. For registers, the summary bit is set if any enabled bit in the event register is set. The events are enabled with the corresponding event enable register. Events captured by an event register remain set until the register is read or cleared. Registers are read with their associated commands. The \*CLS command clears all event registers and all queues except the output queue. If you send \*CLS immediately after a program message terminator, the output queue is also cleared.

## Status Reporting Data Structures

The following figure shows how the status register bits are masked and logically OR'ed to generate service requests (SRQ) on particular events.





The status register bits are described in more detail in the following tables:

- [Table 85](#)
- [Table 83](#)
- [Table 93](#)
- [Table 94](#)
- [Table 96](#)
- [Table 88](#)
- [Table 89](#)
- [Table 91](#)

The status registers picture above shows how the different status reporting data structures work together. To make it possible for any of the Standard Event Status Register bits to generate a summary bit, the bits must be enabled. These bits are enabled by using the \*ESE common command to set the corresponding bit in the Standard Event Status Enable Register.

To generate a service request (SRQ) interrupt to an external controller, at least one bit in the Status Byte Register must be enabled. These bits are enabled by using the \*SRE common command to set the corresponding bit in the Service Request Enable Register. These enabled bits can then set RQS and MSS (bit 6) in the Status Byte Register.

## Status Byte Register (STB)

The Status Byte Register is the summary-level register in the status reporting structure. It contains summary bits that monitor activity in the other status registers and queues. The Status Byte Register is a live register. That is, its summary bits are set and cleared by the presence and absence of a summary bit from other event registers or queues.

If the Status Byte Register is to be used with the Service Request Enable Register to set bit 6 (RQS/MSS) and to generate an SRQ, at least one of the summary bits must be enabled, then set. Also, event bits in all other status registers must be specifically enabled to generate the summary bit that sets the associated summary bit in the Status Byte Register.

The Status Byte Register can be read using either the \*STB? Common Command or the programming interface serial poll command. Both commands return the decimal-weighted sum of all set bits in the register. The difference between the two methods is that the serial poll command reads bit 6 as the Request Service (RQS) bit and clears the bit which clears the SRQ interrupt. The \*STB? command reads bit 6 as the Master Summary Status (MSS) and does not clear the bit or have any affect on the SRQ interrupt. The value returned is the total bit weights of all of the bits that are set at the present time.

The use of bit 6 can be confusing. This bit was defined to cover all possible computer interfaces, including a computer that could not do a serial poll. The important point to remember is that, if you are using an SRQ interrupt to an external computer, the serial poll command clears bit 6. Clearing bit 6 allows the oscilloscope to generate another SRQ interrupt when another enabled event occurs.

No other bits in the Status Byte Register are cleared by either the \*STB? query or the serial poll, except the Message Available bit (bit 4). If there are no other messages in the Output Queue, bit 4 (MAV) can be cleared as a result of reading the response to the \*STB? command.

If bit 4 (weight = 16) and bit 5 (weight = 32) are set, the program prints the sum of the two weights. Since these bits were not enabled to generate an SRQ, bit 6 (weight = 64) is not set.

The following example uses the \*STB? query to read the contents of the oscilloscope's Status Byte Register.

```
myScope.WriteString "*STB?"
varQueryResult = myScope.ReadNumber
MsgBox "Status Byte Register, Read: 0x" + Hex(varQueryResult)
```

The next program prints 0xD1 and clears bit 6 (RQS) and bit 4 (MAV) of the Status Byte Register. The difference in the output value between this example and the previous one is the value of bit 6 (weight = 64). Bit 6 is set when the first enabled summary bit is set and is cleared when the Status Byte Register is read by the serial poll command.

**Example** The following example uses the resource session object's ReadSTB method to read the contents of the oscilloscope's Status Byte Register.

```
varQueryResult = myScope.IO.ReadSTB  
MsgBox "Status Byte Register, Serial Poll: 0x" + Hex(varQueryResult)
```

**NOTE**

**Use Serial Polling to Read Status Byte Register.** Serial polling is the preferred method to read the contents of the Status Byte Register because it resets bit 6 and allows the next enabled event that occurs to generate a new SRQ interrupt.

**See Also** • ["\\*STB \(Read Status Byte\)" on page 250](#)

## Service Request Enable Register (SRE)

Setting the Service Request Enable Register bits enable corresponding bits in the Status Byte Register. These enabled bits can then set RQS and MSS (bit 6) in the Status Byte Register.

Bits are set in the Service Request Enable Register using the \*SRE command and the bits that are set are read with the \*SRE? query.

- Example** The following example sets bit 4 (MAV) and bit 5 (ESB) in the Service Request Enable Register.

```
myScope.WriteString "*SRE " + CStr(CInt("&H30"))
```

This example uses the decimal parameter value of 48, the string returned by CStr(CInt("&H30")), to enable the oscilloscope to generate an SRQ interrupt under the following conditions:

- When one or more bytes in the Output Queue set bit 4 (MAV).
- When an enabled event in the Standard Event Status Register generates a summary bit that sets bit 5 (ESB).

- See Also** • ["\\*SRE \(Service Request Enable\)"](#) on page 248

## Trigger Event Register (TER)

This register sets the TRG bit in the status byte when a trigger event occurs.

The TER event register stays set until it is cleared by reading the register or using the \*CLS command. If your application needs to detect multiple triggers, the TER event register must be cleared after each one.

If you are using the Service Request to interrupt a program or controller operation, you must clear the event register each time the trigger bit is set.

**See Also** • [":TER \(Trigger Event Register\)" on page 297](#)

## Output Queue

The output queue stores the oscilloscope-to-controller responses that are generated by certain instrument commands and queries. The output queue generates the Message Available summary bit when the output queue contains one or more bytes. This summary bit sets the MAV bit (bit 4) in the Status Byte Register.

When using the Keysight VISA COM library, the output queue may be read with the FormattedIO488 object's ReadString, ReadNumber, ReadList, or ReadIEEEBlock methods.

## Message Queue

The message queue contains the text of the last message written to the advisory line on the screen of the oscilloscope. The length of the oscilloscope's message queue is 1. Note that messages sent with the :SYSTem:DSP command do not set the MSG status bit in the Status Byte Register.

## (Standard) Event Status Register (ESR)

The (Standard) Event Status Register (ESR) monitors the following oscilloscope status events:

- PON - Power On
- URQ - User Request
- CME - Command Error
- EXE - Execution Error
- DDE - Device Dependent Error
- QYE - Query Error
- RQC - Request Control
- OPC - Operation Complete

When one of these events occur, the event sets the corresponding bit in the register. If the bits are enabled in the Standard Event Status Enable Register, the bits set in this register generate a summary bit to set bit 5 (ESB) in the Status Byte Register.

You can read the contents of the Standard Event Status Register and clear the register by sending the \*ESR? query. The value returned is the total bit weights of all of the bits that are set at the present time.

**Example** The following example uses the \*ESR query to read the contents of the Standard Event Status Register.

```
myScope.WriteString "*ESR?"  
varQueryResult = myScope.ReadNumber  
MsgBox "Standard Event Status Register: 0x" + Hex(varQueryResult)
```

If bit 4 (weight = 16) and bit 5 (weight = 32) are set, the program prints the sum of the two weights.

**See Also** • ["\\*ESR \(Standard Event Status Register\)"](#) on page 236

## (Standard) Event Status Enable Register (ESE)

To allow any of the (Standard) Event Status Register (ESR) bits to generate a summary bit, you must first enable that bit. Enable the bit by using the \*ESE (Event Status Enable) common command to set the corresponding bit in the (Standard) Event Status Enable Register (ESE).

Set bits are read with the \*ESE? query.

- Example** Suppose your application requires an interrupt whenever any type of error occurs. The error related bits in the (Standard) Event Status Register are bits 2 through 5 (hexadecimal value 0x3C). Therefore, you can enable any of these bits to generate the summary bit by sending:

```
myScope.WriteString "*ESE " + CStr(CInt("&H3C"))
```

Whenever an error occurs, it sets one of these bits in the (Standard) Event Status Register. Because all the error related bits are enabled, a summary bit is generated to set bit 5 (ESB) in the Status Byte Register.

If bit 5 (ESB) in the Status Byte Register is enabled (via the \*SRE command), an SRQ service request interrupt is sent to the controller PC.

### NOTE

**Disabled (Standard) Event Status Register bits respond but do not generate a summary bit.** (Standard) Event Status Register bits that are not enabled still respond to their corresponding conditions (that is, they are set if the corresponding event occurs). However, because they are not enabled, they do not generate a summary bit to the Status Byte Register.

- 
- See Also** • ["\\*ESE \(Standard Event Status Enable\)"](#) on page 234

## Error Queue

As errors are detected, they are placed in an error queue. This queue is first in, first out. If the error queue overflows, the last error in the queue is replaced with error 350, Queue overflow. Any time the queue overflows, the least recent errors remain in the queue, and the most recent error is discarded. The length of the oscilloscope's error queue is 30 (29 positions for the error messages, and 1 position for the Queue overflow message).

The error queue is read with the :SYSTem:ERRor? query. Executing this query reads and removes the oldest error from the head of the queue, which opens a position at the tail of the queue for a new error. When all the errors have been read from the queue, subsequent error queries return "0, No error".

The error queue is cleared when:

- the instrument is powered up,
- the instrument receives the \*CLS common command, or
- the last item is read from the error queue.

## Operation Status Event Register (:OPERegister[:EVENT])

The Operation Status Event Register register hosts these bits:

Name	Location	Description
RUN bit	bit 3	Is set whenever the instrument goes from a stop state to a single or running state.
RUI Enab bit	bit 4	<p>The remote user interface has gone from a disabled state to an enabled state.</p> <p>The front-panel graphical user interface can disable most of the remote interface, including the *OPC syntax, for example when:</p> <ul style="list-style-type: none"> <li>▪ a modal dialog box is open</li> <li>▪ the user is being prompted</li> <li>▪ all segments are being analyzed</li> <li>▪ there is a channel overload</li> <li>▪ certain compliance applications are running</li> </ul> <p>When disabled, commands or queries are accepted, but "settings conflict" errors are returned. The status model is the only part of the remote user interface that is enabled.</p> <p>To determine when the remote interface is re-enabled, you can read this bit or wait for the event that gets generated when its status goes from disabled to enabled.</p>
WAIT TRIG bit	bit 5	Is set by the Trigger Armed Event Register and indicates that the trigger is armed.
MTE bit	bit 9	Comes from the Mask Test Event Registers.
OVLR bit	bit 11	Is set whenever a 50Ω input overload occurs.
HWE bit	bit 12	Comes from the Hardware Event Registers.
IOC bit	bit 13	Is set when any IO operation completes. IO operations are any remote data request using any interface (USB, LAN, or GPIB). For example, if you connect to an oscilloscope using the USB interface and then request waveform data, the IOC bit will be set when the IO operation completes.
IOF bit	bit 14	Is set only when something causes the IO operation to fail, like disconnecting a USB device or interrupting the operation from the oscilloscope's front panel.

If any of these bits are set, the OPER bit (bit 7) of the Status Byte Register is set. The Operation Status Event Register is read and cleared with the :OPERRegister[:EVENT]? query. The register output is enabled or disabled using the mask value supplied with the OPEE command.

**See Also** • [":OPERRegister\[:EVENT\] \(Operation Status Event Register\)"](#) on page 283

## Operation Status Condition Register (:OPERegister:CONDITION)

The Operation Status Condition Register register hosts these bits:

Name	Location	Description
RUN bit	bit 3	Is set whenever the instrument is not stopped.
RUI Enab bit	bit 4	<p>Shows whether the remote user interface is enabled. The front-panel graphical user interface can disable most of the remote interface, including the *OPC syntax, for example when:</p> <ul style="list-style-type: none"> <li>▪ a modal dialog box is open</li> <li>▪ the user is being prompted</li> <li>▪ all segments are being analyzed</li> <li>▪ there is a channel overload</li> <li>▪ certain compliance applications are running</li> </ul> <p>When disabled, commands or queries are accepted, but "settings conflict" errors are returned. The status model is the only part of the remote user interface that is enabled.</p> <p>To determine when the remote interface is re-enabled, you can read this bit or wait for the event that gets generated when its status goes from disabled to enabled.</p>
WAIT TRIG bit	bit 5	Is set by the Trigger Armed Event Register and indicates that the trigger is armed.
MTE bit	bit 9	Comes from the Mask Test Event Registers.
OVLR bit	bit 11	Is set whenever a 50Ω input overload occurs.
HWE bit	bit 12	Comes from the Hardware Event Registers.
IOC bit	bit 13	Is set when any IO operation completes. IO operations are any remote data request using any interface (USB, LAN, or GPIB). For example, if you connect to an oscilloscope using the USB interface and then request waveform data, the IOC bit will be set when the IO operation completes.
IOF bit	bit 14	Is set only when something causes the IO operation to fail, like disconnecting a USB device or interrupting the operation from the oscilloscope's front panel.

The :OPERegister:CONDITION? query returns the value of the Operation Status Condition Register.

See Also · [":OPERegister:CONDITION \(Operation Status Condition Register\)"](#) on page 280

## Arm Event Register (AER)

This register sets bit 5 (Wait Trig bit) in the Operation Status Register and the OPER bit (bit 7) in the Status Byte Register when the instrument becomes armed.

The ARM event register stays set until it is cleared by reading the register with the AER? query or using the \*CLS command. If your application needs to detect multiple triggers, the ARM event register must be cleared after each one.

If you are using the Service Request to interrupt a program or controller operation when the trigger bit is set, then you must clear the event register after each time it has been set.

**See Also** • [":AER \(Arm Event Register\)" on page 260](#)

## Overload Event Register (:OVLRegister)

The Overload Event Register register hosts these bits:

Name	Location	Description
Channel 1 OVL	bit 0	Overload has occurred on Channel 1 input.
Channel 2 OVL	bit 1	Overload has occurred on Channel 2 input.
Channel 3 OVL	bit 2	Overload has occurred on Channel 3 input.
Channel 4 OVL	bit 3	Overload has occurred on Channel 4 input.
External Trigger OVL	bit 4	Overload has occurred on External Trigger input.
Channel 1 Fault	bit 6	Fault has occurred on Channel 1 input.
Channel 2 Fault	bit 7	Fault has occurred on Channel 2 input.
Channel 3 Fault	bit 8	Fault has occurred on Channel 3 input.
Channel 4 Fault	bit 9	Fault has occurred on Channel 4 input.
External Trigger Fault	bit 10	Fault has occurred on External Trigger input.

See Also • [":OVLRegister \(Overload Event Register\)" on page 288](#)

## Hardware Event Event Register (:HWERegister[:EVENT])

This register hosts the PLL LOCKED bit (bit 12).

- The PLL LOCKED bit (bit 12) is for internal use and is not intended for general use.

**See Also** • "[":HWERegister\[:EVENT\] \(Hardware Event Event Register\)"](#) on page 273

## Hardware Event Condition Register (:HWERegister:CONDition)

This register hosts the PLL LOCKED bit (bit 12).

- The :HWERegister:CONDition? query returns the value of the Hardware Event Condition Register.
- The PLL LOCKED bit (bit 12) is for internal use and is not intended for general use.

See Also • "[:HWERegister:CONDition \(Hardware Event Condition Register\)](#)" on page 272

## Mask Test Event Event Register (:MTERegister[:EVENT])

The Mask Test Event Event Register register hosts these bits:

Name	Location	Description
Complete	bit 0	Is set when the mask test is complete.
Fail	bit 1	Is set when there is a mask test failure.
Started	bit 8	Is set when mask testing is started.
Pass	bit 9	Is set when the mask test passes.
Auto Mask	bit 10	Is set when auto mask creation is completed.

The :MTERegister[:EVENT]? query returns the value of, and clears, the Mask Test Event Event Register.

See Also


- [":MTERegister\[:EVENT\] \(Mask Test Event Event Register\)" on page 276](#)

## Clearing Registers and Queues

The \*CLS common command clears all event registers and all queues except the output queue. If \*CLS is sent immediately after a program message terminator, the output queue is also cleared.

See Also · ["\\*CLS \(Clear Status\)" on page 233](#)

## Status Reporting Decision Chart



## Example: Checking for Armed Status

```

# -*- coding: utf-8 -*-

# ****
# This script using the Python language (http://www.python.org/) and
# the PyVISA package (http://pyvisa.readthedocs.org/) shows three
# methods to tell whether a Keysight InfiniiVision oscilloscope is
# armed.
# *****

# Import modules
# -----
import sys
import visa
import time

# Initialization constants
# -----
# Get VISA address from Keysight IO Libraries Connection Expert
VISA_ADDRESS = \
    "TCPIP0::a-mx4154a-60014.cos.is.keysight.com::inst0::INSTR"
GLOBAL_TOUT = 20000 # IO timeout in milliseconds

# =====
# Method 1: Query the Armed Event Register with :AER?
# -----
# This method reads the 1-bit Armed Event Register using the :AER?
# query.
#
# The Armed Event Register bit goes low (0) when it is read using
# :AER? or when a *CLS command is issued.
# =====
def method_1():

    # Stop the oscilloscope.
    KsInfiniiVisionX.query(":STOP;*OPC?")

    # Method 1: Initiate capture using :SINGle
    # -----
    print "Acquiring signal (Method 1, using :SINGle)...\\n"
    now = time.clock()

    # Clear all status registers before checking for new events.
    KsInfiniiVisionX.write("*CLS")

    # Because the :AER? query will not work with :DIGitize (which is
    # blocking), use the :SINGle command to start the acquisition.
    KsInfiniiVisionX.write(":SINGLE")

    # Method 1: Determine if armed using :AER? query.
    # -----
    # Define armed criteria.
    ARMED = 1

```

```

# Test for armed.
ARMED_STATUS = int(KsInfiniiVisionX.query(":AER?"))

# Wait indefinitely until armed.
while ARMED_STATUS != ARMED:
    # Check the status again after small delay.
    time.sleep(0.1)    # 100 ms delay to prevent excessive queries.
    ARMED_STATUS = int(KsInfiniiVisionX.query(":AER?"))

print "Oscilloscope is armed (method 1, using :AER? query) !"
print "It took " + str(time.clock() - now) +\
      " seconds to arm.\n"

# =====
# Method 2: Read the Status Byte
# -----
# This method reads the Status Byte register's OPER bit (bit 7) using
# the "read status byte" function in VISA, which works during blocking
# commands and can therefore be used with the :DIGITIZE command.
#
# The Status Byte bits do NOT go low (0) when the register is read.
#
# The *CLS command will clear the Status Byte bits.
#
# CAUTION: The oscilloscope's status registers are not updated until
# the :DIGITIZE completes. So, while the ARM may go true midway
# through the :DIGITIZE, it does not get reported to the status model
# until the :DIGITIZE completes, and therefore the STB does not
# reflect it as true until the :DIGITIZE completes.
# =====
def method_2():

    # Stop the oscilloscope.
    KsInfiniiVisionX.query(":STOP;*OPC?")

    # Method 2: Initiate capture using :DIGITIZE or :SINGLE
    # -----
    print "Acquiring signal (Method 2, using :DIGITIZE)...\\n"
    now = time.clock()

    # Clear all status registers before checking for new events.
    KsInfiniiVisionX.write("*CLS")

    # Mask out all bits in the Operation Status Event Register except
    # for the ARM bit.
    KsInfiniiVisionX.write(":OPEE 32")  # "Unmask" only the arm bit

    # Use the :DIGITIZE command to start the acquisition.
    KsInfiniiVisionX.write(":DIGITIZE")

    # Method 2: Determine if armed by reading the Status Byte.
    # -----
    # Define register bit masks for the Status Byte Register
    ARM_BIT = 7
    # 1 leftshift 7 = 128 (bit 7 in the Status Byte Register)

```

```

ARM_MASK = 1 << ARM_BIT

# Define armed criteria.
ARMED = 1 << ARM_BIT    # 1 leftshift 7 = 128

# Test for armed.
STATUS_BYTE = int(KsInfiniiVisionX.read_stb())
ARMED_STATUS = STATUS_BYTE & ARM_MASK
# Note that you could also do:
# ARMED_STATUS = int(KsInfiniiVisionX.query("*STB?"))
# BUT *STB? does not work with the blocking :DIGitize.

# Wait indefinitely until armed.
while ARMED_STATUS != ARMED:
    # Check the status again after small delay.
    time.sleep(0.1)    # 100 ms delay to prevent excessive queries.
    STATUS_BYTE = int(KsInfiniiVisionX.read_stb())
    ARMED_STATUS = STATUS_BYTE & ARM_MASK

print "Oscilloscope is armed (method 2, using Read STB function)!"
print "It took " + str(time.clock() - now) +\
      " seconds to arm.\n"

# =====
# Method 3: Query the Operation Status Event Register with :OPER?
# -----
# This method reads the Operation Status Event Register's Wait Trig
# bit (bit 5) using the :OPER? query.
#
# The Operation Status Event Register bits are cleared (0) when the
# register is read.
#
# Also, the Wait Trig bit does NOT go low (0) when the oscilloscope
# becomes unarmed by starting or stopping another acquisition (before
# the first one finishes) or by changing the time scale.
#
# The Wait Trig bit is cleared by a *CLS command, by reading the
# Operation Status Event Register with the :OPER? query, or by reading
# the Armed Event Register register with the :AER? query.
# =====
def method_3():

    # Stop the oscilloscope.
    KsInfiniiVisionX.query(":STOP;*OPC?")

    # Method 3: Initiate capture using :SINGLE
    # -----
    print "Acquiring signal (Method 3, using :SINGLE)...\\n"
    now = time.clock()

    # Clear all status registers before checking for new events.
    KsInfiniiVisionX.write("*CLS")

    # Because the :OPER? query will not work with :DIGITIZE (which is
    # blocking), use the :SINGLE command to start the acquisition.
    KsInfiniiVisionX.write(":SINGLE")

```

```

# Method 3: Determine if armed using :OPER? query.
# -----
# Define bit masks for the Operation Status Event Register
ARM_BIT = 5
# 1 leftshift 5 = 32 (bit 5 in the Operation Status Event
# Register)
ARM_MASK = 1 << ARM_BIT

# Define armed criteria.
ARMED = 1 << ARM_BIT    # 1 leftshift 5 = 32

# Test for armed.
STATUS_REGISTER = int(KsInfiniiVisionX.query(":OPER?"))
ARMED_STATUS = STATUS_REGISTER & ARM_MASK

# Wait indefinitely until armed.
while ARMED_STATUS != ARMED:
    # Check the status again after small delay.
    time.sleep(0.1)    # 100 ms delay to prevent excessive queries.
    STATUS_REGISTER = int(KsInfiniiVisionX.query(":OPER?"))
    ARMED_STATUS = STATUS_REGISTER & ARM_MASK

    print "Oscilloscope is armed (method 3, using :OPER? query)!"
    print "It took " + str(time.clock() - now) + \
          " seconds to arm.\n"

# =====
# Main
# =====

# Connect and initialize oscilloscope
# -----
# Define VISA Resource Manager & Install directory
rm = visa.ResourceManager('C:\\Windows\\System32\\agvisa32.dll')

# Define and open the oscilloscope using the VISA address
KsInfiniiVisionX = rm.open_resource(VISA_ADDRESS)

# Set the Global Timeout
KsInfiniiVisionX.timeout = GLOBAL_TOUT

# Clear the instrument bus
KsInfiniiVisionX.clear()

# Reset the oscilloscope.
KsInfiniiVisionX.write("*RST")

# Autoscale to set up vertical scale and trigger level on Probe Comp.
KsInfiniiVisionX.write(":CHANnel1:DISPLAY OFF")
KsInfiniiVisionX.write(":CHANnel2:DISPLAY ON")
KsInfiniiVisionX.write(":AUToscale:CHANnels DISPLAYed")
KsInfiniiVisionX.write(":AUToscale")

# Ensure a "long" time to arm (5 seconds) and not trigger immediately.
# -----

```

```
# 10 second total capture, with trigger point in the middle = 5s to arm
KsInfiniiVisionX.write(":TIMEbase:RANGE 10")
# Prevent Auto trigger.
KsInfiniiVisionX.write(":TRIGGER:SWEep NORMAl")

# Use the three methods to check whether the oscilloscope is armed.
# -----
method_1()
method_2()
method_3()

# End of Script
# -----
KsInfiniiVisionX.clear()      # Clear communications interface
KsInfiniiVisionX.close()     # Close communications interface
print "All done."
```

## Example: Waiting for IO Operation Complete

### NOTE

The IOC (IO Operation Complete) and IOF (IO Operation Failed) bits in the Operation Status Event Register identify when :WMEMory<r>:SAVE and other :SAVE and :RECall commands are completely done. To determine when a IO operation is complete, you should use these bits instead of the OPC (Operation Complete) bit in the Standard Event Status Register or the \*OPC? query.

```
# -*- coding: utf-8 -*-

# ****
# This script using the Python language (http://www.python.org/) and
# the PyVISA package (http://pyvisa.readthedocs.org/) shows how to
# wait for IO operation completion in a Keysight InfiniiVision
# oscilloscope.
# *****

# Import modules
# -----
import sys
import visa
import time

# Initialization constants
# -----
# Get VISA address from Keysight IO Libraries Connection Expert
VISA_ADDRESS = \
    "TCPIPO::a-mx4154a-60014.cos.is.keysight.com::inst0::INSTR"
GLOBAL_TOUT = 20000 # IO timeout in milliseconds

# =====
# Check for IO Operation Complete using :OPER? query.
# -----
# This method reads the Operation Status Register's IOC bit
# (bit 13) using the :OPER? query.
#
# The Operation Status Event Register bits are cleared (0) when the
# register is read.
#
# All status bits are cleared by a *CLS command.
# =====
def wait_io_operation():

    # -----
    now = time.clock()
    # Define bit masks for the Operation Status Event Register
    IOC_BIT = 13
    # 1 leftshift 13 = 8192 (bit 13 in the Operation Status Event
    # Register)
    IOC_MASK = 1 << IOC_BIT

    # Define IO complete criteria.
```

```

IO_COMPLETE = 1 << IOC_BIT    # 1 leftshift 13 = 8192

# Test for armed.
STATUS_REGISTER = int(KsInfiniiVisionX.query(":OPER?"))
IO_COMPLETE_STATUS = STATUS_REGISTER & IOC_MASK

# Wait indefinitely until armed.
while IO_COMPLETE_STATUS != IO_COMPLETE:
    # Check the status again after small delay.
    time.sleep(0.1)    # 100 ms delay to prevent excessive queries.
    STATUS_REGISTER = int(KsInfiniiVisionX.query(":OPER?"))
    IO_COMPLETE_STATUS = STATUS_REGISTER & IOC_MASK

    time_in_seconds = str(time.clock() - now)
    print "IO Operation Complete (from :OPER? query)."
    print "It took %s seconds for IO operation to complete.\n" % \
        time_in_seconds

# =====
# Main
# =====

# Connect and initialize oscilloscope
# -----
# Define VISA Resource Manager & Install directory
rm = visa.ResourceManager('C:\\Windows\\System32\\agvisa32.dll')

# Define and open the oscilloscope using the VISA address
KsInfiniiVisionX = rm.open_resource(VISA_ADDRESS)

# Set the Global Timeout
KsInfiniiVisionX.timeout = GLOBAL_TOUT

# Clear the instrument bus
KsInfiniiVisionX.clear()

# Reset the oscilloscope.
# KsInfiniiVisionX.write("*RST")
# Or comment out to use the current oscilloscope setup.

# Autoscale to set up vertical scale and trigger level on channels 1 and
# 2.
KsInfiniiVisionX.write(":CHANnel1:DISPlay ON")
KsInfiniiVisionX.write(":CHANnel2:DISPlay ON")
KsInfiniiVisionX.write(":AUToscale:CHANnels DISPlayed")
KsInfiniiVisionX.write(":AUToscale")

# Between :WMMemory<r>:SAVE commands, wait for IO complete.
# -----
# Clear all status registers before checking for new events.
KsInfiniiVisionX.write("*CLS")

KsInfiniiVisionX.write(":WMMemory1:SAVE CHANnel1")
wait_io_operation()
KsInfiniiVisionX.write(":WMMemory2:SAVE CHANnel2")
wait_io_operation()

```

## 43 Status Reporting

```
# End of Script
#
# -----
KsInfiniiVisionX.clear()      # Clear communications interface
KsInfiniiVisionX.close()     # Close communications interface
print "All done."
```

# 44 Synchronizing Acquisitions

Synchronization in the Programming Flow /	1646
Blocking Synchronization /	1647
Polling Synchronization With Timeout /	1648
Synchronizing with a Single-Shot Device Under Test (DUT) /	1650
Synchronization with an Averaging Acquisition /	1652
Example: Blocking and Polling Synchronization /	1654

When remotely controlling an oscilloscope with programming commands, it is often necessary to know when the oscilloscope has finished the previous operation and is ready for the next command. The most common example is when an acquisition is started using the :DIGITIZE, :RUN, or :SINGLE commands. Before a measurement result can be queried, the acquisition must complete. Too often fixed delays are used to accomplish this wait, but fixed delays often use excessive time or the time may not be long enough. A better solution is to use synchronous commands and status to know when the oscilloscope is ready for the next request.

## Synchronization in the Programming Flow

Most remote programming follows these three general steps:

- 1 Set up the oscilloscope and device under test (see [page 1646](#)).
- 2 Acquire a waveform (see [page 1646](#)).
- 3 Retrieve results (see [page 1646](#)).

### Set Up the Oscilloscope

Before making changes to the oscilloscope setup, it is best to make sure it is stopped using the :STOP command followed by the \*OPC? query.

#### NOTE

It is not necessary to use \*OPC?, hard coded waits, or status checking when setting up the oscilloscope. After the oscilloscope is configured, it is ready for an acquisition.

### Acquire a Waveform

When acquiring a waveform there are two possible methods used to wait for the acquisition to complete. These methods are blocking and polling. The table below details when each method should be chosen and why.

	Blocking Wait	Polling Wait
Use When	You know the oscilloscope <i>will</i> trigger based on the oscilloscope setup and device under test.	You know the oscilloscope <i>may or may not</i> trigger on the oscilloscope setup and device under test.
Advantages	No need for polling. Fastest method.	Remote interface will not timeout No need for device clear if no trigger.
Disadvantages	Remote interface may timeout. Device clear only way to get control of oscilloscope if there is no trigger.	Slower method. Requires polling loop. Requires known maximum wait time.
Implementation Details	See " <a href="#">Blocking Synchronization</a> " on page 1647.	See " <a href="#">Polling Synchronization With Timeout</a> " on page 1648.

### Retrieve Results

Once the acquisition is complete, it is safe to retrieve measurements and statistics.

## Blocking Synchronization

Use the :DIGitize command to start the acquisition. This blocks subsequent queries until the acquisition and processing is complete. For example:

```

'
' Synchronizing acquisition using blocking.
' =====

Option Explicit

Public myMgr As VisaComLib.ResourceManager
Public myScope As VisaComLib.FormattedIO488
Public varQueryResult As Variant
Public strQueryResult As String

Sub Main()

    On Error GoTo VisaComError

    ' Create the VISA COM I/O resource.
    Set myMgr = New VisaComLib.ResourceManager
    Set myScope = New VisaComLib.FormattedIO488
    Set myScope.IO = myMgr.Open("TCPIP0::130.29.69.12::inst0::INSTR")
    myScope.IO.Clear      ' Clear the interface.

    ' Set up.
    ' -----
    myScope.WriteString ":TRIGger:MODE EDGE"
    myScope.WriteString ":TRIGger:EDGE:LEVel 2"
    myScope.WriteString ":TIMEbase:SCALe 5e-8"

    ' Acquire.
    ' -----
    myScope.WriteString ":DIGitize"

    ' Get results.
    ' -----
    myScope.WriteString ":MEASure:RISetime"
    myScope.WriteString ":MEASure:RISetime?"
    varQueryResult = myScope.ReadNumber      ' Read risetime.
    Debug.Print "Risetime: " + _
               FormatNumber(varQueryResult * 1000000000, 1) + " ns"

    Exit Sub

VisaComError:
    MsgBox "VISA COM Error:" + vbCrLf + Err.Description

End Sub

```

## Polling Synchronization With Timeout

This example requires a timeout value so the operation can abort if an acquisition does not occur within the timeout period:

```

'
' Synchronizing acquisition using polling.
' =====

Option Explicit

Public myMgr As VisaComLib.ResourceManager
Public myScope As VisaComLib.FormattedIO488
Public varQueryResult As Variant
Public strQueryResult As String

Private Declare Sub Sleep Lib "kernel32" (ByVal dwMilliseconds As Long)

Sub Main()

    On Error GoTo VisaComError

    ' Create the VISA COM I/O resource.
    Set myMgr = New VisaComLib.ResourceManager
    Set myScope = New VisaComLib.FormattedIO488
    Set myScope.IO = myMgr.Open("TCPIP0::130.29.69.12::inst0::INSTR")
    myScope.IO.Clear      ' Clear the interface.

    ' Set up.
    ' -----
    ' Set up the trigger and horizontal scale.
    myScope.WriteString ":TRIGger:MODE EDGE"
    myScope.WriteString ":TRIGger:EDGE:LEVel 2"
    myScope.WriteString ":TIMEbase:SCALE 5e-8"

    ' Stop acquisitions and wait for the operation to complete.
    myScope.WriteString ":STOP"
    myScope.WriteString "*OPC?"
    strQueryResult = myScope.ReadString

    ' Acquire.
    ' -----
    ' Start a single acquisition.
    myScope.WriteString ":SINGLE"

    ' Oscilloscope is armed and ready, enable DUT here.
    Debug.Print "Oscilloscope is armed and ready, enable DUT."

    ' Look for RUN bit = stopped (acquisition complete).
    Dim lngTimeout As Long      ' Max millisecs to wait for single-shot.
    Dim lngElapsed As Long
    lngTimeout = 10000      ' 10 seconds.
    lngElapsed = 0

    Do While lngElapsed <= lngTimeout

```

```
myScope.WriteString ":OPERegister:CONDITION?"
varQueryResult = myScope.ReadNumber
' Mask RUN bit (bit 3, &H8).
If (varQueryResult And &H8) = 0 Then
    Exit Do
Else
    Sleep 100      ' Small wait to prevent excessive queries.
    lngElapsed = lngElapsed + 100
End If
Loop

' Get results.
' -----
If lngElapsed < lngTimeout Then
    myScope.WriteString ":MEASure:RISetime"
    myScope.WriteString ":MEASure:RISetime?"
    varQueryResult = myScope.ReadNumber      ' Read risetime.
    Debug.Print "Risetime: " + _
        FormatNumber(varQueryResult * 1000000000, 1) + " ns"
Else
    Debug.Print "Timeout waiting for single-shot trigger."
End If

Exit Sub

VisaComError:
MsgBox "VISA COM Error:" + vbCrLf + Err.Description

End Sub
```

## Synchronizing with a Single-Shot Device Under Test (DUT)

The examples in ["Blocking Synchronization" on page 1647](#) and ["Polling Synchronization With Timeout" on page 1648](#) assume the DUT is continually running and therefore the oscilloscope will have more than one opportunity to trigger. With a single shot DUT, there is only one opportunity for the oscilloscope to trigger, so it is necessary for the oscilloscope to be armed and ready before the DUT is enabled.

### NOTE

The blocking :DIGitize command cannot be used for a single shot DUT because once the :DIGITIZE command is issued, the oscilloscope is blocked from any further commands until the acquisition is complete.

This example is the same ["Polling Synchronization With Timeout" on page 1648](#) with the addition of checking for the armed event status.

```
' Synchronizing single-shot acquisition using polling.
' =====

Option Explicit

Public myMgr As VisaComLib.ResourceManager
Public myScope As VisaComLib.FormattedIO488
Public varQueryResult As Variant
Public strQueryResult As String

Private Declare Sub Sleep Lib "kernel32" (ByVal dwMilliseconds As Long)

Sub Main()

    On Error GoTo VisaComError

    ' Create the VISA COM I/O resource.
    Set myMgr = New VisaComLib.ResourceManager
    Set myScope = New VisaComLib.FormattedIO488
    Set myScope.IO = myMgr.Open("TCPIP0::130.29.69.12::inst0::INSTR")
    myScope.IO.Clear      ' Clear the interface.

    ' Set up.
    ' -----
    ' Set up the trigger and horizontal scale.
    myScope.WriteString ":TRIGGER:MODE EDGE"
    myScope.WriteString ":TRIGGER:EDGE:LEVel 2"
    myScope.WriteString ":TIMEbase:SCALE 5e-8"

    ' Stop acquisitions and wait for the operation to complete.
    myScope.WriteString ":STOP"
    myScope.WriteString "*OPC?"
    strQueryResult = myScope.ReadString

    ' Acquire.
```

```

' -----
' Start a single acquisition.
myScope.WriteString ":SINGLE"

' Wait until the trigger system is armed.
Do
    Sleep 100      ' Small wait to prevent excessive queries.
    myScope.WriteString ":AER?"
    varQueryResult = myScope.ReadNumber
Loop Until varQueryResult = 1

' Oscilloscope is armed and ready, enable DUT here.
Debug.Print "Oscilloscope is armed and ready, enable DUT."

' Now, look for RUN bit = stopped (acquisition complete).
Dim lngTimeout As Long      ' Max millisecs to wait for single-shot.
Dim lngElapsed As Long
lngTimeout = 10000      ' 10 seconds.
lngElapsed = 0

Do While lngElapsed <= lngTimeout
    myScope.WriteString ":OPERRegister:CONDITION?"
    varQueryResult = myScope.ReadNumber
    ' Mask RUN bit (bit 3, &H8).
    If (varQueryResult And &H8) = 0 Then
        Exit Do
    Else
        Sleep 100      ' Small wait to prevent excessive queries.
        lngElapsed = lngElapsed + 100
    End If
Loop

' Get results.
' -----
If lngElapsed < lngTimeout Then
    myScope.WriteString ":MEASure:RISetime"
    myScope.WriteString ":MEASure:RISetime?"
    varQueryResult = myScope.ReadNumber      ' Read risetime.
    Debug.Print "Risetime: " + _
        FormatNumber(varQueryResult * 1000000000, 1) + " ns"
Else
    Debug.Print "Timeout waiting for single-shot trigger."
End If

Exit Sub

VisaComError:
MsgBox "VISA COM Error:" + vbCrLf + Err.Description

End Sub

```

## Synchronization with an Averaging Acquisition

When averaging, it is necessary to know when the average count has been reached. The :SINGle command does not average.

If it is known that a trigger will occur, a :DIGItize will acquire the complete number of averages, but if the number of averages is large, a timeout on the connection can occur.

The example below polls during the :DIGItize to prevent a timeout on the connection.

```
' Synchronizing in averaging acquisition mode.
' =====

Option Explicit

Public myMgr As VisaComLib.ResourceManager
Public myScope As VisaComLib.FormattedIO488
Public varQueryResult As Variant
Public strQueryResult As String

Private Declare Sub Sleep Lib "kernel32" (ByVal dwMilliseconds As Long)

Sub Main()

    On Error GoTo VisaComError

    ' Create the VISA COM I/O resource.
    Set myMgr = New VisaComLib.ResourceManager
    Set myScope = New VisaComLib.FormattedIO488
    Set myScope.IO = myMgr.Open("TCPIP0::130.29.69.12::inst0::INSTR")
    myScope.IO.Clear      ' Clear the interface.
    myScope.IO.Timeout = 5000

    ' Set up.
    ' -----
    ' Set up the trigger and horizontal scale.
    myScope.WriteString ":TRIGger:SWEep NORMal"
    myScope.WriteString ":TRIGger:MODE EDGE"
    myScope.WriteString ":TRIGger:EDGE:LEVel 2"
    myScope.WriteString ":TIMEbase:SCALe 5e-8"

    ' Stop acquisitions and wait for the operation to complete.
    myScope.WriteString ":STOP"
    myScope.WriteString "*OPC?"
    strQueryResult = myScope.ReadString

    ' Set up average acquisition mode.
    Dim lngAverages As Long
    lngAverages = 256
    myScope.WriteString ":ACQuire:COUNT " + CStr(lngAverages)
    myScope.WriteString ":ACQuire:TYPE AVERAGE"
```

```

' Save *ESE (Standard Event Status Enable register) mask
' (so it can be restored later).
Dim varInitialESE As Variant
myScope.WriteString "*ESE?"
varInitialESE = myScope.ReadNumber

' Set *ESE mask to allow only OPC (Operation Complete) bit.
myScope.WriteString "*ESE " + CStr(CInt("&H01"))

' Acquire using :DIGItize. Set up OPC bit to be set when the
' operation is complete.
' -----
myScope.WriteString ":DIGItize"
myScope.WriteString "*OPC"

' Assume the oscilloscope will trigger, if not put a check here.

' Wait until OPC becomes true (bit 5 of Status Byte register, STB,
' from Standard Event Status register, ESR, is set). STB can be
' read during :DIGItize without generating a timeout.
Do
    Sleep 4000      ' Poll more often than the timeout setting.
    varQueryResult = myScope.IO.ReadSTB
Loop While (varQueryResult And &H20) = 0

' Clear ESR and restore previously saved *ESE mask.
myScope.WriteString "*ESR?"      ' Clear ESR by reading it.
varQueryResult = myScope.ReadNumber
myScope.WriteString "*ESE " + CStr(varInitialESE)

' Get results.
' -----
myScope.WriteString ":WAVeform:COUNt?"
varQueryResult = myScope.ReadNumber
Debug.Print "Averaged waveforms: " + CStr(varQueryResult)

myScope.WriteString ":MEASure:RISetime"
myScope.WriteString ":MEASure:RISetime?"
varQueryResult = myScope.ReadNumber      ' Read risetime.
Debug.Print "Risetime: " +
    FormatNumber(varQueryResult * 1000000000, 1) + " ns"

Exit Sub

VisaComError:
MsgBox "VISA COM Error:" + vbCrLf + Err.Description

End Sub

```

## Example: Blocking and Polling Synchronization

```

# -*- coding: utf-8 -*-

# ****
# This script using the Python language (http://www.python.org/) and
# the PyVISA package (http://pyvisa.readthedocs.org/) shows the two
# best synchronization methods for InfiniiVision oscilloscopes.
# Benefits and drawbacks of each method are described. No error
# handling is provided except in the actual synchronization methods.
# *****

# Import modules
# -----
import sys
import visa
import time

# Initialization constants
# -----
# Get VISA address from Keysight IO Libraries Connection Expert
VISA_ADDRESS = \
    "TCPIPO::a-mx4154a-60014.cos.is.keysight.com::inst0::INSTR"
GLOBAL_TOUT = 10000 # IO timeout in milliseconds

TIME_TO_TRIGGER = 10 # Time in seconds
# -----
# This is the time until the FIRST trigger event.
#
# While the script calculates a general timeout for the given setup,
# it cannot know when a trigger event will occur. Thus, you must
# still set this value.
#
# This time is in addition to the calculated minimum timeout... so, if
# an oscilloscope might take say, 1 us to arm and acquire data, the
# signal might take 100 seconds before it occurs... this accounts for
# that.
#
# The SCOPE_ACQUISITION_TIME_OUT calculation pads this by 1.1.
# -----


TIME_BETWEEN_TRIGGERS = 0.025 # Time in seconds - for Average,
# Segmented, and Equivalent Time modes, else set to 0
# -----
# In Average, Segmented, and Equivalent Time modes, the oscilloscope
# makes repeated acquisitions. This is similar to the above
# TIME_TO_TRIGGER, but it is the time BETWEEN triggers. For example,
# it might take 10 seconds for the first trigger event, and then they
# might start occurring regularly at say, 1 ms intervals. In that
# scenario, 15 seconds (a conservative number for 10s) would be good
# for TIME_TO_TRIGGER, and 2 ms (again conservative) would be good for
# TIME_BETWEEN_TRIGGER.
#
# The default in this sample script is 0.025 seconds. This is to make
# the sample work for the LINE trigger used in this script when the

```

```

# oscilloscope is in Average, Segmented, and Equivalent Time modes to
# force a trigger off of the AC input line (:TRIGger:EDGE:SOURce LINE)
# which runs at 50 or 60 Hz in most of the world (1/50 Hz -> 20 ms, so
# use 25 ms to be conservative).
#
# The SCOPE_ACQUISITION_TIME_OUT calculation pads this by 1.1.
# -----
#
# =====
# Define a simple and fast function utilizing the blocking :DIGitize
# command in conjunction with *OPC?.
# -----
#
# Benefits of this method:
#
#   - Fastest, compact
#   - Only way for Average Acquisition type:
#     - The :SINGle command does not do a complete average.
#     - Counting triggers with :RUN is much too slow.
#   - Allows for easy synchronization with math functions
#   - Don't have to deal with the status registers, which can be
#     confusing.
#   - Potentially faster than polling_method(), for better throughput
#   - Because it's faster, one can retrieve more accurate acquisition
#     times than with a polling method.
#   - Works best for segmented memory if any post processing is done
#     on the oscilloscope, for example, measurements, lister, math,
#     as this does not come back until the processing is all done
#       - In this scenario, :DIGITIZE does not reduce the sample
#         rate or memory depth.
#
# Drawbacks of this method:
#
#   - Usually does not fill acquisition memory to the maximum
#     available, usually only on-screen data.
#
#   - May not be at the highest sample rate (compared with the
#     polling_method()).
#
#   - Requires a well-chosen, hard-set timeout that will cover the
#     time to arm, trigger, and finish acquisition.
#
#   - Requires Exception handling and a device_clear() for a
#     possible timeout (no trigger event).
#
#   - Socket connection cannot do device_clear()
#
#   - Because :DIGITIZE is a "specialized form of the :RUN" command,
#     on these oscilloscopes, that results in:
#
#       - the sample rate MAY be reduced from using :SINGLE -
#         usually at longer time scales - typically only acquires
#         what is on screen, though at the fastest time scales,
#         more than on screen data may be acquired. Thus, for max
#         memory and max sample rate, use the polling_method(),
#         which uses :SINGLE.
#

```

```

#
# How it works:
#
# - The :DIGITIZE command is a blocking command, and thus, all
# other SCPI commands are blocked until :DIGITIZE is completely
# done. This includes any subsequent processing that is already
# set up, such as math and measurements.
#
# KEY POINT: However, :DIGITIZE does not prevent additional
# commands from being sent to the queue or cause the remote
# program to wait. For example, if your program does something
# like:
#
#     KsInfiniiVisionX.write(":DIGITIZE")
#     print("Signal acquired.\n")
#
# The "Signal acquired" message will be written immediately
# after the :DIGITIZE is sent, not after the acquisition and
# processing is complete.
#
# To pause the program until the :DIGITIZE is complete, you must
# wait for a query result after the :DIGITIZE. For example, in
# this case:
#
#     query_result = KsInfiniiVisionX.query(":DIGITIZE;*OPC?")
#     print("Signal acquired.\n")
#
# The "Signal acquired" message will be written after the
# acquisition and processing is complete. The *OPC? query is
# appended to :DIGITIZE with a semi-colon (;), which
# essentially ties it to the same thread in the parser. It is
# immediately dealt with once :DIGITIZE finishes and gives a "1"
# back to the program (whether the program uses it or not),
# allowing the program to move on.
#
# Other Notes:
#
# - If you DO NOT know when a trigger will occur, you should set a
# very long timeout.
#
# - The timeout should be adjusted before and after the :DIGITIZE
# operation, though this is not absolutely required.
#
# - A :DIGITIZE can be aborted with a device clear, which also
# stops the oscilloscope:
#     KsInfiniiVisionX.clear()
#
# - :DIGITIZE disables the anti-aliasing feature (sample rate
# dither) on all InfiniiVision and InfiniiVision X-Series
# oscilloscopes.
#
# - :DIGITIZE temporarily blocks the front panel, and all front
# panel presses are queued until :DIGITIZE is done. So if you
# change the vertical scale, it will not happen until the
# acquisition is done.
#
# The exception is that the Run/Stop button on the front panel

```

```

#      is NOT blocked (unless the front panel is otherwise locked by
#      ":SYSTem:LOCK ON") .
# -----
def blocking_method():

    KsInfiniiVisionX.timeout =  SCOPE_ACQUISITION_TIME_OUT
    # Time in milliseconds (PyVisa uses ms) to wait for the
    # oscilloscope to arm, trigger, finish acquisition, and finish
    # any processing.
    #
    # Note that this is a property of the device interface,
    # KsInfiniiVisionX.
    #
    # If doing repeated acquisitions, this should be done BEFORE the
    # loop, and changed again after the loop if the goal is to
    # achieve the best throughput.

    print("Acquiring signal(s)...")

    # Set up a try/except block to catch a possible timeout and exit.
    try:
        KsInfiniiVisionX.query(":DIGItize;*OPC?")
        # Acquire the signal(s) with :DIGITize (blocking) and wait
        # until *OPC? comes back with a one.
        print("Signal acquired.")

        # Reset timeout back to what it was, GLOBAL_TOUT.
        KsInfiniiVisionX.timeout =  GLOBAL_TOUT

    # Catch a possible timeout and exit.
    except Exception:
        print("The acquisition timed out, most likely due to no " \
              "trigger or improper setup causing no trigger. " \
              "Properly closing the oscilloscope connection and " \
              "exiting script.\n")
        KsInfiniiVisionX.clear() # Clear communications interface;
                               # A device clear also aborts digitize.
        KsInfiniiVisionX.close() # Close communications interface
        sys.exit("Exiting script.")

# -----
# Define a function using the non-blocking :SINGle command and polling
# on the Operation Status Condition Register
# -----
#
# Benefits of this method:
#
# - Don't have to worry about interface timeouts.
# - Easy to expand to know when the oscilloscope is armed.
# - Don't have to worry about interface timeouts
# - Easy to expand to know when scope is armed, and triggered
# - MAY result in a higher sample rate than the blocking method
# - Always fills max available memory
# - Can use with a socket connection if desired
#
#
# Drawbacks of this method:

```

```

#
# - Slow, as you don't want to poll the oscilloscope too fast.
#
# - DOES NOT work for Equivalent time mode. MUST use the blocking
#   method.
#
# - Slow
#
# - Does NOT work for Average Acquisition type
#   - :SINGle does not do a complete average
#     - It does a single acquisition as if it were in NORMal
#       acq. type
#     - Counting triggers in :RUN is much too slow
#
# - Works for Segmented Memory, BUT if any post processing is done
#   on the oscilloscope, for example measurements, lister, math, as
#   this reports that the acquisition is done, which is correct,
#   BUT the processing is NOT done, and it will take an indefinite
#   amount of time to wait for that, though there is no way to tell
#   if it is done. Use the blocking_method for Segmented Memory.
#
# - Can't be used effectively for synchronizing math functions
#
# It can be done by applying an additional hard coded wait after
# the acquisition is done. At least 200 ms is suggested, more
# may be required.
#
# However, as long as the timeout is not excessively short, the
# math happens fast enough that once :OPERegister:CONDITION?
# comes back as done that one can just wait for it when it is
# time to pull the math waveform. The exception would be for eye
# or jitter mode on a 6000 X-Series oscilloscope, where the
# processing time can be long.
#
# - Still need some maximum timeout (here MAX_TIME_TO_WAIT),
#   ideally, or the script will sit in the while loop forever if
#   there is no trigger event
#
# Max timeout (here MAX_TIME_TO_WAIT) must also account for any
# processing done (see comments on math above)
#
# Max timeout (here MAX_TIME_TO_WAIT) must also account for time
# to arm the scope and finish the acquisition
#
# This arm/trigger/finish part is accounted for in the main script.
#
# How it works:
#
# - What really matters is the RUN bit in the Operation Condition
#   (not Event) Register. This bit changes based on the
#   oscilloscope state.
#
# If the oscilloscope is running, it is high (8), and low (0) if
# it is stopped.
#
# The only (best) way to get at this bit is with the
# :OPERation:CONDITION? query. The Operation Condition Register

```

```

# can reflect states for other oscilloscope properties, for
# example, if the oscilloscope is armed, thus it can produce
# values other than 0 (stopped) or 8 (running).
#
# To handle that, the result of :OPERATION:Condition? is bitwise
# ANDed (& in Python) with an 8. This is called "unmasking".
#
# Here, the "unmasking" is done in the script. On the other
# hand, it is possible to "mask" which bits get passed to the
# summary bit to the next register below on the instrument
# itself. However, this method is typically only used when
# working with the Status Byte, and not used here.
#
# - Why 8 = running = not done?
#
# The Run bit is the 4th bit of the Operation Status Condition
# (and Event) Registers.
#
# The registers are binary and start counting at zero, thus the
# 4th bit is bit number 3, and  $2^3 = 8$ , and thus it returns an
# 8 for high and a 0 for low.
#
# - Why the CONDITION and NOT the EVENT register?
#
# The Condition register reflects the CURRENT state, while the
# EVENT register reflects the first event that occurred since it
# was cleared or read (as in: has it EVER happened?), thus the
# CONDITION register is used.
#
# Note that with this method using :SINGLe, for InfiniiVision
# X-Series oscilloscopes only, :SINGLe itself forces the trigger
# sweep mode into NORMAl. This does not happen with the blocking
# method, using :DIGItize, or on the InfiniiVision notXs.
# =====
def polling_method():

    MAX_TIME_TO_WAIT = SCOPE_ACQUISITION_TIME_OUT/float(1000)
    # Time in seconds to wait for the oscilloscope to arm, trigger,
    # and finish acquisition.
    #
    # Note that this is NOT a property of the device interface,
    # KsInfiniiVisionX, but rather some constant in the script to be
    # used later with the Python module "time", and will be used with
    # time.clock().

    # Define "mask" bits.
    #
    # Mask condition for Run state in the Operation Status Condition
    # (and Event) Register.
    #
    # Refer to Programmer's Guide chapters on Status Reporting and
    # Synchronizing Acquisitions.
    RUN_BIT = 3
    # The run bit is the 4th bit (see next set of comments @
    # Completion Criteria).
    RUN_MASK = 1<<RUN_BIT
    # This basically means:  $2^3 = 8$ , or rather, in Python  $2^{**3}$ 

```

```

# (<< is a left shift; left shift is fastest); this is used later
# to "unmask" the result of the Operation Status Event Register
# as there is no direct access to the RUN bit.

# Define completion criterion:
ACQ_DONE = 0
# Means the oscilloscope is stopped
ACQ_NOT_DONE = 1<<RUN_BIT
# Means the oscilloscope is running; value is 8. This is the
# 4th bit of the Operation Status Condition (and Event) Register.
# The registers are binary and start counting at zero, thus the
# 4th bit (4th position in a binary representation of decimal
# 8 = 2^3 = (1 left shift 3). This is either High (running = 8)
# or low (stopped and therefore done with acquisition = 0).

print "Acquiring signal(s)..."

# Define acquisition start time. This is in seconds.
StartTime = time.clock()

# Begin Acquisition with *CLS and the non-blocking :SINGle
# command, concatenated together. The *CLS clears all (non-mask)
# registers & sets them to 0;
KsInfiniiVisionX.write("*CLS;:SINGle")

# Initialize the loop entry condition (assume Acq. is not done).
Acq_State = ACQ_NOT_DONE

# Poll the oscilloscope until Acq_State is a one. (This is NOT a
# "Serial Poll.")
while Acq_State == ACQ_NOT_DONE and (time.clock() - StartTime
                                      <= MAX_TIME_TO_WAIT):

    # Ask oscilloscope if it is done with the acquisition via the
    # Operation Status Condition (not Event) Register.
    # The Condition register reflects the CURRENT state, while
    # the EVENT register reflects the first event that occurred
    # since it was cleared or read, thus the CONDITION register
    # is used.
    #
    # DO NOT do:
    # KsInfiniiVisionX.query("*CLS;SINGle;OPERegister:CONDITION?")
    # as putting :OPERegister:CONDITION? right after :SINGle
    # doesn't work reliably
    #
    # The oscilloscope SHOULD trigger, but it sits there with the
    # Single hard key on the oscilloscope lit yellow; pressing
    # this key causes a trigger.
    Status = int(KsInfiniiVisionX.query(":OPERegister:CONDITION?"))

    # Bitwise AND of the Status and RUN_MASK. This exposes ONLY
    # the 4th bit, which is either High (running = 8) or low
    # (stopped and therefore done with acquisition = 0)
    Acq_State = (Status & RUN_MASK)
    if Acq_State == ACQ_DONE:
        break # Break out of while loop so that the 100 ms pause
              # below is not incurred if done.

```

```

time.sleep(0.1)    # Pause 100 ms to prevent excessive queries
# This can actually be set a little faster, at 0.045.  The
# point here is that:
#
#   1. If there are other things being controlled, going too
#      fast can tie up the bus.
#   2. Going faster does not work on all scopes.  The
#      symptom of this not working is:
#
# The oscilloscope SHOULD trigger, but it sits there with the
# Single hard key on the oscilloscope lit yellow; pressing
# this key causes a trigger.
#
# The pause should be at the end of the loop, so that the
# oscilloscope is immediately asked if it is done.
#
# Loop exits when Acq_State != NOT_DONE, that is, it exits
# the loop when it is DONE or if the max wait time is
# exceeded.

if Acq_State == ACQ_DONE: # Acquisition fully completed
    print "Signal acquired."
else: # Acquisition failed for some reason
    print "Max wait time exceeded."
    print "This happens if there was no trigger event."
    print "Adjust settings accordingly.\n"
    print "Properly closing oscilloscope connection and exiting " \
          "script.\n"
KsInfiniiVisionX.clear() # Clear communications interface
KsInfiniiVisionX.query(":STOP;*OPC?")
# Stop the oscilloscope
KsInfiniiVisionX.close() # Close communications interface
sys.exit("Exiting script.")

# =====
# Do Something with data... save, export, additional analysis...
# =====
def do_something_with_data():

    # For example, make a peak-peak voltage measurement on channel 1:
    Vpp_Ch1 = \
        str(KsInfiniiVisionX.query("MEASure:VPP? CHANnel1")).strip("\n")
    # The result has a newline, so remove it with .strip("\n")
    print "Vpp Ch1 = " + Vpp_Ch1 + " V\n"

# =====
# Main code
# =====

# Connect and initialize oscilloscope
# -----
# Define VISA Resource Manager & Install directory
rm = visa.ResourceManager('C:\\Windows\\System32\\agvisa32.dll')

# Define and open the oscilloscope using the VISA address

```

```

try:
    KsInfiniiVisionX = rm.open_resource(VISA_ADDRESS)
except Exception:
    print "Unable to connect to oscilloscope at " + str(VISA_ADDRESS) \
          + ". Aborting script.\n"
    sys.exit()

# Set the Global Timeout
KsInfiniiVisionX.timeout = GLOBAL_TOUT

# Clear the instrument bus
KsInfiniiVisionX.clear()

# Clear all status registers and errors
KsInfiniiVisionX.write("*CLS")

try:

    # Set up the oscilloscope
    # -----
    # Note that you would normally perform a reset (default setup) if
    # you were to create the setup from scratch... But here we will
    # use the oscilloscope "as is" for the most part.
    # KsInfiniiVisionX.query("*RST;*OPC?")    # Resets the oscilloscope

    # Always stop the oscilloscope when making any changes.
    KsInfiniiVisionX.query(":STOP;*OPC?")

    # For this example, the oscilloscope will be forced to trigger on
    # the # (AC input power) LINE voltage so something happens.
    # Always use normal trigger sweep, never auto.
    KsInfiniiVisionX.write(":TRIGger:SWEep NORMAL")
    # This line simply gives the oscilloscope something to trigger on.
    KsInfiniiVisionX.query(":TRIGger:EDGE:SOURce LINE;*OPC?")

    # Clear the display (so you can see the waveform being acquired -
    # otherwise, there is no need for this).
    KsInfiniiVisionX.write(":CDISplay")

    # Calculate acquisition timeout/wait time by short, overestimate
    # method
    # -----
    # Create some default variables
N_AVERAGES = 1
N_SEGMENTS = 1

    # Get some info about the scope time base setup
HO      = float(KsInfiniiVisionX.query(":TRIGger:HOLDoff?"))
T_RANGE = float(KsInfiniiVisionX.query(":TIMEbase:RANGE?"))
T_POSITION = float(KsInfiniiVisionX.query(":TIMEbase:POSITION?"))

    # Determine Acquisition Type and Mode:
ACQ_TYPE = str(KsInfiniiVisionX.query(":ACQuire:TYPE?").strip("\n"))
ACQ_MODE = str(KsInfiniiVisionX.query(":ACQuire:MODE?").strip("\n"))

if ACQ_MODE == "SEGM":

```

```

N_SEGMENTS = \
    float(KsInfiniiVisionX.query(":ACQuire:SEGmented:COUNT?"))
# Note that if there are a lot of analysis associated segments,
# for example, serial data decode, the timeout will likely need
# to be longer than calculated.
#
# You are encouraged to manually set up the oscilloscope in
# this case, as it will be used, time it, and use that, with
# a little overhead.
#
# Blocking method is recommended for Segmented Memory mode.
elif ACQ_TYPE == "AVER":
    N_AVERAGES = float(KsInfiniiVisionX.query(":ACQuire:COUNT?"))

# Calculate acquisition timeout by overestimate method:
# Recall that PyVisa timeouts are in ms, so multiply by 1000.
SCOPE_ACQUISITION_TIME_OUT = (float(TIME_TO_TRIGGER)*1.1 +
    (T_RANGE*2.0 + abs(T_POSITION)*2.0 + HO*1.1 +
    float(TIME_BETWEEN_TRIGGER)*1.1)*N_SEGMENTS*N_AVERAGES)*1000.0

## Ensure the timeout is no less than 10 seconds
if SCOPE_ACQUISITION_TIME_OUT < 10000.0:
    SCOPE_ACQUISITION_TIME_OUT = 10000.0

# What about Equivalent Time Mode and other odd modes such as
# Jitter or Eye (the last two only being found on the
# 6000 X-Series), and math functions?
#
# In most cases, the padding and 10 second minimum timeout will
# take care of this.
#
# Equivalent Time Mode has effects only at the fastest time
# scales, so it really doesn't make a difference as long as a
# trigger signal is present. If trigger signal occurs rarely,
# adjust the TIME_BETWEEN_TRIGGER constant accordingly.
#
# For math, the math will happen fast enough that the "padding"
# in the timeout calculation takes care of this.
#
# For jitter mode on the 6000 X-Series, you can try this method,
# typically there is always a signal present, and the 10 second
# minimum should work out. If not, make it bigger, or increase
# padding.
#
# For Eye mode on the 6000 X-Series, none of this works anyway,
# and you have to use :RUN (or :RTEYE:ACQuire) and :STOP.

# Acquire Signal
# -----
# Choose blocking_method or polling_method. These were defined as
# functions in case you want to use them repeatedly.
blocking_method()
# If Acquisition Type is Average, always use blocking_method() to
# get complete average.
do_something_with_data()

polling_method()

```

```
do_something_with_data()

# Done - cleanup
KsInfiniiVisionX.clear() # Clear communications interface
KsInfiniiVisionX.close() # Close communications interface
except KeyboardInterrupt:
    KsInfiniiVisionX.clear()
    KsInfiniiVisionX.query(":STOP;*OPC?")
    KsInfiniiVisionX.write(":SYSTem:LOCK OFF")
    KsInfiniiVisionX.clear()
    KsInfiniiVisionX.close()
    sys.exit("User Interupt. Properly closing oscilloscope and "
             "aborting script.")
except Exception:
    KsInfiniiVisionX.clear()
    KsInfiniiVisionX.query(":STOP;*OPC?")
    KsInfiniiVisionX.write(":SYSTem:LOCK OFF")
    KsInfiniiVisionX.clear()
    KsInfiniiVisionX.close()
    sys.exit("Something went wrong. Properly closing oscilloscope "
             "and aborting script.")

# End of Script
# -----
print "Done."
```

# 45 More About Oscilloscope Commands

[Command Classifications / 1666](#)  
[Valid Command/Query Strings / 1667](#)  
[Query Return Values / 1673](#)

## Command Classifications

To help you use existing programs with your oscilloscope, or use current programs with the next generation of Keysight InfiniiVision oscilloscopes, commands are classified by the following categories:

- ["Core Commands" on page 1666](#)
- ["Non-Core Commands" on page 1666](#)
- ["Obsolete Commands" on page 1666](#)

### C Core Commands

Core commands are a common set of commands that provide basic oscilloscope functionality on this oscilloscope and future Keysight InfiniiVision oscilloscopes. Core commands are unlikely to be modified in the future. If you restrict your programs to core commands, the programs should work across product offerings in the future, assuming appropriate programming methods are employed.

### N Non-Core Commands

Non-core commands are commands that provide specific features, but are not universal across all Keysight InfiniiVision oscilloscope models. Non-core commands may be modified or deleted in the future. With a command structure as complex as the one for your oscilloscope, some evolution over time is inevitable. Keysight's intent is to continue to expand command subsystems, such as the rich and evolving trigger feature set.

### O Obsolete Commands

Obsolete commands are older forms of commands that are provided to reduce customer rework for existing systems and programs. Generally, these commands are mapped onto some of the Core and Non-core commands, but may not strictly have the same behavior as the new command. None of the obsolete commands are guaranteed to remain functional in future products. New systems and programs should use the Core (and Non-core) commands. Obsolete commands are listed in:


- [Chapter 41, “Obsolete and Discontinued Commands,” starting on page 1547](#)

## Valid Command/Query Strings

- "Program Message Syntax" on page 1667
- "Duplicate Mnemonics" on page 1671
- "Tree Traversal Rules and Multiple Commands" on page 1671

### Program Message Syntax

To program the instrument remotely, you must understand the command format and structure expected by the instrument. The IEEE 488.2 syntax rules govern how individual elements such as headers, separators, program data, and terminators may be grouped together to form complete instructions. Syntax definitions are also given to show how query responses are formatted. The following figure shows the main syntactical parts of a typical program statement.



Instructions (both commands and queries) normally appear as a string embedded in a statement of your host language, such as Visual Basic or C/C++. The only time a parameter is not meant to be expressed as a string is when the instruction's syntax definition specifies <block data>, such as <learn string>. There are only a few instructions that use block data.

Program messages can have long or short form commands (and data in some cases – see "Long Form to Short Form Truncation Rules" on page 1668), and upper and/or lower case ASCII characters may be used. (Query responses, however, are always returned in upper case.)

Instructions are composed of two main parts:

- The header, which specifies the command or query to be sent.
- The program data, which provide additional information needed to clarify the meaning of the instruction.

**Instruction Header** The instruction header is one or more mnemonics separated by colons (:) that represent the operation to be performed by the instrument.

"":DISPLAY:LABEL ON" is a command. Queries are indicated by adding a question mark (?) to the end of the header, for example, "":DISPLAY:LABEL?". Many instructions can be used as either commands or queries, depending on whether or

not you have included the question mark. The command and query forms of an instruction usually have different program data. Many queries do not use any program data.

There are three types of headers:

- ["Simple Command Headers" on page 1669](#)
- ["Compound Command Headers" on page 1669](#)
- ["Common Command Headers" on page 1669](#)

**White Space (Separator)** White space is used to separate the instruction header from the program data. If the instruction does not require any program data parameters, you do not need to include any white space. White space is defined as one or more space characters. ASCII defines a space to be character 32 (in decimal).

**Program Data** Program data are used to clarify the meaning of the command or query. They provide necessary information, such as whether a function should be on or off, or which waveform is to be displayed. Each instruction's syntax definition shows the program data, as well as the values they accept. ["Program Data Syntax Rules" on page 1670](#) describes all of the general rules about acceptable values.

When there is more than one data parameter, they are separated by commas(,). Spaces can be added around the commas to improve readability.

**Program Message Terminator** The program instructions within a data message are executed after the program message terminator is received. The terminator may be either an NL (New Line) character, an EOI (End-Or-Identify) asserted in the programming interface, or a combination of the two. Asserting the EOI sets the EOI control line low on the last byte of the data message. The NL character is an ASCII linefeed (decimal 10).

#### NOTE

**New Line Terminator Functions.** The NL (New Line) terminator has the same function as an EOS (End Of String) and EOT (End Of Text) terminator.

### Long Form to Short Form Truncation Rules

To get the short form of a command/keyword:

- When the command/keyword is longer than four characters, use the first four characters of the command/keyword unless the fourth character is a vowel; when the fourth character is a vowel, use the first three characters of the command/keyword.
- When the command/keyword is four or fewer characters, use all of the characters.

Long Form	Short form
RANGE	RANG
PATTERn	PATT

Long Form	Short form
TIMebase	TIM
DELay	DEL
TYPE	TYPE

In the oscilloscope programmer's documentation, the short form of a command is indicated by uppercase characters.

Programs written in long form are easily read and are almost self-documenting. The short form syntax conserves the amount of controller memory needed for program storage and reduces I/O activity.

### Simple Command Headers

Simple command headers contain a single mnemonic. :AUToscale and :DIGitize are examples of simple command headers typically used in the oscilloscope. The syntax is:

```
<program mnemonic><terminator>
```

Simple command headers must occur at the beginning of a program message; if not, they must be preceded by a colon.

When program data must be included with the simple command header (for example, :DIGITIZE CHANnel1), white space is added to separate the data from the header. The syntax is:

```
<program mnemonic><separator><program data><terminator>
```

### Compound Command Headers

Compound command headers are a combination of two or more program mnemonics. The first mnemonic selects the subsystem, and the second mnemonic selects the function within that subsystem. The mnemonics within the compound message are separated by colons. For example, to execute a single function within a subsystem:

```
:<subsystem>:<function><separator><program data><terminator>
```

For example, :CHANnel1:BWLIMIT ON

### Common Command Headers

Common command headers control IEEE 488.2 functions within the instrument (such as clear status). Their syntax is:

```
*<command header><terminator>
```

No space or separator is allowed between the asterisk (\*) and the command header. \*CLS is an example of a common command header.

## Program Data Syntax Rules

Program data is used to convey a parameter information related to the command header. At least one space must separate the command header or query header from the program data.

```
<program mnemonic><separator><data><terminator>
```

When a program mnemonic or query has multiple program data, a comma separates sequential program data.

```
<program mnemonic><separator><data>,<data><terminator>
```

For example, :MEASure:DELay CHANnel1,CHANnel2 has two program data: CHANnel1 and CHANnel2.

Two main types of program data are used in commands: character and numeric.

### Character Program Data

Character program data is used to convey parameter information as alpha or alphanumeric strings. For example, the :TIMEbase:MODE command can be set to normal, zoomed (delayed), XY, or ROLL. The character program data in this case may be MAIN, WINDOW, XY, or ROLL. The command :TIMEbase:MODE WINDOW sets the time base mode to zoomed.

The available mnemonics for character program data are always included with the command's syntax definition.

When sending commands, you may either the long form or short form (if one exists). Uppercase and lowercase letters may be mixed freely.

When receiving query responses, uppercase letters are used exclusively.

### Numeric Program Data

Some command headers require program data to be expressed numerically. For example, :TIMEbase:RANGE requires the desired full scale range to be expressed numerically.

For numeric program data, you have the option of using exponential notation or using suffix multipliers to indicate the numeric value. The following numbers are all equal:

```
28 = 0.28E2 = 280e-1 = 28000m = 0.028K = 28e-3K.
```

When a syntax definition specifies that a number is an integer, that means that the number should be whole. Any fractional part will be ignored, truncating the number. Numeric data parameters accept fractional values are called real numbers.

All numbers must be strings of ASCII characters. Thus, when sending the number 9, you would send a byte representing the ASCII code for the character 9 (which is 57). A three-digit number like 102 would take up three bytes (ASCII codes 49, 48, and 50). This is handled automatically when you include the entire instruction in a string.

## Duplicate Mnemonics

Identical function mnemonics can be used in more than one subsystem. For example, the function mnemonic RANGe may be used to change the vertical range or to change the horizontal range:

```
:CHANnel1:RANGE .4
```

Sets the vertical range of channel 1 to 0.4 volts full scale.

```
:TIMEbase:RANGE 1
```

Sets the horizontal time base to 1 second full scale.

:CHANnel1 and :TIMEbase are subsystem selectors and determine which range is being modified.

## Tree Traversal Rules and Multiple Commands

Command headers are created by traversing down the command tree. A legal command header would be :TIMEbase:RANGE. This is referred to as a *compound header*. A compound header is a header made of two or more mnemonics separated by colons. The mnemonic created contains no spaces.

The following rules apply to traversing the tree:

- A leading colon (<NL> or EOI true on the last byte) places the parser at the root of the command tree. A leading colon is a colon that is the first character of a program header. Executing a subsystem command lets you access that subsystem until a leading colon or a program message terminator (<NL>) or EOI true is found.
- In the command tree, use the last mnemonic in the compound header as the reference point (for example, RANGE). Then find the last colon above that mnemonic (TIMEbase:). That is the point where the parser resides. Any command below that point can be sent within the current program message without sending the mnemonics which appear above them (for example, POSITION).

The output statements in the examples are written using the Keysight VISA COM library in Visual Basic. The quoted string is placed on the bus, followed by a carriage return and linefeed (CRLF).

To execute more than one function within the same subsystem, separate the functions with a semicolon (;):

```
:<subsystem>:<function><separator><data>;<function><separator><data><terminator>
```

For example:

```
myScope.WriteString ":TIMEbase:RANGE 0.5;POSITION 0"
```

**NOTE**

The colon between TIMebase and RANGe is necessary because TIMebase:RANGE is a compound command. The semicolon between the RANGe command and the POSition command is the required program message unit separator. The POSition command does not need TIMebase preceding it because the TIMebase:RANGE command sets the parser to the TIMebase node in the tree.

**Example 2:**  
**Program Message Terminator Sets Parser Back to Root**

```
myScope.WriteString ":TIMebase:REFerence CENTER;POSITION 0.00001"
```

or

```
myScope.WriteString ":TIMebase:REFerence CENTER"
myScope.WriteString ":TIMebase:POSITION 0.00001"
```

**NOTE**

In the first line of example 2, the subsystem selector is implied for the POSITION command in the compound command. The POSITION command must be in the same program message as the REFerence command because the program message terminator places the parser back at the root of the command tree.

A second way to send these commands is by placing TIMebase: before the POSITION command as shown in the second part of example 2. The space after POSITION is required.

**Example 3:**  
**Selecting Multiple Subsystems**

You can send multiple program commands and program queries for different subsystems on the same line by separating each command with a semicolon. The colon following the semicolon enables you to enter a new subsystem. For example:

```
<program mnemonic><data>;<program mnemonic><data><terminator>
```

For example:

```
myScope.WriteString ":TIMebase:REFerence CENTER;:DISPlay:VECTors ON"
```

**NOTE**

The leading colon before DISPLAY:VECTors ON tells the parser to go back to the root of the command tree. The parser can then see the DISPLAY:VECTors ON command. The space between REFerence and CENter is required; so is the space between VECTors and ON.

Multiple commands may be any combination of compound and simple commands.

## Query Return Values

Command headers immediately followed by a question mark (?) are queries. Queries are used to get results of measurements made by the instrument or to find out how the instrument is currently configured.

After receiving a query, the instrument interrogates the requested function and places the answer in its output queue. The answer remains in the output queue until it is read or another command is issued.

When read, the answer is transmitted across the bus to the designated listener (typically a controller). For example, the query :TIMEbase:RANGE? places the current time base setting in the output queue. When using the Keysight VISA COM library in Visual Basic, the controller statements:

```
Dim strQueryResult As String  
myScope.WriteString ":TIMEbase:RANGE?"  
strQueryResult = myScope.ReadString
```

pass the value across the bus to the controller and place it in the variable strQueryResult.

### NOTE

**Read Query Results Before Sending Another Command.** Sending another command or query before reading the result of a query clears the output buffer (the current response) and places a Query INTERRUPTED error in the error queue.

### Infinity Representation

The representation of infinity is +9.9E+37. This is also the value returned when a measurement cannot be made.

## 45 More About Oscilloscope Commands

# 46 Programming Examples

VISA COM Examples / 1676

VISA Examples / 1709

VISA.NET Examples / 1756

SICL Examples / 1769

SCPI.NET Examples / 1789

The example programs in this manual are ASCII text files that can be cut from the help file and pasted into your favorite text editor.

- See Also**
- You can find additional programming examples for the InfiniiVision 3000T X-Series oscilloscopes on the Keysight Technologies website at:  
[www.keysight.com/find/3000TX-Series-examples](http://www.keysight.com/find/3000TX-Series-examples)

## VISA COM Examples

- "VISA COM Example in Visual Basic" on page 1676
- "VISA COM Example in C#" on page 1685
- "VISA COM Example in Visual Basic .NET" on page 1694
- "VISA COM Example in Python 3" on page 1702

### VISA COM Example in Visual Basic

To run this example in Visual Basic for Applications (VBA):

- 1 Start the application that provides Visual Basic for Applications (for example, Microsoft Excel).
- 2 Press ALT+F11 to launch the Visual Basic editor.
- 3 Reference the Keysight VISA COM library:
  - a Choose **Tools > References...** from the main menu.
  - b In the References dialog, check the "VISA COM 5.9 Type Library".
  - c Click **OK**.
- 4 Choose **Insert > Module**.
- 5 Cut-and-paste the code that follows into the editor.
- 6 Edit the program to use the VISA address of your oscilloscope, and save the changes.
- 7 Run the program.

```

'
' Keysight VISA COM Example in Visual Basic
' -----
' This program illustrates a few commonly-used programming
' features of your Keysight oscilloscope.
' -----


Option Explicit

Public myMgr As VisaComLib.ResourceManager
Public myScope As VisaComLib.FormattedIO488
Public varQueryResult As Variant
Public strQueryResult As String

' For Sleep subroutine.
Private Declare Sub Sleep Lib "kernel32" (ByVal dwMilliseconds As Long)

'
' Main Program
' -----


Sub Main()

```

```

On Error GoTo VisaComError

' Create the VISA COM I/O resource.
Set myMgr = New VisaComLib.ResourceManager
Set myScope = New VisaComLib.FormattedIO488
Set myScope.IO =
    myMgr.Open("USB0::0x0957::0x17A6::US50210029::0::INSTR")
myScope.IO.Clear      ' Clear the interface.
myScope.IO.Timeout = 10000   ' Set I/O communication timeout.

' Initialize - start from a known state.
Initialize

' Capture data.
Capture

' Analyze the captured waveform.
Analyze

Exit Sub

VisaComError:
MsgBox "VISA COM Error:" + vbCrLf + Err.Description
End

End Sub

'
' Initialize the oscilloscope to a known state.
' -----
Private Sub Initialize()

On Error GoTo VisaComError

' Get and display the device's *IDN? string.
strQueryResult = DoQueryString("*IDN?")
Debug.Print "Identification string: " + strQueryResult

' Clear status and load the default setup.
DoCommand "*CLS"
DoCommand "*RST"

Exit Sub

VisaComError:
MsgBox "VISA COM Error:" + vbCrLf + Err.Description
End

End Sub

'
' Capture the waveform.
' -----
Private Sub Capture()

```

```

On Error GoTo VisaComError

' Use auto-scale to automatically configure oscilloscope.
' -----
DoCommand ":AUToscale"

' Set trigger mode (EDGE, PULSe, PATTern, etc., and input source.
DoCommand ":TRIGger:MODE EDGE"
Debug.Print "Trigger mode: " + _
    DoQueryString(":TRIGger:MODE?")

' Set EDGE trigger parameters.
DoCommand ":TRIGger:EDGE:SOURce CHANnel1"
Debug.Print "Trigger edge source: " + _
    DoQueryString(":TRIGger:EDGE:SOURce?")

DoCommand ":TRIGger:EDGE:LEVel 1.5"
Debug.Print "Trigger edge level: " + _
    DoQueryString(":TRIGger:EDGE:LEVel?")

DoCommand ":TRIGger:EDGE:SLOPe POSitive"
Debug.Print "Trigger edge slope: " + _
    DoQueryString(":TRIGger:EDGE:SLOPe?")

' Save oscilloscope configuration.
' -----
varQueryResult = DoQueryIEEEBlock_UI1(":SYSTem:SETup?")

' Output setup string to a file:
Dim strPath As String
strPath = "c:\scope\config\setup.dat"
Dim hFile As Long
hFile = FreeFile
Open strPath For Binary Access Write Lock Write As hFile
Put hFile, , varQueryResult ' Write data.
Close hFile ' Close file.
Debug.Print "Setup bytes saved: " + CStr(LenB(varQueryResult))

' Change settings with individual commands:
' -----

' Set vertical scale and offset.
DoCommand ":CHANnel1:SCALe 0.05"
Debug.Print "Channel 1 vertical scale: " + _
    DoQueryString(":CHANnel1:SCALe?")

DoCommand ":CHANnel1:OFFSet -1.5"
Debug.Print "Channel 1 vertical offset: " + _
    DoQueryString(":CHANnel1:OFFSet?")

' Set horizontal scale and offset.
DoCommand ":TIMEbase:SCALe 0.0002"
Debug.Print "Timebase scale: " + _
    DoQueryString(":TIMEbase:SCALe?")

DoCommand ":TIMEbase:POSItion 0.0"
Debug.Print "Timebase position: " + _

```

```

DoQueryString(":TIMEbase:POSITION?")

' Set the acquisition type (NORMal, PEAK, AVERage, or HRESolution).
DoCommand ":ACQuire:TYPE NORMal"
Debug.Print "Acquire type: " + _
DoQueryString(":ACQuire:TYPE?")

' Or, configure by loading a previously saved setup.
' -----
Dim varSetupString As Variant
strPath = "c:\scope\config\setup.dat"
Open strPath For Binary Access Read As hFile    ' Open file for input.
Get hFile, , varSetupString    ' Read data.
Close hFile    ' Close file.
' Write learn string back to oscilloscope using ":SYSTem:SETup"
' command:
DoCommandIEEEBlock ":SYSTem:SETup", varSetupString
Debug.Print "Setup bytes restored: " + CStr(LenB(varSetupString))

' Capture an acquisition using :DIGItize.
' -----
DoCommand ":DIGItize CHANnel1"

Exit Sub

VisaComError:
MsgBox "VISA COM Error:" + vbCrLf + Err.Description
End

End Sub

'
' Analyze the captured waveform.
' -----
Private Sub Analyze()

On Error GoTo VisaComError

' Make a couple of measurements.
' -----
DoCommand ":MEASure:SOURce CHANnel1"
Debug.Print "Measure source: " + _
DoQueryString(":MEASure:SOURce?")

DoCommand ":MEASure:FREQuency"
varQueryResult = DoQueryNumber(":MEASure:FREQuency?")
MsgBox "Frequency:" + vbCrLf + _
FormatNumber(varQueryResult / 1000, 4) + " kHz"

DoCommand ":MEASure:VAMPplitude"
varQueryResult = DoQueryNumber(":MEASure:VAMPplitude?")
MsgBox "Vertical amplitude:" + vbCrLf + _
FormatNumber(varQueryResult, 4) + " V"

' Download the screen image.

```

```

' -----
' Get screen image.
DoCommand ":HARDcopy:INKSaver OFF"
Dim byteData() As Byte
byteData = DoQueryIEEEBlock_UI1(":DISPLAY:DATA? PNG, COLOR")

' Save screen image to a file.
Dim strPath As String
strPath = "c:\scope\data\screen.png"
If Len(Dir(strPath)) Then
    Kill strPath      ' Remove file if it exists.
End If

Dim hFile As Long
hFile = FreeFile
Open strPath For Binary Access Write Lock Write As hFile
Put hFile, , byteData      ' Write data.
Close hFile      ' Close file.
MsgBox "Screen image (" + CStr(UBound(byteData) + 1) + _
       " bytes) written to " + strPath

' Download waveform data.
' -----

' Set the waveform points mode.
DoCommand ":WAVeform:POINTs:MODE RAW"
Debug.Print "Waveform points mode: " + _
           DoQueryString(":WAVeform:POINTs:MODE?")

' Get the number of waveform points available.
Debug.Print "Waveform points available: " + _
           DoQueryString(":WAVeform:POINTs?")

' Set the waveform source.
DoCommand ":WAVeform:SOURce CHANnel1"
Debug.Print "Waveform source: " + _
           DoQueryString(":WAVeform:SOURce?")

' Choose the format of the data returned (WORD, BYTE, ASCII):
DoCommand ":WAVeform:FORMAT BYTE"
Debug.Print "Waveform format: " + _
           DoQueryString(":WAVeform:FORMAT?")

' Display the waveform settings:
Dim Preamble()
Dim intFormat As Integer
Dim intType As Integer
Dim lngPoints As Long
Dim lngCount As Long
Dim dblXIncrement As Double
Dim dblXOrigin As Double
Dim lngXReference As Long
Dim sngYIncrement As Single
Dim sngYOrigin As Single
Dim lngYReference As Long

```

```

Preamble() = DoQueryNumbers(":WAVeform:PREamble?")

intFormat = Preamble(0)
intType = Preamble(1)
lngPoints = Preamble(2)
lngCount = Preamble(3)
dblXIncrement = Preamble(4)
dblXOrigin = Preamble(5)
lngXReference = Preamble(6)
sngYIncrement = Preamble(7)
sngYOrigin = Preamble(8)
lngYReference = Preamble(9)

If intFormat = 0 Then
    Debug.Print "Waveform format: BYTE"
ElseIf intFormat = 1 Then
    Debug.Print "Waveform format: WORD"
ElseIf intFormat = 4 Then
    Debug.Print "Waveform format: ASCii"
End If

If intType = 0 Then
    Debug.Print "Acquisition type: NORMAL"
ElseIf intType = 1 Then
    Debug.Print "Acquisition type: PEAK"
ElseIf intType = 2 Then
    Debug.Print "Acquisition type: AVERage"
ElseIf intType = 3 Then
    Debug.Print "Acquisition type: HRESolution"
End If

Debug.Print "Waveform points: " + _
FormatNumber(lngPoints, 0)

Debug.Print "Waveform average count: " + _
FormatNumber(lngCount, 0)

Debug.Print "Waveform X increment: " + _
Format(dblXIncrement, "Scientific")

Debug.Print "Waveform X origin: " + _
Format(dblXOrigin, "Scientific")

Debug.Print "Waveform X reference: " + _
FormatNumber(lngXReference, 0)

Debug.Print "Waveform Y increment: " + _
Format(sngYIncrement, "Scientific")

Debug.Print "Waveform Y origin: " + _
FormatNumber(sngYOrigin, 0)

Debug.Print "Waveform Y reference: " + _
FormatNumber(lngYReference, 0)

' Get the waveform data
varQueryResult = DoQueryIEEEBlock_UI1(":WAVeform:DATA?")

```

```

Debug.Print "Number of data values: " + _
    CStr(UBound(varQueryResult) + 1)

' Set up output file:
strPath = "c:\scope\data\waveform_data.csv"

' Open file for output.
Open strPath For Output Access Write Lock Write As hFile

' Output waveform data in CSV format.
Dim lngDataValue As Long
Dim lngI As Long

For lngI = 0 To UBound(varQueryResult)
    lngDataValue = varQueryResult(lngI)

    ' Write time value, voltage value.
    Print #hFile, _
        FormatNumber(dblXOrigin + (lngI * dblXIncrement), 9) + _
        ", " + _
        FormatNumber(((lngDataValue - lngYReference) * _
        sngYIncrement) + sngYOrigin)

    Next lngI

    ' Close output file.
    Close hFile ' Close file.
    MsgBox "Waveform format BYTE data written to " + _
        "c:\scope\data\waveform_data.csv."

    Exit Sub

VisaComError:
    MsgBox "VISA COM Error:" + vbCrLf + Err.Description
End

End Sub

Private Sub DoCommand(command As String)

    On Error GoTo VisaComError

    myScope.WriteString command
    CheckInstrumentErrors

    Exit Sub

VisaComError:
    MsgBox "VISA COM Error: " + vbCrLf + CStr(Err.Number) + ", " + _
        Err.Source + ", " + _
        Err.Description, vbExclamation, "VISA COM Error"
End

End Sub

Private Sub DoCommandIEEEBlock(command As String, data As Variant)

```

```

On Error GoTo VisaComError

Dim strErrors As String

myScope.WriteLineEEBlock command, data
CheckInstrumentErrors

Exit Sub

VisaComError:
MsgBox "VISA COM Error: " + vbCrLf + CStr(Err.Number) + ", " + _
       Err.Source + ", " + _
       Err.Description, vbExclamation, "VISA COM Error"
End

End Sub

Private Function DoQueryString(query As String) As String

On Error GoTo VisaComError

myScope.WriteString query
DoQueryString = myScope.ReadString
CheckInstrumentErrors

Exit Function

VisaComError:
MsgBox "VISA COM Error: " + vbCrLf + CStr(Err.Number) + ", " + _
       Err.Source + ", " + _
       Err.Description, vbExclamation, "VISA COM Error"
End

End Function

Private Function DoQueryNumber(query As String) As Variant

On Error GoTo VisaComError

myScope.WriteString query
DoQueryNumber = myScope.ReadNumber
CheckInstrumentErrors

Exit Function

VisaComError:
MsgBox "VISA COM Error: " + vbCrLf + CStr(Err.Number) + ", " + _
       Err.Source + ", " + _
       Err.Description, vbExclamation, "VISA COM Error"
End

End Function

Private Function DoQueryNumbers(query As String) As Variant()

On Error GoTo VisaComError

```

```

        Dim strErrors As String

        myScope.WriteString query
        DoQueryNumbers = myScope.ReadList
        CheckInstrumentErrors

        Exit Function

VisaComError:
        MsgBox "VISA COM Error: " + vbCrLf + CStr(Err.Number) + ", " + _
            Err.Source + ", " + _
            Err.Description, vbExclamation, "VISA COM Error"
    End

End Function

Private Function DoQueryIEEEBlock_UI1(query As String) As Variant

    On Error GoTo VisaComError

    myScope.WriteString query
    DoQueryIEEEBlock_UI1 = myScope.ReadIEEEBlock(BinaryType_UI1)
    CheckInstrumentErrors

    Exit Function

VisaComError:
    MsgBox "VISA COM Error: " + vbCrLf + CStr(Err.Number) + ", " + _
        Err.Source + ", " + _
        Err.Description, vbExclamation, "VISA COM Error"
    End

End Function

Private Sub CheckInstrumentErrors()

    On Error GoTo VisaComError

    Dim strErrVal As String
    Dim strOut As String

    myScope.WriteString ":SYSTem:ERRor?"      ' Query any errors data.
    strErrVal = myScope.ReadString           ' Read: Errnum, "Error String".
    While Val(strErrVal) <> 0              ' End if find: 0, "No Error".
        strOut = strOut + "INST Error: " + strErrVal
        myScope.WriteString ":SYSTem:ERRor?"    ' Request error message.
        strErrVal = myScope.ReadString         ' Read error message.
    Wend

    If Not strOut = "" Then
        MsgBox strOut, vbExclamation, "INST Error Messages"
        myScope.FlushWrite (False)
        myScope.FlushRead
    End If

    Exit Sub

```

```

VisaComError:
    MsgBox "VISA COM Error: " + vbCrLf + Err.Description

End Sub

```

## VISA COM Example in C#

To compile and run this example in Microsoft Visual Studio 2008:

- 1** Open Visual Studio.
- 2** Create a new Visual C#, Windows, Console Application project.
- 3** Cut-and-paste the code that follows into the C# source file.
- 4** Edit the program to use the VISA address of your oscilloscope.
- 5** Add a reference to the VISA COM 5.9 Type Library:
  - a** Right-click the project you wish to modify (not the solution) in the Solution Explorer window of the Microsoft Visual Studio environment.
  - b** Choose **Add Reference...**.
  - c** In the Add Reference dialog, select the **COM** tab.
  - d** Select **VISA COM 5.9 Type Library**; then click **OK**.
- 6** Build and run the program.

For more information, see the VISA COM Help that comes with Keysight IO Libraries Suite.

```

/*
 * Keysight VISA COM Example in C#
 * -----
 * This program illustrates a few commonly used programming
 * features of your Keysight oscilloscope.
 * -----
 */

using System;
using System.IO;
using System.Text;
using Ivi.Visa.Interop;
using System.Runtime.InteropServices;

namespace InfiniiVision
{
    class VisaComInstrumentApp
    {
        private static VisaComInstrument myScope;

        public static void Main(string[] args)
        {
            try
            {
                myScope = new

```

```

        VisaComInstrument ("USB0::0x0957::0x17A6::US50210029::0::INSTR"
) ;
myScope.SetTimeoutSeconds(10);

// Initialize - start from a known state.
Initialize();

// Capture data.
Capture();

// Analyze the captured waveform.
Analyze();
}

catch (System.ApplicationException err)
{
    Console.WriteLine("**** VISA COM Error : " + err.Message);
}
catch (System.SystemException err)
{
    Console.WriteLine("**** System Error Message : " + err.Message);
}
catch (System.Exception err)
{
    System.Diagnostics.Debug.Fail("Unexpected Error");
    Console.WriteLine("**** Unexpected Error : " + err.Message);
}
finally
{
    myScope.Close();
}
}

/*
 * Initialize the oscilloscope to a known state.
 * -----
 */
private static void Initialize()
{
    string strResults;

    // Get and display the device's *IDN? string.
    strResults = myScope.DoQueryString("*IDN?");
    Console.WriteLine("*IDN? result is: {0}", strResults);

    // Clear status and load the default setup.
    myScope.DoCommand("*CLS");
    myScope.DoCommand("*RST");
}

/*
 * Capture the waveform.
 * -----
 */
private static void Capture()
{
    // Use auto-scale to automatically configure oscilloscope.
    myScope.DoCommand(":AUToscale");
}

```

```

// Set trigger mode (EDGE, PULSe, PATTern, etc., and input source.
myScope.DoCommand(":TRIGger:MODE EDGE");
Console.WriteLine("Trigger mode: {0}",
    myScope.DoQueryString(":TRIGger:MODE?"));

// Set EDGE trigger parameters.
myScope.DoCommand(":TRIGger:EDGE:SOURce CHANnel1");
Console.WriteLine("Trigger edge source: {0}",
    myScope.DoQueryString(":TRIGger:EDGE:SOURce?"));

myScope.DoCommand(":TRIGger:EDGE:LEVel 1.5");
Console.WriteLine("Trigger edge level: {0}",
    myScope.DoQueryString(":TRIGger:EDGE:LEVel?"));

myScope.DoCommand(":TRIGger:EDGE:SLOPe POSitive");
Console.WriteLine("Trigger edge slope: {0}",
    myScope.DoQueryString(":TRIGger:EDGE:SLOPe?"));

// Save oscilloscope configuration.
byte[] ResultsArray; // Results array.
int nLength; // Number of bytes returned from instrument.
string strPath;

// Query and read setup string.
ResultsArray = myScope.DoQueryIEEEBlock(":SYSTem:SETup?");
nLength = ResultsArray.Length;

// Write setup string to file.
strPath = "c:\\scope\\config\\setup.stp";
FileStream fStream = File.Open(strPath, FileMode.Create);
fStream.Write(ResultsArray, 0, nLength);
fStream.Close();
Console.WriteLine("Setup bytes saved: {0}", nLength);

// Change settings with individual commands:

// Set vertical scale and offset.
myScope.DoCommand(":CHANnel1:SCALe 0.05");
Console.WriteLine("Channel 1 vertical scale: {0}",
    myScope.DoQueryString(":CHANnel1:SCALe?"));

myScope.DoCommand(":CHANnel1:OFFSet -1.5");
Console.WriteLine("Channel 1 vertical offset: {0}",
    myScope.DoQueryString(":CHANnel1:OFFSet?"));

// Set horizontal scale and offset.
myScope.DoCommand(":TIMEbase:SCALe 0.0002");
Console.WriteLine("Timebase scale: {0}",
    myScope.DoQueryString(":TIMEbase:SCALe?"));

myScope.DoCommand(":TIMEbase:POSition 0.0");
Console.WriteLine("Timebase position: {0}",
    myScope.DoQueryString(":TIMEbase:POSition?"));

// Set the acquisition type (NORMAL, PEAK, AVERAGE, or HRESolution
).

```

```

myScope.DoCommand(":ACQuire:TYPE NORMal");
Console.WriteLine("Acquire type: {0}",
    myScope.DoQueryString(":ACQuire:TYPE?"));

// Or, configure by loading a previously saved setup.
byte[] dataArray;
int nBytesWritten;

// Read setup string from file.
strPath = "c:\\scope\\config\\setup.stp";
dataArray = File.ReadAllBytes(strPath);
nBytesWritten = dataArray.Length;

// Restore setup string.
myScope.DoCommandIEEEBlock(":SYSTem:SETup", dataArray);
Console.WriteLine("Setup bytes restored: {0}", nBytesWritten);

// Capture an acquisition using :DIGItize.
myScope.DoCommand(":DIGItize CHANnel1");
}

/*
 * Analyze the captured waveform.
 * -----
 */
private static void Analyze()
{
    byte[] ResultsArray; // Results array.
    int nLength; // Number of bytes returned from instrument.
    string strPath;

    // Make a couple of measurements.
    // -----
    myScope.DoCommand(":MEASure:SOURce CHANnel1");
    Console.WriteLine("Measure source: {0}",
        myScope.DoQueryString(":MEASure:SOURce?"));

    double fResult;
    myScope.DoCommand(":MEASure:FREQuency");
    fResult = myScope.DoQueryNumber(":MEASure:FREQuency?");
    Console.WriteLine("Frequency: {0:F4} kHz", fResult / 1000);

    myScope.DoCommand(":MEASure:VAMplitude");
    fResult = myScope.DoQueryNumber(":MEASure:VAMplitude?");
    Console.WriteLine("Vertical amplitude: {0:F2} V", fResult);

    // Download the screen image.
    // -----
    myScope.DoCommand(":HARDcopy:INKSaver OFF");

    // Get the screen data.
    ResultsArray =
        myScope.DoQueryIEEEBlock(":DISPLAY:DATA? PNG, COLOR");
    nLength = ResultsArray.Length;

    // Store the screen data to a file.
    strPath = "c:\\scope\\data\\screen.png";
}

```

```

FileStream fStream = File.Open(strPath, FileMode.Create);
fStream.Write(ResultsArray, 0, nLength);
fStream.Close();
Console.WriteLine("Screen image ({0} bytes) written to {1}",
    nLength, strPath);

// Download waveform data.
// -----
// Set the waveform points mode.
myScope.DoCommand(":WAVEform:POINTS:MODE RAW");
Console.WriteLine("Waveform points mode: {0}",
    myScope.DoQueryString(":WAVEform:POINTS:MODE?"));

// Get the number of waveform points available.
Console.WriteLine("Waveform points available: {0}",
    myScope.DoQueryString(":WAVEform:POINTS?"));

// Set the waveform source.
myScope.DoCommand(":WAVEform:SOURce CHANnel1");
Console.WriteLine("Waveform source: {0}",
    myScope.DoQueryString(":WAVEform:SOURce?"));

// Choose the format of the data returned (WORD, BYTE, ASCII):
myScope.DoCommand(":WAVEform:FORMAT BYTE");
Console.WriteLine("Waveform format: {0}",
    myScope.DoQueryString(":WAVEform:FORMAT?"));

// Display the waveform settings:
double[] fResultsArray;
fResultsArray = myScope.DoQueryNumbers(":WAVEform:PREamble?");

double fFormat = fResultsArray[0];
if (fFormat == 0.0)
{
    Console.WriteLine("Waveform format: BYTE");
}
else if (fFormat == 1.0)
{
    Console.WriteLine("Waveform format: WORD");
}
else if (fFormat == 2.0)
{
    Console.WriteLine("Waveform format: ASCII");
}

double fType = fResultsArray[1];
if (fType == 0.0)
{
    Console.WriteLine("Acquire type: NORMAL");
}
else if (fType == 1.0)
{
    Console.WriteLine("Acquire type: PEAK");
}
else if (fType == 2.0)
{
}

```

```

        Console.WriteLine("Acquire type: AVERage");
    }
else if (fType == 3.0)
{
    Console.WriteLine("Acquire type: HRESolution");
}

double fPoints = fResultsArray[2];
Console.WriteLine("Waveform points: {0:e}", fPoints);

double fCount = fResultsArray[3];
Console.WriteLine("Waveform average count: {0:e}", fCount);

double fXincrement = fResultsArray[4];
Console.WriteLine("Waveform X increment: {0:e}", fXincrement);

double fXorigin = fResultsArray[5];
Console.WriteLine("Waveform X origin: {0:e}", fXorigin);

double fXreference = fResultsArray[6];
Console.WriteLine("Waveform X reference: {0:e}", fXreference);

double fYincrement = fResultsArray[7];
Console.WriteLine("Waveform Y increment: {0:e}", fYincrement);

double fYorigin = fResultsArray[8];
Console.WriteLine("Waveform Y origin: {0:e}", fYorigin);

double fYreference = fResultsArray[9];
Console.WriteLine("Waveform Y reference: {0:e}", fYreference);

// Read waveform data.
ResultsArray = myScope.DoQueryIEEEBlock(":WAVEFORM:DATA?");
nLength = ResultsArray.Length;
Console.WriteLine("Number of data values: {0}", nLength);

// Set up output file:
strPath = "c:\\scope\\data\\waveform_data.csv";
if (File.Exists(strPath)) File.Delete(strPath);

// Open file for output.
StreamWriter writer = File.CreateText(strPath);

// Output waveform data in CSV format.
for (int i = 0; i < nLength - 1; i++)
    writer.WriteLine("{0:f9}, {1:f6}",
                    fXorigin + ((float)i * fXincrement),
                    (((float)ResultsArray[i] - fYreference)
                     * fYincrement) + fYorigin);

// Close output file.
writer.Close();
Console.WriteLine("Waveform format BYTE data written to {0}",
                 strPath);
}
}

```

```

class VisaComInstrument
{
    private ResourceManagerClass m_ResourceManager;
    private FormattedIO488Class m_IoObject;
    private string m_strVisaAddress;

    // Constructor.
    public VisaComInstrument(string strVisaAddress)
    {
        // Save VISA address in member variable.
        m_strVisaAddress = strVisaAddress;

        // Open the default VISA COM IO object.
        OpenIo();

        // Clear the interface.
        m_IoObject.IO.Clear();
    }

    public void DoCommand(string strCommand)
    {
        // Send the command.
        m_IoObject.WriteString(strCommand, true);

        // Check for inst errors.
        CheckInstrumentErrors(strCommand);
    }

    public void DoCommandIEEEBlock(string strCommand,
                                  byte[] DataArray)
    {
        // Send the command to the device.
        m_IoObject.WriteIEEEBlock(strCommand, DataArray, true);

        // Check for inst errors.
        CheckInstrumentErrors(strCommand);
    }

    public string DoQueryString(string strQuery)
    {
        // Send the query.
        m_IoObject.WriteString(strQuery, true);

        // Get the result string.
        string strResults;
        strResults = m_IoObject.ReadString();

        // Check for inst errors.
        CheckInstrumentErrors(strQuery);

        // Return results string.
        return strResults;
    }

    public double DoQueryNumber(string strQuery)
    {
        // Send the query.

```

```

m_IoObject.WriteString(strQuery, true);

// Get the result number.
double fResult;
fResult = (double)m_IoObject.ReadNumber(
    IEEEASCIIType.ASCIIType_R8, true);

// Check for inst errors.
CheckInstrumentErrors(strQuery);

// Return result number.
return fResult;
}

public double[] DoQueryNumbers(string strQuery)
{
    // Send the query.
    m_IoObject.WriteString(strQuery, true);

    // Get the result numbers.
    double[] fResultsArray;
    fResultsArray = (double[])m_IoObject.ReadList(
        IEEEASCIIType.ASCIIType_R8, ",;");

    // Check for inst errors.
    CheckInstrumentErrors(strQuery);

    // Return result numbers.
    return fResultsArray;
}

public byte[] DoQueryIEEEBlock(string strQuery)
{
    // Send the query.
    m_IoObject.WriteString(strQuery, true);

    // Get the results array.
    System.Threading.Thread.Sleep(2000); // Delay before reading.
    byte[] ResultsArray;
    ResultsArray = (byte[])m_IoObject.ReadIEEEBlock(
        IEEEBinaryType.BinaryType_UI1, false, true);

    // Check for inst errors.
    CheckInstrumentErrors(strQuery);

    // Return results array.
    return ResultsArray;
}

private void CheckInstrumentErrors(string strCommand)
{
    // Check for instrument errors.
    string strInstrumentError;
    bool bFirstError = true;

    do // While not "0,No error".
    {

```

```

m_IoObject.WriteString(":SYSTem:ERRor?", true);
strInstrumentError = m_IoObject.ReadString();

if (!strInstrumentError.ToString().StartsWith("+0,"))
{
    if (bFirstError)
    {
        Console.WriteLine("ERROR(s) for command '{0}': ",
                          strCommand);
        bFirstError = false;
    }
    Console.Write(strInstrumentError);
}
} while (!strInstrumentError.ToString().StartsWith("+0,"));
}

private void OpenIo()
{
    m_ResourceManager = new ResourceManagerClass();
    m_IoObject = new FormattedIO488Class();

    // Open the default VISA COM IO object.
    try
    {
        m_IoObject.IO =
            (IMessage)m_ResourceManager.Open(m_strVisaAddress,
  AccessMode.NO_LOCK, 0, "");
    }
    catch (Exception e)
    {
        Console.WriteLine("An error occurred: {0}", e.Message);
    }
}

public void SetTimeoutSeconds(int nSeconds)
{
    m_IoObject.IO.Timeout = nSeconds * 1000;
}

public void Close()
{
    try
    {
        m_IoObject.IO.Close();
    }
    catch { }

    try
    {
        Marshal.ReleaseComObject(m_IoObject);
    }
    catch { }

    try
    {
        Marshal.ReleaseComObject(m_ResourceManager);
    }
}

```

```
        catch {  
    }  
}  
}
```

# VISA COM Example in Visual Basic .NET

To compile and run this example in Microsoft Visual Studio 2008:

- 1** Open Visual Studio.
  - 2** Create a new Visual Basic, Windows, Console Application project.
  - 3** Cut-and-paste the code that follows into the Visual Basic .NET source file.
  - 4** Edit the program to use the VISA address of your oscilloscope.
  - 5** Add a reference to the VISA COM 5.9 Type Library:
    - a** Right-click the project you wish to modify (not the solution) in the Solution Explorer window of the Microsoft Visual Studio environment.
    - b** Choose **Add Reference....**
    - c** In the Add Reference dialog, select the **COM** tab.
    - d** Select **VISA COM 5.9 Type Library**; then click **OK**.
    - e** Right-click the project you wish to modify (not the solution) in the Solution Explorer window of the Microsoft Visual Studio environment and choose **Properties**; then, select "InfiniiVision.VisaComInstrumentApp" as the **Startup object**.
  - 6** Build and run the program.

For more information, see the VISA COM Help that comes with Keysight IO Libraries Suite.

```
' Keysight VISA COM Example in Visual Basic .NET
' -----
' This program illustrates a few commonly used programming
' features of your Keysight oscilloscope.
' ----

Imports System
Imports System.IO
Imports System.Text
Imports Ivi.Visa.Interop
Imports System.Runtime.InteropServices

Namespace InfiniiVision
    Class VisaComInstrumentApp
        Private Shared myScope As VisaComInstrument

        Public Shared Sub Main(ByVal args As String())
            Try
                myScope = New __
                    VisaComInstrument("USB0::0x0957::0x17A6::US50210029::0::INSTR")
            End Try
        End Sub
    End Class
End Namespace
```

```

)
myScope.SetTimeoutSeconds(10)

' Initialize - start from a known state.
Initialize()

' Capture data.
Capture()

' Analyze the captured waveform.
Analyze()

Catch err As System.ApplicationException
    Console.WriteLine("**** VISA Error Message : " + err.Message)
Catch err As System.SystemException
    Console.WriteLine("**** System Error Message : " + err.Message)
Catch err As System.Exception
    System.Diagnostics.Debug.Fail("Unexpected Error")
    Console.WriteLine("**** Unexpected Error : " + err.Message)
Finally
    myScope.Close()
End Try
End Sub

' Initialize the oscilloscope to a known state.
' -----
Private Shared Sub Initialize()
    Dim strResults As String

    ' Get and display the device's *IDN? string.
    strResults = myScope.DoQueryString("*IDN?")
    Console.WriteLine("*IDN? result is: {0}", strResults)

    ' Clear status and load the default setup.
    myScope.DoCommand("*CLS")
    myScope.DoCommand("*RST")

End Sub

' Capture the waveform.
' -----
Private Shared Sub Capture()

    ' Use auto-scale to automatically configure oscilloscope.
    myScope.DoCommand(":AUToscale")

    ' Set trigger mode (EDGE, PULSe, PATTern, etc., and input source.
    myScope.DoCommand(":TRIGger:MODE EDGE")
    Console.WriteLine("Trigger mode: {0}", _
        myScope.DoQueryString(":TRIGger:MODE?"))

    ' Set EDGE trigger parameters.
    myScope.DoCommand(":TRIGger:EDGE:SOURce CHANnel1")
    Console.WriteLine("Trigger edge source: {0}", _
        myScope.DoQueryString(":TRIGger:EDGE:SOURce?"))

```

```

myScope.DoCommand(":TRIGger:EDGE:LEVel 1.5")
Console.WriteLine("Trigger edge level: {0}", _
    myScope.DoQueryString(":TRIGger:EDGE:LEVel?"))

myScope.DoCommand(":TRIGger:EDGE:SLOPe POSitive")
Console.WriteLine("Trigger edge slope: {0}", _
    myScope.DoQueryString(":TRIGger:EDGE:SLOPe?"))

' Save oscilloscope configuration.
Dim ResultsArray As Byte()      ' Results array.
Dim nLength As Integer         ' Number of bytes returned from inst.
Dim strPath As String
Dim fStream As FileStream

' Query and read setup string.
ResultsArray = myScope.DoQueryIEEEBlock(":SYSTem:SETup?")
nLength = ResultsArray.Length

' Write setup string to file.
strPath = "c:\scope\config\setup.stp"
fStream = File.Open(strPath, FileMode.Create)
fStream.Write(ResultsArray, 0, nLength)
fStream.Close()
Console.WriteLine("Setup bytes saved: {0}", nLength)

' Change settings with individual commands:

' Set vertical scale and offset.
myScope.DoCommand(":CHANnel1:SCALe 0.05")
Console.WriteLine("Channel 1 vertical scale: {0}", _
    myScope.DoQueryString(":CHANnel1:SCALe?"))

myScope.DoCommand(":CHANnel1:OFFSet -1.5")
Console.WriteLine("Channel 1 vertical offset: {0}", _
    myScope.DoQueryString(":CHANnel1:OFFSet?"))

' Set horizontal scale and offset.
myScope.DoCommand(":TIMEbase:SCALe 0.0002")
Console.WriteLine("Timebase scale: {0}", _
    myScope.DoQueryString(":TIMEbase:SCALe?"))

myScope.DoCommand(":TIMEbase:POSition 0.0")
Console.WriteLine("Timebase position: {0}", _
    myScope.DoQueryString(":TIMEbase:POSition?"))

' Set the acquisition type (NORMAL, PEAK, AVERage, or HRESolution)

myScope.DoCommand(":ACQuire:TYPE NORMAL")
Console.WriteLine("Acquire type: {0}", _
    myScope.DoQueryString(":ACQuire:TYPE?"))

' Or, configure by loading a previously saved setup.
Dim DataArray As Byte()
Dim nBytesWritten As Integer

' Read setup string from file.

```

```

strPath = "c:\scope\config\setup.stp"
DataArray = File.ReadAllBytes(strPath)
nBytesWritten = DataArray.Length

' Restore setup string.
myScope.DoCommandIEEEBlock(":SYSTem:SETUp", DataArray)
Console.WriteLine("Setup bytes restored: {0}", nBytesWritten)

' Capture an acquisition using :DIGItize.
myScope.DoCommand(":DIGItize CHANnel1")

End Sub

' Analyze the captured waveform.
' ----

Private Shared Sub Analyze()

Dim fResult As Double
Dim ResultsArray As Byte()      ' Results array.
Dim nLength As Integer         ' Number of bytes returned from inst.
Dim strPath As String

' Make a couple of measurements.
' -----
myScope.DoCommand(":MEASure:SOURce CHANnel1")
Console.WriteLine("Measure source: {0}", _
    myScope.DoQueryString(":MEASure:SOURce?"))

myScope.DoCommand(":MEASure:FREQuency")
fResult = myScope.DoQueryNumber(":MEASure:FREQuency?")
Console.WriteLine("Frequency: {0:F4} kHz", fResult / 1000)

myScope.DoCommand(":MEASure:VAMplitude")
fResult = myScope.DoQueryNumber(":MEASure:VAMplitude?")
Console.WriteLine("Vertical amplitude: {0:F2} V", fResult)

' Download the screen image.
' -----
myScope.DoCommand(":HARDcopy:INKSaver OFF")

' Get the screen data.
ResultsArray = myScope.DoQueryIEEEBlock(":DISPlay:DATA? PNG, COLOR")
nLength = ResultsArray.Length

' Store the screen data to a file.
strPath = "c:\scope\data\screen.png"
Dim fStream As FileStream
fStream = File.Open(strPath, FileMode.Create)
fStream.Write(ResultsArray, 0, nLength)
fStream.Close()
Console.WriteLine("Screen image ({0} bytes) written to {1}", _
    nLength, strPath)

' Download waveform data.
' -----

```

```

' Set the waveform points mode.
myScope.DoCommand(":WAVEform:POINTS:MODE RAW")
Console.WriteLine("Waveform points mode: {0}", _
    myScope.DoQueryString(":WAVEform:POINTS:MODE?"))

' Get the number of waveform points available.
Console.WriteLine("Waveform points available: {0}", _
    myScope.DoQueryString(":WAVEform:POINTS?"))

' Set the waveform source.
myScope.DoCommand(":WAVEform:SOURce CHANnel1")
Console.WriteLine("Waveform source: {0}", _
    myScope.DoQueryString(":WAVEform:SOURce?"))

' Choose the format of the data returned (WORD, BYTE, ASCII):
myScope.DoCommand(":WAVEform:FORMAT BYTE")
Console.WriteLine("Waveform format: {0}", _
    myScope.DoQueryString(":WAVEform:FORMAT?"))

' Display the waveform settings:
Dim fResultsArray As Double()
fResultsArray = myScope.DoQueryNumbers(":WAVEform:PREamble?")

Dim fFormat As Double = fResultsArray(0)
If fFormat = 0 Then
    Console.WriteLine("Waveform format: BYTE")
ElseIf fFormat = 1 Then
    Console.WriteLine("Waveform format: WORD")
ElseIf fFormat = 2 Then
    Console.WriteLine("Waveform format: ASCII")
End If

Dim fType As Double = fResultsArray(1)
If fType = 0 Then
    Console.WriteLine("Acquire type: NORMAL")
ElseIf fType = 1 Then
    Console.WriteLine("Acquire type: PEAK")
ElseIf fType = 2 Then
    Console.WriteLine("Acquire type: AVERAGE")
ElseIf fType = 3 Then
    Console.WriteLine("Acquire type: HRESolution")
End If

Dim fPoints As Double = fResultsArray(2)
Console.WriteLine("Waveform points: {0:e}", fPoints)

Dim fCount As Double = fResultsArray(3)
Console.WriteLine("Waveform average count: {0:e}", fCount)

Dim fxIncrement As Double = fResultsArray(4)
Console.WriteLine("Waveform X increment: {0:e}", fxIncrement)

Dim fxOrigin As Double = fResultsArray(5)
Console.WriteLine("Waveform X origin: {0:e}", fxOrigin)

Dim fxReference As Double = fResultsArray(6)

```

```

Console.WriteLine("Waveform X reference: {0:e}", fXreference)

Dim fYincrement As Double = fResultsArray(7)
Console.WriteLine("Waveform Y increment: {0:e}", fYincrement)

Dim fYorigin As Double = fResultsArray(8)
Console.WriteLine("Waveform Y origin: {0:e}", fYorigin)

Dim fYreference As Double = fResultsArray(9)
Console.WriteLine("Waveform Y reference: {0:e}", fYreference)

' Get the waveform data.
ResultsArray = myScope.DoQueryIEEEBlock(":WAVEFORM:DATA?")
nLength = ResultsArray.Length
Console.WriteLine("Number of data values: {0}", nLength)

' Set up output file:
strPath = "c:\scope\data\waveform_data.csv"
If File.Exists(strPath) Then
    File.Delete(strPath)
End If

' Open file for output.
Dim writer As StreamWriter = File.CreateText(strPath)

' Output waveform data in CSV format.
For index As Integer = 0 To nLength - 1
    ' Write time value, voltage value.
    writer.WriteLine("{0:f9}, {1:f6}", _
                    fXorigin + (CSng(index) * fXincrement), _
                    ((CSng(ResultsArray(index)) - fYreference) * fYincrement) + fYorigin)
Next

' Close output file.
writer.Close()
Console.WriteLine("Waveform format BYTE data written to {0}", strPath)

End Sub

End Class

Class VisaComInstrument
    Private m_ResourceManager As ResourceManagerClass
    Private m_IoObject As FormattedIO488Class
    Private m_strVisaAddress As String

    ' Constructor.
    Public Sub New(ByVal strVisaAddress As String)

        ' Save VISA address in member variable.
        m_strVisaAddress = strVisaAddress

        ' Open the default VISA COM IO object.
        OpenIo()
    End Sub
End Class

```

```

' Clear the interface.
m_IoObject.IO.Clear()

End Sub

Public Sub DoCommand(ByVal strCommand As String)

    ' Send the command.
    m_IoObject.WriteString(strCommand, True)

    ' Check for inst errors.
    CheckInstrumentErrors(strCommand)

End Sub

Public Sub DoCommandIEEEBlock(ByVal strCommand As String, _
    ByVal DataArray As Byte())

    ' Send the command to the device.
    m_IoObject.WriteIEEEBlock(strCommand, DataArray, True)

    ' Check for inst errors.
    CheckInstrumentErrors(strCommand)

End Sub

Public Function DoQueryString(ByVal strQuery As String) As String
    ' Send the query.
    m_IoObject.WriteString(strQuery, True)

    ' Get the result string.
    Dim strResults As String
    strResults = m_IoObject.ReadString()

    ' Check for inst errors.
    CheckInstrumentErrors(strQuery)

    ' Return results string.
    Return strResults
End Function

Public Function DoQueryNumber(ByVal strQuery As String) As Double
    ' Send the query.
    m_IoObject.WriteString(strQuery, True)

    ' Get the result number.
    Dim fResult As Double
    fResult = _
        CDbl(m_IoObject.ReadNumber(IEEEASCIIType.ASCIIType_R8, True))

    ' Check for inst errors.
    CheckInstrumentErrors(strQuery)

    ' Return result number.
    Return fResult
End Function

```

```

Public Function DoQueryNumbers(ByVal strQuery As String) As _
    Double()
    ' Send the query.
    m_IoObject.WriteString(strQuery, True)

    ' Get the result numbers.
    Dim fResultsArray As Double()
    fResultsArray = _
        m_IoObject.ReadList(IEEEASCIIType.ASCIIType_R8, ", ;")

    ' Check for inst errors.
    CheckInstrumentErrors(strQuery)

    ' Return result numbers.
    Return fResultsArray
End Function

Public _
Function DoQueryIEEEBlock(ByVal strQuery As String) As Byte()
    ' Send the query.
    m_IoObject.WriteString(strQuery, True)

    ' Get the results array.
    System.Threading.Thread.Sleep(2000) ' Delay before reading data.
    Dim ResultsArray As Byte()
    ResultsArray = _
        m_IoObject.ReadIEEEBlock(IEEEBinaryType.BinaryType_UI1, _
        False, True)

    ' Check for inst errors.
    CheckInstrumentErrors(strQuery)

    ' Return results array.
    Return ResultsArray
End Function

Private Sub CheckInstrumentErrors(ByVal strCommand As String)
    ' Check for instrument errors.
    Dim strInstrumentError As String
    Dim bFirstError As Boolean = True
    Do      ' While not "0,No error".
        m_IoObject.WriteString(":SYSTem:ERRor?", True)
        strInstrumentError = m_IoObject.ReadString()

        If Not strInstrumentError.ToString().StartsWith("+0,") Then
            If bFirstError Then
                Console.WriteLine("ERROR(s) for command '{0}': {1}, _", _
                    strCommand)
                bFirstError = False
            End If
            Console.Write(strInstrumentError)
        End If
    Loop While Not strInstrumentError.ToString().StartsWith("+0,")
End Sub

Private Sub OpenIo()
    m_ResourceManager = New ResourceManagerClass()

```

```

m_IoObject = New FormattedIO488Class()

' Open the default VISA COM IO object.
Try
    m_IoObject.IO =
        DirectCast(m_ResourceManager.Open(m_strVisaAddress, _
            AccessMode.NO_LOCK, 0, ""), IMessage)
Catch e As Exception
    Console.WriteLine("An error occurred: {0}", e.Message)
End Try
End Sub

Public Sub SetTimeoutSeconds(ByVal nSeconds As Integer)
    m_IoObject.IO.Timeout = nSeconds * 1000
End Sub

Public Sub Close()
    Try
        m_IoObject.IO.Close()
    Catch
        End Try

    Try
        Marshal.ReleaseComObject(m_IoObject)
    Catch
        End Try

    Try
        Marshal.ReleaseComObject(m_ResourceManager)
    Catch
        End Try
    End Sub
End Class
End Namespace

```

### VISA COM Example in Python 3

You can use the Python programming language with the "comtypes" package to control Keysight oscilloscopes.

The Python language and "comtypes" package can be downloaded from the web at <http://www.python.org/> and <https://pypi.org/project/comtypes/>, respectively.

To run this example with Python and "comtypes":

- 1 Cut-and-paste the code that follows into a file named "example.py".
- 2 Edit the program to use the VISA address of your oscilloscope.
- 3 If "python.exe" can be found via your PATH environment variable, open a Command Prompt window; then, change to the folder that contains the "example.py" file, and enter:

```

python example.py

#!python3
#

```

```

# Keysight VISA COM Example in Python using "comtypes"
# ****
# This program illustrates a few commonly used programming
# features of your Keysight oscilloscope.
# ****

# Import Python modules.
# -----
import string
import time
import sys
import array

from comtypes.client import GetModule
from comtypes.client import CreateObject

# Run GetModule once to generate comtypes.gen.VisaComLib.
if not hasattr(sys, "frozen"):
    GetModule("C:\Program Files (x86)\IVI Foundation\VISA\VisaCom\
GlobMgr.dll")

import comtypes.gen.VisaComLib as VisaComLib

# Global variables (booleans: 0 = False, 1 = True).
# ----

# =====
# Initialize:
# =====
def initialize():
    # Get and display the device's *IDN? string.
    idn_string = do_query_string("*IDN?")
    print("Identification string '%s'" % idn_string)

    # Clear status and load the default setup.
    do_command("*CLS")
    do_command("*RST")

# =====
# Capture:
# =====
def capture():

    # Use auto-scale to automatically set up oscilloscope.
    print("Autoscale.")
    do_command(":AUToscale")

    # Set trigger mode.
    do_command(":TRIGger:MODE EDGE")
    qresult = do_query_string(":TRIGger:MODE?")
    print("Trigger mode: %s" % qresult)

    # Set EDGE trigger parameters.
    do_command(":TRIGger:EDGE:SOURce CHANnel1")

```

```

qresult = do_query_string(":TRIGger:EDGE:SOURce?")
print("Trigger edge source: %s" % qresult)

do_command(":TRIGger:EDGE:LEVel 1.5")
qresult = do_query_string(":TRIGger:EDGE:LEVel?")
print("Trigger edge level: %s" % qresult)

do_command(":TRIGger:EDGE:SLOPe POSitive")
qresult = do_query_string(":TRIGger:EDGE:SLOPe?")
print("Trigger edge slope: %s" % qresult)

# Save oscilloscope setup.
setup_bytes = do_query_ieee_block(":SYSTem:SETup?")
nLength = len(setup_bytes)
f = open("setup.stp", "wb")
f.write(bytarray(setup_bytes))
f.close()
print("Setup bytes saved: %d" % nLength)

# Change oscilloscope settings with individual commands:

# Set vertical scale and offset.
do_command(":CHANnel1:SCALe 0.05")
qresult = do_query_number(":CHANnel1:SCALe?")
print("Channel 1 vertical scale: %f" % qresult)

do_command(":CHANnel1:OFFSet -1.5")
qresult = do_query_number(":CHANnel1:OFFSet?")
print("Channel 1 offset: %f" % qresult)

# Set horizontal scale and offset.
do_command(":TIMEbase:SCALe 0.0002")
qresult = do_query_string(":TIMEbase:SCALe?")
print("Timebase scale: %s" % qresult)

do_command(":TIMEbase:POSItion 0.0")
qresult = do_query_string(":TIMEbase:POSItion?")
print("Timebase position: %s" % qresult)

# Set the acquisition type.
do_command(":ACQuire:TYPE NORMal")
qresult = do_query_string(":ACQuire:TYPE?")
print("Acquire type: %s" % qresult)

# Or, configure by loading a previously saved setup.
f = open("setup.stp", "rb")
setup_bytes = f.read()
f.close()
do_command_ieee_block(":SYSTem:SETup", array.array('B', setup_bytes))
print("Setup bytes restored: %d" % len(setup_bytes))

# Capture an acquisition using :DIGItize.
do_command(":DIGItize CHANnel1")

# =====
# Analyze:

```

```

# =====
def analyze():

    # Make measurements.
    #
    do_command(":MEASure:SOURce CHANnel1")
    qresult = do_query_string(":MEASure:SOURce?")
    print("Measure source: %s" % qresult)

    do_command(":MEASure:FREQuency")
    qresult = do_query_string(":MEASure:FREQuency?")
    print("Measured frequency on channel 1: %s" % qresult)

    do_command(":MEASure:VAMPplitude")
    qresult = do_query_string(":MEASure:VAMPplitude?")
    print("Measured vertical amplitude on channel 1: %s" % qresult)

    # Download the screen image.
    #
    do_command(":HARDcopy:INKSaver OFF")

    image_bytes = do_query_ieee_block(":DISPLAY:DATA? PNG, COLOR")
    nLength = len(image_bytes)
    f = open("screen.png", "wb")
    f.write(bytarray(image_bytes))
    f.close()
    print("Screen image written to screen.png.")

    # Download waveform data.
    #

    # Set the waveform points mode.
    do_command(":WAVeform:POINts:MODE RAW")
    qresult = do_query_string(":WAVeform:POINts:MODE?")
    print("Waveform points mode: %s" % qresult)

    # Get the number of waveform points available.
    do_command(":WAVeform:POINts 10240")
    qresult = do_query_string(":WAVeform:POINts?")
    print("Waveform points available: %s" % qresult)

    # Set the waveform source.
    do_command(":WAVeform:SOURce CHANnel1")
    qresult = do_query_string(":WAVeform:SOURce?")
    print("Waveform source: %s" % qresult)

    # Choose the format of the data returned.
    do_command(":WAVeform:FORMat BYTE")
    print("Waveform format: %s" % do_query_string(":WAVeform:FORMat?"))

    # Display the waveform settings from preamble:
    wav_form_dict = {
        0 : "BYTE",
        1 : "WORD",
        4 : "ASCII",
    }
    acq_type_dict = {

```

```

0 : "NORMAl",
1 : "PEAK",
2 : "AVERage",
3 : "HRESolution",
}

(
wav_form,
acq_type,
wfmpnts,
avgcnt,
x_increment,
x_origin,
x_reference,
y_increment,
y_origin,
y_reference
) = do_query_numbers(":WAVEform:PREamble?")

print("Waveform format: %s" % wav_form_dict[wav_form])
print("Acquire type: %s" % acq_type_dict[acq_type])
print("Waveform points desired: %d" % wfmpnts)
print("Waveform average count: %d" % avgcnt)
print("Waveform X increment: %1.12f" % x_increment)
print("Waveform X origin: %1.9f" % x_origin)
print("Waveform X reference: %d" % x_reference)    # Always 0.
print("Waveform Y increment: %f" % y_increment)
print("Waveform Y origin: %f" % y_origin)
print("Waveform Y reference: %d" % y_reference)    # Always 125.

# Get numeric values for later calculations.
x_increment = do_query_number(":WAVEform:XINCrement?")
x_origin = do_query_number(":WAVEform:XORigin?")
y_increment = do_query_number(":WAVEform:YINCrement?")
y_origin = do_query_number(":WAVEform:YORigin?")
y_reference = do_query_number(":WAVEform:YREFerence?")

# Get the waveform data.
data_bytes = do_query_ieee_block(":WAVEform:DATA?")
nLength = len(data_bytes)
print("Number of data values: %d" % nLength)

# Open file for output.
strPath = "waveform_data.csv"
f = open(strPath, "w")

# Output waveform data in CSV format.
for i in range(0, nLength - 1):
    time_val = x_origin + (i * x_increment)
    voltage = (data_bytes[i] - y_reference) * y_increment + y_origin
    f.write("%E, %f\n" % (time_val, voltage))

# Close output file.
f.close()
print("Waveform format BYTE data written to %s." % strPath)

```

```

# =====
# Send a command and check for errors:
# =====
def do_command(command):
    myScope.WriteString("%s" % command, True)
    check_instrument_errors(command)

# =====
# Send a command and check for errors:
# =====
def do_command_ieee_block(command, data):
    myScope.WriteIEEEBlock(command, data, True)
    check_instrument_errors(command)

# =====
# Send a query, check for errors, return string:
# =====
def do_query_string(query):
    myScope.WriteString("%s" % query, True)
    result = myScope.ReadString()
    check_instrument_errors(query)
    return result

# =====
# Send a query, check for errors, return string:
# =====
def do_query_ieee_block(query):
    myScope.WriteString("%s" % query, True)
    result = myScope.ReadIEEEBlock(VisaComLib.BinaryType_UI1, \
        False, True)
    check_instrument_errors(query)
    return result

# =====
# Send a query, check for errors, return values:
# =====
def do_query_number(query):
    myScope.WriteString("%s" % query, True)
    result = myScope.ReadNumber(VisaComLib.ASCIIType_R8, True)
    check_instrument_errors(query)
    return result

# =====
# Send a query, check for errors, return values:
# =====
def do_query_numbers(query):
    myScope.WriteString("%s" % query, True)
    result = myScope.ReadList(VisaComLib.ASCIIType_R8, ", ;")
    check_instrument_errors(query)
    return result

```

```

# =====
# Check for instrument errors:
# =====
def check_instrument_errors(command):

    while True:
        myScope.WriteString(":SYSTem:ERRor?", True)
        error_string = myScope.ReadString()
        if error_string:    # If there is an error string value.

            if error_string.find("+0," , 0, 3) == -1:    # Not "No error".
                print("ERROR: %s, command: '%s'" % (error_string, command))
                print("Exited because of error.")
                sys.exit(1)

            else:    # "No error"
                break

        else:    # :SYSTem:ERRor? should always return string.
            print("ERROR: :SYSTem:ERRor? returned nothing, command: '%s' \
                  % command)
            print("Exited because of error.")
            sys.exit(1)

# =====
# Main program:
# =====
rm = CreateObject("VISA.GlobalRM", \
    interface=VisaComLib.IResourceManager)
myScope = CreateObject("VISA.BasicFormattedIO", \
    interface=VisaComLib.IFormattedIO488)
myScope.IO = \
    rm.Open("TCPIPO::a-mso-x-2260014.cos.is.keysight.com::inst0::INSTR")

# Clear the interface.
myScope.IO.Clear()
print("Interface cleared.")

# Set the Timeout to 15 seconds.
myScope.IO.Timeout = 15000    # 15 seconds.
print("Timeout set to 15000 milliseconds.")

# Initialize the oscilloscope, capture data, and analyze.
initialize()
capture()
analyze()

myScope.IO.Close()
print("End of program")
sys.exit()

```

## VISA Examples

- "VISA Example in C" on page 1709
- "VISA Example in Visual Basic" on page 1718
- "VISA Example in C#" on page 1728
- "VISA Example in Visual Basic .NET" on page 1739
- "VISA Example in Python 3" on page 1749

### VISA Example in C

To compile and run this example in Microsoft Visual Studio 2008:

- 1 Open Visual Studio.
- 2 Create a new Visual C++, Win32, Win32 Console Application project.
- 3 In the Win32 Application Wizard, click **Next >**. Then, check **Empty project**, and click **Finish**.
- 4 Cut-and-paste the code that follows into a file named "example.c" in the project directory.
- 5 In Visual Studio 2008, right-click the Source Files folder, choose **Add > Add Existing Item...**, select the example.c file, and click **Add**.
- 6 Edit the program to use the VISA address of your oscilloscope.
- 7 Choose **Project > Properties....** In the Property Pages dialog, update these project settings:
  - a Under Configuration Properties, Linker, Input, add "visa32.lib" to the Additional Dependencies field.
  - b Under Configuration Properties, C/C++, Code Generation, select Multi-threaded DLL for the Runtime Library field.
  - c Click **OK** to close the Property Pages dialog.
- 8 Add the include files and library files search paths:
  - a Choose **Tools > Options....**
  - b In the Options dialog, under Projects and Solutions, select **VC++ Directories**.
  - c Show directories for **Include files**, and add the include directory (for example, Program Files (x86)\IVI Foundation\VISA\WinNT\Include).
  - d Show directories for **Library files**, and add the library files directory (for example, Program Files (x86)\IVI Foundation\VISA\WinNT\lib\msc).
  - e Click **OK** to close the Options dialog.
- 9 Build and run the program.

```
/*
 * Keysight VISA Example in C
 * -----
 */
```

```

* This program illustrates a few commonly-used programming
* features of your Keysight oscilloscope.
*/

#include <stdio.h>           /* For printf(). */
#include <string.h>          /* For strcpy(), strcat(). */
#include <time.h>            /* For clock(). */
#include <visa.h>             /* Keysight VISA routines. */

#define VISA_ADDRESS "USB0::0x0957::0x17A6::US50210029::0::INSTR"
#define IEEEBLOCK_SPACE 5000000

/* Function prototypes */
void initialize(void);           /* Initialize to known state. */
void capture(void);              /* Capture the waveform. */
void analyze(void);              /* Analyze the captured waveform. */

void do_command(char *command);   /* Send command. */
int do_command_ieeeblock(char *command); /* Command w/IEEE block. */
void do_query_string(char *query); /* Query for string. */
void do_query_number(char *query); /* Query for number. */
void do_query_numbers(char *query); /* Query for numbers. */
int do_query_ieeeblock(char *query); /* Query for IEEE block. */
void check_instrument_errors();   /* Check for inst errors. */
void error_handler();            /* VISA error handler. */

/* Global variables */
ViSession defaultRM, vi;         /* Device session ID. */
ViStatus err;                   /* VISA function return value. */
char str_result[256] = {0};       /* Result from do_query_string(). */
double num_result;              /* Result from do_query_number(). */
unsigned char ieeeblock_data[IEEEBLOCK_SPACE]; /* Result from
   do_query_ieeeblock(). */
double dbl_results[10];          /* Result from do_query_numbers(). */

/* Main Program
 * -----
void main(void)
{
    /* Open the default resource manager session. */
    err = viOpenDefaultRM(&defaultRM);
    if (err != VI_SUCCESS) error_handler();

    /* Open the session using the oscilloscope's VISA address. */
    err = viOpen(defaultRM, VISA_ADDRESS, VI_NULL, VI_NULL, &vi);
    if (err != VI_SUCCESS) error_handler();

    /* Set the I/O timeout to fifteen seconds. */
    err = viSetAttribute(vi, VI_ATTR_TMO_VALUE, 15000);
    if (err != VI_SUCCESS) error_handler();

    /* Initialize - start from a known state. */
    initialize();

    /* Capture data. */
    capture();
}

```

```

/* Analyze the captured waveform. */
analyze();

/* Close the vi session and the resource manager session. */
viClose(vi);
viClose(defaultRM);
}

/* Initialize the oscilloscope to a known state.
 * -----
void initialize (void)
{
    /* Clear the interface. */
    err = viClear(vi);
    if (err != VI_SUCCESS) error_handler();

    /* Get and display the device's *IDN? string. */
    do_query_string("*IDN?");
    printf("Oscilloscope *IDN? string: %s\n", str_result);

    /* Clear status and load the default setup. */
    do_command("*CLS");
    do_command("*RST");
}

/* Capture the waveform.
 * -----
void capture (void)
{
    int num_bytes;
    FILE *fp;

    /* Use auto-scale to automatically configure oscilloscope. */
    do_command(":AUToscale");

    /* Set trigger mode (EDGE, PULSe, PATTern, etc., and input source. */
    do_command(":TRIGger:MODE EDGE");
    do_query_string(":TRIGger:MODE?");
    printf("Trigger mode: %s\n", str_result);

    /* Set EDGE trigger parameters. */
    do_command(":TRIGger:EDGE:SOURce CHANnel1");
    do_query_string(":TRIGger:EDGE:SOURce?");
    printf("Trigger edge source: %s\n", str_result);

    do_command(":TRIGger:EDGE:LEVel 1.5");
    do_query_string(":TRIGger:EDGE:LEVel?");
    printf("Trigger edge level: %s\n", str_result);

    do_command(":TRIGger:EDGE:SLOPe POSitive");
    do_query_string(":TRIGger:EDGE:SLOPe?");
    printf("Trigger edge slope: %s\n", str_result);

    /* Save oscilloscope configuration. */

    /* Read system setup. */
    num_bytes = do_query_ieeeblock(":SYSTem:SETUp?");
}

```

```

printf("Read setup string query (%d bytes).\\n", num_bytes);

/* Write setup string to file. */
fp = fopen ("c:\\scope\\config\\setup.stp", "wb");
num_bytes = fwrite(ieeeblock_data, sizeof(unsigned char), num_bytes,
    fp);
fclose (fp);
printf("Wrote setup string (%d bytes) to ", num_bytes);
printf("c:\\scope\\config\\setup.stp.\\n");

/* Change settings with individual commands:

/* Set vertical scale and offset. */
do_command(":CHANnel1:SCALe 0.05");
do_query_string(":CHANnel1:SCALe?");
printf("Channel 1 vertical scale: %s\\n", str_result);

do_command(":CHANnel1:OFFSet -1.5");
do_query_string(":CHANnel1:OFFSet?");
printf("Channel 1 offset: %s\\n", str_result);

/* Set horizontal scale and offset. */
do_command(":TIMEbase:SCALe 0.0002");
do_query_string(":TIMEbase:SCALe?");
printf("Timebase scale: %s\\n", str_result);

do_command(":TIMEbase:POSItion 0.0");
do_query_string(":TIMEbase:POSItion?");
printf("Timebase position: %s\\n", str_result);

/* Set the acquisition type (NORMal, PEAK, AVERage, or HRESolution). */
/
do_command(":ACQuire:TYPE NORMal");
do_query_string(":ACQuire:TYPE?");
printf("Acquire type: %s\\n", str_result);

/* Or, configure by loading a previously saved setup. */

/* Read setup string from file. */
fp = fopen ("c:\\scope\\config\\setup.stp", "rb");
num_bytes = fread (ieeeblock_data, sizeof(unsigned char),
    IEEEBLOCK_SPACE, fp);
fclose (fp);
printf("Read setup string (%d bytes) from file ", num_bytes);
printf("c:\\scope\\config\\setup.stp.\\n");

/* Restore setup string. */
num_bytes = do_command_ieeeblock(":SYSTem:SETUp", num_bytes);
printf("Restored setup string (%d bytes).\\n", num_bytes);

/* Capture an acquisition using :DIGItize. */
do_command(":DIGItize CHANnel1");
}

/* Analyze the captured waveform.
* -----
void analyze (void)

```

```

{
    double wav_format;
    double acq_type;
    double wav_points;
    double avg_count;
    double x_increment;
    double x_origin;
    double x_reference;
    double y_increment;
    double y_origin;
    double y_reference;

    FILE *fp;
    int num_bytes; /* Number of bytes returned from instrument. */
    int i;

    /* Make a couple of measurements.
     * -----
     do_command(":MEASure:SOURce CHANnel1");
     do_query_string(":MEASure:SOURce?");
     printf("Measure source: %s\n", str_result);

     do_command(":MEASure:FREQuency");
     do_query_number(":MEASure:FREQuency?");
     printf("Frequency: %.4f kHz\n", num_result / 1000);

     do_command(":MEASure:VAMPplitude");
     do_query_number(":MEASure:VAMPplitude?");
     printf("Vertical amplitude: %.2f V\n", num_result);

    /* Download the screen image.
     * -----
     do_command(":HARDcopy:INKSaver OFF");

    /* Read screen image. */
    num_bytes = do_query_ieeeblock(":DISPlay:DATA? PNG, COLOR");
    printf("Screen image bytes: %d\n", num_bytes);

    /* Write screen image bytes to file. */
    fp = fopen ("c:\\scope\\data\\screen.png", "wb");
    num_bytes = fwrite(ieeeblock_data, sizeof(unsigned char), num_bytes,
                      fp);
    fclose (fp);
    printf("Wrote screen image (%d bytes) to ", num_bytes);
    printf("c:\\scope\\data\\screen.png.\n");

    /* Download waveform data.
     * -----
     */

    /* Set the waveform points mode. */
    do_command(":WAVeform:POINTS:MODE RAW");
    do_query_string(":WAVeform:POINTS:MODE?");
    printf("Waveform points mode: %s\n", str_result);

    /* Get the number of waveform points available. */
    do_query_string(":WAVeform:POINTS?");
    printf("Waveform points available: %s\n", str_result);
}

```

```

/* Set the waveform source. */
do_command(":WAVeform:SOURce CHANnel1");
do_query_string(":WAVeform:SOURce?");
printf("Waveform source: %s\n", str_result);

/* Choose the format of the data returned (WORD, BYTE, ASCII) : */
do_command(":WAVeform:FORMAT BYTE");
do_query_string(":WAVeform:FORMAT?");
printf("Waveform format: %s\n", str_result);

/* Display the waveform settings: */
do_query_numbers(":WAVeform:PREamble?");

wav_format = dbl_results[0];
if (wav_format == 0.0)
{
    printf("Waveform format: BYTE\n");
}
else if (wav_format == 1.0)
{
    printf("Waveform format: WORD\n");
}
else if (wav_format == 2.0)
{
    printf("Waveform format: ASCII\n");
}

acq_type = dbl_results[1];
if (acq_type == 0.0)
{
    printf("Acquire type: NORMAL\n");
}
else if (acq_type == 1.0)
{
    printf("Acquire type: PEAK\n");
}
else if (acq_type == 2.0)
{
    printf("Acquire type: AVERage\n");
}
else if (acq_type == 3.0)
{
    printf("Acquire type: HRESolution\n");
}

wav_points = dbl_results[2];
printf("Waveform points: %e\n", wav_points);

avg_count = dbl_results[3];
printf("Waveform average count: %e\n", avg_count);

x_increment = dbl_results[4];
printf("Waveform X increment: %e\n", x_increment);

x_origin = dbl_results[5];
printf("Waveform X origin: %e\n", x_origin);

```

```

x_reference = dbl_results[6];
printf("Waveform X reference: %e\n", x_reference);

y_increment = dbl_results[7];
printf("Waveform Y increment: %e\n", y_increment);

y_origin = dbl_results[8];
printf("Waveform Y origin: %e\n", y_origin);

y_reference = dbl_results[9];
printf("Waveform Y reference: %e\n", y_reference);

/* Read waveform data. */
num_bytes = do_query_ieeeblock(":WAVEform:DATA?");
printf("Number of data values: %d\n", num_bytes);

/* Open file for output. */
fp = fopen("c:\\scope\\data\\waveform_data.csv", "wb");

/* Output waveform data in CSV format. */
for (i = 0; i < num_bytes - 1; i++)
{
    /* Write time value, voltage value. */
    fprintf(fp, "%9f, %6f\n",
            x_origin + ((float)i * x_increment),
            (((float)ieeeblock_data[i] - y_reference) * y_increment)
            + y_origin);
}

/* Close output file. */
fclose(fp);
printf("Waveform format BYTE data written to ");
printf("c:\\scope\\data\\waveform_data.csv.\n");
}

/* Send a command to the instrument.
 * -----
void do_command(command)
char *command;
{
    char message[80];

    strcpy(message, command);
    strcat(message, "\n");
    err = viPrintf(vi, message);
    if (err != VI_SUCCESS) error_handler();

    check_instrument_errors();
}

/* Command with IEEE definite-length block.
 * -----
int do_command_ieeeblock(command, num_bytes)
char *command;
int num_bytes;
{

```

```

        char message[80];
        int data_length;

        strcpy(message, command);
        strcat(message, " #8%08d");
        err = viPrintf(vi, message, num_bytes);
        if (err != VI_SUCCESS) error_handler();

        err = viBufWrite(vi, ieeeblock_data, num_bytes, &data_length);
        if (err != VI_SUCCESS) error_handler();

        check_instrument_errors();

        return(data_length);
    }

/* Query for a string result.
 * -----
void do_query_string(query)
char *query;
{
    char message[80];

    strcpy(message, query);
    strcat(message, "\n");

    err = viPrintf(vi, message);
    if (err != VI_SUCCESS) error_handler();

    err = viScanf(vi, "%t", str_result);
    if (err != VI_SUCCESS) error_handler();

    check_instrument_errors();
}

/* Query for a number result.
 * -----
void do_query_number(query)
char *query;
{
    char message[80];

    strcpy(message, query);
    strcat(message, "\n");

    err = viPrintf(vi, message);
    if (err != VI_SUCCESS) error_handler();

    err = viScanf(vi, "%lf", &num_result);
    if (err != VI_SUCCESS) error_handler();

    check_instrument_errors();
}

/* Query for numbers result.
 * -----
void do_query_numbers(query)

```

```

char *query;
{
    char message[80];

    strcpy(message, query);
    strcat(message, "\n");

    err = viPrintf(vi, message);
    if (err != VI_SUCCESS) error_handler();

    err = viScanf(vi, "%,10lf\n", dbl_results);
    if (err != VI_SUCCESS) error_handler();

    check_instrument_errors();
}

/* Query for an IEEE definite-length block result.
 * -----
int do_query_ieeeblock(query)
char *query;
{
    char message[80];
    int data_length;

    strcpy(message, query);
    strcat(message, "\n");
    err = viPrintf(vi, message);
    if (err != VI_SUCCESS) error_handler();

    data_length = IEEEBLOCK_SPACE;
    err = viScanf(vi, "%#b\n", &data_length, ieeeblock_data);
    if (err != VI_SUCCESS) error_handler();

    if (data_length == IEEEBLOCK_SPACE )
    {
        printf("IEEE block buffer full: ");
        printf("May not have received all data.\n");
    }

    check_instrument_errors();

    return(data_length);
}

/* Check for instrument errors.
 * -----
void check_instrument_errors()
{
    char str_err_val[256] = {0};
    char str_out[800] = "";

    err = viQueryf(vi, ":SYSTem:ERRor?\n", "%t", str_err_val);
    if (err != VI_SUCCESS) error_handler();
    while(strncmp(str_err_val, "+0,No error", 3) != 0 )
    {
        strcat(str_out, ", ");
        strcat(str_out, str_err_val);
}

```

```

        err = viQueryf(vi, ":SYSTem:ERRor?\n", "%t", str_err_val);
        if (err != VI_SUCCESS) error_handler();
    }

    if (strcmp(str_out, "") != 0)
    {
        printf("INST Error%s\n", str_out);
        err = viFlush(vi, VI_READ_BUF);
        if (err != VI_SUCCESS) error_handler();
        err = viFlush(vi, VI_WRITE_BUF);
        if (err != VI_SUCCESS) error_handler();
    }
}

/* Handle VISA errors.
 * -----
void error_handler()
{
    char err_msg[1024] = {0};

    viStatusDesc(vi, err, err_msg);
    printf("VISA Error: %s\n", err_msg);
    if (err < VI_SUCCESS)
    {
        exit(1);
    }
}

```

## VISA Example in Visual Basic

To run this example in Visual Basic for Applications:

- 1** Start the application that provides Visual Basic for Applications (for example, Microsoft Excel).
- 2** Press ALT+F11 to launch the Visual Basic editor.
- 3** Add the visa32.bas file to your project:
  - a** Choose **File > Import File....**
  - b** Navigate to the header file, visa32.bas (installed with Keysight IO Libraries Suite and found in the Program Files (x86)\IVI Foundation\VISA\WinNT\Include), select it, and click **Open**.
- 4** Choose **Insert > Module**.
- 5** Cut-and-paste the code that follows into the editor.
- 6** Edit the program to use the VISA address of your oscilloscope, and save the changes.
- 7** Run the program.

```

'
' Keysight VISA Example in Visual Basic
' -----
' This program illustrates a few commonly-used programming

```

```

' features of your Keysight oscilloscope.
' -----
Option Explicit

Public err As Long      ' Error returned by VISA function calls.
Public drm As Long      ' Session to Default Resource Manager.
Public vi As Long        ' Session to instrument.

' Declare variables to hold numeric values returned by
' viVScanf/viVQueryf.
Public dblQueryResult As Double
Public Const ByteArraySize = 5000000
Public retCount As Long
Public byteArray(ByteArraySize) As Byte
Public paramsArray(2) As Long
Public Const DblArraySize = 20
Public dblArray(DblArraySize) As Double

' Declare fixed length string variable to hold string value returned
' by viVScanf/viVQueryf.
Public strQueryResult As String * 200

' For Sleep subroutine.
Private Declare Sub Sleep Lib "kernel32" (ByVal dwMilliseconds As Long)

'
' Main Program
' -----
Sub Main()

    ' Open the default resource manager session.
    err = viOpenDefaultRM(drm)
    If (err <> VI_SUCCESS) Then HandleVISAError drm

    ' Open the session using the oscilloscope's VISA address.
    err = viOpen(drm, _
                "USB0::0x0957::0x17A6::US50210029::0::INSTR", 0, 15000, vi)
    If (err <> VI_SUCCESS) Then HandleVISAError drm

    ' Set the I/O timeout to ten seconds.
    err = viSetAttribute(vi, VI_ATTR_TMO_VALUE, 10000)
    If (err <> VI_SUCCESS) Then HandleVISAError vi

    ' Initialize - start from a known state.
    Initialize

    ' Capture data.
    Capture

    ' Analyze the captured waveform.
    Analyze

    ' Close the vi session and the resource manager session.
    err = viClose(vi)
    err = viClose(drm)

```

```

End Sub

'

' Initialize the oscilloscope to a known state.
' -----
Private Sub Initialize()

    ' Clear the interface.
    err = viClear(vi)
    If Not (err = VI_SUCCESS) Then HandleVISAError vi

    ' Get and display the device's *IDN? string.
    strQueryResult = DoQueryString("*IDN?")
    MsgBox "*IDN? string: " + strQueryResult, vbOKOnly, "*IDN? Result"

    ' Clear status and load the default setup.
    DoCommand "*CLS"
    DoCommand "*RST"

End Sub

'

' Capture the waveform.
' -----
Private Sub Capture()

    ' Use auto-scale to automatically configure oscilloscope.
    ' -----
    DoCommand ":AUToscale"

    ' Set trigger mode (EDGE, PULSe, PATTern, etc., and input source.
    DoCommand ":TRIGger:MODE EDGE"
    Debug.Print "Trigger mode: " + _
        DoQueryString(":TRIGger:MODE?")

    ' Set EDGE trigger parameters.
    DoCommand ":TRIGger:EDGE:SOURce CHANnel1"
    Debug.Print "Trigger edge source: " + _
        DoQueryString(":TRIGger:EDGE:SOURce?")

    DoCommand ":TRIGger:EDGE:LEVel 1.5"
    Debug.Print "Trigger edge level: " + _
        DoQueryString(":TRIGger:EDGE:LEVel?")

    DoCommand ":TRIGger:EDGE:SLOPe POSitive"
    Debug.Print "Trigger edge slope: " + _
        DoQueryString(":TRIGger:EDGE:SLOPe?")

    ' Save oscilloscope configuration.
    ' -----
    Dim lngSetupStringSize As Long
    lngSetupStringSize = DoQueryIEEEBlock_Bytes(":SYStem:SETup?")
    Debug.Print "Setup bytes saved: " + CStr(lngSetupStringSize)

```

```

' Output setup string to a file:
Dim strPath As String
strPath = "c:\scope\config\setup.dat"
If Len(Dir(strPath)) Then
    Kill strPath      ' Remove file if it exists.
End If

' Open file for output.
Dim hFile As Long
hFile = FreeFile
Open strPath For Binary Access Write Lock Write As hFile
Dim lngI As Long
For lngI = 0 To lngSetupStringSize - 1
    Put hFile, , byteArray(lngI)      ' Write data.
Next lngI
Close hFile      ' Close file.

' Change settings with individual commands:
' -----
' Set vertical scale and offset.
DoCommand ":CHANnel1:SCALe 0.05"
Debug.Print "Channel 1 vertical scale: " + _
    DoQueryString(":CHANnel1:SCALe?")

DoCommand ":CHANnel1:OFFSet -1.5"
Debug.Print "Channel 1 vertical offset: " + _
    DoQueryString(":CHANnel1:OFFSet?")

' Set horizontal scale and position.
DoCommand ":TIMEbase:SCALe 0.0002"
Debug.Print "Timebase scale: " + _
    DoQueryString(":TIMEbase:SCALe?")

DoCommand ":TIMEbase:POSIon 0.0"
Debug.Print "Timebase position: " + _
    DoQueryString(":TIMEbase:POSIon?")

' Set the acquisition type (NORMal, PEAK, AVERage, or HRESolution).
DoCommand ":ACQuire:TYPE NORMal"
Debug.Print "Acquire type: " + _
    DoQueryString(":ACQuire:TYPE?")

' Or, configure by loading a previously saved setup.
' -----
strPath = "c:\scope\config\setup.dat"
Open strPath For Binary Access Read As hFile      ' Open file for input.
Dim lngSetupFileSize As Long
lngSetupFileSize = LOF(hFile)      ' Length of file.
Get hFile, , byteArray      ' Read data.
Close hFile      ' Close file.
' Write learn string back to oscilloscope using ":SYSTem:SETup"
' command:
Dim lngRestored As Long
lngRestored = DoCommandIEEEBlock(":SYSTem:SETup", lngSetupFileSize)
Debug.Print "Setup bytes restored: " + CStr(lngRestored)

```

```

' Capture an acquisition using :DIGItize.
' -----
DoCommand ":DIGItize CHANnel1"

End Sub

'
' Analyze the captured waveform.
' -----

Private Sub Analyze()

    ' Make a couple of measurements.
    ' -----
    DoCommand ":MEASure:SOURce CHANnel1"
    Debug.Print "Measure source: " + _
        DoQueryString(":MEASure:SOURce?")

    DoCommand ":MEASure:FREQuency"
    dblQueryResult = DoQueryNumber(":MEASure:FREQuency?")
    MsgBox "Frequency:" + vbCrLf + _
        FormatNumber(dblQueryResult / 1000, 4) + " kHz"

    DoCommand ":MEASure:VAMplitude"
    dblQueryResult = DoQueryNumber(":MEASure:VAMplitude?")
    MsgBox "Vertical amplitude:" + vbCrLf + _
        FormatNumber(dblQueryResult, 4) + " V"

    ' Download the screen image.
    ' -----
    DoCommand ":HARDcopy:INKSaver OFF"

    ' Get screen image.
    Dim lngBlockSize As Long
    lngBlockSize = DoQueryIEEEBlock_Bytes(":DISPlay:DATA? PNG, COLOR")
    Debug.Print "Screen image bytes: " + CStr(lngBlockSize)

    ' Save screen image to a file:
    Dim strPath As String
    strPath = "c:\scope\data\screen.png"
    If Len(Dir(strPath)) Then
        Kill strPath      ' Remove file if it exists.
    End If
    Dim hFile As Long
    hFile = FreeFile
    Open strPath For Binary Access Write Lock Write As hFile
    Dim lngI As Long
    For lngI = 0 To lngBlockSize - 1
        Put hFile, , byteArray(lngI)      ' Write data.
    Next lngI
    Close hFile      ' Close file.
    MsgBox "Screen image written to " + strPath

    ' Download waveform data.
    ' -----

```

```

' Set the waveform points mode.
DoCommand ":WAVeform:POINTs:MODE RAW"
Debug.Print "Waveform points mode: " + _
    DoQueryString(":WAVeform:POINTs:MODE?")

' Get the number of waveform points available.
Debug.Print "Waveform points available: " + _
    DoQueryString(":WAVeform:POINTs?")

' Set the waveform source.
DoCommand ":WAVeform:SOURce CHANnel1"
Debug.Print "Waveform source: " + _
    DoQueryString(":WAVeform:SOURce?")

' Choose the format of the data returned (WORD, BYTE, ASCII):
DoCommand ":WAVeform:FORMAT BYTE"
Debug.Print "Waveform format: " + _
    DoQueryString(":WAVeform:FORMAT?")

' Display the waveform settings:
Dim intFormat As Integer
Dim intType As Integer
Dim lngPoints As Long
Dim lngCount As Long
Dim dblXIncrement As Double
Dim dblXOrigin As Double
Dim lngXReference As Long
Dim sngYIncrement As Single
Dim lngYOrigin As Long
Dim lngYReference As Long
Dim strOutput As String

Dim lngNumNumbers As Long
lngNumNumbers = DoQueryNumbers(":WAVeform:PREamble?")

intFormat = dblArray(0)
intType = dblArray(1)
lngPoints = dblArray(2)
lngCount = dblArray(3)
dblXIncrement = dblArray(4)
dblXOrigin = dblArray(5)
lngXReference = dblArray(6)
sngYIncrement = dblArray(7)
lngYOrigin = dblArray(8)
lngYReference = dblArray(9)

If intFormat = 0 Then
    Debug.Print "Waveform format: BYTE"
ElseIf intFormat = 1 Then
    Debug.Print "Waveform format: WORD"
ElseIf intFormat = 2 Then
    Debug.Print "Waveform format: ASCII"
End If

If intType = 0 Then
    Debug.Print "Acquisition type: NORMAL"

```

```

        ElseIf intType = 1 Then
            Debug.Print "Acquisition type: PEAK"
        ElseIf intType = 2 Then
            Debug.Print "Acquisition type: AVERage"
        ElseIf intType = 3 Then
            Debug.Print "Acquisition type: HRESolution"
        End If

        Debug.Print "Waveform points: " + _
                    FormatNumber(lngPoints, 0)

        Debug.Print "Waveform average count: " + _
                    FormatNumber(lngCount, 0)

        Debug.Print "Waveform X increment: " + _
                    Format(dblXIncrement, "Scientific")

        Debug.Print "Waveform X origin: " + _
                    Format(dblXOrigin, "Scientific")

        Debug.Print "Waveform X reference: " + _
                    FormatNumber(lngXReference, 0)

        Debug.Print "Waveform Y increment: " + _
                    Format(sngYIncrement, "Scientific")

        Debug.Print "Waveform Y origin: " + _
                    FormatNumber(lngYOrigin, 0)

        Debug.Print "Waveform Y reference: " + _
                    FormatNumber(lngYReference, 0)

        ' Get the waveform data
        Dim lngNumBytes As Long
        lngNumBytes = DoQueryIEEEBlock_Bytes(":WAVEform:DATA?")
        Debug.Print "Number of data values: " + CStr(lngNumBytes)

        ' Set up output file:
        strPath = "c:\scope\data\waveform_data.csv"

        ' Open file for output.
        Open strPath For Output Access Write Lock Write As hFile

        ' Output waveform data in CSV format.
        Dim lngDataValue As Long

        For lngI = 0 To lngNumBytes - 1
            lngDataValue = CLng(byteArray(lngI))

            ' Write time value, voltage value.
            Print #hFile, _
                FormatNumber(dblXOrigin + (lngI * dblXIncrement), 9) + _
                ", " + _
                FormatNumber(((lngDataValue - lngYReference) * sngYIncrement) + lngYOrigin)

        Next lngI
    End Sub
End Class

```

```

' Close output file.
Close hFile    ' Close file.
MsgBox "Waveform format BYTE data written to " + _
"c:\scope\data\waveform_data.csv."

End Sub

Private Sub DoCommand(command As String)

err = viVPrintf(vi, command + vbLf, 0)
If (err <> VI_SUCCESS) Then HandleVISAError vi

CheckInstrumentErrors

End Sub

Private Function DoCommandIEEEBlock(command As String, _
lngBlockSize As Long)

retCount = lngBlockSize

Dim strCommandAndLength As String
strCommandAndLength = command + " %#" + _
Format(lngBlockSize) + "b"

err = viVPrintf(vi, strCommandAndLength + vbLf, paramsArray(1))
If (err <> VI_SUCCESS) Then HandleVISAError vi

DoCommandIEEEBlock = retCount

CheckInstrumentErrors

End Function

Private Function DoQueryString(query As String) As String

Dim strResult As String * 200

err = viVPrintf(vi, query + vbLf, 0)
If (err <> VI_SUCCESS) Then HandleVISAError vi

err = viVScanf(vi, "%t", strResult)
If (err <> VI_SUCCESS) Then HandleVISAError vi

DoQueryString = strResult

CheckInstrumentErrors

End Function

Private Function DoQueryNumber(query As String) As Variant

Dim dblResult As Double

err = viVPrintf(vi, query + vbLf, 0)
If (err <> VI_SUCCESS) Then HandleVISAError vi

```

```

err = viVScanf(vi, "%lf" + vbLf, VarPtr(dblResult))
If (err <> VI_SUCCESS) Then HandleVISAError vi

DoQueryNumber = dblResult

CheckInstrumentErrors

End Function

Private Function DoQueryNumbers(query As String) As Long

Dim dblResult As Double

' Send query.
err = viVPrintf(vi, query + vbLf, 0)
If (err <> VI_SUCCESS) Then HandleVISAError vi

' Set up paramsArray for multiple parameter query returning array.
paramsArray(0) = VarPtr(retCount)
paramsArray(1) = VarPtr(dblArray(0))

' Set retCount to max number of elements array can hold.
retCount = DblArraySize

' Read numbers.
err = viVScanf(vi, "%,#lf" + vbLf, paramsArray(0))
If (err <> VI_SUCCESS) Then HandleVISAError vi

' retCount is now actual number of values returned by query.
DoQueryNumbers = retCount

CheckInstrumentErrors

End Function

Private Function DoQueryIEEEBlock_Bytes(query As String) As Long

' Send query.
err = viVPrintf(vi, query + vbLf, 0)
If (err <> VI_SUCCESS) Then HandleVISAError vi

' Set up paramsArray for multiple parameter query returning array.
paramsArray(0) = VarPtr(retCount)
paramsArray(1) = VarPtr(byteArray(0))

' Set retCount to max number of elements array can hold.
retCount = ByteArraySize

' Get unsigned integer bytes.
err = viVScanf(vi, "%#b" + vbLf, paramsArray(0))
If (err <> VI_SUCCESS) Then HandleVISAError vi

err = viFlush(vi, VI_READ_BUF)
If (err <> VI_SUCCESS) Then HandleVISAError vi

err = viFlush(vi, VI_WRITE_BUF)

```

```

If (err <> VI_SUCCESS) Then HandleVISAError vi

' retCount is now actual number of bytes returned by query.
DoQueryIEEEBlock_Bytes = retCount

CheckInstrumentErrors

End Function

Private Sub CheckInstrumentErrors()

On Error GoTo ErrorHandler

Dim strErrVal As String * 200
Dim strOut As String

err = viVPrintf(vi, ":SYSTem:ERRor?" + vbLf, 0)      ' Query any errors.
If (err <> VI_SUCCESS) Then HandleVISAError vi

err = viVScanf(vi, "%t", strErrVal)      ' Read: Errnum,"Error String".
If (err <> VI_SUCCESS) Then HandleVISAError vi

While Val(strErrVal) <> 0                  ' End if find: 0,"No Error".
    strOut = strOut + "INST Error: " + strErrVal

    err = viVPrintf(vi, ":SYSTem:ERRor?" + vbLf, 0)      ' Request error.
    If (err <> VI_SUCCESS) Then HandleVISAError vi

    err = viVScanf(vi, "%t", strErrVal)      ' Read error message.
    If (err <> VI_SUCCESS) Then HandleVISAError vi

Wend

If Not strOut = "" Then
    MsgBox strOut, vbExclamation, "INST Error Messages"

    err = viFlush(vi, VI_READ_BUF)
    If (err <> VI_SUCCESS) Then HandleVISAError vi

    err = viFlush(vi, VI_WRITE_BUF)
    If (err <> VI_SUCCESS) Then HandleVISAError vi

End If

Exit Sub

ErrorHandler:

MsgBox "*** Error : " + Error, vbExclamation
End

End Sub

Private Sub HandleVISAError(session As Long)

Dim strVisaErr As String * 200
Call viStatusDesc(session, err, strVisaErr)

```

```

    MsgBox "**** VISA Error : " + strVisaErr, vbExclamation

    ' If the error is not a warning, close the session.
    If err < VI_SUCCESS Then
        If session <> 0 Then Call viClose(session)
        End
    End If

End Sub

```

## VISA Example in C#

To compile and run this example in Microsoft Visual Studio 2008:

- 1 Open Visual Studio.
- 2 Create a new Visual C#, Windows, Console Application project.
- 3 Cut-and-paste the code that follows into the C# source file.
- 4 Edit the program to use the VISA address of your oscilloscope.
- 5 Add Keysight's VISA header file to your project:
  - a Right-click the project you wish to modify (not the solution) in the Solution Explorer window of the Microsoft Visual Studio environment.
  - b Click **Add** and then click **Add Existing Item...**
  - c Navigate to the header file, visa32.cs (installed with Keysight IO Libraries Suite and found in the Program Files (x86)\IVI Foundation\VISA\WinNT\Include directory), select it, but *do not click the Open button*.
  - d Click the down arrow to the right of the **Add** button, and choose **Add as Link**.

You should now see the file underneath your project in the Solution Explorer. It will have a little arrow icon in its lower left corner, indicating that it is a link.

- 6 Build and run the program.

For more information, see the tutorial on using VISA in Microsoft .NET in the VISA Help that comes with Keysight IO Libraries Suite.

```

/*
 * Keysight VISA Example in C#
 * -----
 * This program illustrates a few commonly used programming
 * features of your Keysight oscilloscope.
 * -----
 */

using System;
using System.IO;
using System.Text;

namespace InfiniiVision
{
    class VisaInstrumentApp

```

```

{
    private static VisaInstrument myScope;

    public static void Main(string[] args)
    {
        try
        {
            myScope = new
                VisaInstrument("USB0::0x0957::0x17A6::US50210029::0::INSTR");
            myScope.SetTimeoutSeconds(10);

            // Initialize - start from a known state.
            Initialize();

            // Capture data.
            Capture();

            // Analyze the captured waveform.
            Analyze();
        }
        catch (System.ApplicationException err)
        {
            Console.WriteLine("*** VISA Error Message : " + err.Message);
        }
        catch (System.SystemException err)
        {
            Console.WriteLine("*** System Error Message : " + err.Message);
        }
        catch (System.Exception err)
        {
            System.Diagnostics.Debug.Fail("Unexpected Error");
            Console.WriteLine("*** Unexpected Error : " + err.Message);
        }
        finally
        {
            myScope.Close();
        }
    }

/*
 * Initialize the oscilloscope to a known state.
 * -----
 */
private static void Initialize()
{
    StringBuilder strResults;

    // Get and display the device's *IDN? string.
    strResults = myScope.DoQueryString("*IDN?");
    Console.WriteLine("*IDN? result is: {0}", strResults);

    // Clear status and load the default setup.
    myScope.DoCommand("*CLS");
    myScope.DoCommand("*RST");
}

```

```

/*
 * Capture the waveform.
 * -----
 */
private static void Capture()
{
    // Use auto-scale to automatically configure oscilloscope.
    myScope.DoCommand(":AUToscale");

    // Set trigger mode (EDGE, PULSe, PATTern, etc., and input source.
    myScope.DoCommand(":TRIGger:MODE EDGE");
    Console.WriteLine("Trigger mode: {0}",
        myScope.DoQueryString(":TRIGger:MODE?"));

    // Set EDGE trigger parameters.
    myScope.DoCommand(":TRIGger:EDGE:SOURce CHANnel1");
    Console.WriteLine("Trigger edge source: {0}",
        myScope.DoQueryString(":TRIGger:EDGE:SOURce?"));

    myScope.DoCommand(":TRIGger:EDGE:LEVel 1.5");
    Console.WriteLine("Trigger edge level: {0}",
        myScope.DoQueryString(":TRIGger:EDGE:LEVel?"));

    myScope.DoCommand(":TRIGger:EDGE:SLOPe POSitive");
    Console.WriteLine("Trigger edge slope: {0}",
        myScope.DoQueryString(":TRIGger:EDGE:SLOPe?"));

    // Save oscilloscope configuration.
    byte[] ResultsArray; // Results array.
    int nLength; // Number of bytes returned from instrument.
    string strPath;

    // Query and read setup string.
    nLength = myScope.DoQueryIEEEBlock(":SYSTem:SETUp?",
        out ResultsArray);

    // Write setup string to file.
    strPath = "c:\\scope\\config\\setup.stp";
    FileStream fStream = File.Open(strPath, FileMode.Create);
    fStream.Write(ResultsArray, 0, nLength);
    fStream.Close();
    Console.WriteLine("Setup bytes saved: {0}", nLength);

    // Change settings with individual commands:

    // Set vertical scale and offset.
    myScope.DoCommand(":CHANnel1:SCALe 0.05");
    Console.WriteLine("Channel 1 vertical scale: {0}",
        myScope.DoQueryString(":CHANnel1:SCALe?"));

    myScope.DoCommand(":CHANnel1:OFFSet -1.5");
    Console.WriteLine("Channel 1 vertical offset: {0}",
        myScope.DoQueryString(":CHANnel1:OFFSet?"));

    // Set horizontal scale and position.
    myScope.DoCommand(":TIMEbase:SCALe 0.0002");
    Console.WriteLine("Timebase scale: {0}",

```

```

    myScope.DoQueryString(":TIMEbase:SCALe?");

    myScope.DoCommand(":TIMEbase:POSIon 0.0");
    Console.WriteLine("Timebase position: {0}",
                      myScope.DoQueryString(":TIMEbase:POSIon?"));

    // Set the acquisition type (NORMAL, PEAK, AVERage, or HRESolution
    ).
    myScope.DoCommand(":ACQuire:TYPE NORMAL");
    Console.WriteLine("Acquire type: {0}",
                      myScope.DoQueryString(":ACQuire:TYPE?"));

    // Or, configure by loading a previously saved setup.
    byte[] dataArray;
    int nBytesWritten;

    // Read setup string from file.
    strPath = "c:\\scope\\config\\setup.stp";
    dataArray = File.ReadAllBytes(strPath);

    // Restore setup string.
    nBytesWritten = myScope.DoCommandIEEEBlock(":SYSTem:SETup",
  dataArray);
    Console.WriteLine("Setup bytes restored: {0}", nBytesWritten);

    // Capture an acquisition using :DIGItize.
    myScope.DoCommand(":DIGItize CHANnel1");
}

/*
 * Analyze the captured waveform.
 * -----
 */
private static void Analyze()
{
    byte[] ResultsArray; // Results array.
    int nLength; // Number of bytes returned from instrument.
    string strPath;

    // Make a couple of measurements.
    // -----
    myScope.DoCommand(":MEASure:SOURce CHANnel1");
    Console.WriteLine("Measure source: {0}",
                      myScope.DoQueryString(":MEASure:SOURce?"));

    double fResult;
    myScope.DoCommand(":MEASure:FREQuency");
    fResult = myScope.DoQueryNumber(":MEASure:FREQuency?");
    Console.WriteLine("Frequency: {0:F4} kHz", fResult / 1000);

    myScope.DoCommand(":MEASure:VAMplitude");
    fResult = myScope.DoQueryNumber(":MEASure:VAMplitude?");
    Console.WriteLine("Vertical amplitude: {0:F2} V", fResult);

    // Download the screen image.
    // -----
    myScope.DoCommand(":HARDcopy:INKSaver OFF");
}

```

```

// Get the screen data.
nLength = myScope.DoQueryIEEEBlock(":DISPLAY:DATA? PNG, COLOR",
    out ResultsArray);

// Store the screen data to a file.
strPath = "c:\\scope\\data\\screen.png";
FileStream fStream = File.Open(strPath, FileMode.Create);
fStream.Write(ResultsArray, 0, nLength);
fStream.Close();
Console.WriteLine("Screen image ({0} bytes) written to {1}",
    nLength, strPath);

// Download waveform data.
// ----

// Set the waveform points mode.
myScope.DoCommand(":WAVEform:POINTS:MODE RAW");
Console.WriteLine("Waveform points mode: {0}",
    myScope.DoQueryString(":WAVEform:POINTS:MODE?"));

// Get the number of waveform points available.
myScope.DoCommand(":WAVEform:POINTS 10240");
Console.WriteLine("Waveform points available: {0}",
    myScope.DoQueryString(":WAVEform:POINTS?"));

// Set the waveform source.
myScope.DoCommand(":WAVEform:SOURce CHANnel1");
Console.WriteLine("Waveform source: {0}",
    myScope.DoQueryString(":WAVEform:SOURce?"));

// Choose the format of the data returned (WORD, BYTE, ASCII):
myScope.DoCommand(":WAVEform:FORMAT BYTE");
Console.WriteLine("Waveform format: {0}",
    myScope.DoQueryString(":WAVEform:FORMAT?"));

// Display the waveform settings:
double[] fResultsArray;
fResultsArray = myScope.DoQueryNumbers(":WAVEform:PREamble?");

double fFormat = fResultsArray[0];
if (fFormat == 0.0)
{
    Console.WriteLine("Waveform format: BYTE");
}
else if (fFormat == 1.0)
{
    Console.WriteLine("Waveform format: WORD");
}
else if (fFormat == 2.0)
{
    Console.WriteLine("Waveform format: ASCII");
}

double fType = fResultsArray[1];
if (fType == 0.0)
{

```

```

        Console.WriteLine("Acquire type: NORMal");
    }
    else if (fType == 1.0)
    {
        Console.WriteLine("Acquire type: PEAK");
    }
    else if (fType == 2.0)
    {
        Console.WriteLine("Acquire type: AVERage");
    }
    else if (fType == 3.0)
    {
        Console.WriteLine("Acquire type: HRESolution");
    }

    double fPoints = fResultsArray[2];
    Console.WriteLine("Waveform points: {0:e}", fPoints);

    double fCount = fResultsArray[3];
    Console.WriteLine("Waveform average count: {0:e}", fCount);

    double fXincrement = fResultsArray[4];
    Console.WriteLine("Waveform X increment: {0:e}", fXincrement);

    double fXorigin = fResultsArray[5];
    Console.WriteLine("Waveform X origin: {0:e}", fXorigin);

    double fXreference = fResultsArray[6];
    Console.WriteLine("Waveform X reference: {0:e}", fXreference);

    double fYincrement = fResultsArray[7];
    Console.WriteLine("Waveform Y increment: {0:e}", fYincrement);

    double fYorigin = fResultsArray[8];
    Console.WriteLine("Waveform Y origin: {0:e}", fYorigin);

    double fYreference = fResultsArray[9];
    Console.WriteLine("Waveform Y reference: {0:e}", fYreference);

    // Read waveform data.
    nLength = myScope.DoQueryIEEEBlock(":WAVeform:DATA?",
        out ResultsArray);
    Console.WriteLine("Number of data values: {0}", nLength);

    // Set up output file.
    strPath = "c:\\scope\\data\\waveform_data.csv";
    if (File.Exists(strPath)) File.Delete(strPath);

    // Open file for output.
    StreamWriter writer = File.CreateText(strPath);

    // Output waveform data in CSV format.
    for (int i = 0; i < nLength - 1; i++)
        writer.WriteLine("{0:f9}, {1:f6}",
            fXorigin + ((float)i * fXincrement),
            (((float)ResultsArray[i] - fYreference) *
            fYincrement) + fYorigin);
}

```

```

        // Close output file.
        writer.Close();
        Console.WriteLine("Waveform format BYTE data written to {0}",
                          strPath);
    }
}

class VisaInstrument
{
    private int m_nResourceManager;
    private int m_nSession;
    private string m_strVisaAddress;

    // Constructor.
    public VisaInstrument(string strVisaAddress)
    {
        // Save VISA address in member variable.
        m_strVisaAddress = strVisaAddress;

        // Open the default VISA resource manager.
        OpenResourceManager();

        // Open a VISA resource session.
        OpenSession();

        // Clear the interface.
        int nViStatus;
        nViStatus = visa32.viClear(m_nSession);
    }

    public void DoCommand(string strCommand)
    {
        // Send the command.
        VisaSendCommandOrQuery(strCommand);

        // Check for inst errors.
        CheckInstrumentErrors(strCommand);
    }

    public int DoCommandIEEEBlock(string strCommand,
                                 byte[] dataArray)
    {
        // Send the command to the device.
        string strCommandAndLength;
        int nViStatus, nLength, nBytesWritten;

        nLength = dataArray.Length;
        strCommandAndLength = String.Format("{0} #8%08d",
  strCommand);

        // Write first part of command to formatted I/O write buffer.
        nViStatus = visa32.viPrintf(m_nSession, strCommandAndLength,
                                    nLength);
        CheckVisaStatus(nViStatus);

        // Write the data to the formatted I/O write buffer.
    }
}

```

```

nViStatus = visa32.viBufWrite(m_nSession, DataArray, nLength,
    out nBytesWritten);
CheckVisaStatus(nViStatus);

// Check for inst errors.
CheckInstrumentErrors(strCommand);

return nBytesWritten;
}

public StringBuilder DoQueryString(string strQuery)
{
    // Send the query.
    VisaSendCommandOrQuery(strQuery);

    // Get the result string.
    StringBuilder strResults = new StringBuilder(1000);
    strResults = VisaGetResultString();

    // Check for inst errors.
    CheckInstrumentErrors(strQuery);

    // Return string results.
    return strResults;
}

public double DoQueryNumber(string strQuery)
{
    // Send the query.
    VisaSendCommandOrQuery(strQuery);

    // Get the result string.
    double fResults;
    fResults = VisaGetResultNumber();

    // Check for inst errors.
    CheckInstrumentErrors(strQuery);

    // Return string results.
    return fResults;
}

public double[] DoQueryNumbers(string strQuery)
{
    // Send the query.
    VisaSendCommandOrQuery(strQuery);

    // Get the result string.
    double[] fResultsArray;
    fResultsArray = VisaGetResultNumbers();

    // Check for inst errors.
    CheckInstrumentErrors(strQuery);

    // Return string results.
    return fResultsArray;
}

```

```

public int DoQueryIEEEBlock(string strQuery,
    out byte[] ResultsArray)
{
    // Send the query.
    VisaSendCommandOrQuery(strQuery);

    // Get the result string.
    int length;    // Number of bytes returned from instrument.
    length = VisaGetResultIEEEBlock(out ResultsArray);

    // Check for inst errors.
    CheckInstrumentErrors(strQuery);

    // Return string results.
    return length;
}

private void VisaSendCommandOrQuery(string strCommandOrQuery)
{
    // Send command or query to the device.
    string strWithNewline;
    strWithNewline = String.Format("{0}\n", strCommandOrQuery);
    int nViStatus;
    nViStatus = visa32.viPrintf(m_nSession, strWithNewline);
    CheckVisaStatus(nViStatus);
}

private StringBuilder VisaGetString()
{
    StringBuilder strResults = new StringBuilder(1000);

    // Read return value string from the device.
    int nViStatus;
    nViStatus = visa32.viScanf(m_nSession, "%1000t", strResults);
    CheckVisaStatus(nViStatus);

    return strResults;
}

private double VisaGetResultNumber()
{
    double fResults = 0;

    // Read return value string from the device.
    int nViStatus;
    nViStatus = visa32.viScanf(m_nSession, "%lf", out fResults);
    CheckVisaStatus(nViStatus);

    return fResults;
}

private double[] VisaGetResultNumbers()
{
    double[] fResultsArray;
    fResultsArray = new double[10];
}

```

```

// Read return value string from the device.
int nViStatus;
nViStatus = visa32.viScanf(m_nSession, "%,10lf\n",
                           fResultsArray);
CheckVisaStatus(nViStatus);

return fResultsArray;
}

private int VisaGetResultIEEEBlock(out byte[] ResultsArray)
{
    // Results array, big enough to hold a PNG.
    ResultsArray = new byte[300000];
    int length; // Number of bytes returned from instrument.

    // Set the default number of bytes that will be contained in
    // the ResultsArray to 300,000 (300kB).
    length = 300000;

    // Read return value string from the device.
    int nViStatus;
    nViStatus = visa32.viScanf(m_nSession, "%#b", ref length,
                               ResultsArray);
    CheckVisaStatus(nViStatus);

    // Write and read buffers need to be flushed after IEEE block?
    nViStatus = visa32.viFlush(m_nSession, visa32.VI_WRITE_BUF);
    CheckVisaStatus(nViStatus);

    nViStatus = visa32.viFlush(m_nSession, visa32.VI_READ_BUF);
    CheckVisaStatus(nViStatus);

    return length;
}

private void CheckInstrumentErrors(string strCommand)
{
    // Check for instrument errors.
    StringBuilder strInstrumentError = new StringBuilder(1000);
    bool bFirstError = true;

    do // While not "0,No error"
    {
        VisaSendCommandOrQuery(":SYSTem:ERRor?");
        strInstrumentError = VisaGetResultString();

        if (!strInstrumentError.ToString().StartsWith("+0,"))
        {
            if (bFirstError)
            {
                Console.WriteLine("ERROR(s) for command '{0}': {1}",
                                  strCommand);
                bFirstError = false;
            }
            Console.Write(strInstrumentError);
        }
    } while (!strInstrumentError.ToString().StartsWith("+0,"));
}

```

```

    }

private void OpenResourceManager()
{
    int nViStatus;
    nViStatus =
        visa32.viOpenDefaultRM(out this.m_nResourceManager);
    if (nViStatus < visa32.VI_SUCCESS)
        throw new
            ApplicationException("Failed to open Resource Manager");
}

private void OpenSession()
{
    int nViStatus;
    nViStatus = visa32.viOpen(this.m_nResourceManager,
        this.m_strVisaAddress, visa32.VI_NO_LOCK,
        visa32.VI_TMO_IMMEDIATE, out this.m_nSession);
    CheckVisaStatus(nViStatus);
}

public void SetTimeoutSeconds(int nSeconds)
{
    int nViStatus;
    nViStatus = visa32.viSetAttribute(this.m_nSession,
        visa32.VI_ATTR_TMO_VALUE, nSeconds * 1000);
    CheckVisaStatus(nViStatus);
}

public void CheckVisaStatus(int nViStatus)
{
    // If VISA error, throw exception.
    if (nViStatus < visa32.VI_SUCCESS)
    {
        StringBuilder strError = new StringBuilder(256);
        visa32.viStatusDesc(this.m_nResourceManager, nViStatus,
            strError);
        throw new ApplicationException(strError.ToString());
    }
}

public void Close()
{
    if (m_nSession != 0)
        visa32.viClose(m_nSession);
    if (m_nResourceManager != 0)
        visa32.viClose(m_nResourceManager);
}
}

```

## VISA Example in Visual Basic .NET

To compile and run this example in Microsoft Visual Studio 2008:

- 1** Open Visual Studio.
- 2** Create a new Visual Basic, Windows, Console Application project.
- 3** Cut-and-paste the code that follows into the Visual Basic .NET source file.
- 4** Edit the program to use the VISA address of your oscilloscope.
- 5** Add Keysight's VISA header file to your project:
  - a** Right-click the project you wish to modify (not the solution) in the Solution Explorer window of the Microsoft Visual Studio environment.
  - b** Choose **Add** and then choose **Add Existing Item...**
  - c** Navigate to the header file, visa32.vb (installed with Keysight IO Libraries Suite and found in the Program Files (x86)\IVI Foundation\VISA\WinNT\Include directory), select it, but *do not click the Open button*.
  - d** Click the down arrow to the right of the **Add** button, and choose **Add as Link**.

You should now see the file underneath your project in the Solution Explorer. It will have a little arrow icon in its lower left corner, indicating that it is a link.

- e** Right-click the project again and choose **Properties**; then, select "InfiniiVision.VisalnstrumentApp" as the **Startup object**.

- 6** Build and run the program.

For more information, see the tutorial on using VISA in Microsoft .NET in the VISA Help that comes with Keysight IO Libraries Suite.

```
'-----'
' Keysight VISA Example in Visual Basic .NET
' -----
' This program illustrates a few commonly-used programming
' features of your Keysight oscilloscope.
' -----'

Imports System
Imports System.IO
Imports System.Text

Namespace InfiniiVision
    Class VisaInstrumentApp
        Private Shared myScope As VisaInstrument

        Public Shared Sub Main(ByVal args As String())
            Try
                myScope =
                    New VisaInstrument("USB0::0x0957::0x17A6::US50210029::0::INSTR")
            myScope.SetTimeoutSeconds(10)
        End Sub
    End Class
End Namespace
```

```

' Initialize - start from a known state.
Initialize()

' Capture data.
Capture()

' Analyze the captured waveform.
Analyze()

Catch err As System.ApplicationException
    Console.WriteLine("*** VISA Error Message : " + err.Message)
Catch err As System.SystemException
    Console.WriteLine("*** System Error Message : " + err.Message)
Catch err As System.Exception
    Debug.Fail("Unexpected Error")
    Console.WriteLine("*** Unexpected Error : " + err.Message)
End Try
End Sub

'
' Initialize the oscilloscope to a known state.
' -----
Private Shared Sub Initialize()
    Dim strResults As StringBuilder

    ' Get and display the device's *IDN? string.
    strResults = myScope.DoQueryString("*IDN?")
    Console.WriteLine("*IDN? result is: {0}", strResults)

    ' Clear status and load the default setup.
    myScope.DoCommand("*CLS")
    myScope.DoCommand("*RST")

End Sub

'
' Capture the waveform.
' -----
Private Shared Sub Capture()

    ' Use auto-scale to automatically configure oscilloscope.
    myScope.DoCommand(":AUToscale")

    ' Set trigger mode (EDGE, PULSe, PATTern, etc., and input source.
    myScope.DoCommand(":TRIGger:MODE EDGE")
    Console.WriteLine("Trigger mode: {0}", _
        myScope.DoQueryString(":TRIGger:MODE?"))

    ' Set EDGE trigger parameters.
    myScope.DoCommand(":TRIGger:EDGE:SOURce CHANnel1")
    Console.WriteLine("Trigger edge source: {0}", _
        myScope.DoQueryString(":TRIGger:EDGE:SOURce?"))

    myScope.DoCommand(":TRIGger:EDGE:LEVel 1.5")
    Console.WriteLine("Trigger edge level: {0}", _

```

```

myScope.DoQueryString(":TRIGger:EDGE:LEVel?"))

myScope.DoCommand(":TRIGger:EDGE:SLOPe POSitive")
Console.WriteLine("Trigger edge slope: {0}", _
    myScope.DoQueryString(":TRIGger:EDGE:SLOPe?"))

' Save oscilloscope configuration.
Dim ResultsArray As Byte()      ' Results array.
Dim nLength As Integer         ' Number of bytes returned from inst.
Dim strPath As String
Dim fStream As FileStream

' Query and read setup string.
nLength = myScope.DoQueryIEEEBlock(":SYSTem:SETup?", _
    ResultsArray)

' Write setup string to file.
strPath = "c:\scope\config\setup.stp"
fStream = File.Open(strPath, FileMode.Create)
fStream.Write(ResultsArray, 0, nLength)
fStream.Close()
Console.WriteLine("Setup bytes saved: {0}", nLength)

' Change settings with individual commands:

' Set vertical scale and offset.
myScope.DoCommand(":CHANnel1:SCALe 0.05")
Console.WriteLine("Channel 1 vertical scale: {0}", _
    myScope.DoQueryString(":CHANnel1:SCALe?"))

myScope.DoCommand(":CHANnel1:OFFSet -1.5")
Console.WriteLine("Channel 1 vertical offset: {0}", _
    myScope.DoQueryString(":CHANnel1:OFFSet?"))

' Set horizontal scale and position.
myScope.DoCommand(":TIMEbase:SCALe 0.0002")
Console.WriteLine("Timebase scale: {0}", _
    myScope.DoQueryString(":TIMEbase:SCALe?"))

myScope.DoCommand(":TIMEbase:POSItion 0.0")
Console.WriteLine("Timebase position: {0}", _
    myScope.DoQueryString(":TIMEbase:POSItion?"))

' Set the acquisition type (NORMAL, PEAK, AVERAGE, or HRESolution)

myScope.DoCommand(":ACQuire:TYPE NORMAL")
Console.WriteLine("Acquire type: {0}", _
    myScope.DoQueryString(":ACQuire:TYPE?"))

' Or, configure by loading a previously saved setup.
Dim DataArray As Byte()
Dim nBytesWritten As Integer

' Read setup string from file.
strPath = "c:\scope\config\setup.stp"
DataArray = File.ReadAllBytes(strPath)

```

```

' Restore setup string.
nBytesWritten = myScope.DoCommandIEEEBlock(":SYSTem:SETup", _
    DataArray)
Console.WriteLine("Setup bytes restored: {0}", nBytesWritten)

' Capture an acquisition using :DIGitize.
myScope.DoCommand(":DIGitize CHANnel1")

End Sub

'

' Analyze the captured waveform.
' -----
Private Shared Sub Analyze()

    Dim fResult As Double
    Dim ResultsArray As Byte()      ' Results array.
    Dim nLength As Integer        ' Number of bytes returned from inst.
    Dim strPath As String

    ' Make a couple of measurements.
    ' -----
    myScope.DoCommand(":MEASure:SOURce CHANnel1")
    Console.WriteLine("Measure source: {0}", _
        myScope.DoQueryString(":MEASure:SOURce?"))

    myScope.DoCommand(":MEASure:FREQuency")
    fResult = myScope.DoQueryNumber(":MEASure:FREQuency?")
    Console.WriteLine("Frequency: {0:F4} kHz", fResult / 1000)

    myScope.DoCommand(":MEASure:VAMplitude")
    fResult = myScope.DoQueryNumber(":MEASure:VAMplitude?")
    Console.WriteLine("Vertical amplitude: {0:F2} V", fResult)

    ' Download the screen image.
    ' -----
    myScope.DoCommand(":HARDcopy:INKSaver OFF")

    ' Get the screen data.
    nLength = myScope.DoQueryIEEEBlock(":DISPlay:DATA? PNG, COLOR", _
        ResultsArray)

    ' Store the screen data to a file.
    strPath = "c:\scope\data\screen.png"
    Dim fStream As FileStream
    fStream = File.Open(strPath, FileMode.Create)
    fStream.Write(ResultsArray, 0, nLength)
    fStream.Close()
    Console.WriteLine("Screen image ({0} bytes) written to {1}", _
        nLength, strPath)

    ' Download waveform data.
    ' -----
    ' Set the waveform points mode.
    myScope.DoCommand(":WAVeform:POINTS:MODE RAW")

```

```

Console.WriteLine("Waveform points mode: {0}", _
    myScope.DoQueryString(":WAVEform:POINts:MODE?"))

' Get the number of waveform points available.
myScope.DoCommand(":WAVEform:POINts 10240")
Console.WriteLine("Waveform points available: {0}", _
    myScope.DoQueryString(":WAVEform:POINts?"))

' Set the waveform source.
myScope.DoCommand(":WAVEform:SOURce CHANnel1")
Console.WriteLine("Waveform source: {0}", _
    myScope.DoQueryString(":WAVEform:SOURce?"))

' Choose the format of the data returned (WORD, BYTE, ASCII):
myScope.DoCommand(":WAVEform:FORMAT BYTE")
Console.WriteLine("Waveform format: {0}", _
    myScope.DoQueryString(":WAVEform:FORMAT?"))

' Display the waveform settings:
Dim fResultsArray As Double()
fResultsArray = myScope.DoQueryNumbers(":WAVEform:PREamble?")

Dim fFormat As Double = fResultsArray(0)
If fFormat = 0 Then
    Console.WriteLine("Waveform format: BYTE")
ElseIf fFormat = 1 Then
    Console.WriteLine("Waveform format: WORD")
ElseIf fFormat = 2 Then
    Console.WriteLine("Waveform format: ASCII")
End If

Dim fType As Double = fResultsArray(1)
If fType = 0 Then
    Console.WriteLine("Acquire type: NORMAL")
ElseIf fType = 1 Then
    Console.WriteLine("Acquire type: PEAK")
ElseIf fType = 2 Then
    Console.WriteLine("Acquire type: AVERage")
ElseIf fType = 3 Then
    Console.WriteLine("Acquire type: HRESolution")
End If

Dim fPoints As Double = fResultsArray(2)
Console.WriteLine("Waveform points: {0:e}", fPoints)

Dim fCount As Double = fResultsArray(3)
Console.WriteLine("Waveform average count: {0:e}", fCount)

Dim fXincrement As Double = fResultsArray(4)
Console.WriteLine("Waveform X increment: {0:e}", fXincrement)

Dim fXorigin As Double = fResultsArray(5)
Console.WriteLine("Waveform X origin: {0:e}", fXorigin)

Dim fXreference As Double = fResultsArray(6)
Console.WriteLine("Waveform X reference: {0:e}", fXreference)

```

```

Dim fYincrement As Double = fResultsArray(7)
Console.WriteLine("Waveform Y increment: {0:e}", fYincrement)

Dim fYorigin As Double = fResultsArray(8)
Console.WriteLine("Waveform Y origin: {0:e}", fYorigin)

Dim fYreference As Double = fResultsArray(9)
Console.WriteLine("Waveform Y reference: {0:e}", fYreference)

' Get the waveform data.
nLength = myScope.DoQueryIEEEBlock(":WAVEform:DATA?", _
    ResultsArray)
Console.WriteLine("Number of data values: {0}", nLength)

' Set up output file:
strPath = "c:\scope\data\waveform_data.csv"
If File.Exists(strPath) Then
    File.Delete(strPath)
End If

' Open file for output.
Dim writer As StreamWriter = File.CreateText(strPath)

' Output waveform data in CSV format.
For index As Integer = 0 To nLength - 1
    ' Write time value, voltage value.
    writer.WriteLine("{0:f9}, {1:f6}", _
        fXorigin + (CSng(index) * fxincrement), _
        ((CSng(ResultsArray(index)) - fYreference) _ 
         * fyincrement) + fyorigin)
Next

' Close output file.
writer.Close()
Console.WriteLine("Waveform format BYTE data written to {0}", _
    strPath)

End Sub

End Class

Class VisaInstrument
    Private m_nResourceManager As Integer
    Private m_nSession As Integer
    Private m_strVisaAddress As String

    ' Constructor.
    Public Sub New(ByVal strVisaAddress As String)
        ' Save VISA address in member variable.
        m_strVisaAddress = strVisaAddress

        ' Open the default VISA resource manager.
        OpenResourceManager()

        ' Open a VISA resource session.
        OpenSession()
    End Sub
End Class

```

```

' Clear the interface.
Dim nViStatus As Integer
nViStatus = visa32.viClear(m_nSession)
End Sub

Public Sub DoCommand(ByVal strCommand As String)
    ' Send the command.
    VisaSendCommandOrQuery(strCommand)

    ' Check for inst errors.
    CheckInstrumentErrors(strCommand)

End Sub

Public Function DoCommandIEEEBlock(ByVal strCommand As String, _
    ByVal DataArray As Byte()) As Integer

    ' Send the command to the device.
    Dim strCommandAndLength As String
    Dim nViStatus As Integer
    Dim nLength As Integer
    Dim nBytesWritten As Integer

    nLength = DataArray.Length
    strCommandAndLength = [String].Format("{0} #8{1:D8}", _
        strCommand, nLength)

    ' Write first part of command to formatted I/O write buffer.
    nViStatus = visa32.viPrintf(m_nSession, strCommandAndLength)
    CheckVisaStatus(nViStatus)

    ' Write the data to the formatted I/O write buffer.
    nViStatus = visa32.viBufWrite(m_nSession, DataArray, nLength, _
        nBytesWritten)
    CheckVisaStatus(nViStatus)

    ' Check for inst errors.
    CheckInstrumentErrors(strCommand)

    Return nBytesWritten
End Function

Public Function DoQueryString(ByVal strQuery As String) _
    As StringBuilder
    ' Send the query.
    VisaSendCommandOrQuery(strQuery)

    ' Get the result string.
    Dim strResults As New StringBuilder(1000)
    strResults = VisaGetResultString()

    ' Check for inst errors.
    CheckInstrumentErrors(strQuery)

    ' Return string results.
    Return strResults
End Function

```

```

Public Function DoQueryNumber(ByVal strQuery As String) As Double
    ' Send the query.
    VisaSendCommandOrQuery(strQuery)

    ' Get the result string.
    Dim fResults As Double
    fResults = VisaGetResultNumber()

    ' Check for inst errors.
    CheckInstrumentErrors(strQuery)

    ' Return string results.
    Return fResults
End Function

Public Function DoQueryNumbers(ByVal strQuery As String) _
    As Double()
    ' Send the query.
    VisaSendCommandOrQuery(strQuery)

    ' Get the result string.
    Dim fResultsArray As Double()
    fResultsArray = VisaGetResultNumbers()

    ' Check for instrument errors (another command and result).
    CheckInstrumentErrors(strQuery)

    ' Return string results.
    Return fResultsArray
End Function

Public Function DoQueryIEEEBlock(ByVal strQuery As String, _
    ByRef ResultsArray As Byte()) As Integer
    ' Send the query.
    VisaSendCommandOrQuery(strQuery)

    ' Get the result string.
    System.Threading.Thread.Sleep(2000) ' Delay before reading data.
    Dim length As Integer
    ' Number of bytes returned from instrument.
    length = VisaGetResultIEEEBlock(ResultsArray)

    ' Check for inst errors.
    CheckInstrumentErrors(strQuery)

    ' Return string results.
    Return length
End Function

Private Sub VisaSendCommandOrQuery(ByVal strCommandOrQuery _
    As String)
    ' Send command or query to the device.
    Dim strWithNewline As String
    strWithNewline = [String].Format("{0}" & Chr(10) & "", _
        strCommandOrQuery)
    Dim nViStatus As Integer

```

```

nViStatus = visa32.viPrintf(m_nSession, strWithNewline)
CheckVisaStatus(nViStatus)
End Sub

Private Function VisaGetString() As StringBuilder
    Dim strResults As New StringBuilder(1000)

    ' Read return value string from the device.
    Dim nViStatus As Integer
    nViStatus = visa32.viScanf(m_nSession, "%1000t", strResults)
    CheckVisaStatus(nViStatus)

    Return strResults
End Function

Private Function VisaGetResultNumber() As Double
    Dim fResults As Double = 0

    ' Read return value string from the device.
    Dim nViStatus As Integer
    nViStatus = visa32.viScanf(m_nSession, "%lf", fResults)
    CheckVisaStatus(nViStatus)

    Return fResults
End Function

Private Function VisaGetResultNumbers() As Double()
    Dim fResultsArray As Double()
    fResultsArray = New Double(9) {}

    ' Read return value string from the device.
    Dim nViStatus As Integer
    nViStatus = visa32.viScanf(m_nSession,
        "%,10lf" & Chr(10) & "", fResultsArray)
    CheckVisaStatus(nViStatus)

    Return fResultsArray
End Function

Private Function VisaGetResultIEEEBlock(ByRef ResultsArray _
    As Byte()) As Integer
    ' Results array, big enough to hold a PNG.
    ResultsArray = New Byte(299999) {}
    Dim length As Integer
    ' Number of bytes returned from instrument.
    ' Set the default number of bytes that will be contained in
    ' the ResultsArray to 300,000 (300kB).
    length = 300000

    ' Read return value string from the device.
    Dim nViStatus As Integer
    nViStatus = visa32.viScanf(m_nSession, "%#b", length, _
        ResultsArray)
    CheckVisaStatus(nViStatus)

    ' Write and read buffers need to be flushed after IEEE block?
    nViStatus = visa32.viFlush(m_nSession, visa32.VI_WRITE_BUF)

```

```

CheckVisaStatus(nViStatus)

nViStatus = visa32.viFlush(m_nSession, visa32.VI_READ_BUF)
CheckVisaStatus(nViStatus)

    Return length
End Function

Private Sub CheckInstrumentErrors(ByVal strCommand As String)
    ' Check for instrument errors.
    Dim strInstrumentError As New StringBuilder(1000)
    Dim bFirstError As Boolean = True
    Do      ' While not "0,No error"
        VisaSendCommandOrQuery(":SYSTem:ERRor?")
        strInstrumentError = VisaGetResultString()

        If Not strInstrumentError.ToString().StartsWith("+0,") Then
            If bFirstError Then
                Console.WriteLine("ERROR(s) for command '{0}': ", _
                    strCommand)
                bFirstError = False
            End If
            Console.Write(strInstrumentError)
        End If
    Loop While Not strInstrumentError.ToString().StartsWith("+0,")
End Sub

Private Sub OpenResourceManager()
    Dim nViStatus As Integer
    nViStatus = visa32.viOpenDefaultRM(Me.m_nResourceManager)
    If nViStatus < visa32.VI_SUCCESS Then
        Throw New _
            ApplicationException("Failed to open Resource Manager")
    End If
End Sub

Private Sub OpenSession()
    Dim nViStatus As Integer
    nViStatus = visa32.viOpen(Me.m_nResourceManager, _
        Me.m_strVisaAddress, visa32.VI_NO_LOCK, _
        visa32.VI_TMO_IMMEDIATE, Me.m_nSession)
    CheckVisaStatus(nViStatus)
End Sub

Public Sub SetTimeoutSeconds(ByVal nSeconds As Integer)
    Dim nViStatus As Integer
    nViStatus = visa32.viSetAttribute(Me.m_nSession, _
        visa32.VI_ATTR_TMO_VALUE, nSeconds * 1000)
    CheckVisaStatus(nViStatus)
End Sub

Public Sub CheckVisaStatus(ByVal nViStatus As Integer)
    ' If VISA error, throw exception.
    If nViStatus < visa32.VI_SUCCESS Then
        Dim strError As New StringBuilder(256)
        visa32.viStatusDesc(Me.m_nResourceManager, nViStatus, strError)
        Throw New ApplicationException(strError.ToString())
    End If
End Sub

```

```

    End If
End Sub

Public Sub Close()
    If m_nSession <> 0 Then
        visa32.viClose(m_nSession)
    End If
    If m_nResourceManager <> 0 Then
        visa32.viClose(m_nResourceManager)
    End If
End Sub
End Class
End Namespace

```

## VISA Example in Python 3

You can use the Python programming language with the PyVISA package to control Keysight InfiniiVision Series oscilloscopes.

The Python language and PyVISA package can be downloaded from the web at <http://www.python.org/> and <http://pyvisa.readthedocs.io/>, respectively.

To run this example with Python and PyVISA:

- 1 Cut-and-paste the code that follows into a file named "example.py".
- 2 Edit the program to use the VISA address of your oscilloscope.
- 3 If "python.exe" can be found via your PATH environment variable, open a Command Prompt window; then, change to the folder that contains the "example.py" file, and enter:

```

python example.py

#!python3

# *****
# This program illustrates a few commonly-used programming
# features of your Keysight oscilloscope.
# *****

# Import modules.
# -----
import visa
import string
import struct
import sys

# Global variables (booleans: 0 = False, 1 = True).
# -----
debug = 0

# *****
# Initialize:
# *****
def initialize():

```

```

# Get and display the device's *IDN? string.
idn_string = do_query_string("*IDN?")
print("Identification string: '%s'" % idn_string)

# Clear status and load the default setup.
do_command("*CLS")
do_command("*RST")

# =====
# Capture:
# =====
def capture():

    # Use auto-scale to automatically set up oscilloscope.
    print("Autoscale.")
    do_command(":AUToscale")

    # Set trigger mode.
    do_command(":TRIGger:MODE EDGE")
    qresult = do_query_string(":TRIGger:MODE?")
    print("Trigger mode: %s" % qresult)

    # Set EDGE trigger parameters.
    do_command(":TRIGger:EDGE:SOURce CHANnel1")
    qresult = do_query_string(":TRIGger:EDGE:SOURce?")
    print("Trigger edge source: %s" % qresult)

    do_command(":TRIGger:EDGE:LEVel 1.5")
    qresult = do_query_string(":TRIGger:EDGE:LEVel?")
    print("Trigger edge level: %s" % qresult)

    do_command(":TRIGger:EDGE:SLOPe POSitive")
    qresult = do_query_string(":TRIGger:EDGE:SLOPe?")
    print("Trigger edge slope: %s" % qresult)

    # Save oscilloscope setup.
    sSetup = do_query_ieee_block(":SYSTem:SETUp?")

    f = open("setup.stp", "wb")
    f.write(sSetup)
    f.close()
    print("Setup bytes saved: %d" % len(sSetup))

    # Change oscilloscope settings with individual commands:

    # Set vertical scale and offset.
    do_command(":CHANnel1:SCALE 0.05")
    qresult = do_query_string(":CHANnel1:SCALE?")
    print("Channel 1 vertical scale: %s" % qresult)

    do_command(":CHANnel1:OFFSet -1.5")
    qresult = do_query_string(":CHANnel1:OFFSet?")
    print("Channel 1 offset: %s" % qresult)

    # Set horizontal scale and offset.

```

```

do_command(":TIMEbase:SCALe 0.0002")
qresult = do_query_string(":TIMEbase:SCALe?")
print("Timebase scale: %s" % qresult)

do_command(":TIMEbase:POSition 0.0")
qresult = do_query_string(":TIMEbase:Position?")
print("Timebase position: %s" % qresult)

# Set the acquisition type.
do_command(":ACQuire:TYPE NORMal")
qresult = do_query_string(":ACQuire:TYPE?")
print("Acquire type: %s" % qresult)

# Or, set up oscilloscope by loading a previously saved setup.
sSetup = ""
f = open("setup.stp", "rb")
sSetup = f.read()
f.close()
do_command_ieee_block(":SYSTem:SETup", sSetup)
print("Setup bytes restored: %d" % len(sSetup))

# Capture an acquisition using :DIGitize.
do_command(":DIGitize CHANnel1")

# =====
# Analyze:
# =====
def analyze():

    # Make measurements.
    # -----
    do_command(":MEASure:SOURce CHANnel1")
    qresult = do_query_string(":MEASure:SOURce?")
    print("Measure source: %s" % qresult)

    do_command(":MEASure:FREQuency")
    qresult = do_query_string(":MEASure:FREQuency?")
    print("Measured frequency on channel 1: %s" % qresult)

    do_command(":MEASure:VAMPplitude")
    qresult = do_query_string(":MEASure:VAMPplitude?")
    print("Measured vertical amplitude on channel 1: %s" % qresult)

    # Download the screen image.
    # -----
    do_command(":HARDcopy:INKSaver OFF")

    sDisplay = do_query_ieee_block(":DISPlay:DATA? PNG, COLOR")

    # Save display data values to file.
    f = open("screen_image.png", "wb")
    f.write(sDisplay)
    f.close()
    print("Screen image written to screen_image.png.")

    # Download waveform data.

```

```

# -----
# Set the waveform points mode.
do_command(":WAVEform:POINTS:MODE RAW")
qresult = do_query_string(":WAVEform:POINTS:MODE?")
print("Waveform points mode: %s" % qresult)

# Get the number of waveform points available.
do_command(":WAVEform:POINTS 10240")
qresult = do_query_string(":WAVEform:POINTS?")
print("Waveform points available: %s" % qresult)

# Set the waveform source.
do_command(":WAVEform:SOURce CHANnel1")
qresult = do_query_string(":WAVEform:SOURce?")
print("Waveform source: %s" % qresult)

# Choose the format of the data returned:
do_command(":WAVEform:FORMAT BYTE")
print("Waveform format: %s" % do_query_string(":WAVEform:FORMAT?"))

# Display the waveform settings from preamble:
wav_form_dict = {
    0 : "BYTE",
    1 : "WORD",
    4 : "ASCII",
}
acq_type_dict = {
    0 : "NORMAL",
    1 : "PEAK",
    2 : "AVERage",
    3 : "HRESolution",
}

preamble_string = do_query_string(":WAVEform:PREamble?")
(
    wav_form, acq_type, wfmpnts, avgcnt, x_increment, x_origin,
    x_reference, y_increment, y_origin, y_reference
) = preamble_string.split(",")

print("Waveform format: %s" % wav_form_dict[int(wav_form)])
print("Acquire type: %s" % acq_type_dict[int(acq_type)])
print("Waveform points desired: %s" % wfmpnts)
print("Waveform average count: %s" % avgcnt)
print("Waveform X increment: %s" % x_increment)
print("Waveform X origin: %s" % x_origin)
print("Waveform X reference: %s" % x_reference)    # Always 0.
print("Waveform Y increment: %s" % y_increment)
print("Waveform Y origin: %s" % y_origin)
print("Waveform Y reference: %s" % y_reference)

# Get numeric values for later calculations.
x_increment = do_query_number(":WAVEform:XINCrement?")
x_origin = do_query_number(":WAVEform:XORigin?")
y_increment = do_query_number(":WAVEform:YINCrement?")
y_origin = do_query_number(":WAVEform:YORigin?")
y_reference = do_query_number(":WAVEform:YREFerence?")

```

```

# Get the waveform data.
sData = do_query_ieee_block(":WAVEform:DATA?")

# Unpack unsigned byte data.
values = struct.unpack("%dB" % len(sData), sData)
print("Number of data values: %d" % len(values))

# Save waveform data values to CSV file.
f = open("waveform_data.csv", "w")

for i in range(0, len(values) - 1):
    time_val = x_origin + (i * x_increment)
    voltage = ((values[i] - y_reference) * y_increment) + y_origin
    f.write("%E, %f\n" % (time_val, voltage))

f.close()
print("Waveform format BYTE data written to waveform_data.csv.")

# =====
# Send a command and check for errors:
# =====
def do_command(command, hide_params=False):

    if hide_params:
        (header, data) = command.split(" ", 1)
        if debug:
            print("\nCmd = '%s'" % header)
        else:
            if debug:
                print("\nCmd = '%s'" % command)

        InfiniiVision.write("%s" % command)

        if hide_params:
            check_instrument_errors(header)
        else:
            check_instrument_errors(command)

# =====
# Send a command and binary values and check for errors:
# =====
def do_command_ieee_block(command, values):
    if debug:
        print("Cmb = '%s'" % command)
    InfiniiVision.write_binary_values("%s " % command, values, datatype='B')
    check_instrument_errors(command)

# =====
# Send a query, check for errors, return string:
# =====
def do_query_string(query):
    if debug:

```

```

    print("Qys = '%s'" % query)
    result = InfiniiVision.query("%s" % query)
    check_instrument_errors(query)
    return result

# =====
# Send a query, check for errors, return floating-point value:
# =====
def do_query_number(query):
    if debug:
        print("Qyn = '%s'" % query)
    results = InfiniiVision.query("%s" % query)
    check_instrument_errors(query)
    return float(results)

# =====
# Send a query, check for errors, return binary values:
# =====
def do_query_ieee_block(query):
    if debug:
        print("Qys = '%s'" % query)
    result = InfiniiVision.query_binary_values("%s" % query, datatype='s')
    check_instrument_errors(query)
    return result[0]

# =====
# Check for instrument errors:
# =====
def check_instrument_errors(command):

    while True:
        error_string = InfiniiVision.query(":SYSTem:ERRor?")
        if error_string:    # If there is an error string value.

            if error_string.find("+0," , 0, 3) == -1:    # Not "No error".

                print("ERROR: %s, command: '%s'" % (error_string, command))
                print("Exited because of error.")
                sys.exit(1)

            else:    # "No error"
                break

        else:    # :SYSTem:ERRor? should always return string.
            print("ERROR: :SYSTem:ERRor? returned nothing, command: '%s'" % command)
            print("Exited because of error.")
            sys.exit(1)

# =====
# Main program:
# =====

```

```
rm = visa.ResourceManager("C:\\Windows\\System32\\agvisa32.dll")
InfiniiVision = rm.open_resource("TCPIP0::a-mso-x-2260014.cos.is.keysight.com::inst0::INSTR")

InfiniiVision.timeout = 15000
InfiniiVision.clear()

# Initialize the oscilloscope, capture data, and analyze.
initialize()
capture()
analyze()

InfiniiVision.close()
print("End of program.")
sys.exit()
```

## VISA.NET Examples

These programming examples show how to use the VISA.NET drivers that come with Keysight IO Libraries Suite.

- "VISA.NET Example in C#" on page 1756
- "VISA.NET Example in Visual Basic .NET" on page 1762

### VISA.NET Example in C#

To compile and run this example in Microsoft Visual Studio 2013:

- 1 Open Visual Studio.
- 2 Choose **FILE > New > Project....**
- 3 In the New Project dialog box, select **.NET Framework 4.5.2**.
- 4 Create a new Visual C#, Console Application project.
- 5 Cut-and-paste the code that follows into the C# source file.
- 6 Edit the program to use the VISA address of your oscilloscope.
- 7 Add a reference to the VISA.NET driver:
  - a Right-click the project you wish to modify (not the solution) in the Solution Explorer window of the Microsoft Visual Studio environment.
  - b Choose **Add Reference....**
  - c In the Reference Manager dialog box, under **Assemblies**, select **Extensions**.
  - d In the "Targeting: .NET Framework 4.5.2" list, select the **Ivi.Visa Assembly** check box; then, click **OK**.
- 8 Build and run the program.

For more information, see the VISA.NET Help that comes with Keysight IO Libraries Suite.

```
/*
 * Keysight VISA.NET Example in C#
 * -----
 * This program illustrates a few commonly used programming
 * features of your Keysight InfiniiVision oscilloscope.
 * -----
 */

using System;
using System.IO;
using System.Collections.Generic;
using System.Text;

using Ivi.Visa;
using Ivi.Visa.FormattedIO;
```

```

namespace Example
{
    class Program
    {

        static void Main(string[] args)
        {
            // Change this variable to the address of your instrument
            string VISA_ADDRESS = "TCPIP0::141.121.230.6::inst0::INSTR";

            // Create a connection (session) to the instrument
            IMessageBasedSession session;
            try
            {
                session = GlobalResourceManager.Open(VISA_ADDRESS) as
                    IMessageBasedSession;
            }
            catch (NativeVisaException visaException)
            {
                Console.WriteLine("Couldn't connect.");
                Console.WriteLine("Error is:\r\n{0}\r\n", visaException);
                Console.WriteLine("Press any key to exit...");
                Console.ReadKey();
                return;
            }

            // Create a formatted I/O object which will help us format the
            // data we want to send/receive to/from the instrument
            MessageBasedFormattedIO myScope =
                new MessageBasedFormattedIO(session);

            // For Serial and TCP/IP socket connections enable the read
            // Termination Character, or read's will timeout
            if (session.ResourceName.Contains("ASRL") ||
                session.ResourceName.Contains("SOCKET"))
                session.TerminationCharacterEnabled = true;

            session.TimeoutMilliseconds = 20000;

            // Initialize - start from a known state.
            // =====
            string strResults;
            FileStream fStream;

            // Get and display the device's *IDN? string.
            myScope.WriteLine("*IDN?");
            strResults = myScope.ReadLine();
            Console.WriteLine("*IDN? result is: {0}", strResults);

            // Clear status and load the default setup.
            myScope.WriteLine("*CLS");
            myScope.WriteLine("*RST");

            // Capture data.
            // =====
            // Use auto-scale to automatically configure oscilloscope.
            myScope.WriteLine(":AUToscale");
        }
    }
}

```

```

// Set trigger mode (EDGE, PULSe, PATTern, etc., and input source.
myScope.WriteLine(":TRIGger:MODE EDGE");
myScope.WriteLine(":TRIGger:MODE?");
strResults = myScope.ReadLine();
Console.WriteLine("Trigger mode: {0}", strResults);

// Set EDGE trigger parameters.
myScope.WriteLine(":TRIGger:EDGE:SOURce CHANnel1");
myScope.WriteLine(":TRIGger:EDGE:SOURce?");
strResults = myScope.ReadLine();
Console.WriteLine("Trigger edge source: {0}", strResults);

myScope.WriteLine(":TRIGger:EDGE:LEVel 1.5");
myScope.WriteLine(":TRIGger:EDGE:LEVel?");
strResults = myScope.ReadLine();
Console.WriteLine("Trigger edge level: {0}", strResults);

myScope.WriteLine(":TRIGger:EDGE:SLOPe POSitive");
myScope.WriteLine(":TRIGger:EDGE:SLOPe?");
strResults = myScope.ReadLine();
Console.WriteLine("Trigger edge slope: {0}", strResults);

// Save oscilloscope configuration.
byte[] ResultsArray; // Results array.
int nLength; // Number of bytes returned from instrument.
string strPath;

// Query and read setup string.
myScope.WriteLine(":SYSTem:SETup?");
ResultsArray = myScope.ReadLineBinaryBlockOfByte();
nLength = ResultsArray.Length;

// Write setup string to file.
strPath = "c:\\scope\\config\\setup.stp";
fStream = File.Open(strPath, FileMode.Create);
fStream.Write(ResultsArray, 0, nLength);
fStream.Close();
Console.WriteLine("Setup bytes saved: {0}", nLength);

// Change settings with individual commands:

// Set vertical scale and offset.
myScope.WriteLine(":CHANnel1:SCALe 0.05");
myScope.WriteLine(":CHANnel1:SCALe?");
strResults = myScope.ReadLine();
Console.WriteLine("Channel 1 vertical scale: {0}", strResults);

myScope.WriteLine(":CHANnel1:OFFSet -1.5");
myScope.WriteLine(":CHANnel1:OFFSet?");
strResults = myScope.ReadLine();
Console.WriteLine("Channel 1 vertical offset: {0}", strResults);

// Set horizontal scale and offset.
myScope.WriteLine(":TIMEbase:SCALe 0.0002");
myScope.WriteLine(":TIMEbase:SCALe?");
strResults = myScope.ReadLine();

```

```

Console.WriteLine("Timebase scale: {0}", strResults);

myScope.WriteLine(":TIMEbase:POSition 0.0");
myScope.WriteLine(":TIMEbase:POSition?");
strResults = myScope.ReadLine();
Console.WriteLine("Timebase position: {0}", strResults);

// Set the acquisition type (NORMAL, PEAK, AVERAGE, or HRESolution
).
myScope.WriteLine(":ACQuire:TYPE NORMAL");
myScope.WriteLine(":ACQuire:TYPE?");
strResults = myScope.ReadLine();
Console.WriteLine("Acquire type: {0}", strResults);

// Or, configure by loading a previously saved setup.
byte[] dataArray;
int nBytesWritten;

// Read setup string from file.
strPath = "c:\\scope\\config\\setup.stp";
dataArray = File.ReadAllBytes(strPath);
nBytesWritten = dataArray.Length;

// Restore setup string.
myScope.WriteLine(":SYSTem:SETup ");
myScope.WriteBinary(dataArray);
myScope.WriteLine("");
Console.WriteLine("Setup bytes restored: {0}", nBytesWritten);

// Capture an acquisition using :DIGitize.
myScope.WriteLine(":DIGITIZE CHANnel1");

// Analyze the captured waveform.
// =====

// Make a couple of measurements.
// -----
myScope.WriteLine(":MEASure:SOURce CHANnel1");
myScope.WriteLine(":MEASure:SOURce?");
strResults = myScope.ReadLine();
Console.WriteLine("Measure source: {0}", strResults);

double fResult;
myScope.WriteLine(":MEASure:FREQuency");
myScope.WriteLine(":MEASure:FREQuency?");
fResult = myScope.ReadLineDouble();
Console.WriteLine("Frequency: {0:F4} kHz", fResult / 1000);

myScope.WriteLine(":MEASure:VAMplitude");
myScope.WriteLine(":MEASure:VAMplitude?");
fResult = myScope.ReadLineDouble();
Console.WriteLine("Vertical amplitude: {0:F2} V", fResult);

// Download the screen image.
// -----
myScope.WriteLine(":HARDcopy:INKSaver OFF");

```

```

// Get the screen data.
myScope.WriteLine(":DISPlay:DATA? PNG, COLOR");
ResultsArray = myScope.ReadLineBinaryBlockOfByte();
nLength = ResultsArray.Length;

// Store the screen data to a file.
strPath = "c:\\scope\\data\\screen.png";
fStream = File.Open(strPath, FileMode.Create);
fStream.Write(ResultsArray, 0, nLength);
fStream.Close();
Console.WriteLine("Screen image ({0} bytes) written to {1}",
    nLength, strPath);

// Download waveform data.
// ----

// Set the waveform points mode.
myScope.WriteLine(":WAVEform:POINTS:MODE RAW");
myScope.WriteLine(":WAVEform:POINTS:MODE?");
strResults = myScope.ReadLine();
Console.WriteLine("Waveform points mode: {0}", strResults);

// Get the number of waveform points available.
myScope.WriteLine(":WAVEform:POINTS?");
strResults = myScope.ReadLine();
Console.WriteLine("Waveform points available: {0}", strResults);

// Set the waveform source.
myScope.WriteLine(":WAVEform:SOURce CHANnel1");
myScope.WriteLine(":WAVEform:SOURce?");
strResults = myScope.ReadLine();
Console.WriteLine("Waveform source: {0}", strResults);

// Choose the format of the data returned (WORD, BYTE, ASCII):
myScope.WriteLine(":WAVEform:FORMAT BYTE");
myScope.WriteLine(":WAVEform:FORMAT?");
strResults = myScope.ReadLine();
Console.WriteLine("Waveform format: {0}", strResults);

// Display the waveform settings:
double[] fResultsArray;
myScope.WriteLine(":WAVEform:PREamble?");
fResultsArray = myScope.ReadLineListOfDouble();

double fFormat = fResultsArray[0];
if (fFormat == 0.0)
{
    Console.WriteLine("Waveform format: BYTE");
}
else if (fFormat == 1.0)
{
    Console.WriteLine("Waveform format: WORD");
}
else if (fFormat == 2.0)
{
    Console.WriteLine("Waveform format: ASCII");
}

```

```

double fType = fResultsArray[1];
if (fType == 0.0)
{
    Console.WriteLine("Acquire type: NORMAl");
}
else if (fType == 1.0)
{
    Console.WriteLine("Acquire type: PEAK");
}
else if (fType == 2.0)
{
    Console.WriteLine("Acquire type: AVERAge");
}
else if (fType == 3.0)
{
    Console.WriteLine("Acquire type: HRESolution");
}

double fPoints = fResultsArray[2];
Console.WriteLine("Waveform points: {0:e}", fPoints);

double fCount = fResultsArray[3];
Console.WriteLine("Waveform average count: {0:e}", fCount);

double fXincrement = fResultsArray[4];
Console.WriteLine("Waveform X increment: {0:e}", fXincrement);

double fXorigin = fResultsArray[5];
Console.WriteLine("Waveform X origin: {0:e}", fXorigin);

double fXreference = fResultsArray[6];
Console.WriteLine("Waveform X reference: {0:e}", fXreference);

double fYincrement = fResultsArray[7];
Console.WriteLine("Waveform Y increment: {0:e}", fYincrement);

double fYorigin = fResultsArray[8];
Console.WriteLine("Waveform Y origin: {0:e}", fYorigin);

double fYreference = fResultsArray[9];
Console.WriteLine("Waveform Y reference: {0:e}", fYreference);

// Read waveform data.
myScope.WriteLine(":WAVEform:DATA?");
ResultsArray = myScope.ReadLineBinaryBlockOfByte();
nLength = ResultsArray.Length;
Console.WriteLine("Number of data values: {0}", nLength);

// Set up output file:
strPath = "c:\\scope\\data\\waveform_data.csv";
if (File.Exists(strPath)) File.Delete(strPath);

// Open file for output.
StreamWriter writer = File.CreateText(strPath);

// Output waveform data in CSV format.

```

```

        for (int i = 0; i < nLength - 1; i++)
            writer.WriteLine("{0:f9}, {1:f6}",
                fxorigin + ((float)i * fXincrement),
                (((float)ResultsArray[i] - fYreference)
                 * fYincrement) + fYorigin);

        // Close output file.
        writer.Close();
        Console.WriteLine("Waveform format BYTE data written to {0}",
            strPath);

        // Close the connection to the instrument
        // -----
        session.Dispose();

        Console.WriteLine("Press any key to exit...");
        Console.ReadKey();

    }
}
}

```

## VISA.NET Example in Visual Basic .NET

To compile and run this example in Microsoft Visual Studio 2013:

- 1** Open Visual Studio.
- 2** Choose **FILE > New > Project....**
- 3** In the New Project dialog box, select **.NET Framework 4.5.2**.
- 4** Create a new Visual Basic, Console Application project.
- 5** Cut-and-paste the code that follows into the Visual Basic .NET source file.
- 6** Edit the program to use the VISA address of your oscilloscope.
- 7** Add a reference to the VISA.NET driver:
  - a** Right-click the project you wish to modify (not the solution) in the Solution Explorer window of the Microsoft Visual Studio environment.
  - b** Choose **Add Reference...**
  - c** In the Reference Manager dialog box, under **Assemblies**, select **Extensions**.
  - d** In the "Targeting: .NET Framework 4.5.2" list, select the **Ivi.Visa Assembly** check box; then, click **OK**.
- 8** Specify the Startup object:
  - a** Right-click the project you wish to modify (not the solution) in the Solution Explorer window of the Microsoft Visual Studio environment.
  - b** Choose **Properties**.
  - c** In the Properties dialog box, under **Application**, select the **Startup object:** field and choose **Sub Main**.
  - d** Save your change and close the Properties dialog box.

**9** Build and run the program.

For more information, see the VISA.NET driver help that comes with Keysight Command Expert.

```
'-----'
' Keysight VISA.NET Example in VB.NET
' -----
' This program illustrates a few commonly used programming
' features of your Keysight InfiniiVision oscilloscope.
' -----'

Imports System
Imports System.IO
Imports System.Collections.Generic
Imports System.Text

Imports Ivi.Visa
Imports Ivi.Visa.FormattedIO

Namespace Example
    Class Program

        Public Shared Sub Main(args As String())
            ' Change this variable to the address of your instrument
            Dim VISA_ADDRESS As String = "TCPIPO::141.121.230.6::inst0::INSTR"

            ' Create a connection (session) to the instrument
            Dim session As IMessageBasedSession
            Try
                session = TryCast(GlobalResourceManager.Open(VISA_ADDRESS), _
                    IMessageBasedSession)
                Catch visaException As NativeVisaException
                    Console.WriteLine("Couldn't connect.")
                    Console.WriteLine("Error is:" & vbCrLf & "{0}" & vbCrLf & vbCrLf, visaException)
                    Console.WriteLine("Press any key to exit...")
                    Console.ReadKey()
                    Return
                End Try

                ' Create a formatted I/O object which will help us format the
                ' data we want to send/receive to/from the instrument
                Dim myScope As New MessageBasedFormattedIO(session)

                ' For Serial and TCP/IP socket connections enable the read
                ' Termination Character, or read's will timeout
                If session.ResourceName.Contains("ASRL") OrElse _
                    session.ResourceName.Contains("SOCKET") Then
                    session.TerminationCharacterEnabled = True
                End If

                session.TimeoutMilliseconds = 20000

                ' Initialize - start from a known state.
                ' =====
            End Sub
        End Class
    End Namespace
```

```

Dim strResults As String
Dim fStream As FileStream

' Get and display the device's *IDN? string.
myScope.WriteLine("*IDN?")
strResults = myScope.ReadLine()
Console.WriteLine("*IDN? result is: {0}", strResults)

' Clear status and load the default setup.
myScope.WriteLine("*CLS")
myScope.WriteLine("*RST")

' Capture data.
' =====
' Use auto-scale to automatically configure oscilloscope.
myScope.WriteLine(":AUToscale")

' Set trigger mode (EDGE, PULSe, PATTern, etc., and input source.
myScope.WriteLine(":TRIGger:MODE EDGE")
myScope.WriteLine(":TRIGger:MODE?")
strResults = myScope.ReadLine()
Console.WriteLine("Trigger mode: {0}", strResults)

' Set EDGE trigger parameters.
myScope.WriteLine(":TRIGger:EDGE:SOURce CHANnel1")
myScope.WriteLine(":TRIGger:EDGE:SOURce?")
strResults = myScope.ReadLine()
Console.WriteLine("Trigger edge source: {0}", strResults)

myScope.WriteLine(":TRIGger:EDGE:LEVel 1.5")
myScope.WriteLine(":TRIGger:EDGE:LEVel?")
strResults = myScope.ReadLine()
Console.WriteLine("Trigger edge level: {0}", strResults)

myScope.WriteLine(":TRIGger:EDGE:SLOPe POSitive")
myScope.WriteLine(":TRIGger:EDGE:SLOPe?")
strResults = myScope.ReadLine()
Console.WriteLine("Trigger edge slope: {0}", strResults)

' Save oscilloscope configuration.
Dim ResultsArray As Byte()
' Results array.
Dim nLength As Integer
' Number of bytes returned from instrument.
Dim strPath As String

' Query and read setup string.
myScope.WriteLine(":SYSTem:SETup?")
ResultsArray = myScope.ReadLineBinaryBlockOfByte()
nLength = ResultsArray.Length

' Write setup string to file.
strPath = "c:\scope\config\setup.stp"
fStream = File.Open(strPath, FileMode.Create)
fStream.Write(ResultsArray, 0, nLength)
fStream.Close()
Console.WriteLine("Setup bytes saved: {0}", nLength)

```

```

' Change settings with individual commands:

' Set vertical scale and offset.
myScope.WriteLine(":CHANnel1:SCALE 0.05")
myScope.WriteLine(":CHANnel1:SCALE?")
strResults = myScope.ReadLine()
Console.WriteLine("Channel 1 vertical scale: {0}", strResults)

myScope.WriteLine(":CHANnel1:OFFSet -1.5")
myScope.WriteLine(":CHANnel1:OFFSet?")
strResults = myScope.ReadLine()
Console.WriteLine("Channel 1 vertical offset: {0}", strResults)

' Set horizontal scale and offset.
myScope.WriteLine(":TIMEbase:SCALE 0.0002")
myScope.WriteLine(":TIMEbase:SCALE?")
strResults = myScope.ReadLine()
Console.WriteLine("Timebase scale: {0}", strResults)

myScope.WriteLine(":TIMEbase:POSITION 0.0")
myScope.WriteLine(":TIMEbase:POSITION?")
strResults = myScope.ReadLine()
Console.WriteLine("Timebase position: {0}", strResults)

' Set the acquisition type (NORMAL, PEAK, AVERage, or HRESolution)

myScope.WriteLine(":ACQuire:TYPE NORMAL")
myScope.WriteLine(":ACQuire:TYPE?")
strResults = myScope.ReadLine()
Console.WriteLine("Acquire type: {0}", strResults)

' Or, configure by loading a previously saved setup.
Dim dataArray As Byte()
Dim nBytesWritten As Integer

' Read setup string from file.
strPath = "c:\scope\config\setup.stp"
dataArray = File.ReadAllBytes(strPath)
nBytesWritten = dataArray.Length

' Restore setup string.
myScope.WriteLine(":SYSTem:SETup ")
myScope.WriteBinary(dataArray)
myScope.WriteLine("")
Console.WriteLine("Setup bytes restored: {0}", nBytesWritten)

' Capture an acquisition using :DIGITIZE.
myScope.WriteLine(":DIGITIZE CHANnel1")

' Analyze the captured waveform.
' =====

' Make a couple of measurements.
' -----
myScope.WriteLine(":MEASure:SOURce CHANnel1")
myScope.WriteLine(":MEASure:SOURce?")

```

```

strResults = myScope.ReadLine()
Console.WriteLine("Measure source: {0}", strResults)

Dim fResult As Double
myScope.WriteLine(":MEASure:FREQuency")
myScope.WriteLine(":MEASure:FREQuency?")
fResult = myScope.ReadLineDouble()
Console.WriteLine("Frequency: {0:F4} kHz", fResult / 1000)

myScope.WriteLine(":MEASure:VAMPplitude")
myScope.WriteLine(":MEASure:VAMPplitude?")
fResult = myScope.ReadLineDouble()
Console.WriteLine("Vertical amplitude: {0:F2} V", fResult)

' Download the screen image.
' -----
myScope.WriteLine(":HARDcopy:INKSaver OFF")

' Get the screen data.
myScope.WriteLine(":DISPlay:DATA? PNG, COLOR")
ResultsArray = myScope.ReadLineBinaryBlockOfByte()
nLength = ResultsArray.Length

' Store the screen data to a file.
strPath = "c:\scope\data\screen.png"
fStream = File.Open(strPath, FileMode.Create)
fStream.Write(ResultsArray, 0, nLength)
fStream.Close()
Console.WriteLine("Screen image ({0} bytes) written to {1}", _
    nLength, strPath)

' Download waveform data.
' ----

' Set the waveform points mode.
myScope.WriteLine(":WAVEform:POINTS:MODE RAW")
myScope.WriteLine(":WAVEform:POINTS:MODE?")
strResults = myScope.ReadLine()
Console.WriteLine("Waveform points mode: {0}", strResults)

' Get the number of waveform points available.
myScope.WriteLine(":WAVEform:POINTS?")
strResults = myScope.ReadLine()
Console.WriteLine("Waveform points available: {0}", strResults)

' Set the waveform source.
myScope.WriteLine(":WAVEform:SOURce CHANnel1")
myScope.WriteLine(":WAVEform:SOURce?")
strResults = myScope.ReadLine()
Console.WriteLine("Waveform source: {0}", strResults)

' Choose the format of the data returned (WORD, BYTE, ASCII):
myScope.WriteLine(":WAVEform:FORMAT BYTE")
myScope.WriteLine(":WAVEform:FORMAT?")
strResults = myScope.ReadLine()
Console.WriteLine("Waveform format: {0}", strResults)

```

```

' Display the waveform settings:
Dim fResultsArray As Double()
myScope.WriteLine(":WAVEform:PREamble?")
fResultsArray = myScope.ReadLineListOfDouble()

Dim fFormat As Double = fResultsArray(0)
If fFormat = 0.0 Then
    Console.WriteLine("Waveform format: BYTE")
ElseIf fFormat = 1.0 Then
    Console.WriteLine("Waveform format: WORD")
ElseIf fFormat = 2.0 Then
    Console.WriteLine("Waveform format: ASCII")
End If

Dim fType As Double = fResultsArray(1)
If fType = 0.0 Then
    Console.WriteLine("Acquire type: NORMAL")
ElseIf fType = 1.0 Then
    Console.WriteLine("Acquire type: PEAK")
ElseIf fType = 2.0 Then
    Console.WriteLine("Acquire type: AVERage")
ElseIf fType = 3.0 Then
    Console.WriteLine("Acquire type: HRESolution")
End If

Dim fPoints As Double = fResultsArray(2)
Console.WriteLine("Waveform points: {0:e}", fPoints)

Dim fCount As Double = fResultsArray(3)
Console.WriteLine("Waveform average count: {0:e}", fCount)

Dim fXincrement As Double = fResultsArray(4)
Console.WriteLine("Waveform X increment: {0:e}", fXincrement)

Dim fXorigin As Double = fResultsArray(5)
Console.WriteLine("Waveform X origin: {0:e}", fXorigin)

Dim fXreference As Double = fResultsArray(6)
Console.WriteLine("Waveform X reference: {0:e}", fXreference)

Dim fYincrement As Double = fResultsArray(7)
Console.WriteLine("Waveform Y increment: {0:e}", fYincrement)

Dim fYorigin As Double = fResultsArray(8)
Console.WriteLine("Waveform Y origin: {0:e}", fYorigin)

Dim fYreference As Double = fResultsArray(9)
Console.WriteLine("Waveform Y reference: {0:e}", fYreference)

' Read waveform data.
myScope.WriteLine(":WAVEform:DATA?")
ResultsArray = myScope.ReadLineBinaryBlockOfByte()
nLength = ResultsArray.Length
Console.WriteLine("Number of data values: {0}", nLength)

' Set up output file:
strPath = "c:\scope\data\waveform_data.csv"

```

```
If File.Exists(strPath) Then
    File.Delete(strPath)
End If

' Open file for output.
Dim writer As StreamWriter = File.CreateText(strPath)

' Output waveform data in CSV format.
For i As Integer = 0 To nLength - 2
    writer.WriteLine("{0:f9}, {1:f6}", _
        fXorigin + (CSng(i) * fXincrement), _
        ((CSng(ResultsArray(i)) - fYreference) _ 
         * fYincrement) + fYorigin)
Next

' Close output file.
writer.Close()
Console.WriteLine("Waveform format BYTE data written to {0}", _
    strPath)

' Close the connection to the instrument
' -----
session.Dispose()

Console.WriteLine("Press any key to exit...")
Console.ReadKey()

End Sub
End Class
End Namespace
```

## SICL Examples

- "SICL Example in C" on page 1769
- "SICL Example in Visual Basic" on page 1778

### SICL Example in C

To compile and run this example in Microsoft Visual Studio 2008:

- 1 Open Visual Studio.
- 2 Create a new Visual C++, Win32, Win32 Console Application project.
- 3 In the Win32 Application Wizard, click **Next >**. Then, check **Empty project**, and click **Finish**.
- 4 Cut-and-paste the code that follows into a file named "example.c" in the project directory.
- 5 In Visual Studio 2008, right-click the Source Files folder, choose **Add > Add Existing Item...**, select the example.c file, and click **Add**.
- 6 Edit the program to use the SICL address of your oscilloscope.
- 7 Choose **Project > Properties....** In the Property Pages dialog, update these project settings:
  - a Under Configuration Properties, Linker, Input, add "sicl32.lib" to the Additional Dependencies field.
  - b Under Configuration Properties, C/C++, Code Generation, select Multi-threaded DLL for the Runtime Library field.
  - c Click **OK** to close the Property Pages dialog.
- 8 Add the include files and library files search paths:
  - a Choose **Tools > Options....**
  - b In the Options dialog, select **VC++ Directories** under Projects and Solutions.
  - c Show directories for **Include files**, and add the include directory (for example, Program Files\Agilent\IO Libraries Suite\include).
  - d Show directories for **Library files**, and add the library files directory (for example, Program Files\Agilent\IO Libraries Suite\lib).
  - e Click **OK** to close the Options dialog.
- 9 Build and run the program.

```
/*
 * Keysight SICL Example in C
 * -----
 * This program illustrates a few commonly-used programming
 * features of your Keysight oscilloscope.
 */

#include <stdio.h>           /* For printf() . */
```

```

#include <string.h>           /* For strcpy(), strcat(). */
#include <time.h>            /* For clock(). */
#include <sicl.h>             /* Keysight SICL routines. */

#define SICL_ADDRESS      "usb0[2391::6054::US50210029::0]"
#define TIMEOUT          5000
#define IEEEBLOCK_SPACE  300000

/* Function prototypes */
void initialize(void);           /* Initialize to known state. */
void capture(void);              /* Capture the waveform. */
void analyze(void);              /* Analyze the captured waveform. */

void do_command(char *command);   /* Send command. */
int do_command_ieeeblock(char *command); /* Command w/IEEE block. */
void do_query_string(char *query); /* Query for string. */
void do_query_number(char *query); /* Query for number. */
void do_query_numbers(char *query); /* Query for numbers. */
int do_query_ieeeblock(char *query); /* Query for IEEE block. */
void check_instrument_errors();   /* Check for inst errors. */

/* Global variables */
INST id;                         /* Device session ID. */
char str_result[256] = {0};        /* Result from do_query_string(). */
double num_result;                /* Result from do_query_number(). */
unsigned char ieeeblock_data[IEEEBLOCK_SPACE]; /* Result from
  do_query_ieeeblock(). */
double dbl_results[10];           /* Result from do_query_numbers(). */

/* Main Program
 * -----
void main(void)
{
    /* Install a default SICL error handler that logs an error message
     * and exits. On Windows 98SE or Windows Me, view messages with
     * the SICL Message Viewer. For Windows 2000 or XP, use the Event
     * Viewer.
    */
    ionerror(I_ERROR_EXIT);

    /* Open a device session using the SICL_ADDRESS */
    id = iopen(SICL_ADDRESS);

    if (id == 0)
    {
        printf ("Oscilloscope iopen failed!\n");
    }
    else
    {
        printf ("Oscilloscope session opened!\n");
    }

    /* Initialize - start from a known state. */
    initialize();

    /* Capture data. */
    capture();
}

```

```

/* Analyze the captured waveform. */
analyze();

/* Close the device session to the instrument. */
iclose(id);
printf ("Program execution is complete...\n");

/* For WIN16 programs, call _siclcleanup before exiting to release
 * resources allocated by SICL for this application. This call is
 * a no-op for WIN32 programs.
 */
_siclcleanup();
}

/* Initialize the oscilloscope to a known state.
 * -----
void initialize (void)
{
    /* Set the I/O timeout value for this session to 5 seconds. */
    itimeout(id, TIMEOUT);

    /* Clear the interface. */
    iclear(id);

    /* Get and display the device's *IDN? string. */
    do_query_string("*IDN?");
    printf("Oscilloscope *IDN? string: %s\n", str_result);

    /* Clear status and load the default setup. */
    do_command("*CLS");
    do_command("*RST");
}

/* Capture the waveform.
 * -----
void capture (void)
{
    int num_bytes;
    FILE *fp;

    /* Use auto-scale to automatically configure oscilloscope.
     * -----
    do_command(":AUToscale");

    /* Set trigger mode (EDGE, PULSe, PATTern, etc., and input source. */
    do_command(":TRIGger:MODE EDGE");
    do_query_string(":TRIGger:MODE?");
    printf("Trigger mode: %s\n", str_result);

    /* Set EDGE trigger parameters. */
    do_command(":TRIGger:EDGE:SOURce CHANnel1");
    do_query_string(":TRIGger:EDGE:SOURce?");
    printf("Trigger edge source: %s\n", str_result);

    do_command(":TRIGger:EDGE:LEVel 1.5");
    do_query_string(":TRIGger:EDGE:LEVel?");
}

```

```

printf("Trigger edge level: %s\n", str_result);

do_command(":TRIGger:EDGE:SLOPe POSitive");
do_query_string(":TRIGger:EDGE:SLOPe?");
printf("Trigger edge slope: %s\n", str_result);

/* Save oscilloscope configuration.
 * -----
 */

/* Read system setup. */
num_bytes = do_query_ieeeblock(":SYSTem:SETUp?");
printf("Read setup string query (%d bytes).\n", num_bytes);

/* Write setup string to file. */
fp = fopen ("c:\\scope\\config\\setup.stp", "wb");
num_bytes = fwrite(ieeeblock_data, sizeof(unsigned char), num_bytes,
    fp);
fclose (fp);
printf("Wrote setup string (%d bytes) to ", num_bytes);
printf("c:\\scope\\config\\setup.stp.\n");

/* Change settings with individual commands:
 * -----
 */

/* Set vertical scale and offset. */
do_command(":CHANnel1:SCALe 0.05");
do_query_string(":CHANnel1:SCALe?");
printf("Channel 1 vertical scale: %s\n", str_result);

do_command(":CHANnel1:OFFSet -1.5");
do_query_string(":CHANnel1:OFFSet?");
printf("Channel 1 offset: %s\n", str_result);

/* Set horizontal scale and position. */
do_command(":TIMEbase:SCALe 0.0002");
do_query_string(":TIMEbase:SCALe?");
printf("Timebase scale: %s\n", str_result);

do_command(":TIMEbase:POSIon 0.0");
do_query_string(":TIMEbase:POSIon?");
printf("Timebase position: %s\n", str_result);

/* Set the acquisition type (NORMAL, PEAK, AVERAGE, or HRESolution). */
do_command(":ACQuire:TYPE NORMAL");
do_query_string(":ACQuire:TYPE?");
printf("Acquire type: %s\n", str_result);

/* Or, configure by loading a previously saved setup.
 * -----
 */

/* Read setup string from file. */
fp = fopen ("c:\\scope\\config\\setup.stp", "rb");
num_bytes = fread (ieeeblock_data, sizeof(unsigned char),
    IEEEBLOCK_SPACE, fp);
fclose (fp);
printf("Read setup string (%d bytes) from file ", num_bytes);

```

```

printf("c:\\\\scope\\\\config\\\\setup.stp.\n");

/* Restore setup string. */
num_bytes = do_command_ieeeblock(":SYSTem:SEtUp", num_bytes);
printf("Restored setup string (%d bytes).\n", num_bytes);

/* Capture an acquisition using :DIGItize.
 * -----
do_command(":DIGItize CHANnel1");
}

/* Analyze the captured waveform.
 * -----
void analyze (void)
{
    double wav_format;
    double acq_type;
    double wav_points;
    double avg_count;
    double x_increment;
    double x_origin;
    double x_reference;
    double y_increment;
    double y_origin;
    double y_reference;

    FILE *fp;
    int num_bytes; /* Number of bytes returned from instrument. */
    int i;

    /* Make a couple of measurements.
     * -----
do_command(":MEASure:SOURce CHANnel1");
do_query_string(":MEASure:SOURce?");
printf("Measure source: %s\n", str_result);

do_command(":MEASure:FREQuency");
do_query_number(":MEASure:FREQuency?");
printf("Frequency: %.4f kHz\n", num_result / 1000);

do_command(":MEASure:VAMplitude");
do_query_number(":MEASure:VAMplitude?");
printf("Vertical amplitude: %.2f V\n", num_result);

/* Download the screen image.
 * -----
do_command(":HARDcopy:INKSaver OFF");

/* Read screen image. */
num_bytes = do_query_ieeeblock(":DISPlay:DATA? PNG, COlor");
printf("Screen image bytes: %d\n", num_bytes);

/* Write screen image bytes to file. */
fp = fopen ("c:\\\\scope\\\\data\\\\screen.png", "wb");
num_bytes = fwrite(ieeeblock_data, sizeof(unsigned char), num_bytes,
                  fp);
fclose (fp);
}

```

```

printf("Wrote screen image (%d bytes) to ", num_bytes);
printf("c:\\scope\\data\\screen.png.\n");

/* Download waveform data.
 * -----
 */

/* Set the waveform points mode. */
do_command(":WAVEform:POINTs:MODE RAW");
do_query_string(":WAVEform:POINTs:MODE?");
printf("Waveform points mode: %s\n", str_result);

/* Get the number of waveform points available. */
do_command(":WAVEform:POINTs 10240");
do_query_string(":WAVEform:POINTs?");
printf("Waveform points available: %s\n", str_result);

/* Set the waveform source. */
do_command(":WAVEform:SOURce CHANnel1");
do_query_string(":WAVEform:SOURCE?");
printf("Waveform source: %s\n", str_result);

/* Choose the format of the data returned (WORD, BYTE, ASCII): */
do_command(":WAVEform:FORMAT BYTE");
do_query_string(":WAVEform:FORMAT?");
printf("Waveform format: %s\n", str_result);

/* Display the waveform settings: */
do_query_numbers(":WAVEform:PREamble?");

wav_format = dbl_results[0];
if (wav_format == 0.0)
{
    printf("Waveform format: BYTE\n");
}
else if (wav_format == 1.0)
{
    printf("Waveform format: WORD\n");
}
else if (wav_format == 2.0)
{
    printf("Waveform format: ASCii\n");
}

acq_type = dbl_results[1];
if (acq_type == 0.0)
{
    printf("Acquire type: NORMAL\n");
}
else if (acq_type == 1.0)
{
    printf("Acquire type: PEAK\n");
}
else if (acq_type == 2.0)
{
    printf("Acquire type: AVERage\n");
}
else if (acq_type == 3.0)
{
    printf("Acquire type: HISTogram\n");
}

```

```

{
    printf("Acquire type: HRESolution\n");
}

wav_points = dbl_results[2];
printf("Waveform points: %e\n", wav_points);

avg_count = dbl_results[3];
printf("Waveform average count: %e\n", avg_count);

x_increment = dbl_results[4];
printf("Waveform X increment: %e\n", x_increment);

x_origin = dbl_results[5];
printf("Waveform X origin: %e\n", x_origin);

x_reference = dbl_results[6];
printf("Waveform X reference: %e\n", x_reference);

y_increment = dbl_results[7];
printf("Waveform Y increment: %e\n", y_increment);

y_origin = dbl_results[8];
printf("Waveform Y origin: %e\n", y_origin);

y_reference = dbl_results[9];
printf("Waveform Y reference: %e\n", y_reference);

/* Read waveform data. */
num_bytes = do_query_ieeeblock(":WAVEFORM:DATA?");
printf("Number of data values: %d\n", num_bytes);

/* Open file for output. */
fp = fopen("c:\\scope\\data\\waveform_data.csv", "wb");

/* Output waveform data in CSV format. */
for (i = 0; i < num_bytes - 1; i++)
{
    /* Write time value, voltage value. */
    fprintf(fp, "%9f, %6f\n",
            x_origin + ((float)i * x_increment),
            (((float)ieeeblock_data[i] - y_reference) * y_increment)
            + y_origin);
}

/* Close output file. */
fclose(fp);
printf("Waveform format BYTE data written to ");
printf("c:\\scope\\data\\waveform_data.csv.\n");
}

/* Send a command to the instrument.
 * -----
void do_command(command)
char *command;
{
    char message[80];

```

```

        strcpy(message, command);
        strcat(message, "\n");
        iprintf(id, message);

        check_instrument_errors();
    }

/* Command with IEEE definite-length block.
 * -----
int do_command_ieeeblock(command, num_bytes)
char *command;
int num_bytes;
{
    char message[80];
    int data_length;

    strcpy(message, command);
    strcat(message, "#8%08d");
    iprintf(id, message, num_bytes);
    ifwrite(id, ieeeblock_data, num_bytes, 1, &data_length);

    check_instrument_errors();

    return(data_length);
}

/* Query for a string result.
 * -----
void do_query_string(query)
char *query;
{
    char message[80];

    strcpy(message, query);
    strcat(message, "\n");
    iprintf(id, message);

    iscanf(id, "%t\n", str_result);

    check_instrument_errors();
}

/* Query for a number result.
 * -----
void do_query_number(query)
char *query;
{
    char message[80];

    strcpy(message, query);
    strcat(message, "\n");
    iprintf(id, message);

    iscanf(id, "%lf", &num_result);

    check_instrument_errors();
}

```

```

}

/* Query for numbers result.
 * -----
void do_query_numbers(query)
char *query;
{
    char message[80];

    strcpy(message, query);
    strcat(message, "\n");
    sprintf(id, message);

    iscanf(id, "%,10lf\n", dbl_results);

    check_instrument_errors();
}

/* Query for an IEEE definite-length block result.
 * -----
int do_query_ieeeblock(query)
char *query;
{
    char message[80];
    int data_length;

    strcpy(message, query);
    strcat(message, "\n");
    sprintf(id, message);

    data_length = IEEEBLOCK_SPACE;
    iscanf(id, "%#b", &data_length, ieeeblock_data);

    if (data_length == IEEEBLOCK_SPACE )
    {
        printf("IEEE block buffer full: ");
        printf("May not have received all data.\n");
    }

    check_instrument_errors();

    return(data_length);
}

/* Check for instrument errors.
 * -----
void check_instrument_errors()
{
    char str_err_val[256] = {0};
    char str_out[800] = "";

    ipromptf(id, ":SYSTem:ERRor?\n", "%t", str_err_val);
    while(strncmp(str_err_val, "+0,No error", 3) != 0 )
    {
        strcat(str_out, ", ");
        strcat(str_out, str_err_val);
        ipromptf(id, ":SYSTem:ERRor?\n", "%t", str_err_val);
}

```

```

    }

    if (strcmp(str_out, "") != 0)
    {
        printf("INST Error%s\n", str_out);
        iflush(id, I_BUF_READ | I_BUF_WRITE);
    }
}

```

## SICL Example in Visual Basic

To run this example in Visual Basic for Applications:

- 1 Start the application that provides Visual Basic for Applications (for example, Microsoft Excel).
- 2 Press ALT+F11 to launch the Visual Basic editor.
- 3 Add the sicl32.bas file to your project:
  - a Choose **File > Import File....**
  - b Navigate to the header file, sicl32.bas (installed with Keysight IO Libraries Suite and found in the Program Files\Agilent\IO Libraries Suite\include directory), select it, and click **Open**.
- 4 Choose **Insert > Module**.
- 5 Cut-and-paste the code that follows into the editor.
- 6 Edit the program to use the SICL address of your oscilloscope, and save the changes.
- 7 Run the program.

```

'
' Keysight SICL Example in Visual Basic
' -----
' This program illustrates a few commonly-used programming
' features of your Keysight oscilloscope.
' -----


Option Explicit

Public id As Integer      ' Session to instrument.

' Declare variables to hold numeric values returned by
' ivscanf/ifread.
Public dblQueryResult As Double
Public Const ByteArraySize = 5000000
Public retCount As Long
Public byteArray(ByteArraySize) As Byte

' Declare fixed length string variable to hold string value returned
' by ivscanf.
Public strQueryResult As String * 200

' For Sleep subroutine.

```

```

Private Declare Sub Sleep Lib "kernel32" (ByVal dwMilliseconds As Long)

'
' Main Program
' -----
'

Sub Main()

    On Error GoTo ErrorHandler

    ' Open a device session using the SICL_ADDRESS.
    id = iopen("usb0[2391::6054::US50210029::0]")
    Call itimeout(id, 5000)

    ' Initialize - start from a known state.
    Initialize

    ' Capture data.
    Capture

    ' Analyze the captured waveform.
    Analyze

    ' Close the vi session and the resource manager session.
    Call iclose(id)

    Exit Sub

ErrorHandler:

    MsgBox "*** Error : " + Error, vbExclamation
    End

End Sub

'
' Initialize the oscilloscope to a known state.
' -----
'

Private Sub Initialize()

    On Error GoTo ErrorHandler

    ' Clear the interface.
    Call iclear(id)

    ' Get and display the device's *IDN? string.
    strQueryResult = DoQueryString("*IDN?")
    MsgBox "Result is: " + RTrim(strQueryResult), vbOKOnly, "*IDN? Result"

    ' Clear status and load the default setup.
    DoCommand "*CLS"
    DoCommand "*RST"

    Exit Sub

ErrorHandler:

```

```

    MsgBox "*** Error : " + Error, vbExclamation
End

End Sub

'

' Capture the waveform.
' -----
Private Sub Capture()

On Error GoTo ErrorHandler

' Use auto-scale to automatically configure oscilloscope.
' -----
DoCommand ":AUToscale"

' Set trigger mode (EDGE, PULSe, PATTern, etc., and input source.
DoCommand ":TRIGger:MODE EDGE"
Debug.Print "Trigger mode: " + _
DoQueryString(":TRIGger:MODE?")

' Set EDGE trigger parameters.
DoCommand ":TRIGger:EDGE:SOURce CHANnel1"
Debug.Print "Trigger edge source: " + _
DoQueryString(":TRIGger:EDGE:SOURce?")

DoCommand ":TRIGger:EDGE:LEVel 1.5"
Debug.Print "Trigger edge level: " + _
DoQueryString(":TRIGger:EDGE:LEVel?")

DoCommand ":TRIGger:EDGE:SLOPe POSitive"
Debug.Print "Trigger edge slope: " + _
DoQueryString(":TRIGger:EDGE:SLOPe?")

' Save oscilloscope configuration.
' -----
Dim lngSetupStringSize As Long
lngSetupStringSize = DoQueryIEEEBlock_Bytes(":SYSTem:SETup?")
Debug.Print "Setup bytes saved: " + CStr(lngSetupStringSize)

' Output setup string to a file:
Dim strPath As String
strPath = "c:\scope\config\setup.dat"
If Len(Dir(strPath)) Then
    Kill strPath      ' Remove file if it exists.
End If

' Open file for output.
Dim hFile As Long
hFile = FreeFile
Open strPath For Binary Access Write Lock Write As hFile
Dim lngI As Long
For lngI = 0 To lngSetupStringSize - 1
    Put hFile, , byteArray(lngI)      ' Write data.
Next lngI

```

```

        Close hFile      ' Close file.

        ' Change settings with individual commands:
        ' -----
        ' Set vertical scale and offset.
        DoCommand ":CHANnel1:SCALe 0.05"
        Debug.Print "Channel 1 vertical scale: " + _
                    DoQueryString(":CHANnel1:SCALe?")

        DoCommand ":CHANnel1:OFFSet -1.5"
        Debug.Print "Channel 1 vertical offset: " + _
                    DoQueryString(":CHANnel1:OFFSet?")

        ' Set horizontal scale and position.
        DoCommand ":TIMEbase:SCALe 0.0002"
        Debug.Print "Timebase scale: " + _
                    DoQueryString(":TIMEbase:SCALe?")

        DoCommand ":TIMEbase:POSIon 0.0"
        Debug.Print "Timebase position: " + _
                    DoQueryString(":TIMEbase:POSIon?")

        ' Set the acquisition type (NORMal, PEAK, AVERage, or HRESolution).
        DoCommand ":ACQuire:TYPE NORMal"
        Debug.Print "Acquire type: " + _
                    DoQueryString(":ACQuire:TYPE?")

        ' Or, configure by loading a previously saved setup.
        ' -----
        strPath = "c:\scope\config\setup.dat"
        Open strPath For Binary Access Read As hFile      ' Open file for input.
        Dim lngSetupFileSize As Long
        lngSetupFileSize = LOF(hFile)      ' Length of file.
        Get hFile, , byteArray      ' Read data.
        Close hFile      ' Close file.
        ' Write setup string back to oscilloscope using ":SYSTem:SETup"
        ' command:
        Dim lngRestored As Long
        lngRestored = DoCommandIEEEBlock(":SYSTem:SETup", lngSetupFileSize)
        Debug.Print "Setup bytes restored: " + CStr(lngRestored)

        ' Capture an acquisition using :DIGitize.
        ' -----
        DoCommand ":DIGitize CHANnel1"

        Exit Sub

ErrorHandler:
        MsgBox "*** Error : " + Error, vbExclamation
        End

End Sub

        '
        ' Analyze the captured waveform.

```

```

' -----
Private Sub Analyze()

    On Error GoTo ErrorHandler

    ' Make a couple of measurements.
    ' -----
    DoCommand ":MEASure:SOURce CHANnel1"
    Debug.Print "Measure source: " + _
        DoQueryString(":MEASure:SOURce?")

    DoCommand ":MEASure:FREQuency"
    dblQueryResult = DoQueryNumber(":MEASure:FREQuency?")
    MsgBox "Frequency:" + vbCrLf + _
        FormatNumber(dblQueryResult / 1000, 4) + " kHz"

    DoCommand ":MEASure:VAMPplitude"
    dblQueryResult = DoQueryNumber(":MEASure:VAMPplitude?")
    MsgBox "Vertical amplitude:" + vbCrLf + _
        FormatNumber(dblQueryResult, 4) + " V"

    ' Download the screen image.
    ' -----
    DoCommand ":HARDcopy:INKSaver OFF"

    ' Get screen image.
    Dim lngBlockSize As Long
    lngBlockSize = DoQueryIEEEBlock_Bytes(":DISPLAY:DATA? PNG, COLOR")
    Debug.Print "Screen image bytes: " + CStr(lngBlockSize)

    ' Save screen image to a file:
    Dim strPath As String
    strPath = "c:\scope\data\screen.png"
    If Len(Dir(strPath)) Then
        Kill strPath      ' Remove file if it exists.
    End If
    Dim hFile As Long
    hFile = FreeFile
    Open strPath For Binary Access Write Lock Write As hFile
    Dim lngI As Long
    ' Skip past header.
    For lngI = CInt(Chr(byteArray(1))) + 2 To lngBlockSize - 1
        Put hFile, , byteArray(lngI)      ' Write data.
    Next lngI
    Close hFile      ' Close file.
    MsgBox "Screen image written to " + strPath

    ' Download waveform data.
    ' -----
    ' Set the waveform points mode.
    DoCommand ":WAVEform:POINTS:MODE RAW"
    Debug.Print "Waveform points mode: " + _
        DoQueryString(":WAVEform:POINTS:MODE?")

    ' Get the number of waveform points available.

```

```

DoCommand ":WAVeform:POINTs 10240"
Debug.Print "Waveform points available: " + _
    DoQueryString(":WAVeform:POINTs?")

' Set the waveform source.
DoCommand ":WAVeform:SOURce CHANnel1"
Debug.Print "Waveform source: " + _
    DoQueryString(":WAVeform:SOURce?")

' Choose the format of the data returned (WORD, BYTE, ASCII):
DoCommand ":WAVeform:FORMAT BYTE"
Debug.Print "Waveform format: " + _
    DoQueryString(":WAVeform:FORMAT?")

' Display the waveform settings:
Dim Preamble() As Double
Dim intFormat As Integer
Dim intType As Integer
Dim lngPoints As Long
Dim lngCount As Long
Dim dblXIncrement As Double
Dim dblXOrigin As Double
Dim lngXReference As Long
Dim sngYIncrement As Single
Dim sngYOrigin As Single
Dim lngYReference As Long

Preamble() = DoQueryNumbers(":WAVeform:PREamble?")

intFormat = Preamble(0)
intType = Preamble(1)
lngPoints = Preamble(2)
lngCount = Preamble(3)
dblXIncrement = Preamble(4)
dblXOrigin = Preamble(5)
lngXReference = Preamble(6)
sngYIncrement = Preamble(7)
sngYOrigin = Preamble(8)
lngYReference = Preamble(9)

If intFormat = 0 Then
    Debug.Print "Waveform format: BYTE"
ElseIf intFormat = 1 Then
    Debug.Print "Waveform format: WORD"
ElseIf intFormat = 2 Then
    Debug.Print "Waveform format: ASCII"
End If

If intType = 0 Then
    Debug.Print "Acquisition type: NORMAL"
ElseIf intType = 1 Then
    Debug.Print "Acquisition type: PEAK"
ElseIf intType = 2 Then
    Debug.Print "Acquisition type: AVERAGE"
ElseIf intType = 3 Then
    Debug.Print "Acquisition type: HRESolution"
End If

```

```

Debug.Print "Waveform points: " + _
FormatNumber(lngPoints, 0)

Debug.Print "Waveform average count: " + _
FormatNumber(lngCount, 0)

Debug.Print "Waveform X increment: " + _
Format(dblXIncrement, "Scientific")

Debug.Print "Waveform X origin: " + _
Format(dblXOrigin, "Scientific")

Debug.Print "Waveform X reference: " + _
FormatNumber(lngXReference, 0)

Debug.Print "Waveform Y increment: " + _
Format(sngYIncrement, "Scientific")

Debug.Print "Waveform Y origin: " + _
FormatNumber(sngYOrigin, 0)

Debug.Print "Waveform Y reference: " + _
FormatNumber(lngYReference, 0)

' Get the waveform data
Dim lngNumBytes As Long
lngNumBytes = DoQueryIEEEBlock_Bytes(":WAVEFORM:DATA?")
Debug.Print "Number of data values: " + _
CStr(lngNumBytes - CInt(Chr(byteArray(1))) - 2)

' Set up output file:
strPath = "c:\scope\data\waveform_data.csv"

' Open file for output.
Open strPath For Output Access Write Lock Write As hFile

' Output waveform data in CSV format.
Dim lngDataValue As Long

' Skip past header.
For lngI = CInt(Chr(byteArray(1))) + 2 To lngNumBytes - 2
    lngDataValue = CLng(byteArray(lngI))

    ' Write time value, voltage value.
    Print #hFile, _
        FormatNumber(dblXOrigin + (lngI * dblXIncrement), 9) + _
        ", " + _
        FormatNumber(((lngDataValue - lngYReference) * _
        sngYIncrement) + sngYOrigin)

Next lngI

' Close output file.
Close hFile    ' Close file.
MsgBox "Waveform format BYTE data written to " + _
"c:\scope\data\waveform_data.csv."

```

```

        Exit Sub

ErrorHandler:
    MsgBox "*** Error : " + Error, vbExclamation
End

End Sub

Private Sub DoCommand(command As String)

On Error GoTo ErrorHandler

Call ivprintf(id, command + vbLf)

CheckInstrumentErrors

Exit Sub

ErrorHandler:
    MsgBox "*** Error : " + Error, vbExclamation
End

End Sub

Private Function DoCommandIEEEBlock(command As String, _
    lngBlockSize As Long)

On Error GoTo ErrorHandler

' Send command part.
Call ivprintf(id, command + " ")

' Write definite-length block bytes.
Call ifwrite(id, byteArray(), lngBlockSize, vbNull, retCount)

' retCount is now actual number of bytes written.
DoCommandIEEEBlock = retCount

CheckInstrumentErrors

Exit Function

ErrorHandler:
    MsgBox "*** Error : " + Error, vbExclamation
End

End Function

Private Function DoQueryString(query As String) As String

Dim actual As Long

On Error GoTo ErrorHandler

```

```

Dim strResult As String * 200

Call ivprintf(id, query + vbLf)
Call ivscanf(id, "%200t", strResult)
DoQueryString = strResult

CheckInstrumentErrors

Exit Function

ErrorHandler:

MsgBox "*** Error : " + Error, vbExclamation
End

End Function

Private Function DoQueryNumber(query As String) As Double

On Error GoTo ErrorHandler

Dim dblResult As Double

Call ivprintf(id, query + vbLf)
Call ivscanf(id, "%lf" + vbLf, dblResult)
DoQueryNumber = dblResult

CheckInstrumentErrors

Exit Function

ErrorHandler:

MsgBox "*** Error : " + Error, vbExclamation
End

End Function

Private Function DoQueryNumbers(query As String) As Double()

On Error GoTo ErrorHandler

Dim dblResults(10) As Double

Call ivprintf(id, query + vbLf)
Call ivscanf(id, "%,10lf" + vbLf, dblResults)
DoQueryNumbers = dblResults

CheckInstrumentErrors

Exit Function

ErrorHandler:

MsgBox "*** Error : " + Error, vbExclamation
End

```

```

End Function

Private Function DoQueryIEEEBlock_Bytes(query As String) As Long

On Error GoTo ErrorHandler

' Send query.
Call ivprintf(id, query + vbLf)

' Read definite-length block bytes.
Sleep 2000    ' Delay before reading data.
Call ifread(id, byteArray(), ByteArraySize, vbNull, retCount)

' Get number of block length digits.
Dim intLengthDigits As Integer
intLengthDigits = CInt(Chr(byteArray(1)))

' Get block length from those digits.
Dim strBlockLength As String
strBlockLength = ""
Dim i As Integer
For i = 2 To intLengthDigits + 1
    strBlockLength = strBlockLength + Chr(byteArray(i))
Next

' Return number of bytes in block plus header.
DoQueryIEEEBlock_Bytes = CLng(strBlockLength) + intLengthDigits + 2

CheckInstrumentErrors

Exit Function

ErrorHandler:

MsgBox "*** Error : " + Error, vbExclamation
End

End Function

Private Sub CheckInstrumentErrors()

On Error GoTo ErrorHandler

Dim strErrVal As String * 200
Dim strOut As String

Call ivprintf(id, ":SYSTem:ERRor?" + vbLf)    ' Query any errors data.
Call ivscanf(id, "%200t", strErrVal)    ' Read: Errnum, "Error String".
While Val(strErrVal) <> 0                ' End if find: +0,"No Error".
    strOut = strOut + "INST Error: " + strErrVal
    Call ivprintf(id, ":SYSTem:ERRor?" + vbLf)    ' Request error message
    Call ivscanf(id, "%200t", strErrVal)    ' Read error message.
Wend

If Not strOut = "" Then

```

## 46 Programming Examples

```
    MsgBox strOut, vbExclamation, "INST Error Messages"
    Call iflush(id, I_BUF_READ Or I_BUF_WRITE)

End If

Exit Sub

ErrorHandler:

    MsgBox "*** Error : " + Error, vbExclamation
    End

End Sub
```

## SCPI.NET Examples

You can also program the oscilloscope using the SCPI.NET drivers that come with Keysight's free Command Expert software.

While you can write code manually using the SCPI.NET drivers, you can also use the Command Expert software to:

- Connect to instruments and control them interactively using SCPI command sets.
- Quickly prototype and test command sequences.
- Generate C#, VB.NET, or C/C++ code for command sequences.
- Find, download, and install SCPI command sets.
- Browse command trees, search for commands, and view command descriptions.

The Command Expert suite also comes with Add-ons for easy instrument control and measurement data retrieval in NI LabVIEW, Microsoft Excel, Keysight VEE, and Keysight SystemVue.

To download the Keysight Command Expert software, see:

<http://www.keysight.com/find/commandexpert>

For more on programming with the SCPI.NET drivers, see "Using SCPI.NET Drivers" in the help that comes with Keysight Command Expert.



# Index

## Symbols

\*ESR? (Event Status Register) query, 87  
\*OPC (Operation Complete) query, 87  
+9.9E+37, infinity representation, 1673  
+9.9E+37, measurement error, 621

## Numerics

0 (zero) values in waveform data, 1463  
1 (one) values in waveform data, 1463  
4000 X-Series oscilloscopes, command differences from, 60  
82350B GPIB interface, 6

## A

A429 SEARch commands, 1232  
A429 serial bus commands, 910  
absolute value math function, 524  
AC coupling, trigger edge, 1379  
AC input coupling for specified channel, 346  
AC RMS measured on waveform, 640, 687  
accumulate activity, 259  
ACQuire commands, 299  
acquire data, 268, 317  
acquire mode on autoscale, 263  
acquire reset conditions, 244, 1321  
acquire sample rate, 315  
acquire sample rate, setting (Digitizer mode), 315  
ACQuire subsystem, 79  
acquired data points, 308  
acquired data points, setting (Digitizer mode), 308  
acquisition anti-alias control, 302  
acquisition count, 304  
acquisition mode, 300, 307, 1482  
acquisition type, 300, 317  
acquisition types, 1456  
active edges, 259  
active printer, 545  
activity logic levels, 259  
activity on digital channels, 259  
add function, 1477  
add math function, 523  
add math function as g(t) source, 1564  
address field size, IIC serial decode, 1016  
address of network printer, 550

address value, USB search, 1296  
address value, USB trigger, 1173  
address, IIC trigger pattern, 1019  
Addresses softkey, 68  
Adjacent Channel Power Ratio (ACPR), FFT analysis measurement, 643  
adjacent signal source, USB 2.0 signal quality test, 375  
AER (Arm Event Register), 260, 280, 283, 1630  
Agilent Flash directory, 869, 889  
alignment, I2S trigger, 998  
all (snapshot) measurement, 622  
ALL segments waveform save option, 901  
all segments, :WAVEform:DATA?, 1473  
AM demo signal, 396  
AM depth, waveform generator modulation, 1513  
AM modulation type, waveform generator, 1523  
amplitude profile, Control Loop Response (Bode) power analysis, 782  
amplitude profile, frequency response analysis, 484  
amplitude profile, Power Supply Rejection Ratio (PSRR) power analysis, 825  
amplitude, vertical, 636, 680  
amplitude, waveform generator, 483, 1532  
analog channel coupling, 346  
analog channel display, 347  
analog channel impedance, 348  
analog channel input, 1558  
analog channel inversion, 349  
analog channel labels, 350, 429  
analog channel memory depth, automatic, 309  
analog channel offset, 351  
analog channel protection lock, 1324  
analog channel range, 367  
analog channel sample rate, automatic, 316  
analog channel scale, 368  
analog channel source for glitch, 1392  
analog channel units, 357, 369  
analog channels only oscilloscopes, 6  
analog probe attenuation, 352  
analog probe head type, 358  
analog probe sensing, 1559  
analog probe skew, 363, 1557  
analysis results, save, 890  
analyzing captured data, 75  
angle brackets, 225  
annotate channels, 350

annotation background, display, 415  
annotation color, display, 416  
annotation text, display, 417  
annotation X1 position, 418  
annotation Y1 position, 419  
annotation, display, 414  
anti-alias control, 302  
apparent power, 699  
apply network printer connection settings, 551  
arbitrary waveform generator output, 1509  
arbitrary waveform, byte order, 1496  
arbitrary waveform, capturing from other sources, 1504  
arbitrary waveform, clear, 1501  
arbitrary waveform, download DAC values, 1502  
arbitrary waveform, download floating-point values, 1497  
arbitrary waveform, interpolation, 1503  
arbitrary waveform, points, 1500  
arbitrary waveform, recall, 864  
arbitrary waveform, save, 877  
area for hardcopy print, 544  
area for saved image, 1598  
area measurement, 623, 635  
ARINC 429 auto setup, 912  
ARINC 429 base, 913  
ARINC 429 demo signal, 398  
ARINC 429 signal speed, 921  
ARINC 429 signal type, 919  
ARINC 429 source, 920  
ARINC 429 trigger data pattern, 923, 1235  
ARINC 429 trigger label, 922, 926, 1233  
ARINC 429 trigger SDI pattern, 924, 1236  
ARINC 429 trigger SSM pattern, 925, 1237  
ARINC 429 trigger type, 927, 1234  
ARINC 429 user-defined baud rate, 914  
ARINC 429 word and error counters, reset, 916  
ARINC 429 word format, 918  
Arm Event Register (AER), 260, 280, 283, 1630  
arm event, NFC arm and event trigger, 1394  
armed status, checking for, 1637  
arming edge slope, Edge Then Edge trigger, 1366  
arming edge source, Edge Then Edge trigger, 1367  
arrange waveforms, 1561  
ASCII format, 1465  
ASCII format for data transfer, 1459

ASCII string, quoted, 225  
 ASCIixy waveform data format, 898  
 assign channel names, 350  
 attenuation factor (external trigger) probe, 445  
 attenuation for oscilloscope probe, 352  
 audio channel, I2S trigger, 1007  
 AUT option for probe sense, 1559, 1563  
 Auto Range capability for DVM, 438  
 auto set up, trigger level, 1359  
 auto set up, USB 2.0 signal quality test, 372  
 auto setup (ARINC 429), 912  
 auto setup for M1553 trigger, 1045  
 auto setup for power analysis signals, 828  
 auto trigger sweep mode, 1349  
 automask create, 723  
 automask source, 724  
 automask units, 725  
 automatic measurements constants, 352  
 automatic probe type detection, 1559, 1563  
 autoscale, 261  
 autoscale acquire mode, 263  
 autoscale channels, 264  
 AUToscale command, 78  
 autoset for FLEXray event trigger, 988  
 autosetup for FLEXray decode, 978  
 average math function, clear, 498  
 average value measurement, 637, 681  
 Average, power modulation analysis, 805  
 averaged value math function, 524  
 averaging acquisition type, 300, 1457  
 averaging, synchronizing with, 1652  
 Ax + B math function, 524

**B**

backlight, display, 420  
 band pass filter math function, 524  
 band-pass filter math function, center frequency, 514  
 band-pass filter math function, frequency width, 515  
 bandwidth filter limits, 444  
 bandwidth filter limits to 20 MHz, 345  
 bar chart of current harmonics results, 789  
 BARTlett window, 467, 513  
 base 10 exponential math function, 524  
 base value measurement, 638, 682  
 base, ARINC 429, 913  
 base, I2S serial decode, 999  
 base, MIL-STD-1553 serial decode, 1046  
 base, SENT decode, 1094  
 base, UART trigger, 1157  
 base, USB decode, 1167  
 basic instrument functions, 231  
 baud rate, 942, 1030, 1146  
 baud rate, CAN FD, 944  
 baud rate, user-defined, ARINC 429, 914  
 begin acquisition, 268, 292, 294

BHARris window for minimal spectral leakage, 467, 513  
 Bin Size, FFT, 500  
 binary block data, 225, 422, 559, 1332, 1463  
 BINary waveform data format, 898  
 bind levels for masks, 744  
 bit order, 1147  
 bit order, SPI decode, 1127  
 bit rate measurement, 624  
 bit selection command, bus, 321  
 bit weights, 236  
 bitmap display, 422, 560  
 bits in Service Request Enable Register, 249  
 bits in Standard Event Status Enable Register, 234  
 bits in Status Byte Register, 251  
 bits selection command, bus, 322  
 blank, 266  
 block data, 225, 239, 1332  
 block response data, 82  
 blocking commands, 87  
 blocking synchronization, 1647  
 blocking synchronization example, 1654  
 blocking wait, 1646  
 BMP format screen image data, 422, 560  
 braces, 224  
 built-in measurements, 75  
 burst data demo signal, 397  
 burst width measurement, 625  
 burst, minimum time before next, 1374  
 bus bit selection command, 321  
 bus bits selection commands, 322  
 bus clear command, 324  
 bus commands, 320  
 BUS data format, 1460  
 bus display, 325  
 bus label command, 326  
 bus mask command, 327  
 BUS<n> commands, 319  
 button disable, 1318  
 button, calibration protect, 335  
 byte format for data transfer, 1459, 1465  
 BYTeorder, 1461

**C**

C, SICL library example, 1769  
 C, VISA library example, 1709  
 C#, VISA COM example, 1685  
 C#, VISA example, 1728  
 C#, VISA.NET example, 1756  
 CAL PROTECT button, 335  
 CAL PROTECT switch, 330  
 calculating preshoot of waveform, 658  
 calculating the waveform overshoot, 652  
 calibrate, 331, 332, 335, 339  
 CALibrate commands, 329  
 calibrate date, 331  
 calibrate introduction, 330

calibrate label, 332  
 calibrate output, 333  
 calibrate start, 336  
 calibrate status, 337  
 calibrate switch, 335  
 calibrate temperature, 338  
 calibrate time, 339  
 CAN acknowledge, 941  
 CAN and LIN demo signal, 398  
 CAN baud rate, 942  
 CAN demo signal, 397  
 CAN FD baud rate, 944  
 CAN FD data triggers, starting byte position, 953  
 CAN frame counters, reset, 934  
 CAN SEArch commands, 1238  
 CAN serial bus commands, 929  
 CAN serial search, data, 1241  
 CAN serial search, data length, 1242  
 CAN serial search, ID, 1243  
 CAN serial search, ID mode, 1244  
 CAN serial search, mode, 1239  
 CAN signal definition, 943  
 CAN source, 945  
 CAN symbolic data display, 938  
 CAN symbolic data, recall, 865  
 CAN trigger, 946, 952  
 CAN trigger data pattern, 950  
 CAN trigger ID pattern, 954  
 CAN trigger pattern id mode, 955  
 CAN trigger, ID filter for, 949  
 CAN triggering, 906  
 capture data, 268  
 capturing data, 74  
 cardiac waveform generator output, 1508  
 center frequency set, 452, 501, 523  
 center of screen, 1490  
 center screen, FFT vertical value at, 460, 462  
 center screen, vertical value at, 522, 529  
 center time base reference, 1342  
 CFD demo signal, 399  
 channel, 298, 350, 1554, 1556  
 channel coupling, 346  
 channel display, 347  
 channel input impedance, 348  
 channel inversion, 349  
 channel label, 350, 1555  
 channel labels, 428, 429  
 channel numbers, 1561  
 channel overload, 366  
 Channel Power, FFT analysis measurement, 644  
 channel protection, 366  
 channel reset conditions, 244, 1321  
 channel selected to produce trigger, 1392, 1434  
 channel signal type, 364  
 channel skew for oscilloscope probe, 363, 1557  
 channel status, 295, 1561  
 channel threshold, 1556

channel vernier, 370  
 channel, stop displaying, 266  
 CHANnel<n> commands, 341, 344  
 channels to autoscale, 264  
 channels, how autoscale affects, 261  
 characters to display, 1316  
 chart logic bus state math function, 525  
 chart logic bus state, clock edge, 494  
 chart logic bus state, clock source, 493  
 chart logic bus timing math function, 525  
 chart logic bus, units, 497  
 chart logic bus, value for data = 0, 496  
 chart logic bus, value for data increment, 495  
 chart serial signal math function, 526  
 Chart Serial Signal math function, serial bus source, 531  
 Chart Serial Signal math function, time mode, 532  
 Chart Serial Signal math function, time offset, 535  
 Chart Serial Signal math function, time range, 534  
 classes of input signals, 467, 513  
 classifications, command, 1666  
 clear, 421  
 clear bus command, 324  
 clear cumulative edge variables, 1554  
 clear FFT function, 453  
 clear markers, 626, 1575  
 clear measurement, 626, 1575  
 clear message from display, 431  
 clear message queue, 233  
 Clear method, 77  
 clear persistence data from display, 433  
 clear reference waveforms, 1539  
 clear screen, 1562  
 clear status, 233  
 clear waveform area, 413  
 clipped high waveform data value, 1463  
 clipped low waveform data value, 1463  
 clock, 1017, 1128, 1132  
 Clock Extension Peripheral Interface (CXPI), 959  
 clock period, SENT signal, 1092  
 clock slope, I2S, 1000  
 CLOCK source, I2S, 1002  
 clock source, setup and hold trigger, 1421  
 clock timeout, SPI, 1129  
 clock with infrequent glitch demo signal, 396  
 CLS (Clear Status), 233  
 CME (Command Error) status bit, 234, 236  
 CMOS threshold voltage for digital channels, 409, 1556  
 CMOS trigger threshold voltage, 1603  
 code, :ACQuire:COMplete, 303  
 code, :ACQuire:SEGmented, 312  
 code, :ACQuire:TYPE, 318  
 code, :AUToscale, 262  
 code, :CHANnel<n>:LABEL, 350  
 code, :CHANnel<n>:PROBe, 352  
 code, :CHANnel<n>:RANGE, 367  
 code, :DIGitize, 269  
 code, :DISPlay:DATA, 422  
 code, :DISPlay:LABEL, 428  
 code, :DISPlay:ORDER, 1561  
 code, :MEASure:PERiod, 668  
 code, :MEASure:REsults, 660  
 code, :MEASure:TEDGE, 676  
 code, :MTESt, 719  
 code, :POD<n>:THreshold, 755  
 code, :RUN:/STOP, 292  
 code, :SYSTem:SETup, 1332  
 code, :TIMEbase:DELay, 1602  
 code, :TIMEbase:MODE, 1339  
 code, :TIMEbase:RANGE, 1341  
 code, :TIMEbase:REFerence, 1342  
 code, :TRIGger:MODE, 1362  
 code, :TRIGger:SLOPe, 1382  
 code, :TRIGger:SOURce, 1383  
 code, :VIEW and :BLANK, 298  
 code, :WAVEform, 1478  
 code, :WAVEform:DATA, 1463  
 code, :WAVEform:POINTS, 1467  
 code, :WAVEform:PREamble, 1471  
 code, :WAVEform:SEGmented, 312  
 code, :WGEN:ARbitrary:DATA, 1497  
 code, \*RST, 246  
 code, SICL library example in C, 1769  
 code, SICL library example in Visual Basic, 1778  
 code, VISA COM library example in C#, 1685  
 code, VISA COM library example in Python, 1702  
 code, VISA COM library example in Visual Basic, 1676  
 code, VISA COM library example in Visual Basic .NET, 1694  
 code, VISA library example in C, 1709  
 code, VISA library example in C#, 1728  
 code, VISA library example in Python, 1749  
 code, VISA library example in Visual Basic, 1718  
 code, VISA library example in Visual Basic .NET, 1739  
 code, VISA.NET library example in C#, 1756  
 code, VISA.NET library example in Visual Basic .NET, 1762  
 colon, root commands prefixed by, 258  
 color palette for hardcopy, 556  
 color palette for image, 884  
 Comma Separated Values (CSV) waveform data format, 898  
 command classifications, 1666  
 command differences from 4000 X-Series oscilloscopes, 60  
 command errors detected in Standard Event Status, 236  
 Command Expert, 1756, 1789  
 command header, 1667  
 command headers, common, 1669  
 command headers, compound, 1669  
 command headers, simple, 1669  
 command strings, valid, 1667  
 commands quick reference, 89  
 commands sent over interface, 231  
 commands, more about, 1665  
 commands, obsolete and discontinued, 1547  
 common (\*) commands, 3, 227, 231  
 common command headers, 1669  
 common logarithm math function, 524  
 completion criteria for an acquisition, 303, 304  
 COMPliance commands, 371  
 compound command headers, 1669  
 compound header, 1671  
 computer control examples, 1675  
 concurrent commands, 87  
 conditions for external trigger, 443  
 conditions, reset, 244, 1321  
 conduction calculation method for switching loss, 850  
 Config softkey, 68  
 configurations, oscilloscope, 239, 243, 247, 1332  
 Configure softkey, 68  
 connect oscilloscope, 67  
 connect sampled data points, 1560  
 Connection Expert, 69  
 connection type, hi-speed, USB 2.0 signal quality test, 380  
 constants for making automatic measurements, 352  
 constants for scaling display factors, 352  
 constants for setting trigger levels, 352  
 Control Loop Response (Bode) power analysis settings, 765  
 control loop response (Bode) power analysis, apply, 766  
 control loop response power analysis, single frequency, 773  
 control loop response power analysis, sweep start frequency, 774  
 control loop response power analysis, sweep stop frequency, 775  
 controller initialization, 74  
 conversion type of power supply, 802  
 copy display, 290  
 copyright, 2  
 core commands, 1666  
 count, 1462  
 count totalize, gating enable/disable, 391  
 count values, 304  
 count, averaged value math function, 492  
 count, averages, FFT function, 451  
 count, Edge Then Edge trigger, 1369  
 count, Nth edge of burst, 1373  
 counter, 384, 627  
 counter commands, 383  
 counter mode, 387  
 counter source, 389  
 counter totalize, clear, 390

counter totalize, gating polarity, 392  
 counter totalize, gating signal source, 393  
 counter totalize, slope, 394  
 counter, digits of resolution, 388  
 counter, enable/disable, 386  
 coupling, 1379  
 COUPling demo signal, 399  
 coupling for channels, 346  
 CRC format, SENT, 1093  
 CRC value, USB search, 1297  
 CRC value, USB trigger, 1174  
 create automask, 723  
 crest factor, 701  
 CSV (Comma Separated Values) waveform data format, 898  
 CT bits (CXPI), triggering on, 973  
 cumulative edge activity, 1554  
 current harmonics analysis fail count, 790  
 current harmonics analysis results, save, 888  
 current harmonics analysis run count, 795  
 current harmonics analysis, apply, 787  
 current harmonics results data, 788  
 current harmonics results display, 789  
 current logic levels on digital channels, 259  
 current oscilloscope configuration, 239, 243, 247, 1332  
 current probe, 357, 369, 447  
 CURRent segment waveform save option, 901  
 current source, 845  
 cursor display setting, X1, 584  
 cursor display setting, X2, 587  
 cursor display setting, Y1, 593  
 cursor display setting, Y2, 595  
 cursor mode, 583  
 cursor position, 582, 585, 588, 590, 594, 597  
 cursor readout, 1576, 1580, 1581  
 cursor reset conditions, 244, 1321  
 cursor source, 586, 589  
 cursor time, 1576, 1580, 1581  
 cursor units, X, 591, 592  
 cursor units, Y, 598, 599  
 cursor values, saving, 891  
 cursors track measurements, 665  
 cursors, how autoscale affects, 261  
 cursors, X1, X2, Y1, Y2, 581  
 custom time base reference, 1342  
 custom time base reference location, 1343  
 CXPI demo signal, 398  
 CXPI frame data value, 969  
 CXPI party bit display, 962  
 CXPI serial bus commands, 959  
 CXPI signal baud rate, 961  
 CXPI signal source, 963  
 CXPI signal tolerance, 964  
 CXPI trigger mode, 965  
 CXPI triggering, 906  
 cycle count base, FLEXray frame trigger, 991

cycle count repetition, FLEXray frame trigger, 992  
 cycle measured, 641, 648  
 cycle time, 655  
 cycles analyzed, number of, 829, 830

## D

D- source, 1441  
 D- source, USB 2.0 signal quality test, 377  
 D- USB signal source, 1168  
 D+ source, 1442  
 D+ source, USB 2.0 signal quality test, 378  
 D+ USB signal source, 1169  
 data, 1018, 1020, 1463  
 data (waveform) maximum length, 900  
 data 2, 1021  
 data acquisition types, 1456  
 data conversion, 1458  
 data format for transfer, 1458  
 data length, USB search, 1299  
 data length, USB trigger, 1176  
 data output order, 1461  
 data pattern length, 952, 1039  
 data pattern, ARINC 429 trigger, 923, 1235  
 data pattern, CAN trigger, 950  
 data PID, USB search, 1304  
 data PID, USB trigger, 1182  
 data point index, 1487  
 data points, 308  
 data record, measurement, 1468  
 data record, raw acquisition, 1468  
 data required to fill time buckets, 303  
 DATA source, I2S, 1003  
 data source, setup and hold trigger, 1422  
 data structures, status reporting, 1615  
 data value, USB search, 1298  
 data value, USB trigger, 1175  
 data, saving and recalling, 413  
 date, calibration, 331  
 date, system, 1314  
 DC coupling for edge trigger, 1379  
 DC input coupling for specified channel, 346  
 DC offset correction for integrate input, 519  
 DC RMS measured on waveform, 640, 687  
 DC waveform generator output, 1507  
 DCMotor demo signal, 399  
 DDE (Device Dependent Error) status bit, 234, 236  
 decision chart, status reporting, 1636  
 default conditions, 244, 1321  
 define channel labels, 350  
 define delay measurement parameters, 634  
 define glitch trigger, 1390  
 define logic thresholds, 1556  
 define measurement, 630  
 define measurement source, 667  
 define trigger, 1391, 1410, 1411, 1413

defined as, 224  
 definite-length block query response, 82  
 definite-length block response data, 225  
 degauss probe, 354  
 delay bits, SPI MISO stream, 1130  
 delay measured to calculate phase, 656  
 delay measurement, 630, 632  
 delay measurement parameters, define, 634  
 delay measurements, 676  
 delay time, Edge Then Edge trigger, 1368  
 DELay trigger commands, 1365  
 delay, how autoscale affects, 261  
 delayed time base, 1339  
 delayed window horizontal scale, 1348  
 delete mask, 733  
 delta time, 1576  
 delta voltage measurement, 1584  
 delta X cursor, 581  
 delta Y cursor, 581  
 demo, 395  
 DEMO commands, 395  
 demo signal, 397  
 demo signal function, 396  
 demo signal phase angle, 401  
 demo signals output control, 402  
 deskew for power measurements, 783  
 destination, remote command logging, 1326  
 detecting probe types, 1559, 1563  
 Device Clear to abort a sequential (blocking) command, 88  
 device-defined error queue clear, 233  
 DIFF source for function, 1567  
 differences from 4000 X-Series oscilloscope commands, 60  
 differential D+ and D- USB signal source, 1170  
 differential probe heads, 358  
 differential probe source, USB 2.0 signal quality test, 376  
 differential signal type, 364  
 differentiate math function, 305, 523, 1477  
 digital channel commands, 404, 405, 406, 407, 409  
 digital channel data, 1460  
 digital channel labels, 429  
 digital channel order, 1561  
 digital channel source for glitch trigger, 1392  
 digital channels, 6  
 digital channels, activity and logic levels on, 259  
 digital channels, groups of, 751, 753, 755  
 digital pod, stop displaying, 266  
 digital reset conditions, 245, 1322  
 DIGItal<d> commands, 403  
 digitize channels, 268  
 DIGItize command, 74, 79, 1456  
 Digitizer mode, 306  
 digits, 225

disable anti-alias mode, 305  
 disable front panel, 1318  
 disable function, 1568  
 disabling calibration, 335  
 disabling channel display, 347  
 disabling status register bits, 234, 248  
 discontinued and obsolete commands, 1547  
 display annotation, 414  
 display annotation background, 415  
 display annotation color, 416  
 display annotation text, 417  
 display channel labels, 428  
 display clear, 421  
 DISPlay commands, 411  
 display commands introduction, 413  
 display connect, 1560  
 display date, 1314  
 display factors scaling, 352  
 display for channels, 347  
 display frequency span, 465, 510  
 display measurements, 620, 665  
 display mode, FFT, 455  
 display order, 1561  
 display persistence, 432  
 display reference, 1340  
 display reference waveforms, 1540  
 display reset conditions, 245, 1322  
 display serial number, 293  
 display transparent, 435  
 display vectors, 436  
 display wave position, 1561  
 display, FFT function, 454  
 display, lister, 563  
 display, measurement statistics on/off, 670  
 display, oscilloscope, 405, 432, 499, 753, 1316  
 display, serial decode bus, 908  
 displaying a baseline, 1364  
 displaying unsynchronized signal, 1364  
 divide math function, 523  
 DLC data length code (CXPI), triggering on, 974  
 DLC value in CAN FD trigger, 951  
 DNS IP, 68  
 domain, 68  
 domain, network printer, 552  
 driver, printer, 1573  
 DSO models, 6  
 duplicate mnemonics, 1671  
 duration, 1410, 1411, 1413  
 duration for glitch trigger, 1386, 1387, 1391  
 duration of power analysis, 831, 832, 833, 834, 835, 836  
 duration qualifier, trigger, 1410, 1411  
 duration triggering, 1350  
 duty cycle measurement, 75, 620, 641, 648  
 Duty Cycle, power modulation analysis, 805  
 DVM commands, 437

DVM displayed value, 439  
 DVM enable/disable, 440  
 DVM input source, 442  
 DVM mode, 441

**E**

EBURst trigger commands, 1372  
 ECL channel threshold, 1556  
 ECL threshold voltage for digital channels, 409  
 ECL trigger threshold voltage, 1603  
 edge activity, 1554  
 edge counter, Edge Then Edge trigger, 1369  
 edge counter, Nth edge of burst, 1373  
 edge coupling, 1379  
 edge fall time, 642  
 edge preshoot measured, 658  
 edge rise time, 663  
 EDGE SEARch commands, 1207  
 edge search slope, 1208  
 edge search source, 1209  
 edge slew rate, 666  
 edge slope, 1382  
 edge source, 1383  
 edge string for OR'ed edge trigger, 1405  
 EDGE trigger commands, 1377  
 edge triggering, 1350  
 edges (activity) on digital channels, 259  
 edges in measurement, 630  
 efficiency, 702  
 efficiency power analysis, apply, 784  
 elapsed time in mask test, 730  
 ellipsis, 225  
 enable channel labels, 428  
 enabling calibration, 335  
 enabling channel display, 347  
 enabling status register bits, 234, 248  
 end of string (EOS) terminator, 1668  
 end of text (EOT) terminator, 1668  
 end or identify (EOI), 1668  
 endpoint value, USB search, 1300  
 endpoint value, USB trigger, 1177  
 energy loss, 703  
 envelope math function, 525  
 EOI (end or identify), 1668  
 EOS (end of string) terminator, 1668  
 EOT (end of text) terminator, 1668  
 erase data, 421  
 erase measurements, 1575  
 erase screen, 1562  
 error counter (ARINC 429), 915  
 error counter (ARINC 429), reset, 916  
 error frame count (CAN), 932  
 error frame count (UART), 1148  
 error messages, 1317, 1605  
 error number, 1317  
 error queue, 1317, 1626  
 error, measurement, 620  
 ESB (Event Status Bit), 249, 251

ESE (Standard Event Status Enable Register), 234, 1625  
 ESR (Standard Event Status Register), 236, 1624  
 ET value, USB search, 1301  
 ET value, USB trigger, 1178  
 ETE demo signal, 397  
 event status conditions occurred, 251  
 Event Status Enable Register (ESE), 234, 1625  
 Event Status Register (ESR), 236, 297, 1624  
 example code, :ACQuire:COMplete, 303  
 example code, :ACQuire:SEGmented, 312  
 example code, :ACQuire:TYPE, 318  
 example code, :AUToscale, 262  
 example code, :CHANnel<n>:LAbel, 350  
 example code, :CHANnel<n>:PROBe, 352  
 example code, :CHANnel<n>:RANGe, 367  
 example code, :DIGitize, 269  
 example code, :DISPlay:DATA, 422  
 example code, :DISPlay:LAbel, 428  
 example code, :DISPlay:ORDer, 1561  
 example code, :MEASure:PERiod, 668  
 example code, :MEASure:RESults, 660  
 example code, :MEASure:TEDGE, 676  
 example code, :MTEST, 719  
 example code, :POD<n>:THRehold, 755  
 example code, :RUN:/STOP, 292  
 example code, :SYSTem:SETup, 1332  
 example code, :TIMEbase:DElay, 1602  
 example code, :TIMEbase:MODE, 1339  
 example code, :TIMEbase:RANGE, 1341  
 example code, :TIMEbase:REFERENCE, 1342  
 example code, :TRIGger:MODE, 1362  
 example code, :TRIGger:SLOPe, 1382  
 example code, :TRIGger:SOURce, 1383  
 example code, :VIEW and :BLANK, 298  
 example code, :WAVEform, 1478  
 example code, :WAVEform:DATA, 1463  
 example code, :WAVEform:POINTs, 1467  
 example code, :WAVEform:PREamble, 1471  
 example code, :WAVEform:SEGmented, 312  
 example code, :WGEN:ARbitrary:DATA, 1497  
 example code, \*RST, 246  
 example programs, 6, 1675  
 examples on the website, 1675  
 excursion delta for FFT peak search, 1218  
 EXE (Execution Error) status bit, 234, 236  
 execution error detected in Standard Event Status, 236  
 exponential fall waveform generator output, 1508  
 exponential math function, 524  
 exponential notation, 224  
 exponential rise waveform generator output, 1508  
 extended video triggering license, 1435  
 external glitch trigger source, 1392

external range, 446  
 External Scaling, enable/disable, 355  
 External Scaling, gain, 356  
 external trigger, 443, 445, 1383  
 EXternal trigger commands, 443  
 EXternal trigger level, 1380  
 external trigger probe attenuation factor, 445  
 external trigger probe sensing, 1563  
 EXternal trigger source, 1383  
 external trigger units, 447

## F

fail count, current harmonics analysis, 790  
 fail/pass status (overall) for current harmonics analysis, 797  
 failed waveforms in mask test, 728  
 failure, self test, 253  
 fall time measurement, 620, 642  
 Fall Time, power modulation analysis, 805  
 falling edge count measurement, 649  
 falling pulse count measurement, 650  
 FAST data, SENT, 1481  
 Fast Fourier Transform (FFT)  
     functions, 452, 465, 467, 501, 510, 513, 523, 1567  
 FF values in waveform data, 1463  
 FFT (Fast Fourier Transform) functions, 452, 465, 467, 501, 510, 513, 523, 1567  
 FFT (Fast Fourier Transform)  
     operation, 1477  
 FFT bin size/RBW/sample rate readout, 509  
 FFT detector decimation type, 503  
 FFT detector points, 502  
 FFT display mode, 455  
 FFT function display, 454  
 FFT function, source input, 464  
 FFT math function, 305  
 FFT vertical units, 466, 512  
 FFTPhase (Fast Fourier Transform)  
     functions, 523  
 fifty ohm impedance, disable setting, 1324  
 filename for hardcopy, 1570  
 filename for recall, 866, 1505  
 filename for save, 879  
 filter CXPI trigger by ID, 967  
 filter for frequency reject, 1381  
 filter for high frequency reject, 1354  
 filter for noise reject, 1363  
 filter used to limit bandwidth, 345, 444  
 filters to Fast Fourier Transforms, 467, 513  
 filters, math, 524  
 fine horizontal adjustment (vernier), 1345  
 fine vertical adjustment (vernier), 370  
 finish pending device operations, 240  
 first point displayed, 1487  
 FLATtop window for amplitude measurements, 467, 513  
 FLEXray autoset for event trigger, 988

FLEXray autoseup, 978  
 FlexRay demo signal, 398  
 FlexRay frame counters, reset, 982  
 FLEXray SEARch commands, 1248  
 FlexRay serial search, cycle, 1249  
 FlexRay serial search, data, 1250  
 FlexRay serial search, data length, 1251  
 FlexRay serial search, frame, 1252  
 FlexRay serial search, mode, 1253  
 FLEXray source, 985  
 FLEXray trigger, 986  
 FLEXray trigger commands, 976  
 FM burst demo signal, 397  
 FM modulation type, waveform generator, 1523  
 force trigger, 1353  
 format, 1465, 1470  
 format (word), ARINC 429, 918  
 format for block data, 239  
 format for generic video, 1431, 1435  
 format for hardcopy, 1569  
 format for image, 882  
 format for waveform data, 898  
 FormattedIO488 object, 77  
 formfeed for hardcopy, 542, 547  
 formulas for data conversion, 1458  
 frame, 1133  
 frame counters (CAN), error, 932  
 frame counters (CAN), overload, 933  
 frame counters (CAN), reset, 934  
 frame counters (CAN), total, 936  
 frame counters (FlexRay), null, 981, 983  
 frame counters (FlexRay), reset, 982  
 frame counters (FlexRay), total, 984  
 frame counters (UART), error, 1148  
 frame counters (UART), reset, 1149  
 frame counters (UART), Rx frames, 1150  
 frame counters (UART), Tx frames, 1151  
 frame ID, CXPI trigger, 972  
 frame ID, FLEXray BSS event trigger, 989  
 frame ID, FLEXray frame trigger, 993  
 frame type, FLEXray frame trigger, 994  
 frame value, USB search, 1302  
 frame value, USB trigger, 1179  
 framing, 1131  
 FRANalysis commands, 469  
 frequency deviation, waveform generator FM modulation, 1515  
 frequency measurement, 75, 620, 647  
 frequency measurements with X cursors, 591  
 frequency mode, Control Loop Response (Bode) power analysis, 772  
 frequency mode, Power Supply Rejection Ratio (PSRR) power analysis, 817  
 frequency resolution, 467, 513  
 frequency response analysis, data, 471  
 frequency response analysis, enable, 472  
 frequency response analysis, run, 478  
 frequency response analysis, single frequency, 474

frequency response analysis, sweep start frequency, 475  
 frequency response analysis, sweep stop frequency, 476  
 frequency span of display, 465, 510  
 Frequency, power modulation analysis, 805  
 front panel mode, 1364  
 front panel Single key, 294  
 front panel Stop key, 296  
 front-panel lock, 1318  
 FSK modulation type, waveform generator, 1523  
 FSK rate, waveform generator modulation, 1518  
 FT commands, 449  
 full-scale horizontal time, 1341, 1347  
 full-scale vertical axis defined, 461, 528  
 function, 452, 465, 467, 499, 501, 510, 513, 522, 523, 528, 529, 530, 1567, 1568  
 FUNCtion commands, 485  
 function memory, 295  
 function turned on or off, 1568  
 function, demo signal, 396  
 function, first source input, 537  
 function, second source input, 539  
 function, waveform generator, 1506  
 functions, 1477

## G

g(t) source, first input channel, 1565  
 g(t) source, math operation, 1564  
 g(t) source, second input channel, 1566  
 gain data, including in control loop response results, 779  
 gain data, including in FRA results, 481  
 gain data, including in PSRR results, 822  
 gain for Ax + B math operation, 520  
 gated measurement window, 689  
 gateway IP, 68  
 gating, FFT math function, 459, 506  
 gaussian pulse waveform generator output, 1509  
 general SBUS<n> commands, 907  
 general SEARch commands, 1202  
 general trigger commands, 1351  
 GENeric, 1431, 1435  
 generic video format, 1431, 1435  
 Generic video trigger, edge number, 1436  
 Generic video trigger, greater than sync pulse width time, 1439  
 Generic video trigger, horizontal sync control, 1437  
 Generic video trigger, horizontal sync pulse time, 1438  
 glitch demo signal, 396  
 glitch duration, 1391  
 glitch qualifier, 1390  
 GLITCH SEARch commands, 1210  
 glitch search, greater than value, 1211

glitch search, less than value, 1212  
 glitch search, polarity, 1213  
 glitch search, qualifier, 1214  
 glitch search, range, 1215  
 glitch search, source, 1216  
 glitch source, 1392  
 GLITch trigger commands, 1384  
 glitch trigger duration, 1386  
 glitch trigger polarity, 1389  
 glitch trigger source, 1386  
 GPIB interface, 68  
 graticule area for hardcopy print, 544  
 graticule axis labels, 424  
 graticule colors, invert for hardcopy, 548, 1572  
 graticule colors, invert for image, 883  
 graticule intensity, 425  
 graticule type, 426  
 grayscale palette for hardcopy, 556  
 grayscale palette for image, 884  
 grayscaling on hardcopy, 1571  
 greater than qualifier, 1390  
 greater than time, 1386, 1391, 1410, 1413  
 greater than value for glitch search, 1211  
 grid axis labels, 424  
 grid intensity, 425  
 grid type, 426  
 groups of digital channels, 751, 753, 755, 1556

## H

handshake PID, USB search, 1305  
 handshake PID, USB trigger, 1183  
 HANNing window for frequency resolution, 467, 513  
 hardcopy, 290, 542  
 HARDCopy commands, 541  
 hardcopy factors, 546, 881  
 hardcopy filename, 1570  
 hardcopy format, 1569  
 hardcopy formfeed, 547  
 hardcopy grayscale, 1571  
 hardcopy invert graticule colors, 548, 1572  
 hardcopy layout, 549  
 hardcopy palette, 556  
 hardcopy print, area, 544  
 hardcopy printer driver, 1573  
 Hardware Event Condition Register (:HWERegister:CONDition), 272  
 Hardware Event Condition Register (:OPERegister:CONDition), 1633  
 Hardware Event Enable Register (HWEenable), 270  
 Hardware Event Event Register (:HWERegister:[EVENT]), 273, 1632  
 HARMonics demo signal, 399  
 HCOPY commands, 541  
 head type, probe, 358

header, 1667  
 high pass filter math function, 524  
 high resolution acquisition type, 1458  
 high trigger level, 1360  
 high-frequency reject filter, 1354, 1381  
 high-level voltage, waveform generator, 1533  
 high-pass filter cutoff frequency, 516  
 high-resolution acquisition type, 300  
 hold time, setup and hold trigger, 1423  
 hold until operation complete, 240  
 holdoff time, 1355  
 holes in waveform data, 1463  
 hop frequency, waveform generator FSK modulation, 1517  
 horizontal adjustment, fine (vernier), 1345  
 horizontal position, 1346  
 horizontal scale, 1344, 1348  
 horizontal scaling, 1470  
 horizontal time, 1341, 1347, 1576  
 Host ID of oscilloscope, 1315  
 Host name softkey, 68  
 hostname, 68  
 hub address value, USB search, 1303  
 hub address value, USB trigger, 1180  
 hubs, USB 2.0 signal quality, 373  
 HWEenable (Hardware Event Enable Register), 270  
 HWERegister:CONDition (Hardware Event Condition Register), 272, 1633  
 HWERegister:[EVENT] (Hardware Event Event Register), 273, 1632

## I

I1080L50HZ, 1431, 1435  
 I1080L60HZ, 1431, 1435  
 I2C demo signal, 397  
 I2S alignment, 998  
 I2S audio channel, 1007  
 I2S clock slope, 1000  
 I2S CLOCK source, 1002  
 I2S DATA source, 1003  
 I2S demo signal, 398  
 I2S pattern data, 1008  
 I2S pattern format, 1010  
 I2S range, 1011  
 I2S receiver width, 1001  
 I2S SEARch commands, 1254  
 I2S serial bus commands, 995  
 I2S serial decode base, 999  
 I2S serial search, audio channel, 1255  
 I2S serial search, data, 1257  
 I2S serial search, format, 1258  
 I2S serial search, mode, 1256  
 I2S serial search, range, 1259  
 I2S transmit word size, 1012  
 I2S trigger operator, 1005  
 I2S triggering, 906  
 I2S word select (WS) low, 1013  
 I2S word select (WS) source, 1004

ID filter for CAN trigger, 949  
 id mode, 955  
 ID pattern, CAN trigger, 954  
 identification number, 238  
 identification of options, 241  
 identifier, LIN, 1036  
 idle, 1374  
 idle state, SENT bus, 1098  
 idle until operation complete, 240  
 IDN (Identification Number), 238  
 IEC 61000-3-2 standard for current harmonics analysis, 796  
 IEEE 488.2 standard, 231  
 IIC address, 1019  
 IIC clock, 1017  
 IIC data, 1018, 1020  
 IIC data 2, 1021  
 IIC SEARch commands, 1260  
 IIC serial decode address field size, 1016  
 IIC serial search, address, 1263  
 IIC serial search, data, 1264  
 IIC serial search, data2, 1265  
 IIC serial search, mode, 1261  
 IIC serial search, qualifier, 1266  
 IIC trigger commands, 1014  
 IIC trigger qualifier, 1022  
 IIC trigger type, 1023  
 IIC triggering, 906  
 image format, 882  
 image invert graticule colors, 883  
 image memory, 295  
 image palette, 884  
 image, save, 880  
 image, save with inksaver, 883  
 impedance, 348  
 infinity representation, 1673  
 initial load current, transient response analysis, 857  
 initialization, 74, 77  
 initialize, 244, 1321  
 initialize label list, 429  
 initiate acquisition, 268  
 inksaver, save image with, 883  
 input coupling for channels, 346  
 input for integrate, DC offset correction, 519  
 input impedance for channels, 348, 1558  
 input inversion for specified channel, 349  
 input power, 705  
 input source, Control Loop Response (Bode) power analysis, 777  
 input source, Power Supply Rejection Ratio (PSRR) power analysis, 820  
 inrush current, 709  
 inrush current analysis, 799, 800, 801  
 inrush current expected, 837  
 insert label, 350  
 installed options identified, 241  
 instruction header, 1667  
 instrument number, 238  
 instrument options identified, 241  
 instrument requests service, 251

instrument serial number, 293  
 instrument settings, 542  
 instrument status, 84  
 instrument type, 238  
 integrate DC offset correction, 519  
 integrate math function, 523, 1477  
 Integrate math function, Initial Condition, 518  
 INTegrate source for function, 1567  
 intensity, waveform, 427  
 internal low-pass filter, 345, 444  
 introduction to :ACQuire commands, 300  
 introduction to :BUS<n> commands, 320  
 introduction to :CALibrate commands, 330  
 introduction to :CHANnel<n> commands, 344  
 introduction to :COUNTER commands, 384  
 introduction to :DEMO commands, 395  
 introduction to :DIGItal<d> commands, 404  
 introduction to :DISPlay commands, 413  
 introduction to :EXTernal commands, 443  
 introduction to :FFT commands, 450  
 introduction to :FRANalysis commands, 470  
 introduction to :FUNCtion commands, 491  
 introduction to :HARDcopy commands, 542  
 introduction to :LISTER commands, 561  
 introduction to :LTESt commands, 566  
 introduction to :MARKer commands, 581  
 introduction to :MEASURE commands, 620  
 introduction to :POD<n> commands, 751  
 introduction to :RECall commands, 862  
 introduction to :SAVE commands, 876  
 introduction to :SBUS commands, 905  
 introduction to :SYSTem commands, 1313  
 introduction to :TIMEbase commands, 1338  
 introduction to :TRIGger commands, 1349  
 introduction to :WAVEform commands, 1456  
 introduction to :WGEN<w> commands, 1495  
 introduction to :WMEMory<r> commands, 1537  
 introduction to common (\*) commands, 231  
 introduction to root () commands, 258  
 invert graticule colors for hardcopy, 548, 1572  
 invert graticule colors for image, 883  
 inverted masks, bind levels, 744  
 inverting input for channels, 349  
 IO library, referencing, 76  
 IO operation complete, waiting for, 1642  
 IP address, 68

## K

key disable, 1318

key press detected in Standard Event Status Register, 236  
 KEYSight demo signal, 399  
 Keysight Interactive IO application, 71  
 Keysight IO Control icon, 69  
 Keysight IO Libraries Suite, 6, 65, 76, 78  
 Keysight IO Libraries Suite, installing, 66  
 knob disable, 1318  
 known state, 244, 1321

**L**

label, 1555  
 label command, bus, 326  
 label list, 350, 429  
 label reference waveforms, 1541  
 label, ARINC 429 trigger, 922, 926, 1233  
 label, digital channel, 406  
 labels, 350, 428, 429  
 labels to store calibration information, 332  
 labels, specifying, 413  
 LAN instrument, 70  
 LAN interface, 67, 69  
 LAN Settings softkey, 68  
 landscape layout for hardcopy, 549  
 language for program examples, 73  
 layout for hardcopy, 549  
 leakage into peak spectrum, 467, 513  
 learn string, 239, 1332  
 least significant byte first, 1461  
 left time base reference, 1342  
 legal values for channel offset, 351  
 legal values for frequency span, 465, 510  
 legal values for offset, 522, 529  
 length for waveform data, 899  
 length of data, CXPI trigger, 970  
 less than qualifier, 1390  
 less than time, 1387, 1391, 1411, 1413  
 less than value for glitch search, 1212  
 level for trigger voltage, 1380, 1388  
 LF coupling, 1379  
 license information, 241  
 limits for line number, 1431  
 LIN acknowledge, 1029  
 LIN baud rate, 1030  
 LIN demo signal, 397  
 LIN identifier, 1036  
 LIN pattern data, 1037  
 LIN pattern format, 1040  
 LIN SEARch commands, 1267  
 LIN serial decode bus parity bits, 1028  
 LIN serial search, data, 1270  
 LIN serial search, data format, 1272  
 LIN serial search, data length, 1271  
 LIN serial search, frame ID, 1268  
 LIN serial search, mode, 1269  
 LIN source, 1031  
 LIN standard, 1032  
 LIN symbolic data display, 1027  
 LIN symbolic data, recall, 867  
 LIN sync break, 1033

LIN trigger, 1034, 1039  
 LIN trigger commands, 1025  
 LIN trigger definition, 1599  
 LIN triggering, 906  
 line frequency setting for current harmonics analysis, 791  
 line glitch trigger source, 1392  
 line number for TV trigger, 1431  
 line terminator, 224  
 LINE trigger level, 1380  
 LINE trigger source, 1383  
 Linear units for FFT (Magnitude), 512  
 list of channel labels, 429  
 LISTer commands, 561  
 lister display, 563  
 lister time reference, 564  
 ln math function, 524  
 load utilization (CAN), 937  
 local lockout, 1318  
 location, custom time base reference location, 1343  
 lock, 1318  
 lock mask to signal, 735  
 lock, analog channel protection, 1324  
 lockout message, 1318  
 log file name, remote command logging, 1325, 1328  
 log math function, 524  
 Logarithmic units for FFT (Magnitude), 512  
 logic level activity, 1554  
 long form, 1668  
 low frequency sine with glitch demo signal, 397  
 low pass filter math function, 524  
 low trigger level, 1361  
 lower threshold, 655  
 lower threshold voltage for measurement, 1574  
 lowercase characters in commands, 1667  
 low-frequency reject filter, 1381  
 low-level voltage, waveform generator, 1534  
 low-pass filter cutoff frequency, 517  
 low-pass filter used to limit bandwidth, 345, 444  
 LRN (Learn Device Setup), 239  
 lsbfirst, 1461  
 LTEST commands, 565

**M**

M1553 SEARch commands, 1276  
 M1553 trigger commands, 1044  
 M1553 trigger type, 1050  
 magnify math function, 525  
 magnitude of occurrence, 678  
 main sweep range, 1346  
 main time base, 1602  
 main time base mode, 1339  
 making measurements, 620  
 MAN option for probe sense, 1559, 1563

Manchester baud rate, 1054  
 Manchester bit order, 1055  
 Manchester bit values trigger, data value, 1066  
 Manchester bit values trigger, data width, 1067  
 Manchester bus display format, 1056  
 Manchester decode base, 1053  
 Manchester idle time in bits, 1059  
 Manchester number of bits in header field, 1058  
 Manchester number of bits in trailer field, 1068  
 Manchester number of bits per word in data field, 1069  
 Manchester number of words in data field, 1057  
 Manchester polarity, 1060  
 MANChest serial bus commands, 1051  
 Manchester signal source, 1061  
 Manchester signal tolerance, 1064  
 Manchester starting edge, 1063  
 Manchester sync size, 1062  
 Manchester trigger mode, 1065  
 Manchester/NRZ demo signal, 398  
 manual cursor mode, 583  
 manufacturer string, 1319, 1320  
 MARKer commands, 579  
 marker mode, 594  
 marker position, 596  
 marker readout, 1580, 1581  
 marker set for voltage measurement, 1585, 1586  
 marker sets start time, 1577  
 marker time, 1576  
 markers for delta voltage measurement, 1584  
 markers track measurements, 665  
 markers, command overview, 581  
 markers, mode, 583  
 markers, time at start, 1581  
 markers, time at stop, 1580  
 markers, X delta, 582, 590  
 markers, X1 position, 585  
 markers, X1Y1 source, 586  
 markers, X2 position, 588  
 markers, X2Y2 source, 589  
 markers, Y delta, 597  
 markers, Y1 position, 594  
 markers, Y2 position, 596  
 mask, 234, 248  
 mask command, bus, 327  
 mask statistics, reset, 729  
 mask statistics, saving, 892  
 mask test commands, 717  
 Mask Test Event Enable Register (MTEenable), 274  
 mask test event event register, 276  
 Mask Test Event Event Register (:MTERegister[:EVENT]), 276, 1634  
 mask test run mode, 736  
 mask test termination conditions, 736

mask test, all channels, 722  
 mask test, enable/disable, 734  
 mask, delete, 733  
 mask, get as binary block data, 732  
 mask, load from binary block data, 732  
 mask, lock to signal, 735  
 mask, recall, 868  
 mask, save, 885, 886  
 masks, bind levels, 744  
 master summary status bit, 251  
 math filters, 524  
 math function, stop displaying, 266  
 math operators, 523  
 math transforms, 523  
 math visualizations, 525  
 MAV (Message Available), 233, 249, 251  
 max hold math function, 525  
 maximum duration, 1387, 1410, 1411  
 maximum math function, 525  
 maximum number of peaks for FFT peak search, 1219  
 maximum position, 1340  
 maximum random trigger holdoff time, 1356  
 maximum range for zoomed window, 1347  
 maximum scale for zoomed window, 1348  
 maximum vertical value measurement, 683  
 maximum vertical value, time of, 690, 1578  
 maximum waveform data length, 900  
 MEASure commands, 601  
 measure mask test failures, 737  
 measure overshoot, 652  
 measure period, 655  
 measure phase between channels, 656  
 MEASure power commands, 693  
 measure preshoot, 658  
 measure start voltage, 1585  
 measure stop voltage, 1586  
 measure value at a specified time, 692, 1587  
 measure value at top of waveform, 688  
 measurement error, 620  
 measurement limit test, copy all limits from results, 568  
 measurement limit test, copy limit from results, 567  
 measurement limit test, enable, 570  
 measurement limit test, enable/disable, 576  
 measurement limit test, fail condition, 571  
 measurement limit test, lower limit, 572, 577  
 measurement limit test, margin when copying from results, 569  
 measurement limit test, measurement source, 573  
 measurement limit test, results, 574  
 measurement limit test, stop on failure, 575  
 measurement record, 1468  
 measurement results, saving, 893

measurement setup, 620, 667  
 measurement source, 667  
 measurement statistics results, 660  
 measurement statistics, display on/off, 670  
 measurement trend math function, 525  
 measurement window, 689  
 measurements, AC RMS, 640, 687  
 measurements, area, 623, 635  
 measurements, average value, 637, 681  
 measurements, base value, 638, 682  
 measurements, built-in, 75  
 measurements, burst width, 625  
 measurements, clear, 626, 1575  
 measurements, command overview, 620  
 measurements, counter, 627  
 measurements, DC RMS, 640, 687  
 measurements, definition setup, 630  
 measurements, fall time, 642  
 measurements, falling edge count, 649  
 measurements, falling pulse count, 650  
 measurements, frequency, 647  
 measurements, how autoscale affects, 261  
 measurements, lower threshold level, 1574  
 measurements, maximum vertical value, 683  
 measurements, maximum vertical value, time of, 690, 1578  
 measurements, minimum vertical value, 684  
 measurements, minimum vertical value, time of, 691, 1579  
 measurements, negative duty cycle, 648  
 measurements, overshoot, 652  
 measurements, period, 655  
 measurements, phase, 656  
 measurements, positive duty cycle, 641  
 measurements, preshoot, 658  
 measurements, pulse width, negative, 651  
 measurements, pulse width, positive, 659  
 measurements, ratio of AC RMS values, 686  
 measurements, rise time, 663  
 measurements, rising edge count, 654  
 measurements, rising pulse count, 657  
 measurements, show, 665  
 measurements, slew rate, 666  
 measurements, snapshot all, 622  
 measurements, source channel, 667  
 measurements, standard deviation, 664  
 measurements, start marker time, 1580  
 measurements, stop marker time, 1581  
 measurements, thresholds, 1577  
 measurements, time between start and stop markers, 1576  
 measurements, time between trigger and edge, 675  
 measurements, time between trigger and vertical value, 678  
 measurements, time between trigger and voltage level, 1582  
 measurements, upper threshold value, 1583

measurements, vertical amplitude, 636, 680  
 measurements, vertical peak-to-peak, 639, 685  
 measurements, voltage difference, 1584  
 memory depth, setting (Digitizer mode), 308  
 memory setup, 247, 1332  
 menu, display, 430  
 menu, system, 1601  
 message available bit, 251  
 message available bit clear, 233  
 message decode/triggering format, SENT, 1096  
 message displayed, 251  
 message error, 1605  
 message queue, 1623  
 message, CAN symbolic search, 1245  
 message, CAN symbolic trigger, 956  
 message, clear from display, 431  
 message, LIN symbolic search, 1273  
 message, LIN symbolic trigger, 1041  
 messages ready, 251  
 midpoint of thresholds, 655  
 MIL-STD-1553 demo signal, 398  
 MIL-STD-1553 serial decode base, 1046  
 MIL-STD-1553 serial search, data, 1278  
 MIL-STD-1553 serial search, mode, 1277  
 MIL-STD-1553 serial search, Remote Terminal Address, 1279  
 MIL-STD-1553, dual demo signal, 399  
 min hold math function, 525  
 minimum duration, 1386, 1410, 1411, 1413  
 minimum math function, 525  
 minimum random trigger holdoff time, 1357  
 minimum vertical value measurement, 684  
 minimum vertical value, time of, 691, 1579  
 MISO data pattern width, 1137  
 MISO data pattern, SPI trigger, 1136  
 MISO data source, SPI trigger, 1134  
 MISO data, SPI, 1481  
 mixed-signal demo signals, 397  
 mixed-signal oscilloscopes, 6  
 mnemonics, duplicate, 1671  
 mode, 583, 1339, 1432  
 mode, serial decode, 909  
 model number, 238  
 models, oscilloscope, 3  
 modes for triggering, 1362  
 Modify softkey, 68  
 modulating signal frequency, waveform generator, 1514, 1516  
 modulation (waveform generator), enabling/disabling, 1522  
 modulation analysis, 803  
 modulation analysis source (voltage or current), 804  
 modulation analysis, type of, 805  
 modulation type, waveform generator, 1523

MOSI data pattern width, 1139  
 MOSI data pattern, SPI trigger, 1138  
 MOSI data source, SPI trigger, 1135, 1600  
 most significant byte first, 1461  
 move cursors, 1580, 1581  
 msbfirrst, 1461  
 MSG (Message), 249, 251  
 MSO models, 6  
 MSS (Master Summary Status), 251  
 MTEnable (Mask Test Event Enable Register), 274  
 MTERegister[:EVENT] (Mask Test Event Event Register), 276, 1634  
 MTEST commands, 717  
 multi-channel waveform data, save, 887  
 multiple commands, 1671  
 multiple queries, 83  
 multiplier value for SENT Fast Channel Signal, 1105  
 multiply math function, 523, 1477  
 multiply math function as g(t) source, 1564

## N

N275xA InfiniiMode probe mode, 361  
 N275xA InfiniiMode probe quick-action button, 353  
 N2820A high sensitivity current probe, 635, 636, 637, 638, 639, 640  
 N8900A Infinium Offline oscilloscope analysis software, 887  
 name channels, 350  
 name list, 429  
 natural logarithm math function, 524  
 negative glitch trigger polarity, 1389  
 negative pulse width, 651  
 negative pulse width measurement, 75  
 negative pulse width, power modulation analysis, 805  
 negative slope, 1128, 1382  
 negative slope, Nth edge in burst, 1375  
 negative TV trigger polarity, 1433  
 network domain password, 553  
 network domain user name, 555  
 network printer address, 550  
 network printer domain, 552  
 network printer slot, 554  
 network printer, apply connection settings, 551  
 new line (NL) terminator, 224, 1668  
 new load current, transient response analysis, 858  
 NFC demo signal, 397  
 NFC trigger commands, 1393  
 nibble order for SENT Fast Channel Signal, 1109  
 NL (new line) terminator, 224, 1668  
 NM bits (CXPI), triggering on, 975  
 NMONotonic, dual demo signal, 399  
 noise floor, 851, 854  
 noise reject filter, 1363

noise waveform generator output, 1507  
 noise, adding to waveform generator output, 1521  
 noisy sine waveform demo signal, 396  
 non-core commands, 1666  
 non-interlaced GENeric mode, 1435  
 non-volatile memory, label list, 326, 406, 429  
 normal acquisition type, 300, 1457  
 normal trigger sweep mode, 1349  
 notices, 2  
 NR1 number format, 224  
 NR3 number format, 224  
 NRZ baud rate, 1073  
 NRZ bit order, 1074  
 NRZ bit values trigger, data value, 1085  
 NRZ bit values trigger, data width, 1086  
 NRZ bus display format, 1075  
 NRZ decode base, 1072  
 NRZ frame size, 1077  
 NRZ idle state level, 1080  
 NRZ idle time in bits, 1079  
 NRZ number of bits in header field, 1078  
 NRZ number of bits in trailer field, 1087  
 NRZ number of bits per word in data field, 1088  
 NRZ number of start bits, 1083  
 NRZ number of words in data field, 1076  
 NRZ polarity, 1081  
 NRZ serial bus commands, 1070  
 NRZ signal source, 1082  
 NRZ trigger mode, 1084  
 Nth edge burst trigger source, 1376  
 Nth edge burst triggering, 1350  
 Nth edge in a burst idle, 1374  
 Nth edge in burst slope, 1375  
 Nth edge of burst counter, 1373  
 Nth edge of Edge Then Edge trigger, 1369  
 NTSC, 1431, 1435  
 null frame count (FlexRay), 981  
 null offset, 851  
 NULL string, 1316  
 number format, 224  
 number of nibbles, SENT message, 1099  
 number of points, 308, 1466, 1468  
 number of time buckets, 1466, 1468  
 numeric variables, 82  
 numeric variables, reading query results into multiple, 84  
 nwidth, 651

## O

obsolete and discontinued commands, 1547  
 obsolete commands, 1666  
 Occupied Bandwidth, FFT analysis measurement, 645  
 occurrence reported by magnitude, 1582  
 offset, 491  
 offset for Ax + B math operation, 521

offset value for channel voltage, 351  
 offset value for FFT function, 460, 462  
 offset value for selected function, 522, 529  
 offset value for SENT Fast Channel Signal, 1107  
 offset, waveform generator, 1535  
 one values in waveform data, 1463  
 OPC (Operation Complete) command, 240  
 OPC (Operation Complete) status bit, 234, 236  
 OPEE (Operation Status Enable Register), 278  
 Open method, 77  
 operating configuration, 239, 1332  
 operating state, 247  
 operation complete, 240  
 operation status condition register, 280  
 Operation Status Condition Register (:OPERRegister:CONDition), 280, 1629  
 operation status conditions occurred, 251  
 Operation Status Enable Register (OPEE), 278  
 operation status event register, 283  
 Operation Status Event Register (:OPERRegister[:EVENT]), 283, 1627  
 operations for function, 523  
 operators, math, 523  
 OPERRegister:CONDition (Operation Status Condition Register), 280, 1629  
 OPERRegister[:EVENT] (Operation Status Event Register), 283, 1627  
 OPT (Option Identification), 241  
 optional syntax terms, 224  
 options, 241  
 OR trigger commands, 1404  
 order of digital channels on display, 1561  
 order of output, 1461  
 oscilloscope connection, opening, 77  
 oscilloscope connection, verifying, 69  
 oscilloscope external trigger, 443  
 oscilloscope models, 3  
 oscilloscope, connecting, 67  
 oscilloscope, initialization, 74  
 oscilloscope, operation, 6  
 oscilloscope, program structure, 74  
 oscilloscope, setting up, 67  
 oscilloscope, setup, 78  
 output control, demo signals, 402  
 output control, waveform generator, 1525  
 output load impedance, waveform generator, 482, 1526  
 output messages ready, 251  
 output polarity, waveform generator, 1528  
 output power, 708  
 output queue, 240, 1622  
 output queue clear, 233  
 output ripple, 714  
 output ripple analysis, 827  
 output sequence, 1461  
 output source, Control Loop Response (Bode) power analysis, 778

output source, Power Supply Rejection Ratio (PSRR) power analysis, 821  
 overall pass/fail status for current harmonics analysis, 797  
 overlapped commands, 87  
 overload, 366  
 Overload Event Enable Register (OVL), 286  
 Overload Event Register (:OVLRegister), 1631  
 Overload Event Register (OVL), 288  
 overload frame count (CAN), 933  
 overload protection, 286, 288  
 overshoot of waveform, 652  
 overshoot percent for transient response analysis, 838  
 overvoltage, 366  
 OVL (Overload Event Enable Register), 286  
 OVL (Overload Event Register), 288  
 OVL bit, 280, 283  
 OVLRegister (Overload Event Register), 1631

**P**

P1080L24HZ, 1431, 1435  
 P1080L25HZ, 1431, 1435  
 P1080L50HZ, 1431, 1435  
 P1080L60HZ, 1431, 1435  
 P480L60HZ, 1431, 1435  
 P720L60HZ, 1431, 1435  
 PAL, 1431, 1435  
 palette for hardcopy, 556  
 palette for image, 884  
 PAL-M, 1431, 1435  
 parametric measurements, 620  
 parity, 1153  
 parity bits, LIN serial decode bus, 1028  
 parser, 258, 1671  
 pass, self test, 253  
 pass/fail status (overall) for current harmonics analysis, 797  
 password, network domain, 553  
 path information, recall, 869  
 path information, save, 889  
 pattern, 1019, 1020, 1021  
 pattern data, I2S, 1008  
 pattern data, LIN, 1037  
 pattern duration, 1386, 1387, 1410, 1411  
 pattern for pattern trigger, 1407  
 pattern format, I2S, 1010  
 pattern format, LIN, 1040  
 pattern length, 952, 1039  
 PATTern trigger commands, 1406  
 pattern trigger format, 1409  
 pattern trigger qualifier, 1412  
 pattern triggering, 1350  
 pattern width, 1137, 1139  
 pause pulse, SENT messages, 1100  
 peak current, 709  
 peak data, 1457

peak detect, 317  
 peak detect acquisition type, 301, 1457  
 PEAK SEARch commands, 1217  
 peak-peak math function, 525  
 peak-to-peak vertical value measurement, 639, 685  
 pending operations, 240  
 percent of waveform overshoot, 652  
 percent thresholds, 630  
 period measured to calculate phase, 656  
 period measurement, 75, 620, 655  
 Period, power modulation analysis, 805  
 period, waveform generator, 1530  
 persistence data, clear from display, 433  
 persistence, waveform, 413, 432  
 phase angle, demo signals, 401  
 phase data, including in control loop response results, 779  
 phase data, including in FRA results, 481  
 phase measured between channels, 656  
 phase measurements, 676  
 phase measurements with X cursors, 591  
 phase shifted demo signals, 396  
 PID check value, USB trigger, 1181  
 PLL Locked bit, 272  
 PNG format screen image data, 422, 560  
 pod, 751, 753, 754, 755, 1477, 1556  
 POD commands, 751  
 POD data format, 1460  
 pod, stop displaying, 266  
 points, 308, 1466, 1468  
 points in waveform data, 1456  
 points per decade, Control Loop Response (Bode) power analysis, 776  
 points per decade, frequency response analysis, 477  
 points per decade, Power Supply Rejection Ratio (PSRR) power analysis, 819  
 points, setting (Digitizer mode), 308  
 polarity, 1154, 1433  
 polarity for glitch search, 1213  
 polarity for glitch trigger, 1389  
 polarity, runt search, 1223  
 polarity, runt trigger, 1415  
 polling synchronization example, 1654  
 polling synchronization with timeout, 1648  
 polling wait, 1646  
 PON (Power On) status bit, 234, 236  
 port value, USB search, 1308  
 port value, USB trigger, 1186  
 portrait layout for hardcopy, 549  
 position, 407, 588, 1340, 1346  
 position cursors, 1580, 1581  
 position in zoomed view, 1346  
 position waveforms, 1561  
 positive glitch trigger polarity, 1389  
 positive pulse width, 659  
 positive pulse width measurement, 75  
 positive pulse width, power modulation analysis, 805  
 positive slope, 1128, 1382  
 positive slope, Nth edge in burst, 1375

- positive TV trigger polarity, 1433  
 positive width, 659  
 power analysis, enabling, 786  
 Power commands, 757  
 power factor, 704  
 power factor for IEC 61000-3-2 Standard Class C, 792  
 power loss, 710  
 power phase angle, 698  
 power quality analysis, 826  
 power supply rejection ratio (PSRR), 813, 815, 816, 818  
 Power Supply Rejection Ratio (PSRR) power analysis settings, 812  
 preamble data, 1470  
 preamble metadata, 1456  
 predefined logic threshold, 1556  
 predefined threshold voltages, 1603  
 present working directory, recall operations, 869  
 present working directory, save operations, 889  
 preset conditions, 1321  
 preshoot measured on waveform, 658  
 previously stored configuration, 243  
 print command, 290  
 print job, start, 558  
 print mask test failures, 738  
 print query, 1596  
 printer driver for hardcopy, 1573  
 printer, active, 545  
 printing, 542  
 printing in grayscale, 1571  
 probe, 1380  
 probe attenuation affects channel voltage range, 367  
 probe attenuation factor (external trigger), 445  
 probe attenuation factor for selected channel, 352  
 probe head type, 358  
 probe ID, 359  
 probe sense for oscilloscope, 1559, 1563  
 probe skew value, 363, 1557  
 process sigma, mask test run, 741  
 program data, 1668  
 program data syntax rules, 1670  
 program initialization, 74  
 program message, 77, 231  
 program message syntax, 1667  
 program message terminator, 1668  
 program structure, 74  
 programming examples, 6, 1675  
 protecting against calibration, 335  
 protection, 286, 288, 366  
 protection lock, 1324  
 PTYPE byte (CXPI), trigger when present, 968  
 PTYPE frames, CXPI, 965  
 pulse waveform generator output, 1507  
 pulse width, 651, 659  
 pulse width duration trigger, 1386, 1387, 1391  
 pulse width measurement, 75, 620  
 pulse width trigger, 1363  
 pulse width trigger level, 1388  
 pulse width triggering, 1350  
 pulse width, waveform generator, 1510  
 pwidth, 659  
 Python, VISA COM example, 1702  
 Python, VISA example, 1749  
 PyVISA package, 1749
- Q**
- qualifier, 1391  
 qualifier for glitch search, 1214  
 qualifier, runt search, 1224  
 qualifier, runt trigger, 1416  
 qualifier, transition search, 1228  
 qualifier, transition trigger, 1426  
 qualifier, trigger duration, 1410, 1411  
 qualifier, trigger pattern, 1412  
 queries, multiple, 83  
 query error detected in Standard Event Status, 236  
 query responses, block data, 82  
 query responses, reading, 81  
 query results, reading into numeric variables, 82  
 query results, reading into string variables, 82  
 query return values, 1673  
 query setup, 542, 581, 620, 1332  
 query subsystem, 320, 404  
 querying setup, 344  
 querying the subsystem, 1350  
 queues, clearing, 1635  
 quick reference, commands, 89  
 quoted ASCII string, 225  
 QYE (Query Error) status bit, 234, 236
- R**
- ramp symmetry, waveform generator, 1511  
 ramp symmetry, waveform generator modulating signal, 1520  
 ramp waveform generator output, 1507  
 random trigger holdoff, 1358  
 range, 491, 1347  
 range for channels, 367  
 range for duration trigger, 1413  
 range for external trigger, 446  
 range for full-scale vertical axis, 461, 528  
 range for glitch search, 1215  
 range for glitch trigger, 1391  
 range for time base, 1341  
 range of offset values, 351  
 range qualifier, 1390  
 range, I2S, 1011  
 ranges, value, 225  
 ratio measurements with X cursors, 591  
 ratio measurements with Y cursors, 598  
 ratio of AC RMS values measured between channels, 686  
 Ratio, power modulation analysis, 805  
 raw acquisition record, 1468  
 RCL (Recall), 243  
 Rds (dynamic ON resistance) waveform, 850  
 Rds(on) power measurement, 711  
 Rds(on) value for conduction calculation, 852  
 reactive power, 712  
 read configuration, 239  
 ReadIEEEBlock method, 77, 81, 83  
 ReadList method, 77, 81  
 ReadNumber method, 77, 81  
 readout, 1576  
 ReadString method, 77, 81  
 real power, 713  
 Real Power source in Class D harmonics analysis, 793  
 real-time acquisition mode, 307  
 recall, 243, 862, 1332  
 recall arbitrary waveform, 864  
 recall CAN symbolic data, 865  
 RECall commands, 861  
 recall filename, 866, 1505  
 recall LIN symbolic data, 867  
 recall mask, 868  
 recall path information, 869  
 recall reference waveform, 871  
 recall setup, 870  
 recalling and saving data, 413  
 receiver width, I2S, 1001  
 RECTangular window for transient signals, 467, 513  
 reference, 491  
 reference for time base, 1602  
 reference point, FFT Phase, 507  
 reference waveform save source, 902  
 reference waveform, recall, 871  
 reference waveform, save, 903  
 reference waveforms, clear, 1539  
 reference waveforms, display, 1540  
 reference waveforms, label, 1541  
 reference waveforms, save to, 1542  
 reference waveforms, skew, 1543  
 reference waveforms, Y offset, 1544  
 reference waveforms, Y range, 1545  
 reference waveforms, Y scale, 1546  
 reference, lister, 564  
 reference, time base, 1342  
 registers, 236, 243, 247, 260, 274, 276, 278, 280, 283, 286, 288  
 registers, clearing, 1635  
 reject filter, 1381  
 reject high frequency, 1354  
 reject noise, 1363  
 relative standard deviation, 674  
 remote command logging, enable/disable, 1325, 1329

remote control examples, 1675  
 Remote Terminal Address (RTA), M1553 trigger, 1049  
 remote user interface enabled/disabled status, 281, 284, 1627, 1629  
 remove cursor information, 583  
 remove labels, 428  
 remove message from display, 1316  
 reorder channels, 261  
 repetitive acquisitions, 292  
 report errors, 1317  
 report transition, 678  
 reporting status, 1613  
 reporting the setup, 1350  
 request service, 251  
 Request-for-OPC flag clear, 233  
 reset, 244  
 reset conditions, 244  
 reset defaults, waveform generator, 1531  
 reset mask statistics, 729  
 reset measurements, 421  
 Resolution Bandwidth, FFT, 508  
 resolution of printed copy, 1571  
 resource session object, 77  
 ResourceManager object, 77  
 restore configurations, 239, 243, 247, 1332  
 restore labels, 428  
 restore setup, 243  
 return values, query, 1673  
 returning acquisition type, 317  
 returning number of data points, 308  
 reverse polarity, NFC trigger, 1396  
 RF burst demo signal, 397  
 right time base reference, 1342  
 ringing pulse demo signal, 396  
 ripple (output) analysis, 827  
 ripple, output, 714  
 rise time measurement, 620  
 rise time of positive edge, 663  
 Rise Time, power modulation analysis, 805  
 rising edge count measurement, 654  
 rising pulse count measurement, 657  
 RMS - AC, power modulation analysis, 805  
 RMS value measurement, 640, 687  
 roll time base mode, 1339  
 root (:) commands, 255, 258  
 root level commands, 3  
 RQL (Request Control) status bit, 234, 236  
 RQS (Request Service), 251  
 RS-232/UART triggering, 906  
 R-sense resistor value, N2825A user-defined R-sense head, 362  
 RST (Reset), 244  
 rules, tree traversal, 1671  
 rules, truncation, 1668  
 run, 252, 292  
 Run bit, 280, 283  
 run count, current harmonics analysis, 795  
 run mode, mask test, 736  
 run state, 291  
 run, USB 2.0 signal quality test, 374

running configuration, 247, 1332  
 RUNT SEARch commands, 1222  
 runt search polarity, 1223  
 runt search qualifier, 1224  
 runt search source, 1225  
 runt search, pulse time, 1226  
 RUNT trigger commands, 1414  
 runt trigger polarity, 1415  
 runt trigger qualifier, 1416  
 runt trigger source, 1417  
 runt trigger time, 1418  
 Rx frame count (UART), 1150  
 Rx source, 1155

**S**

S and E or U value, USB search, 1310  
 S and E or U value, USB trigger, 1188  
 sample rate, 3, 315  
 Sample Rate, FFT, 511  
 sample rate, setting (Digitizer mode), 315  
 sampled data, 1560  
 sampled data points, 1463  
 SAV (Save), 247  
 save, 247, 876  
 save arbitrary waveform, 877  
 SAVE commands, 873  
 save current harmonics analysis results, 888  
 save filename, 879  
 save image, 880  
 save image with inksaver, 883  
 save mask, 885, 886  
 save mask test failures, 739  
 save path information, 889  
 save reference waveform, 903  
 save setup, 896  
 save to reference waveform location, 1542  
 save waveform data, 897  
 saved image, area, 1598  
 saving and recalling data, 413  
 SBUS A429 commands, 910  
 SBUS CAN commands, 929  
 SBUS commands, 905  
 SBUS CXPI commands, 959  
 SBUS I2S commands, 995  
 SBUS MANchester commands, 1051  
 SBUS NRZ commands, 1070  
 SBUS SENT commands, 1089  
 SBUS USBPd commands, 1189  
 SBUS<n> commands, general, 907  
 SC value, USB search, 1309  
 SC value, USB trigger, 1187  
 scale, 463, 530, 1344, 1348  
 scale factors output on hardcopy, 546, 881  
 scale for channels, 368  
 scale units for channels, 357, 369  
 scale units for external trigger, 447  
 scaling display factors, 352  
 SCPI commands, 85  
 SCPI.NET examples, 1789

scratch measurements, 1575  
 screen area for hardcopy print, 544  
 screen area for saved image, 1598  
 screen display of logged remote commands, enable/disable, 1327  
 screen image data, 422, 559  
 SDI pattern, ARINC 429 trigger, 924, 1236  
 SEARch commands, 1201  
 SEARch commands, A429, 1232  
 SEARch commands, CAN, 1238  
 SEARch commands, EDGE, 1207  
 SEARch commands, FLEXray, 1248  
 SEARch commands, general, 1202  
 SEARch commands, GLITch, 1210  
 SEARch commands, I2S, 1254  
 SEARch commands, IIC, 1260  
 SEARch commands, LIN, 1267  
 SEARch commands, M1553, 1276  
 SEARch commands, PEAK, 1217  
 SEARch commands, RUNT, 1222  
 SEARch commands, SENT, 1280  
 SEARch commands, SPI, 1285  
 SEARch commands, TRANsition, 1227  
 SEARch commands, UART, 1289  
 SEARch commands, USB, 1293  
 search event (found) times, saving, 894  
 search for found event, 1204  
 search mode, 1205  
 search state, 1206  
 search, edge slope, 1208  
 search, edge source, 1209  
 search, USB, 1295  
 SECAM, 1431, 1435  
 seconds per division, 1344  
 segmented memory acquisition times, 895  
 segmented waveform save option, 901  
 segments, analyze, 310  
 segments, count of waveform, 1474  
 segments, setting number of memory, 311  
 segments, setting the index, 312  
 segments, time tag, 1475  
 select measurement channel, 667  
 self-test, 253  
 sensing a channel probe, 1559  
 sensing a external trigger probe, 1563  
 sensitivity of oscilloscope input, 352  
 SENT demo signal, 399  
 SENT enhanced serial message ID and data lengths, 1123  
 SENT fast channel data search value, 1281  
 SENT fast channel data trigger setting, 1118  
 SENT FAST data, 1481  
 SENT input source, 1113  
 SENT percent tolerance variation trigger, 1124  
 SENT SEARch commands, 1280  
 SENT search mode, 1282  
 SENT serial bus commands, 1089  
 SENT signal length setting, 1103  
 SENT signals display setting, 1102

- SENT slow channel data search  
    value, 1283  
SENT slow channel ID and data trigger data setting, 1119  
SENT slow channel ID search value, 1284  
SENT slow channel ID trigger setting, 1121  
SENT SLOW data, 1481  
SENT trigger mode, 1116  
SENT triggering, 906  
sequential commands, 87  
serial clock, 1017, 1132  
serial data, 1018  
serial decode bus, 905  
serial decode bus display, 908  
serial decode mode, 909  
serial frame, 1133  
serial number, 293  
service request, 251  
Service Request Enable Register (SRE), 249, 1620  
set center frequency, 452, 501  
set cursors, 1580, 1581  
set date, 1314  
set time, 1334  
set up oscilloscope, 67  
setting digital display, 405  
setting digital label, 326, 406  
setting digital position, 407  
setting digital threshold, 409  
setting display, 499  
setting external trigger level, 443  
setting impedance for channels, 348  
setting inversion for channels, 349  
setting pod display, 753  
setting pod size, 754  
setting pod threshold, 755  
settings, 243, 247  
settings conflict errors, 281, 284, 1627, 1629  
settings, instrument, 542  
setup, 301, 320, 344, 404, 413, 542, 1332  
setup and hold trigger clock source, 1421  
setup and hold trigger data source, 1422  
setup and hold trigger hold time, 1423  
setup and hold trigger setup time, 1424  
setup and hold trigger slope, 1420  
setup configuration, 243, 247, 1332  
setup defaults, 244, 1321  
setup memory, 243  
setup reported, 1350  
setup time, setup and hold trigger, 1424  
setup, recall, 870  
setup, save, 896  
shape of modulation signal, waveform generator, 1519  
SHOLD trigger commands, 1419  
short form, 5, 1668  
show channel labels, 428  
show measurements, 620, 665  
SICL example in C, 1769  
SICL example in Visual Basic, 1778  
SICL examples, 1769  
sidebar, display, 434  
sigma, mask test run, 741  
signal speed, ARINC 429, 921  
signal type, 364  
signal type, ARINC 429, 919  
signal value, CAN symbolic search, 1247  
signal value, CAN symbolic trigger, 958  
signal value, LIN symbolic search, 1275  
signal value, LIN symbolic trigger, 1043  
signal, CAN symbolic search, 1246  
signal, CAN symbolic trigger, 957  
signal, LIN symbolic search, 1274  
signal, LIN symbolic trigger, 1042  
signed data, 1459  
simple command headers, 1669  
sine cardinal waveform generator output, 1508  
sine waveform demo signal, 396  
sine waveform generator output, 1506  
single acquisition, 294  
single frequency, frequency response analysis, 473  
single-ended probe heads, 358  
single-ended signal type, 364  
single-shot demo signal, 396  
single-shot DUT, synchronizing with, 1650  
single-shot waveform generator output, 1529  
size, 754  
size, digital channels, 408  
skew, 363, 1557  
skew reference waveform, 1543  
slew rate of an edge, 666  
slew rate power analysis, 847  
slope, 1128, 1382  
slope (direction) of waveform, 1582  
slope not valid in TV trigger mode, 1382  
slope, arming edge, Edge Then Edge trigger, 1366  
slope, Nth edge in burst, 1375  
slope, setup and hold trigger, 1420  
slope, transition search, 1229  
slope, transition trigger, 1427  
slope, trigger edge, Edge Then Edge trigger, 1370  
slot, network printer, 554  
SLOW data, SENT, 1481  
smoothing acquisition type, 1458  
smoothing math function, 524  
smoothing math function, number of points, 536  
snapshot all measurement, 622  
software version, 238  
source, 667, 920, 945, 1031  
source (voltage or current) for slew rate analysis, 848  
source channel, M1553, 1047  
source for function, 1567  
source for glitch search, 1216  
source for Nth edge burst trigger, 1376  
source for trigger, 1383  
source for TV trigger, 1434  
source function for FFT peak search, 1220  
source input for FFT function, 464  
source input for function, first, 537  
source input for function, second, 539  
source, arming edge, Edge Then Edge trigger, 1367  
source, automask, 724  
source, FLEXray, 985  
source, mask test, 749  
source, NFC trigger, 1397  
source, runt search, 1225  
source, runt trigger, 1417  
source, save reference waveform, 902  
source, transition trigger, 1230, 1428  
source, trigger edge, Edge Then Edge trigger, 1371  
source, waveform, 1477  
span, 523  
span of frequency on display, 465, 510  
Spec error counter (CAN), 935  
special PID, USB search, 1306  
special PID, USB trigger, 1184  
specify measurement, 667  
speed of ARINC 429 signal, 921  
speed, USB decode, 1171  
SPI, 1128  
SPI clock timeout, 1129  
SPI decode bit order, 1127  
SPI decode word width, 1141  
SPI demo signal, 398  
SPI MISO data, 1481  
SPI SEARch commands, 1285  
SPI serial search, data, 1287  
SPI serial search, data width, 1288  
SPI serial search, mode, 1286  
SPI trigger, 1131, 1137, 1139  
SPI trigger clock, 1132  
SPI trigger commands, 1125  
SPI trigger frame, 1133  
SPI trigger MISO data pattern, 1136  
SPI trigger MOSI data pattern, 1138  
SPI trigger type, 1140  
SPI trigger, MISO data source, 1134  
SPI trigger, MOSI data source, 1135, 1600  
SPI triggering, 906  
square math function, 524  
square root math function, 524  
square wave duty cycle, waveform generator, 1512  
square waveform generator output, 1506  
SRE (Service Request Enable Register), 249, 1620  
SRQ (Service Request interrupt), 270, 274, 278  
SSM pattern, ARINC 429 trigger, 925, 1237  
standard deviation measured on waveform, 664  
Standard Event Status Enable Register (ESE), 234, 1625

Standard Event Status Register (ESR), 236, 1624  
 standard for CAN FD decode, 940  
 standard for video, 1435  
 standard, LIN, 1032  
 standard, NFC trigger, 1398  
 start acquisition, 252, 268, 292, 294  
 start and stop edges, 630  
 start cursor, 1580  
 start frequency, FFT math function, 457, 504  
 start measurement, 620  
 start print job, 558  
 start time, 1391, 1580  
 start time marker, 1577  
 starting bit for SENT Fast Channel Signal, 1111  
 starting byte of data, CXPI trigger, 971  
 state memory, 247  
 state of instrument, 239, 1332  
 state, run, 291  
 statistics increment, 671  
 statistics reset, 673  
 statistics results, 660  
 statistics, max count, 672  
 statistics, relative standard deviation, 674  
 statistics, type of, 669  
 status, 250, 295, 297  
 Status Byte Register (STB), 248, 250, 251, 1618  
 status data structure clear, 233  
 status registers, 84  
 status reporting, 1613  
 STB (Status Byte Register), 248, 250, 251, 1618  
 steady state output voltage expected, 842, 843, 844  
 step size for frequency span, 465, 510  
 stop, 268, 296  
 stop acquisition, 296  
 stop cursor, 1581  
 stop displaying channel, 266  
 stop displaying math function, 266  
 stop displaying pod, 266  
 stop frequency, FFT math function, 458, 505  
 stop on mask test failure, 740  
 stop time, 1391, 1581  
 storage, 247  
 store instrument setup, 239, 247  
 store setup, 247  
 storing calibration information, 332  
 string variables, 82  
 string variables, reading multiple query results into, 83  
 string variables, reading query results into multiple, 83  
 string, quoted ASCII, 225  
 subnet mask, 68  
 subsource, waveform source, 1481  
 subsystem commands, 3, 1671  
 subtract math function, 523, 1477

subtract math function as g(t) source, 1564  
 sweep mode, trigger, 1349, 1364  
 sweep speed set to fast to measure fall time, 642  
 sweep speed set to fast to measure rise time, 663  
 switch disable, 1318  
 switching level, current, 851  
 switching level, voltage, 854  
 switching loss per cycle, 700  
 switching loss power analysis, 849  
 sync break, LIN, 1033  
 sync frame count (FlexRay), 983  
 syntax elements, 224  
 syntax rules, program data, 1670  
 syntax, optional terms, 224  
 syntax, program message, 1667  
 SYSTem commands, 1311  
 system commands, 1314, 1316, 1317, 1318, 1332, 1334  
 system commands introduction, 1313

**T**

table of current harmonics results, 789  
 tdelta, 1576  
 Tektronix probe model number, 360  
 telnet ports 5024 and 5025, 1463  
 Telnet sockets, 85  
 temporary message, 1316  
 TER (Trigger Event Register), 297, 1621  
 termination conditions, mask test, 736  
 test sigma, mask test run, 741  
 test, self, 253  
 test, USB 2.0 signal quality, 379  
 text, writing to display, 1316  
 THD (total harmonics distortion), 798  
 threshold, 409, 755, 1556, 1603  
 threshold for FFT peak search, 1221  
 threshold voltage (lower) for measurement, 1574  
 threshold voltage (upper) for measurement, 1583  
 thresholds, 630, 1577  
 thresholds used to measure period, 655  
 thresholds, how autoscale affects, 261  
 time base, 1339, 1340, 1341, 1344, 1602  
 time base commands introduction, 1338  
 time base reference, 1342  
 time base reset conditions, 245, 1322  
 time base window, 1346, 1347, 1348  
 time between arm and trigger, NFC arm and trigger event, 1395  
 time between points, 1576  
 time buckets, 303, 304  
 time delay, 1602  
 time delay, Edge Then Edge trigger, 1368  
 time delta, 1576  
 time difference between data points, 1485  
 time duration, 1391, 1410, 1411, 1413

time holdoff for trigger, 1355  
 time interval, 678, 1576  
 time interval between trigger and occurrence, 1582  
 time marker sets start time, 1577  
 time measurements with X cursors, 591  
 time per division, 1341  
 time record, 467, 513  
 time reference, lister, 564  
 time specified, 692, 1587  
 time, calibration, 339  
 time, mask test run, 742  
 time, runt pulse search, 1226  
 time, runt trigger, 1418  
 time, start marker, 1580  
 time, stop marker, 1581  
 time, system, 1334  
 time, transition search, 1231  
 time, transition trigger, 1429  
 time/div, how autoscale affects, 261  
 time-at-max measurement, 1578  
 time-at-min measurement, 1579  
 TIMebase commands, 1337  
 timebase vernier, 1345  
 TIMebase:MODE, 80  
 time-ordered label list, 429  
 timeout enable, NFC arm and trigger event, 1402  
 timeout occurred, NFC arm and trigger event, 1401  
 timeout period, NFC arm and trigger event, 1403  
 timeout, SPI clock, 1129  
 timing measurement, 620  
 title channels, 350  
 title, mask test, 750  
 token PID, USB search, 1307  
 token PID, USB trigger, 1185  
 tolerance for determining valid SENT sync pulses, 1115  
 tolerance, automask, 726, 727  
 top of waveform value measured, 688  
 total frame count (CAN), 936  
 total frame count (FlexRay), 984  
 Total Harmonic Distortion, FFT analysis measurement, 646  
 total harmonics distortion (THD), 798  
 total waveforms in mask test, 731  
 touchscreen on/off, 1335  
 trace memory, 295  
 track measurements, 665  
 transfer instrument state, 239, 1332  
 transforms, math, 523  
 transient response, 715  
 transient response analysis, 855, 856, 859  
 TRANsition SEARch commands, 1227  
 transition search qualifier, 1228  
 transition search slope, 1229  
 transition search time, 1231  
 transition trigger qualifier, 1426  
 transition trigger slope, 1427  
 transition trigger source, 1230, 1428

- transition trigger time, 1429  
 transmit word size, I2S, 1012  
 transparent screen background, remote command logging, 1330  
 transparent, display, 435  
 tree traversal rules, 1671  
 trend measurement, 540  
 TRG (Trigger), 249, 251, 252  
 TRIG OUT BNC, 333  
 trigger armed event register, 280, 283  
 trigger armed status, checking for, 1637  
 trigger burst, UART, 1158  
 trigger channel source, 1392, 1434  
 TRIGger commands, 1349  
 TRIGger commands, general, 1351  
 trigger data, UART, 1159  
 TRIGger DELay commands, 1365  
 trigger duration, 1410, 1411  
 TRIGger EBURst commands, 1372  
 TRIGger EDGE commands, 1377  
 trigger edge coupling, 1379  
 trigger edge slope, 1382  
 trigger edge slope, Edge Then Edge trigger, 1370  
 trigger edge source, Edge Then Edge trigger, 1371  
 trigger event bit, 297  
 Trigger Event Register (TER), 1621  
 trigger event, NFC trigger, 1399  
 TRIGger FLEXray commands, 976  
 TRIGger GLITch commands, 1384  
 trigger holdoff, 1355  
 trigger idle, UART, 1160  
 TRIGger IIC commands, 1014  
 trigger level auto set up, 1359  
 trigger level constants, 352  
 trigger level voltage, 1380  
 trigger level, high, 1360  
 trigger level, low, 1361  
 TRIGger LIN commands, 1025  
 TRIGger M1553 commands, 1044  
 TRIGger NFC commands, 1393  
 trigger occurred, 251  
 TRIGger OR commands, 1404  
 TRIGger PATTern commands, 1406  
 trigger pattern qualifier, 1412  
 trigger qualifier, UART, 1161  
 trigger reset conditions, 245, 1322  
 TRIGger RUNT commands, 1414  
 TRIGger SHOld commands, 1419  
 trigger SPI clock slope, 1128  
 TRIGger SPI commands, 1125  
 trigger status bit, 297  
 trigger sweep mode, 1349  
 TRIGger TV commands, 1425, 1430  
 trigger type, ARINC 429, 927, 1234  
 trigger type, SPI, 1140  
 trigger type, UART, 1162  
 TRIGger UART commands, 1142  
 TRIGger USB commands, 1164, 1440  
 TRIGger ZONE commands, 1445  
 trigger, ARINC 429 source, 920  
 trigger, CAN, 946  
 trigger, CAN FD sample point, 939  
 trigger, CAN pattern data length, 952  
 trigger, CAN pattern ID mode, 955  
 trigger, CAN sample point, 941  
 trigger, CAN signal baudrate, 942  
 trigger, CAN signal definition, 943  
 trigger, CAN source, 945  
 trigger, duration greater than, 1410  
 trigger, duration less than, 1411  
 trigger, duration range, 1413  
 trigger, edge coupling, 1379  
 trigger, edge level, 1380  
 trigger, edge reject, 1381  
 trigger, edge slope, 1382  
 trigger, edge source, 1383  
 trigger, FLEXray, 986  
 trigger, FLEXray error, 987  
 trigger, FLEXray event, 990  
 trigger, force a, 1353  
 trigger, glitch greater than, 1386  
 trigger, glitch less than, 1387  
 trigger, glitch level, 1388  
 trigger, glitch polarity, 1389  
 trigger, glitch qualifier, 1390  
 trigger, glitch range, 1391  
 trigger, glitch source, 1392  
 trigger, high frequency reject filter, 1354  
 trigger, holdoff, 1355  
 trigger, I2S, 1005  
 trigger, I2S alignment, 998  
 trigger, I2S audio channel, 1007  
 trigger, I2S clock slope, 1000  
 trigger, I2S CLOCksource, 1002  
 trigger, I2S DATA source, 1003  
 trigger, I2S pattern data, 1008  
 trigger, I2S pattern format, 1010  
 trigger, I2S range, 1011  
 trigger, I2S receiver width, 1001  
 trigger, I2S transmit word size, 1012  
 trigger, I2S word select (WS) low, 1013  
 trigger, I2S word select (WS) source, 1004  
 trigger, IIC clock source, 1017  
 trigger, IIC data source, 1018  
 trigger, IIC pattern address, 1019  
 trigger, IIC pattern data, 1020  
 trigger, IIC pattern data 2, 1021  
 trigger, IIC qualifier, 1022  
 trigger, IIC signal baudrate, 1030  
 trigger, IIC type, 1023  
 trigger, LIN, 1034  
 trigger, LIN pattern data, 1037  
 trigger, LIN pattern data length, 1039  
 trigger, LIN pattern format, 1040  
 trigger, LIN sample point, 1029  
 trigger, LIN signal definition, 1599  
 trigger, LIN source, 1031  
 trigger, mode, 1362  
 trigger, noise reject filter, 1363  
 trigger, Nth edge burst source, 1376  
 trigger, Nth edge in burst slope, 1375  
 trigger, Nth edge of burst count, 1373  
 trigger, Nth edge of Edge Then Edge trigger, 1369  
 trigger, SPI clock slope, 1128  
 trigger, SPI clock source, 1132  
 trigger, SPI clock timeout, 1129  
 trigger, SPI frame source, 1133  
 trigger, SPI framing, 1131  
 trigger, SPI pattern MISO width, 1137  
 trigger, SPI pattern MOSI width, 1139  
 trigger, sweep, 1364  
 trigger, threshold, 1603  
 trigger, TV line, 1431  
 trigger, TV mode, 1432, 1604  
 trigger, TV polarity, 1433  
 trigger, TV source, 1434  
 trigger, TV standard, 1435  
 trigger, UART base, 1157  
 trigger, UART baudrate, 1146  
 trigger, UART bit order, 1147  
 trigger, UART parity, 1153  
 trigger, UART polarity, 1154  
 trigger, UART Rx source, 1155  
 trigger, UART Tx source, 1156  
 trigger, UART width, 1163  
 trigger, USB, 1172, 1444  
 trigger, USB D- source, 1441  
 trigger, USB D+ source, 1442  
 trigger, USB speed, 1443  
 truncation rules, 1668  
 TST (Self Test), 253  
 tstart, 1580  
 tstop, 1581  
 TTL threshold voltage for digital channels, 409, 1556  
 TTL trigger threshold voltage, 1603  
 turn function on or off, 1568  
 turn off channel, 266  
 turn off channel labels, 428  
 turn off digital pod, 266  
 turn off math function, 266  
 turn off time, 706, 809, 810  
 turn on channel labels, 428  
 turn on channel number display, 1561  
 turn on time, 707, 809, 810  
 turn on/turn off analysis thresholds, 810  
 turn on/turn off time analysis, 806, 807, 808, 809  
 turning channel display on and off, 347  
 turning off/on function calculation, 499  
 turning vectors on or off, 1560  
 TV mode, 1432, 1604  
 TV trigger commands, 1425, 1430  
 TV trigger line number setting, 1431  
 TV trigger mode, 1434  
 TV trigger polarity, 1433  
 TV trigger standard setting, 1435  
 TV triggering, 1350  
 tvmode, 1604  
 Tx data, UART, 1481  
 Tx frame count (UART), 1151  
 Tx source, 1156

type of power being converted, efficiency measurement, 785  
type, USB 2.0 signal quality test, 381

**U**

UART base, 1157  
UART baud rate, 1146  
UART bit order, 1147  
UART frame counters, reset, 1149  
UART parity, 1153  
UART polarity, 1154  
UART Rx source, 1155  
UART SEARch commands, 1289  
UART serial search, data, 1290  
UART serial search, data qualifier, 1292  
UART serial search, mode, 1291  
UART trigger burst, 1158  
UART trigger commands, 1142  
UART trigger data, 1159  
UART trigger idle, 1160  
UART trigger qualifier, 1161  
UART trigger type, 1162  
UART Tx data, 1481  
UART Tx source, 1156  
UART width, 1163  
UART/RS232 demo signal, 397  
UART/RS-232 triggering, 906  
units (vertical) for FFT, 466, 512  
units per division, 357, 368, 369, 447, 1344  
units per division (vertical) for FFT function, 463  
units per division (vertical) for function, 368, 530  
units, automask, 725  
units, X cursor, 591, 592  
units, Y cursor, 598, 599  
unsigned data, 1459  
unsigned mode, 1483  
upper threshold, 655  
upper threshold voltage for measurement, 1583  
uppercase characters in commands, 1667  
URQ (User Request) status bit, 234, 236  
USB (Device) interface, 67  
USB 2.0 signal quality test results, save, 878  
USB demo signal, 399  
USB PD demo signal, 399  
USB PD trigger mode, 1191  
USB PD trigger, control message type, 1194  
USB PD trigger, data message type, 1196, 1197  
USB PD trigger, header content trigger qualifier, 1200  
USB PD trigger, header type, 1192  
USB PD trigger, user-defined header value, 1199  
USB PD triggering, 906

USB PD waveform source, 1190  
USB SEARch commands, 1293  
USB source, 1441, 1442  
USB speed, 1443  
USB storage device, recalling files from, 862  
USB storage device, saving files to, 876  
USB trigger, 1444  
USB trigger commands, 1164, 1440  
USB triggering, 1350  
USBPd serial bus commands, 1189  
user defined channel labels, 350  
user defined threshold, 1556  
user event conditions occurred, 251  
User Files directory, 869, 889  
user name, network domain, 555  
User's Guide, 6  
user-defined baud rate, ARINC 429, 914  
user-defined Real Power in Class D harmonics analysis, 794  
user-defined threshold voltage for digital channels, 409  
user-defined trigger threshold, 1603  
USR (User Event bit), 249, 251  
utilization, CAN bus, 937

**V**

valid command strings, 1667  
valid pattern time, 1410, 1411  
value, 678  
value measured at base of waveform, 638, 682  
value measured at specified time, 692, 1587  
value measured at top of waveform, 688  
value ranges, 225  
values required to fill time buckets, 304  
VBA, 76, 1676  
Vce(sat) power measurement, 716  
Vce(sat) value for conduction calculation, 853  
vectors turned on or off, 1560  
vectors, display, 436  
vectors, turning on or off, 413  
vernier, channel, 370  
vernier, horizontal, 1345  
vertical adjustment, fine (vernier), 370  
vertical amplitude measurement, 636, 680  
vertical axis defined by RANGE, 461, 528  
vertical axis range for channels, 367  
vertical offset for channels, 351  
vertical peak-to-peak measured on waveform, 639, 685  
vertical scale, 368, 463, 530  
vertical scaling, 1470  
vertical threshold, 1556  
vertical units for FFT, 466, 512  
vertical value at center screen, 460, 462, 522, 529

vertical value maximum measured on waveform, 683  
vertical value measurements to calculate overshoot, 652  
vertical value minimum measured on waveform, 684  
video line to trigger on, 1431  
video standard selection, 1435  
view, 298, 1484, 1561  
view turns function on or off, 1568  
VISA COM example in C#, 1685  
VISA COM example in Python, 1702  
VISA COM example in Visual Basic, 1676  
VISA COM example in Visual Basic .NET, 1694  
VISA example in C, 1709  
VISA example in C#, 1728  
VISA example in Python, 1749  
VISA example in Visual Basic, 1718  
VISA example in Visual Basic .NET, 1739  
VISA examples, 1676, 1709  
VISA.NET example in C#, 1756  
VISA.NET example in Visual Basic .NET, 1762  
VISA.NET examples, 1756  
Visual Basic .NET, VISA COM example, 1694  
Visual Basic .NET, VISA example, 1739  
Visual Basic .NET, VISA.NET example, 1762  
Visual Basic 6.0, 77  
Visual Basic for Applications, 76, 1676  
Visual Basic, SICL library example, 1778  
Visual Basic, VISA COM example, 1676  
Visual Basic, VISA example, 1718  
visualizations, math, 525  
voltage (waveform generator), frequency response analysis, 483  
voltage crossing reported or not found, 1582  
voltage difference between data points, 1488  
voltage difference measured, 1584  
voltage in, frequency response analysis, 479, 480  
voltage level for active trigger, 1380  
voltage marker used to measure waveform, 1585, 1586  
voltage offset value for channels, 351  
voltage probe, 357, 369, 447  
voltage profile, frequency response analysis, 484  
voltage ranges for channels, 367  
voltage ranges for external trigger, 446  
voltage source, 846  
voltage threshold, 630  
voltage, maximum expected input, 839, 840, 841

**W**

WAI (Wait To Continue), 254

wait, 254  
 wait for operation complete, 240  
 Wait Trig bit, 280, 283  
 warranty, 2  
 waveform base value measured, 638, 682  
 WAWaveform command, 75  
 WAWaveform commands, 1453  
 waveform data, 1456  
 waveform data format, 898  
 waveform data length, 899  
 waveform data length, maximum, 900  
 waveform data, save, 897  
 waveform generator, 1495  
 waveform generator amplitude, 483, 1532  
 waveform generator function, 1506  
 waveform generator high-level voltage, 1533  
 waveform generator load impedance, Control Loop Response (Bode) power analysis, 780  
 waveform generator load impedance, Power Supply Rejection Ratio (PSRR) power analysis, 823  
 waveform generator low-level voltage, 1534  
 waveform generator offset, 1535  
 waveform generator output control, 1525  
 waveform generator output load impedance, 482, 1526  
 waveform generator output mode, 1527  
 waveform generator output polarity, 1528  
 waveform generator period, 1530  
 waveform generator pulse width, 1510  
 waveform generator ramp symmetry, 1511  
 waveform generator reset defaults, 1531  
 waveform generator square wave duty cycle, 1512  
 waveform introduction, 1456  
 waveform maximum vertical value measured, 683  
 waveform minimum vertical value measured, 684  
 waveform must cross voltage level to be an occurrence, 1582  
 WAWaveform parameters, 80  
 waveform peak-to-peak vertical value measured, 639, 685  
 waveform period, 655  
 waveform persistence, 413  
 waveform RMS value measured, 640, 687  
 waveform save option for segments, 901  
 waveform source, 1477  
 waveform source subsource, 1481  
 waveform standard deviation value measured, 664  
 waveform vertical amplitude, 636, 680  
 waveform voltage measured at marker, 1585, 1586  
 waveform, byte order, 1461  
 waveform, count, 1462  
 waveform, data, 1463  
 waveform, format, 1465

waveform, points, 1466, 1468  
 waveform, preamble, 1470  
 waveform, type, 1482  
 waveform, unsigned, 1483  
 waveform, view, 1484  
 waveform, X increment, 1485  
 waveform, X origin, 1486  
 waveform, X reference, 1487  
 waveform, Y increment, 1488  
 waveform, Y origin, 1489  
 waveform, Y reference, 1490  
 WAWaveform:FORMat, 80  
 waveforms, mask test run, 743  
 wavegen output amplitude(s), Control Loop Response (Bode) power analysis, 781  
 wavegen output amplitude(s), Power Supply Rejection Ratio (PSRR) power analysis, 824  
 Web control, 85  
 website, examples on, 1675  
 WGEN commands, 1491  
 WGEN trigger source, 1383  
 what's new, 41  
 width, 1163, 1391  
 window, 1346, 1347, 1348  
 window time, 1341  
 window time base mode, 1339  
 window, measurement, 689  
 windows, 467, 513  
 windows as filters to Fast Fourier Transforms, 467, 513  
 windows for Fast Fourier Transform functions, 467, 513  
 WMEMory commands, 1537  
 word counter (ARINC 429), 917  
 word counter (ARINC 429), reset, 916  
 word format, 1465  
 word format for data transfer, 1459  
 word format, ARINC 429, 918  
 word select (WS) low, I2S trigger, 1013  
 word select (WS) source, I2S, 1004  
 word width, SPI decode, 1141  
 write mode, remote command logging, 1325, 1331  
 write text to display, 1316  
 WriteIEEEBlock method, 77, 83  
 WriteList method, 77  
 WriteNumber method, 77  
 WriteString method, 77

## X

X axis markers, 581  
 X cursor units, 591, 592  
 X delta, 582, 590  
 X delta, mask scaling, 746  
 X1 and X2 cursor value difference, 582, 590  
 X1 cursor, 581, 585, 586  
 X1, mask scaling, 745  
 X2 cursor, 581, 588, 589

X-axis functions, 1338  
 X-increment, 1485  
 X-of-max measurement, 690  
 X-of-min measurement, 691  
 X-origin, 1486  
 X-reference, 1487  
 X-Y mode, 1338, 1339

## Y

Y axis markers, 581  
 Y cursor units, 598, 599  
 Y offset, reference waveform, 1544  
 Y range, reference waveform, 1545  
 Y scale, reference waveform, 1546  
 Y1 and Y2 cursor value difference, 597  
 Y1 cursor, 581, 586, 594, 597  
 Y1, mask scaling, 747  
 Y2 cursor, 581, 589, 596, 597  
 Y2, mask scaling, 748  
 Y-axis value, 1489  
 Y-increment, 1488  
 Y-origin, 1489, 1490  
 Y-reference, 1490

## Z

zero values in waveform data, 1463  
 zone 1 or zone 2 mode, 1448  
 zone 1 or zone 2 placement, 1449  
 zone 1 or zone 2 state, 1451  
 zone 1 or zone 2 validity, 1450  
 zone qualified trigger source, 1446  
 zone qualified trigger state, 1447  
 ZONE trigger commands, 1445  
 Zoom In/Out setting for N2820A channel, 365  
 zoomed time base, 1339  
 zoomed time base measurement window, 689  
 zoomed time base mode, how autoscale affects, 261  
 zoomed window horizontal scale, 1348