

Larkspur DC-04 / customer engineer markups

FICTIONAL REPLAY - not a design certification or commercial offer

Document role: markup

Revision: B

Comment 1 | MSB-01 | main_breaker_trip_a: 3000 A | Revise the main trip setting.

Comment 2 | MSB-01 | enclosure_type: NEMA 3R | Show the specified enclosure.

Comment 3 | MSB-01 | communications_protocol: Modbus TCP | Match the controls schedule.

Comment 4 | MSB-01 | cable_entry: top | Coordinate top-entry cables.

Comment 5 | MSB-01 | enclosure_width_mm: 2400 mm | Correct the overall width.

Comment 6 | MSB-01 | nameplate_text: MSB-01 / 480 V / 85 kA | Correct the label.

Comment 8 | MSB-01 | bus_material: copper | Provide copper per specification.

Comment 9 | MSB-01 | metering: multifunction | Confirm the meter type shown.

Comment 10 | MSB-01 | bus_plating: silver | Confirm bus plating.

Comment 11 | MSB-01 | Confirm lifting-eye clearance; detail is unclear.

Comment 7 | MSB-01 | short_circuit_ka: 85 kA | Match the purchase order rating.