

Scale 1/4" = 1'-0" on a 24 × 36 sheet · North is up-left (the angled wall faces Old Placerville Rd) · Dimensions scaled from the listing plan, ±2 ft, field-verify

Phase 1 · Occupancy, seating and exit plan

Change of occupancy B → A-3 with **no construction**. The suite is used exactly as it stands today.

SEATS SET OUT

180 = 175 movable chairs + 5 wheelchair spaces, 9 rows

OCCUPANT LOAD, CBC TABLE 1004.5

AREA	SF	SF PER PERSON	LOAD
Worship area, chairs not fixed	2,128	7 net	304
Pulpit area, floor level	332	15 net	23
Fellowship, tables and chairs	792	15 net	53
Lobby	421	15 net	29
Chair and table storage	295	300 gross	1
Nursery, existing office	124	35 net	4
Classroom, existing office	106	20 net	6
Classroom, existing office	126	20 net	7
Classroom, existing 14' × 19' room	265	20 net	14
Church office, existing room	102	150 gross	1
Restrooms and vestibule	565	n/a	0
Calculated occupant load			**442**

EXITS

EXIT	DOOR	CLEAR	CAPACITY
1 · front door, west wall	glass pair	≈ 60 in	300
2 · vestibule to parking lot	single, two doors in series	32 in	160
3 · north wall	single	32 in	160
Three exits; two required for 442			**620**

LEGEND

- Worship area, chairs not fixed
- Fellowship, tables and chairs
- Chair and table storage
- Pulpit area, floor level
- Lobby
- Existing rooms, used as is
- **EXIT** exit sign at door
- emergency light
- **FE** fire extinguisher
- accessible route

NOTES

1. No walls, doors, plumbing, lighting or HVAC are added, removed or moved. Every room keeps its walls and doors.
2. Movable chairs, 21 × 23 in, 36 in back to back (13 in clear). 5 ft center aisle, 3 ft minimum side aisles, 5 ft back aisle. 5 wheelchair spaces, 33 in wide, with companion seats at both ends of the back row. Chairs ganged in groups of three or more, since the worship area loads above 200.
3. Area labels set the occupant load: the worship area is only the seating block and its aisles; the rest of the open floor is fellowship space with tables.
4. To verify on site, as these may be required even without construction: panic hardware on exits 1 to 3, exit signs and emergency lighting where shown, the occupant load sign, an extinguisher within 75 ft of travel, and whether the building's alarm already has horns and strobes in the suite.
5. Parking per Planning: 0.3 per seat, 180 seats need 54 spaces; 55 on site.

Bible Fellowship Baptist Church
10360 Old Placerville Rd, Sacramento CA 95827 · APN 077-0050-068-0000
Prepared for Thomas Roman, Architect, TR-Architecture · Nov 2, 2026
DRAFT for architect review. Not for permit until reviewed and stamped.

P1-1