AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE	PAGE	OF	PAGES
	1		2

2. AMENDMENT/MODIFICATION NUMBER	3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQUISITION NUMBER	5. PROJECT NUMBER *(If applicable)*
0002	08/05/2026	15BH0N26PR000083	26Z6AU1

6. ISSUED BY — CODE: BFAO

Federal Bureau of Prisons
Field Acquisition Office
U.S. Armed Forces Reserve Complex
346 Marine Forces Drive
Grand Prairie, TX 75051

Julie Bergami
(O) 202-598-6019
jbergami@bop.gov

7. ADMINISTERED BY *(If other than Item 6)* — CODE: 15BH0N

Federal Bureau of Prisons
FDC Honolulu
351 Elliott Street
Honolulu, HI 96819

8. NAME AND ADDRESS OF CONTRACTOR *(Number, street, country, state and ZIP Code)*

CODE | FACILITY CODE

(X)

X

9A. AMENDMENT OF SOLICITATION NUMBER: 15BBNF26B60300001

9B. DATED *(SEE ITEM 11)*: 07/01/2026

10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED *(SEE ITEM 13)*

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [ ] is extended, [X] is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning __1__ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NUMBER AS DESCRIBED IN ITEM 14.

CHECK ONE	
	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: *(Specify authority)* THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NUMBER IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES *(such as changes in paying office, appropriation date, etc.)* SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER *(Specify type of modification and authority)*

E. IMPORTANT: Contractor [ ] is not, [ ] is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION *(Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

Amendment 0002 is hereby issued to incorporate the following into Invitation for Bids 15BBNF26B60300001:

1) Incorporate Bidder's Question with FBOP Response (see attached).

End of Amendment 0002

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER *(Type or print)*		16A. NAME AND TITLE OF CONTRACTING OFFICER *(Type or print)*	
		Julie Bergami Contracting Officer	
15B. CONTRACTOR/OFFEROR *(Signature of person authorized to sign)*	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA By *(Signature of Contracting Officer)*	16C. DATE SIGNED

FDC HONOLULU – UPGRADE FIRE DETECTION SYSTEM
PROJECT 26Z6AU1 QUESTIONS & ANSWERS
SOLICITATION 15BBNF26B60300001

SUBMITTED BY AMERICAN ALARM CO.:

36. The List of Bidder's Qualifications ask for certification of the qualified design professional (NICET Level III minimum or Licensed Professional Engineer) who will provide the sealed and signed shop drawings. Under Hawaii laws governing professional engineering (HRS Chapter 464 and HAR Chapter 16-115), fire protection systems that form part of commercial or public building permit packages must be submitted by a licensed design professional (PE). While NICET III or IV certifications qualify technicians for planning, layout, and installing systems under national standards, a NICET credential does not grant legal authority to stamp or seal engineering design documents for building permits in Hawaii.

    Please confirm that no building permit is required for this project and that project drawings will not have to be peer reviewed or stamped by a licensed design professional (PE).
    Clarification: This project will not require to seek a building permit through the State of Hawaii or the through the city of Honolulu. The project will require stamped engineering drawing from a licensed Professional Engineer (PE) as stated in the specifications section 01 10 00-1.4.A.1.a, and section 01 40 00-1.4. Further directions on design requirements can be found in section 23 09 23.12. The design submittal will be reviewed and approved by the Engineer of Record and the BOP AHJ.