



Laporan Compliance Fasilitas

Periode: Juni 2026 · Dibuat: 25 Juni 2026

PT Aplikanusa Lintasarta
Facility Management Service Platform
Dibuat oleh: System SuperAdmin



Ringkasan KPI Portofolio

67% Compliance Rate	12 Total Aset	2 Dokumen Expired	1 WO Open
Rp 227.550.000.000 Nilai Portofolio	8 Dokumen Valid	2 Dokumen Warning	1 PM Overdue



Dokumen Akan/Sudah Expired (30 hari ke depan)

Dokumen	Aset	Jatuh Tempo	Sisa Hari	Status
Polis Asuransi Kebakaran Kantor Medan	Kantor Regional FMS Medan	13 Juli 2026	18 hari	WARNING
Pajak Kendaraan Tahunan (PKB) Hilux B 9102 SQA	Toyota Hilux Operasional DC	15 Juli 2026	20 hari	WARNING



Ringkasan Aset

Nama Aset	Tipe	Lokasi	Status	Nilai Buku	Dok.
AC Precision Server Room Medan	facility	Server Room Lt. 1, Kantor Medan	good	Rp 320.000.000	0
Gedung Technopark Lintasarta Jatiluhur	office	Jatiluhur, Purwakarta — Regional Bandung	good	Rp 125.000.000.000	3
Genset Caterpillar 1500 kVA (Backup A)	facility	Power Station Room, Jatiluhur — Regional Bandung	warning	Rp 2.400.000.000	1 (1 expired)
Genset Perkins 500 kVA Surabaya	facility	Ruang Genset, Kantor Surabaya	good	Rp 650.000.000	0
Kantor Regional FMS Bandung	office	Jl. Braga No. 45, Bandung	good	Rp 18.000.000.000	2
Kantor Regional FMS Medan	office	Jl. Gatot Subroto No. 212, Medan	good	Rp 12.000.000.000	2
Kantor Regional FMS Surabaya	office	Jl. Basuki Rahmat No. 88, Surabaya	good	Rp 22.000.000.000	2
Menara Thamrin Lt. 9 — Kantor Pusat Lintasarta	office	Menara Thamrin Lt. 9, Jakarta Pusat	good	Rp 45.000.000.000	0
PoP Shelter Medan Amplas	facility	Jl. Sisingamangaraja, Medan Amplas, Medan	good	Rp 800.000.000	0
Precision AC AHU-DC01 (Lantai 1)	facility	Data Center Room A, Jatiluhur — Regional Bandung	good	Rp 750.000.000	0

Toyota Avanza Operasional Surabaya	vehicle	Pool Kendaraan, Kantor Surabaya	good	Rp 180.000.000	1 (1 expired)
Toyota Hilux Operasional DC	vehicle	Pool Kendaraan, Jakarta Pusat	good	Rp 450.000.000	1

 Work Order Open

No. Tiket	Judul	Aset	Prioritas	SLA Deadline
WO-2026-0001	AC Presisi Data Hall 1 Jatiluhur Overheat	Precision AC AHU-DC01 (Lantai 1)	critical	25 Juni 2026