

Record of Water Well

Indiana Department of Natural Resources

Reference Number 987	Driving directions to well EXIT ON TO 10TH ST FROM I 465 AND GO W ON 10TH ST TO COUNTRY CLUB RD, TURN N ON COUNTRY CLUB RD AND GO TO 2626			Date completed Mar 09, 1992
Owner-Contractor	Name	Address	Telephone	
Owner	TOM LINKS	2626 COUNTRY CLUB RD	(000) 291-0632	
Driller	HARNESS BROS	2494 W 350 S DANVILLE IN	(000) 539-6848	
Operator	DESTER HARNESS	License: 137		
Construction Details				
Well	Use: Home	Drilling method: Rotary	Pump type: Submersible	
	Depth: 135.0	Pump setting depth: 100.0	Water quality: CLEAR	
Casing	Length: 131.0	Material: PVC	Diameter: 4.0	
Screen	Length: 4.0	Material: PVC	Diameter: 4.0 Slot size: 40	
Well Capacity Test	Type of test: Air	Test rate: 10.0 gpm for 1.0 hrs.	Bail Test rate: gpm for hrs.	
	Drawdown: 10.0 ft.	Static water level: 60.0 ft.	Bailer Drawdown: ft.	
Grouting Information	Material: BENT		Depth: from 3.0 to 120.0	
	Installation Method: PUMP		Number of bags used: 8.0	
Well Abandonment	Sealing material:		Depth: from to	
	Installation Method:		Number of bags used:	
Administrative	County: MARION		Township: 16N Range: 2E	
	Section: NW of the SW of the NW of Section 27		Topo map: CLERMONT	
	Grant Number:			
	Field located by:		on:	
	Courthouse location by:		on:	
	Location accepted w/o verification by:		on:	
	Subdivision name:		Lot number:	
	Ft W of EL:	Ft N of SL:	Ft E of WL:	Ft S of NL:
	Ground elevation:	Depth to bedrock:	Bedrock elevation:	Aquifer elevation:
	UTM Easting:		UTM Northing:	
Well Log	Top	Bottom	Formation	
	1.0	60.0	CLAY GRAY	
	60.0	130.0	CLAY BLUE	
	130.0	135.0	GRAVEL	
Comments	SKETCH MAP			