

Record of Water Well

Indiana Department of Natural Resources

Reference Number 5	Driving directions to well PETTY RD TO RANGELINE RD(300W) AT LANTERN PARK ADDN. LOT 60		Date completed May 22, 1964
Owner-Contractor Driller Operator Company	Name WILBER REYNARD WILBER REYNARD JOE ALLARDT	Address ALBANY IN License: null E WASHINGTON MUNCIE IN	Telephone
Construction Details Well Casing Screen	Use: Home Depth: 60.0 Length: 35.0 Length:	Drilling method: Cable Tool Pump setting depth: Material: Material:	Pump type: Water quality: Diameter: 4.0 Diameter: Slot size:
Well Capacity Test	Type of test: Pumping Drawdown: 0.0 ft.	Test rate: 15.0 gpm for 0.5 hrs. Static water level: 18.0 ft.	BailTest rate: gpm for hrs. Bailer Drawdown ft.
Grouting Information	Material: Installation Method:	Depth: from to Number of bags used:	
Well Abandonment	Sealing material: Installation Method:	Depth: from to Number of bags used:	
Administrative	County: DELAWARE Section: SW of the NE of the SE of Section 1 Grant Number: Field located by: Courthouse location by: Location accepted w/o verification by: Subdivision name: LANTERN PARK ADDN. Ft W of EL: 1300.0 Ft N of SL: 1400.0 Ground elevation: 940.0 Depth to bedrock: 35.0 UTM Easting: 632160.0		Township: 20N Range: 9E Topo map: MUNCIE WEST on: on: on: Lot number: 60 Ft E of WL: Ft S of NL: Bedrock elevation: 905.0 Aquifer elevation: UTM Northing: 4452160.0
Well Log	Top 0.0 25.0 30.0 35.0	Bottom 25.0 30.0 35.0 60.0	Formation HARD PAN SAND & GRAVEL RED MUD LIMESTONE
Comments			