

Record of Water Well

Indiana Department of Natural Resources

Reference Number 2	Driving directions to well PETTY RD FROM MUNCIE TO RANGELINE RD(300W); LANTERN PARK ADDN. LOT 58			Date completed Apr 15, 1964
Owner-Contractor Driller Operator Company	Name WILBER REYNARD WILBER REYNARD JOE ALLARDT	Address ALBANY IN License: null E MAIN ST MUNCIE IN	Telephone	
Construction Details Well Casing Screen	Use: Home Depth: 55.0 Length: 40.0 Length:	Drilling method: Cable Tool Pump setting depth: Material: Material:	Pump type: Water quality: Diameter: 4.0 Diameter: Slot size:	
Well Capacity Test	Type of test: Pumping Drawdown: 0.0 ft.	Test rate: 15.0 gpm for 1.0 hrs. Static water level: 18.0 ft.	Bail Test rate: gpm for hrs. Bailer Drawdown ft.	
Grouting Information	Material: Installation Method:	Depth: from to Number of bags used:		
Well Abandonment	Sealing material: Installation Method:	Depth: from to Number of bags used:		
Administrative	County: DELAWARE Section: NE of the SE of Section 1 Grant Number: Field located by: Courthouse location by: Location accepted w/o verification by: Subdivision name: LANTERN PARK ADDN. Ft W of EL: Ground elevation: UTM Easting:		Township: 20N Range: 9E Topo map: MUNCIE WEST on: on: on: Lot number: 58 Ft E of WL: Bedrock elevation: UTM Northing:	
Well Log	Top	Bottom	Formation	
	0.0	25.0	HARD PAN	
	25.0	30.0	SAND & GRAVEL	
	30.0	40.0	RED MUD	
	40.0	55.0	LIMESTONE	
Comments				