

Record of Water Well

Indiana Department of Natural Resources

Reference Number 3454	Driving directions to well TAKE 325E SOUTH OFF SR 2 APPROX 1.5 MILES TO WASHINGTON SQUARE SUBDIV, TURN E 1 BLOCK, S 1 BLOCK, EAST TO END OF CUL-DE-SAC, SE CORNER		Date completed Oct 14, 1991
Owner-Contractor	Name	Address	Telephone
Owner	SPEC	350 ARLINGTON COURT, VALPARAISO, IN	
Driller	JOHNSON WELL DRILLING	1303 ROBIN ROAD, VALPARAISO, IN	(219) 462-5548
Operator	BUD JOHNSON	License: 312	
Company	BIRKY CONSTRUCTION	634 SOUTH BAUMS BRIDGE ROAD, KOUTS, IN	
Construction Details			
Well	Use: Home	Drilling method: Rotary	Pump type: Submersible
	Depth: 65.0	Pump setting depth:	Water quality: CLEAR
Casing	Length: 60.0	Material: PVC	Diameter: 4.0
Screen	Length: 5.0	Material: PVC	Diameter: 3.0 Slot size: 10
Well Capacity Test	Type of test: Pumping	Test rate: 20.0 gpm for 0.5 hrs.	Bail Test rate: gpm for hrs.
	Drawdown: ft.	Static water level: 18.0 ft.	Bailer Drawdown: ft.
Grouting Information	Material: VOLCLAY		Depth: from 50.0 to 20.0
	Installation Method: TREMIE PUMPED		Number of bags used: 2.0
Well Abandonment	Sealing material:		Depth: from to
	Installation Method:		Number of bags used:
Administrative	County: PORTER		Township: 35N Range: 5W
	Section: NW of the SW of the NE of Section 28		Topo map: WANATAH
	Grant Number:		
	Field located by: J FREY		on: Nov 01, 1994
	Courthouse location by:		on:
	Location accepted w/o verification by:		on:
	Subdivision name: WASHINGTON SQUARE		Lot number:
	Ft W of EL: 2450.0	Ft N of SL:	Ft E of WL: Ft S of NL: 1525.0
	Ground elevation: 782.0	Depth to bedrock:	Bedrock elevation: Aquifer elevation: 717.0
	UTM Easting: 500138.0		UTM Northing: 4589519.0
Well Log	Top	Bottom	Formation
	0.0	10.0	YELLOW CLAY
	10.0	40.0	YELLOW SAND
	40.0	50.0	GRAY SAND & GRAVEL
	50.0	65.0	GRAY SAND
Comments			