

Record of Water Well

Indiana Department of Natural Resources

Reference Number 44	Driving directions to well NORTH OF JACKSON ST. ON ELLIOT RD., WESTLAWN PARK, LOT 75		Date completed May 01, 1967	
Owner-Contractor	Name	Address	Telephone	
Owner	KEY REALTY CO.	706 W MCGALLIARD MUNCIE IN		
Driller	VERBA DOUGHTY	R1 YORKTOWN IN		
Operator	VERBA DOUGHTY	License: null		
Company	KEY REALTY	706 W MCGALLIARD MUNCIE IN		
Construction Details				
Well	Use: Home	Drilling method: Cable Tool	Pump type:	
	Depth: 135.0	Pump setting depth:	Water quality:	
Casing	Length: 135.0	Material:	Diameter: 4.5	
Screen	Length:	Material:	Diameter: Slot size:	
Well Capacity Test	Type of test: Bail / Pump	Test rate: 12.0 gpm for 8.0 hrs.	Bail Test rate: 12.0 gpm for 0.5 hrs.	
	Drawdown: 10.0 ft.	Static water level: 40.0 ft.	Bailer Drawdown: 10.0 ft.	
Grouting Information	Material:	Depth: from to		
	Installation Method:	Number of bags used:		
Well Abandonment	Sealing material:	Depth: from to		
	Installation Method:	Number of bags used:		
Administrative	County: DELAWARE		Township: 20N Range: 9E	
	Section: NW of Section 2		Topo map: MUNCIE WEST	
	Grant Number:			
	Field located by: MJH		on:	
	Courthouse location by:		on:	
	Location accepted w/o verification by:		on:	
	Subdivision name: WESTLAWN PARK ADDN.		Lot number: 75	
	Ft W of EL:	Ft N of SL:	Ft E of WL:	Ft S of NL:
	Ground elevation:	Depth to bedrock:	Bedrock elevation:	Aquifer elevation:
	UTM Easting:		UTM Northing:	
Well Log	Top	Bottom	Formation	
	0.0	3.0	SOIL	
	3.0	20.0	RED CLAY	
	20.0	35.0	SAND	
	35.0	75.0	GRAY MUD	
	75.0	95.0	GRAY SAND	
	95.0	110.0	RED MUD	
	110.0	130.0	SAND	
	130.0	135.0	GRAVEL	
Comments				