

Record of Water Well

Indiana Department of Natural Resources

Reference Number 3458		Driving directions to well BRANCHVILLE 5 MI S OF I 64 & 2 MI OFF HWY 37, GO INTO BRANCHVILLE, 1 MI S OF TOWN LOOK FOR GRAVEL RD, CROSS BRIDGE GOES TO RT, 1ST HOUSE ON LF		Date completed Jan 16, 1992	
Owner-Contractor Name		Address		Telephone	
Owner	GOLDMAN FARM, MATENIA GOLDMAN	STAR ROUTE 65 BRANCHVILLE IN	(812) 843-5512		
Driller	RICHARDVILLE DRILLING CO INC	9000 MARX RD EVANSVILLE IN	(812) 985-5251		
Operator	GARY RICHARDVILLE	License: 413			
Construction Details					
Well	Use: Home	Drilling method: Rotary	Pump type: Submersible		
	Depth: 70.0	Pump setting depth: 60.0	Water quality: CLEAR		
Casing	Length: 34.0	Material: PVC	Diameter: 6.0		
Screen	Length: 40.0	Material: PVC LINER	Diameter: 4.5 Slot size:		
Well Capacity Test		Type of test: Air	Test rate: 7.5 gpm for 1.0 hrs.	Bail Test rate: gpm for hrs.	
		Drawdown: ft.	Static water level: 30.0 ft.	Bailer Drawdown: ft.	
Grouting Information		Material: BNSL		Depth: from 0.0 to 34.0	
		Installation Method: PUMP		Number of bags used: 2.0	
Well Abandonment		Sealing material:		Depth: from to	
		Installation Method:		Number of bags used:	
Administrative		County: PERRY		Township: 4S Range: 2W	
		Section: SE of Section 24		Topo map: BRANCHVILLE	
		Grant Number:			
		Field located by:		on:	
		Courthouse location by:		on:	
		Location accepted w/o verification by:		on:	
		Subdivision name:		Lot number:	
		Ft W of EL:	Ft N of SL:	Ft E of WL:	Ft S of NL:
		Ground elevation:	Depth to bedrock:	Bedrock elevation:	Aquifer elevation:
		UTM Easting:	UTM Northing:		
Well Log		Top	Bottom	Formation	
		0.0	5.0	CLAY	
		5.0	7.0	HARD SANDY SHALE	
		7.0	11.0	SANDY LIME	
		11.0	33.0	SOFT DARK SHALE	
		33.0	70.0	LIME HARD, BROKEN STREAKS	
Comments					