## Record of Water Well

## Indiana Department of Natural Resources

Reference Number	Driving directions to well				Date completed	
480	EVAN PARK ADDN. ON CORNBREAD RD. (450W & 150S)				Mar 08, 1962	
Owner-Contractor	Name	Address		Telephone		
Driller	GEORGE SKINNER	R2 YORKTO				
Operator	GEORGE SKINNER	License: nu				
Company	HUGO COOK	R4 SPRUCE	E ST MUNCIE IN			
Construction Details						
Well	Use: Home	<b>Drilling method:</b> Cable Tool		Pump type:		
	<b>Depth:</b> 64.0	Pump setting depth:		Water quality:		
Casing	Length: 64.0	Material:		Diameter: 4.0		
Screen	Length:	Materi	al:	Diameter: Sl	Diameter: Slot size:	
Well Capacity Test	Type of test: Pumping	Test rate: 10.0 gpm for		BailTest rate: gpm for hrs.		
	Drawdown: 12.0 ft.	Static water level: 11.0 ft.		Bailer Drawdown ft.		
Grouting Information	Material: Depth: from to					
	•			mber of bags used:		
Well Abandonment	Sealing material: Depth:			pth: from to		
	Installation Method: Num			mber of bags used:		
Administrative	County: DELAWARE			Township: 20N Range	<b>e:</b> 9E	
	Section: SW of the NE of Section 23				Topo map: MUNCIE WEST	
	Grant Number:					
	Field located by: RZB			on: Jul 17, 1962		
	Courthouse location by:			on:		
	Location accepted w/o verification by:			on:		
	Subdivision name: EVAN PARK ADDN.			Lot number:		
	Ft W of EL:		Ft N of SL:	Ft E of WL:	Ft S of NL:	
	Ground elevation: 935.0		Depth to bedrock:	Bedrock elevation:	Aquifer elevation: 871.0	
	UTM Easting:			UTM Northing:	7.44	
Well Log	Тор	Bottom	Formation			
	0.0	8.0	CLAY			
	8.0	28.0	MUDDY GRAVEL			
	28.0	57.0	QUICK SAND			
			· ·			
Comments	57.0	64.0	COURSE SAND & 0	GRA VEL		