Record of Water Well

Indiana Department of Natural Resources

Reference Number Driving directions to well Date completed 464 WEST MUNCIE 500W(ANDREWS RD) & 126S Jul 09, 1963

Owner-Contractor Name Address Telephone

R2 YORKTOWN IN Driller GEORGE SKINNER Operator GEORGE SKINNER License: null

MARSHAL SISK CONTR. R7 BREWINGTON WOODS MUNCIE IN Company

Construction Details

Drilling method: Cable Tool Well Use: Home Pump type: **Depth:** 70.0 Pump setting depth: Water quality: Casing Length: 25.0 Material: Diameter: 4.0

Diameter: Slot size: Length: Material: Screen

Well Capacity Test Type of test: Pumping Test rate: 10.0 gpm for 3.0 hrs. BailTest rate: gpm for hrs.

Drawdown: 2.0 ft. Static water level: 15.0 ft. Bailer Drawdown ft.

Grouting Information Material: Depth: from to

Installation Method: Number of bags used:

Well Abandonment Sealing material: Depth: from to

Installation Method: Number of bags used:

Administrative County: DELAWARE Township: 20N Range: 9E

> Topo map: MUNCIE WEST Section: of Section 22

Grant Number:

Field located by: on: Courthouse location by: on: Location accepted w/o verification by: on:

Subdivision name: Lot number:

Ft W of EL: Ft N of SL: Ft E of WL: Ft S of NL: Ground elevation: Depth to bedrock: Bedrock elevation: Aquifer elevation:

UTM Easting: UTM Northing:

Top Bottom Formation Well Log

> 0.0 24.0 CLAY 24.0 25.0 SHALE STONE 70.0 LIMESTONE 25.0

PROC BY WLS 10/63 Comments