

Record of Water Well

Indiana Department of Natural Resources

Reference Number 480	Driving directions to well EVAN PARK ADDN. ON CORNBREAD RD. (450W & 150S)		Date completed Mar 08, 1962	
Owner-Contractor Driller Operator Company	Name GEORGE SKINNER GEORGE SKINNER HUGO COOK	Address R2 YORKTOWN IN License: null R4 SPRUCE ST MUNCIE IN	Telephone	
Construction Details Well Casing Screen	Use: Home Depth: 64.0 Length: 64.0 Length:	Drilling method: Cable Tool Pump setting depth: Material: Material:	Pump type: Water quality: Diameter: 4.0 Diameter: Slot size:	
Well Capacity Test	Type of test: Pumping Drawdown: 12.0 ft.	Test rate: 10.0 gpm for 2.0 hrs. Static water level: 11.0 ft.	Bail Test rate: gpm for hrs. Bailer Drawdown ft.	
Grouting Information	Material: Installation Method:	Depth: from to Number of bags used:		
Well Abandonment	Sealing material: Installation Method:	Depth: from to Number of bags used:		
Administrative	County: DELAWARE Section: SW of the NE of Section 23 Grant Number: Field located by: RZB Courthouse location by: Location accepted w/o verification by: Subdivision name: EVAN PARK ADDN. Ft W of EL: Ground elevation: 935.0 UTM Easting:		Township: 20N Range: 9E Topo map: MUNCIE WEST on: Jul 17, 1962 on: on: Lot number: Ft E of WL: Bedrock elevation: UTM Northing:	
Well Log	Top	Bottom	Formation	
	0.0	8.0	CLAY	
	8.0	28.0	MUDDY GRAVEL	
	28.0	57.0	QUICK SAND	
	57.0	64.0	COURSE SAND & GRAVEL	
Comments				