

Test Report

Page 1 of 3

Client: Scientific Sanitation Solutions Pty Ltd
Address: 323 Lynnwood Road, Menlo Park, 0047
Report no: 170022
Project: Water Purification

Date of report: 30 November 2023
Date accepted: 20 November 2023
Date completed: 30 November 2023
Date received: 20 November 2023

Lab no:				4221	4222	4223	4224
Date sampled:				16-Nov-23	17-Nov-23	17-Nov-23	17-Nov-23
Aquatico sampled:				No	No	No	No
Sample type:				Water	Water	Water	Water
Locality description:				Raw water- Before	SA-After 30min	SA-After 2hours	SA-After 24 hours
Analyses		Unit	Method				
A	AQL pH @ 25°C	pH	ALM 20	7.32	6.91	6.91	7.24
A	AQL Electrical conductivity (EC) @ 25°C	mS/m	ALM 20	44.2	70.5	72.2	70.8
A	AQL Total Dissolved solids @ 180°C	mg/l	ALM 24	248	470	480	474
A	AQL Total Alkalinity	mg CaCO ₃ /l	ALM 01	130	177	174	167
A	AQL Chloride (Cl)	mg/l	ALM 02	30.1	30.5	29.5	29.9
A	AQL Sulphate (SO ₄)	mg/l	ALM 03	37.0	115	115	119
A	AQL Nitrate (NO ₃) as N	mg/l	ALM 06	0.299	1.35	1.36	1.42
A	AQL Total oxidised nitrogen as N	mg/l	ALM 06	1.94	1.38	1.38	1.44
A	AQL Nitrite (NO ₂) as N	mg/l	ALM 07	1.64	<0.065	<0.065	<0.065
A	AQL Ammonium (NH ₄) as N	mg/l	ALM 05	3.64	4.66	4.59	4.63
N	AQL Un-ionized Ammonia as N	mg/l	ALM 26	0.046	0.023	0.023	0.049
A	AQL Fluoride (F)	mg/l	ALM 08	0.359	<0.263	0.342	0.376
A	AQL Acid Soluble Calcium (Ca)	mg/l	ALM 30	30.8	30.4	30.7	30.5
A	AQL Acid Soluble Magnesium (Mg)	mg/l	ALM 30	11.3	12.0	12.0	12.1
A	AQL Acid Soluble Sodium (Na)	mg/l	ALM 30	30.9	48.5	52.5	45.1
A	AQL Acid Soluble Potassium (K)	mg/l	ALM 30	6.65	50.4	51.4	54.2
A	AQL Acid Soluble Aluminium (Al)	mg/l	ALM 31	0.016	0.210	0.256	0.216
A	AQL Acid Soluble Iron (Fe)	mg/l	ALM 31	<0.004	<0.004	<0.004	<0.004
A	AQL Acid Soluble Manganese (Mn)	mg/l	ALM 31	0.041	0.023	0.002	<0.001
A	AQL Acid Soluble Chromium (Cr)	mg/l	ALM 31	<0.003	<0.003	<0.003	<0.003
A	AQL Acid Soluble Copper (Cu)	mg/l	ALM 31	0.015	0.013	0.015	0.021
A	AQL Acid Soluble Nickel (Ni)	mg/l	ALM 31	<0.002	<0.002	<0.002	<0.002
A	AQL Acid Soluble Zinc (Zn)	mg/l	ALM 31	<0.002	<0.002	<0.002	<0.002
A	AQL Acid Soluble Cadmium (Cd)	mg/l	ALM 31	<0.002	<0.002	<0.002	<0.002
A	AQL Acid Soluble Lead (Pb)	mg/l	ALM 31	<0.004	<0.004	<0.004	<0.004

A = Accredited N = Non accredited Sub = Sub-contracted NR = Not requested RTF = Results to follow NATD = Not able to determine ATR = Alternative test report ; Results relate only to the items received and tested ; Results reported against the limit of detection; Results marked 'Non SANAS Accredited' in this report are not included in the SANAS Schedule of Accreditation for this laboratory; Uncertainty of measurement available on request for all methods included in the SANAS Schedule of Accreditation; The report shall not be reproduced except in full without approval of the laboratory

M. Swanepoel
 Technical Signatory

Test Report

Page 2 of 3

Client: Scientific Sanitation Solutions Pty Ltd
Address: 323 Lynnwood Road, Menlo Park, 0047
Report no: 170022
Project: Water Purification

Date of report: 30 November 2023
Date accepted: 20 November 2023
Date completed: 30 November 2023
Date received: 20 November 2023

Lab no:				4221	4222	4223	4224
Date sampled:				16-Nov-23	17-Nov-23	17-Nov-23	17-Nov-23
Aquatico sampled:				No	No	No	No
Sample type:				Water	Water	Water	Water
Locality description:				Raw water- Before	SA-After 30min	SA-After 2hours	SA-After 24 hours
Analyses		Unit	Method				
A	AQL E.coli	CFU/100ml	ALM 40	700	<1	<1	<1
A	AQL Total coliform	CFU/100ml	ALM 40	2800	<1	<1	<1
A	AQL Heterotrophic plate count	CFU/ml	ALM 43	39500	<1	<1	5
A	AQL Turbidity	NTU	ALM 21	20.4	2.29	0.982	0.953
A	AQL Total hardness	mg CaCO ₃ /l	ALM 26	123	125	126	126
A	AQL Free chlorine (Cl ₂)	mg/l	ALM 23	0.07	0.93	1.16	0.67
A	AQL True Colour	mg/l Pt-Co	ALM 22	21.0	<5.00	5.00	5.00
A	AQL Total Cyanide (CN)	mg/l	ALM 16	<0.005	<0.005	<0.005	<0.005
N	AQL Phenol	mg/l	ALM 71	<0.01	<0.01	<0.01	<0.01
A	AQL Total organic carbon (TOC)	mg/l	ALM 63	6.55	7.39	7.80	8.53
A	AQL Acid Soluble Arsenic (As)	mg/l	ALM 34	<0.006	<0.006	<0.006	<0.006
A	AQL Acid Soluble Selenium (Se)	mg/l	ALM 34	<0.002	<0.002	<0.002	<0.002
A	AQL Acid Soluble Mercury (Hg)	mg/l	ALM 34	<0.005	<0.005	<0.005	<0.005
A	AQL Acid Soluble Boron (B)	mg/l	ALM 33	<0.013	<0.013	<0.013	<0.013
A	AQL Acid Soluble Barium (Ba)	mg/l	ALM 33	0.029	0.015	0.014	0.020
A	AQL Acid Soluble Uranium (U)	mg/l	ALM 37	<0.015	<0.015	<0.015	<0.015
A	AQL Langelier Saturation Index	LSI	ALM 26	-0.98	-1.29	-1.30	-0.98
A	AQL Acid Soluble Antimony (Sb)	mg/l	ALM 36	<0.001	<0.001	<0.001	<0.001
N	AQL Temperature	°C	ALM 20	25.9	26.0	26.0	26.2
A	AQL Trihalomethanes (THM)	µg/l	OLM 02	<2	<2	<2	<2
A	AQL Bromoform	µg/l	OLM 02	<2	<2	<2	<2
A	AQL Chloroform	µg/l	OLM 02	<2	<2	<2	<2
A	AQL Dibromochloromethane	µg/l	OLM 02	<2	<2	<2	<2
A	AQL Bromodichloromethane	µg/l	OLM 02	<2	<2	<2	<2
A	AQL Combined Bromoform	ratio	OLM 02	<0.020	<0.020	<0.020	<0.020

A = Accredited N = Non accredited Sub = Sub-contracted NR = Not requested RTF = Results to follow NATD = Not able to determine ATR = Alternative test report ; Results relate only to the items received and tested ; Results reported against the limit of detection; Results marked 'Non SANAS Accredited' in this report are not included in the SANAS Schedule of Accreditation for this laboratory; Uncertainty of measurement available on request for all methods included in the SANAS Schedule of Accreditation; The report shall not be reproduced except in full without approval of the laboratory

Authenticated signature on first page

Test Report

Page 3 of 3

Client: Scientific Sanitation Solutions Pty Ltd
Address: 323 Lynnwood Road, Menlo Park, 0047
Report no: 170022
Project: Water Purification

Date of report: 30 November 2023
Date accepted: 20 November 2023
Date completed: 30 November 2023
Date received: 20 November 2023

Lab no:					4221	4222	4223	4224
Date sampled:					16-Nov-23	17-Nov-23	17-Nov-23	17-Nov-23
Aquatico sampled:					No	No	No	No
Sample type:					Water	Water	Water	Water
Locality description:					Raw water- Before	SA-After 30min	SA-After 2hours	SA-After 24 hours
Analyses					Unit	Method		
A	AQL	Combined Chloroform	ratio	OLM 02	<0.007	<0.007	<0.007	<0.007
A	AQL	Combined Dibromochloromethane	ratio	OLM 02	<0.020	<0.020	<0.020	<0.020
A	AQL	Combined Bromodichloromethane	ratio	OLM 02	<0.033	<0.033	<0.033	<0.033
A	AQL	THM Sum of rations	ratio	OLM 02	<0.080	<0.080	<0.080	<0.080
N	AQL	Monochloramine	mg/l	ALM 67	0.11	4.69	4.75	4.61
N	AQL	Microcystin	µg/l	ALM 68	<0.5	<0.5	<0.5	<0.5
N	AQL	Combined Nitrate plus Nitrite	ratio	ALM 26	1.85	<1.00	<1.00	<1.00

A = Accredited N = Non accredited Sub = Sub-contracted NR = Not requested RTF = Results to follow NATD = Not able to determine ATR = Alternative test report ; Results relate only to the items received and tested ; Results reported against the limit of detection; Results marked 'Non SANAS Accredited' in this report are not included in the SANAS Schedule of Accreditation for this laboratory; Uncertainty of measurement available on request for all methods included in the SANAS Schedule of Accreditation; The report shall not be reproduced except in full without approval of the laboratory

Authenticated signature on first page