

TEST REPORT

Water

Simlab (Pty) Ltd

Attn: Mare Benadie

P.O.Box 1231
Kimberley
8301
+27633246914



@VinlabSA

Sample Details

SampleID	W56053	W56054			
Water Type	Drinking Water	Drinking Water			
Water Source	Not Indicated	Not Indicated			
Sample Temperature					
Description	14790 - Before	14791 - After			
Batch Number					
PO Number	SSS(3/10/24)	SSS(3/10/24)			
Date Received	2024-10-07	2024-10-07			
Condition	Good	Good			

Water - Micro

	Unit	Method	Uncertainty	Limits	Results	Results	Results	Results	Results
Total Coliforms (Water)	cfu/100mL	VIN-05-MW09		<= 10	57	nd			
E-Coli (Water)	cfu/100mL	VIN-05-MW09		not detected	3	nd			
Date Tested					2024-10-07	2024-10-07			

Adelize Fourie

Adelize Fourie
Laboratory Manager (Waterlab)

VIN-05-
M01, M02, M03, M04, M05, M08, M10, M28,
M43, MW01, MW02, MW03, MW04,
MW05, MW06, MW07, MW08/9/10,
MW12, MW13, MW14

Please click [here](#) for SANS241-1:2015 drinking water limits

Test results relate only to the items tested as received. This Document shall not be reproduced without the written approval of Vinlab (Pty) Ltd. Opinions and interpretations expressed herein are outside the scope of SANAS accreditation. Results for methods VIN-05-MW12, 13 and 14, are based on Cq values, a positive result (detected) indicates a Cq value <35 and a negative result (non-detected) indicates a Cq value of >35.

* Not SANAS Accredited. Results marked "Not SANAS Accredited" in this report are not included in the SANAS Scope of Accreditation for Vinlab.

Vinlab is not liable to any client for any loss or damages suffered which could, directly or remotely, be linked to our services. Alcohol results are obtained using the most appropriate or a combination of one of the following methods: Py= pycnometer; W=winescan; Al=alcolyzer. W = Winescan. Micro results: Enumeration of yeast: WL nutrient, 3 days unless otherwise specified, 30°C. Samples that have had prior microbiological spoilage or treatment for spoilage should always be sterile filtered at bottling. SO2 additions less than 10 days may depress the growth of microbes in culture although they are viable/active in the wine. Some microbes, especially lactobacilli, may not grow in culture even where viable/potentially active in the wine.

[^] - Conductivity <1000mS/m = ±1mS/m, >1000mS/m = ±9mS/m
^{^^} - COD, LR = ±16mg/L, MR = ±48mg/L, HR = ±477mg/L
^{^^^} - pH ±0.1