

Test Report

Page 1 of 1

Client: Scientific Sanitation Solutions Pty Ltd
Address: 323 Lynnwood Road, Menlo Park, 0047
Report no: 98451
Project: Scientific Sanitation Solutions Pty Ltd

Date of report: 20 January 2021
Date accepted: 17 January 2021
Date completed: 20 January 2021
Date received: 15 January 2021

Lab no:				79466	79467
Date sampled:				15-Jan-21	15-Jan-21
Aquatico sampled:				No	No
Sample type:				Water	Water
Locality description: Analyses				Sani Amanzi Before	Sanie Amanzi After 30 minutes
A	E.coli	CFU/100ml	ALM 40	660	<1
N	Faecal coliform	CFU/100ml	ALM 42	1900	<1
A	Total coliform	CFU/100ml	ALM 40	1900	<1
A	TotalViableCount	CFU/ml	ALM 43	>50000	20

A = Accredited N = Non accredited Out = Outsourced Sub = Sub-contracted NR = Not requested RTF = Results to follow NATD = Not able to determine ATR = Alternative test report ; Results only apply to the samples as received and tested; Results reported against the limit of detection; Results marked 'Non SANAS Accredited' in this report are not included in the SANAS Schedule of Accreditation for this laboratory; Uncertainty of measurement available on request for all methods included in the SANAS Schedule of Accreditation; The report shall not be reproduced except in full without approval of the laboratory
The results apply to the sample received.