



GREEN EARTH ENVIRONMENTAL TESTING LABORATORY

ISO 17025 Certified | Environmental Analysis & Monitoring Services

WATER QUALITY ANALYSIS REPORT

Report Number: GE-2026-0671 **Collection Date:** 15 June 2026
Company Name: ABC Textile Industries Pvt Ltd **Received Date:** 15 June 2026
Sample Type: ETP Outlet Water **Analysis Date:** 16 June 2026

PARAMETER	RESULT	UNIT	STANDARD LIMIT	COMPLIANCE
pH	7.2	-	6.5 - 8.5	Compliant
TDS	420	mg/L	2100	Compliant
COD	260	mg/L	250	Above Limit
BOD	35	mg/L	30	Above Limit
TSS	95	mg/L	100	Compliant
Chloride	180	mg/L	600	Compliant
Sulphate	120	mg/L	1000	Compliant
Oil & Grease	4	mg/L	10	Compliant

Overall Status:

⚠️ **NON-COMPLIANT**

Remarks: The sample exceeds permissible limits for COD and BOD parameters. Corrective actions are recommended to optimize the Effluent Treatment Plant (ETP) process parameters.

Dr. Rajesh Kumar

Chief Environmental Analyst

