

GE

LAB

GREEN EARTH ENVIRONMENTAL TESTING LABORATORY

Plot No. 42, SIDCO Industrial Estate, Guindy, Chennai, Tamil Nadu - 600032

Email: compliance@greenearthlab.in | Web: www.greenearthlab.in

ISO/IEC 17025:2017 CERTIFIED LABORATORY

WATER QUALITY ANALYSIS REPORT

Report Number	: GE-2026-1048	Sample Type	: ETP Outlet Water
Company Name	: ABC Textile Industries Pvt Ltd	Collection Date	: 18 June 2026
Industry Category	: Textile Processing (Red Category)	Analysis Date	: 19 June 2026

S.No	Parameters Analyzed	Unit	Observed Value	TNPCB Limit	Status
1	pH (at 25°C)	-	7.1	6.5 - 8.5	COMPLIANT
2	Total Dissolved Solids (TDS)	mg/L	480	2100	COMPLIANT
3	Chemical Oxygen Demand (COD)	mg/L	240	250	COMPLIANT
4	Biochemical Oxygen Demand (BOD)	mg/L	28	30	COMPLIANT
5	Total Suspended Solids (TSS)	mg/L	92	100	COMPLIANT
6	Chloride (as Cl)	mg/L	170	600	COMPLIANT
7	Sulphate (as SO ₄)	mg/L	110	1000	COMPLIANT
8	Oil & Grease	mg/L	3	10	COMPLIANT

Overall Compliance Status: **COMPLIANT**

Remarks: All analyzed water quality parameters are within TNPCB permissible discharge limits.

Rajesh Kumar

[QR CODE]
VERIFY

Scan to verify report authenticity

OFFICIAL
STAMP
GE-LAB

Dr. Rajesh Kumar

Chief Environmental Analyst
Authorized Signatory

This document serves as an official laboratory analysis report supporting environmental statutory compliance criteria. The parameters listed above are evaluated based on the regulatory standards specified by the Tamil Nadu Pollution Control Board (TNPCB) for inland surface water disposal.