GDAŃSKI UNIWERSYTET MEDYCZNY

MEDICAL UNIVERSITY OF GDAŃSK

ATEST HIGIENICZNY
HYGIENIC CERTIFICATE

atesty higieniczne GUMed

Hygienic certificate number: **AH 94/322/94/2023**

Date of issue: **8 August 2023**

Product:	Self-supporting double skin insulating panels with rigid PIR polyisocyanurate foam core: PIR STANDARD (PU-PIR-W-ST), PIR FROST (PU-PIR-F), PIR PLUS (PU-PIR-W-PLUS), PIR LIGHT, layered roof plate PIR STANDARD (PU-PIR-R)
Intended use:	Material to be used in construction as insulation for walls, roofs and floors of food industry (without direct contact with food) production, sport, office, commercial, service, administration, public utility, agricultural and healthcare (without operating theatres/intensive care units) facilities.
Manufacturer:	Balex Metal sp. z o.o., ul. Wejherowska 12C, 84-239 Bolszewo
The substantive basis for issuing the certificate:	Application (Institution submitting the products for assessment: Balex Metal sp. z o.o., ul. Wejherowska 12C, 84-239 Bolszewo) of 21 March 2023 (no. 322/94/94/2024) with necessary documentation.

According to the currently available knowledge, the assessed product (when used in accordance with the manufacturer's guidelines) should not pose a risk to human health.

Recommendations and comments:

- The product shall be used in accordance with the Manufacturer's recommendations.
- Handling in accordance with information in the Material Safety Data Sheet.
- Rooms in which the above product was used shall be ventilated until smell disappears.
- The label shall be marked in accordance with applicable legislation.
- Handling of post construction waste in accordance with applicable legal provisions.
- The certificate does not refer to occupational health and safety upon product installation.
- In case of use in healthcare facilities the requirements provided for in the regulation of the Minister of Health of 26 March 2019 (Journal of Laws of 2019, item 595 of 29 March 2019) and currently applicable legal regulations shall be taken into account.
- Avoid operation causing dusting from surface.

Hygienic certificate does not include the assessment of the utility values, technical parameters and allergenic properties of the product.

The certificate may be changed or canceled after presenting relevant evidence by either party. This certificate expires after 5 years from the date of its issue or in the case of changes in the recipe or production technology of the product, its intended use and after changes of legal regulations related to the assessed product.

KIEROWNIK
Zakładu Toksykologii Środowiska
Lidia Wolska
prof. dr hab. Lidia Wolska

Kontakt w sprawie atestu higienicznego
ZAKŁAD TOKSYKOLOGII ŚRODOWISKA GUMed
ul. Dębowa 23a, 80-204 Gdańsk

Contact regarding the hygienic certificate
DIVISION OF ENVIRONMENTAL TOXICOLOGY MUG
Dębowa 23a Str., 80-204 Gdańsk, Poland

tel. +48 58 349 19 36 **fax** +48 58 349 19 37 **e-mail** zts-atesty@gumed.edu.pl