A Low-pass Filter Method to Suppress the Voltage Variations Caused by Introducing Droop Control in DC Microgrids

Fulong Li, Zhengyu Lin, Wenping Cao Aston University

Alian Chen
Shandong University

Jiande Wu Zhejiang University

lif12@aston.ac.uk

1. Microgrid Configurations





Fig.1: Single DC Bus microgrid configuration

- Contains:
 - ✓ Distributed sources
 - ✓ Energy storage
 - ✓ DC load/AC load
- Control methods:
 - **-**□ Droop control
 - ☐ DC bus signalling
 - ☐ Master-salve control


Large droop coefficient → bus oscillations


- Exceed the designed margin → instability
- Variations in introduced output current

2. Control blocks of Two Nodes




3. Analysis






- Lack the immunity on frequencies lower than crossover frequency
- ❖ Adding low-pass filter can compensate the unavailability over lower frequencies

4. Simulation Results





- Conclusions:
- 1. Introducing droop control can cause voltage variations
- 2. Larger droop coefficient can cause larger variations
- 3. Low-pass filter on output current path can reduce variations





This project has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 734796.